

Elevator Energy Consumption

Background

This technical topic expands on the **P4P New Construction Program Guidelines v4.1 Section 4.5.18** that describes modeling savings from elevators. Additions and changes to the section are shown in **blue font** below. A similar calculation procedure may be used by P4P Existing Buildings (EB) projects to document savings from elevator replacement, except design parameters of the existing elevators must be used instead of the baseline parameters.

Elevators may account for 4% - 10% of project energy cost, and present significant opportunity for energy savings. The example included in the Technical Topic is based on an actual project, and shows ~35% savings in the proposed elevator energy use compared to the baseline elevator.

There is a companion “**Elevator Energy Consumption Calculator**” spreadsheet that implements the described methodology.

Elevators (from P4P New Construction Program Guidelines v4.1 Section 4.5.18)

Elevators are a regulated load in ASHRAE 90.1-2013 and have mandatory requirements. Performance credit may be claimed for any component that exceeds mandatory or baseline requirements such as fan power, lighting power density, elevator motor efficiency, and elevator mechanical efficiency.

The baseline shall be modeled as follows:

- ≤ 4 stories: hydraulic motor, 58% mechanical efficiency
- > 4 stories: traction motor, 64% mechanical efficiency
- 0.33 W/CFM for ventilation fans
- 3.14 W/SqFt lighting power density
- Cab motor power shall be calculated using the following equations

$$bhp = (Weight\ of\ Car + Rated\ Load - Counterweight) \times Speed\ of\ Car / (33,000 \times h_{mechanical})$$

$$P_m = bhp * 746 / h_{motor}$$

Where:

- *Weight of Car* = proposed design elevator car weight, lb
- *Rated Load* = proposed design elevator load at which to operate, lb
- *Counterweight of Car* = elevator counterweight,
 - *hydraulic elevators*: no counterweight
 - *traction elevators*: same as in proposed design; if not specified, weight of car + 40% of rated load
- *Speed of Car* = speed of the proposed elevator, ft/min
- *P_m* = peak cab motor power
- *h_{mechanical}* = mechanical efficiency of the elevator
- *h_{motor}* = motor efficiency
 - Cab motor efficiency (*h_{motor}*) shall be determined using the following tables

- [Table G3.9.3 for hydraulic baseline elevators](#)
- [Table G3.9.1 for traction baseline elevators](#)

Table G3.9.3 Performance Rating Method Hydraulic Elevator Motor Efficiency

| Horsepower | Full-Load Efficiency |
|------------|----------------------|
| 10 | 72% |
| 20 | 75% |
| 30 | 78% |
| 40 | 78% |
| 100 | 80% |

Table G3.9.1 Performance Rating Method Motor Efficiency Requirements

| Motor Horsepower | Minimum Nominal Full-Load Efficiency, % |
|------------------|---|
| 1.0 | 82.5 |
| 1.5 | 84.0 |
| 2.0 | 84.0 |
| 3.0 | 87.5 |
| 5.0 | 87.5 |
| 7.5 | 89.5 |
| 10.0 | 89.5 |
| 15.0 | 91.0 |
| 20.0 | 91.0 |
| 25.0 | 92.4 |
| 30.0 | 92.4 |
| 40.0 | 93.0 |
| 50.0 | 93.0 |
| 60.0 | 93.6 |
| 75.0 | 94.1 |
| 100.0 | 94.5 |
| 125.0 | 94.5 |
| 150.0 | 95.0 |
| 200.0 | 95.0 |

Elevator full load hours must be calculated as follows:

$$EFLH_{elev} = DH * 365$$

Where:

- $EFLH_{elev}$ – elevator effective full load hours
- DH – average travel time from Table 1 below, based on building type and size, and the elevator application type. Alternative elevator run hours may be considered with prior program approval.

Table 1: Usage Categories

| Usage Intensity/ Frequency | Very Low Very Seldom | Low Seldom | Medium Occasionally | High Frequently | Very High Very Frequently |
|--|--|---|--|---|---|
| Average Travel Time (hours per day) | 0.2 | 0.5 | 1.5 | 3 | 6 |
| Typical Type of Buildings and Use | Residential building with up to 6 dwellings. Small office or administrative building with few operations. | Residential building with up to 20 dwellings. Small Office or Administrative Building with 2 to 5 floors. Small Hotels Goods lift with few operations. | Residential building with up to 50 dwellings. Small office or administrative building with up to 10 floors. Medium Sized Hotels Goods lift with medium operations | Residential building with more than 50 dwellings. Tall office or administrative building with more than 10 floors. Large Hotel Small to Medium Sized Hospitals Good lift in production process with a single shaft. | Office or administration building over 100 meters in height. Large Hospital Goods lift in production process with several shafts. |

Baseline elevator fans shall operate continuously, 24/7.

Baseline elevator lighting shall operate continuously, 24/7.

The proposed design shall be modeled as follows:

Design elevator cab motor power [Watt] must be calculated as follows:

$$P_{m,prop} = bhp_{prop} * 746/h_{motor,prop}$$

Where:

- bhp_{prop} and $H_{motor,prop}$ is the brake horse power and electrical efficiency of the proposed elevator motor. Tables G3.9.3 & G3.9.1 above must be used as applicable if proposed elevator motor efficiency is unavailable.

Design fan and lighting power shall be based on design documents.

The same effective full load hours (EFLH_{elev}) must be modeled for the proposed design as for the baseline.

If elevator cab lighting has occupancy sensor controls, the annual lighting runtime must be equal to EFLH_{elev}.

Elevator usage may be included in the baseline and proposed simulation models in lieu of using the Elevator Energy Consumption Calculator. However, elevators are not expected to interact with other building systems and components, thus either methods should result in the same energy savings.

Example

Proposed design of a 10-floor office building includes 4 passenger elevators (Car 1) and 1 service elevator (Car 2). Parameters of both elevators are shown in Figure 1.

Figure 1: Elevator Calculator - Description of the Proposed Equipment

| Elevator ID | | 1 | 2 |
|-----------------|---|---|--------------------------------|
| Application | Elevator Name | Car 1 | Car 2 |
| | Quantity | 4 | 1 |
| | Passenger or service elevator? | Passenger | Service |
| | Buildings and elevator type | Office or administrative building 6 - 10 floors | Goods lift with few operations |
| | Average Travel Time (hours per day) | 1.5 | 0.5 |
| | Usage Type: Intensity/ Frequency | Medium/ Occasionally | Low/ Seldom |
| | Number of Stories Served (including below grade floors) | 10 | 10 |
| Proposed Design | Counterweight of Car (lbs) (if unknown, leave blank) | | |
| | Weight of Car (lb.) | 8,098 | 8,824 |
| | Rated Load (lb.) | 3,500 | 4,000 |
| | Speed of Car (ft./min) | 1,200 | 1,200 |
| | bhp | 81.94 | 53.43 |
| | Motor efficiency (%) | 94.5% | 93.6% |
| | Cabin Fan Power (Watt) | 90 | 90 |
| | Cabin Airflow (CFM) | 325 | 325 |
| | Cabin Lighting Power (Watt) | 100 | 100 |
| | Cabin Occupancy Sensor Lighting Controls (Y/N) | Yes | Yes |
| | Cab Area (Square Feet) | 56 | 56 |

The total baseline elevator annual electric consumption is calculated as follows:

$$bhp_1 = (8,098 \text{ lbs} + 3,500 \text{ lbs} - (8,098 \text{ lbs} + 0.4 * 3,500 \text{ lbs})) * 1,200 \text{ ft}/\text{min} / (33,000 * 0.64) = 119.3 \text{ bhp}$$

$$P_{m,1} = 119.3 * \frac{746}{0.945} = 94,177 \text{ W} = 94.2 \text{ kW}$$

$$bhp_2 = (8,824 \text{ lbs} + 4,000 \text{ lbs} - (8,824 \text{ lbs} + 0.4 * 4,000 \text{ lbs})) * 1,200 \text{ ft}/\text{min} / (33,000 * 0.64) = 136.4 \text{ bhp}$$

$$P_{m,2} = 136.4 * \frac{746}{0.95} = 107,109 \text{ W} = 107.1 \text{ kW}$$

$$Elevator_{Baseline} \frac{kWh}{yr} = \left(94.2 \text{ kW} * 1.5 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} \right) * 4 + \left(107.1 \text{ kW} * 0.5 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} \right) * 1 = 225,843.8 \text{ kWh}/\text{yr}$$

$$\text{Lighting Load}_1 = 3.14 \frac{W}{sf} * 56 sf * 24 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 4 * \frac{1kW}{1000W} = 6,161.4 \text{ kWh/yr}$$

$$\text{Lighting Load}_2 = 3.14 \frac{W}{sf} * 56 sf * 24 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 1 * \frac{1kW}{1000W} = 1,540.4 \text{ kWh/yr}$$

$$\text{Lighting Load}_{1+2} = 7,701.8 \frac{\text{kWh}}{\text{yr}}$$

$$\text{Ventilation Load}_1 = 0.33 \frac{W}{CFM} * 325 CFM * 24 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 4 * \frac{1kW}{1000W} = 3,758.0 \text{ kWh/yr}$$

$$\text{Ventilation Load}_2 = 0.33 \frac{W}{CFM} * 325 CFM * 24 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 1 * \frac{1kW}{1000W} = 939.5 \text{ kWh/yr}$$

$$\text{Ventilation Load}_{1+2} = 4,697.5 \text{ kWh/yr}$$

$$\text{Total Elevator}_{\text{Baseline}} \frac{\text{kWh}}{\text{yr}} = 225,843.8 \frac{\text{kWh}}{\text{yr}} + 7,701.8 \frac{\text{kWh}}{\text{yr}} + 4,697.5 \frac{\text{kWh}}{\text{yr}} = 238,243.1 \text{ kWh/yr}$$

The total proposed elevator annual electric consumption is calculated as follows:

$$P_{m,1} = 81.94 \text{ HP} * \frac{746}{0.945} = 64,685 \text{ W} = 64.7 \text{ kW}$$

$$P_{m,2} = 53.43 \text{ HP} * \frac{746}{0.936} = 42,584 \text{ W} = 42.6 \text{ kW}$$

$$\begin{aligned} \text{Elevator}_{\text{Design}} \frac{\text{kWh}}{\text{yr}} &= \left(64.7 \text{ kW} * 1.5 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} \right) * 4 + \left(42.6 \text{ kW} * 0.5 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} \right) * 1 \\ &= 149,467.5 \text{ kWh/yr} \end{aligned}$$

$$\text{Lighting Load}_1 = 100 \text{ W} * 1.5 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 4 * \frac{1kW}{1000W} = 219.0 \text{ kWh/yr}$$

$$\text{Lighting Load}_2 = 100 \text{ W} * 0.5 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 1 * \frac{1kW}{1000W} = 18.3 \text{ kWh/yr}$$

$$\text{Lighting Load}_{1+2} = 237.3 \text{ kWh/yr}$$

$$\text{Ventilation Load}_1 = 90 \text{ W} * 24 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 4 * \frac{1kW}{1000W} = 3,153.6 \text{ kWh/yr}$$

$$\text{Ventilation Load}_2 = 90 \text{ W} * 24 \frac{\text{hours}}{\text{day}} * 365 \frac{\text{days}}{\text{year}} * 1 * \frac{1kW}{1000W} = 788.4 \text{ kWh/yr}$$

$$\text{Ventilation Load}_{1+2} = 3,942.0 \text{ kWh/yr}$$

$$\text{Total Elevator}_{\text{Design}} = 149,467.5 \frac{\text{kWh}}{\text{yr}} + 237.3 \frac{\text{kWh}}{\text{yr}} + 3,942.0 \frac{\text{kWh}}{\text{yr}} = 153,646.8 \frac{\text{kWh}}{\text{yr}}$$

The total elevator savings are calculated as follows:

$$\text{Total Elevator Savings} = 238,243.1 \frac{\text{kWh}}{\text{yr}} - 153,646.8 \frac{\text{kWh}}{\text{yr}} = 84,596.3 \frac{\text{kWh}}{\text{yr}}$$

Figure 2: Elevator Calculator – Baseline and Proposed Energy Use and Savings

| Elevator ID | | 1 | 2 | 3 |
|----------------------------|--|----------|----------|---|
| Proposed kWh | Peak Motor Power per Motor, Pm (kW) | 64.7 | 42.6 | |
| | Annual Motor Energy Use (kWh/yr) | 141,693 | 7,775 | |
| | Annual Cabin Fan Energy Use (kWh/Yr) | 3,154 | 788 | - |
| | Annual Cabin Lighting Energy Use (kWh/Yr) | 219 | 18 | - |
| Baseline Parameters | | | | |
| Baseline kWh | Cab Lighting Power Allowance (W/SF) | 3.14 | 3.14 | - |
| | Cab Fan Power Allowance (W/CFM) | 0.33 | 0.33 | - |
| | Baseline Elevator Type | Traction | Traction | - |
| | Counterweight [weight of car + 40% of rated load] (lb.) | 9,498 | 10,424 | - |
| | Cab Mechanical Efficiency [h mechanical] (%) ASHRAE 90.1-2016 Table G3.9.2 | 64.0% | 64.0% | - |
| | bhp | 119.3 | 136.4 | |
| | Cab Motor Efficiency [h motor] (%) ASHRAE 90.1-2016 Tables G3.9.3 & G3.9.1 | 94.5% | 95.0% | |
| | Peak Motor Power per Motor, Pm (kW) | 94.2 | 107.1 | |
| | Annual Motor kWh/yr | 206,298 | 19,546 | |
| | Annual Fan kWh/Yr | 3,758 | 940 | |
| | Annual Light kWh/Yr | 6,161 | 1,540 | |

| Savings Summary | | | | |
|-----------------|-----------------------------------|----------------|--|---------------|
| Building | Annual Electric Consumption (kWh) | | | Savings |
| | Baseline | Proposed | | |
| Motor | 225,844 | 149,468 | | 76,376 |
| Fans | 4,698 | 3,942 | | 756 |
| Lights | 7,702 | 237 | | 7,465 |
| Total | 238,243 | 153,647 | | 84,596 |

References

1. Goel, S, M Rosenberg, and C Eley. “ANSI/ASHRAE/IES Standard 90.1-2016 Performance Rating Method Reference Manual.” Pacific Northwest National Laboratory, Sept. 2017.
2. “Lifts Energy Efficiency” VDI-4707 Part 1, March 2009.
3. Pacific Northwest National Laboratory, “PNNL 2013EndUseTables”, June 20 2014.