



Combined Heat & Power (CHP) Program

For Fiscal Year 2018

(7/1/2017 through 6/30/2018)

Table of Contents

1. Overall Program Description 3

2. Target Market 3

3. Link to Website Information 4

4. CHP System Eligibility..... 4

 Ineligible Types of CHP Systems: 5

5. Financial Incentives..... 5

6. Application Process..... 7

 Pre—Installation 7

 First Incentive Payment 7

 Second Incentive Payment 8

 Third Incentive Payment..... 8

7. Extensions 9

8. Inspections..... 9

9. Program Dispute Resolution..... 9

10. Call Center Support..... 10

1. Overall Program Description

New Jersey's Clean Energy Program™ (NJCEP) supports the statewide growth of Commercial and Industrial (C&I) Combined Heat & Power (CHP) technologies to enhance energy efficiency through on-site power generation.

For the purposes of this program, CHP is defined as follows:

- *Combined Heat and Power*

Combined heat and power, also known as cogeneration, is the sequential production of electricity and useful thermal energy from a single source fuel. Useful thermal energy means energy in the form of direct heat, steam, hot water, or other thermal form that is used for heating, cooling, humidity control, process use, or other valid thermal end-use energy requirements; and for which fuel or electricity would otherwise be consumed. Bio-power and partial bio-power projects that meet these criteria are considered to be CHP projects for program purposes.

Waste heat to power projects that comply with the following definition are treated as CHP projects:

- *Waste Heat to Power*

Waste heat to power (WHP) is the process of capturing waste heat discharged as a byproduct of a process and using that heat to generate power. In this configuration, a source fuel is first used to provide thermal energy to meet load requirements of a process or system (i.e. not deliberately creating excess thermal energy for the purpose of electricity generation). The byproduct of this process is heat that would otherwise be wasted to the atmosphere. The waste heat is then repurposed to produce electricity, as opposed to directly consuming additional fuel for this purpose.

Projects meeting the definitions of either CHP or WHP above are eligible to receive incentives, and are collectively referred to as CHP projects in the remainder of this document.

Program participants are eligible to receive financial incentives for CHP installations to further enhance energy efficiency in their buildings through on-site power generation with recovery and productive use of waste heat and reduce existing and new demands to the electric power grid.

By installing CHP systems, participants will assist in reducing overall system peak demand, furthering the use of emerging technologies, reducing emissions, and using distributed generation to provide reliability solutions for New Jersey while supporting the state's Energy Master Plan.

2. Target Market

The CHP program is open to all New Jersey-based commercial and industrial (C&I) customers paying into the Societal Benefits Fund. Applications are reviewed and funds committed on a first come, first serve

basis provided all program requirements are met. CHP systems that receive funding from the Energy Resiliency Bank will not be eligible for incentives through NJCEP.

3. Link to Website Information

- The following link routes to the overall homepage for the CHP program:
NJCleanEnergy.com/CHP

4. CHP System Eligibility

Natural gas, hydrogen, biogas, and mixed fuel (e.g. natural gas and biogas) CHP equipment installed on the customer side of the utility meter is eligible for incentives. 100% renewable fueled projects, including biogas and landfill gas-fueled projects which meet CHP program criteria, are also eligible to receive incentives. Incentives for mixed-fueled and 100% renewable-fueled systems will not exceed those listed in the table in Section 5.

To qualify for incentives, CHP projects must meet all of the following eligibility criteria:

- Equipment must be new, commercially available, and permanently installed. (Expansion of an existing system with new equipment is also eligible, however, only the incremental expansion would be eligible for incentives.)
- The CHP system must achieve an annual system efficiency of at least 65% (Lower Heating Value – LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.
- Waste heat utilization systems or other mechanical recovery systems are required. New electric generation equipment which captures waste heat or energy from existing systems is also allowed. In order to qualify for incentives, systems must operate a minimum of 5,000 full load equivalent hours per year (i.e. run at least 5,000 hours per year at full rated KW output). The Office of Clean Energy (OCE) may grant exceptions to the minimum operating hours requirement for Critical Facilities (as identified in the host municipality's state-certified Emergency Operation Plan and/or as defined by the New Jersey Office of Emergency Management and/or FEMA), provided the proposed system operates a minimum of 3,500 full-load equivalent hours per year and has blackstart capability.
- Projects are subject to ten (10) year warranty requirements.
- Each CHP and WHP project must pass a project-level cost-effectiveness analysis demonstrating the simple project payback period, including any federal tax benefits and the Program incentive. CHP systems installed in Critical Facilities must not exceed a payback period of 20 years, CHP systems fueled by a Class 1 renewable source must not exceed a payback period of 25 years, and all other CHP systems must not exceed a payback period of 10 years.
- All CHP project submissions must contain specific cost data for making the unit island mode capable, regardless of whether the project has the capability or not.

- System must be sized to meet all or a portion of the customer's on-site load, not to exceed 100% of most recent historical annual consumption or peak demand. For all CHP projects, any surplus power that may become available during the course of a given year may be sold to PJM. Any CHP system fueled by a Class 1 renewable source is exempted from this program requirement, provided the system is sized to match the Class 1 renewable fuel produced on-site.

Third party ownership (or leased equipment), such as procured under Power Purchase Agreements is permitted within the program with the following provisions:

- In order to ensure the equipment remains on site and is in operation for the term of the agreement, a binding agreement is required between the parties. A copy of this agreement shall be provided to the Program Manager prior to commitment of incentives. The agreement should state that the equipment could be transferred to new owners should the property be sold or otherwise have a buyout provision such that the equipment remains on site and stays in operation. Only permanently installed equipment is eligible for incentives and this must be physically demonstrable, upon inspection, prior to receiving an incentive. This can be demonstrated by electrical, thermal and fuel connections in accordance with industry practices for permanently installed equipment and be secured to a permanent surface (e.g. foundation). Any indication of portability, including but not limited to temporary structures, quick disconnects, unsecured equipment, wheels, carrying handles, dolly, trailer or platform will deem the system ineligible.
- The customer/applicant will be allowed to sign over the incentive to the third party owner. A valid project cost shall be demonstrated as part of the application in order to establish an appropriate incentive level.
- All other program rules apply.

Ineligible Types of CHP Systems:

The following types of generating systems/equipment are not eligible for the program:

- Used, refurbished, temporary, pilot, demonstration or portable equipment/systems.
- Back-Up Generators - systems intended for emergency or back-up generation purposes.
- Any system/equipment that uses diesel fuel, other types of oil, or coal for continuous operation.
- Fuel Cell systems which do not have a heat recovery component.

5. Financial Incentives

Incentives vary based on CHP technology, type, project size and total project cost. Details on qualifying technologies and available incentives can be found below.

Projects will receive incentives in three partial payments. The first incentive will be paid upon proof of purchase of equipment. The second payment will be paid upon project installation and operation, including successful inspection. The remainder of the project incentive will be paid upon acceptance and confirmation that the project is achieving the required performance thresholds based on twelve (12)

New Jersey's Clean Energy Program™ CHP Program Guide

months of continuous operating data submitted within 24 months of installation demonstrating the system meets program requirements. The payment structure is summarized below:

Purchase	Installation	Acceptance of 12 months post-installation data
30%	50%	20%

Applicants will not be allowed to receive incentives for the installed generation equipment from other available SBC-funded programs or from the Energy Resilience Bank. CHP projects will be evaluated on a per site basis and incentives awarded accordingly. Installations of multiple systems planned for the same site within a 12-month period must be combined into a single project.

CHP technology types and incentive levels:

Eligible Technology	Size (Installed Rated Capacity)	Incentive (\$/Watt)	% of Total Cost Cap per project	\$ Cap per project
Gas Internal Combustion Engine Combined Heat & Power Powered by non-renewable or renewable fuel source, or a combination	≤500 kW ⁽¹⁾	\$2.00	30-40% ⁽²⁾	\$2 million
	>500 kW – 1 MW ⁽¹⁾	\$1.00		
	>1 MW – 3 MW ⁽¹⁾	\$0.55	30%	\$3 million
Gas Internal Combustion Engine	>3 MW ⁽¹⁾	\$0.35		
Gas Combustion Turbine				
Microturbine				
Fuel Cells with heat recovery				
Waste Heat to Power (WHP) ⁽³⁾ Powered by non-renewable fuel source. Heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine)	≤1 MW ⁽¹⁾	\$1.00	30%	\$2 million
	>1 MW ⁽¹⁾	\$0.50	30%	\$3 million

(1) Incentives for CHP and WHP are tiered which means the incentive levels vary based upon the installed rated capacity, as listed in the chart above. For example, a 4 MW CHP system would receive \$2.00/watt for the first 500 kW, \$1.00/watt for the second 500 kW, \$0.55/watt for the next 2 MW and \$0.35/watt for the last 1 MW (up to the caps listed).

- (2) The maximum incentive will be limited to 30% of total project. This cap will be increased to 40% where a cooling application is used or included with the CHP system (e.g. absorption chiller).
- (3) Projects installing CHP with WHP will be eligible for incentives shown above, not to exceed the lesser of percent per project cap or dollars per project cap of the CHP. Minimum efficiency will be calculated based on annual total electricity generated, utilized waste heat at the host site (i.e. not lost/rejected), and energy input.
- (4) CHP systems fueled by a Class 1 renewable fuel source are eligible for a 30% incentive bonus. If the fuel is mixed, the bonus will be prorated accordingly. For example if the mix is 60/40 (60% being a Class 1 renewable), the bonus will be 18%. This bonus will be included in the final partial payment, based on system performance and fuel mix consumption data.

6. Application Process

All submittals to the program must be signed by a New Jersey licensed Professional Engineer (PE) certifying that the information is accurate to the best of their knowledge. Applications must be submitted through the [on-line portal](#). Hard copy or email submissions will not be accepted.

Pre—Installation

Applicant submits an electronic application Excel-based workbook and required supporting documentation.

1. After a post-submission completeness review is completed to verify application submission, an engineer is assigned to the project who reviews the workbook for technical and eligibility requirements.
2. If an application is deemed complete and meets program criteria, a pre-inspection of the site will be scheduled to verify that no existing CHP is present, as well as to verify any existing heating/cooling equipment to be modified and/or tied into the CHP.
3. Prior to approval, a Project Manager is assigned to the project and a commitment/award letter will be issued approving the system and reserving the incentive. If the project incentive is projected to be more than \$500,000, NJBPU Board approval is also required before a commitment/award letter can be issued.
4. The incentive funding will be reserved for eighteen months from the date of the award letter.

First Incentive Payment

1. In order to collect the first incentive, Applicant (or authorized contractor) must submit the following to the program.
 - a. Executed customer/developer agreement (if not previously submitted)
 - b. Proof of equipment purchase (invoice, receipt, etc.)

1. Must be detailed to show what equipment was purchased, including quantity and cost.
Equipment purchased date does not have to precede application approval date.
- b. Current Tax Clearance Certificate
- c. Signed W9 form (if not previously submitted)
2. The Project Manager reviews all the above, and if satisfactory, issues the payment.

Second Incentive Payment

1. Applicant must purchase a qualifying system and have it installed according to Program Requirements within 18 months of the date listed on the Approval Letter. Projects are expected to be designed and proposed as feasible, viable projects that can be permitted in all relevant jurisdictions. The Program, however, recognizes that some project changes may be required in order to be consistent with the results of any environmental assessment, DEP, or other local state or federal permitting requirement, or events that are unforeseen by the proposals. The Project Manager must be notified in advance of any proposed change in a project while the application is pending or active for that project.
2. After the approved system is installed, the Applicant (or authorized contractor) must submit the following to the program in order to receive the second incentive payment and the Project Manager reviews for completeness:
 - a. Updated Application with post-installation/as-built data
 - b. Proof of additional purchases/labor (invoices)
(1) Installation date should post-date approval letter date.
 - c. Proof of executed 10-year warranty or service contract
 - d. Copy of the Electrical Code Inspection Certificate
 - e. Completed Interconnection Application approved by the utility company
 - f. Current Tax Clearance Certificate
3. The Project Manager schedules a Post-inspection to verify system was installed per approved application.
4. After the installation is completed, submittal documents verified, and necessary inspections are performed and passed, the Project Manager approves payment of second incentive.

Third Incentive Payment

1. In order to receive the final, third incentive, Applicant (or authorized contractor) must submit the following to the program and the Project Manager will review for completeness of submittal:
 - a. 12 months of operational data demonstrating minimum system efficiency was achieved and annual generated kWh are within 20% of that stated in the approved Application. This shall be done by implementing appropriate metering as part of the system installation. Data collected should include, but is not limited to, fuel input (MMBtu), electrical output (kWh, MMBtu), recoverable and utilized thermal output (MMBtu). The detailed metering plan included with the Application shall be followed.
 - b. Current Tax Clearance Certificate

2. Project Manager verifies minimum performance thresholds have been achieved and approves payment of Third Incentive.

7. Extensions

Any circumstances leading to the delay past the 18-month timeframe must be reported to the program at least one month prior to the expiration of the funding award. Extension requests must be submitted in writing and must present a schedule that identifies how much extra time is needed to complete the project. Two six-month extensions may be granted so long as the applicant can demonstrate proof of significant project advancement in the form of copies of permits, equipment invoices, installation invoices indicating percent complete, updated project schedules, etc. The Program Administrator, with the approval of OCE Staff, may approve up to two additional six-month extensions, beyond the extensions the Program Managers are authorized to approve.

8. Inspections

Pre and Post inspections are conducted on 100% of projects. Installation cannot begin until an application is approved, which includes a site Pre-inspection. A Pre-inspection alone (before Application approval) is not an approval to begin installation. The Post-Installation inspection confirms that the project has been installed per the specifications of the approved application as well as in line with all program requirements.

9. Program Dispute Resolution

Disputes, concerns, or complaints that arise will be addressed initially by the Program Manager or Program Staff at the point of contact. If resolution for whatever reason is not possible, there is a [dispute resolution process](#) backed by the NJ Board of Public Utilities.

For contractual disputes between a system owner and installer or registrant, the NJ Division of Consumer Affairs (DCA) is the point of contact and the agency has an online complaint form.

The program is designed to allow for participation by any third-party contractor that meets the program requirements. There are BPU approved contractor remediation procedures that will be followed if a contractor is found to violate program procedures and rules or consistently violates program requirements which may include being barred from participating in the program.

10. Call Center Support

New Jersey's Clean Energy Program operates a call center staffed weekdays between 8 AM and 7 PM. The phone number is 866-NJSMART. The call center is trained in answering general questions about the program and application processes as well as able to provide specific information pertaining to an application.

Email inquiries may also be directed to chp@NJCleanEnergy.com.