



FY 2020 WARMAdvantage & COOLAdvantage Programs

Eligible Measures and Required Documents List

For Systems Purchased on or after July 1, 2019 through June 30, 2020

WARMAdvantage for new Heating Equipment

Equipment Type			Minimum* Efficiency Criteria	Sizing and Selection	Incentive
Furnace	Natural Gas/ Propane	Tier 1	Annual Fuel Utilization Efficiency (AFUE) 95% or greater	Selection of the equipment in accordance with ACCA Manual S based on load calculations in accordance with ACCA Manual J is required.	\$250
		Tier 2	AFUE 97% or greater		\$500
	Oil	AFUE 85% or greater	\$250		
Boiler	Natural Gas/ Propane		AFUE 90% or greater		\$300
	Oil		AFUE 87% or greater		\$300
Water Heater	Natural Gas/ Propane	Tankless - On-Demand	<2 gallons & Uniform Energy Factor – UEF 0.90, or greater	\$300	
		Tank, Power- vented	≤55 gallons & Uniform Energy Factor – UEF 0.64, or greater OR >55 gallons & Uniform Energy Factor -UEF 0.85, or greater	\$300	
	Electric	Heat Pump	Energy Factor - Uniform Energy Factor – UEF 2.0, or greater	\$750	
Furnace and Water Heater Combination			Qualifying Tier 1 natural gas/ propane furnace (above) AND a qualifying water heater (above)	\$700	
			Qualifying Tier 2 natural gas/ propane furnace (above) AND a qualifying water heater (above)	\$950	
Boiler and Water Heater Combination			<ul style="list-style-type: none"> Combi-boiler – an integrated unit, combining a water heater and a qualifying boiler (above) Qualifying stand-alone water heater (above) AND a qualifying boiler (above) Indirect water heater attached to a qualifying boiler (above) 	\$700	
Homeowners located in a designated Urban Enterprise Zone (UEZ) may be eligible for additional incentives for the purchase of qualifying equipment (above). Verification of home being located in a designated UEZ required.					\$200 per unit

COOLAdvantage for new Air Conditioner & Heat Pump Equipment

Equipment Type		Minimum* Efficiency Criteria	Incentive
Central Air Conditioner	Tier 1	16 SEER, 13 EER system efficiency	\$300
	Tier 2	18 SEER, 13 EER system efficiency	\$500
Central Air Source Heat Pump	Tier 1	16 SEER, 13 EER, 10 HSPF system efficiency	\$600
	Tier 2	18 SEER, 13 EER, 10 HSPF system efficiency	\$1,000
Mini-Split A/C		20 SEER, 12.5 EER system efficiency	\$500
Mini-Split Cold Climate Air Source Heat Pump (CCASHP)		Single ductless indoor unit SEER ≥ 20, EER ≥ 12, & HSPF ≥ 12, COP 1.75 @ 5°F	\$1,000
		Multi- and ducted indoor units SEER ≥ 18, EER ≥ 12, & HSPF ≥ 10, COP 1.75 @ 5°F	\$2,000
Air-to-Water Heat Pump with Integrated Domestic Hot Water		SEER ≥ 18, EER ≥ 12, & HSPF ≥ 10, COP 1.75 @ 5°F	\$2,000
Homeowners located in a designated Urban Enterprise Zone (UEZ) may be eligible for additional incentives for the purchase of qualifying equipment (above). Verification of home being located in a designated UEZ required.			\$200 per unit

All components of the system necessary to meet the specified minimum efficiency requirements must be newly purchased and installed (e.g. Both the condenser and coil, condenser and air handler, condenser, coil and furnace) must be replaced or installed as a matched set as listed on the supporting documentation of the efficiency ratings



FY 2020 WARMAdvantage & COOLAdvantage Eligible Measures and Required Documents List

For Systems Purchased on or after July 1, 2019 through June 30, 2020

Documents to be Submitted for all new equipment (copies are accepted)

<p>REQUIRED: Itemized Contractor's invoice/contract (or supplier invoice, if self-installed)—marked PAID or FINANCING ARRANGEMENTS—and clearly indicating:</p> <ol style="list-style-type: none"> 1. Customer name or installation address 2. Date of purchase 3. Manufacturer/ Brand 4. Model number for each installed unit 5. Total Cost 	<p>Completed by contractor</p>
<p>REQUIRED: Copy of UPC Label, distributor's invoice, photo of nameplate, or warranty registration confirmation showing model and serial numbers</p>	<p>Submit with application</p>
<p>REQUIRED: Copy of AHRI Certificate showing AFUE, SEER, EER, HSPF, or UEF, and BTUH. Also provide the AHRI number and certificate for the installed matched system. Exception: AHRI not required for Cold Climate Heat Pumps., see below for cold climate heat pump required documentation</p>	<p>Provided by contractor, found at AHRIdirectory.org</p>
<p>REQUIRED: For Cold Climate Air Source Mini-Split Heat Pump:</p> <ul style="list-style-type: none"> • Copy of Manufacturers specification sheet showing SEER, EER, HSPF and COP @ 5°F 	<p>Available from Manufacturers or equipment listing websites</p>
<p>REQUIRED: Municipal Building Permit number entered on portal/paper application and/or a copy of the Permit or Permit Application</p>	<p>Submit with application</p>
<p>REQUIRED IF APPLICABLE: UEZ verification of home being located in a designated UEZ, submit screen shot of address look-up verification from https://www.nj.gov/njbusiness/financing/uez/</p>	<p>Submit with application</p>

Apply online at

NJCleanEnergy.com/COOL or NJCleanEnergy.com/WARM

For more information: NJCleanEnergy.com or 866-NJSMART