



Steven Winter Associates, Inc.
Building Systems Consultants
www.swinter.com

293 Route 18, Suite 330
East Brunswick, NJ 08816

Telephone (866) 676-1972
Facsimile (203) 852-0741

September 18, 2010

**Local Government Energy Program
Energy Audit Final Report**

**Freehold Regional High School District
Colts Neck High School
59 Five Points Road
Colts Neck, NJ 07722**

Project Number: LGEA65



Table of Contents

EXECUTIVE SUMMARY 3

INTRODUCTION 5

HISTORICAL ENERGY CONSUMPTION..... 6

EXISTING FACILITY AND SYSTEMS DESCRIPTION12

PROPOSED ENERGY CONSERVATION MEASURES 25

APPENDIX A: EQUIPMENT LIST 46

APPENDIX B: LIGHTING STUDY 53

APPENDIX C: THIRD PARTY ENERGY SUPPLIERS 64

APPENDIX D: GLOSSARY AND METHOD OF CALCULATIONS 67

APPENDIX E: STATEMENT OF ENERGY PERFORMANCE FROM ENERGY STAR®..... 71

APPENDIX F: INCENTIVE PROGRAMS..... 72

APPENDIX G: VENDINGMISER™ AND SNACKMISER™ ENERGY SAVINGS 74

APPENDIX H: ENERGY CONSERVATION MEASURES..... 75

APPENDIX I: METHOD OF ANALYSIS 78

EXECUTIVE SUMMARY

The Freehold RHSD (Regional High School District) Colts Neck High School is a two-story building slab on grade comprising a total conditioned floor area of 220,000 square feet. The original structure was built in 1995, with an addition completed in 2009. The following chart provides an overview of current energy usage in the building based on the analysis period of January 2009 through January 2010:

Table 1: State of Building-Energy Usage

	Electric Usage, kWh/yr	Gas Usage, therms/yr	Other fuel usage	Current Annual Cost of Energy, \$	Site Energy Use Intensity, kBtu/sq ft yr	Joint Energy Consumption, MMBtu/yr
Current	3,635,786	143,801	N/A	775,865	122.0	26,786
Proposed	3,464,183	143,801	N/A	\$749,156	119.0	26,200
Savings	171,603	0	N/A	\$26,709*	3.0	586
% Savings	5%	0%	N/A	3%	2%	2%
Renewables	227,895	Includes SRECs		171,296	3.5	778

*Includes operation and maintenance savings

There may be energy procurement opportunities for the Freehold RHSD Colts Neck High School to reduce annual utility costs, which are \$13,306 higher, when compared to the average estimated NJ commercial utility rates.

SWA has also entered energy information about the Colts Neck High School in the U.S. Environmental Protection Agency's (EPA) *ENERGY STAR® Portfolio Manager* energy benchmarking system. This high school is comprised of K-12 School space type. The Colts Neck High School received a national energy performance rating of 2, which indicates that this building is in the 2nd percentile when compared to other buildings that are eligible for a national energy performance rating. This school is consuming energy at a far greater rate than almost all other benchmarked high schools across the nation. Its low score is primarily the result of the building's cooling system. The schools cooling system which conditions one hundred percent of the building area is atypical for a high school. There is also additional consumption due to unnecessary summer time cooling of unoccupied areas.

Based on the current state of the building and its energy use, SWA recommends implementing various energy conservation measures from the savings detailed in Table 1. The measures are categorized by payback period in Table 2 below:

Table 2: Energy Conservation Measure Recommendations

ECMs	First Year Savings (\$)	Simple Payback Period (years)	Initial Investment, \$	CO2 Savings, lbs/yr
0-5 Year	22,123	2.7	59,346	203,537
5-10 Year	4,586	6.8	31,201	43,457
>10 year	0	N/A	0	0
Total	26,709	3.4	91,165	246,994
Renewables	171,296	8.1	1,383,375	312,217

SWA estimates that implementing the recommended ECMs is equivalent to removing approximately 21 cars from the roads each year or avoiding the need of 601 trees to absorb the annual CO₂ generated.

Other recommendations to increase building efficiency pertaining to operations and maintenance and capital improvements are below. This is an abbreviated list with only a few select highly recommended improvements. For the full list see the Proposed Further Recommendations section.

Further Recommendations:

- Capital Improvements
 - Replace domestic water heaters
 - Replace Hot and Chilled Water Fan Coil Rooftop Units
 - Provide dedicated makeup air unit for kitchen hood
- Operations and Maintenance
 - Provide weather-stripping/air-sealing
 - Repair/seal wall cracks and penetrations
 - Insulate uninsulated hot water and chilled water piping
 - Reevaluate and optimize the building occupancy schedule for the cooling system

Based on the requirements of the LGEA program, the Freehold RHSD must commit to implementing some of these measures, and must submit paperwork to the Local Government Energy Audit program within one year of this report's approval to demonstrate that they have spent, net of other NJCEP incentives, at least 25% of the cost of the audit (per building). The Colts Neck High School should spend a minimum of \$4,566 (or 25% of \$18,262) worth of ECMs, net of other NJCEP incentives, to fulfill the obligations.

Financial Incentives and Other Program Opportunities

The table below summarizes the recommended next steps that Freehold RHSD can take to achieve greater energy efficiency, reduce operating costs and exceed the 25% expenditure requirement (see Appendix H for more ECMs and details).

Table 3: Next Steps for the Colts Neck High School

Recommended ECMs	Incentive Program (Please refer to Appendix F for details)
Install thirty (30) new occupancy sensors	Smart Start, Direct Install
Install (27) new bi-level T8 fluorescent fixtures in stairwells	Smart Start, Direct Install
Install fifteen (15) new CFL fixtures	N/A

There are various incentive programs that the Freehold RHSD could apply for that could help lower the cost of installing the ECMs. For the Colts Neck High School, and contingent upon available funding, SWA recommends the following incentive programs:

Direct Install 2010 Program: Buildings can receive up to 60% of the installed cost of energy saving upgrades. The 200 kW peak demand threshold has been waived for local government entities who receive their Energy Efficiency and Conservation Block Grant in conjunction with Direct Install

Smart Start: Majority of energy saving equipment and design measures have moderate incentives under this program.

Renewable Energy Incentive Program: Receive up to \$0.75/Watt toward installation cost for PV panels upon available funding.

For each 1,000 kWh generated by renewable energy, receive a credit between \$475 and \$600.

Utility Sponsored Programs: See available programs with JCP&L.

https://www.firstenergycorp.com/JCP_L/index.html New Jersey Natural Gas <http://www.njng.com/>

Energy Efficiency and Conservation Block Grant Rebate Program: Provides up to \$20,000 per local government toward energy saving measures.

Please refer to Appendix F for further details.

INTRODUCTION

Launched in 2008, the Local Government Energy Audit (LGEA) Program provides subsidized energy audits for municipal and local government-owned facilities, including offices, courtrooms, town halls, police and fire stations, sanitation buildings, transportation structures, schools and community centers. The Program will subsidize up to 100% of the cost of the audit. The Board of Public Utilities (BPU) Office of Clean Energy has assigned TRC Energy Services to administer the Program.

Steven Winter Associates, Inc. (SWA) is a 38-year-old architectural/engineering research and consulting firm, with specialized expertise in green technologies and procedures that improve the safety, performance, and cost effectiveness of buildings. SWA has a long-standing commitment to creating energy-efficient, cost-saving and resource-conserving buildings. As consultants on the built environment, SWA works closely with architects, developers, builders, and local, state, and federal agencies to develop and apply sustainable, 'whole building' strategies in a wide variety of building types: commercial, residential, educational and institutional.

SWA performed an energy audit and assessment for the Colts Neck High School at 59 Five Points Road, Colts Neck, NJ 07722. The process of the audit included facility visits on April 19, May 6, June 28 and June 30, 2010 benchmarking and energy bills analysis, assessment of existing conditions, energy modeling, energy conservation measures and other recommendations for improvements. The scope of work includes providing a summary of current building conditions, current operating costs, potential savings, and investment costs to achieve these savings. The facility description includes energy usage, occupancy profiles and current building systems along with a detailed inventory of building energy systems, recommendations for improvement and recommendations for energy purchasing and procurement strategies.

The goal of this Local Government Energy Audit is to provide sufficient information to the Freehold RHD to make decisions regarding the implementation of the most appropriate and most cost-effective energy conservation measures for the Colts Neck High School.


HISTORICAL ENERGY CONSUMPTION

Energy usage, load profile and cost analysis

SWA reviewed utility bills from March 2008 through February 2010 that were received from the utility companies supplying the Colts Neck High School with electricity and natural gas. A 12 month period of analysis from March 2009 through February 2010 was used for all calculations and for purposes of benchmarking the building.



Electricity - The Colts Neck High School is currently served by one electric meter. The Colts Neck High School currently buys electricity from JCP&L at **an average aggregated rate of \$0.154/kWh**. The Colts Neck High School purchased **approximately 3,635,786 kWh, or \$558,674 worth of electricity**, in the previous year. The average monthly demand was 777.6 kW and the annual peak demand was 932.6 kW.

The chart below shows the monthly electric usage and costs. The dashed green line represents the approximate baseload or minimum electric usage required to operate the Colts Neck High School.



Natural gas - The Colts Neck High School is currently served by one meter for natural gas. The Colts Neck High School currently buys natural gas from Pepco Energy Services (commodity gas) and NJ Natural Gas (transportation) at **an average aggregated rate of \$1.510/therm**. The Colts Neck High School purchased **approximately 143,801 therms, or \$217,191 worth of natural gas**, in the previous year.


The chart below shows the monthly natural gas usage and costs. The green line represents the approximate baseload or minimum natural gas usage required to operate the Colts Neck High School.



The chart above shows the monthly natural gas usage along with the heating degree days or HDD. Heating degree days is the difference of the average daily temperature and a base temperature, on a particular day. The heating degree days are zero for the days when the average temperature exceeds the base temperature. SWA's analysis used a base temperature of 65 degrees Fahrenheit.

The following table and pie charts show energy use for the Colts Neck High School based on utility bills for the 12 month period. Note: electrical cost at \$45/MMBtu of energy is 3 times as expensive as natural gas at \$15/MMBtu


Annual Energy Consumption / Costs					
	MMBtu	% MMBtu	\$	% \$	\$/MMBtu
Electric Miscellaneous	7,115	27%	\$320,393	41%	45
Electric For Cooling	1,210	5%	\$54,472	7%	45
Electric For Heating	1,023	4%	\$46,080	6%	45
Lighting	3,059	11%	\$137,729	18%	45
Domestic Hot Water (Gas)	1,527	6%	\$23,062	3%	15
Building Space Heating (Gas)	12,853	48%	\$194,130	25%	15
Totals	26,786	100%	\$775,865	100%	---
Total Electric Usage	12,406	46%	\$558,674	72%	45
Total Gas Usage	14,380	54%	\$217,191	28%	15
Totals	26,786	100%	\$775,865	100%	---



Energy benchmarking

SWA has entered energy information about the Colts Neck High School in the U.S. Environmental Protection Agency's (EPA) *ENERGY STAR® Portfolio Manager* energy benchmarking system. This high school is categorized as a K-12 School space type. The Colts Neck High School received a national energy performance rating of 2. The Site Energy Use Intensity is 122.0 kBtu/ft²-yr compared to the national average of a school building consuming 63.0 kBtu/ft²-yr. See ECM section for guidance on how to improve the building's rating. This school is consuming energy at a far greater rate than almost all other benchmarked high schools. Its low score is primarily the result of the building's cooling system. The school's cooling system which conditions one hundred percent of the building area is atypical for a high school. There is also additional consumption due to unnecessary summer time cooling of unoccupied areas.

Due to the nature of its calculation based upon a survey of existing buildings of varying usage, the national average for “School” space types is very subjective, and is not an absolute bellwether for gauging performance. Additionally, should the Freehold RHSD desire to reach this average there are other large scale and financially less advantageous improvements that can be made, such as envelope window, door and insulation upgrades that would help the building reach this goal.



Per the LGEA program requirements, SWA has assisted the Freehold RHSD to create an *ENERGY STAR® Portfolio Manager* account and share the Colts Neck High School facilities information to allow future data to be added and tracked using the benchmarking tool. SWA has shared this Portfolio Manager account information with the Freehold RHSD (user name of “frhsd8579” with a password of “frhsd8579”) and TRC Energy Services (user name of “TRC-LGEA”).

Tariff analysis

As part of the utility bill analysis, SWA evaluated the current utility rates and tariffs. Tariffs are typically assigned to buildings based on size and building type.


Tariff analysis is performed to determine if the rate that a Freehold RHSD is contracted to pay with each utility provider is the best rate possible resulting in the lowest costs for electric and gas provision. Typically, the natural gas prices increase during the heating months when natural gas is used by the hot water boiler units. Some high gas price per therm fluctuations in the summer may be due to high energy costs that recently occurred and low use caps for the non-heating months. Typically, electricity prices also increase during the cooling months when electricity is used by the HVAC condensing units and air handlers.

The supplier charges a market-rate price based on use, and the billing does not break down demand costs for all periods because usage and demand are included in the rate. Currently, the Freehold RHSD is paying a general service rate for natural gas. Demand is broken out in the bill. Thus the building pays for fixed costs such as meter reading charges during the summer months. The building is direct metered and currently purchases electricity at a general service rate for usage with an additional charge for electrical demand factored into each monthly bill. The general service rate for electric charges is market-rate based on usage and demand. Demand prices are reflected in the utility bills and can be verified by observing the price fluctuations throughout the year.


Energy Procurement strategies

Billing analysis is conducted using an average aggregated rate that is estimated based on the total cost divided by the total energy usage per utility per 12 month period. Average aggregated rates do not separate demand charges from usage, and instead provide a metric of inclusive cost per unit of energy. Average aggregated rates are used in order to equitably compare building utility rates to average utility rates throughout the state of New Jersey.

The average estimated NJ commercial utility rates for electric are \$0.150/kWh, while Colts Neck High School pays a rate of \$0.154/kWh. The Colts Neck High School annual electric utility costs are \$13,306 higher, when compared to the average estimated NJ commercial utility rates. Electric bill analysis shows fluctuations up to 7% over the most recent 12 month period.



The average estimated NJ commercial utility rates for gas are \$1.550/therm, while Colts Neck High School pays a rate of \$1.51/therm. Natural gas bill analysis shows fluctuations up to 93% over the most recent 12 month period.



Utility rate fluctuations may have been caused by adjustments between estimated and actual meter readings; others may be due to unusual high and recent escalating energy costs and the building paying for fixed costs such as meter reading charges during the summer months.

SWA recommends that the Colts Neck High School further explore opportunities of purchasing both natural gas and electricity from third-party suppliers in order to reduce rate fluctuation and ultimately reduce the annual cost of energy for the Colts Neck High School. Appendix C contains a complete list of third-party energy suppliers for the Freehold RHSD service area.

EXISTING FACILITY AND SYSTEMS DESCRIPTION

This section gives an overview of the current state of the facility and systems. Please refer to the Proposed Further Recommendations section for recommendations for improvement.

Based on visits from SWA on April 19, May 6, June 28 and June 30, 2010 the following data was collected and analyzed.

Building Characteristics

The two-story, (slab on grade), 220,000 square foot Colts Neck High School building was originally constructed in 1995 with an addition completed in 2009. It houses administrative offices, gymnasiums, a cafeteria, an auditorium and classrooms.



Partial Front Façade (typ.)



Partial Side Façade (typ.)



Partial Side Façade (typ.)



Partial Rear Façade (typ.)

Building Occupancy Profiles

Its occupancy is approximately 1,700 students and 142 faculty and staff from 7:30am until 3:30pm, extra-curricular activities continuing to 6:00pm and cleaning activities completed by midnight Monday through Friday. Saturday activities are 7:00am until 2:30pm and Sunday activities are sporadic and driven by sport events. Summer school occupancy is approximately 300 students and 30 faculty and staff.

Building Envelope

Due to unfavorable weather conditions (min. 18 deg. F delta-T in/outside and no/low wind), no exterior envelope infrared (IR) images were taken during the field audit.

Exterior Walls

The exterior wall envelope is mostly constructed of brick veneer and some EIFS (Exterior Insulation Finishing System) accents, over concrete block with 1-1/2 inches of foam board insulation.

Note: Wall insulation levels could not be verified in the field and are based on available construction plans.

Exterior and interior wall surfaces were inspected during the field audit. They were found to be in overall acceptable, age-appropriate condition with only a few signs of uncontrolled moisture, air-leakage or other energy-compromising issues.

The following specific exterior wall problem spots and areas were identified:



Signs of water damage at perimeter walls due to damage roof flashing or gutters

Delaminating or deteriorating caulk

Damaged EIFS through baseball or tennis ball impacts

Roof

The building's roof is predominantly a flat and parapet type over steel decking with a built-up asphalt finish and reflective stone coating. It is original. Two and a half inches of foam board roof insulation are assumed.

Note: Roof insulation levels could not be verified in the field, and are based on available construction plans.

Roofs, related flashing, gutters and downspouts were inspected during the field audit. They were reported to be in overall acceptable, age-appropriate condition, with no signs of uncontrolled moisture, air-leakage or other energy-compromising issues.

Base

The building's base is composed of a slab-on-grade floor with a perimeter foundation and no detectable slab edge/perimeter insulation.

Slab/perimeter insulation levels could not be verified in the field and the lack of existing insulation is based on available construction plans.

The building's base and its perimeter were inspected for signs of uncontrolled moisture or water presence and other energy-compromising issues. Overall the base was reported to be in acceptable condition with no signs of uncontrolled moisture, air-leakage and/or other energy-compromising issues except for reports of condensation on ground floor finishes during hot and humid outside conditions.

Windows

The building contains basically two different types of windows.

Casement type windows with a non-insulated aluminum frame, tinted double glazing and some interior shading devices. The windows are located throughout the building and are original and have never been replaced

Windows, shading devices, sills, related flashing and caulking were inspected as far as accessibility allowed for signs of moisture, air-leakage and other energy compromising issues. Overall, the windows were found to be in acceptable condition with no signs of uncontrolled moisture, air-leakage and/or other energy-compromising issues.

Exterior doors

The building contains only one type of exterior door.

Aluminum/steel frame with safety glass type exterior doors. They are located throughout the building and are original.

All exterior doors, thresholds, related flashing, caulking and weather-stripping were inspected for signs of moisture, air-leakage and other energy-compromising issues. Overall, the doors were found to be in acceptable, age appropriate condition with no signs of uncontrolled moisture, air-leakage and/ or other energy-compromising issues.

Building air-tightness

Overall the field auditors found the building to be reasonably air-tight with only a few areas of suggested improvements, as described in more detail earlier in this chapter.

The air tightness of buildings helps maximize all other implemented energy measures and investments, and minimizes potentially costly long-term maintenance, repair and replacement expenses.

Mechanical Systems

Heating Ventilation Air Conditioning

The original building is heated and cooled by one boiler and chiller plant located in 'D' Wing behind the Cafeteria. The 2003 additions are also heated by the original boiler plant, and cooled by a supplemental air-cooled chiller located on grade outside the D Wing and adjacent to some athletic fields. Space conditioning and ventilation is provided by a combination of rooftop fan coil units, exhaust fans and unit ventilators. It should be noted that both the original building and the additions are controlled by a Johnson Metasys Automatic Temperature Controls (ATC) system, and that there were no complaints about the comfort provided by the mechanical systems. Temperature control appeared to be very good on the days of our site visits.

Equipment

The various spaces in Colts Neck High School are heated/cooled by multiple roof mounted, floor-mounted and ceiling mounted fan coil units, as well as classroom unit ventilators, and several hot water perimeter radiators and cabinet unit heaters. The following paragraphs contain a summary of the systems in the various portions of the building. A comprehensive Equipment List can be found in Appendix A.

The Auditorium is conditioned by one (1) large fan coil air handling unit suspended from the roof deck above the Stage. This unit provides heating, cooling and ventilation. Heating is provided by a hot water coil in the unit that is fed by the building's original boiler plant. The air handling unit also contains a cooling coil that receives chilled water from the original chiller plant. The fan coil unit was installed in 1998, is in good condition and should be retained.

The Media Center and Room A125 are conditioned by hot and chilled water fan coil units located above the ceiling within the space. This equipment was installed in 1998 and 2001 respectively and is in very good condition.



Hot and chilled water air handling unit suspended from roof deck

Classrooms A110-A124, A126, A129-A136, A208, A210, A216, A218, A220, A222, and A224-A228 are heated, cooled and ventilated by four-pipe hot and chilled water floor-mounted unit ventilators. The unit ventilators were installed in 1998 or 2001, depending on

when the particular wing in which they are located was constructed. All units are more or less halfway through their expected service lives and are in good condition.

The remainder of the classrooms, the Main Offices, the Cafeteria and Faculty Dining Lounge are served by rooftop hot and chilled water air handling units and exhaust fans. The units were installed in 1998 or 2001, depending on when the particular wing in which they are located was constructed. Additionally, the return air ductwork of the Cafeteria and Faculty Dining Lounge rooftop units are provided with fresh air by two (2) rooftop energy recovery units (ERUs). The ERUs are connected via ductwork below the roof deck that ties into the return duct of the affected fan coil unit. All units are more or less halfway through their expected service lives and are in good condition.



Energy recovery unit above cafeteria

The Kitchen hood receives makeup air the rooftop air handling units serving the kitchen via air transfer through wall openings. This practice leads to heated air from the Cafeteria being lost out through the hood, making the boiler produce more hot water than necessary to keep the Cafeteria heated when the kitchen hood is running. SWA recommends that a gas-fired heated makeup air unit be installed above the Kitchen and ducted into the Kitchen ceiling to provide adequate makeup air for the kitchen hood.

The Main Gymnasium and adjacent locker rooms, Team Rooms, Trainer's Office, etc. are heated, cooled and ventilated by a total of six (6) hot and chilled water fan coil units located on a second level mezzanine adjacent to the Gymnasium. All units appear to be in very good condition and should be retained.

The Auxiliary Gym is served by a rooftop hot and chilled water unit on a low roof above a storage room that is adjacent to the Auxiliary Gym.

Rooms A202, A204, A206, A229, A217, A219, A221 and A223 contain laboratory fume hoods with corresponding rooftop exhaust fans. All equipment is in good condition and can be retained.

In general, the rooftop units serving this building contain a chilled water coil for cooling, hot water coil for heating, supply fan and return fan. In cooling mode, the chilled water absorbs heat from the passing air in the evaporator coil and transfers the heat to the refrigerant in the chiller. There are two chillers serving the building, one water-cooled chiller and one air-cooled chiller. In the case of the water-cooled chiller, the heat is then transferred from the chiller to a separate water loop and rejected at an exterior cooling tower. In the case of the

air-cooled chiller, the chilled water is pumped to the external air-cooled chiller and the heat is transferred to refrigerant and then rejected to the atmosphere.

The rooftop units draw in outside air directly, providing a means of ventilation without an additional building penetration above that required for the distribution ductwork.

The air-cooled chiller uses refrigerant R-22, which contains CFCs and is being phased out of production for environmental reasons. Newer equipment will contain refrigerant R-410A, which is more environmentally-friendly than R-22. The liquid cooled chiller contains R-134a, which is more environmentally friendly than R-22.

The air handling unit heating coils, unit ventilators, hydronic unit heaters and finned-tube radiation located in the original building are provided with hot water by three (3) HB Smith cast iron sectional boilers located in the mechanical room across from D103. These boilers were installed in 1998 and are in very good condition. This equipment is about 40% of the way through its expected service life of 30 years per the 2007 ASHRAE Applications Handbook. The thermal efficiency of this equipment can be expected to be approximately 80%.



One of three cast iron boilers (l.) and condensing boiler (r.)

The heating loads in the additions are served by one (1) Aerco Benchmark condensing boiler also located in the original boiler room. The boiler was installed in 2001 and is in very good condition. This equipment is about one third of its way through its expected service life of 30 years. The efficiency of this equipment can range from about 80-93%. In general, condensing boilers are most efficient when operating at temperatures that are lower than non-condensing or cast iron boilers. No operational problems were reported with these boilers.

The air handling unit and unit ventilator cooling coils in the original building are served by a water-cooled chiller as mentioned above. This chiller is piped to a cooling tower located outside for heat rejection. The chiller and cooling tower were installed in 1998 and are in very good condition. The chiller is about halfway through its expected service life of 25 years, and the cooling tower is slightly over its expected service life of 20 years.

The cooling loads in the additions are served by an air-cooled chiller located on grade outside the 'D' Wing. This equipment was installed in 2001 and is less than halfway through its expected service life of 25 years. The chiller appears to be in very good condition.



Water-cooled chiller (l.) and air –cooled chiller (r.)

There are several exhaust fans located on the roof, which serve the bathrooms, kitchen hood and general exhaust. The fans are in generally good condition and were all operating at the time of the field visit. In general, most of the building exhaust fans have an estimated 50% useful operating life left.

Distribution Systems

The heating hot water is pumped to the original building loads by one pair of pumps, and to the loads in the 2001 additions by another pair of pumps. One of each pair of pumps runs at a time, in lead-lag fashion. The original building pump motors are labeled as premium efficiency, however, the newer pumps are standard efficiency. The standard efficiency motors are recommended for replacement with premium efficiency motors in the ECM section of this report.

The chilled water is pumped to the original building loads by one pair of pumps, and to the loads in the 2001 additions by another pair of pumps. One of each pair of pumps runs at a time, in lead-lag fashion. It appears that one set of pumps is standard efficiency and one set is premium efficiency. The standard efficiency motors are recommended for replacement with premium efficiency motors in the ECM section of this report.

In general, the air distribution in the school is via ducted constant volume systems, where the air handling equipment delivers the same volume of air to the conditioned space at all occupied times. Upon a call for cooling, the chilled water coil valve opens to allow chilled water into the cooling coil until the space thermostat is satisfied. Similarly, upon a call for heating, the hot water coil valve is opened to allow hot water to flow through the heating coil until the space thermostat is satisfied.

It should be noted that in some instances, ductwork insulation was not observed. Since it is possible that the ductwork is internally lined, SWA recommends that the ductwork is inspected and insulated if required.

Controls

The original building and the additions are controlled by a Johnson Metasys Automatic Temperature Controls (ATC) system, and that there were no complaints about the comfort

provided by the mechanical systems. Temperature control appeared to be very good on the days of our site visits.



Johnson Metasys control panel (l.) and typical thermostat (r.)

Domestic Hot Water

The domestic hot water (DHW) for Colts Neck High School is provided by two (2) A.O. Smith Legend gas-fired water heaters located in the original mechanical room. These boilers have a 90% nominal efficiency and are in fair condition. These heaters are almost at the end of their expected service life of 15 years and should be considered for replacement. However, due to their nominal efficiency, this replacement cannot be justified by energy savings alone, and will be listed in the Capital Improvements section of this report.



Domestic water heaters

Commercial Refrigeration

The school also has an approximately 16' x 16' walk-in cooler and freezer inside the kitchen. This cooler was manufactured by Tafco and is original to the building (1998). The equipment is in good condition. Although nameplate data was not found, it is estimated that there may be an opportunity for energy savings by replacing the evaporator fans.

Both the cooler and freezer utilize remote condensing units for heat rejection that located on the roof. SWA recommends that this equipment is replaced as part of a capital improvement project within the district. The condensing units are labeled as using R-22 refrigerant, which is not as environmentally friendly as R-404a that would be used in a replacement unit by the same manufacturer.



Condensing Units for Walk-in Boxes

The kitchen contained three (3) stainless steel refrigerators, one (1) stainless steel refrigerator/freezer and one (1) ice machine, and the server contained one glass door merchandiser. All equipment appears to be in very good condition.

The Nurse's Office contains one (1) ice machine and the Main Gymnasium Trainer's Room contains two (2) ice machines. This equipment was installed in the last 5-10 years and is in good condition.

Electrical systems

Lighting

See attached lighting schedule in Appendix B for a complete inventory of lighting throughout the building including estimated power consumption and proposed lighting recommendations.

As of **July 1, 2010** magnetic ballasts most commonly used for the operation of T12 lamps will no longer be produced for commercial and industrial applications. Also, many T12 lamps will be phased out of production starting July 2012.

Interior Lighting - The Colts Neck High School currently contains mostly fixtures with electronically ballasted T8 lamps. There are also incandescent, CFL, pulse start metal halide and high pressure sodium lamps installed on the premises. Based on measurements of lighting levels for each space, there are no vastly over-illuminated areas.

Exit Lights - Exit signs were found to be LED type.

Exterior Lighting - The exterior lighting surveyed during the building audit was found to be a mix of metal halide and high pressure sodium fixtures as well as fixtures with electronically ballasted T8 lamps and CFL's. Exterior lighting is controlled by a combination of photocells, switches and timers.

Appliances and process

SWA has conducted a general survey of larger, installed equipment. Appliances and other miscellaneous equipment account for a significant portion of electrical usage within the building. Typically, appliances are referred to as “plug-load” equipment, since they are not inherent to the building’s systems, but rather plug into an electrical outlet. Equipment such as process motors, computers, computer servers, radio and dispatch equipment, refrigerators, vending machines, printers, etc. all create an electrical load on the building that is hard to separate out from the rest of the building’s energy usage based on utility analysis.

There are three dishwashers installed at the school. All of them are manufactured by Maytag and are model # MDC5100AWW. Also installed at the school are two old washing machines and two old dryers. All four laundry units are manufactured by Estate, and both dryers are electric. The model numbers for the dryers are TEDS840PQ0 and TEDX540JQ1. The washing machines are older inefficient models and are not ENERGY STAR® qualified.

Installed at the school are eight refrigerated vending machines and four non-refrigerated vending machines. While six of the refrigerated vending machines are new energy efficient and or ENERGY STAR® qualified, there are still two machines that are old and could benefit from a retrofit with a VendingMiser™ device. Four vending machines are also installed and two of them are new energy efficient and or ENERGY STAR® qualified while the other two are older and could benefit from a retrofit with a SnackMiser™ device. There are twenty five refrigerators installed throughout the school. Of these units only one is a new full size residential ENERGY STAR® qualified refrigerator while the others are older, less efficient models that should be replaced with ENERGY STAR® qualified devices. Of the twenty-four non ENERGY STAR® qualified refrigerators, seven are compact units while seventeen are larger full size residential units. Also present in the building is an ice machine and several pieces of commercial kitchen equipment which include six commercial refrigerators, two commercial freezers and two walk in refrigerator / freezer combination units.

Elevators

The Colts Neck High School has one installed 20 horsepower elevator manufactured by Schindler with a capacity of 2,500 lbs. The unit was installed in 1998 and is in very good condition.

Generator

There is one (1) Detroit Diesel 100 KW diesel emergency generator located in a dedicated room just off the original boiler room. This generator was installed in 1998. This generator is in good condition.



Emergency Generator

Other electrical systems

There are currently energy-impacting electrical systems installed at the Colts Neck High School in the form of three transformers. All three are manufactured by General Electric and are sized at 150 kVA, 112.5 kVA, and 30 kVA and are in good working condition.

RENEWABLE AND DISTRIBUTED ENERGY MEASURES

Renewable energy is defined as any power source generated from sources which are naturally replenished, such as sunlight, wind and geothermal. Technology for renewable energy is improving, and the cost of installation is decreasing, due to both demand and the availability of state and federal government-sponsored funding. Renewable energy reduces the need for using either electricity or fossil fuel, therefore lowering costs by reducing the amount of energy purchased from the utility company. Technology such as photovoltaic panels or wind turbines, use natural resources to generate electricity on the site. Geothermal systems offset the thermal loads in a building by using water stored in the ground as either a heat sink or heat source. Solar thermal collectors heat a specified volume of water, reducing the amount of energy required to heat water using building equipment. Cogeneration or CHP allows you to generate electricity locally, while also taking advantage of heat wasted during the generation process.

Existing systems

Currently there are no renewable energy systems installed in the building.

Evaluated Systems

Solar Photovoltaic

Photovoltaic panels convert light energy received from the sun into a usable form of electricity. Panels can be connected into arrays and mounted directly onto building roofs, as well as installed onto built canopies over areas such as parking lots, building roofs or other open areas. Electricity generated from photovoltaic panels is generally sold back to the utility company through a net meter. Net-metering allows the utility to record the amount of electricity generated in order to pay credits to the consumer that can offset usage and demand costs on the electric bill. In addition to generation credits, there are incentives available called Solar Renewable Energy Credits (SRECs) that are subsidized by the state government. Specifically, the New Jersey State government pays a market-rate SREC to facilities that generate electricity in an effort to meet state-wide renewable energy requirements.

Based on utility analysis and a study of roof conditions, the Colts Neck High School is a good candidate for a 47.38 kW or 140.07 kW Solar Panel installation. See ECM's# 11 & 13 for details.

Solar Thermal Collectors

Solar thermal collectors are not cost-effective for this building and would not be recommended due to the insufficient and intermittent use of domestic hot water throughout the building to justify the expenditure.

Wind

The Colts Neck High School is not a good candidate for wind power generation due to insufficient wind conditions in this area of New Jersey.

Geothermal

The Colts Neck High School is not a good candidate for geothermal installation since it would require replacement of the entire existing HVAC system, of which major components still have between 40% and 60% remaining useful life.

Combined Heat and Power

The Colts Neck High School is not a good candidate for CHP installation and would not be cost-effective due to the size and operations of the building. Typically, CHP is best suited for buildings with a high electrical baseload to accommodate the electricity generated, as well as a means for using waste heat generated. Typical applications include buildings with an absorption chiller, where waste heat would be used efficiently.

PROPOSED ENERGY CONSERVATION MEASURES

Energy Conservation Measures (ECMs) are recommendations determined for the building based on improvements over current building conditions. ECMs have been determined for the building based on installed cost, as well as energy and cost-savings opportunities.

Recommendations: Energy Conservation Measures

ECM#	Description of Recommended 0-5 Year Payback ECMs
1	Install Fifteen (15) New CFL Fixtures
2	Install Variable Frequency Drives on Motors of Heating Hot Water Circulators
3	Retrofit Two (2) Refrigerated Vending Machines with VendingMiser™ Devices
4	Retrofit Two (2) Existing Vending Machines with SnackMiser™ Devices
5	Install Variable Frequency Drives on Motors of Heating Hot Water Circulators
6	Install Thirty (30) New Occupancy Sensors
7	Install (27) New Bi-level T8 Fluorescent Fixtures in Stairwells
8	Install Variable Frequency Drives on Motors of Chilled Water Circulators
ECM#	Description of Recommended 5-10 Year Payback ECMs
9	Install Premium Efficiency Motors on (2) Heating Hot Water Circulators
10	Install Variable Frequency Drives on Motors of Chilled Water Circulators
12	Replace Seven (7) Compact Refrigerators with 2.7 Cu. Ft. ENERGY STAR® Models
14	Replace Two (2) Washing Machines with ENERGY STAR® Units
15	Replace Seventeen (17) Large Refrigerators with ENERGY STAR® Units
16	Install Premium Efficiency Motors on Walk-In Box Evaporator Fans
ECM#	Description of Recommended Renewable Energy ECMs
11	Install 49.68 kW PV Rooftop System with Incentives
13	Install 190.90 kW PV Rooftop System without Incentives

Note: In order to clearly present the overall energy opportunities for the building and ease the decision and choice of which ECM to implement, SWA calculated each ECM independently and did not incorporate slight/potential interactions between some of the listed ECM retrofits (i.e. lighting change influence on heating/cooling).

ECM#1: Install Fifteen (15) New CFL Fixtures

On the day of the site visit, SWA completed a lighting inventory of Colts Neck High School (see Appendix B). The existing lighting inventory contained a total of 15 inefficient incandescent lamps. SWA recommends that each incandescent lamp is replaced with a more efficient, Compact Fluorescent Lamp (CFL). CFLs are capable of providing equivalent or better light output while using less power.

Installation cost:

Estimated installed cost: \$135 (includes \$75 of labor)

Source of cost estimate: RS Means; Published and established costs, NJ Clean Energy Program

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	therms, 1st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
135	0	135	904	0.2	0	0.0	265	405	5	2,023	0.3	1398	280	299	1,707	1,619

Assumptions: SWA calculated the savings for this measure using measurements taken the days of the field visits and using the observed occupancy assumptions.

Rebates/financial incentives:

- There is no incentive available for this measure at this time.

Please see Appendix F for more information on Incentive Programs.

ECM#2: Install Variable Frequency Drives on Motors of Heating Hot Water Circulators

The Mechanical Room houses two (2) pairs of floor-mounted circulator pumps as part of the hot water heating system to serve the hot water coils in the air handling units and other hot water terminal units listed in this report. The pumps that serve the 2001 additions are rated at 40 Hp each. Adding variable frequency drives (VFDs) to these two pumps will vary the flow according to the required heating capacity to better meet the load of the building. This set of pumps operates in a lead-lag fashion. The pump motors are on-off operation. Colts Neck High School will realize energy savings by utilizing variable frequency drives for the pump motors, and incorporating this new motor control method into the BMS programming.

Installation cost:

Estimated installed cost: \$20,000 (includes \$4,800 labor)

Source of cost estimate: RS Means Cost Data and Honeywell VFD Quick Savings Estimator

Economics (with no incentives):

Install VFDs on 40 Hp Hot Water Heating Pump Motors

est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
20,000	0	20,000	64,000	13.3	0	1.0	0	9,856	15	147,840	2.0	639	43	49	97,660	87,680

Assumptions: SWA calculated the savings for this measure using nameplate data taken and using the billing analysis. The Honeywell VFD Quick Savings Estimator was used with the assumption that one of each set of heating water pumps operates for the heating season. According to weather bin data for McGuire AFB, Trenton, NJ, each set of pumps considered should operate for approximately 4,000 hours per year.

Rebates/financial incentives:

NJ Clean Energy – There are no incentives at this time for hot water pump applications, only for chilled water pumps and centrifugal fans.

Please see Appendix F for more information on Incentive Programs.

ECM#3: Retrofit Two (2) Refrigerated Vending Machines with VendingMiser™ Devices

A simple plug and play device the VendingMiser™ device is compatible with refrigerated vending machines. It utilizes Passive Infrared Sensors (PIR) to help the vending machine save power. This unit is to be installed on the existing refrigerated vending machines.

Installation cost:

Estimated installed cost: \$398 (Includes \$40 of labor)

Source of cost estimate: *Manufacturers info*

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	therms, 1st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
398	0	398	1,109	0.2	N/A	0.1	0	171	5	854	2.3	115	23	43	2,511	1,986

Assumptions: SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis. Average weekly operating hours = 40.

Rebates/financial incentives:

NJ Clean Energy – None available for this ECM

Please see Appendix F for more information on Incentive Programs.

ECM#4: Retrofit Two (2) Existing Vending Machines with SnackMiser™ Devices

A simple plug and play device the VendingMiser™ device is compatible with refrigerated vending machines. It utilizes Passive Infrared Sensors (PIR) to help the vending machine save power. This unit is to be installed on the existing refrigerated vending machines.

Installation cost:

Estimated installed cost: \$198 (Includes \$40 of labor)
 Source of cost estimate: *Manufacturers info*

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	therms, 1st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
198	0	198	532	0.1	N/A	0.1	0	82	5	410	2.4	107	21	41	766	953

Assumptions: SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis. Average weekly operating hours = 40.

Rebates/financial incentives:

NJ Clean Energy – None available for this ECM

Please see Appendix F for more information on Incentive Programs.

ECM#5: Install Variable Frequency Drives on Motors of Heating Hot Water Circulators

The Mechanical Room houses two (2) pairs of floor-mounted circulator pumps as part of the hot water heating system to serve the hot water coils in the air handling units and other hot water terminal units listed in this report. The pumps that serve the original building are rated at 20 Hp each. Adding variable frequency drives (VFDs) to these two pumps will vary the flow according to the required heating capacity to better meet the load of the building. This set of pumps operates in a lead-lag fashion. The pump motors are on-off operation. Colts Neck High School will realize energy savings by utilizing variable frequency drives for the pump motors, and incorporating this new motor control method into the BMS programming.

Installation cost:

Estimated installed cost: \$13,500 (includes \$3,250 labor)

Source of cost estimate: RS Means Cost Data and Honeywell VFD Quick Savings Estimator

Economics (with no incentives):

Install VFDs on 20 Hp Hot Water Heating Pump Motors

est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
13,500	0	13,500	32,200	6.7	0	0.5	0	4,959	15	74,382	2.7	451	30	36	45,698	44,114

Assumptions: SWA calculated the savings for this measure using nameplate data taken and using the billing analysis. The Honeywell VFD Quick Savings Estimator was used with the assumption that one of each set of heating water pumps operates for the heating season. According to weather bin data for McGuire AFB, Trenton, NJ, each set of pumps considered should operate for approximately 4,000 hours per year.

Rebates/financial incentives:

NJ Clean Energy – There are no incentives at this time for hot water pump applications, only for chilled water pumps and centrifugal fans.

Please see Appendix F for more information on Incentive Programs.

ECM#6: Install Thirty (30) New Occupancy Sensors

On the days of the site visits, SWA completed a lighting inventory of Colts Neck High School (see Appendix B). The building contains twenty five areas that could benefit from the installation of thirty occupancy sensors. These areas consisted of various offices, meeting rooms, lounges, and bathrooms that could show energy savings by having the lights turn off after a period of no occupancy. Typically, occupancy sensors have an adjustable time delay that shuts down the lights automatically if no motion is detected within a set time period. Advanced micro-phonic lighting sensors include sound detection as a means to controlling lighting operation.

Installation cost:

Estimated installed cost: \$6,600 (includes \$2,400 of labor)

Source of cost estimate: *RS Means; Published and established costs, NJ Clean Energy Program*

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	Therms of Natural gas, 1 st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
6,600	600	6,000	12,460	2.6	0	0.2	0	1,919	15	28,783	3.1	380	25	31	16,579	22,310

Assumptions: SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis.

Rebates/financial incentives:

- *NJ Clean Energy – SmartStart – Wall-mounted Occupancy Sensors (\$20 per control)*
- *Maximum incentive amount: \$600*

Please see Appendix F for more information on Incentive Programs.

ECM#7: Install (27) New Bi-level T8 Fluorescent Fixtures in Stairwells

On the day of the site visit, SWA completed a lighting inventory of Colts Neck High School (see Appendix B). The school currently contains 27 T8 fluorescent lighting fixtures that are operated 16 hours per day in stairwells. New technology called bi-level lighting, combines fluorescent lighting fixtures with an occupancy sensor. These efficient light fixtures operate at a minimal light level in order to meet code and safety requirements and power up to a higher level when any motion is detected in the stairwells. Colts Neck High School would be an appropriate application for these fixtures since there are large periods of time when the stairwells should be unoccupied.

Installation cost:

Estimated installed cost: \$3,915 (includes \$1,620 of labor)

Source of cost estimate: *RS Means; Published and established costs, NJ Clean Energy Program*

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	Therms of Natural gas, 1 st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
4,590	675	3,915	6,623	1.4	0	0.1	0	1,020	15	15,298	3.8	291	19	25	8,086	11,858

Assumptions: SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis.

Rebates/financial incentives:

- *NJ Clean Energy – SmartStart – bi-level T8 fluorescent fixtures (\$25 per fixture)*
- *Maximum incentive amount: \$675*

Please see Appendix F for more information on Incentive Programs

ECM#8: Install Variable Frequency Drives on Motors of Chilled Water Circulators

The Mechanical Room houses two (2) pairs of floor-mounted circulator pumps as part of the chilled water system to serve the cooling coils in the air handling units and other terminal units listed in this report. The pumps that serve the 2001 additions are rated at 40 Hp each. Adding variable frequency drives (VFDs) to these two pumps will vary the flow according to the required cooling capacity to better meet the load of the building. This set of pumps operates in a lead-lag fashion. The pump motors are on-off operation. Colts Neck High School will realize energy savings by utilizing variable frequency drives for the pump motors, and incorporating this new motor control method into the BMS programming.

Installation cost:

Estimated installed cost: \$15,200 (includes \$4,800 labor)

Source of cost estimate: RS Means Cost Data and Honeywell VFD Quick Savings Estimator

Economics (with no incentives):

est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
20,000	4,800	15,200	24,100	5.0	0	0.4	0	3,711	15	55,671	4.1	266	18	23	29,106	33,017

Assumptions: SWA calculated the savings for this measure using nameplate data taken and using the billing analysis. The Honeywell VFD Quick Savings Estimator was used with the assumption that one of each set of chilled water pumps operates for the cooling season. According to weather bin data for McGuire AFB, Trenton, NJ, each set of pumps considered should operate for approximately 1,500 hours per year.

Rebates/financial incentives:

NJ Clean Energy – For 20 Hp+ Chilled Water Pumps, \$60 per VFD rated Hp.

Maximum incentive amount: \$4,800

Please see Appendix F for more information on Incentive Programs.

ECM#9: Install Premium Efficiency Motors on (2) Heating Hot Water Circulators

The Mechanical Room houses two pairs of pumps that serve the hot water heating system for the building. One pair of 40 Hp floor-mounted circulator pumps serves the hot water coils and other hot water terminal units in 2001 addition. These pumps are in good condition and are almost halfway through their expected service lives of 20 years. These pumps operate in a lead-lag fashion, and the pump motors are standard efficiency. Colts Neck High School will realize energy savings by utilizing premium efficiency motors for the existing pumps.

Installation cost:

Estimated installed cost: \$4,758 (includes \$1,270 labor)

Source of cost estimate: Similar projects and DOE Motor Master International selection & savings analysis

Economics (with incentives):

est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
5,082	324	4,758	5,632	1.2	0	0.1	0	867	20	17,347	5.5	265	13	18	8,146	7,716

Assumptions: SWA calculated the savings for this measure using nameplate data taken and using the billing analysis. The DOE Motor Master International selection and calculator was used with the assumption that one of each set of heating water pumps operates for the heating season. According to weather bin data for McGuire AFB, Trenton, NJ, each set of pumps considered should operate for approximately 4,000 hours per year.

Rebates/financial incentives:

NJ Clean Energy – Premium motors (\$45-\$700 per motor)

Maximum incentive amount: \$324

Please see Appendix F for more information on Incentive Programs.

ECM#10: Install Variable Frequency Drives on Motors of Chilled Water Circulators

The Mechanical Room houses two (2) pairs of floor-mounted circulator pumps as part of the chilled water system to serve the cooling coils in the air handling units and other terminal units listed in this report. The pumps that serve the original building are rated at 25 Hp each. Adding variable frequency drives (VFDs) to these two pumps will vary the flow according to the required cooling capacity to better meet the load of the building. This set of pumps operates in a lead-lag fashion. The pump motors are on-off operation. Colts Neck High School will realize energy savings by utilizing variable frequency drives for the pump motors, and incorporating this new motor control method into the BMS programming.

Installation cost:

Estimated installed cost: \$13,000 (includes \$3,850 labor)

Source of cost estimate: RS Means Cost Data and Honeywell VFD Quick Savings Estimator

Economics (with no incentives):

est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
16,000	3,000	13,000	15,100	3.1	0	0.2	0	2,325	15	34,881	5.6	168	11	16	14,760	20,687

Assumptions: SWA calculated the savings for this measure using nameplate data taken and using the billing analysis. The Honeywell VFD Quick Savings Estimator was used with the assumption that one of each set of chilled water pumps operates for the cooling season. According to weather bin data for McGuire AFB, Trenton, NJ, each set of pumps considered should operate for approximately 1,500 hours per year.

Rebates/financial incentives:

NJ Clean Energy – For 20 Hp+ Chilled Water Pumps, \$60 per VFD rated Hp.

Maximum incentive amount: \$3,000

Please see Appendix F for more information on Incentive Programs.

ECM's#11 & 13: Install 190.90 kW PV Rooftop System without Incentives or Install 49.68 kW PV Rooftop System with Incentives

Currently, the building does not use any renewable energy systems. Renewable energy systems such as photovoltaic (PV) panels can be mounted on the building roof facing south which can offset a portion of the purchased electricity for the building. Power stations generally have two separate electrical charges: usage and demand. Usage is the amount of electricity in kilowatt-hours that a building uses from month to month. Demand is the amount of electrical power that a building uses at any given instance in a month period. During the summer periods, electric demand at a power station is high, due to the amount of air conditioners, lights, and other equipment being used within the region. Demand charges increase to offset the utility's cost to provide enough electricity at that given time. Photovoltaic systems offset the amount of electricity used by a building and help to reduce the building's electric demand, resulting in a higher cost savings. Installing a PV system will offset electric demand and reduce annual electric consumption, while utilizing available state incentives. PV systems are modular and readily allow for future expansions.

The size of the system was determined considering the available roof surface area, without compromising service space for roof equipment and safety, as well as the facilities' annual base load and mode of operation. A PV system could be installed on a portion of the roof with panels facing south. A commercial multi-crystalline 230 watt panel has 17.5 square feet of surface area (providing 13.1 watts per square foot). A 47.38 kW system needs approximately 206 panels which would take up 3,605 square feet. The larger 140.07 kW system would require approximately 609 panels which would take up 10,660 square feet.

A PV system would reduce the building's electric load and allow more capacity for surrounding buildings as well as serve as an example of energy efficiency for the community. The building is not eligible for a residential 30% federal tax credit. Colts Neck High School may want to consider applying for a grant and / or engage a PV generator / leaser who would install the PV system and then sell the power at a reduced rate. Typically, a major utility provides the ability to buy SREC's at \$600/MWh or best market offer.

Two different system sizes were proposed due to installation incentives only being offered for systems less than 50kW in size. The first option takes advantage of these incentives by staying below the 50kW system threshold, and the second option takes advantage of the total usable space on the school's roof to install a PV system. SWA recommends installing the larger system; however, if sufficient funding is not available, Colts Neck High School should at least install the 47.38kW system. As mentioned above, these systems are modular and can be expanded in the future.

Please note that this analysis did not consider the structural capability of the existing building to support the above recommended system. SWA recommends that Colts Neck High School contract with a structural engineer to determine if additional building structure is required to support the recommended system and what costs would be associated with incorporating the additional supports prior to system installation. Should additional costs be identified, Colts Neck High School should include these costs in the financial analysis of the project.

Installation cost:

Estimated installed cost – 47.38 kW system: \$332,850 (includes \$127,000 of labor)

Estimated installed cost – 140.07 kW system: \$1,050,525 (includes \$375,425 of labor)

Source of cost estimate: Similar projects.

Economics (with incentives):

ECM#11: Install 49.68 kW PV Rooftop System with Incentives

Install a 47.38 kW PV System with Incentives																																	
est. installed cost, \$	355,350	est. incentives, \$	22,500	net est. ECM cost with incentives, \$	332,850	kWh, 1st yr savings	58,007	kW, demand reduction/mo	47	therms, 1st yr savings	0	kBtu/sq ft, 1st yr savings	0.9	est. operating cost, 1st yr savings, \$	0	total 1st yr savings, \$	43,733	life of measure, yrs	25	est. lifetime cost savings, \$	223,327	simple payback, yrs	7.6	lifetime return on investment, %	123.9	annual return on investment, %	5.0	internal rate of return, %	10.6	net present value, \$	238,143	CO ₂ reduced, lbs/yr	79,470

cash flow yr	0	1	2	3	4	5	6	7	8	9	10	11
	-332,850	43,733	43,733	43,733	43,733	43,733	43,733	43,733	43,733	43,733	43,733	43,733

cash flow yr	12	13	14	15	16	17	18	19	20	21	22	23	24	25
	43,733	43,733	43,733	43,733	8,933	8,933	8,933	8,933	8,933	8,933	8,933	8,933	8,933	8,933

ECM's#13: Install 190.90 kW PV Rooftop System without Incentives

Install a 140.07 kW PV System with Incentives																																			
est. installed cost, \$	1,050,525	est. incentives, \$	0	net est. ECM cost with incentives, \$	1,050,525	kWh, 1st yr savings	169,888	kW, demand reduction/mo	140	therms, 1st yr savings	0	kBtu/sq ft, 1st yr savings	2.6	est. operating cost, 1st yr savings, \$	0	total 1st yr savings, \$	127,563	life of measure, yrs	25	est. lifetime cost savings, \$	654,069	simple payback, yrs	8.2	lifetime return on investment, %	107.0	annual return on investment, %	4.3	internal rate of return, %	9.4	net present value, \$	615,557	CO ₂ reduced, lbs/yr	232,747	estimated cost of labor, \$	375,425

cash flow yr 0	cash flow yr 1	cash flow yr 2	cash flow yr 3	cash flow yr 4	cash flow yr 5	cash flow yr 6	cash flow yr 7	cash flow yr 8	cash flow yr 9
-1, 050,525	127,563	127,563	127,563	127,563	127,563	127,563	127,563	127,563	127,563

cash flow yr 10	cash flow yr 11	cash flow yr 12	cash flow yr 13	cash flow yr 14	cash flow yr 15	cash flow yr 16	cash flow yr 17	cash flow yr 18	cash flow yr 19	cash flow yr 20
127,563	127,563	127,563	127,563	127,563	127,563	26,163	26,163	26,163	26,163	26,163

cash flow yr 21	cash flow yr 22	cash flow yr 23	cash flow yr 24	cash flow yr 25
26,163	26,163	26,163	26,163	26,163

Assumptions: SWA estimated the cost and savings of the system based on past PV projects. SWA projected physical dimensions based on a typical Polycrystalline Solar Panel (230 Watts, model #ND-U230C1). PV systems are sized based on Watts and physical dimensions for an array will differ with the efficiency of a given solar panel (W/sq ft).

Rebates/financial incentives:

NJ Clean Energy - Renewable Energy Incentive Program, Incentive based on \$0.75 / watt Solar PV application up to the first 30 kW for systems 50 kW or less. Incentive amount for this application is \$22,500 for the 47.38 kW proposed option. There are no associated incentives for the larger 140.07 kW system due to the NJ Clean Energy - Renewable Energy Incentive Program’s cap on the size of the PV system.

<http://www.njcleanenergy.com/renewable-energy/programs/renewable-energy-incentive-program>

NJ Clean Energy - Solar Renewable Energy Certificate Program. Each time a solar electric system generates 1,000kWh (1MWh) of electricity, a SREC is issued which can then be sold or traded separately from the power. The buildings must also become net-metered in order to earn SRECs as well as sell power back to the electric grid. A total annual SREC credit of \$34,800 has been incorporated in the above costs for the 47.38 kW system and an annual SREC credit of \$101,400 for the 140.07 kW system; however, it requires proof of performance, application approval and negotiations with the utility.

Please see Appendix F for more information on Incentive Programs.

ECM#12: Replace Seven (7) Compact Refrigerators with 2.7 Cu. Ft. ENERGY STAR® Models

On the day of the site visit, SWA observed that there were seven older 2.7 cu. ft. model refrigerators that are not ENERGY STAR® rated (using approximately 254 kWh/year). Appliances, such as refrigerators, that are over 10 years of age should be replaced with newer efficient models with the Energy Star label. SWA recommends the replacement of the older model compact refrigerators with a 2.7 cf. ft. ENERGY STAR® model or equivalent. Besides saving energy, the replacement will also keep their surroundings cooler. When compared to the average electrical consumption of older equipment, Energy Star equipment results in large savings. Look for the Energy Star label when replacing appliances and equipment, including: window air conditioners, refrigerators, printers, computers, copy machines, etc. More information can be found in the “Products” section of the Energy Star website at: <http://www.energystar.gov>.

Installation cost:

Estimated installed cost: \$693 (Includes \$115 in labor cost)

Source of cost estimate: Manufacturer and Store established costs

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	therms, 1st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
693	0	693	560	0.1	0	0.1	0	86	15	1,294	8.0	87	6	9	322	1,003

Assumptions: SWA calculated the savings for this measure using measurements taken the day of the field visit and using the billing analysis aggregate utility rate.

Rebates/financial incentives:

- There is no incentive available for this measure at this time.

Please see Appendix F for more information on Incentive Programs.

ECM#14: Replace Two (2) Washing Machines with ENERGY STAR® Units

On the day of the site visit, SWA observed that there were two older model washing machines installed. SWA recommends replacing these units with two new ENERGY STAR® labeled washing machines.

Installation cost:

Estimated installed cost: \$1,600 (includes \$100 of labor)
 Source of cost estimate: Manufacturer

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	Therms of Natural gas, 1 st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
1,600	0	1,600	1,000	0.2	0	0.1	17	171	15	2,565	9.4	60	4	7	412	1,791

Assumptions: SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis.

Rebates/financial incentives:

- None

Please see Appendix F for more information on Incentive Programs

ECM#15: Replace Seventeen (17) Large Refrigerators with ENERGY STAR® Units

On the day of the site visit, SWA observed that there were seventeen older 17 cu. ft. model inefficient refrigerators in the apartment units which were not Energy Star rated (using approximately 773 kWh/yr each). Appliances, such as refrigerators, that are over 10 years of age should be replaced with newer efficient models with the Energy Star label. SWA recommends the replacement of the existing older refrigerators with a 17 cu. ft. top freezer refrigerator ENERGY STAR®, or equivalent. Besides saving energy, the replacement will also keep their surroundings cooler. When compared to the average electrical consumption of older equipment, Energy Star equipment results in large savings. Look for the Energy Star label when replacing appliances and equipment, including: window air conditioners, refrigerators, printers, computers, copy machines, etc. More information can be found in the “Products” section of the Energy Star website at: <http://www.energystar.gov>.

Installation cost:

Estimated installed cost: \$7,650 (includes \$1,700 of labor)
Source of cost estimate: Manufacturer

Economics:

est. installed cost, \$	est. incentives, \$	Net est. cost with incentives, \$	kWh, 1st year savings	kW, demand reduction	Therms of Natural gas, 1 st year savings	kBtu/sq ft, 1st year savings	Est. operating cost, 1st year savings, \$	Total 1st year savings, \$	Life of measure, years	Est. lifetime energy cost savings, \$	Simple payback, years	Lifetime return-on-investment, %	Annual return-on-investment, %	Internal rate of return, %	Net present value, \$	CO ₂ reduced, lbs/year
7,650	0	7,650	5,100	1.1	0	0.1	0	785	15	11,781	9.7	54	4	6	1,592	9,132

Assumptions: SWA calculated the savings for this measure using measurements taken the days of the field visits and using the billing analysis.

Rebates/financial incentives:

- None

Please see Appendix F for more information on Incentive Programs

ECM#16: Install Premium Efficiency Motors on Walk-In Box Evaporator Fans

There is one walk-in cooler box and one walk-in freezer box in the Kitchen of Colts Neck High School. Typically, the evaporator and condenser fans of walk-in coolers will run 24 hours per day, 7 days per week for a cooler and 18 hours per day, 7 days per week. The motors on these fans are standard efficiency, shaded pole motors. The freezer fans could not be observed at the time of the survey since the cooler door was locked, but it is assumed that on average for this size box, there will be approximately (3) evaporator motors. It is assumed the motors are fractional horsepower. Colts Neck High School will realize energy savings by utilizing premium efficiency motors for these fans.

Installation cost:

Estimated installed cost: \$3,500 (includes \$1,300 of labor)

Source of cost estimate: Similar projects and manufacturer's data

Economics (with incentives):

est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime energy cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
3,500	0	3,500	2,283	0.5	0	0.0	0	352	20	7,032	10.0	101	5	8	1,731	3,128

Assumptions: SWA calculated the savings for this measure using nameplate data taken and using the billing analysis. Calculations were completed with the assumption that all of the cooler fans operate for 8,760 hours per year and all of the freezer fans operate for 6,570 hours per year.

Rebates/financial incentives:

NJ Clean Energy – There are no incentives available since these are single phase, fractional horsepower motors

Please see Appendix F for more information on Incentive Programs.

PROPOSED FURTHER RECOMMENDATIONS

Capital Improvements

Capital Improvements are recommendations for the building that may not be cost-effective at the current time, but that could yield a significant long-term payback. These recommendations should typically be considered as part of a long-term capital improvement plan. Capital improvements should be considered if additional funds are made available, or if the installed costs can be shared with other improvements, such as major building renovations. SWA recommends the following capital improvements for the Colts Neck High School:

- Install premium motors when replacements are required - Select NEMA Premium motors when replacing motors that have reached the end of their useful operating lives.
- Install energy efficient clothes dryers when replacements are required – Select the most energy efficient replacement unit since ENERGY STAR® does not qualify clothes dryers.
- Replace Domestic Water Heaters - The domestic water heaters in the boiler room are nearing the end of their expected service life. Since these units were originally very efficient for equipment of its type, replacement cannot be justified by energy savings alone. Based on the capacity of these heaters, a suitable replacement would be similar to the Aerco Model KC-1000. Replacement cost is estimated to be \$60,000 and the estimated simple payback is 47 years.
- Replace Hot and Chilled Water Fan Coil Rooftop Units – Various units on the roof are approaching the end of their useful life per 2007 ASHRAE Applications Handbook. Should the maintenance on the units become more frequent, replacement should be considered. This is a replacement in kind measure that offers negligible energy savings. Estimated replacement cost is \$20,000-\$25,000 per unit.
- Provide dedicated makeup air unit for Kitchen – Per the current system operation, conditioned air from the Cafeteria is transferred to the kitchen and out of the building via the kitchen hood. SWA recommends adding a dedicated makeup air unit to be ducted into the kitchen to greatly reduce the need for conditioned transfer air from the Cafeteria to serve the kitchen hood.
- Consider replacement of the condensing units for the walk-in cooler and walk-in freezer. Both the cooler and freezer utilize remote condensing units for heat rejection that located on the roof. SWA recommends that this equipment is replaced as part of the replacement of the walk-in boxes. The condensing units are labeled as using R-22 refrigerant, which is not as environmentally friendly as R-404a that would be used in a replacement unit by the same manufacturer. Estimated cost to replace both condensing units is \$12,000.

Operations and Maintenance

Operations and Maintenance measures consist of low/no cost measures that are within the capability of the current building staff to handle. These measures typically require little investment, and they yield a short payback period. These measures may address equipment settings or staff operations that, when addressed will reduce energy consumption or costs.

- Repair damaged EIFS façade areas.

- Inspect and replace cracked/ineffective caulk.
- Install/repair and maintain flashing to minimize uncontrolled wind-driven and roof water run-off causing exterior wall damage.
- Maintain roofs - SWA recommends regular maintenance to verify water is draining correctly.
- Maintain downspouts and cap flashing - Repair/install missing downspouts and cap flashing as needed to prevent water/moisture infiltration and insulation damage. SWA recommends round downspout elbows to minimize clogging.
- Provide weather-stripping/air-sealing - SWA observed that exterior door weather-stripping was beginning to deteriorate in places. Doors and vestibules should be observed annually for deficient weather-stripping and replaced as needed. The perimeter of all window frames should also be regularly inspected, and any missing or deteriorated caulking should be re-caulked to provide an unbroken seal around the window frames. Any other accessible gaps or penetrations in the thermal envelope penetrations should also be sealed with caulk or spray foam.
- Repair/seal wall cracks and penetrations - SWA recommends as part of the maintenance program installing weep holes, installing proper flashing and correct masonry efflorescence, and sealing wall cracks and penetrations wherever necessary in order to keep insulation dry and effective.
- Provide water-efficient fixtures and controls - Adding controlled on/off timers on all lavatory faucets is a cost-effective way to reduce domestic hot water demand and save water. Building staff can also easily install faucet aerators and/or low-flow fixtures to reduce water consumption. There are many retrofit options, which can be installed now or incorporated as equipment is replaced. Routine maintenance practices that identify and quickly address water leaks are a low-cost way to save water and energy. Retrofitting with more efficient water-consumption fixtures/appliances will reduce energy consumption for water heating, while also decreasing water/sewer bills.
- Boilers and building piping insulation - Insulate un-insulated heating piping throughout the building to efficiently deliver heat where required and provide personnel protection.
- Water levels in the expansion tanks and the integrity of the tank bladder should be checked on a regular basis to confirm proper operation.
- For Aerco condensing boiler, inspect the igniter and flame sensor and calibrate combustion every six months per manufacturer's recommendations.
- Change filters in rooftop units and air handling units monthly to ensure efficient operation of the fan, ensure adequate air delivery to the space.
- Tighten belts on exhaust fans and air handling unit supply fans every three to six months – tightening belts on belt-driven fans can maximize overall efficiency of the equipment.
- Inspect condensate pan and drain line on all RTUs and air handling units. Remove sludge or foreign materials that might obstruct proper drainage.

- Inspect and replace gasketing around door into (2) walk-in refrigeration boxes. Ineffective gasketing allows infiltration of warm air into the walk-in box, which increases the run-time of the compressors.
- Reevaluate and optimize the building occupancy schedule for the cooling system controls - modify the existing building occupancy schedule for the cooling system controls to eliminate cooling of unoccupied areas.
- SWA recommends that the building considers purchasing the most energy-efficient equipment, including ENERGY STAR® labeled appliances, when equipment is installed or replaced. More information can be found in the “Products” section of the ENERGY STAR® website at: <http://www.energystar.gov>.
- Use smart power electric strips - in conjunction with occupancy sensors to power down computer equipment when left unattended for extended periods of time. Create an energy educational program - that teaches how to minimize energy use. The U.S. Department of Energy offers free information for hosting energy efficiency educational programs and plans. For more information please visit: <http://www1.eere.energy.gov/education/>.

The recommended ECMs and the list above are cost-effective energy efficiency measures and building upgrades that will reduce operating expenses for the Freehold RHSD. Based on the requirements of the LGEA program, the Freehold RHSD must commit to implementing some of these measures, and must submit paperwork to the Local Government Energy Audit program within one year of this report's approval to demonstrate that they have spent, net of other NJCEP incentives, at least 25% of the cost of the audit (per building). The Colts Neck High School should spend a minimum of \$4,566 (or 25% of \$18,262) worth of ECMs, net of other NJCEP incentives, to fulfill the obligations.

APPENDIX A: EQUIPMENT LIST

Inventory

Building System	Description	Model #	Fuel	Location	Space Served	Date Installed	Estimated Remaining Useful Life %
Ventilation	Exhaust Fan "D10"	Penn #LC12A	Electric	Roof	Mech Equip Room	1997	30%
Ventilation	Exhaust Fan	Dayton #4YC86G S/N#05F13910	Electric	Roof	Mech Equip Room	1997	30%
Ventilation	Exhaust Fan	Cook #225ACRU S/N#2145890730 460V-3Ph, 1.5HP	Electric	Roof	Mech Equip Room	2006	70%
Ventilation	Exhaust Fan	Dayton #4YC86G S/N#05E28826	Electric	Roof	Mech Equip Room	1997	30%
Cooling	RTU "D3"	McQuay #RDS800CYY S/N#37H01044 460V-3Ph	Electric	Roof above Faculty/Kitchen	D wing	1997	15%
Ventilation	(2) Exhaust Fans "D9&8"	Penn #LC12A	Electric	Roof above Faculty/Kitchen	D wing	1997	30%
Refrigeration	Condensing Unit	ColdZone #ORE-S30L2-2T S/N#G9714689-061 208-3Ph, 30A, R-22	Electric	Roof above Faculty/Kitchen	D wing	1997	15%
Refrigeration	Condensing Unit	ColdZone #ORE-S15H2-2T S/N#G9714689-011 208V-3PH, 30A, R-22	Electric	Roof above Faculty/Kitchen	D wing	1997	15%
Cooling	RTU "E1"	McQuay #RAH047CLY S/N#37H01046 460V-3Ph, 33MCA	Electric	Roof above Kitchen	D wing	1997	15%
Ventilation	Exhaust Fan "E2"	Penn #LC14A	Electric	Roof above D Corridor	D wing	1997	30%
Ventilation	Exhaust Fan "D7"	Penn #FX30 BFT	Electric	Roof above Kitchen	D wing	1997	30%
Cooling	RTU "D1"	McQuay #RDS800CYY S/N#37H01042 460V-3Ph, 33MCA	Electric	Roof above Cafeteria	D wing	1997	15%
Ventilation	Exhaust Fan "D5"	Penn #FX14B	Electric	Roof above Cafeteria	D wing	1997	30%
Ventilation	Energy Recovery Ventilator	Venmar #ERV1500 S/N#6D8120010901616 460V-3Ph, 3/4HP	Electric	Roof above Cafeteria	RTU D6	2001	50%
Cooling	RTU "D6"	McQuay #RDS708BY S/N#FB0U011100034 460V-3Ph, 6 MCA	Electric	Roof above Faculty	Faculty/Dining Lounge	2001	40%
Cooling	RTU "D4"	McQuay #RDS708BY S/N#37H01045 460V-3Ph, 15 MCA	Electric	Roof above Cafeteria	D wing	1997	15%
Cooling	RTU "D2"	McQuay #RDS800CYY S/N#37H01043 460V-3Ph, 15 MCA	Electric	Roof above Cafeteria	D wing	1997	15%
Continued on next page							

Continued from previous page							
Building System	Description	Model #	Fuel	Location	Space Served	Date Installed	Estimated Remaining Useful Life %
Ventilation	Exhaust Fan "D4"	Penn #LC12A	Electric	Roof above Cafeteria	D wing	1997	30%
Ventilation	Energy Recovery Ventilator	Venmar #ERV3000 S/N#6J8120010901622 460V-3Ph, 3 HP	Electric	Roof above Cafeteria	RTU D5	2001	50%
Cooling	RTU "D5"	McQuay #RDS708BY S/N#FB0U011100033 460V-3Ph, 14 MCA	Electric	Roof above Cafeteria	Cafeteria	2001	40%
Ventilation	Exhaust Fan "E1"	Penn #LC16A	Electric	Roof above Student Store	Student Store	1997	30%
Cooling	RTU "E4"	McQuay #RDS708BY S/N#FB0U011100071 460V-3Ph, 4 MCA	Electric	Roof above Art Classrooms	Art Classrooms	2001	40%
Ventilation	(4) Exhaust Fans	No Markings	Electric	Roof above Art Classrooms	Art Classrooms	1997	30%
Cooling	RTU "E2"	McQuay #RDS708BY S/N#37H01047 460V-3Ph, 15 MCA	Electric	Roof above Art Classrooms	Art Classrooms	1997	15%
Cooling	RTU "E3"	McQuay #RDS708BY S/N#37H01048 460V-3Ph, 15 MCA	Electric	Roof above Art Classrooms	Art Classrooms	1997	15%
Ventilation	Exhaust Fan	Penn #LC12A	Electric	Roof above Music	Music Rooms	1997	30%
Ventilation	Exhaust Fan "A5"	Penn #LC14A	Electric	Roof above A wing	A wing rooms	1997	30%
Cooling	RTU "A2"	McQuay #RDS800CYY S/N#37H01040 460V-3Ph, 17 MCA	Electric	Roof above A wing	A wing rooms	1997	15%
Cooling	RTU "A1"	McQuay #RAH047CLY S/N#37H01039 460V-3Ph, 33 MCA	Electric	Roof above A wing	A wing rooms	1997	15%
Ventilation	Exhaust Fan "A4"	Penn #LC14A	Electric	Roof above A wing	A wing rooms	1997	30%
Ventilation	Exhaust Fan "A14"	Penn #LC20A	Electric	Roof above A wing	A wing rooms	1997	30%
Ventilation	(3) Supply Fans "A4", "A3" & "A1"	Penn #MU3010	Electric	Roof above A wing	A wing rooms	1997	30%
Ventilation	(3) Upblast Fans "A12", "A13" & "A9"	Penn #FMX12T	Electric	Roof above A wing	A wing rooms	1997	30%
Ventilation	Exhaust Fan	Dayton #4YC676 S/N#11258147 0803	Electric	Roof above A wing	A wing rooms	1997	30%
Ventilation	(7) Exhaust Fans "A1, 2, 3, 6, 7, 10, 11"	Penn	Electric	Roof above A wing	A wing rooms	1997	30%
Continued on next page							

Continued from previous page

Building System	Description	Model #	Fuel	Location	Space Served	Date Installed	Estimated Remaining Useful Life %
Ventilation	(2) Exhaust Fans	Carnes #VUDK10J3A1UA14 S/N#313741.008	Electric	Roof above A wing expansion	"2 nd Fl Fumehood"	2001	55%
Ventilation	(2) Exhaust Fans "RV-1" & "RV-2"	Greenheck #GRSR-12 S/N#02C22692/91	Electric	Roof above A wing expansion	A wing expansion classrooms	2001	55%
Ventilation	(8) Exhaust Fans	Carnes # varies	Electric	Roof above A wing expansion	A wing expansion classrooms	2001	55%
Cooling	RTU	McQuay #RDS708BY S#37H0068903 460V-3PH, 15A	Electric	Roof above B Classrooms	B rooms and surrounding area	1997	15%
Cooling	RTU	McQuay #RDS708BY S#37H0068803 460V-3PH, 15A	Electric	Roof above Nurse area	Front offices	1997	15%
Cooling	RTU 'B3'	McQuay #RDS800CYY S#37H0104100 460V-3PH, 17A	Electric	Roof above Media Center	Media Center	1997	15%
Cooling	RTU 'B1'	McQuay #RDS708BY S#37H0068703 460V-3PH, 15A	Electric	Roof above Media Center	Main Entrance, A Wing Classrooms	1997	15%
Ventilation	Exhaust Fan 'EF B5'	Penn # LC12A	Electric	Roof above IT room	IT room	1997	30%
Ventilation	Exhaust Fan 'EF B3'	Penn # LC12A	Electric	Roof above office/corridor	Office area	1997	30%
Ventilation	Exhaust Fan 'EF B2'	Penn # LC14A	Electric	Roof above office/corridor	Office area	1997	30%
Ventilation	Exhaust Fan 'EF B4'	Penn # LC12A	Electric	Roof above B101	B101 restrooms	1997	30%
Ventilation	(8) Exhaust Fans (EF C1 thru C8)	Penn #LC40A 3 phase	Electric	Gymnasium Roof	Gymnasium	1997	30%
Cooling	RTU 'C9'	McQuay #RDS802CYY S#FBOUO1110002500 460-3PH, 14 MCA Std Eff. Supply fan 7.5HP	Electric	Roof next to Auxiliary Gym	Auxiliary Gym	2001	55%
Ventilation	Exhaust Fan 'C2'	Carnes M#VEBK10K2A1UA20SPC1 115V, 1/6HP	Electric	Roof next to Auxiliary Gym	Restrooms	2001	55%
Ventilation	Exhaust Fan 'C1'	Carnes M#VEBK10K2A1UA20SPC1 115V, 1/4HP	Electric	Roof next to Auxiliary Gym	C100 thru C102	2001	55%
Ventilation	Exhaust Fan 'B6'	Carnes M#VEBK21W1G1UA20SPC1 480V-3PH, 3HP	Electric	A wing Roof	A wing addition, first floor	2001	55%
Ventilation	(8) Roof Vents	Carnes #GSAA series	Electric	A wing roof	A wing addition	2001	55%

Continued on next page

Continued from previous page

Building System	Description	Model #	Fuel	Location	Space Served	Date Installed	Estimated Remaining Useful Life %
Cooling	RTU 'B5'	McQuay #RDS708BY S#FBOUO1110003203	Electric	A wing roof	A wing addition	2001	55%
Ventilation	Exhaust Fan 'B2'	Carnes #VEBK12L1AUA20SPC1 S#313741003 115v, 1/4HP	Electric	A wing roof	A Wing addition	2001	55%
Cooling	RTU 'A5'	McQuay #RDS708BY S#FBOUO1110003103	Electric	A Wing roof	A wing addition	2001	55%
Ventilation	Exhaust Fan	Carnes #VBK12L1A1UA20SPC1 S#313741.002 115V, 1/4HP	Electric	A wing roof	A wing addition	2001	55%
Cooling	RTU 'A4'	McQuay #RDS708BY S#FBOUO1110007203	Electric	A Wing roof	A wing addition	2001	55%
Cooling	RTU 'A3'	McQuay #RDS800CYY S#FBOUO1110002400	Electric	A Wing roof	A wing addition	2001	55%
Ventilation	Exhaust Fan 'A1'	Carnes #VEBK21T1G1UA20SPC1 S#313741.001 480v-3PH, 1.5HP	Electric	A wing roof	A wing addition restrooms	2001	55%
Ventilation	(2) Exhaust Fans	Carnes #VUDK10J3A1UA14SPC1 115V, 1/8HP	Electric	A wing roof	A wing fume hoods	2001	55%
Heating	(3) Boilers 80% Eff.	Smith Cast Iron #M450A, 17 sections, 3849 MBH water 5474 gas MBH	Gas	Mechanical Room	Original Building	1998	60%
Heating	Boiler 90% Eff.	Aerco Benchmark 2.0 S/N# G010762	Gas	Mechanical Room	Additions	2002	70%
Heating	Boiler burner	Powerflame burner #HAC4C-G02 S/N#059779406 480V-3Ph, 5 HP	Gas	Mechanical Room	Original Building Boilers	1998	40%
Domestic Hot Water	(2) Water Heaters 90% Eff.	A.O.Smith Legend 2000 #LW1000 920 1000 MBH S/N#C97 37119 S/N#L96 34717	Gas	Mechanical Room	Entire School	1998	15%
Heating	(2) Boiler Pumps 90% Eff.	Bell & Gossett T661 #D40E20, 40HP, 1760RPM	Electric	Mechanical Room	2001 Additions	1998	40%
Heating	(2) Boiler Pumps 93% Eff.	US Electric #R352B 20HP, 1775RPM "premium efficiency"	Electric	Mechanical Room	Original Building	1998	40%
Cooling	Chiller 9.5 EER	McQuay #ALS270CS27-ER11 S/N#STNU011100066 460V-3Ph, 526 MCA	Electric	Grass area outside mechanical room	2001 Additions	2001	55%

Continued on next page

Continued from previous page

Building System	Description	Model #	Fuel	Location	Space Served	Date Installed	Estimated Remaining Useful Life %
Cooling	Chiller	McQuay #PEH087-ABBB S#57F81016-00	Electric	Mechanical Room	Original Building	1998	40%
Cooling	(2) Chiller Pumps 93% Eff.	US Electric #J364A 25 HP "premium efficiency"	Electric	Mechanical Room	Original Building	1998	40%
Cooling	(2) Chiller Pumps 90% Eff.	Bell & Gossett 1510BF 40HP, 562 GPM	Electric	Mechanical Room	Additions	1998	40%
Power	Generator	M#100GS60 S#382723 100KW, 125 KVA	Diesel	Mechanical Room	Boilers, Em Ltg, Walk In Coolers	1998	40%
Heating / Cooling	(38) Floor Mounted Unit Ventilators	McQuay "AAF" Series	Electric	A Wing	A wing classrooms	1998 & 2001	40% to 55%
Heating / Cooling	Above Ceiling Fan Coil Unit	McQuay (no visible nameplate)	Electric	A Wing	A125	1998	40%
Heating / Cooling	(3) Floor Mounted Unit Ventilators	McQuay "AAF" Series	Electric	C Wing	C wing classrooms	2001	55%
Heating / Cooling	Above Ceiling Fan Coil Unit	McQuay (no visible nameplate)	Electric	Mechanical / Janitor Room	Mechanical / Janitor Room	1998	40%
Heating	HW Unit Heaters	McQuay unit heaters	Electric	Various	Mech Wing, Cafeteria, Gym storage	1998	40%
Heating / Cooling	(2) 45 Ton Air Handling Units	McQuay #LSL137DH S#97B0075000 S#97B0075100	Electric	Gym Mezzanine	Gym	1998	40%
Heating / Cooling	(2) 10 Ton Air Handling Units	McQuay #LSL108CH S#37D00932-06 S#37D00934-06	Electric	Gym Mezzanine	Gym	1998	40%
Heating / Cooling	(2) Air Handling Units	McQuay #LSL106CH S#37D00931-06 Second unit not readable	Electric	Gym Mezzanine	Gym	1998	40%
Heating / Cooling	Air Handling Unit	Large Air handler (no accessible nameplate)	Electric	Auditorium stage ceiling	Auditorium	1998	40%
Heating / Cooling	Above Ceiling Fan Coil Unit	McQuay (no visible nameplate)	Electric	Media Room	Media Room	1998	40%
Heating / Cooling	Ceiling or wall Unit Ventilators	McQuay (no visible nameplate)	Electric	Various	Entrance vestibules, stairwells	1998	40%

Continued on next page

Continued from previous page

Building System	Description	Model #	Fuel	Location	Space Served	Date Installed	Estimated Remaining Useful Life %
Motor	Elevator motor	Schindler 300A, 20HP, 480V	Electric	Elevator Machine Room	Elevator	1998	40%
Refrigeration	Commercial Refrigerator	Traulsen #AHT232WREHHS S#T725420F97 115V-1 Ph, 10.4A	Electric	Kitchen	Kitchen	1998	40%
Refrigeration	(2) Commercial Refrigerators	Traulsen #AHT132WREHHS S#T725410F97 S#T725440F97 115V-1 Ph, 10.4A	Electric	Kitchen	Kitchen	1998	40%
Cooking	(4) Fryers	Wells #F856, 480V, 14A	Electric	Kitchen	Kitchen	1998	30%
Cooking	(2) Griddle	Wells #G136, 208V-3 Ph, 28A	Electric	Kitchen	Kitchen	1998	30%
Cooking	Range & Fryer	Garland #M35, 110 MBH	Natural Gas	Kitchen	Kitchen	1998	30%
Cooking	Steam Generator: Cleveland Steam	Nameplate not accessible	Natural Gas	Kitchen	Kitchen	1998	30%
Cooking	Ovens	Garland 'Master' double oven Nameplate note accessible	Natural Gas	Kitchen	Kitchen	1998	30%
Warming	Heating Cabinet	Traulsen No nameplate	Electric	Kitchen	Kitchen	1998	30%
Warming	Heating wells	Wells No Nameplate	Electric	Kitchen	Kitchen	1998	30%
Misc.	Dishwasher	Hobart #CRS66A S#85-1004678 208-3Ph, 59A	Electric	Kitchen	Kitchen	1998	30%
Refrigeration	Walk-in Cooler / Freezer	Tafco 16'x16' (split in 2 sections) No nameplate data	Electric	Kitchen	Kitchen	1998	40%
Misc	Ice Machine	Hoshizaki #KM-630MAE	Electric	Kitchen	Kitchen	1998	40%
Refrigeration	Fridge/ Freezer	Nortland imperial #U305P-1436 S#98C862198	Electric	Kitchen	Kitchen	1998	40%
Refrigeration	Commercial Refrigerator	Traulsen #ADH132WREHHS S#T25450F97	Electric	Faculty Kitchen	Faculty	1998	40%

Continued on next page

Continued from previous page							
Building System	Description	Model #	Fuel	Location	Space Served	Date Installed	Estimated Remaining Useful Life %
Refrigeration	Commercial Refrigerator	Coca Cola True#GDM-26 S#4901254	Electric	Faculty Kitchen	Faculty	1998	40%
Ventilation	(14) Fume Hoods	EnviroAire or Fisher Hamilton	Electric	Various Lab Rooms	Labs	1998 & 2001	40%
Kiln	Kiln	Bailey 24-24-38 Type A-1 240V, 72A	Electric	E101	E101	1998	30%
Lighting	See details - Appendix B	-	Electric	See details - Appendix B	Library	1998 and 2001	varies

Note: The remaining useful life of a system (in %) is an estimate based on the system date of built and existing conditions derived from visual inspection.

Appendix B: Lighting Study

Marker	Floor	Location	Existing Fixture Information											Propose Information						Annual Savings									
			Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Voltage	Total Watts	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Voltage	Total Watts	Energy Use kWh/Year	Future Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)
1		Vestibule - Exit 71	Recessed	E	478	1	3	32	5w	24	365	5	885	N/A	Recessed	E	478	3	32	24	365	5	101	885	0	0	0	0	0
2		Mechanical Room	Parabolic Ceiling Suspended	E	478	14	3	32	5w	9	365	5	1,414	N/A	Parabolic Ceiling Suspended	E	478	14	3	32	9	365	5	1,414	4,645	0	0	0	
3		Mechanical Room	Exit Sign	E	LED	2	1	5	5w	24	365	1	91	N/A	Parabolic Ceiling Suspended	E	478	2	1	5	24	365	1	111	91	0	0	0	
4		Storage Treatment	Parabolic Ceiling Suspended	E	478	18	2	32	5w	4	365	5	1,242	N/A	Parabolic Ceiling Suspended	E	478	18	2	32	4	365	5	1,242	1,813	0	0	0	
5		Storage Treatment	Parabolic Ceiling Suspended	E	478	18	2	32	5w	4	365	5	1,242	N/A	Parabolic Ceiling Suspended	E	478	18	2	32	4	365	5	1,242	1,813	0	0	0	
6		Storage Treatment	Parabolic Ceiling Suspended	E	478	18	2	32	5w	4	365	5	1,242	N/A	Parabolic Ceiling Suspended	E	478	18	2	32	4	365	5	1,242	1,813	0	0	0	
7		Storage Room	Parabolic Ceiling Suspended	E	478	1	2	32	5w	4	365	5	48	N/A	Parabolic Ceiling Suspended	E	478	1	2	32	4	365	5	48	48	0	0	0	
8		Storage Room	Parabolic Ceiling Suspended	E	478	1	2	32	5w	4	365	5	48	N/A	Parabolic Ceiling Suspended	E	478	1	2	32	4	365	5	48	48	0	0	0	
9		Storage Room	Parabolic Ceiling Suspended	E	478	1	2	32	5w	4	365	5	48	N/A	Parabolic Ceiling Suspended	E	478	1	2	32	4	365	5	48	48	0	0	0	
10		Receiving Area	Recessed	E	478	17	3	32	5w	16	365	5	1,717	N/A	Recessed	E	478	17	3	32	16	365	5	1,717	10,027	0	0	0	
11		Receiving Area	Recessed	E	478	6	2	32	5w	9	365	5	453	N/A	Recessed	E	478	6	2	32	9	365	5	453	1,388	0	0	0	
12		Receiving Area	Parabolic Ceiling Suspended	E	478	6	2	32	5w	9	365	5	414	N/A	Parabolic Ceiling Suspended	E	478	6	2	32	9	365	5	414	1,360	0	0	0	
13		Office - Custodian	Recessed	E	LED	2	1	5	N	24	365	1	95	N/A	High Bay	E	LED	2	1	5	24	365	1	11	95	0	0	0	
14		Classroom (0103)	Wall Mounted	E	478	2	6	32	5w	8	190	5	394	N/A	Recessed	E	478	2	6	32	8	190	5	394	599	0	0	0	
15		Classroom (0103)	Wall Mounted	E	478	2	6	32	5w	8	190	5	394	N/A	Recessed	E	478	2	6	32	8	190	5	394	599	0	0	0	
16		Classroom (0103)	Parabolic Ceiling Suspended	E	478	2	30	32	5w	8	190	5	1,390	N/A	Recessed	E	478	2	30	32	8	190	5	1,390	1,961	0	0	0	
17		Classroom (0103)	Parabolic Ceiling Suspended	E	478	1	30	32	5w	8	190	5	480	N/A	Recessed	E	478	1	30	32	8	190	5	480	662	0	0	0	
18		Storage Room (0103)	Recessed	E	LED	1	1	5	N	24	365	1	16	N/A	Equipment / Flame Hood	E	LED	1	1	5	24	365	1	16	16	0	0	0	
19		Classroom (0102)	Recessed	E	478	4	3	32	5w	8	190	5	614	N/A	Recessed	E	478	4	3	32	8	190	5	614	882	0	0	0	
20		Classroom (0102)	Wall Mounted	E	478	1	12	32	5w	8	190	5	404	N/A	Recessed	E	478	1	12	32	8	190	5	404	614	0	0	0	
21		Classroom (0102)	Wall Mounted	E	478	1	20	32	5w	8	190	5	399	N/A	Recessed	E	478	1	20	32	8	190	5	399	581	0	0	0	
22		Classroom (0102)	Parabolic Ceiling Suspended	E	478	5	27	32	5w	8	190	5	2,607	N/A	Parabolic Ceiling Suspended	E	478	5	27	32	8	190	5	2,607	3,863	0	0	0	
23		Classroom (0102)	Exit Sign	E	LED	1	1	5	N	8	365	1	6	N/A	Exit Sign	E	LED	1	1	5	8	365	1	6	6	0	0	0	
24		Storage Room (0102)	Recessed	E	478	1	2	32	5w	2	365	5	69	N/A	Recessed	E	478	1	2	32	2	365	5	69	26	0	0	0	
25		Meeting Room - Faculty Lounge	Parabolic Ceiling Suspended	E	478	5	30	32	5w	9	190	5	4,825	C	Parabolic Ceiling Suspended	E	478	5	30	32	7	190	5	4,825	6,186	0	2,063	2,063	
26		Meeting Room - Faculty Lounge	Parabolic Ceiling Suspended	E	478	2	21	32	5w	9	190	5	1,354	C	Parabolic Ceiling Suspended	E	478	2	21	32	7	190	5	1,354	1,737	0	379	379	
27		Meeting Room - Faculty Lounge	Parabolic Ceiling Suspended	E	478	5	30	32	5w	9	190	5	4,825	C	Parabolic Ceiling Suspended	E	478	5	30	32	7	190	5	4,825	6,186	0	2,063	2,063	
28		Meeting Room - Faculty Lounge	Exit Sign	E	LED	4	1	5	N	24	365	1	65	N/A	Exit Sign	E	LED	4	1	5	24	365	1	65	65	0	0	0	
29		Office - Faculty Lounge	Recessed	E	LED	1	1	5	N	24	365	1	16	N/A	Recessed	E	LED	1	1	5	24	365	1	16	16	0	0	0	
30		Office - Faculty Lounge	Exit Sign	E	LED	1	1	5	5w	24	365	1	48	N/A	Exit Sign	E	LED	1	1	5	24	365	1	48	48	0	0	0	
31		Curry Room - Faculty Lounge	Recessed	E	478	9	3	32	5w	9	190	5	1,382	C	Recessed	E	478	9	3	32	7	190	5	1,382	1,737	0	345	345	
32		Office	Recessed	E	478	2	3	32	5w	9	190	5	202	N/A	Recessed	E	478	2	3	32	9	190	5	202	345	0	0	0	
33		Bathroom Men	Recessed	E	478	2	3	32	5w	8	190	5	202	N/A	Recessed	E	478	2	3	32	8	190	5	202	307	0	0	0	
34		Bathroom Women	Recessed	E	478	2	3	32	5w	8	190	5	202	N/A	Recessed	E	478	2	3	32	8	190	5	202	307	0	0	0	
35		Kitchen Closet	Recessed	E	478	1	2	32	5w	4	190	5	69	N/A	Recessed	E	478	1	2	32	4	190	5	69	52	0	0	0	
36		Locker Room Women	Recessed	E	478	2	2	32	5w	8	190	5	138	N/A	Recessed	E	478	2	2	32	8	190	5	138	210	0	0	0	
37		Bathroom Women	Recessed	E	478	1	2	32	5w	8	190	5	105	N/A	Recessed	E	478	1	2	32	8	190	5	105	165	0	0	0	
38		Kitchen	Recessed	E	478	5	4	32	5w	9	190	5	695	N/A	Recessed	E	478	5	4	32	9	190	5	695	1,137	0	0	0	
39		Kitchen	Exit Sign	E	LED	3	1	5	N	24	365	1	48	N/A	Exit Sign	E	LED	3	1	5	24	365	1	48	48	0	0	0	
40		Kitchen	Recessed	E	478	2	3	32	5w	4	190	5	143	N/A	Recessed	E	478	2	3	32	4	190	5	143	210	0	0	0	
41		Kitchen - Storage Room	Recessed	E	478	2	3	32	5w	4	190	5	105	N/A	Recessed	E	478	2	3	32	4	190	5	105	165	0	0	0	
42		Kitchen	Recessed	E	478	2	3	32	5w	4	190	5	210	N/A	Recessed	E	478	2	3	32	4	190	5	210	307	0	0	0	
43		Walk-in Refrigerator #1	Recessed	E	Inc	2	1	60	5w	4	190	0	120	CFL	Ceiling Mounted	CFL	Inc	2	1	20	4	190	0	40	30	81	0	0	81
44		Walk-in Refrigerator #2	Recessed	E	Inc	2	1	60	5w	4	190	0	120	CFL	Ceiling Mounted	CFL	Inc	2	1	20	4	190	0	40	30	61	0	0	61
45		Kitchen	Recessed	E	478	9	4	32	5w	9	190	5	1,897	N/A	Recessed	E	478	9	4	32	9	190	5	1,897	2,047	0	0	0	
46		Kitchen	Recessed	E	Inc	6	1	60	5w	9	190	0	360	CFL	Recessed	CFL	Inc	6	1	20	9	190	0	120	205	419	0	0	419
47		Kitchen	Recessed	E	478	15	4	32	5w	9	190	5	3,411	N/A	Recessed	E	478	15	4	32	9	190	5	3,411	3,885	0	0	0	
48		Kitchen	Recessed	E	478	1	4	32	5w	9	190	5	133	N/A	Recessed	E	478	1	4	32	9	190	5	133	227	0	0	0	

Member	Floor	Location	Existing Fixture Information										Proposed Information										Annual Savings										
			Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Wastage	Total Wastage	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Wastage	Total Wastage	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)				
48	1	Kitchen	Recessed	E	478	4	4	32	N	190	5	532	110	N/A	478	E	3	4	32	190	5	532	0	0	0	0	0	0	0				
50	1	Kitchen	Recessed	E	478	2	1	60	N	24	365	1	26	N/A	478	E	3	1	20	190	0	137	0	0	0	0	0	0	137				
51	1	Kitchen	Recessed	E	478	3	4	32	N	190	5	399	92	N/A	478	E	3	4	32	190	5	399	0	0	0	0	0	0	0	0			
52	1	Kitchen	Recessed	E	478	3	4	32	N	190	5	399	92	N/A	478	E	3	4	32	190	5	399	0	0	0	0	0	0	0	0			
53	1	Classroom (0101)	Wall Mounted	E	478	2	24	32	5w	190	5	1,548	2,350	N/A	478	E	2	24	32	190	5	1,548	0	0	0	0	0	0	0				
54	1	Classroom (0101)	Wall Mounted	E	478	2	6	32	5w	190	5	384	599	N/A	478	E	2	6	32	190	5	384	0	0	0	0	0	0	0	0			
55	1	Classroom (0101)	Parabolic Ceiling Suspended	E	478	2	24	32	5w	190	5	1,548	2,350	N/A	478	E	2	24	32	190	5	1,548	0	0	0	0	0	0	0				
56	1	Classroom (0101)	Parabolic Ceiling Suspended	E	478	2	18	32	5w	190	5	591	893	N/A	478	E	2	18	32	190	5	591	0	0	0	0	0	0	0	0			
57	1	Classroom (0101)	LED	E	478	2	18	32	N	190	5	8	18	N/A	478	E	2	18	32	190	5	8	0	0	0	0	0	0	0	0			
58	1	Storage Room (0101)	Recessed	E	478	2	4	32	N	190	5	268	101	N/A	478	E	2	4	32	190	5	268	0	0	0	0	0	0	0	0	0		
59	1	Storage Room (0101)	Recessed	E	478	2	4	32	N	190	5	268	101	N/A	478	E	2	4	32	190	5	268	0	0	0	0	0	0	0	0	0	0	
60	1	Life Safety Egress (0101)	Recessed	E	478	2	18	32	5w	190	5	1,162	1,768	N/A	478	E	2	18	32	190	5	1,162	0	0	0	0	0	0	0	0	0		
61	1	Classroom (0100)	Parabolic Ceiling Suspended	E	478	2	18	32	5w	190	5	1,162	1,768	N/A	478	E	2	18	32	190	5	1,162	0	0	0	0	0	0	0	0	0		
62	1	Classroom (0100)	Wall Mounted	E	478	2	14	32	5w	190	5	906	1,377	N/A	478	E	2	14	32	190	5	906	0	0	0	0	0	0	0	0	0		
63	1	Classroom (0100)	Wall Mounted	E	478	1	20	32	5w	190	5	645	980	N/A	478	E	1	20	32	190	5	645	0	0	0	0	0	0	0	0	0		
64	1	Classroom (0100)	LED	E	478	1	1	5	N	24	365	1	6	N/A	478	E	1	1	5	24	365	1	6	0	0	0	0	0	0	0	0		
65	1	Classroom (0100)	LED	E	478	4	3	32	5w	190	5	404	614	N/A	478	E	4	3	32	190	5	404	0	0	0	0	0	0	0	0	0	0	
66	1	Bathroom Men	Recessed	E	478	4	3	32	5w	190	5	404	614	N/A	478	E	4	3	32	190	5	404	0	0	0	0	0	0	0	0	0	0	
67	1	Bathroom Women	Recessed	E	478	4	3	32	5w	190	5	404	614	N/A	478	E	4	3	32	190	5	404	0	0	0	0	0	0	0	0	0	0	0
68	1	Jailor's Closet	Recessed	E	478	8	3	32	5w	261	5	69	36	N/A	478	E	8	3	32	261	5	69	0	0	0	0	0	0	0	0	0	0	
69	1	Hallway	Recessed	E	478	8	3	32	5w	16	365	5	808	4,719	N/A	478	E	8	3	32	16	365	5	808	0	0	0	0	0	0	0	0	
70	1	Vestibule - Exit 12	Recessed	E	478	1	3	32	5w	24	365	5	101	895	N/A	478	E	1	3	32	24	365	5	101	0	0	0	0	0	0	0	0	
71	1	Cafeteria	Parabolic Ceiling Suspended	E	478	7	15	32	5w	190	5	3,965	7,241	N/A	478	E	7	15	32	190	5	3,965	0	0	0	0	0	0	0	0	0	0	
72	1	Cafeteria	Parabolic Ceiling Suspended	E	478	8	20	32	5w	190	5	5,160	11,765	N/A	478	E	8	20	32	190	5	5,160	0	0	0	0	0	0	0	0	0	0	
73	1	Cafeteria	LED	E	478	5	1	5	N	24	365	1	28	N/A	478	E	5	1	5	24	365	1	28	0	0	0	0	0	0	0	0	0	
74	1	Cafeteria	LED	E	478	2	12	32	5w	12	190	5	778	1,774	N/A	478	E	2	12	32	12	190	5	778	0	0	0	0	0	0	0	0	
75	1	Cafeteria	LED	E	478	2	8	32	5w	12	190	5	522	1,190	N/A	478	E	2	8	32	12	190	5	522	0	0	0	0	0	0	0	0	
76	1	Cafeteria	LED	E	478	2	12	32	5w	12	190	5	778	1,774	N/A	478	E	2	12	32	12	190	5	778	0	0	0	0	0	0	0	0	0
77	1	Cafeteria	LED	E	478	21	4	32	5w	12	190	5	2,793	6,269	N/A	478	E	21	4	32	12	190	5	2,793	0	0	0	0	0	0	0	0	
78	1	Cafeteria	Parabolic Ceiling Suspended	E	478	7	18	32	5w	12	190	5	4,087	9,273	N/A	478	E	7	18	32	12	190	5	4,087	0	0	0	0	0	0	0	0	
79	1	Hallway	Recessed	E	478	11	4	32	5w	16	365	5	1,483	8,544	N/A	478	E	11	4	32	16	365	5	1,483	0	0	0	0	0	0	0	0	
80	1	Hallway	LED	E	478	1	1	5	N	24	365	1	6	48	N/A	478	E	1	1	5	24	365	1	6	0	0	0	0	0	0	0	0	
81	1	Fitness Center	Recessed Parabolic	E	478	24	4	32	5w	190	5	3,192	4,952	C	478	E	015	24	4	32	6	190	5	3,192	0	0	0	0	0	0	0	0	
82	1	Fitness Center	LED	E	478	1	1	5	N	24	365	1	6	48	N/A	478	E	1	1	5	24	365	1	6	0	0	0	0	0	0	0	0	
83	1	Fitness Center	LED	E	478	1	1	5	N	24	365	1	6	48	N/A	478	E	1	1	5	24	365	1	6	0	0	0	0	0	0	0	0	0
84	1	Fitness Center	LED	E	478	2	1	5	N	24	365	1	11	96	N/A	478	E	2	1	5	24	365	1	11	0	0	0	0	0	0	0	0	0
85	1	Hallway	Recessed	E	478	11	3	32	5w	16	365	5	1,111	6,489	N/A	478	E	11	3	32	16	365	5	1,111	0	0	0	0	0	0	0	0	0
86	1	Office - Women Phys. Ed.	Recessed	E	478	4	4	32	5w	190	5	532	909	C	478	E	015	4	4	32	6	190	5	532	0	0	0	0	0	0	0	0	
87	1	Bathroom Women	Recessed	E	478	2	2	32	5w	201	5	138	289	N/A	478	E	2	2	32	201	5	138	0	0	0	0	0	0	0	0	0	0	0
88	1	Showers Women	Recessed	E	478	1	1	60	N	8	365	0	60	175	CFL	478	E	2	2	32	8	251	5	138	0	0	0	0	0	0	0	0	
89	1	Storage Room	Recessed	E	478	1	2	32	5w	2	365	5	69	50	N/A	478	E	1	2	32	2	365	5	69	0	0	0	0	0	0	0	0	
90	1	Locker Room Women	Parabolic Ceiling Suspended	E	478	16	2	32	5w	8	190	5	1,054	1,878	N/A	478	E	16	2	32	8	190	5	1,054	0	0	0	0	0	0	0	0	
91	1	Locker Room Women	Recessed	E	478	3	3	32	5w	8	190	5	303	481	N/A	478	E	3	3	32	8	190	5	303	0	0	0	0	0	0	0	0	
92	1	Locker Room Women - Showers	Recessed	E	478	2	2	32	5w	8	190	5	202	307	N/A	478	E	2	2	32	8	190	5	202	0	0	0	0	0	0	0	0	
93	1	Locker Room Women - Showers	Recessed	E	478	2	2	32	5w	8	190	5	202	307	N/A	478	E	2	2	32	8	190	5	202	0	0	0	0	0	0	0	0	0
94	1	Locker Room Women - Showers	LED	E	478	2	2	32	N	34	190	5	315	515	N/A	478	E	2	2	32	34	190	5	315	0	0	0	0	0	0	0	0	
95	1	Locker Room Women - Showers	Recessed	E	478	1	3	32	5w	8	190	5	101	154	N/A	478	E	1	3	32	8	1											

Location		Existing Fixture Information											New Fixture Information						Annual Savings												
Member	Floor	Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Voltage	Total Watts	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Watts	Total Watts	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)		
87		Bathroom Men	Recessed	E	478	2	32	5	N	8	365	5	138	403	N/A	Recessed	478	E	2	32	5	8	365	5	138	403	0	0	0		
88		Storage Room	Recessed	E	478	1	60	1	N	2	190	0	60	91	N/A	Recessed	478	E	1	20	8	190	0	261	0	60	91	0	0	151	
99		Locker Room Men	Parabolic Ceiling Suspended	E	478	16	32	5	2	8	190	5	1,044	1,879	N/A	Parabolic Ceiling Suspended	478	E	16	32	5	8	190	5	261	5	1,104	1,879	0	0	0
100		Locker Room Men	Recessed	E	478	2	32	5	2	8	190	5	202	307	N/A	Recessed	478	E	2	32	5	8	190	5	202	307	0	0	0	0	0
101		Locker Room Men - Bathroom	Recessed	E	478	3	32	5	2	8	190	5	202	307	N/A	Recessed	478	E	3	32	5	8	190	5	202	307	0	0	0	0	0
102		Locker Room Men - Showers	Exit Sign	E	478	3	32	5	N	24	365	1	11	95	N/A	Exit Sign	478	E	3	32	5	24	365	1	11	95	0	0	0	0	0
103		Locker Room Men - Showers	Recessed	E	478	1	5	1	N	5	190	5	101	154	N/A	Equipment / Furne Hood	LED	E	1	5	24	365	5	24	365	5	111	95	0	0	0
104		Locker Room Men - Vestibule	Recessed	E	478	1	32	5	2	8	190	5	101	154	N/A	Recessed	478	E	1	32	5	8	190	5	101	154	0	0	0	0	0
105		Locker Room Men - Vestibule	Recessed	E	478	4	32	5	2	8	190	5	404	2,059	N/A	Recessed	478	E	4	32	5	8	190	5	404	2,059	0	0	0	0	0
106		Hallway	Recessed	E	478	4	32	5	2	8	190	5	133	202	N/A	Recessed	478	E	4	32	5	8	190	5	133	202	0	0	0	0	0
107		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
108		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
109		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
110		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
111		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
112		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
113		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
114		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
115		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
116		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
117		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
118		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
119		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
120		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
121		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
122		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
123		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
124		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
125		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
126		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
127		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
128		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
129		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
130		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
131		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
132		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
133		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
134		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
135		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
136		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
137		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
138		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
139		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
140		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
141		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
142		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
143		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190	5	133	202	0	0	0	0	0
144		Office	Recessed	E	478	1	4	32	5	2	190	5	133	202	N/A	Recessed	478	E	1	4	32	5	190								

Location		Existing Fixture Information										Proposed Information										Annual Savings								
Member	Floor	Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Voltage	Total Watts	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Watts	Total Watts	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)	
145		Bathroom	Recessed	T	478	1	3	32	5w	8	180	5	101	145	C	Recessed	478	T	N	1	3	32	8	180	5	101	145	0	0	0
146		Storage Room	Recessed	T	478	3	3	32	5w	2	261	5	303	53	C	Recessed	478	T	N	3	3	32	2	261	5	303	53	0	0	0
147		Gymnasium	Recessed	T	478	3	3	32	5w	12	150	5	303	601	C	Recessed	478	T	N	3	3	32	12	150	5	303	601	0	0	0
148		Gymnasium	Parabolic Ceiling Suspended	E	478	6	2	32	5w	12	150	5	414	844	C	Parabolic Ceiling Suspended	478	E	N	6	2	32	12	150	5	414	844	0	0	0
149		Gymnasium	Exit Sign	E	478	1	5	11	24	365	1	6	48	48	N/A	Exit Sign	478	E	N	1	5	11	24	365	1	6	48	0	0	0
150		Hallway	Recessed	E	478	4	3	32	5w	16	365	5	404	2,359	N/A	Recessed	478	E	5w	4	3	32	16	365	5	404	2,359	0	0	0
151		Storage Room	Recessed	E	478	1	3	32	5w	2	365	5	101	74	N/A	Recessed	478	E	5w	1	3	32	2	365	5	101	74	0	0	0
152		Hallway	Recessed	E	478	3	3	32	5w	18	365	1	17	96	N/A	Recessed	478	E	5w	3	3	32	18	365	1	17	96	0	0	0
153		Hallway	Recessed	E	478	3	3	32	5w	18	365	1	17	96	N/A	Recessed	478	E	5w	3	3	32	18	365	1	17	96	0	0	0
154		Vestibule - Exit 5	Recessed	E	478	1	3	32	5w	2	365	5	101	309	N/A	Recessed	478	E	5w	1	3	32	2	365	5	101	309	0	0	0
155		Classroom (C100)	Parabolic Ceiling Suspended	E	478	2	16	32	5w	8	365	5	1,034	1,034	N/A	Parabolic Ceiling Suspended	478	E	5w	2	16	32	8	365	5	1,034	1,034	0	0	0
156		Classroom (C101)	Parabolic Ceiling Suspended	E	478	2	16	32	5w	8	365	5	1,034	1,034	N/A	Parabolic Ceiling Suspended	478	E	5w	2	16	32	8	365	5	1,034	1,034	0	0	0
157		Classroom (C102)	Parabolic Ceiling Suspended	E	478	2	16	32	5w	8	365	5	1,034	1,034	N/A	Parabolic Ceiling Suspended	478	E	5w	2	16	32	8	365	5	1,034	1,034	0	0	0
158		Classroom (C101)	Parabolic Ceiling Suspended	E	478	1	14	32	5w	8	190	5	453	689	N/A	Parabolic Ceiling Suspended	478	E	5w	1	14	32	8	190	5	453	689	0	0	0
159		Classroom (C102)	Parabolic Ceiling Suspended	E	478	1	14	32	5w	8	190	5	453	689	N/A	Parabolic Ceiling Suspended	478	E	5w	1	14	32	8	190	5	453	689	0	0	0
160		Vestibule	Recessed	E	478	1	3	32	5w	2	365	5	101	895	N/A	Recessed	478	E	5w	1	3	32	2	365	5	101	895	0	0	0
161		Vestibule	Recessed	E	478	1	3	32	5w	2	365	5	101	895	N/A	Recessed	478	E	5w	1	3	32	2	365	5	101	895	0	0	0
162		Hallway	Recessed	E	478	1	3	32	5w	18	365	5	707	4,129	N/A	Recessed	478	E	5w	1	3	32	18	365	5	707	4,129	0	0	0
163		Gymnasium	Exit Sign	E	478	1	5	11	24	365	1	22	183	N/A	Exit Sign	478	E	5w	1	5	11	24	365	1	22	183	0	0	0	
164		Gymnasium	High Bay	E	478	30	2	350	5w	12	150	70	23,100	5,268	N/A	High Bay	478	E	5w	30	2	350	12	150	70	23,100	5,268	0	0	0
165		Storage Room	Parabolic Ceiling Suspended	E	478	9	2	32	5w	2	190	5	621	298	N/A	Parabolic Ceiling Suspended	478	E	5w	9	2	32	2	190	5	621	298	0	0	0
166		Storage Room	Exit Sign	E	478	1	5	11	24	365	1	6	48	48	N/A	Exit Sign	478	E	5w	1	5	11	24	365	1	6	48	0	0	0
167		Storage Room	Recessed	E	478	1	3	32	5w	2	190	5	621	298	N/A	Recessed	478	E	5w	1	3	32	2	190	5	621	298	0	0	0
168		Storage Room	Recessed	E	478	1	3	32	5w	2	190	5	621	298	N/A	Recessed	478	E	5w	1	3	32	2	190	5	621	298	0	0	0
169		Hallway	Recessed	E	478	8	3	32	5w	18	365	5	808	4,719	N/A	Recessed	478	E	5w	8	3	32	18	365	5	808	4,719	0	0	0
170		Bathroom Men	Recessed	E	478	4	3	32	5w	4	201	5	404	422	N/A	Recessed	478	E	5w	4	3	32	4	201	5	404	422	0	0	0
171		Hallway	Exit Sign	E	478	2	5	11	24	365	1	11	64	64	N/A	Exit Sign	478	E	5w	2	5	11	24	365	1	11	64	0	0	0
172		Janitor's Closet	Recessed	E	478	1	2	32	5w	2	201	5	69	36	N/A	Recessed	478	E	5w	1	2	32	2	201	5	69	36	0	0	0
173		Janitor's Closet	Recessed	E	478	1	2	32	5w	2	201	5	69	36	N/A	Recessed	478	E	5w	1	2	32	2	201	5	69	36	0	0	0
174		Bathroom Women	Recessed	E	478	4	3	32	5w	8	190	5	404	614	N/A	Recessed	478	E	5w	4	3	32	8	190	5	404	614	0	0	0
175		Vestibule - Exit 9	Recessed	E	478	2	4	32	5w	24	365	5	208	2,300	N/A	Recessed	478	E	5w	2	4	32	24	365	5	208	2,300	0	0	0
176		Staircase	Recessed	E	478	4	3	32	5w	18	365	5	404	2,359	18-BL	Recessed	478	E	BL	4	3	32	18	365	5	404	2,359	0	0	961
177		Staircase	Exit Sign	E	478	1	5	11	24	365	1	6	48	48	N/A	Exit Sign	478	E	5w	1	5	11	24	365	1	6	48	0	0	0
178		Storage Room	Recessed	E	478	1	3	32	5w	2	365	5	101	144	N/A	Recessed	478	E	5w	1	3	32	2	365	5	101	144	0	0	0
179		Storage Room	Recessed	E	478	1	3	32	5w	2	365	5	101	144	N/A	Recessed	478	E	5w	1	3	32	2	365	5	101	144	0	0	0
180		Nurse's Station	Recessed	E	478	2	4	32	5w	9	190	5	266	456	N/A	Recessed	478	E	5w	2	4	32	9	190	5	266	456	0	0	0
181		Nurse's Station	Recessed	E	478	6	4	32	5w	9	190	5	108	1,365	C	Recessed	478	E	OC	6	4	32	9	190	5	108	1,365	0	0	341
182		Nurse's Station Storage	Recessed	E	478	2	4	32	5w	2	190	5	266	101	N/A	Recessed	478	E	5w	2	4	32	2	190	5	266	101	0	0	0
183		Nurse's Station Office	Wall Mounted	E	478	2	4	32	5w	9	190	5	266	456	N/A	Recessed	478	E	5w	2	4	32	9	190	5	266	456	0	0	0
184		Hallway	Recessed	E	478	7	2	32	5w	16	365	5	483	2,821	N/A	Recessed	478	E	5w	7	2	32	16	365	5	483	2,821	0	0	0
185		Hallway	Exit Sign	E	478	1	5	11	24	365	1	17	145	145	N/A	Exit Sign	478	E	5w	1	5	11	24	365	1	17	145	0	0	0
186		Office	Parabolic Ceiling Suspended	E	478	1	4	32	5w	9	201	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	5w	1	4	32	9	201	5	133	312	0	0	0
187		Office	Parabolic Ceiling Suspended	E	478	1	4	32	5w	9	201	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	5w	1	4	32	9	201	5	133	312	0	0	0
188		Office	Parabolic Ceiling Suspended	E	478	1	4	32	5w	9	201	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	5w	1	4	32	9	201	5	133	312	0	0	0
189		Office	Parabolic Ceiling Suspended	E	478	1	4	32	5w	9	201	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	5w	1	4	32	9	201	5	133	312	0	0	0
190		Office	Parabolic Ceiling Suspended	E	478	1	4	32	5w	9	201	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	5w	1	4	32	9	201	5	133	312	0	0	0
191		Office	Parabolic Ceiling Suspended	E	478	1	4	32	5w	9	201	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	5w	1	4	32	9	201	5	133	312	0	0	0
192		Office	Parabolic Ceiling Suspended	E	478	1	4	32	5w	9	201	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	5w	1	4	32	9	201	5	133	312	0	0	0

Member	Floor	Location	Existing Fixture Information										Proposed Information										Annual Savings						
			Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Wastage	Total Watts	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Wastage	Total Watts	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)
183		Bathroom Men		Recessed	E	478	1	32	Sw	8	190	5	69	105	N/A	Recessed	478	E	1	1	32	8	190	5	69	105	0	0	0
184		Bathroom Women		Recessed	E	478	1	32	Sw	8	190	5	69	105	N/A	Recessed	478	E	1	1	32	8	190	5	69	105	0	0	0
185		Office		Recessed	E	478	1	32	Sw	8	190	5	197	337	N/A	Recessed	478	E	1	1	32	8	190	5	197	337	0	0	0
186		Hallway		Recessed	E	18 U-Shop	5	32	N	24	365	5	345	2,015	N/A	Recessed	478 U-Shop	E	5	2	32	18	365	5	345	2,015	0	0	0
187		Hallway		Exit Sign	E	LED	1	5	N	4	48	0	48	0	N/A	Equipment / Fume Hood	LED	E	1	1	5	24	365	1	48	0	0	0	0
188		Bathroom Men		Recessed	E	478	1	32	Sw	8	190	5	69	105	N/A	Recessed	478	E	1	1	32	8	190	5	69	105	0	0	0
189		Bathroom Women		Recessed	E	478	1	32	Sw	8	190	5	69	105	N/A	Recessed	478	E	1	1	32	8	190	5	69	105	0	0	0
200		Meeting Room		Wall Mounted	E	478	10	32	Sw	8	190	5	690	1,049	C	Recessed	478	E	10	4	32	8	190	5	690	1,049	262	0	262
201		Office		Recessed Parabolic	E	478	3	32	Sw	8	190	5	303	518	N/A	Recessed Parabolic	478	E	3	3	32	8	190	5	303	518	0	0	0
202		Hallway		Exit Sign	E	LED	2	5	N	4	48	0	96	0	N/A	Equipment / Fume Hood	LED	E	2	1	5	24	365	1	96	0	0	0	0
203		Hallway		Exit Sign	E	LED	2	5	N	4	48	0	96	0	N/A	Equipment / Fume Hood	LED	E	2	1	5	24	365	1	96	0	0	0	0
204		Storage Room		Recessed	E	478	1	32	Sw	8	190	5	69	105	N/A	Recessed	478	E	1	1	32	8	190	5	69	105	0	0	0
205		Main Office		Recessed	E	478	1	32	Sw	8	190	5	69	105	N/A	Recessed	478	E	1	1	32	8	190	5	69	105	0	0	0
206		Main Office		Parabolic Ceiling Suspended	E	478	1	10	Sw	9	261	5	325	763	N/A	Parabolic Ceiling Suspended	478	E	1	10	32	9	261	5	325	763	0	0	0
207		Main Office		Parabolic Ceiling Suspended	E	478	3	4	Sw	9	261	5	399	937	N/A	Parabolic Ceiling Suspended	478	E	3	4	32	9	261	5	399	937	0	0	0
208		Office		Recessed	E	478	3	4	Sw	9	261	5	399	937	N/A	Recessed	478	E	3	4	32	9	261	5	399	937	0	0	0
209		Office		Recessed	E	478	4	4	Sw	9	261	5	532	1,260	C	Recessed	478	E	4	4	32	7	261	5	532	937	0	312	312
210		Career room		Wall Mounted	E	478	1	8	Sw	9	190	5	291	397	N/A	Recessed	478	E	1	8	32	8	190	5	291	397	0	0	0
211		Career room		Parabolic Ceiling Suspended	E	478	3	4	Sw	9	261	5	399	606	N/A	Parabolic Ceiling Suspended	478	E	3	4	32	8	190	5	399	606	0	0	0
212		Comby		Recessed	E	18 U-Shop	4	32	Sw	18	365	5	278	1,612	C	Recessed	478 U-Shop	E	4	2	32	12	365	5	278	1,209	0	403	403
213		Comby		Exit Sign	E	LED	3	5	N	24	365	1	145	145	N/A	Equipment / Fume Hood	LED	E	3	1	5	24	365	1	145	145	0	0	0
214		Office		Wall Mounted	E	478	3	6	Sw	9	261	5	501	1,388	N/A	Recessed	478	E	3	6	32	9	261	5	501	1,388	0	0	0
215		Office		Parabolic Ceiling Suspended	E	478	2	4	Sw	9	261	5	325	712	N/A	Parabolic Ceiling Suspended	478	E	2	4	32	9	261	5	325	712	0	0	0
216		Office		Parabolic Ceiling Suspended	E	478	1	4	Sw	9	261	5	243	572	N/A	Parabolic Ceiling Suspended	478	E	1	4	32	9	261	5	243	572	0	0	0
217		Office		Parabolic Ceiling Suspended	E	478	1	4	Sw	9	261	5	133	312	N/A	Parabolic Ceiling Suspended	478	E	1	4	32	9	261	5	133	312	0	0	0
218		Attendance Office		Parabolic Ceiling Suspended	E	478	2	4	Sw	9	261	5	266	625	N/A	Parabolic Ceiling Suspended	478	E	2	4	32	9	261	5	266	625	0	0	0
219		Attendance Office		Wall Mounted	E	478	2	6	Sw	9	261	5	394	325	N/A	Recessed	478	E	2	6	32	9	261	5	394	325	0	0	0
220		Main Office		Wall Mounted	E	478	4	4	Sw	9	261	5	532	1,260	C	Recessed	478	E	4	4	32	7	261	5	532	937	0	312	312
221		Main Office		High Bay	E	HPG	2	150	N	9	201	30	360	846	N/A	High Bay	HPG	E	2	1	150	9	201	30	360	846	0	0	0
222		Main Office		Wall Mounted	E	478	1	18	Sw	9	261	5	517	1,214	N/A	Recessed	478	E	1	18	32	9	261	5	517	1,214	0	0	0
223		Hallway		Recessed	E	478	11	32	Sw	16	365	5	1,111	6,489	N/A	Recessed	478	E	11	3	32	16	365	5	1,111	6,489	0	0	0
224		Hallway		Exit Sign	E	LED	1	5	N	24	365	1	48	48	N/A	Equipment / Fume Hood	LED	E	1	1	5	24	365	1	48	48	0	0	0
225		Mechanical Room		Parabolic Ceiling Suspended	E	478	4	2	Sw	2	291	5	278	144	N/A	Parabolic Ceiling Suspended	478	E	4	2	32	2	291	5	278	144	0	0	0
226		Mechanical Room		Exit Sign	E	LED	1	5	N	24	365	1	48	48	N/A	Equipment / Fume Hood	LED	E	1	1	5	24	365	1	48	48	0	0	0
227		Mechanical Room		Exit Sign	E	LED	1	5	N	24	365	1	48	48	N/A	Equipment / Fume Hood	LED	E	1	1	5	24	365	1	48	48	0	0	0
228		Mechanical Room		Parabolic Ceiling Suspended	E	478	4	2	Sw	2	291	5	278	144	N/A	Parabolic Ceiling Suspended	478	E	4	2	32	2	291	5	278	144	0	0	0
229		Storage Room		Parabolic Ceiling Suspended	E	478	10	2	Sw	2	291	5	690	360	N/A	Parabolic Ceiling Suspended	478	E	10	2	32	2	291	5	690	360	0	0	0
230		Storage Room		Exit Sign	E	LED	1	5	N	24	365	1	48	48	N/A	Equipment / Fume Hood	LED	E	1	1	5	24	365	1	48	48	0	0	0
231		Verstule		Recessed	E	478	1	4	Sw	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	E	1	1	5	24	365	1	6	48	0	0	0
232		Verstule		Recessed	E	478	1	4	Sw	24	365	1	133	1,165	N/A	Equipment / Fume Hood	LED	E	1	4	32	24	365	1	133	1,165	0	0	0
233		Lobby		Wall Mounted	E	478	1	12	Sw	16	365	5	399	2,272	N/A	Recessed	478	E	1	12	32	16	365	5	399	2,272	0	0	0
234		Lobby		Wall Mounted	E	478	2	18	Sw	16	365	5	1,182	3,393	N/A	Recessed	478	E	2	18	32	16	365	5	1,182	3,393	0	0	0
235		Lobby		Exit Sign	E	LED	1	5	N	24	365	1	48	48	N/A	Equipment / Fume Hood	LED	E	1	1	5	24	365	1	48	48	0	0	0
236		Verstule		Recessed	E	478	2	4	Sw	8	365	5	298	777	N/A	Recessed	478	E	2	4	32	8	365	5	298	777	0	0	0
237		Verstule		Parabolic Ceiling Suspended	E	478	7	9	Sw	8	190	5	2,051	3,118	N/A	Parabolic Ceiling Suspended	478	E	7	9	32	8	190	5	2,051	3,118	0	0	0
238		Media Center		Parabolic Ceiling Suspended	E	478	1	15	Sw	8	190	5	101	194	N/A	Parabolic Ceiling Suspended	478	E	1	15	32	8	190	5	101	194	0	0	0
239		Media Center		Parabolic Ceiling Suspended	E	478	1	15	Sw	8	190	5	101	194	N/A	Parabolic Ceiling Suspended	478	E	1	15	32	8	190	5	101	194	0	0	0
240		Media Center		Parabolic Ceiling Suspended	E	478	1	6	Sw	8	190	5	197	298	N/A	Parabolic Ceiling Suspended	478	E	1	6	32	8	190	5	197	298	0	0	0

Location		Existing Fixture Information										Retrofit Information										Annual Savings									
Marker	Floor	Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Savings (kWh)	Total Watts	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	Controls	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Watts	Total Watts	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)	
241		Media Center	Parabolic Ceiling Suspended	E	4TB	1	0	32	4W	8	160	0	197	299	N/A	Parabolic Ceiling Suspended	4TB	E	OS	1	0	32	8	160	5	197	299	0	0	0	
242		Media Center	Parabolic Ceiling Suspended	E	4TB	1	0	32	5W	8	160	0	293	445	N/A	Parabolic Ceiling Suspended	4TB	E	OS	1	0	32	8	160	5	293	445	0	0	0	
243		Media Center	Parabolic Ceiling Suspended	E	4TB	1	15	32	5W	8	160	0	485	737	N/A	Parabolic Ceiling Suspended	4TB	E	OS	1	15	32	8	160	5	485	737	0	0	0	
244		Media Center	LED Sign	E	LED	1	5	24	365	1	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	OS	1	1	5	24	365	1	6	48	0	0	
245		Office	Recessed	E	4TB	10	3	32	OS	2	201	0	1,010	2,372	N/A	Recessed	4TB	E	OS	10	3	32	2	201	5	201	5	1,010	2,372	0	0
246		Storage Room	Recessed	E	4TB	3	2	32	5W	2	201	0	207	108	N/A	Recessed	4TB	E	OS	3	2	32	2	201	5	207	108	0	0	0	
247		Storage Room	Recessed	E	4TB	6	3	32	5W	2	201	0	608	316	N/A	Recessed	4TB	E	OS	6	3	32	2	201	5	608	316	0	0	0	
248		Storage Room	Wall Mounted	E	4TB	1	3	32	5W	2	201	0	697	359	N/A	Wall Mounted	4TB	E	OS	1	3	32	2	201	5	697	359	0	0	0	
249		Storage Room	Wall Mounted	E	4TB	3	2	32	5W	2	201	0	697	359	N/A	Wall Mounted	4TB	E	OS	3	2	32	2	201	5	697	359	0	0	0	
250		Library	Recessed	E	4TB	9	2	32	5W	8	160	0	1,927	209	N/A	Recessed	4TB	E	OS	9	2	32	8	160	5	1,927	209	0	0	0	
251		Library	Parabolic Ceiling Suspended	E	4TB	9	2	32	5W	8	160	0	621	844	N/A	Recessed Parabolic	4TB	E	OS	9	2	32	8	160	5	621	844	0	0	0	
252		Library	LED Sign	E	LED	1	5	24	365	1	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	OS	1	1	5	24	365	1	6	48	0	0	0
253		Library	Recessed Parabolic	E	4TB	9	2	32	5W	8	160	0	621	844	N/A	Recessed Parabolic	4TB	E	OS	9	2	32	8	160	5	621	844	0	0	0	
254		Library	Recessed Parabolic	E	4TB	9	2	32	5W	8	160	0	621	844	N/A	Recessed Parabolic	4TB	E	OS	9	2	32	8	160	5	621	844	0	0	0	
255		Library	Recessed Parabolic	E	4TB	9	2	32	5W	8	160	0	621	844	N/A	Recessed Parabolic	4TB	E	OS	9	2	32	8	160	5	621	844	0	0	0	
256		Hallway	Recessed	E	4TB	3	3	32	5W	18	365	0	909	5,209	N/A	Recessed	4TB	E	OS	3	3	32	18	365	5	909	5,209	0	0	0	
257		Office (A105)	Parabolic Ceiling Suspended	E	4TB	5	3	32	5W	8	201	0	905	1,186	C	Parabolic Ceiling Suspended	4TB	E	OS	5	3	32	7	201	5	905	1,186	0	297	297	
258		Electrical Room	Recessed	E	4TB	1	2	32	5W	2	201	0	69	16	N/A	Recessed	4TB	E	OS	1	2	32	2	201	5	69	16	0	0	0	
259		Server Room (Recycle)	Recessed	E	4TB	1	2	32	5W	2	201	0	69	16	N/A	Recessed	4TB	E	OS	1	2	32	2	201	5	69	16	0	0	0	
260		Storage Room	Recessed	E	4TB	3	2	32	5W	2	201	0	101	53	N/A	Recessed	4TB	E	OS	3	2	32	2	201	5	101	53	0	0	0	
261		Classroom (A100A)	Parabolic Ceiling Suspended	E	4TB	3	8	32	5W	8	160	0	783	1,180	N/A	Parabolic Ceiling Suspended	4TB	E	OS	3	8	32	8	160	5	783	1,180	0	0	0	
262		Classroom (A100B)	Parabolic Ceiling Suspended	E	4TB	3	8	32	5W	8	160	0	783	1,180	N/A	Parabolic Ceiling Suspended	4TB	E	OS	3	8	32	8	160	5	783	1,180	0	0	0	
263		Hallway	Recessed	E	4TB	6	3	32	5W	16	365	0	608	3,539	N/A	Recessed	4TB	E	OS	6	3	32	16	365	5	608	3,539	0	0	0	
264		Classroom (A102A)	Parabolic Ceiling Suspended	E	4TB	2	8	32	5W	8	160	0	522	793	N/A	Parabolic Ceiling Suspended	4TB	E	OS	2	8	32	8	160	5	522	793	0	0	0	
265		Classroom (A102B)	Parabolic Ceiling Suspended	E	4TB	2	8	32	5W	8	160	0	522	793	N/A	Parabolic Ceiling Suspended	4TB	E	OS	2	8	32	8	160	5	522	793	0	0	0	
266		Storage Room	Recessed	E	4TB	1	3	32	5W	2	201	0	101	53	N/A	Recessed	4TB	E	OS	1	3	32	2	201	5	101	53	0	0	0	
267		Classroom	Recessed Parabolic	E	4TB	2	8	32	5W	8	160	0	522	793	N/A	Recessed Parabolic	4TB	E	OS	2	8	32	8	160	5	522	793	0	0	0	
268		Hallway	Recessed	E	4TB	2	3	32	5W	2	201	0	121	581	N/A	Recessed	4TB	E	OS	2	3	32	2	201	5	121	581	0	0	0	
269		Hallway	Recessed	E	4TB	1	3	32	5W	2	201	0	121	581	N/A	Recessed	4TB	E	OS	1	3	32	2	201	5	121	581	0	0	0	
270		Hallway	Recessed	E	4TB	1	3	32	5W	2	201	0	121	581	N/A	Recessed	4TB	E	OS	1	3	32	2	201	5	121	581	0	0	0	
271		Hallway	Recessed	E	4TB	1	3	32	5W	2	201	0	121	581	N/A	Recessed	4TB	E	OS	1	3	32	2	201	5	121	581	0	0	0	
272		Hallway	LED Sign	E	LED	1	5	24	365	1	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	OS	1	1	5	24	365	1	6	48	0	0	0
273		Hallway	Wall Mounted	E	4TB	6	10	32	5W	16	201	0	1,560	8143	N/A	Equipment / Frame Hood	4TB	E	OS	6	10	32	16	201	5	1,560	8143	0	0	0	
274		Hallway	Wall Mounted	E	4TB	6	10	32	5W	16	201	0	1,560	8143	N/A	Equipment / Frame Hood	4TB	E	OS	6	10	32	16	201	5	1,560	8143	0	0	0	
275		Student Store	Recessed	E	4TB	6	4	32	5W	16	201	0	1,182	4,939	N/A	Recessed	4TB	E	OS	6	4	32	16	201	5	1,182	4,939	0	0	0	
276		Bathroom Men	Recessed	E	4TB	4	3	32	5W	8	160	0	404	614	N/A	Recessed	4TB	E	OS	4	3	32	8	160	5	404	614	0	0	0	
277		Bathroom Women	Recessed	E	4TB	4	3	32	5W	8	160	0	404	614	N/A	Recessed	4TB	E	OS	4	3	32	8	160	5	404	614	0	0	0	
278		Janitor's Closet	Recessed	E	4TB	1	2	32	5W	2	201	0	69	36	N/A	Recessed	4TB	E	OS	1	2	32	2	201	5	69	36	0	0	0	
279		Storage Room	Recessed	E	4TB	1	3	32	5W	2	201	0	111	440	N/A	Recessed	4TB	E	OS	1	3	32	2	201	5	111	440	0	0	0	
280		Storage Room	Recessed	E	4TB	1	3	32	5W	2	201	0	111	440	N/A	Recessed	4TB	E	OS	1	3	32	2	201	5	111	440	0	0	0	
281		Electrical Room	Recessed	E	4TB	2	2	32	5W	2	190	0	138	52	N/A	Recessed	4TB	E	OS	2	2	32	2	190	5	138	52	0	0	0	
282		Hallway	LED Sign	E	LED	1	5	24	365	1	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	OS	1	1	5	24	365	1	6	48	0	0	0
283		Vestibule	Recessed	E	4TB	1	3	32	5W	24	365	0	101	895	N/A	Recessed	4TB	E	OS	1	3	32	24	365	5	101	895	0	0	0	
284		Hallway	Wall Mounted	E	4TB	6	20	32	5W	16	365	0	3,870	22,621	N/A	Recessed	4TB	E	OS	6	20	32	16	365	5	3,870	22,621	0	0	0	
285		Hallway	Wall Mounted	E	4TB	6	8	32	5W	16	365	0	1,568	9,145	N/A	Recessed	4TB	E	OS	6	8	32	16	365	5	1,568	9,145	0	0	0	
286		Hallway	Recessed	E	4TB	10	3	32	5W	10	365	0	1,010	5,888	N/A	Recessed	4TB	E	OS	10	3	32	10	365	5	1,010	5,888	0	0	0	
287		Hallway	LED Sign	E	LED	4	1	5	24	365	1	22	193	0	0	N/A	Equipment / Frame Hood	LED	E	OS	4	1	5	24	365	1	22	193	0	0	0
288		Hallway	Parabolic Ceiling Suspended	E	4TB	1	15	32	5W	8	160	0	485	737	N/A	Parabolic Ceiling Suspended	4TB	E	OS	1	15	32	8	160	5	485	737	0	0	0	
289		Media Center	Parabolic Ceiling Suspended	E	4TB	1	6	32	5W	8	160	0																			

Location		Existing Fixture Information										Retrofit Information										Annual Savings							
Marker	Floor	Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Savings (kWh)	Total Watts	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Watts	Total Watts	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)
241		Media Center	Parabolic Ceiling Suspended	E	4TB	1	0	32	Sw	8	160	0	197	299	N/A	Parabolic Ceiling Suspended	4TB	E	1	0	32	8	160	0	197	299	0	0	0
242		Media Center	Parabolic Ceiling Suspended	E	4TB	1	0	32	Sw	8	160	0	293	445	N/A	Parabolic Ceiling Suspended	4TB	E	1	0	32	8	160	0	293	445	0	0	0
243		Media Center	Parabolic Ceiling Suspended	E	4TB	1	15	32	Sw	8	160	0	485	737	N/A	Parabolic Ceiling Suspended	4TB	E	1	15	32	8	160	0	485	737	0	0	0
244		Media Center	LED Sign	E	LED	1	5	24	Sw	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	1	5	24	365	1	6	48	0	0	0	
245		Office	Recessed	E	4TB	10	3	OS	OS	2,372	2,372	0	1,010	1,010	N/A	Recessed	4TB	E	10	3	32	2,372	2,372	0	1,010	1,010	0	0	0
246		Storage Room	Recessed	E	4TB	3	2	32	Sw	2	201	0	207	108	N/A	Recessed	4TB	E	3	2	32	2	201	0	207	108	0	0	0
247		Storage Room	Recessed	E	4TB	6	3	32	Sw	2	201	0	698	316	N/A	Recessed	4TB	E	6	3	32	2	201	0	698	316	0	0	0
248		Storage Room	Recessed	E	4TB	3	2	32	Sw	2	201	0	698	316	N/A	Recessed	4TB	E	3	2	32	2	201	0	698	316	0	0	0
249		Storage Room	Recessed	E	4TB	3	2	32	Sw	2	201	0	698	316	N/A	Recessed	4TB	E	3	2	32	2	201	0	698	316	0	0	0
250		Library	Recessed	E	4TB	3	2	32	Sw	2	201	0	697	329	N/A	Recessed	4TB	E	3	2	32	2	201	0	697	329	0	0	0
251		Library	Recessed	E	4TB	9	2	32	Sw	8	190	0	621	844	N/A	Recessed	4TB	E	9	2	32	8	190	0	621	844	0	0	0
252		Library	Recessed	E	4TB	7	2	32	Sw	8	190	0	437	209	N/A	Recessed	4TB	E	7	2	32	8	190	0	437	209	0	0	0
253		Library	Recessed	E	4TB	7	2	32	Sw	8	190	0	437	209	N/A	Recessed	4TB	E	7	2	32	8	190	0	437	209	0	0	0
254		Library	Recessed	E	4TB	9	2	32	Sw	8	190	0	621	844	N/A	Recessed	4TB	E	9	2	32	8	190	0	621	844	0	0	0
255		Library	Recessed	E	4TB	9	2	32	Sw	8	190	0	621	844	N/A	Recessed	4TB	E	9	2	32	8	190	0	621	844	0	0	0
256		Hallway	Recessed	E	4TB	3	3	32	Sw	18	365	3	909	5209	N/A	Recessed	4TB	E	3	3	32	18	365	3	909	5209	0	0	0
257		Office (A105)	Parabolic Ceiling Suspended	E	4TB	5	3	32	Sw	8	201	0	905	1186	C	Parabolic Ceiling Suspended	4TB	E	5	3	32	8	201	0	905	1186	0	297	297
258		Electrical Room	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	168	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	168	0	0	0
259		Server Room (Recycle)	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	168	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	168	0	0	0
260		Storage Room	Recessed	E	4TB	3	2	32	Sw	2	201	0	101	53	N/A	Recessed	4TB	E	3	2	32	2	201	0	101	53	0	0	0
261		Classroom (A100A)	Parabolic Ceiling Suspended	E	4TB	3	8	32	Sw	8	190	0	783	1180	N/A	Parabolic Ceiling Suspended	4TB	E	3	8	32	8	190	0	783	1180	0	0	0
262		Classroom (A100B)	Parabolic Ceiling Suspended	E	4TB	3	8	32	Sw	8	190	0	783	1180	N/A	Parabolic Ceiling Suspended	4TB	E	3	8	32	8	190	0	783	1180	0	0	0
263		Hallway	Recessed	E	4TB	6	3	32	Sw	16	365	6	608	3639	N/A	Recessed	4TB	E	6	3	32	16	365	6	608	3639	0	0	0
264		Classroom (A102A)	Parabolic Ceiling Suspended	E	4TB	2	8	32	Sw	8	190	0	522	793	N/A	Parabolic Ceiling Suspended	4TB	E	2	8	32	8	190	0	522	793	0	0	0
265		Classroom (A102B)	Parabolic Ceiling Suspended	E	4TB	2	8	32	Sw	8	190	0	522	793	N/A	Parabolic Ceiling Suspended	4TB	E	2	8	32	8	190	0	522	793	0	0	0
266		Storage Room	Recessed	E	4TB	1	3	32	Sw	2	201	0	101	53	N/A	Recessed	4TB	E	1	3	32	2	201	0	101	53	0	0	0
267		Classroom	Recessed	E	4TB	2	8	32	Sw	8	190	0	522	793	N/A	Recessed	4TB	E	2	8	32	8	190	0	522	793	0	0	0
268		Hallway	Recessed	E	4TB	2	3	32	Sw	8	190	0	121	581	N/A	Recessed	4TB	E	2	3	32	8	190	0	121	581	0	0	0
269		Hallway	Recessed	E	4TB	12	3	32	Sw	12	365	1	1,212	1,212	N/A	Recessed	4TB	E	12	3	32	12	365	1	1,212	1,212	0	0	0
270		Hallway	Recessed	E	4TB	10	3	32	Sw	10	201	0	1,010	1,010	N/A	Recessed	4TB	E	10	3	32	10	201	0	1,010	1,010	0	0	0
271		Hallway	LED Sign	E	LED	1	5	24	Sw	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	1	5	24	365	1	6	48	0	0	0	
272		Hallway	LED Sign	E	LED	1	5	24	Sw	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	1	5	24	365	1	6	48	0	0	0	
273		Hallway	LED Sign	E	LED	1	5	24	Sw	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	1	5	24	365	1	6	48	0	0	0	
274		Hallway	LED Sign	E	LED	1	5	24	Sw	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	1	5	24	365	1	6	48	0	0	0	
275		Student Store	Recessed	E	4TB	6	4	32	Sw	16	201	1	1,182	4,939	N/A	Recessed	4TB	E	6	4	32	16	201	1	1,182	4,939	0	0	0
276		Bathroom Men	Recessed	E	4TB	4	3	32	Sw	8	190	0	404	614	N/A	Recessed	4TB	E	4	3	32	8	190	0	404	614	0	0	0
277		Bathroom Women	Recessed	E	4TB	4	3	32	Sw	8	190	0	404	614	N/A	Recessed	4TB	E	4	3	32	8	190	0	404	614	0	0	0
278		Janitor's Closet	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	36	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	36	0	0	0
279		Storage Room	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	36	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	36	0	0	0
280		Storage Room	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	36	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	36	0	0	0
281		Storage Room	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	36	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	36	0	0	0
282		Storage Room	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	36	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	36	0	0	0
283		Storage Room	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	36	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	36	0	0	0
284		Storage Room	Recessed	E	4TB	1	2	32	Sw	2	201	0	69	36	N/A	Recessed	4TB	E	1	2	32	2	201	0	69	36	0	0	0
285		Hallway	LED Sign	E	LED	1	5	24	Sw	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	1	5	24	365	1	6	48	0	0	0	
286		Hallway	LED Sign	E	LED	1	5	24	Sw	24	365	1	6	48	N/A	Equipment / Frame Hood	LED	E	1	5	24	365	1	6	48	0	0	0	
287		Auditorium	LED Sign	E	LED	8	1	5	Sw	24	365	1	44	385	N/A	Equipment / Frame Hood	LED	E	8	1	5	24	365	1	44	385	0	0	0
288		Auditorium	Recessed	E	CFL	14	1	23	Sw	4	190	0	322	245	N/A	Recessed	CFL	E	14	1	23	4	190	0	322	245	0	0	0

Marker	Floor	Location	Existing Fixture Information										Retrofit Information										Annual Savings								
			Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Savings (kWh)	Energy Use kWh/Year	Total Watts	Category	Fixture Type	Lamp Type	Ballast	Controls	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Watts	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)	
287		Auditorium	Exit Sign	Recessed	S	LED	8	1	5	N	24	365	1	44	365	1	44	365	1	N	8	1	5	24	365	1	44	365	0	0	0
288		Auditorium	Recessed	Recessed	S	LED	14	1	23	2w	4	190	0	372	245	0	372	245	0	N	14	1	23	4	190	0	372	245	0	0	0
289		Auditorium	Wall Mounted	Recessed	E	4TB	6	2	32	5w	4	190	0	414	315	0	414	315	0	E	6	2	32	4	190	0	414	315	0	0	0
290		Bathroom	Exit Sign	Recessed	S	LED	1	1	5	N	24	365	1	6	48	0	6	48	0	N	1	1	5	24	365	1	6	48	0	0	0
291		Bathroom	Recessed	Recessed	S	CFL	35	1	23	5w	4	190	0	805	612	0	805	612	0	N	35	1	23	4	190	0	805	612	0	0	0
292		Above Stage Area	Parabolic Ceiling Suspended	Recessed	E	4TB	4	3	32	5w	4	190	0	604	507	0	604	507	0	E	4	3	32	4	190	0	604	507	0	0	0
293		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	12	2	32	5w	4	190	0	808	629	0	808	629	0	E	12	2	32	4	190	0	808	629	0	0	0
294		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	3	32	5w	4	190	0	12	96	0	12	96	0	E	3	3	32	4	190	0	12	96	0	0	0
295		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	3	32	5w	4	190	0	12	96	0	12	96	0	E	3	3	32	4	190	0	12	96	0	0	0
296		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	3	32	5w	4	190	0	12	96	0	12	96	0	E	3	3	32	4	190	0	12	96	0	0	0
297		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	3	32	5w	4	190	0	12	96	0	12	96	0	E	3	3	32	4	190	0	12	96	0	0	0
298		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	2	32	5w	4	190	0	8	64	0	8	64	0	E	2	2	32	4	190	0	8	64	0	0	0
299		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	10	32	5w	8	190	0	1,368	2,086	0	1,368	2,086	0	E	4	10	32	8	190	0	1,368	2,086	0	0	0
300		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	10	32	5w	8	190	0	1,300	1,976	0	1,300	1,976	0	E	4	10	32	8	190	0	1,300	1,976	0	0	0
301		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	1	1	5	N	24	365	1	6	48	0	6	48	0	N	1	1	5	24	365	1	6	48	0	0	0
302		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	6	3	32	5w	2	261	1	608	516	0	608	516	0	E	6	3	32	2	261	1	608	516	0	0	0
303		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	10	32	5w	8	190	0	1,300	1,976	0	1,300	1,976	0	E	4	10	32	8	190	0	1,300	1,976	0	0	0
304		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	3	32	5w	4	190	0	808	629	0	808	629	0	E	3	3	32	4	190	0	808	629	0	0	0
305		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	3	32	5w	4	190	0	1,168	2,544	0	1,168	2,544	0	E	3	3	32	4	190	0	1,168	2,544	0	0	0
306		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	12	32	5w	8	190	0	1,168	2,544	0	1,168	2,544	0	E	3	12	32	8	190	0	1,168	2,544	0	0	0
307		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	1	1	5	N	24	365	1	6	48	0	6	48	0	N	1	1	5	24	365	1	6	48	0	0	0
308		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	4	32	5w	8	190	0	248	404	0	248	404	0	E	2	4	32	8	190	0	248	404	0	0	0
309		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	22	32	5w	8	190	0	2,127	3,233	0	2,127	3,233	0	E	3	22	32	8	190	0	2,127	3,233	0	0	0
310		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	5	4	32	5w	8	190	0	865	1,011	0	865	1,011	0	E	5	4	32	8	190	0	865	1,011	0	0	0
311		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	1	1	5	N	24	365	1	6	48	0	6	48	0	N	1	1	5	24	365	1	6	48	0	0	0
312		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	2	32	5w	2	190	0	207	79	0	207	79	0	E	3	2	32	2	190	0	207	79	0	0	0
313		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	2	32	5w	2	190	0	707	61	0	707	61	0	E	2	2	32	2	190	0	707	61	0	0	0
314		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	4	32	5w	4	190	0	533	61	0	533	61	0	E	4	4	32	4	190	0	533	61	0	0	0
315		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	4	32	5w	4	190	0	533	61	0	533	61	0	E	4	4	32	4	190	0	533	61	0	0	0
316		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	4	32	5w	4	190	0	533	61	0	533	61	0	E	4	4	32	4	190	0	533	61	0	0	0
317		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	2	32	5w	2	190	0	207	79	0	207	79	0	E	2	2	32	2	190	0	207	79	0	0	0
318		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	2	32	5w	2	190	0	207	79	0	207	79	0	E	2	2	32	2	190	0	207	79	0	0	0
319		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	10	3	32	5w	10	365	5	1,010	5,898	0	1,010	5,898	0	E	10	3	32	10	365	5	1,010	5,898	0	0	0
320		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	1	1	5	N	24	365	1	6	48	0	6	48	0	N	1	1	5	24	365	1	6	48	0	0	0
321		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	4	32	5w	8	190	0	532	809	0	532	809	0	E	4	4	32	8	190	0	532	809	0	0	0
322		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	4	32	5w	8	190	0	532	809	0	532	809	0	E	4	4	32	8	190	0	532	809	0	0	0
323		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	4	32	5w	2	201	5	268	138	0	268	138	0	E	2	4	32	2	201	5	268	138	0	0	0
324		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	1	1	5	N	24	365	1	6	48	0	6	48	0	N	1	1	5	24	365	1	6	48	0	0	0
325		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	6	2	32	5w	2	201	5	268	138	0	268	138	0	E	6	2	32	2	201	5	268	138	0	0	0
326		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	1	5	N	24	365	1	6	48	0	6	48	0	N	2	1	5	24	365	1	6	48	0	0	0
327		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	10	32	5w	8	190	0	1,300	1,976	0	1,300	1,976	0	E	4	10	32	8	190	0	1,300	1,976	0	0	0
328		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB U-Shaped	1	2	32	5w	2	261	5	69	36	0	69	36	0	E	1	2	32	2	261	5	69	36	0	0	0
329		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	3	2	32	5w	2	201	5	207	108	0	207	108	0	E	3	2	32	2	201	5	207	108	0	0	0
330		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	10	32	5w	8	190	0	1,300	1,976	0	1,300	1,976	0	E	4	10	32	8	190	0	1,300	1,976	0	0	0
331		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	10	32	5w	8	190	0	1,300	1,976	0	1,300	1,976	0	E	4	10	32	8	190	0	1,300	1,976	0	0	0
332		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB U-Shaped	1	2	32	N	2	201	5	69	36	0	69	36	0	E	1	2	32	2	201	5	69	36	0	0	0
333		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	4	4	32	5w	8	190	0	532	809	0	532	809	0	E	4	4	32	8	190	0	532	809	0	0	0
334		Storage Room	Parabolic Ceiling Suspended	Recessed	E	4TB	2	3	32	5w	16	365	5	202	1,180	0	202	1,180	0	E	2	3	32	16	365	5	202	1,180	0	0	0

Marker	Floor	Location	Existing Fixture Information										Proposed Information										Annual Savings									
			Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Voltage	Total Watts	Energy Use kWh/Year	Category	Fixture Type	Lamp Type	Ballast	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Voltage	Total Watts	Energy Use kWh/Year	Fixture Savings (kWh)	Control Savings (kWh)	Total Savings (kWh)			
335	1	Hallway	Exit Sign	S	LED	1	1	5	N	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	24	365	1	9	48	0	0	0		
336	1	Hallway - Exit 28	Recessed	E	4TB	4	3	32	Sw	2	24	365	1	404	N/A	Recessed	4TB	E	N	4	3	32	24	365	5	404	2529	0	0	0		
337	1	Verdura - Exit 28	Exit Sign	S	LED	1	1	5	N	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	24	365	1	6	48	0	0	0		
338	1	Hallway	Recessed	E	4TB	6	3	32	Sw	18	365	5	808	4,719	N/A	Recessed	4TB	E	N	6	3	32	18	365	5	808	4,719	0	0	0		
339	1	Hallway	Exit Sign	S	LED	2	1	5	N	24	365	1	11	96	N/A	Equipment / Fume Hood	LED	S	N	2	1	5	24	365	1	11	96	0	0	0		
340	2b	Staircase	Recessed	E	4TB	5	3	32	Sw	18	365	5	505	2,849	18-3L	Recessed	4TB	E	BL	5	3	32	18	365	5	505	2,849	0	1296	1296		
341	2b	Staircase	Exit Sign	S	LED	1	1	5	N	18	365	1	6	32	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	18	365	1	6	32	0	0	0		
342	2	Storage Room	Recessed	E	4TB	3	2	32	Sw	18	365	5	607	1,329	N/A	Recessed	4TB	E	N	3	2	32	18	365	5	607	1,329	0	0	0		
343	2	Storage Room	Recessed	E	4TB	3	2	32	Sw	18	365	5	607	1,329	N/A	Recessed	4TB	E	N	3	2	32	18	365	5	607	1,329	0	0	0		
344	2	Lobby	Exit Sign	S	LED	1	1	5	N	16	365	1	11	64	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	16	365	1	11	64	0	0	0		
345	2	Office (A200)	Recessed	E	4TB	1	2	32	Sw	0	180	5	69	99	N/A	Recessed	4TB	E	N	1	2	32	0	180	5	69	99	0	0	0		
346	2	Office (A200)	Recessed	E	4TB	6	4	32	Sw	0	180	5	798	1,140	N/A	Recessed	4TB	E	N	6	4	32	0	180	5	798	1,140	0	0	0		
347	2	Hallway	Recessed	E	4TB	7	3	32	Sw	16	365	5	707	4,129	N/A	Recessed	4TB	E	N	7	3	32	16	365	5	707	4,129	0	0	0		
348	2	Hallway	Exit Sign	S	LED	1	1	5	N	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	24	365	1	6	48	0	0	0		
349	2	Storage Room	Recessed	E	4TB	1	2	32	Sw	2	24	365	1	69	36	N/A	Recessed	4TB	E	N	1	2	32	2	24	365	1	69	36	0	0	0
350	2	Science Room / Laboratory (A226)	Parabolic Ceiling Suspended	E	4TB	1	2	32	Sw	2	24	365	1	1827	2,777	N/A	Parabolic Ceiling Suspended	4TB	E	N	1	2	32	2	24	365	1	1827	2,777	0	0	0
351	2	Classroom (A226)	Parabolic Ceiling Suspended	E	4TB	7	8	32	Sw	0	180	5	1,976	1,976	N/A	Parabolic Ceiling Suspended	4TB	E	N	7	8	32	0	180	5	1,976	1,976	0	0	0		
352	2	Classroom (A227)	Parabolic Ceiling Suspended	E	4TB	4	10	32	Sw	0	180	5	1,500	1,500	N/A	Parabolic Ceiling Suspended	4TB	E	N	4	10	32	0	180	5	1,500	1,500	0	0	0		
353	2	Classroom (A227)	Parabolic Ceiling Suspended	E	4TB	4	10	32	Sw	0	180	5	1,500	1,500	N/A	Parabolic Ceiling Suspended	4TB	E	N	4	10	32	0	180	5	1,500	1,500	0	0	0		
354	2	Hallway	Exit Sign	S	LED	1	1	5	N	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	24	365	1	6	48	0	0	0		
355	2	Hallway	Exit Sign	S	LED	2	1	5	N	24	365	1	11	96	N/A	Equipment / Fume Hood	LED	S	N	2	1	5	24	365	1	11	96	0	0	0		
356	2	Hallway	Recessed	E	4TB	5	2	32	Sw	2	24	365	1	345	180	N/A	Recessed	4TB	E	N	5	2	32	2	24	365	1	345	180	0	0	0
357	2	Electrical Room	Recessed	E	4TB	4	3	32	Sw	0	180	5	404	614	N/A	Recessed	4TB	E	N	4	3	32	0	180	5	404	614	0	0	0		
358	2	Bathroom Women	Recessed	E	4TB U-Shaped	1	2	32	Sw	0	180	5	69	105	N/A	Recessed	4TB U-Shaped	E	N	1	2	32	0	180	5	69	105	0	0	0		
359	2	Jenlin's Chapel	Recessed	E	4TB	3	2	32	Sw	2	24	365	1	207	108	N/A	Recessed	4TB	E	N	3	2	32	2	24	365	1	207	108	0	0	0
360	2	Bathroom Men	Recessed	E	4TB	4	3	32	Sw	4	180	5	404	307	N/A	Recessed	4TB	E	N	4	3	32	4	180	5	404	307	0	0	0		
361	2	Bathroom Men	Recessed	E	4TB U-Shaped	1	2	32	Sw	0	180	5	69	105	N/A	Recessed	4TB U-Shaped	E	N	1	2	32	0	180	5	69	105	0	0	0		
362	2	Hallway	Recessed	E	4TB	12	3	32	Sw	34	365	5	1,212	7,078	N/A	Recessed	4TB	E	N	12	3	32	34	365	5	1,212	7,078	0	0	0		
363	2	Hallway	Recessed	E	4TB	1	2	32	Sw	0	180	5	62	79	N/A	Recessed	4TB	E	N	1	2	32	0	180	5	62	79	0	0	0		
364	2	Hallway	Recessed	E	4TB	1	2	32	Sw	0	180	5	62	79	N/A	Recessed	4TB	E	N	1	2	32	0	180	5	62	79	0	0	0		
365	2	Classroom (A226)	Parabolic Ceiling Suspended	E	4TB	3	16	32	Sw	0	180	5	1,513	2,348	N/A	Parabolic Ceiling Suspended	4TB	E	N	3	16	32	0	180	5	1,513	2,348	0	0	0		
366	2	Classroom (A226)	Exit Sign	S	LED	2	1	5	N	24	365	1	11	96	N/A	Equipment / Fume Hood	LED	S	N	2	1	5	24	365	1	11	96	0	0	0		
367	2	Classroom (A226)	Parabolic Ceiling Suspended	E	4TB	4	16	32	Sw	0	180	5	2,068	3,143	N/A	Parabolic Ceiling Suspended	4TB	E	N	4	16	32	0	180	5	2,068	3,143	0	0	0		
368	2	Classroom (A224)	Parabolic Ceiling Suspended	E	4TB	4	16	32	Sw	0	180	5	2,068	3,143	N/A	Parabolic Ceiling Suspended	4TB	E	N	4	16	32	0	180	5	2,068	3,143	0	0	0		
369	2	Classroom (A224)	Exit Sign	S	LED	2	1	5	N	24	365	1	11	96	N/A	Equipment / Fume Hood	LED	S	N	2	1	5	24	365	1	11	96	0	0	0		
370	2	Hallway	Recessed	E	4TB	1	3	32	Sw	16	365	5	101	590	N/A	Recessed	4TB	E	N	1	3	32	16	365	5	101	590	0	0	0		
371	2	Hallway	Exit Sign	S	LED	1	1	5	N	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	24	365	1	6	48	0	0	0		
372	2b	Staircase	Recessed	E	4TB	4	3	32	Sw	19	365	5	64	2,359	18-3L	Recessed	4TB	E	BL	4	3	32	19	365	5	64	2,359	0	961	961		
373	2	Hallway	Recessed	E	4TB	1	1	5	N	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	24	365	1	6	48	0	0	0		
374	2	Science Room / Laboratory (A223)	Parabolic Ceiling Suspended	E	4TB	7	10	32	Sw	0	180	5	2,275	3,456	N/A	Parabolic Ceiling Suspended	4TB	E	N	7	10	32	0	180	5	2,275	3,456	0	0	0		
375	3	Classroom (A227)	Parabolic Ceiling Suspended	E	4TB	4	6	32	Sw	0	180	5	788	1,188	N/A	Parabolic Ceiling Suspended	4TB	E	N	4	6	32	0	180	5	788	1,188	0	0	0		
376	3	Hallway	Recessed	E	4TB	6	3	32	Sw	0	180	5	808	1,228	N/A	Recessed	4TB	E	N	6	3	32	0	180	5	808	1,228	0	0	0		
377	3	Classroom (A220)	Parabolic Ceiling Suspended	E	4TB	6	3	32	Sw	0	180	5	788	1,188	N/A	Parabolic Ceiling Suspended	4TB	E	N	6	3	32	0	180	5	788	1,188	0	0	0		
378	2	Science Room / Laboratory	Parabolic Ceiling Suspended	E	4TB	4	6	32	Sw	0	180	5	788	1,188	N/A	Parabolic Ceiling Suspended	4TB	E	N	4	6	32	0	180	5	788	1,188	0	0	0		
379	2	Science Room / Laboratory	Parabolic Ceiling Suspended	E	4TB	1	4	32	Sw	0	180	5	133	202	N/A	Parabolic Ceiling Suspended	4TB	E	N	1	4	32	0	180	5	133	202	0	0	0		
380	2	Science Room / Laboratory	Exit Sign	S	LED	1	1	5	N	24	365	1	6	48	N/A	Equipment / Fume Hood	LED	S	N	1	1	5	24	365	1	6	48	0	0	0		
381	2	Science Room / Laboratory (A221)	Recessed	E	4TB	5	3	32	Sw	16	365	5	659	2,649	N/A	Recessed	4TB	E	N	5	3	32	16	365	5	659	2,649	0	0	0		
382	2	Science Room / Laboratory (A221)	Parabolic Ceiling Suspended	E	4TB	7	10	32	Sw	0	180	5	2,275	3,456	N/A	Parabolic Ceiling Suspended	4TB	E	N	7	10	32	0	180	5	2,275	3,456	0	0			

Legend

Fixture Type	Lamp Type	Control Type	Ballast Type	Retrofit Category
Ceiling Suspended	CFL	Admtn. Timer (T)	S (Soft)	NA (None)
Exit Sign	3T12 U-Shaped	Bi-Level (BL)	E (Electronic)	TB (Install new TB)
Science	3T5	Contact (C)	M (Magnetic)	TS (Install new TS)
High Bay	3T5 U-Shaped	Daylight & Motion (M)		CFL (Install new CFL)
Parabolic Ceiling Mounted	3T8	Daylight & Switch (DLSw)		LEDs (Install new LED Exit)
Parabolic Ceiling Suspended	3T8 U-Shaped	Daylight Sensor (DS)		LED (Install new LED)
Parabolic Wall Mounted	4T5	Dimmer (D)		D (Delamping)
Parabolic Wall Suspended	4T5 U-Shaped	Motion Sensor (MS)		C (Controls Only)
Parabolic Wallpack	4T5 U-Shaped	Motion Sensor (MSw)		P-SMH (Install new Pulse-Start Metal Halide)
Chandelier	6T12	None (N)		
Equipment / Fume Hood	6T12 U-Shaped	Occupancy Sensor (OS)		
Flood	6T5	Occupancy Sensor - CM (OSCM)		
Landscape	6T5 U-Shaped	PhotoCell (PC)		
Low Bay	6T8	Switch (Sw)		
Parabolic Wall Mounted	6T8 U-Shaped			
Pole Mounted	8T12			
Pole Mounted Off Building	8T12 U-Shaped			

APPENDIX C: THIRD PARTY ENERGY SUPPLIERS
<http://www.state.nj.us/bpu/commercial/shopping.html>

Third Party Electric Suppliers for JCPL Service Territory	Telephone & Web Site
Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 www.hess.com
BOC Energy Services, Inc. 575 Mountain Avenue Murray Hill, NJ 07974	(800) 247-2644 www.boc.com
Commerce Energy, Inc. 4400 Route 9 South, Suite 100 Freehold, NJ 07728	(800) 556-8457 www.commerceenergy.com
Constellation NewEnergy, Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	(888) 635-0827 www.newenergy.com
Direct Energy Services, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(866) 547-2722 www.directenergy.com
FirstEnergy Solutions 300 Madison Avenue Morristown, NJ 07926	(800) 977-0500 www.fes.com
Glacial Energy of New Jersey, Inc. 207 LaRoche Avenue Harrington Park, NJ 07640	(877) 569-2841 www.glacialenergy.com
Integritys Energy Services, Inc. 99 Wood Ave, South, Suite 802 Iselin, NJ 08830	(877) 763-9977 www.integritysenergy.com
Liberty Power Delaware, LLC Park 80 West Plaza II, Suite 200 Saddle Brook, NJ 07663	(866) 769-3799 www.libertypowercorp.com
Liberty Power Holdings, LLC Park 80 West Plaza II, Suite 200 Saddle Brook, NJ 07663	(800) 363-7499 www.libertypowercorp.com
Pepco Energy Services, Inc. 112 Main St. Lebanon, NJ 08833	(800) 363-7499 www.pepco-services.com
PPL EnergyPlus, LLC 811 Church Road Cherry Hill, NJ 08002	(800) 281-2000 www.pplenergyplus.com
Sempra Energy Solutions 581 Main Street, 8th Floor Woodbridge, NJ 07095	(877) 273-6772 www.semprasolutions.com
South Jersey Energy Company One South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 756-3749 www.southjerseyenergy.com

Third Party Electric Suppliers for JCPL Service Territory	Telephone & Web Site
Suez Energy Resources NA, Inc. 333 Thornall Street, 6th Floor Edison, NJ 08837	(888) 644-1014 www.suezenergyresources.com
UGI Energy Services, Inc. 704 East Main Street, Suite 1 Moorestown, NJ 08057	(856) 273-9995 www.ugienergyservices.com

Third Party Gas Suppliers for NJNG Service Territory	Telephone & Web Site
Cooperative Industries 412-420 Washington Avenue Belleville, NJ 07109	(800) 628-9427 www.cooperativenet.com
Direct Energy Services, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(866) 547-2722 www.directenergy.com
Gateway Energy Services Corp. 44 Whispering Pines Lane Lakewood, NJ 08701	(800) 805-8586 www.gesc.com
UGI Energy Services, Inc. 704 East Main Street, Suite 1 Moorestown, NJ 08057	(856) 273-9995 www.ugienergyservices.com
Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 www.hess.com
Intelligent Energy 2050 Center Avenue, Suite 500 Fort Lee, NJ 07024	(800) 724-1880 www.intelligentenergy.org
Metromedia Energy, Inc. 6 Industrial Way Eatontown, NJ 07724	(877) 750-7046 www.metromediaenergy.com
MxEnergy, Inc. 510 Thornall Street, Suite 270 Edison, NJ 08837	(800) 375-1277 www.mxenergy.com
NATGASCO (Mitchell Supreme) 532 Freeman Street Orange, NJ 07050	(800) 840-4427 www.natgasco.com
NJ Gas & Electric 1 Bridge Plaza, Fl. 2 Fort Lee, NJ 07024	(866) 568-0290 www.NewJerseyGasElectric.com
Pepco Energy Services, Inc. 112 Main Street Lebanon, NJ 08833	(800) 363-7499 www.pepco-services.com
PPL EnergyPlus, LLC 811 Church Road Cherry Hill, NJ 08002	(800) 281-2000 www.pplenergyplus.com

Third Party Gas Suppliers for NJNG Service Territory	Telephone & Web Site
South Jersey Energy Company One South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 756-3749 www.southjerseyenergy.com
Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	(800) 225-1560 www.spragueenergy.com
Woodruff Energy 73 Water Street Bridgeton, NJ 08302	(800) 557-1121 www.woodruffenergy.com

APPENDIX D: GLOSSARY AND METHOD OF CALCULATIONS

Net ECM Cost: The net ECM cost is the cost experienced by the customer, which is typically the total cost (materials + labor) of installing the measure minus any available incentives. Both the total cost and the incentive amounts are expressed in the summary for each ECM.

Annual Energy Cost Savings (AECS): This value is determined by the audit firm based on the calculated energy savings (kWh or Therm) of each ECM and the calculated energy costs of the building.

Lifetime Energy Cost Savings (LECS): This measure estimates the energy cost savings over the lifetime of the ECM. It can be a simple estimation based on fixed energy costs. If desired, this value can factor in an annual increase in energy costs as long as the source is provided.

Simple Payback: This is a simple measure that displays how long the ECM will take to break-even based on the annual energy and maintenance savings of the measure.

ECM Lifetime: This is included with each ECM so that the owner can see how long the ECM will be in place and whether or not it will exceed the simple payback period. Additional guidance for calculating ECM lifetimes can be found below. This value can come from manufacturer's rated lifetime or warranty, the ASHRAE rated lifetime, or any other valid source.

Operating Cost Savings (OCS): This calculation is an annual operating savings for the ECM. It is the difference in the operating, maintenance, and / or equipment replacement costs of the existing case versus the ECM. In the case where an ECM lifetime will be longer than the existing measure (such as LED lighting versus fluorescent) the operating savings will factor in the cost of replacing the units to match the lifetime of the ECM. In this case or in one where one-time repairs are made, the total replacement / repair sum is averaged over the lifetime of the ECM.

Return on Investment (ROI): The ROI is expressed as the percentage return of the investment based on the lifetime cost savings of the ECM. This value can be included as an annual or lifetime value, or both.

Net Present Value (NPV): The NPV calculates the present value of an investment's future cash flows based on the time value of money, which is accounted for by a discount rate (assumes bond rate of 3.2%).

Internal Rate of Return (IRR): The IRR expresses an annual rate that results in a break-even point for the investment. If the owner is currently experiencing a lower return on their capital than the IRR, the project is financially advantageous. This measure also allows the owner to compare ECMs against each other to determine the most appealing choices.

Gas Rate and Electric Rate (\$/therm and \$/kWh): The gas rate and electric rate used in the financial analysis is the total annual energy cost divided by the total annual energy usage for the 12 month billing period studied. The graphs of the monthly gas and electric rates reflect the total monthly energy costs divided by the monthly usage, and display how the average rate fluctuates throughout the year. The average annual rate is the only rate used in energy savings calculations.

Calculation References

Term	Definition
ECM	Energy Conservation Measure
AOCS	Annual Operating Cost Savings
AECS	Annual Energy Cost Savings
LOCS*	Lifetime Operating Cost Savings
LECS	Lifetime Energy Cost Savings
LCS	Lifetime Cost Savings
NPV	Net Present Value
IRR	Internal Rate of Return
DR	Discount Rate
Net ECM Cost	Total ECM Cost – Incentive
LECS	AECS X ECM Lifetime
AOCS	LOCS / ECM Lifetime
LCS	LOCS+LECS
Simple Payback	Net ECM Cost / (AECS + AOCS)
Lifetime ROI	(LECS + LOCS – Net ECM Cost) / Net ECM Cost
Annual ROI	(Lifetime ROI / Lifetime) = [(AECS + OCS) / Net ECM Cost – (1 / Lifetime)]

* The lifetime operating cost savings are all avoided operating, maintenance, and/or component replacement costs over the lifetime of the ECM. This can be the sum of any annual operating savings, recurring or bulk (i.e. one-time repairs) maintenance savings, or the savings that comes from avoiding equipment replacement needed for the existing measure to meet the lifetime of the ECM (e.g. lighting change outs).

Excel NPV and IRR Calculation

In Excel, function =IRR (values) and =NPV(rate, values) are used to quickly calculate the IRR and NPV of a series of annual cash flows. The investment cost will typically be a negative cash flow at year 0 (total cost - incentive) with years 1 through the lifetime receiving a positive cash flow from the annual energy cost savings and annual maintenance savings. The calculations in the example below are for an ECM that saves \$850 annually in energy and maintenance costs (over a 10 year lifetime) and takes \$5,000 to purchase and install after incentives:

	A	B	C	D	E	F	G	H	I
1									
2									
3					Year	Cash Flow			
4					0	\$ (5,000.00)			Investment Cost
5					1	\$ 850.00			Cash Flow: Annual Energy Cost Savings + Annual Maintenance Savings
6					2	\$ 850.00			
7					3	\$ 850.00			
8					4	\$ 850.00			
9					5	\$ 850.00			
10					6	\$ 850.00			
11					7	\$ 850.00			
12					8	\$ 850.00			
13					9	\$ 850.00			
14					10	\$ 850.00			
15									
16					IRR	11.03%			Formula: =IRR(F4:F14) =NPV(0.03,F5:F14)+F4
17					NPV	\$2,250.67			

Solar PV ECM Calculation

There are several components to the calculation:

Costs:	Material of PV system including panels, mounting and net-metering + Labor
Energy Savings:	Reduction of kWh electric cost for life of panel, 25 years
Incentive 1:	NJ Renewable Energy Incentive Program (REIP), for systems of size 50kW or less, \$1/Watt incentive subtracted from installation cost
Incentive 2:	Solar Renewable Energy Credits (SRECs) - Market-rate incentive. Calculations assume \$600/Megawatt hour consumed per year for a maximum of 15 years; added to annual energy cost savings for a period of 15 years. (Megawatt hour used is rounded to nearest 1,000 kWh)
Assumptions:	A Solar Pathfinder device is used to analyze site shading for the building and determine maximum amount of full load operation based on available sunlight. When the Solar Pathfinder device is not implemented, amount of full load operation based on available sunlight is assumed to be 1,180 hours in New Jersey.

Total lifetime PV energy cost savings =
kWh produced by panel * [\$/kWh cost * 25 years + \$600/Megawatt hour /1000 * 15 years]

ECM and Equipment Lifetimes

Determining a lifetime for equipment and ECM's can sometimes be difficult. The following table contains a list of lifetimes that the NJCEP uses in its commercial and industrial programs. Other valid sources are also used to determine lifetimes, such as the DOE, ASHRAE, or the manufacturer's warranty.

Lighting is typically the most difficult lifetime to calculate because the fixture, ballast, and bulb can all have different lifetimes. Essentially the ECM analysis will have different operating cost savings (avoided equipment replacement) depending on which lifetime is used.

When the bulb lifetime is used (rated burn hours / annual burn hours), the operating cost savings is just reflecting the theoretical cost of replacing the existing case bulb and ballast over the life of the recommended bulb. Dividing by the bulb lifetime will give an annual operating cost savings.

When a fixture lifetime is used (e.g. 15 years) the operating cost savings reflects the avoided bulb and ballast replacement cost of the existing case over 15 years minus the projected bulb and ballast replacement cost of the proposed case over 15 years. This will give the difference of the equipment replacement costs between the proposed and existing cases and when divided by 15 years will give the annual operating cost savings.

New Jersey Clean Energy Program Commercial & Industrial Lifetimes

Measure	Life Span
Commercial Lighting — New	15
Commercial Lighting — Remodel/Replacement	15
Commercial Custom — New	18
Commercial Chiller Optimization	18
Commercial Unitary HVAC — New - Tier 1	15
Commercial Unitary HVAC — Replacement - Tier 1	15
Commercial Unitary HVAC — New - Tier 2	15
Commercial Unitary HVAC — Replacement Tier 2	15
Commercial Chillers — New	25
Commercial Chillers — Replacement	25
Commercial Small Motors (1-10 HP) — New or Replacement	20
Commercial Medium Motors (11-75 HP) — New or Replacement	20
Commercial Large Motors (76-200 HP) — New or Replacement	20
Commercial VSDs — New	15
Commercial VSDs — Retrofit	15
Commercial Comprehensive New Construction Design	18
Commercial Custom — Replacement	18
Industrial Lighting — New	15
Industrial Lighting — Remodel/Replacement	15
Industrial Unitary HVAC — New - Tier 1	15
Industrial Unitary HVAC — Replacement - Tier 1	15
Industrial Unitary HVAC — New - Tier 2	15
Industrial Unitary HVAC — Replacement Tier 2	15
Industrial Chillers — New	25
Industrial Chillers — Replacement	25
Industrial Small Motors (1-10 HP) — New or Replacement	20
Industrial Medium Motors (11-75 HP) — New or Replacement	20
Industrial Large Motors (76-200 HP) — New or Replacement	20
Industrial VSDs — New	15
Industrial VSDs — Retrofit	15
Industrial Custom — Non-Process	18
Industrial Custom — Process	10
Small Commercial Gas Furnace — New or Replacement	20
Small Commercial Gas Boiler — New or Replacement	20
Small Commercial Gas DHW — New or Replacement	10
C&I Gas Absorption Chiller — New or Replacement	25
C&I Gas Custom — New or Replacement (Engine Driven Chiller)	25
C&I Gas Custom — New or Replacement (Gas Efficiency Measures)	18
O&M savings	3
Compressed Air (GWh participant)	8

APPENDIX E: STATEMENT OF ENERGY PERFORMANCE FROM ENERGY STAR®

OMB No. 2060-0347



STATEMENT OF ENERGY PERFORMANCE
Freehold Regional HS District - Colts Neck High School

Building ID: 2303478
 For 12-month Period Ending: February 28, 2010¹
 Date SEP becomes ineligible: N/A

Date SEP Generated: July 20, 2010

Facility Freehold Regional HS District - Colts Neck High School 59 Five Points Road Colts Neck, NJ 07722	Facility Owner N/A	Primary Contact for this Facility N/A
--	------------------------------	---

Year Built: 1995
 Gross Floor Area (ft²): 220,000

Energy Performance Rating² (1-100) 2

Site Energy Use Summary³

Electricity - Grid Purchase(kBtu)	12,408,383
Natural Gas (kBtu) ⁴	14,380,102
Total Energy (kBtu)	26,788,485

Energy Intensity⁴

Site (kBtu/ft²/yr)	122
Source (kBtu/ft²/yr)	257

Emissions (based on site energy use)

Greenhouse Gas Emissions (MtCO ₂ e/year)	2,654
---	-------

Electric Distribution Utility

FirstEnergy - Jersey Central Power & Lt Co

National Average Comparison

National Average Site EUI	83
National Average Source EUI	133
% Difference from National Average Source EUI	93%
Building Type	K-12 School

Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

Meets Industry Standards⁵ for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Certifying Professional
N/A

Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

The government estimates the average time needed to fill out this form is 8 hours (includes the time for entering energy data, Licensed Professional facility inspection, and retitling the SEP) and welcomes suggestions for reducing this level of effort. Send comments (referencing OMB control number) to the Director, Collection Strategies Division, U.S. EPA (2822T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20480.

EPA Form 5900-16

APPENDIX F: INCENTIVE PROGRAMS

New Jersey Clean Energy Pay for Performance

The NJ Clean Energy Pay for Performance (P4P) Program relies on a network of Partners who provide technical services to clients. LGEA participating clients who are not receiving Direct Energy Efficiency and Conservation Block Grants are eligible for P4P. SWA is an eligible Partner and can develop an Energy Reduction Plan for each project with a whole-building traditional energy audit, a financial plan for funding the energy measures and an installation construction schedule.

The Energy Reduction Plan must define a comprehensive package of measures capable of reducing a building's energy consumption by 15+%. P4P incentives are awarded upon the satisfactory completion of three program milestones: submittal of an Energy Reduction Plan prepared by an approved Program Partner, installation of the recommended measures and completion of a Post-Construction Benchmarking Report. The incentives for electricity and natural gas savings will be paid based on actual savings, provided that the minimum 15% performance threshold savings has been achieved.

For further information, please see: <http://www.njcleanenergy.com/commercial-industrial/programs/pay-performance/existing-buildings> .

Direct Install 2010 Program*

Direct Install is a division of the New Jersey Clean Energy Programs' Smart Start Buildings. It is a turn-key program for small to mid-sized facilities to aid in upgrading equipment to more efficient types. It is designed to cut overall energy costs by upgrading lighting, HVAC and other equipment with energy efficient alternatives. The program pays **up to 60%** of the retrofit costs, including equipment cost and installation costs.

Eligibility:

- Existing small and mid-sized commercial and industrial facilities with peak electrical demand **below 200 kW** within 12 months of applying
- Must be located in New Jersey
- Must be served by one of the state's public, regulated or natural gas companies
 - Electric: Atlantic City Electric, Jersey Central Power & Light, Orange Rockland Electric, PSE&G
 - Natural Gas: Elizabethtown Gas, New Jersey Natural Gas, PSE&G, South Jersey Gas

For the most up to date information on contractors in New Jersey who participate in this program, go to: <http://www.njcleanenergy.com/commercial-industrial/programs/direct-install>

Smart Start

New Jersey's SmartStart Building Program is administered by New Jersey's Office of Clean Energy. The program also offers design support for larger projects and technical assistance for smaller projects. If your project specifications do not fit into anything defined by the program, there are even incentives available for custom projects.

There are a number of improvement options for commercial, industrial, institutional, government, and agricultural projects throughout New Jersey. Alternatives are designed to

enhance quality while building in energy efficiency to save money. Project categories included in this program are New Construction and Additions, Renovations, Remodeling and Equipment Replacement.

For the most up to date information on how to participate in this program, go to: <http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>.

Renewable Energy Incentive Program*

The Renewable Energy Incentive Program (REIP) provides incentives that reduce the upfront cost of installing renewable energy systems, including solar, wind, and sustainable biomass. Incentives vary depending upon technology, system size, and building type. Current incentive levels, participation information, and application forms can be found at the website listed below.

Solar Renewable Energy Credits (SRECs) represent all the clean energy benefits of electricity generated from a solar energy system. SRECs can be sold or traded separately from the power, providing owners a source of revenue to help offset the cost of installation. All solar project owners in New Jersey with electric distribution grid-connected systems are eligible to generate SRECs. Each time a system generates 1,000 kWh of electricity an SREC is earned and placed in the customer's account on the web-based SREC tracking system.

For the most up to date information on how to participate in this program, go to: <http://www.njcleanenergy.com/renewable-energy/home/home>.

Utility Sponsored Programs

Check with your local utility companies for further opportunities that may be available.

Energy Efficiency and Conservation Block Grant Rebate Program

The Energy Efficiency and Conservation Block Grant (EECBG) Rebate Program provides supplemental funding up to \$20,000 for eligible New Jersey local government entities to lower the cost of installing energy conservation measures. Funding for the EECBG Rebate Program is provided through the American Recovery and Reinvestment Act (ARRA).

For the most up to date information on how to participate in this program, go to: <http://njcleanenergy.com/EECBG>

Other Federal and State Sponsored Programs

Other federal and state sponsored funding opportunities may be available, including BLOCK and R&D grant funding. For more information, please check <http://www.dsireusa.org/>.

*Subject to availability. Incentive program timelines might not be sufficient to meet the 25% in 12 months spending requirement outlined in the LGEA program.

APPENDIX G: VendingMiser™ and SnackMiser™ Energy Savings



EnergyMisers

[VendingMiser®](#) [CoolerMiser™](#) [SnackMiser™](#) [PlugMiser™](#) [VM2iQ®](#) [CM2iQ®](#)

Savings Calculator

Please replace the default values in the table below with your location's unique information and then click on the "calculate savings" button.

Note: To calculate for CoolerMiser, use the equivalent VendingMiser results. To calculate for PlugMiser, use the equivalent SnackMiser results.

Energy Costs (\$0.000 per kWh)	154
Facility Occupied Hours per Week	40
Number of Cold Drink Vending Machines	2
Number of Non-refrigerated Snack Machines	2
Power Requirements of Cold Drink Machine (Watts; 400 typical)	100
Power Requirements of Snack Machine (Watts; 80 typical)	40
VendingMiser® Sale Price (for cold drink machines)	199
SnackMiser™ Sale Price (for snack machines)	99

Results of your location's projected savings with VendingMiser® installed:

COLD DRINK MACHINES Current Projected Total Savings % Savings				
kWh	1747	638	1109	63%
Cost of Operation	\$269.07	\$98.23	\$170.84	63%
SNACK MACHINES Current Projected Total Savings % Savings				
kWh	699	166	532	76%
Cost of Operation	\$107.63	\$25.63	\$82	76%

Location's Total Annual Savings

	Current	Projected	Total Savings	% Savings
kWh	2446	804	1642	67%
Cost of Operation	\$376.70	\$123.86	\$252.84	67%

Total Project Cost Break Even (Months)

\$596	28.29
-------	-------

Estimated Five Year Savings on ALL Machines = \$1,264.20

APPENDIX H: ENERGY CONSERVATION MEASURES

ECM #	ECM description	Est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	KBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
1	Install Fifteen (15) New CFL Fixtures	135	0	135	904	0.2	0	0.0	265	405	5	2,023	0.3	1398	280	299	1,707	1,619
2	Install Variable Frequency Drives on Motors of Heating Hot Water Circulators	20,000	0	20,000	64,000	13.3	0	1.0	0	9,856	15	147,840	2.0	639	43	49	97,660	87,680
3	Retrofit Two (2) Refrigerated Vending Machines with VendingMiser™ Devices	398	0	398	1,109	0.2	0	0.1	0	171	5	854	2.3	115	23	43	2,511	1,986
4	Retrofit Two (2) Existing Vending Machines with SnackMiser™ Devices	198	0	198	532	0.1	0	0.1	0	82	5	410	2.4	107	21	41	766	953
5	Install Variable Frequency Drives on Motors of Heating Hot Water Circulators	13,500	0	13,500	32,200	6.7	0	0.5	0	4,959	15	74,382	2.7	451	30	36	45,698	44,114

0-5 Year Payback

ECM #	ECM description	Est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	KBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
6	Install thirty (30) New Occupancy Sensors	6,600	600	6,000	12,460	2.6	0	0.2	0	1,919	15	28,783	3.1	380	25	31	16,579	22,310
7	Install (27) New Bi-level T8 Fluorescent Fixtures in Stairwells	4,590	675	3,915	6,623	1.4	0	0.1	0	1,020	15	15,298	3.8	291	19	25	8,086	11,858
8	Install Variable Frequency Drives on Motors of Chilled Water Circulators	20,000	4,800	15,200	24,100	5.0	0	0.4	0	3,711	15	55,671	4.1	266	18	23	29,106	33,017
9	Install Premium Efficiency Motors on (2) Heating Hot Water Circulators	5,082	324	4,758	5,632	1.2	0	0.1	0	867	20	17,347	5.5	265	13	18	8,146	7,716
10	Install Variable Frequency Drives on Motors of Chilled Water Circulators	16,000	3,000	13,000	15,100	3.1	0	0.2	0	2,325	15	34,881	5.6	168	11	16	14,760	20,687
12	Replace Seven (7) Compact Refrigerators with 2.7 Cu. Ft. ENERGY STAR® Models	693	0	693	560	0.1	0	0.1	0	86	15	1,294	8.0	87	6	9	322	1,003

5-10 Year Payback

ECM #	ECM description	Est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	KBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
14	Replace Two (2) Washing Machines with ENERGY STAR® Units	1,600	0	1,600	1,000	0.2	0	0.1	17	171	15	2,565	9.4	60	4	7	412	1,791
15	Replace Seventeen (17) Large Refrigerators with ENERGY STAR® Units	7,650	0	7,650	5,100	1.1	0	0.1	0	785	15	11,781	9.7	54	4	6	1,592	9,132
16	Install Premium Efficiency Motors on Walk-In Box Evaporator Fans	3,500	0	3,500	2,283	0.5	0	0.0	0	352	20	7,032	10.0	101	5	8	1,731	3,128
11	Install 49.68 kW PV Rooftop System with Incentives	355,350	22,500	332,850	58,007	47	0	0.9	0	43,733	25	223,327	7.6	123.9	5.0	10.6	238,143	79,470
13	Install 190.90 kW PV Rooftop System without Incentives	1,050,525	0	1,050,525	169,888	140	0	2.6	0	127,563	25	654,069	8.2	107.0	4.3	9.4	615,557	232,747

Renewable Measures

APPENDIX I: METHOD OF ANALYSIS

Assumptions and tools

Energy modeling tool: Established/standard industry assumptions, E-Quest
Cost estimates: RS Means 2009 (Facilities Maintenance & Repair Cost Data)
RS Means 2009 (Building Construction Cost Data)
RS Means 2009 (Mechanical Cost Data)
Published and established specialized equipment material and labor costs
Cost estimates also based on utility bill analysis and prior experience with similar projects

Disclaimer

This engineering audit was prepared using the most current and accurate fuel consumption data available for the site. The estimates that it projects are intended to help guide the owner toward best energy choices. The costs and savings are subject to fluctuations in weather, variations in quality of maintenance, changes in prices of fuel, materials, and labor, and other factors. Although we cannot guarantee savings or costs, we suggest that you use this report for economic analysis of the building and as a means to estimate future cash flow.

THE RECOMMENDATIONS PRESENTED IN THIS REPORT ARE BASED ON THE RESULTS OF ANALYSIS, INSPECTION, AND PERFORMANCE TESTING OF A SAMPLE OF COMPONENTS OF THE BUILDING SITE. ALTHOUGH CODE-RELATED ISSUES MAY BE NOTED, SWA STAFF HAVE NOT COMPLETED A COMPREHENSIVE EVALUATION FOR CODE-COMPLIANCE OR HEALTH AND SAFETY ISSUES. THE OWNER(S) AND MANAGER(S) OF THE BUILDING(S) CONTAINED IN THIS REPORT ARE REMINDED THAT ANY IMPROVEMENTS SUGGESTED IN THIS SCOPE OF WORK MUST BE PERFORMED IN ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL LAWS AND REGULATIONS THAT APPLY TO SAID WORK. PARTICULAR ATTENTION MUST BE PAID TO ANY WORK WHICH INVOLVES HEATING AND AIR MOVEMENT SYSTEMS, AND ANY WORK WHICH WILL INVOLVE THE DISTURBANCE OF PRODUCTS CONTAINING MOLD, ASBESTOS, OR LEAD.