



Steven Winter Associates, Inc.
Building Systems Consultants
www.swinter.com

293 Route 18 South, Suite 330
East Brunswick, NJ 08816

Telephone (866) 676-1972
Facsimile (203) 852-0741

June 14, 2013

**Local Government Energy Program
Energy Audit Report**

**Modell's Sports Complex
Dwight-Englewood School
315 East Palisade Avenue
Englewood, NJ 07631**

Project Number: LGEA106



Table of Contents

EXECUTIVE SUMMARY 3

INTRODUCTION 6

HISTORICAL ENERGY CONSUMPTION..... 7

EXISTING FACILITY AND SYSTEMS DESCRIPTION..... 13

RENEWABLE AND DISTRIBUTED ENERGY MEASURES..... 22

PROPOSED ENERGY CONSERVATION MEASURES 24

PROPOSED FURTHER RECOMMENDATIONS..... 30

APPENDIX A: EQUIPMENT LIST 33

APPENDIX B: LIGHTING STUDY 34

APPENDIX C: UPCOMING EQUIPMENT PHASEOUTS 36

APPENDIX D: THIRD PARTY ENERGY SUPPLIERS 38

APPENDIX E: GLOSSARY AND METHOD OF CALCULATIONS..... 45

APPENDIX F: STATEMENT OF ENERGY PERFORMANCE FROM ENERGY STAR®..... 49

APPENDIX G: INCENTIVE PROGRAMS 50

APPENDIX H: ENERGY CONSERVATION MEASURES..... 53

APPENDIX I: METHOD OF ANALYSIS 54

EXECUTIVE SUMMARY

The Dwight-Englewood School's Modell Athletic Complex is a two story, 37,500 ft² athletic complex. The originally building, built in 1954, currently houses the Silberfein Gymnasium. In 1976 an addition was constructed which now houses the large gymnasium, locker rooms, weight room, athletic offices restrooms, and lobby. The two gymnasium areas are double height and there are two levels of single height locker rooms, storage, and offices. There is also a one-story structure which connects the athletic complex to the Imperatore Library. The following chart provides a comparison of the current building energy usage based on the period from December 2011 through November 2012 with the proposed energy usage resulting from the installation of recommended Energy Conservation Measures (ECMs) excluding any renewable energy:

Table 1: State of Building—Energy Usage

	Electric Usage (kWh/yr)	Gas Usage (therms/yr)	Current Annual Cost of Energy (\$)	Site Energy Use Intensity (kBtu/ft ² /yr)	Source Energy Use Intensity (kBtu/ft ² /yr)	Joint Energy Consumption (MMBtu/yr)
Current	124,593	13,950	\$32,956	49	77	1,820
Proposed	87,810	12,060	\$24,145	40	60	1,506
Savings	36,783	1,891	\$8,810*	8.	16	315
% Savings	29.5%	13.6%	26.7%	17.3%	21.4%	17.3%
*Includes operation and maintenance savings						

SWA has entered energy information about the Dwight-Englewood School facility into the U.S. Environmental Protection Agency's (EPA) Energy Star Portfolio Manager Energy Benchmarking system. This facility is categorized as a "Other-Recreation" space type. The ENERGY STAR® Portfolio Manager calculates an Energy Performance Rating for several building types; however, the system is currently unable to calculate a Performance Rating for this building type. The Site Energy Utilization Intensity (Site EUI) was calculated to be 49 kBtu/ft²/yr compared to the National Median of 39 kBtu/ft²/yr. See the ECM section for guidance on how to further reduce the building's energy intensity.

Recommendations

Based on the current state of the building and its energy use, SWA recommends implementing the following Energy Conservation Measures:

Recommended ECMs	Incentive Program (APPENDIX G for details)
Upgrade 37 Incandescent lamps to Compact Fluorescent Lamps (CFLs)	N/A
Install 14 occupancy sensors	Smart Start
Retro-commissioning	N/A
Retrofit 29 Metal Halide fixtures with T5 fixtures	Smart Start

Appendix H contains an Energy Conservation Measures table

Capital Improvements are recommendations for the building that may not be cost-effective at the current time, but that could yield a significant long-term payback. Capital improvements may also constitute equipment that is currently being operated beyond its useful lifetime. These recommendations should typically be considered as part of a long-term capital improvement plan. Capital improvements should be considered if additional funds are made available, or if the installed costs can be shared with other improvements, such as major building renovations.

- Replace the original boilers
- Replace the existing electric water heater
- Replace all roof surfaces
- Replace existing windows and doors
- Consider installing a photovoltaic system

In addition to these ECMs, SWA recommends the following Operation and Maintenance (O&M) measures that would contribute to reducing energy usage at low or no cost:

- Interlock exhaust fan controls to packaged roof top units
- Replace old motors with NEMA premium efficiency models
- Install water-efficient fixtures and controls
- Inspect and replace cracked/ineffective caulk.
- Inspect and maintain sealants at all windows for airtight performance.
- Inspect and maintain weather-stripping around all exterior doors and roof hatches.
- Purchase Energy Star® appliances when new purchases are made
- Use smart electric power strips
- Create an energy educational program

There may be energy procurement opportunities for the Dwight-Englewood School to reduce annual utility costs. The building currently pays a competitive utility rate for electric and gas, but may be able to further reduce utility costs. SWA recommends further evaluation with energy suppliers, listed in Appendix D.

Energy Conservation Measure Implementation

Table 2: Energy Conservation Measure Recommendations

Measures	First Year Savings (\$)	Simple Payback Period (Years)	Initial Investment	CO2 Savings (lbs/yr)
0-5 Year	\$8,387	1.8	\$15,505	82,187
Total	\$8,387	1.8	\$15,505	82,187

Environmental Benefits

SWA estimates that implementing the recommended ECMs is equivalent to removing approximately 7 cars from the roads each year or is equivalent of planting 200 trees to absorb CO₂ from the atmosphere.

INTRODUCTION

Launched in 2008, the Local Government Energy Audit (LGEA) Program provides subsidized energy audits for municipal and local government-owned facilities, including offices, courtrooms, town halls, police and fire stations, sanitation buildings, transportation structures, schools and community centers. The Program will subsidize up to 100% of the cost of the audit. The Board of Public Utilities (BPUs) Office of Clean Energy has assigned TRC Energy Services to administer the Program.

Steven Winter Associates, Inc. (SWA) is a 40-year-old architectural/engineering research and consulting firm, with specialized expertise in green technologies and procedures that improve the safety, performance, and cost effectiveness of buildings. SWA has a long-standing commitment to creating energy-efficient, cost-saving and resource-conserving buildings. As consultants on the built environment, SWA works closely with architects, developers, builders, and local, state, and federal agencies to develop and apply sustainable, 'whole building' strategies in a wide variety of building types: commercial, residential, educational and institutional.

SWA performed an energy audit and assessment for the Dwight-Englewood School at 315 East Palisade Avenue, Englewood, NJ. The process of the audit included facility visits on December 10th-11th, 2012 and January 3rd-4th, 2013, benchmarking and energy bill analysis, assessment of existing conditions, energy conservation measures and other recommendations for improvements. The scope of work includes providing a summary of current building conditions, current operating costs, potential savings, and investment costs to achieve these savings. The facility description includes energy usage, occupancy profiles and current building systems along with a detailed inventory of building energy systems, recommendations for improvement and recommendations for energy purchasing and procurement strategies.

The goal of this Local Government Energy Audit is to provide sufficient information to the Dwight-Englewood Schools to make decisions regarding the implementation of the most appropriate and most cost-effective energy conservation measures.

HISTORICAL ENERGY CONSUMPTION

Energy usage, load profile and cost analysis

SWA reviewed electric and gas utility bills from December 2010 through November 2012 that were received from the Dwight-Englewood School. A 12 month period of analysis from December 2011 through November 2012 was used for all calculations and for purposes of benchmarking the building.

Electricity – The building is currently served by one electric meter, supplied and delivered by Public Service Electric & Gas (PSE&G). Electricity is shared with the adjacent Imperatore Library, therefore electric consumption and costs were apportioned according to square footage. Electricity is predominantly used for heating and cooling equipment. Electricity was purchased at an average aggregated rate of \$0.158/kWh and the school consumed 124,593 kWh, or \$19,669 of electricity, for the analyzed billing period. The annual monthly peak demand was 41.8 kW for the month of August, while the average monthly demand was 34 kW.

The chart below shows the monthly electric usage and costs. The dashed green line represents the approximate baseload or minimum electric usage required to operate the building. The baseline usage for the facility is approximately 9,028 kWh.




Figure 1 Annual electric usage and costs

Natural gas – The building is served by one natural gas meter which is supplied by HESS and deliver by PSE&G. Natural gas was purchased at an average aggregated rate of \$0.952/therm and the school consumed 13,950 therms, or \$13,287 of natural gas, for the analyzed billing period. The chart below shows the monthly natural gas usage and costs. The green line represents the approximate baseload or minimum natural gas usage required to operate the school. The non-heating gas baseload for the school is approximately 0 therms. As expected, usage peaks in the winter months in conjunction with the operation of the gas-fired hot water heating boiler. The monthly natural gas costs also peak in the winter months in correlation with the increased natural gas usage.




Figure 2 Annual natural gas usage, costs and estimated baseload




Figure 3 Natural gas usage and heating degree day curves

The chart above shows the monthly natural gas usage along with the heating degree days or HDD. Heating degree days is the difference of the average daily temperature and a base temperature of 65°F, on a particular day. The heating degree days are zero for the days when the average temperature exceeds the base temperature. As expected, the natural gas consumption profile follows a curve similar to the HDD curve. Deficiencies in gas consumption are shown in the chart when the usage curve rises above the HDD curve. In the chart above,

gas usage slightly exceeds the HDD curve between January and March; however, this is attributed to a non-weather dependent domestic hot water heating.

The following pie charts and table show energy use for Dwight-Englewood School based on utility bills for the analyzed billing period. Note: electrical cost at \$46/MMBtu of energy is almost 5 times as expensive as natural gas at \$10/MMBtu.

Annual Energy Consumption / Costs					
	MMBtu	% MMBtu	\$	% \$	\$/MMBtu
Electric Misc	7	0.4%	\$336	1%	46
Electric For Cooling	18	1%	\$849	3%	46
Electric For Heating	59	3%	\$2,751	8%	46
Lighting	251	14%	\$11,619	35%	46
Domestic Hot Water (Elec)	89	5%	\$4,114	12%	46
Domestic Hot Water (Gas)	179	10%	\$1,708	5%	10
Building Space Heating (Gas)	1,216	67%	\$11,579	35%	10
Totals	1,820	100%	\$32,956	100%	18
Total Electric Usage	425	23%	\$19,669	60%	46
Total Gas Usage	1,395	77%	\$13,287	40%	10
Totals	1,820	100%	\$32,956	100%	18




Figure 4 Annual energy consumption and cost breakdown

Energy Benchmarking

SWA has entered energy information about the building in the U.S. Environmental Protection Agency's (EPA) ENERGY STAR® Portfolio Manager energy benchmarking system. This facility is categorized as a "Other-Recreation" space type. The ENERGY STAR® Portfolio Manager calculates an Energy Performance Rating for several building types; however, the system is currently unable to calculate a Performance Rating for this building type. The Site Energy Utilization Intensity (Site EUI) was calculated to be 49 kBtu/ft²/yr compared to the National Median of 39 kBtu/ft²/yr. See the ECM section for guidance on how to further reduce the building's energy intensity.

The ENERGY STAR® Portfolio Manager uses a national survey conducted by the U.S. Energy Information Administration (EIA). This national survey, known as the Commercial Building Energy Consumption Survey (CBECS), is conducted every four years, and gathers data on building characteristics and energy use from thousands of buildings across the United States. Due to insufficient data in the 2007 survey, Portfolio Manager continues to use data provided by 2003 survey. The Portfolio Manager software uses this data to create a database by building type. By entering the building parameters and utility data into the software, Portfolio Manager is able to generate a performance scale from 1-100 by comparing it to similar school buildings. This 100 point scale determines how well the building performs relative to other buildings across the country, regardless of climate and other differentiating factors.




Figure 5 Monthly site energy intensity breakdowns per energy type

Per the LGEA program requirements, SWA has assisted the Dwight-Englewood School in creating an ENERGY STAR® Portfolio Manager account and sharing the school information to allow future data to be added and tracked using the benchmarking tool. SWA has shared this Portfolio Manager account information with the Dwight-Englewood School (user name of "DwightEnglewoodSchool" with a password of "██████████") and TRC Energy Services (user name of "██████████").

Tariff analysis

Tariff analysis can help determine if the school is paying the lowest rate possible for electric and gas service. Tariffs are typically assigned to buildings based on size and building type. Rate fluctuations are expected during periods of peak usage. Natural gas prices often increase during winter months since large volumes of natural gas is needed for heating equipment. Similarly, electricity prices often increase during the summer months when additional electricity is needed for cooling equipment.

As part of the utility bill analysis, SWA evaluated the current utility rates and tariffs for the Dwight-Englewood School. The electric use for the building is direct-metered and purchased under the Large Power and Lighting-Secondary service rate schedule, which includes demand and societal benefits charges. The Large Power and Lighting rate schedule is a market-rate based on electric usage and electric demand. Demand prices are reflected in the utility bills and can be verified by observing the price fluctuations throughout the year. The school is also paying for natural gas under the Large Volume Gas rate schedule, which includes fixed costs such as meter reading charges.

Energy Procurement strategies

Utility analysis was conducted using an average aggregated rate which is estimated based on the total cost divided by the total energy usage for each utility over a 12 month period. Average aggregated rates do not separate demand charges from usage, and instead provide a metric of inclusive cost per unit of energy. Average aggregated rates are used in order to equitably compare building utility rates to average utility rates throughout the state of New Jersey.

The average estimated NJ commercial utility rates for electric are \$0.137/kWh, while the school pays a rate of \$0.158/kWh. The school's annual electric utility costs are \$2,650 higher, when compared to the average estimated NJ commercial utility rates. Electric bill analysis shows fluctuations up to 14% over the analyzed billing period. The electric rate fluctuations in the winter and spring can be attributed to a combination of demand charges, market rate changes and actual and estimated meter readings. The Dwight-Englewood School can benefit from switching to a third-party supplier, which would bring the supply costs and overall electric costs down.




Figure 6 Average NJ electric rate compared to the average aggregated electric rate and demand

The average estimated NJ commercial utility rates for gas are \$0.811/therm, while the building pays a rate of \$0.952/therm. The school's annual natural gas costs are \$1,973 higher, when compared to the average estimated NJ commercial utility rates. The natural gas rate analysis shows fluctuations over the analyzed billing period. Utility rate fluctuations in the spring and summer months may have been caused by a combination of low usage and the assessment of fixed fees and costs.




Figure 7 Average NJ gas rate versus monthly gas rates the building pays

Preceding the expiration of any third-party supplier contract, SWA recommends that the building

further explore opportunities of purchasing electricity and natural gas from other third-party suppliers in order to reduce rate fluctuation and ultimately reduce the annual cost of energy for Dwight-Englewood Schools. Appendix F contains a complete list of third-party energy suppliers for the Dwight-Englewood service area.

EXISTING FACILITY AND SYSTEMS DESCRIPTION

This section gives an overview of the current state of the facility and systems. Please refer to the Proposed Further Recommendations section for recommendations for improvement.

Based on visits from SWA in December of 2012 and January of 2013 the following data was collected and analyzed.

Building Characteristics

The Dwight-Englewood School's Modell Athletic Complex is a two-story, 37,500 ft² athletic complex. The original building, built in 1954, currently houses the Silberfein Gymnasium. In 1976 an addition was constructed which now houses the large gymnasium, locker rooms, weight room, athletic offices, restrooms and lobby. The two gymnasiums are each over 20 feet tall and are mechanically ventilated. In the 1976 addition, there are two levels of locker rooms, storage, and offices. The Silberfein Gymnasium houses the small gymnasium, restrooms, and offices. There is a small one-story structure which connects the athletic complex to the Imperatore Library.



Image 1 Side entrance



Image 2 Exterior of main gymnasium

Building Occupancy Profiles

Maximum capacity is approximately 1,000 students and 10 faculty members from 7:30AM until 10:00PM from Monday through Friday. Cleaning crews are in the building until 11:00PM. This building is used 12 months a year, though operating hours vary depending on sports schedules.

Building Envelope

On January 3rd, 2013, SWA performed a building envelope analysis. At this time, the average outside dry bulb temperature was approximately 34°F with an average wind speed of 8 mph. These conditions are considered favorable for infrared imagery. Infrared imagery requires a minimum temperature difference of 18°F, between indoor and outdoor spaces. Infrared images

below exhibit specific building envelope deficiencies, such as unwanted heat transfer and air infiltration. Additional building envelope characteristics are detailed below. The building envelope consists of the outer shell of the building including the walls, windows, doors, and roof. This section will examine the overall condition of the envelope and note any deficiencies discovered during the audit.

General Note: All findings and recommendations on the exterior envelope (base, walls, roofs, doors and windows) are based on the energy auditors' experience and expertise on detailed visual analysis, as far as accessibility and weather conditions allowed at the time of the field audit.

Exterior and Interior Walls

The exterior construction of the building is mainly comprised of constructed masonry units (CMU) and brick veneer, over concrete block with an unconfirmed level of detectable insulation. Based on the year of construction of the building (1954), SWA estimated the insulation thermal resistance to be R-19 as per ASHRAE 90.1 1999. Because the building was built prior to the publication of this standard, the actual insulation thermal resistance may be less, which allows more heat loss.

Exterior and interior wall surfaces were inspected during the field audit. They were found to be in overall fair condition with no signs of uncontrolled moisture, air-leakage or other energy-compromising issues detected on all facades.



Image 3: CMU exterior appears in good condition.



Image 4: Dampers bent, may no longer function.

Roof

The building has a flat roof, above the newer large gymnasium, supported on steel bar-joists and corrugated flashing, finished with a modified bitumen membrane. A similar roof assembly is used for the corridor between the old gymnasium and the new gymnasium, locker rooms, and the section connecting the old gymnasium to the Imperatore Library, but with an ethylene propylene diene monomer (EPDM) membrane and a light gray finish. The larger roof is ballasted with river rock. A visual inspection of the insulation thermal resistance and condition was not possible at the time of the audit; however, based on the year of construction, the insulation thermal resistance value (R-value) is estimated to be R-11 as per ASHRAE 90.1-1999. It is likely that the roof was replaced since the building's original construction date, therefore actual insulation levels are dependent on whether or not

additional insulation was installed. The roof above the old gymnasium is a low-pitch open gable type, with an asphalt shingle finish. The interior of the old gymnasium roof is lined with approximately 1" of acoustic fiberboard and rigid insulation. The age of the roof is unknown; however, there are no known leak issues. Insulation levels of other roof areas could not be verified through non-intrusive methods.

Roofs, related flashing, gutters and downspouts were inspected during the field audit. They were reported to be in overall fair condition. The roof shows evidence of pooling or standing water which can indicate deteriorating roof insulation beneath the membrane, and/or poor roof construction. Pooling water can accelerate deterioration of the roof membrane and also allows ice to form in the winter. Other roof areas showed evidence of foliage build up, which can lead to clogged roof drains.



Image 5 Some Pooling and Warping



Image 6 roof top units (RTUs)

Base

The building's base is composed of a slab-on-grade floor with no below grade levels.

The building's base and its perimeter were inspected for signs of uncontrolled moisture or water presence and other energy-compromising issues. Overall the base was reported to be in fair condition with a few signs of uncontrolled moisture, air-leakage and/ or other energy-compromising issues neither visible on the interior nor exterior.

Windows

The buildings windows consist of double glazed varieties of the following types:

1. Extruded aluminum double-hopper
 - a. Original building
2. Extruded aluminum double-hung and fixed windows
 - a. 1976 addition
3. Clerestory windows
 - a. Along three sides of large gymnasium.

Windows, shading devices, sill, related flashing and caulking were inspected as far as accessibility allowed for signs of moisture, air-leakage, and other energy compromising issues. Overall, the windows were found to be in good condition with no signs of energy compromising issues.

One deficiency noted during the January walkthrough were window air conditioning (AC) units installed in the bathroom windows. Maintenance personnel informed SWA that the ACs are rarely turned on and not removed during the winter months. These AC units should be removed in the winter months to prevent heat from escaping between the unit and window frame.

The following specific window problems were identified:



Image 7: AC units installed in winter

Exterior doors

The building contains the following exterior doors:

1. Aluminum type doors with low-E, double glazing and a non-insulated aluminum door frame. This door is located all the entrances and emergency exits.

All exterior doors, thresholds, related flashing, caulking and weather-stripping were inspected for signs of moisture, air-leakage and other energy-compromising issues. Overall, the doors were found to be in good condition with only a few signs of uncontrolled moisture, air-leakage and/ or other energy-compromising issues. Heat was seen escaping from below and between exterior doors as noted in the building envelope section, inferring deficient weather-stripping.




Image 8 Heat leaking through non-insulated door frames and between doors




Image 9 Image of doors taken from the interior lobby

The photos above detail an infrared image of the building. The number in the top left corner represents the temperature of the area within the crosshairs in the center of the photo. The numbers on the bottom of the photo represent the scale of the color gradient shown. The highest temperatures are shown in yellow and the coldest in deep purple.

Image 8 shows the exterior doors of the Modell's complex. We see the double pane glass providing sufficient insulation while the non-insulated aluminum frame is allowing heat to transfer to the exterior. This would be prevented with a foam-core insulated door frame.

Image 9 is taken from inside the lobby of the Modell's Sports Complex. Here we can see 30°F air infiltrating through the bottom of the doors. This infers a deficiency in weather-stripping.

Building air-tightness

Overall the field auditors found the building to adequately air-tight with few areas of suggested improvements, as described in more detail earlier in this section. The air tightness of buildings helps maximize all other implemented energy measures and investments, and minimizes potentially costly long-term maintenance, repair and replacement expenses.

Mechanical Systems

Heating Ventilation Air Conditioning

The HVAC system of the Modell's Sports Complex consists of a central heating hot water system and ventilation system of all areas in the building. Heating is accomplished by wall cabinet unit heaters and baseboard heaters. Mechanical cooling is provided only in a few areas of the building. Selected areas are cooled during the warmer months.

Equipment

Heating Systems

The heating plant consists of two Dunham-Bush gas-fired boilers rated at a capacity of 1,750 MBH each. They are located in the boiler room, located below the old gymnasium, and supply heating hot water to the Modell's Sports Complex and Imperatore Library. The hot water boilers operate on a lead/lag sequence and provide Heating Hot Water (HHW) to the various heating equipment. HHW is distributed to air handling units (AHUs), wall cabinet unit heaters and baseboard heaters throughout the facility. Hot water leaves the boiler at 180°F and returns at 170°F, giving the boiler a 10 degree Fahrenheit delta-T or change in temperature.



Image 10: Dunham-Bush Hot Water Boiler



Image 11: Boiler Nameplate Information

The HHW is distributed via four constant volume HHW pumps. One pair of 3 HP pumps delivers HHW to the Library while the second pair delivers HHW to the athletic complex. The HHW pumps serving the gymnasium were refurbished in 2012. HHW is pumped to the coils in a roof top heat recovery unit, serving the locker room section. Air is exhausted through the roof top unit, and wall and roof exhaust fans. According to the facility's manager, the heat recovery unit was out of service for nearly 20 years. However, a fan belt was replaced approximately 2 years ago and the unit is currently in operation. The unit runs from 7:00 AM – 9:00 PM. The new gymnasium is ventilated using four ceiling-mounted unit ventilators, with hot water coils, and exhausts air with three roof-mounted exhaust fans.



Image 12: Gymnasium HHW Pumps

The old gymnasium is heated by four packaged rooftop units. The units are located on the roofs connecting the old gymnasium to the new gymnasium and Imperatore Library. The units use a built-in natural gas furnace to heat air that is delivered to the space.

Cooling Systems

Cooling is provided only to a portion of the building. Cooling to the old gymnasium is provided by the four packaged rooftop units which are equipped with direct expansion (DX) coils and utilize R-22 refrigerant. The large gymnasium and locker room section has no mechanical cooling. The locker room's restroom area is ventilated by wall exhaust fans controlled by a manual switch. Small office areas are cooled with window AC units



Image 13: packaged units serving small gymnasium



Image 14: Unit ventilator with reheat serving large gymnasium

Controls

The building is currently not equipped with a building management system or BMS. Timers are used to control operation times of the unit ventilators and heat recovery unit, while the packaged roof top units are controlled by the thermostats located in the old gymnasium. Small offices window ACs are manually controlled by the occupant. Locker room wall exhaust fans are controlled by manual switch. Aquastat controls on the domestic hot water heater and heating hot water boilers set a temperature range for the boilers to maintain.



Image 15 Unit Ventilator Timers



Image 16 DHW Aquastat

Domestic Hot Water

In the summer the building is provided domestic hot water (DHW) by one electric emersion heater and Adamson storage tank. During heating mode, the building is supplied DHW from a hot water heat exchanger fed from the buildings heating hot water system.



Image 17 DHW Boiler

Electrical systems

Lighting

See attached lighting schedule in Appendix B for a complete inventory of lighting throughout the building including estimated power consumption and proposed lighting recommendations.

Interior lighting – Lighting in the large gymnasium consists of high-output fluorescent T5 lighting. The small gymnasium is lit with a mix of high-output fluorescent T5, metal halide, and wall mounted fixtures believed to be of the 75 watt halogen type. The locker rooms consisted of T8 lighting.

SWA was informed, during the walkthrough, of complaints pertaining to the lobby lighting with respect to warm up times of the lights. The lighting consists of a mix of halogen and metal halide lighting along with T8 fixtures. When the halogen and metal halide fixtures are switched off they can take longer than 5 minutes to restart. It is recommended that these fixtures be replaced with more energy efficient fixtures which also have faster start-up times. All lighting is operable by wall switches.




Image 18 Small Gymnasium Metal Halide



Image 19 Small Gymnasium Halogen Lighting




Image 20 Large Gymnasium T5 Lighting




Image 21 Lobby High Bay Metal Halide

Exit Lights – All emergency exits signs have been upgraded to LED exit signs, which operate on low wattage and have a long lifespan.

Exterior Lighting – Seven halogen wall mounted exterior lights are installed near exits of the building.



Image 22 Exterior Halogen Lights

Other electrical systems

There are currently no other significant energy-impacting electrical systems installed at the Modell's Sports Complex.

RENEWABLE AND DISTRIBUTED ENERGY MEASURES

Renewable energy is defined as any power source generated from sources which are naturally replenished, such as sunlight, wind and geothermal. Technology for renewable energy is improving and the cost of installation is decreasing due to both demand and the availability of government-sponsored funding. Renewable energy reduces the need for using either electricity or fossil fuel, therefore lowering costs by reducing the amount of energy purchased from the utility company. Solar photovoltaic panels and wind turbines use natural resources to generate electricity. Geothermal systems offset the thermal loads in a building by using water stored in the ground as either a heat sink or heat source. Cogeneration or Combined Heat and Power (CHP) allows for heat recovery during electricity generation.

Existing systems

Currently there are no renewable energy systems installed in the building.

Evaluated Systems

Solar Photovoltaic

Photovoltaic panels convert light energy received from the sun into a usable form of electricity. Panels can be connected into arrays and mounted directly onto building roofs, as well as installed onto built canopies over areas such as parking lots, building roofs or other open areas. Electricity generated from photovoltaic panels is generally sold back to the utility company through a net meter. Net-metering allows the utility to record the amount of electricity generated in order to pay credits to the consumer that can offset usage and demand costs on the electric bill. In addition to generation credits, there are incentives available called Solar Renewable Energy Certificates (SRECs) that are subsidized by the state government. Specifically, the New

Jersey State government pays a market-rate SREC to facilities that generate electricity in an effort to meet state-wide renewable energy requirements.

The Modell's Sports Complex appears to be a good candidate for a 30 kW solar photovoltaic (PV) system. A structural analysis would be required to determine if the roof above the auditorium can hold a PV system. See the Capital Improvement section for more information.

Solar Thermal Collectors

Solar thermal collectors are not cost-effective for this building and would not be recommended due to the insufficient and intermittent use of domestic hot water throughout the building to justify the expenditure.

Wind

The School is not a good candidate for wind power generation due to insufficient wind conditions in this area of New Jersey.

Geothermal

The School is not a good candidate for geothermal installation since it would require replacement of the entire existing HVAC system, as well as extensive installation of geothermal wells and pumping equipment.

Combined Heat and Power

The School is not a good candidate for CHP installation and would not be cost-effective due to the size and operations of the building. Typically, CHP is best suited for buildings with a constant electrical baseload to accommodate the electricity generated, as well as a means for using waste heat generated. Additionally, the seasonal occupancy schedule of the School is not well suited for a CHP installation.

PROPOSED ENERGY CONSERVATION MEASURES

Energy Conservation Measures (ECMs) are recommendations determined for the building based on improvements over current building conditions. ECMs have been determined for the building based on installed cost, as well as energy and cost-savings opportunities.

Recommendations: Energy Conservation Measures

#	Energy Conservation Measures
ECM 1	Upgrade 37 Incandescent lamps to Compact Fluorescent Lamps (CFLs)
ECM 2	Install 14 occupancy sensors
ECM 3	Retro-commissioning
ECM 4	Retrofit 29 Metal Halide fixtures with T5 fixtures

In order to clearly present the overall energy opportunities for the building and ease the decision of which ECM to implement, SWA calculated each ECM independently and did not incorporate slight/potential overlaps between some of the listed ECMs (i.e. lighting change influence on heating/cooling).

ECM #1: Upgrade 37 Incandescent lamps to Compact Fluorescent Lamps (CFLs)

The building is equipped with fixtures containing inefficient incandescent lamps. SWA recommends that each incandescent lamp be replaced with a more efficient Compact Fluorescent Lamp (CFL). CFLs are capable of providing equivalent or better light output while using less power when compared to incandescent, halogen and Metal Halide fixtures. CFL bulbs produce the same lumen output with less wattage than incandescent bulbs and last up to five times longer. The labor for the recommended installations is evaluated using prevailing electrical contractor wages. The building owner may decide to perform this work with in-house resources from the Maintenance Department on a scheduled, longer timeline than otherwise performed by a contractor.

Installation cost:

Estimated installed cost: \$478 (includes \$148 of labor)

Source of cost estimate: *RS Means; Published and established costs, NJ Clean Energy Program*

Economics:

net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo.	therms, 1st yr savings	kBtu/sq. ft., 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
\$478	8,466	2	0	0.8	\$8	\$1,346	5	\$6,730	0.4	1,308%	262%	281%	\$5,476	15,158

Assumptions: SWA calculated the savings for this measure using measurements taken on the day of the field visit and using the billing analysis. SWA also assumed 2 hours/day to replace aging burnt out lamps.

Rebates/financial incentives:

- There currently are no incentives for this measure at this time.

Please see APPENDIX G for more information on Incentive Programs.

ECM #2: Install 14 occupancy sensors

The building contains several areas that could benefit from the installation of occupancy sensors. These areas consisted of locker rooms, bathrooms and offices that are used sporadically throughout the day and could show energy savings by having the lights turn off after a period of no occupancy. Typically, occupancy sensors have an adjustable time delay that shuts down the lights automatically if no motion is detected within a set time period. Advanced ultrasonic lighting sensors include sound detection as a means to controlling lighting operation.

Installation cost:

Estimated installed cost: \$2,800 (includes \$840 of labor)

Source of cost estimate: RS Means, Published and established costs, NJ Clean Energy Program

Economics:

net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo.	therms, 1st yr savings	kBtu/sq. ft., 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
\$2,800	9,700	2	0	0.9	\$0	\$1,533	15	\$22,995	1.8	721%	48%	55%	\$14,766	17,368

Assumptions: SWA calculated the savings for this measure using measurements taken on the day of the field visit and using the billing analysis.

Rebates/financial incentives:

- NJ Clean Energy – SmartStart – Wall-mounted occupancy sensors (\$20 per occupancy sensor)
– Maximum incentive amount is \$280

Please see APPENDIX G for more information on Incentive Programs.

ECM #3: Retro-commissioning

Retro-commissioning, or existing building commissioning, is a systematic building investigation process for improving and optimizing a building's operation and maintenance. The process focuses on the building's energy consumption by analyzing equipment such as the HVAC mechanical equipment, related controls and consumption patterns derived from utility and other usage information. Retro-commissioning may not necessarily emphasize bringing the building back to its original intended design specifications if the retro-commissioning team finds that the original specifications no longer apply to existing equipment or building needs. The process may result in recommendations for capital improvements, but its primary intent is to optimize the building systems by equipment tune-up, improved operation and maintenance, and diagnostic testing.

The retro-commissioning process involves obtaining documentation about the facility equipment and its current operation as well as multiple site visits for further review of operating parameters and conditions with the maintenance staff. All major energy consuming systems are diagnosed to determine system operation. The retro-commissioning process can also identify potential capital intensive improvements that can be made to further reduce energy usage and utility cost. Often, the savings associated with the low cost improvements can be used to lower maintenance costs associated with the capital intensive measures and make the overall package more economically viable.

The goals of RCx include:

- Finding opportunities to reduce energy costs through readily implemented changes to the operation of the building.
- Evaluating set points of equipment and systems with the intent of bringing them to a proper operational state.
- Improving indoor environmental quality (IEQ) thereby reducing occupant complaints and reducing staff time spent on complaint calls.
- Improving equipment reliability through enhanced operation and maintenance procedures.

Installation cost:

Estimated installed cost: \$7,500

Source of cost estimate: Similar projects

Economics:

net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo.	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
\$7,500	11,877	0	1,969	6.3	\$0	\$3,750	12	\$45,000	2.0	500%	42%	50%	\$28,475	42,966

Assumptions: SWA calculated the estimated the ECM cost at \$0.20/ft², which is typical of buildings of this size and type.

Rebates/financial incentives: This project does not qualify for a rebate or other financial incentive at this time.

Please see APPENDIX G for more information on Incentive Programs.

ECM #4: Retrofit 29 Metal Halide fixtures with T5 fixtures

During the field audit, SWA completed a building interior as well as exterior lighting inventory (see Appendix B). The existing Modell's Sports Complex lighting consists of standard probe start Metal Halide (MH) lamps. SWA recommends replacing the interior higher wattage MH fixtures with T5 lamps and electronic ballasts which offer the advantages of standard probe start MH lamps, but minimize the disadvantages. They produce higher light output both initially and over time, operate more efficiently, produce whiter light, and turn on and re-strike faster. Due to these characteristics, energy savings can be realized via one-to-one substitution of lower-wattage systems, or by taking advantage of higher light output and reducing the number of fixtures required in the space. The labor for the recommended installations is evaluated using prevailing electrical contractor wages. The building owner may decide to perform this work with in-house resources from the Maintenance Department on a scheduled, longer timeline than otherwise performed by a contractor.

Installation cost:

Estimated installed cost: \$4,844 (includes \$2,755 of labor)

Source of cost estimate: RS Means; Published and established costs, NJ Clean Energy Program

Economics:

net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo.	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
\$4,844	5,200	1	0	0.5	\$1,173	\$1,995	15	\$29,925	2.4	518%	35%	41%	\$18,054	9,311

Assumptions: SWA calculated the savings for this measure using measurements taken on the day of the field visit and using the billing analysis.

Rebates/financial incentives:

- NJ Clean Energy – SmartStart program – High Bay T5 fixtures with electronic ballast (\$16 per fixture) – Maximum incentive amount \$464

Please see APPENDIX G for more information on Incentive Programs.

Proposed Further Recommendations

Capital Improvements

Capital improvements are recommendations for the building that may not be cost-effective at the current time, but that could yield a significant long-term payback. These recommendations should typically be considered as part of a long-term capital improvement plan. Capital improvements should be considered if additional funds are made available. SWA recommends the following capital improvements for the Dwight-Englewood School.

- Replace the original boilers with newer efficient models. The existing boilers are original and have reached their end of life. SWA recommends replacing the boilers to reduce the amount of maintenance required to keep them running, and to reduce the possibility of equipment failure during the heating season. Additionally, newer boilers are more efficient and contribute to reduced energy consumption. SWA estimates a replacement cost of \$116,250, including removing the old boilers, and replacing them with three boilers with higher efficiencies and a combined capacity equivalent to the existing heating plant. With an estimated system efficiency improvement of 15%, the building can save approximately \$7,000, annually. Further investigation is required to accurately calculate project costs and savings.
- Replace the existing electric water heater with an Energy Star water heater. The existing water heater is old and has reached the end of its useful life. Prior to equipment failure, SWA recommends replacing the electric water heater with a natural gas-fired water heater. Although electric water heaters heat up water more efficiently than gas-fired water heaters, the lower energy cost of natural gas reduces operation costs. The water heater replacement should have a direct or power vent for a more efficient combustion. SWA estimates a replacement cost of \$10,000, including removing the old water heater, and replacing it with a gas-fired model with a higher efficiency. SWA estimates an annual savings of \$1,700. Further investigation is required to accurately calculate project costs and savings.
- Replace all roof surfaces. During the time of the visit, the roof surface showed evidence of deterioration. It is estimated that the roof surfaces have reached the end of their useful life. SWA recommends replacing the roof surfaces which is estimated to cost \$87,004.
- Replace the existing windows and doors – Despite having double glazed doors and windows along the north, south and west exposures, they are all framed with non-insulated metal frames. This was seen from the infrared images in the building description section, showing heat loss through the frames. This heat loss increases the building's heating loads, increasing natural gas consumption. Based on estimated window sizes, heating degree days and an overall U-factor of 0.50 (Btu/h-ft²·°F), SWA estimates 42,654 kBtu of heat lost through the doors and windows. A complete window and door upgrade can cost approximately \$39,000. Further analysis is required to determine project feasibility and potential savings.
- Consider installing a photovoltaic system – Currently, the building does not use any renewable energy systems. Renewable energy systems such as photovoltaic (PV) panels can offset a portion of the purchased electricity for the building. Power stations generally have two separate electric charges, usage and demand. Usage is the amount of electricity in kilowatt-hours that a building uses from month to month. Demand is the amount of electrical power that a building uses at any given instance in a month period. During the summer periods, electric demand at a power station is high, due to the amount of air conditioners, lights and other equipment being used within the region. Demand charges increase to offset the utility's cost to provide enough

electricity at the given time. Photovoltaic systems offset the amount of electricity used by a building and help to reduce the building's electric demand, resulting in a higher cost savings. Installing a PV system will offset electric demand and reduce annual electric consumption, while utilizing available state incentives.

The size of the system was determined considering the available roof surface, without compromising service space for roof equipment and safety. A PV system could be installed on a portion of the roof with panels facing south. A commercial multi-crystalline 230 panel has 17.5 square feet of surface area, providing approximately 13.1 watts per square foot. SWA estimates a 30 kW system can be installed above the auditorium's roof with an estimated project cost of \$210,000. The school can take advantage of the Solar Renewable Energy Certificates (SRECs) Registration Program, to increase the annual savings. In the program, an SREC is earned for every 1,000 kWh generated by the PV system. The SRECs can then be traded in a market, providing the school with a new revenue stream which reduces the payback period. The system is estimated to saved the building 35,400 kWh annually; however, due to low SREC prices, the project can take approximately 16 years to payback. Further investigation would be required to accurately estimate project costs and economic factors that would be used for an implementation decision.

Operations and Maintenance

Operations and Maintenance measures consist of low/no cost measures that are within the capability of the current building staff to handle. These measures typically require little investment, and they yield a short payback period. These measures may address equipment settings or staff operations that, when addressed will reduce energy consumption or costs.

- Interlock exhaust fans to the air handling units. The exhaust fans currently operate 24 hours per day, which is a waste of energy. SWA recommends connecting the fans to the air handling units, so that the exhaust fans shut off, when the air handling units shut off.
- Replace motors with NEMA premium efficiency models – SWA observed several motors that were not NEMA premium efficiency models and are beyond their useful lifetime. Since these motors have been maintained well, SWA recommends replacing them with high efficiency models as part of routine O&M the next time that they fail. This measure can be conducted by in-house maintenance staff.
- Install water-efficient fixtures and controls – Building staff can also easily install faucet aerators and/or low-flow fixtures to reduce water consumption. There are many retrofit options, which can be installed now or incorporated as equipment is replaced. Routine maintenance practices that identify and quickly address water leaks are a low-cost way to save water and energy. Retrofitting with more efficient water-consumption fixtures/appliances will reduce energy consumption for water heating, while also decreasing water/sewer bills. This measure can be conducted by in-house maintenance staff with little investment, and yield a short payback.
- Inspect and replace cracked/ineffective caulk. This measure can be conducted by in-house maintenance staff with little investment, and yield a short payback.
- Inspect and maintain sealants at all windows for airtight performance. This measure can be conducted by in-house maintenance staff with little investment, and yield a short payback.
- Inspect and maintain weather-stripping around all exterior doors and roof hatches. This measure can be conducted by in-house maintenance staff with little investment, and yield a short payback.

- SWA recommends that the building considers purchasing the most energy-efficient equipment, including ENERGY STAR® labeled appliances, when equipment is installed or replaced. ENERGY STAR® appliances meet stricter standards compared to standard appliances. Stricter standards include exceeding Federal minimum efficiencies and reduced environmental impact. More information can be found in the “Products” section of the ENERGY STAR® website at: <http://www.energystar.gov>.
- Consider the use of smart power electric strips - in conjunction with occupancy sensors to power down computer equipment when left unattended for extended periods of time.
- Create an energy educational program - that teaches students and professionals how to minimize energy use. An educational program may be incorporated into school curricula to increase students’ environmental awareness. The U.S. Department of Energy offers free information for hosting energy efficiency educational programs and plans. For more information please visit: <http://www1.eere.energy.gov/education/>.

APPENDIX A: EQUIPMENT LIST

Building System	Description	Model #	Fuel	Location	Space Served	Year Installed	Estimated Remaining Useful Life %
Heating	Hot Water Boiler Output MBH - 1750 Max Press. Steam PSI - 15 Max Press. H2O - 30	Dunham Bush Model # - 36-45-239 Serial No. - P7435	Natural Gas	Boiler Room	Modell/Library	1972	0%
Heating	Hot Water Boiler Output MBH - 2750 Max Press. Steam PSI - 15 Max Press. H2O - 31	Dunham Bush Model # - 36-45-239 Serial No. - P71365	Natural Gas	Boiler Room	Modell/Library	1977	0%
Heating	1730 RPM, 3 HP, Frame 182JM, Type TDP-BCZ	Universal, Model # FVE 182TTDR813-4AA, Serial # 1211505	Electric	Boiler Room	Modell	N/A	0%
Heating	1731 RPM, 3 HP, Frame 182JM, Type TDP-BCZ	Universal, Model # FVE 182TTDR813-4AA, Serial # 1211534	Electric	Boiler Room	Modell	N/A	0%
Domestic Hot Water	Electric water heater, KW - 10, Volt - 208, Hz - 60	Adamson Model # AE1.0068V21F Serial - PEB1014-P	Electric	Boiler Room	Modell/Library	1976	0%
Domestic Hot Water	Circulator, Volt - 115, RPM - 1725, FLA - 2.5, HP - 1/12	Model # - AQL48S17D1048T	Electric	Boiler Room	Modell/Library	N/A	0%
Domestic Hot Water	Volt - 115, RPM - 1725, HP - 1/12	Bell & Gossett	Electric	Boiler Room	Modell	N/A	0%
Heating	HHW Pump - 1	N/A	Electric	Modell Boiler Room	Library	2012	95%
Heating	HHW Pump - 2	N/A	Electric	Modell Boiler Room	Library	2012	95%
Heating	Burner, HP - 100 RPM - 6450 Volt - 208-230 / 460 Amps - 2.7-2.6 / 1.9 Efficiency - 74%	Baldor Model # VM 30	Electric	Boiler Room	Modell/Library	N/A	0%
Heating	Burner, HP - 100 RPM - 6450 Volt - 208-230 / 460 Amps - 2.7-2.6 / 1.9 Efficiency - 74%	Baldor Model # VM 30	Electric	Boiler Room	Modell/Library	N/A	100%
Heating/Cooling	Roof Top Unit, 1 compressor, R-22 refrigerant, gas furnace, 3 phase, 115,000 Btuh Input Capacity	Carrier, Model # 48TJE006--511--, Serial # 1900G20723	Electric/Natural Gas	Roof	Modell	2000	13%
Heating/Cooling	Roof Top Unit, 1 compressor, R-22 refrigerant, gas furnace, 3 phase, 115,000 Btuh Input Capacity	Carrier, Model # 48TJE006--511--, Serial # 1900G20712	Electric/Natural Gas	Roof	Modell	2000	13%
Heating/Cooling	Roof Top Unit, 1 compressor, R-22 refrigerant, gas furnace, 3 phase, 115,000 Btuh Input Capacity	Carrier, Model # 48TJE006--511--, Serial # N/A	Electric/Natural Gas	Roof	Modell	2000	13%
Heating/Cooling	Roof Top Unit, 1 compressor, R-22 refrigerant, gas furnace, 3 phase, 115,000 Btuh Input Capacity	Carrier, Model # 48TJE006--511--, Serial # N/A	Electric/Natural Gas	Roof	Modell	2000	13%

Note: The remaining useful life of a system (in %) is an estimate based on the system date of built and existing conditions derived from visual inspection.

Appendix B: Lighting Study

Location			Existing Fixture Information										Retrofit Information										Annual Savings							
Marker	Floor	Room Identification	Fixture Type	Ballast	Lamp Type	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Controls	Operational Hours per Day	Operational Days per Year	Ballast Wattage	Total Watts	Energy Use kWh/year	Category	Fixture Type	Lamp Type	Ballast	Controls	# of Fixtures	# of Lamps per Fixture	Watts per Lamp	Operational Hours per Day	Operational Days per Year	Ballast Watts	Total Watts	Energy Use kWh/year	Fixture Savings (kWh)	Controls Savings (kWh)	Total Savings (kWh)
1	1	Hallway	Recessed Parabolic	S	Hal	14	1	75	Sw	9	230	17	1,281	2,652	CFL	Recessed Parabolic	CFL	S	Sw	14	1	25	9	230	0	350	725	1927	0	1927
2	1	Gymnasium	Ceiling Suspended	E	4T5	8	6	54	Sw	9	230	46	2,962	6,131	C	Ceiling Suspended	4T5	E	OS	8	6	54	7	230	46	2962	4598	0	1533	1533
3	1	Gymnasium	High Bay	S	MH	25	1	250	Sw	9	230	70	8,000	16,560	T5	High Bay	4T5	E	Sw	25	4	54	9	230	31	6171	12773	3787	0	3787
4	1	Gymnasium	Wall Mounted	E	Hal	10	1	75	Sw	9	230	17	915	1,894	CFL	Wall Mounted	CFL	E	Sw	10	1	25	9	230	0	250	518	1377	0	1377
5	1	Office	Ceiling Mounted	E	4T8	6	2	32	Sw	9	230	10	444	919	C	Ceiling Mounted	4T8	E	OS	6	2	32	7	230	10	444	689	0	230	230
6	1	Office	Ceiling Mounted	E	4T8	5	2	32	Sw	9	230	10	370	766	C	Ceiling Mounted	4T8	E	OS	5	2	32	7	230	10	370	574	0	191	191
7	1	Office	Ceiling Mounted	E	4T8	3	2	32	Sw	9	230	10	222	460	C	Ceiling Mounted	4T8	E	OS	3	2	32	7	230	10	222	345	0	115	115
8	1	Hallway	Recessed Parabolic	E	4T8 U-Shaped	2	2	32	Sw	9	230	10	148	306	N/A	Recessed Parabolic	4T8 U-Shaped	E	Sw	2	2	32	9	230	10	148	306	0	0	0
9	1	Gymnasium	Recessed Parabolic	E	4T5	36	4	28	Sw	9	230	16	4,607	9,537	C	Recessed Parabolic	4T5	E	OS	36	4	28	7	230	16	4607	7153	0	2384	2384
10	1	Lobby	Recessed Parabolic	E	Hal	8	1	75	Sw	8	230	17	732	1,347	CFL	Recessed Parabolic	CFL	E	Sw	8	1	25	8	230	0	200	368	979	0	979
11	1	Lobby	Recessed Parabolic	S	MH	4	1	250	Sw	8	230	70	1,280	2,355	T5	Recessed Parabolic	4T5	E	Sw	4	4	28	8	230	16	512	942	1413	0	1413
12	1	Lobby	Recessed Parabolic	E	4T8	6	1	32	Sw	8	230	5	222	408	N/A	Recessed Parabolic	4T8	E	Sw	6	1	32	8	230	5	222	408	0	0	0
13	2	Hallway	Recessed Parabolic	E	4T8 U-Shaped	2	2	32	Sw	9	230	10	148	306	N/A	Recessed Parabolic	4T8 U-Shaped	E	Sw	2	2	32	9	230	10	148	306	0	0	0
14	2	Locker Room	Recessed Parabolic	E	4T8	11	2	32	Sw	9	230	10	814	1,685	C	Recessed Parabolic	4T8	E	OS	11	2	32	7	230	10	814	1264	0	421	421
15	2	Office	Ceiling Mounted	E	4T8	2	4	32	Sw	9	230	20	296	613	C	Ceiling Mounted	4T8	E	OS	2	4	32	7	230	20	296	460	0	153	153
16	Bsmt	Hallway	Recessed Parabolic	E	Hal	5	1	75	Sw	9	230	17	458	947	CFL	Recessed Parabolic	CFL	E	Sw	5	1	25	9	230	0	125	259	688	0	688
17	Bsmt	Hallway	Recessed Parabolic	E	4T8 U-Shaped	2	2	32	Sw	9	230	10	148	306	N/A	Recessed Parabolic	4T8 U-Shaped	E	Sw	2	2	32	9	230	10	148	306	0	0	0
18	Bsmt	Hallway	Recessed Parabolic	E	4T8 U-Shaped	2	2	32	Sw	9	230	10	148	306	N/A	Recessed Parabolic	4T8 U-Shaped	E	Sw	2	2	32	9	230	10	148	306	0	0	0
19	Bsmt	Bathroom	Recessed Parabolic	E	4T8	2	2	32	Sw	9	230	10	148	306	C	Recessed Parabolic	4T8	E	OS	2	2	32	7	230	10	148	230	0	77	77
20	Bsmt	Bathroom	Recessed Parabolic	E	4T8	2	4	32	Sw	9	230	20	296	613	C	Recessed Parabolic	4T8	E	OS	2	4	32	7	230	20	296	460	0	153	153
21	Bsmt	Locker Room Men	Ceiling Mounted	E	4T8	52	2	32	Sw	9	230	10	3,848	7,965	C	Ceiling Mounted	4T8	E	OS	52	2	32	7	230	10	3848	5974	0	1991	1991
22	Bsmt	Locker Room Men	Ceiling Mounted	E	4T8	2	4	32	Sw	9	230	20	296	613	C	Ceiling Mounted	4T8	E	OS	2	4	32	7	230	20	296	460	0	153	153
23	Bsmt	Locker Room Women	Ceiling Mounted	E	4T8	52	2	32	Sw	9	230	10	3,848	7,965	C	Ceiling Mounted	4T8	E	OS	52	2	32	7	230	10	3848	5974	0	1991	1991
24	Bsmt	Locker Room Women	Ceiling Mounted	E	4T8	2	4	32	Sw	9	230	20	296	613	C	Ceiling Mounted	4T8	E	OS	2	4	32	7	230	20	296	460	0	153	153
25	Bsmt	Locker Room	Ceiling Mounted	E	4T8	4	2	32	Sw	9	230	10	296	613	C	Ceiling Mounted	4T8	E	OS	4	2	32	7	230	10	296	460	0	153	153
26	1	Throughout	Exit Sign	S	LED	18	3	5	N	24	365	2	297	2,602	N/A	Exit Sign	LED	S	N	18	3	5	24	365	2	297	2602	0	0	0
27	Ext	Exterior	Wall Mounted	E	Hal	12	1	75	Sw	12	365	17	1,098	4,809	CFL	Wall Mounted	CFL	E	Sw	12	1	25	12	365	0	300	1314	3495	0	3495
Totals:						297	61	1,506				491	33,618	73,598						297	67	838			316	27,762	50,232	13,666	9,700	23,366

Rows Highlighted Yellow Indicate an Energy Conservation Measure is recommended for that space

Proposed Lighting Summary Table			
Total Gross Floor Area (SF)	37,500		
Average Power Cost (\$/kWh)	0.1580		
Exterior Lighting	Existing	Proposed	Savings
Exterior Annual Consumption (kWh)	4,809	1,314	3,495
Exterior Power (watts)	1,098	300	798
Total Interior Lighting	Existing	Proposed	Savings
Annual Consumption (kWh)	68,789	48,918	19,871
Lighting Power (watts)	32,520	27,462	5,058
Lighting Power Density (watts/SF)	0.87	0.73	0.13
Estimated Cost of Fixture Replacement (\$)	5,322		
Estimated Cost of Controls Improvements (\$)	2,800		
Total Consumption Cost Savings (\$)	4,873		

LEGEND			
Lamp Type		Controls	
CFL	Compact Fluorescent	T	Autom. Timer
Inc	Incandescent	BL	Bi-Level
LED	Light Emitting Diode	Ct	Contact
MH	Metal Halide	M	Daylight & Motion
MV	Mercury Vapor	DLSw	Daylight & Switch
PSMH	Pulse Start Metal Halide	DL	Daylight Sensor
HPS	High Pressure Sodium	DSw	Delay Switch
LPS	Low Pressure Sodium	D	Dimmer
FI	Fluorescent	MS	Motion Sensor
4'T8	4 Feet long T8 Linear Lamp	MSw	Motion& Switch
4'T8 U-shaped	4 Feet long T8 U-shaped Lamp	N	None
4'T5	4 Feet long T5 Linear Lamp	OS	Occupancy Sensor
Ballast Type		OSCM	Occupancy Sensor Ceiling Mounted
E	Electronic	PC	Photocell
M	Magnetic	Sw	Switch
S	Self		

APPENDIX C: UPCOMING EQUIPMENT PHASEOUTS

LIGHTING:

- As of **July 1, 2010** magnetic ballasts most commonly used for the operation of T12 lamps are no longer being produced for commercial and industrial applications.
- As of **January 1, 2012** 100 watt incandescent bulbs have been phased out in accordance with the Energy Independence and Security Act of 2007.
- As of **July 2012** many non energy saver model T12 lamps have been phased out of production.
- As of **January 1, 2013** 75 watt incandescent bulbs have been phased out in accordance with the Energy Independence and Security Act of 2007.
- Starting **January 1, 2014** 60 and 40 watt incandescent bulbs will be phased out in accordance with the Energy Independence and Security Act of 2007.
- Energy Independence and Security Act of 2007 incandescent lamp phase-out exclusions:
 1. Appliance lamp (e.g. refrigerator or oven light)
 2. Black light lamp
 3. Bug lamp
 4. Colored lamp
 5. Infrared lamp
 6. Left-hand thread lamp
 7. Marine lamp
 8. Marine signal service lamp
 9. Mine service lamp
 10. Plant light lamp
 11. Reflector lamp
 12. Rough service lamp
 13. Shatter-resistant lamp (including a shatter-proof lamp and a shatter-protected lamp)
 14. Sign service lamp
 15. Silver bowl lamp
 16. Showcase lamp
 17. 3-way incandescent lamp
 18. Traffic signal lamp
 19. Vibration service lamp
 20. Globe shaped "G" lamp (as defined in ANSI C78.20-2003 and C79.1-2002 with a diameter of 5 inches or more)
 21. T shape lamp (as defined in ANSI C78.20-2003 and C79.1-2002) and that uses not more than 40 watts or has a length of more than 10 inches
 22. A B, BA, CA, F, G16-1/2, G-25, G30, S, or M-14 lamp (as defined in ANSI C79.1-2002 and ANSI C78.20-2003) of 40 watts or less
 23. Candelabra incandescent and other lights not having a medium Edison screw base.
- When installing compact fluorescent lamps (CFLs), be advised that they contain a very small amount of mercury sealed within the glass tubing and EPA guidelines concerning

cleanup and safe disposal of compact fluorescent light bulbs should be followed. Additionally, all lamps to be disposed should be recycled in accordance with EPA guidelines through state or local government collection or exchange programs instead.

HCFC (Hydro chlorofluorocarbons):

- As of **January 1, 2010**, no production and no importing of R-142b and R-22, except for use in equipment manufactured before January 1, 2010, in accordance with adherence to the Montreal Protocol.
- As of **January 1, 2015**, No production and no importing of any HCFCs, except for use as refrigerants in equipment manufactured before January 1, 2010.
- As of **January 1, 2020** No production and no importing of R-142b and R-22.

APPENDIX D: THIRD PARTY ENERGY SUPPLIERS

<http://www.state.nj.us/bpu/commercial/shopping.html>

PSE&G ELECTRIC SERVICE TERRITORY Last Updated: 1/24/13

*CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I –INDUSTRIAL

Supplier	Telephone & Web Site	*Customer Class
AEP Energy, Inc. 309 Fellowship Road, Fl. 2 Mount Laurel, NJ 08054	(866) 258-3782 www.aepenergy.com	C/I ACTIVE
Alpha Gas and Electric, LLC 641 5 th Street Lakewood, NJ 08701	(855) 553-6374 www.alphagasandelectric.com	R/C ACTIVE
Ambit Northeast, LLC 103 Carnegie Center Suite 300 Princeton, NJ 08540	(877)-30-AMBIT (877) 302-6248 www.ambitenergy.com	R/C ACTIVE
American Powernet Management, LP 437 North Grove St. Berlin, NJ 08009	(877) 977-2636 www.americanpowernet.com	C ACTIVE
Amerigreen Energy, Inc. 1463 Lambertson Road Trenton, NJ 08611	888-423-8357 www.amerigreen.com	R/C ACTIVE
AP Gas & Electric, LLC 10 North Park Place, Suite 420 Morristown, NJ 07960	(855) 544-4895 www.apge.com	R/C/I ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	(201) 384-5552 www.astralenergyllc.com	R/C/I ACTIVE
ATCO Energy LLC 101 Hudson Street Suite 2100 Jersey City, NJ 07302	855-276-9673 www.atcoenergyco.com	R/C ACTIVE
Barclays Capital Services, Inc. 70 Hudson Street Jersey City, NJ 07302-4585	(888) 526-7000 www.group.barclays.com	C ACTIVE
BBPC, LLC d/b/a Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540	(888) 651-4121 www.greateasternenergy.com	C/I ACTIVE

Champion Energy Services, LLC 72 Avenue L Newark, NJ 07105	(877) 653-5090 www.championenergyservices.com	R/C/I ACTIVE
Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	888-565-4490 www.4choiceenergy.com	R/C ACTIVE
Clearview Electric, Inc. 505 Park Drive Woodbury, NJ 08096	(888) CLR-VIEW (800) 746-4702 www.clearviewenergy.com	R/C/I ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07446	1-866-587-8674 www.commerceenergy.com	R ACTIVE
ConEdison Solutions Cherry Tree Corporate Center 535 State Highway Suite 180 Cherry Hill, NJ 08002	(888) 665-0955 www.conedsolutions.com	C/I ACTIVE
Constellation NewEnergy, Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	(866) 237-7693 www.constellation.com	R/C/I ACTIVE
Constellation Energy 900A Lake Street, Suite 2 Ramsey, NJ 07446	(877) 997-9995 www.constellation.com	R ACTIVE
Credit Suisse, (USA) Inc. 700 College Road East Princeton, NJ 08450	(212) 538-3124 www.creditsuisse.com	C ACTIVE
Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(888) 925-9115 www.directenergybusiness.com	C/I ACTIVE
Direct Energy Services, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830	(866) 348-4193 www.directenergy.com	R ACTIVE
Discount Energy Group, LLC 811 Church Road, Suite 149 Cherry Hill, New Jersey 08002	(800) 282-3331 www.discountenergygroup.com	R/C ACTIVE

Dominion Retail, Inc. d/b/a Dominion Energy Solutions 395 Route #70 West Suite 125 Lakewood, NJ 08701	(866) 275-4240 www.dom.com/products	R/C ACTIVE
DTE Energy Supply, Inc. One Gateway Center, Suite 2600 Newark, NJ 07102	(877) 332-2450 www.dtesupply.com	C/I ACTIVE
Energy.me Midwest LLC 90 Washington Blvd Bedminster, NJ 07921	(855) 243-7270 www.energy.me	R/C/I ACTIVE
Energy Plus Holdings LLC 309 Fellowship Road East Gate Center, Suite 200 Mt. Laurel, NJ 08054	(877) 866-9193 www.energypluscompany.com	R/C ACTIVE
Ethical Electric Benefit Co. d/b/a Ethical Electric 100 Overlook Center, 2 nd Fl. Princeton, NJ 08540	(888) 444-9452 www.ethicalelectric.com	R/C ACTIVE
FirstEnergy Solutions 300 Madison Avenue Morristown, NJ 07962	(800) 977-0500 www.fes.com	C/I ACTIVE
Gateway Energy Services Corp. 120 Wood Avenue Suite 611 Iselin, NJ 08830	(800) 313-8333 Residential (800) 715-8777 Commercial www.gesc.com	R/C ACTIVE
GDF SUEZ Energy Resources NA, Inc. 333 Thornall Street Sixth Floor Edison, NJ 08837	(866) 999-8374 www.gdfsuezenergyresources.com	C/I ACTIVE
Glacial Energy of New Jersey, Inc. 21 Pine Street, Suite 237 Rockaway, NJ 07866	(888) 452-2425 www.glacialenergy.com	C/I ACTIVE
Global Energy Marketing LLC 129 Wentz Avenue Springfield, NJ 07081	(800) 542-0778 www.globalp.com	C/I ACTIVE

Green Mountain Energy Company 211 Carnegie Center Drive Princeton, NJ 08540	(866) 767-5818 www.greenmountain.com/commercial-home	C/I ACTIVE
Hess Corporation 1 Hess Plaza Woodbridge, NJ 07095	(800) 437-7872 www.hess.com	C/I ACTIVE
Hess Small Business Services, LLC One Hess Plaza Woodbridge, NJ 07095	888-494-4377 www.hessenergy.com	C/I ACTIVE
HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	(888) 264-4908 www.hikoenergy.com	R/C ACTIVE
HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue Ridgefield, NJ 07657	(877) 390-7155 www.hopenergy.com	R/C/I ACTIVE
Hudson Energy Services, LLC 7 Cedar Street Ramsey, New Jersey 07446	(877) Hudson 9 www.hudsonenergyservices.com	C ACTIVE
IDT Energy, Inc. 550 Broad Street Newark, NJ 07102	(877) 887-6866 www.idtenergy.com	R/C ACTIVE
Independence Energy Group, LLC 3711 Market Street, 10 th Fl. Philadelphia, PA 19104	(877) 235-6708 www.chooseindependence.com	R/C ACTIVE
Integritys Energy Services, Inc. 99 Wood Ave, South, Suite 802 Iselin, NJ 08830	(877) 763-9977 www.integritysenergy.com	C/I ACTIVE
Keil & Sons, Inc. d/b/a Systrum Energy 1 Bergen Blvd. Fairview, NJ 07022	(877) 797-8786 www.systrumenergy.com	R/C/I ACTIVE

Liberty Power Delaware, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	C/I ACTIVE
Liberty Power Holdings, LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	(866) 769-3799 www.libertypowercorp.com	R/C/I ACTIVE
Linde Energy Services 575 Mountain Avenue Murray Hill, NJ 07974	(800) 247-2644 www.linde.com	C/I ACTIVE
Marathon Power LLC 302 Main Street Paterson, NJ 07505	(888) 779-7255 www.mecny.com	R/C/I ACTIVE
MXenergy Electric Inc. 900 Lake Street Ramsey, NJ 07446	(800) 785-4374 www.mxenergy.com	R/C/I ACTIVE
NATGASCO, Inc. (Supreme Energy, Inc.) 532 Freeman St. Orange, NJ 07050	(800) 840-4427 www.supremeenergyinc.com	R/C ACTIVE
NextEra Energy Services New Jersey, LLC 651 Jernee Mill Road Sayreville, NJ 08872	(877) 528-2890 Commercial (800) 882-1276 Residential www.nexteraenergyservices.com	R/C/I ACTIVE
New Jersey Gas & Electric 1 Bridge Plaza fl. 2 Fort Lee, NJ 07024	(866) 568-0290 www.NJGandE.com	R/C ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th Floor Woodbridge, NJ 07095	(877) 273-6772 www.noblesolutions.com	C/I ACTIVE
North American Power and Gas, LLC 222 Ridgedale Avenue Cedar Knolls, NJ 07927	(888) 313-9086 www.napower.com	R/C/I ACTIVE

Palmco Power NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053	(877) 726-5862 www.PalmcoEnergy.com	R/C/I ACTIVE
Pepco Energy Services, Inc. 112 Main St. Lebanon, NJ 08833	(800) ENERGY-9 (363-7499) www.pepco-services.com	C/I ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666	(855) 32-POWER (76937) www.plymouthenergy.com	R/C/I ACTIVE
PPL Energy Plus, LLC 811 Church Road Cherry Hill, NJ 08002	(800) 281-2000 www.pplenergyplus.com	C/I ACTIVE
Public Power & Utility of New Jersey, LLC 39 Old Ridgebury Rd. Suite 14 Danbury, CT 06810	(888) 354-4415 www.ppandu.com	R/C/I ACTIVE
Reliant Energy 211 Carnegie Center Princeton, NJ 08540	(877) 297-3795 (877) 297-3780 www.reliant.com/pjm	R/C/I ACTIVE
ResCom Energy LLC 18C Wave Crest Ave. Winfield Park, NJ 07036	(888) 238-4041 http://rescomenergy.com	R/C/I ACTIVE
Respond Power LLC 10 Regency CT Lakewood, NJ 08701	(877) 973-7763 www.respondpower.com	R/C/I ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	(800) 266-6020 www.southjerseenergy.com	C/I ACTIVE
Sperian Energy Corp. 1200 Route 22 East, Suite 2000 Bridgewater, NJ 08807	(888) 682-8082	R/C/I ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4 Barrington, N.J. 08007	(800) 695-0666 www.sjnaturalgas.com	R/C ACTIVE
Spark Energy, L.P. 2105 CityWest Blvd., Ste 100 Houston, Texas 77042	(800) 441-7514 www.sparkenergy.com	R/C/I ACTIVE

Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928	(800) 225-1560 www.spragueenergy.com	C/I ACTIVE
Starion Energy PA Inc. 101 Warburton Avenue Hawthorne, NJ 07506	(800) 600-3040 www.starionenergy.com	R/C/I ACTIVE
Stream Energy 309 Fellowship Rd., Suite 200 Mt. Laurel, NJ 08054	(877) 39-8150 www.streamenergy.net	R ACTIVE
Texas Retail Energy LLC Park 80 West Plaza II, Suite 200 Saddle Brook, NJ 07663	(866) 532-0761	C/I ACTIVE
UGI Energy Services, Inc. dba UGI Energy Link 224 Strawbridge Drive Suite 107 Moorestown, NJ 08057	(800) 427-8545 www.ugienergyservices.com	C/I ACTIVE
Verde Energy USA, Inc. 2001 Route 46 Waterview Plaza Suite 301 Parsippany, NJ 07054	(800) 388-3862 www.lowcostpower.com	R/C/I ACTIVE
Viridian Energy 2001 Route 46, Waterview Plaza Suite 310 Parsippany, NJ 07054	(866) 663-2508 www.viridian.com	R/C/I ACTIVE
Xoom Energy New Jersey, LLC 744 Broad Street Newark, NJ 07102	(888) 997-8979 www.xoomenergy.com	R/C/I ACTIVE
YEP Energy 89 Headquarters Plaza North #1463 Morristown, NJ 07960	(855) 363-7736 www.yepenergyNJ.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	(855) 732-2493 www.thisisyourenergvy.com	R/C/I ACTIVE

[Back to the main supplier page](#)

APPENDIX E: GLOSSARY AND METHOD OF CALCULATIONS

Net ECM Cost: The net ECM cost is the cost experienced by the customer, which is typically the total cost (materials + labor) of installing the measure minus any available incentives. Both the total cost and the incentive amounts are expressed in the summary for each ECM.

Annual Energy Cost Savings (AECS): This value is determined by the audit firm based on the calculated energy savings (kWh or Therm) of each ECM and the calculated energy costs of the building.

Lifetime Energy Cost Savings (LECS): This measure estimates the energy cost savings over the lifetime of the ECM. It can be a simple estimation based on fixed energy costs. If desired, this value can factor in an annual increase in energy costs as long as the source is provided.

Simple Payback: This is a simple measure that displays how long the ECM will take to break-even based on the annual energy and maintenance savings of the measure.

ECM Lifetime: This is included with each ECM so that the owner can see how long the ECM will be in place and whether or not it will exceed the simple payback period. Additional guidance for calculating ECM lifetimes can be found below. This value can come from manufacturer's rated lifetime or warranty, the ASHRAE rated lifetime, or any other valid source.

Operating Cost Savings (OCS): This calculation is an annual operating savings for the ECM. It is the difference in the operating, maintenance, and / or equipment replacement costs of the existing case versus the ECM. In the case where an ECM lifetime will be longer than the existing measures (such as LED lighting versus fluorescent) the operating savings will factor in the cost of replacing the units to match the lifetime of the ECM. In this case or in one where one-time repairs are made, the total replacement / repair sum is averaged over the lifetime of the ECM.

Return on Investment (ROI): The ROI is expressed as the percentage return of the investment based on the lifetime cost savings of the ECM. This value can be included as an annual or lifetime value, or both.

Net Present Value (NPV): The NPV calculates the present value of an investment's future cash flows based on the time value of money, which is accounted for by a discount rate (assumes bond rate of 3.2%).

Internal Rate of Return (IRR): The IRR expresses an annual rate that results in a break-even point for the investment. If the owner is currently experiencing a lower return on their capital than the IRR, the project is financially advantageous. This measure also allows the owner to compare ECMs against each other to determine the most appealing choices.

Gas Rate and Electric Rate (\$/therm and \$/kWh): The gas rate and electric rate used in the financial analysis is the total annual energy cost divided by the total annual energy usage for the 12 month billing period studied. The graphs of the monthly gas and electric rates reflect the total monthly energy costs divided by the monthly usage, and display how the average rate fluctuates throughout the year. The average annual rate is the only rate used in energy savings calculations.

Calculation References

Term	Definition
ECM	Energy Conservation Measure
AOCS	Annual Operating Cost Savings
AECS	Annual Energy Cost Savings
LOCS*	Lifetime Operating Cost Savings
LECS	Lifetime Energy Cost Savings
LCS	Lifetime Cost Savings
NPV	Net Present Value
IRR	Internal Rate of Return
DR	Discount Rate
Net ECM Cost	Total ECM Cost – Incentive
LECS	AECS X ECM Lifetime
AOCS	LOCS / ECM Lifetime
LCS	LOCS+LECS
Simple Payback	Net ECM Cost / (AECS + AOCS)
Lifetime ROI	(LECS + LOCS – Net ECM Cost) / Net ECM Cost
Annual ROI	(Lifetime ROI / Lifetime) = [(AECS + OCS) / Net ECM Cost – (1 / Lifetime)]

* The lifetime operating cost savings are all avoided operating, maintenance, and/or component replacement costs over the lifetime of the ECM. This can be the sum of any annual operating savings, recurring or bulk (i.e. one-time repairs) maintenance savings, or the savings that comes from avoiding equipment replacement needed for the existing measure to meet the lifetime of the ECM (e.g. lighting change outs).

Excel NPV and IRR Calculation

In Excel, function =IRR (values) and =NPV (rate, values) are used to quickly calculate the IRR and NPV of a series of annual cash flows. The investment cost will typically be a negative cash flow at year 0 (total cost - incentive) with years 1 through the lifetime receiving a positive cash flow from the annual energy cost savings and annual maintenance savings. The calculations in the example below are for an ECM that saves \$850 annually in energy and maintenance costs (over a 10 year lifetime) and takes \$5,000 to purchase and install after incentives:

	A	B	C	D	E	F	G	H	I
1									
2									
3									
4					Year	Cash Flow			
5					0	\$ (5,000.00)		Investment Cost	
6					1	\$ 850.00			
7					2	\$ 850.00			
8					3	\$ 850.00			
9					4	\$ 850.00			
10					5	\$ 850.00			
11					6	\$ 850.00			
12					7	\$ 850.00			
13					8	\$ 850.00			
14					9	\$ 850.00			
15					10	\$ 850.00			
16					IRR	11.03%			
17					NPV	\$2,250.67			

ECM Lifetime: [Years 1-10]

Cash Flow: Annual Energy Cost Savings + Annual Maintenance Savings [Years 1-10]

Formula:
 =IRR(F4:F14)
 =NPV(0.03,F5:F14)+F4

Solar PV ECM Calculation

There are several components to the calculation:

Costs:	Material of PV system including panels, mounting and net-metering + Labor
Energy Savings:	Reduction of kWh electric cost for life of panel, 25 years Solar Renewable Energy Credits (SRECs) – Market-rate incentive. Calculations assume \$608/Megawatt hour consumed per year for a maximum of 15 years; added to annual energy cost savings for a period of 15 years. (Megawatt hour used is rounded to nearest 1,000 kWh)
Assumptions:	A Solar Pathfinder device is used to analyze site shading for the building and determine maximum amount of full load operation based on available sunlight. When the Solar Pathfinder device is not implemented, amount of full load operation based on available sunlight is assumed to be 1,180 hours in New Jersey.

Total lifetime PV energy cost savings =
kWh produced by panel * [\$/kWh cost * 25 years + \$608/Megawatt hour /1000 * 15 years]

ECM and Equipment Lifetimes

Determining a lifetime for equipment and ECM's can sometimes be difficult. The following table contains a list of lifetimes that the NJCEP uses in its commercial and industrial programs. Other valid sources are also used to determine lifetimes, such as the DOE, ASHRAE, or the manufacturer's warranty.

Lighting is typically the most difficult lifetime to calculate because the fixture, ballast, and bulb can all have different lifetimes. Essentially the ECM analysis will have different operating cost savings (avoided equipment replacement) depending on which lifetime is used.

When the bulb lifetime is used (rated burn hours / annual burn hours), the operating cost savings is just reflecting the theoretical cost of replacing the existing case bulb and ballast over the life of the recommended bulb. Dividing by the bulb lifetime will give an annual operating cost savings.

When a fixture lifetime is used (e.g. 15 years) the operating cost savings reflects the avoided bulb and ballast replacement cost of the existing case over 15 years minus the projected bulb and ballast replacement cost of the proposed case over 15 years. This will give the difference of the equipment replacement costs between the proposed and existing cases and when divided by 15 years will give the annual operating cost savings.

New Jersey Clean Energy Program Commercial Equipment Life Span

Measure	Life Span
Commercial Lighting — New	15
Commercial Lighting — Remodel/Replacement	15
Commercial Custom — New	18
Commercial Chiller Optimization	18
Commercial Unitary HVAC — New - Tier 1	15
Commercial Unitary HVAC — Replacement - Tier 1	15
Commercial Unitary HVAC — New - Tier 2	15
Commercial Unitary HVAC — Replacement Tier 2	15
Commercial Chillers — New	25
Commercial Chillers — Replacement	25
Commercial Small Motors (1-10 HP) — New or Replacement	20
Commercial Medium Motors (11-75 HP) — New or Replacement	20
Commercial Large Motors (76-200 HP) — New or Replacement	20
Commercial VSDs — New	15
Commercial VSDs — Retrofit	15
Commercial Comprehensive New Construction Design	18
Commercial Custom — Replacement	18
Industrial Lighting — New	15
Industrial Lighting — Remodel/Replacement	15
Industrial Unitary HVAC — New - Tier 1	15
Industrial Unitary HVAC — Replacement - Tier 1	15
Industrial Unitary HVAC — New - Tier 2	15
Industrial Unitary HVAC — Replacement Tier 2	15
Industrial Chillers — New	25
Industrial Chillers — Replacement	25
Industrial Small Motors (1-10 HP) — New or Replacement	20
Industrial Medium Motors (11-75 HP) — New or Replacement	20
Industrial Large Motors (76-200 HP) — New or Replacement	20
Industrial VSDs — New	15
Industrial VSDs — Retrofit	15
Industrial Custom — Non-Process	18
Industrial Custom — Process	10
Small Commercial Gas Furnace — New or Replacement	20
Small Commercial Gas Boiler — New or Replacement	20
Small Commercial Gas DHW — New or Replacement	10
C&I Gas Absorption Chiller — New or Replacement	25
C&I Gas Custom — New or Replacement (Engine Driven Chiller)	25
C&I Gas Custom — New or Replacement (Gas Efficiency Measures)	18
O&M savings	3
Compressed Air (GWh participant)	8

APPENDIX F: STATEMENT OF ENERGY PERFORMANCE FROM ENERGY STAR®

OMB No. 2060-0347



STATEMENT OF ENERGY PERFORMANCE Dwight-Englewood School - Modell's Athletic Complex

Building ID: 3419985
For 12-month Period Ending: November 30, 2012¹
Date SEP becomes ineligible: N/A

Date SEP Generated: February 13, 2013

Facility	Facility Owner	Primary Contact for this Facility
Dwight-Englewood School - Modell's Athletic Complex 315 East Palisade Avenue Englewood, NJ 07631	N/A	N/A
Year Built: 1954		
Gross Floor Area (ft²): 37,500		
Energy Performance Rating² (1-100): N/A		
Site Energy Use Summary³		
Electricity - Grid Purchase (kBtu)	425,111	<div style="border: 1px solid black; width: 100%; height: 100%; display: flex; align-items: center; justify-content: center;"> <div style="border: 1px solid black; width: 80%; height: 80%; margin: 5px;"></div> <div style="border: 1px solid black; width: 100%; height: 100%; display: flex; flex-direction: column; justify-content: center; align-items: center;"> <div style="border: 1px solid black; width: 100%; text-align: center; padding: 2px;">Stamp of Certifying Professional</div> <div style="border: 1px solid black; width: 100%; text-align: center; padding: 2px;">Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.</div> </div> </div>
Natural Gas (kBtu) ⁴	1,395,012	
Total Energy (kBtu)	1,820,123	
Energy Intensity⁴		
Site (kBtu/ft²/yr)	49	
Source (kBtu/ft²/yr)	77	
Emissions (based on site energy use)		
Greenhouse Gas Emissions (MtCO ₂ e/year)	134	
Electric Distribution Utility		
Public Service Electric & Gas Co		
National Median Comparison		
National Median Site EUI	39	
National Median Source EUI	100	
% Difference from National Median Source EUI	-23%	
Building Type	Recreation	
Meets Industry Standards⁵ for Indoor Environmental Conditions:		Certifying Professional
Ventilation for Acceptable Indoor Air Quality	N/A	N/A
Acceptable Thermal Environmental Conditions	N/A	
Adequate Illumination	N/A	

Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Values represent energy intensity, annualized to a 12-month period.
5. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

The government estimates the average time needed to fill out this form is 6 hours (includes the time for entering energy data, Licensed Professional facility inspection, and certifying the SEP) and we welcome suggestions for reducing this level of effort. Send comments (please include OMB control number) to the Director, Collection Strategies Division, U.S., EPA (2622), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460.

EPA Form 5900-16

APPENDIX G: INCENTIVE PROGRAMS

New Jersey Clean Energy Pay for Performance

The NJ Clean Energy Pay for Performance (P4P) Program relies on a network of Partners who provide technical services to clients. LGEA participating clients who are not receiving Direct Energy Efficiency and Conservation Block Grants are eligible for P4P. SWA is an eligible Partner and can develop an Energy Reduction Plan for each project with a whole-building traditional energy audit, a financial plan for funding the energy measures and an installation construction schedule.

The Energy Reduction Plan must define a comprehensive package of measures capable of reducing a building's energy consumption by 15+%. P4P incentives are awarded upon the satisfactory completion of three program milestones: submittal of an Energy Reduction Plan prepared by an approved Program Partner, installation of the recommended measures, and completion of a Post-Construction Benchmarking Report. The incentives for electricity and natural gas savings will be paid based on actual savings, provided that the minimum 15% performance threshold savings has been achieved.

Energy Provider Incentives

- **South Jersey Gas** - Offers financing up to \$100,000 on the customer's portion of project cost through private lender. In addition to available financing, it provides matching incentive on gas P4P incentives #2 and #3 up to \$100,000 (not to exceed total project cost).

For further information, please see: <http://www.njcleanenergy.com/commercial-industrial/programs/pay-performance/existing-buildings> .

Direct Install 2011 Program*

Direct Install is a division of the New Jersey Clean Energy Programs' Smart Start Buildings. It is a turn-key program for small to mid-sized facilities to aid in upgrading equipment to more efficient types. It is designed to cut overall energy costs by upgrading lighting, HVAC, and other equipment with energy efficient alternatives. The program pays **up to 70%** of the retrofit costs, including equipment cost and installation costs. Each project is limited to \$75,000 in incentives.

Eligibility:

- Existing small and mid-sized commercial and industrial facilities with peak electrical demand **below 150 kW** within 12 months of applying (the 150 kW peak demand threshold has been waived for local government entities who receive and utilize their Energy Efficiency and Conservation Block Grant in conjunction with Direct Install)
- Must be located in New Jersey
- Must be served by one of the state's public, regulated or natural gas companies

Energy Provider Incentives

- **South Jersey Gas** – Program offers financing up to \$25,000 on customer's 40% portion of the project and combines financing rate based on portion of the project devoted to gas

and electric measures. All gas measures financed at 0%, all electric measures financed at normal rate. Does not offer financing on projects that only include electric measures.

- **Atlantic City Electric** – Provides a free audit, and additional incentives up to 20% of the current incentive up to a maximum of \$5,000 per customer.

For the most up to date information on contractors in New Jersey who participate in this program, go to: <http://www.njcleanenergy.com/commercial-industrial/programs/direct-install> or visit the utility web sites.

Smart Start

New Jersey's SmartStart Building Program is administered by New Jersey's Office of Clean Energy. The program also offers design support for larger projects and technical assistance for smaller projects. If your project specifications do not fit into anything defined by the program, there are even incentives available for custom projects.

There are a number of improvement options for commercial, industrial, institutional, government, and agricultural projects throughout New Jersey. Alternatives are designed to enhance quality while building in energy efficiency to save money. Project categories included in this program are New Construction and Additions, Renovations, Remodeling and Equipment Replacement.

Energy Provider Incentives

- **South Jersey Gas** – Program to finance projects up to \$25,000 not covered by incentive
- **New Jersey Natural Gas** – Will match SSB incentives on gas equipment
- **PSE&G** - Provides funding for site-specific uses of emerging technology. The incentives are determined on a case by case basis.

For the most up to date information on how to participate in this program, go to: <http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-smartstart-buildings>.

Renewable Energy Incentive Program*

The Renewable Energy Incentive Program (REIP) provides incentives that reduce the upfront cost of installing renewable energy systems, including solar, wind, and sustainable biomass. Incentives vary depending upon technology, system size, and building type. Current incentive levels, participation information, and application forms can be found at the website listed below.

Solar Renewable Energy Credits (SRECs) represent all the clean energy benefits of electricity generated from a solar energy system. SRECs can be sold or traded separately from the power, providing owners a source of revenue to help offset the cost of installation. All solar project owners in New Jersey with electric distribution grid-connected systems are eligible to generate SRECs. Each time a system generates 1,000 kWh of electricity an SREC is earned and placed in the customer's account on the web-based SREC tracking system.

For the most up to date information on how to participate in this program, go to: <http://www.njcleanenergy.com/renewable-energy/home/home>.

Combined Heat and Power (CHP)

Energy Provider Incentives

- South Jersey Gas - Provides additional incentive of \$1.00/watt up to \$1,000,000 on top of NJCEP incentive.

Utility Sponsored Programs

Check with your local utility companies for further opportunities that may be available.

Energy Efficiency and Conservation Block Grant Rebate Program

The Energy Efficiency and Conservation Block Grant (EECBG) Rebate Program provides supplemental funding up to \$20,000 for eligible New Jersey local government entities to lower the cost of installing energy conservation measures. Funding for the EECBG Rebate Program is provided through the American Recovery and Reinvestment Act (ARRA).

For the most up to date information on how to participate in this program, go to:

<http://njcleanenergy.com/EECBG>.

Other Federal and State Sponsored Programs

Other federal and state sponsored funding opportunities may be available, including BLOCK and R&D grant funding. For more information, please check <http://www.dsireusa.org/>.

*Subject to availability. Incentive program timelines might not be sufficient to meet the 25% in 12 months spending requirement outlined in the LGEA program.

APPENDIX H: ENERGY CONSERVATION MEASURES

ECM #	ECM description	est. installed cost, \$	est. incentives, \$	net est. ECM cost with incentives, \$	kWh, 1st yr savings	kW, demand reduction/mo	therms, 1st yr savings	kBtu/sq ft, 1st yr savings	est. operating cost, 1st yr savings, \$	total 1st yr savings, \$	life of measure, yrs	est. lifetime cost savings, \$	simple payback, yrs	lifetime return on investment, %	annual return on investment, %	internal rate of return, %	net present value, \$	CO ₂ reduced, lbs/yr
1	Upgrade 37 Incandescent lamps to CFLs	478	0	478	8,466	2	0	0.8	8	1,346	5	6,730	0.4	1,308	262	281	5,476	15,158
2	Install 14 occupancy sensors	3,080	280	2,800	9,700	2	0	0.9	0	1,533	15	22,995	1.8	721	48	55	14,766	17,368
3	Retro-commissioning	7,500	none at this time	7,500	11,877	0	1,969	6.3	0	3,750	12	45,000	2.0	500	42	50	28,475	42,966
4	Replace 29 Metal Halide fixtures with T5 fixtures	6,134	1,290	4,844	5,200	1	0	0.5	1,173	1,995	15	29,925	2.4	518	35	41	18,054	9,311

Assumptions:

Discount Rate: 3.2%; Energy Price Escalation Rate: 0%

Note:

A 0.0 electrical demand reduction/month indicates that it is very low/negligible

APPENDIX I: METHOD OF ANALYSIS

Assumptions and tools

Cost estimates: RS Means 2012 (Facilities Maintenance & Repair Cost Data)
RS Means 2012 (Building Construction Cost Data)
RS Means 2012 (Mechanical Cost Data)
Published and established specialized equipment material and labor costs
Cost estimates also based on utility bill analysis and prior experience with similar projects

Disclaimer

This engineering audit was prepared using the most current and accurate fuel consumption data available for the site. The estimates that it projects are intended to help guide the owner toward best energy choices. The costs and savings are subject to fluctuations in weather, variations in quality of maintenance, changes in prices of fuel, materials, and labor, and other factors. Although we cannot guarantee savings or costs, we suggest that you use this report for economic analysis of the building and as a means to estimate future cash flow.

THE RECOMMENDATIONS PRESENTED IN THIS REPORT ARE BASED ON THE RESULTS OF ANALYSIS, INSPECTION, AND PERFORMANCE TESTING OF A SAMPLE OF COMPONENTS OF THE BUILDING SITE. ALTHOUGH CODE-RELATED ISSUES MAY BE NOTED, SWA STAFF HAVE NOT COMPLETED A COMPREHENSIVE EVALUATION FOR CODE-COMPLIANCE OR HEALTH AND SAFETY ISSUES. THE OWNER(S) AND MANAGER(S) OF THE BUILDING(S) CONTAINED IN THIS REPORT ARE REMINDED THAT ANY IMPROVEMENTS SUGGESTED IN THIS SCOPE OF WORK MUST BE PERFORMED IN ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL LAWS AND REGULATIONS THAT APPLY TO SAID WORK. PARTICULAR ATTENTION MUST BE PAID TO ANY WORK WHICH INVOLVES HEATING AND AIR MOVEMENT SYSTEMS, AND ANY WORK WHICH WILL INVOLVE THE DISTURBANCE OF PRODUCTS CONTAINING MOLD, ASBESTOS, OR LEAD.