

**NEW BRUNSWICK  
BOARD OF EDUCATION**

**LIVINGSTON ELEMENTARY SCHOOL**

**206 DELAVAN STREET  
NEW BRUNSWICK, NJ 08901**

**FACILITY ENERGY REPORT**

**TABLE OF CONTENTS**

I. HISTORIC ENERGY CONSUMPTION/COST..... 2

II. FACILITY DESCRIPTION ..... 7

III. MAJOR EQUIPMENT LIST ..... 9

IV. ENERGY CONSERVATION MEASURES..... 10

V. ADDITIONAL RECOMMENDATIONS ..... 27

Appendix A – ECM Cost & Savings Breakdown

Appendix B – New Jersey Smart Start<sup>®</sup> Program Incentives

Appendix C – Portfolio Manager “Statement of Energy Performance”

Appendix D – Major Equipment List

Appendix E – Investment Grade Lighting Audit

Appendix F – Renewable / Distributed Energy Measures Calculations

**I. HISTORIC ENERGY CONSUMPTION/COST**

The energy usage for the facility has been tabulated and plotted in graph form as depicted within this section. Each energy source has been identified and monthly consumption and cost noted per the information provided by the Owner.

Electric Utility Provider:	Public Service Electric & Gas
Electric Utility Rate Structure:	Large Power & Lighting Service (LPLS)
Third Party Supplier:	None

Natural Gas Utility Provider:	Public Service Electric & Gas
Utility Rate Structure:	Large Volume Gas (LVG)
Third Party Supplier:	None


The electric usage profile represents the actual electrical usage for the facility. The electric utility measures consumption in kilowatt-hours (KWH) and maximum demand in kilowatts (KW). One KWH usage is equivalent to 1000 watts running for one hour. One KW of electric demand is equivalent to 1000 watts running at any given time. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges. Rates used in this report reflect the historical data received for the facility.

The gas usage profile within each facility report shows the actual natural gas energy usage for the facility. The gas utility measures consumption in cubic feet x 100 (CCF), and converts the quantity into Therms of energy. One Therm is equivalent to 100,000 BTUs of energy.

**Table 1  
Electricity Billing Data**

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: PSE&G			
Rate: GLP			
Meter No: 728010136 ; 278004267			
Account # 70 055 890 09			
Third Party Utility Direct Energy			
TPS Meter / Acct No: N/A			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND KW</b>	<b>TOTAL BILL</b>
Nov-11	17,865	98.3	\$2,299
Dec-11	24,860	102.4	\$3,423
Jan-12	21,010	91.3	\$2,918
Feb-12	19,355	92.7	\$4,523
Mar-12	15,350	97.6	\$2,265
Apr-12	15,385	91.8	\$2,486
May-12	15,385	90.6	\$3,391
Jun-12	22,990	88.9	\$3,687
Jul-12	10,690	93.6	\$2,511
Aug-12	16,100	82.4	\$3,173
Sep-12	14,015	92.9	\$2,106
Oct-12	12,825	101.1	\$1,993
<b>Totals</b>	<b>205,830</b>	<b>102.4 Max</b>	<b>\$34,775</b>
<b>AVERAGE DEMAND</b>		<b>93.6 KW average</b>	
<b>AVERAGE RATE</b>		<b>\$0.169 \$/kWh</b>	


**Figure 1**  
**Electricity Usage Profile**



**Table 4  
Natural Gas Billing Data**

<b>NATURAL GAS USAGE SUMMARY</b>		
Utility Provider: PSE&G		
Rate: LVG		
Meter No: 2283620		
Point of Delivery ID: 70 055 953 00		
Third Party Utility Provider: N/A		
TPS Meter No: N/A		
<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
Nov-11	3,663.00	\$3,246.58
Dec-11	3,078.00	\$2,942.72
Jan-12	3,401.00	\$3,048.76
Feb-12	2,759.00	\$2,459.44
Mar-12	1,229.00	\$855.28
Apr-12	601.00	\$461.23
May-12	687.00	\$528.67
Jun-12	61.00	\$238.17
Jul-12	16.00	\$110.46
Aug-12	0.00	\$115.14
Sep-12	315.00	\$316.39
Oct-12	1,540.00	\$1,793.71
<b>TOTALS</b>	<b>17,350.00</b>	<b>\$16,116.55</b>
<b>AVERAGE RATE:</b>	<b>\$0.93</b>	<b>\$/THERM</b>

**Figure 2**  
**Natural Gas Usage Profile**



## II. FACILITY DESCRIPTION

The Livingston Elementary School is located at 206 Delavan Street in New Brunswick, New Jersey. The 40,000 SF Elementary School was built in 1922 with no additions. The building is a three-story structure with a basement. The building consists of office space for administrative use, multipurpose room, classrooms, kitchen, and mechanical room.

### Occupancy Profile

The typical school hours of Livingston Elementary School are Monday through Friday between 8:50 am and 3:15 pm. The building is open and operational between 7:00 am and 8:00 pm. The elementary school has a student population of approximately 429, and 35 administrative staff and teachers.

### Building Envelope

Exterior walls for the Livingston Elementary School are brick faced with a concrete block construction. The windows are in below average condition with single pane windows with aluminum frames. Blinds are utilized throughout the facility, per occupant comfort. The roof is a flat, built up roofing system and is need of repair/replacement.

### Heating Plant

Heating is provided to the facility from the Mechanical Room which houses two natural gas fired, cast iron sectional steam boilers made by Weil McLain. Both boilers have equivalent heating capacity characteristics having an input capacity of 2,713 MBH and output of 1,882 MBH for a combined output of 3,754 MBH. Both boilers appear to be maintained and in fair condition. Combustion tests were not available for review but based on age the estimated fuel-to-thermal efficiency for the boilers is 70%, based on radiation losses and inefficiencies in operation inherent to the older technology and steam systems. Both boilers are approximately 24 years old which is within the typical ASHRAE service life of 35 years.

The boiler condensate is pumped to the boiler via two (2) 3/4 HP pumps, located on the condensate receiver skid. At the time of the visit, it was observed that this skid (including the tank, pumps and controls) were being replaced.

### HVAC Systems

The classrooms within the facility are conditioned via vintage heating only steam fan coil units and perimeter steam radiation. During the survey it was noted that the majority of the fan coil units were not operational. Many of the steam control valves have been replaced. The steam traps that were inspected at the time of the survey had not been replaced and were older.

The Art Room is served by an above ceiling, heating only steam fan coil unit, by American Air Filter.

There are a total of eleven (11) window air conditioning units throughout the school ranging in size from 8,000 Btu/h to 12,000 Btu/h.



### Exhaust System

Air is exhausted from the toilet rooms and other areas of the facility through the roof exhaust fans.

### HVAC System Controls

The boilers of the school are controlled by a Johnson Metasys controller. The controller operates the boilers based on outside air temperature and three zone temperature sensors in the school. The classrooms have thermostats and steam control valves with pneumatic actuators. Many of the steam valves appeared to have been replaced recently and are in good condition. The fans within the majority of the classroom fan coil units are not functional.

### Domestic Hot Water

The domestic hot water for Livingston Elementary School is an AO Smith 275 MBH gas fired water heater with storage capacity of 100 gallons. This unit is two (2) years old and is in excellent condition.

### Water Conservation

It was observed at the time of the survey that the flush valves on the water closets and urinals in the public restrooms had been replaced with auto-sensor flush valves and the hand sink faucets had been replaced with metered/auto-sensor faucets.

### Lighting

Refer to the **Investment Grade Lighting Audit Appendix** for a detailed list of the lighting throughout the facility and estimated operating hours per space.

### III. MAJOR EQUIPMENT LIST

The equipment list contains major energy consuming equipment that through implementation of energy conservation measures could yield substantial energy savings. The list shows the major equipment in the facility and all pertinent information utilized in energy savings calculations. An approximate age was assigned to the equipment in some cases if a manufactures date was not shown on the equipment's nameplate. The ASHRAE service life for the equipment along with the remaining useful life is also shown in the Appendix.

Refer to the **Major Equipment List Appendix** for this facility.

#### IV. ENERGY CONSERVATION MEASURES

Energy Conservation Measures are developed specifically for this facility. The energy savings and calculations are highly dependent on the information received from the site survey and interviews with operations personnel. The assumptions and calculations should be reviewed by the owner to ensure accurate representation of this facility. The following ECMs were analyzed:

**Table 1**  
**ECM Financial Summary**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST<sup>A</sup></b>	<b>ANNUAL SAVINGS<sup>B</sup></b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
ECM #1	Lighting Upgrade - Trailers	\$16,720	\$1,937	8.6	73.8%
ECM #2	Gym Lighting Upgrade	\$6,550	\$659	9.9	50.9%
ECM #3	Lighting Controls Upgrade	\$11,920	\$1,956	6.1	146.1%
ECM #4	Window Replacement	\$88,920	\$1,925	46.2	-67.5%
ECM #5	Computer Automatic Standby or Hibernate Modes	\$3,667	\$5,739	0.6	682.5%
ECM #6	Boiler Burner and Controls Upgrade	\$26,000	\$686	37.9	-44.6%
<b>RENEWABLE ENERGY MEASURES (REM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST</b>	<b>ANNUAL SAVINGS</b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
REM #1	31.96 KW PV System	\$202,527	\$13,298	15.2	-1.5%
<b>Notes:</b>	A. Cost takes into consideration applicable NJ Smart Start <sup>TM</sup> incentives.				
	B. Savings takes into consideration applicable maintenance savings.				

**Table 2**  
**ECM Energy Summary**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
ECM #1	Lighting Upgrade - Trailers	4.4	11,461	-
ECM #2	Gym Lighting Upgrade	1.5	3,900	-
ECM #3	Lighting Controls Upgrade	-	11,571	-
ECM #4	Window Replacement	-	-	2,070
ECM #5	Computer Automatic Standby or Hibernate Modes	-	33,957	-
ECM #6	Boiler Burner and Controls Upgrade	-	-	738
<b>RENEWABLE ENERGY MEASURES (REM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
REM #1	31.96 KW PV System	32.0	36,931	-

**Table 3  
Facility Project Summary**

<b>ENERGY SAVINGS IMPROVEMENT PROGRAM - POTENTIAL PROJECT</b>					
<b>ENERGY CONSERVATION MEASURES</b>	<b>ANNUAL ENERGY SAVINGS (\$)</b>	<b>PROJECT COST (\$)</b>	<b>SMART START INCENTIVES</b>	<b>CUSTOMER COST</b>	<b>SIMPLE PAYBACK</b>
Lighting Upgrade - Trailers	\$1,937	\$16,720	\$0	\$16,720	8.6
Gym Lighting Upgrade	\$659	\$7,550	\$1,000	\$6,550	9.9
Lighting Controls Upgrade	\$1,956	\$13,050	\$1,130	\$11,920	6.1
Window Replacement	\$1,925	\$88,920	\$0	\$88,920	46.2
Computer Automatic Standby or Hibernate	\$5,739	\$3,667	\$0	\$3,667	0.6
Boiler Burner and Controls Upgrade	\$686	\$26,000	\$0	\$26,000	37.9
<i>Design / Construction Extras (15%)</i>	<i>\$0</i>	<i>\$23,386</i>	<i>\$0</i>	<i>\$23,386</i>	
<b>Total Project</b>	<b>\$12,901</b>	<b>\$179,293</b>	<b>\$2,130</b>	<b>\$177,163</b>	<b>14</b>

Design / Construction Extras is shown as an additional cost for the facility project summary. This cost is included to estimate the costs associated with construction management fees for a larger combined project.

## ECM #1: Lighting Upgrade – Trailers

### Description:

The majority of the interior lighting throughout Livingston Elementary School is provided with fluorescent fixtures with older generation, 700 series and 741/ECO 32W T8 lamps and electronic ballasts. Although these T8 lamps are considered fairly efficient, further energy savings can be achieved by replacing the existing T8 lamps with new generation, 800 series 28W T8 lamps without compromising light output. Concord Engineering recommends that these fixtures remain unmodified due to the extensive costs which will be incurred if these fixtures are to be re-lamped and re-ballasted, which results in a long payback period unless said fixtures reside in an area which is over-lit, in which case the fixtures will be de-lamped and given a new reflector. In addition, there are a number of older and outdated fixtures in the modular trailers with T12 lamps and magnetic ballasts. It is recommended to replace all of the T12 fixtures in these areas with higher efficiency fluorescent T8 fixtures with electronic ballasts.

### Energy Savings Calculations:

The **Investment Grade Lighting Audit Appendix** outlines the hours of operation, proposed retrofits, costs, savings, and payback periods for each set of fixtures in the each building.

### Energy Savings Summary:

<b>ECM #1 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$16,720
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$16,720
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$1,937
<b>Total Yearly Savings (\$/Yr):</b>	\$1,937
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	8.6
<b>Simple Lifetime ROI</b>	73.8%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$29,055
<b>Internal Rate of Return (IRR)</b>	8%
<b>Net Present Value (NPV)</b>	\$6,403.78

## ECM #2: Lighting & Controls Upgrade – Gymnasium

### Description:

The gymnasium at Livingston Elementary School is currently lit via fourteen 400W Metal Halide fixtures. The space would be better served with a more efficient, fluorescent lighting system. Concord Engineering recommends upgrading the lighting to an energy-efficient T5 High Output lighting system.

This measure replaces all the HID, 400 W HID MH fixtures with a well-designed T5HO lighting system. Ten, 54 watt, 6-Lamp T5HO fixtures will be required in order to meet the mandated 50 foot-candle average within the spaces.

### Energy Savings Calculations:

A detailed Investment Grade Lighting Audit can be found in **Investment Grade Lighting Audit Appendix** that outlines the proposed retrofits, costs, savings, and payback periods

### Energy Savings Summary:

<b>ECM #2 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$7,550
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$1,000
<b>Net Installation Cost (\$):</b>	\$6,550
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$659
<b>Total Yearly Savings (\$/Yr):</b>	\$659
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	9.9
<b>Simple Lifetime ROI</b>	50.9%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$9,887
<b>Internal Rate of Return (IRR)</b>	6%
<b>Net Present Value (NPV)</b>	\$1,318.29

### ECM #3: Lighting Controls Upgrade – Occupancy Sensors

#### Description:

Some of the lights in the Livingston Elementary School are left on unnecessarily. In many cases the lights are left on because of the inconvenience to manually switch lights off when a room is left or on when a room is first occupied. This is common in rooms that are occupied for only short periods and only a few times per day. In some instances lights are left on due to the misconception that it is better to keep the lights on rather than to continuously switch lights on and off. Although increased switching reduces lamp life, the energy savings outweigh the lamp replacement costs. The payback timeframe for when to turn the lights off is approximately two minutes. If the lights are expected to be off for at least a two minute interval, then it pays to shut them off.

Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed. Occupancy sensors detect motion and will switch the lights on when the room is occupied. Occupancy sensors can either be mounted in place of a current wall switch, or on the ceiling to cover large areas.

The U.S. Department of Energy sponsored a study to analyze energy savings achieved through various types of building system controls. The referenced savings is based on the “Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” document posted for public use April 2005. The study has found that commercial buildings have the potential to achieve significant energy savings through the use of building controls. The average energy savings are as follows based on the report:

- Occupancy Sensors for Lighting Control                      20% - 28% energy savings.

Savings resulting from the implementation of this ECM for energy management controls are estimated to be 20% of the total light energy controlled by occupancy sensors (The majority of the savings is expected to be after school hours when rooms are left with lights on)

This ECM includes installation of ceiling or switch mount sensors for individual offices, classrooms, large bathrooms, and Media Centers. Sensors shall be manufactured by SensorSwitch, Watt Stopper or equivalent. The **Investment Grade Lighting Audit Appendix** of this report includes the summary of lighting controls implemented in this ECM and outlines the proposed controls, costs, savings, and payback periods. The calculations adjust the lighting power usage by the applicable percent savings for each area that includes lighting controls.

#### Energy Savings Calculations:

$$\text{Energy Savings} = (\% \text{ Savings} \times \text{Controlled Light Energy (kWh/Yr)})$$

$$\text{Savings.} = \text{Energy Savings (kWh)} \times \text{Ave Elec Cost} \left( \frac{\$}{\text{kWh}} \right)$$



**Rebates and Incentives:**

From the **NJ Smart Start® Program Incentives Appendix**, the installation of a lighting control device warrants the following incentive:

Smart Start Incentive

$$= (\# \text{ Wall mount sensors} \times \$20 \text{ per sensor})$$

$$+ (\# \text{ Ceiling mount sensors} \times \$35 \text{ per sensor})$$

**Energy Savings Summary:**

<b>ECM #3 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$13,050
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$1,130
<b>Net Installation Cost (\$):</b>	\$11,920
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$1,956
<b>Total Yearly Savings (\$/Yr):</b>	\$1,956
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	6.1
<b>Simple Lifetime ROI</b>	146.1%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$29,333
<b>Internal Rate of Return (IRR)</b>	14%
<b>Net Present Value (NPV)</b>	\$11,424.70

## ECM #4: Window Replacement

### Description:

The Livingston Elementary School's envelope consists of single pane windows with aluminum frames.

The windows account for significant energy use through leakage heat loss and conductive heat loss. The age and condition of the windows contribute to the leakage rate of the building. The single pane construction allows higher thermal (conductive) energy loss. These factors lead to increased energy use in the heating season. The heating loss due to single pane glass is combined with heat loss due to poor seals at each operable window. New double pane windows with low E glazing offer a substantial improvement in thermal performance in the summer months.

This ECM includes the replacement of all remaining older windows single pane glass in the facility with double pane windows with low emissivity glass. The proposed windows include reduced outside air leakage. In addition the double pane structure will significantly increase the insulation value compared to the existing single pane window structure.

The basis for this ECM is Serious Windows at \$40 per SF of window installed.

### Energy Savings Calculations:

$$\text{Infiltration} \left( \frac{\text{Ft}^3}{\text{Min.}} \right) = \text{Window Area} (\text{Ft}^2) \times \text{Estimated Infiltration per SF of Window} \left( \frac{\text{CFM}}{\text{Ft}^2} \right)$$

$$\text{Heat Load} \left( \frac{\text{Btu}}{\text{Hr.}} \right) = 1.1 \times \text{Infiltration} \left( \frac{\text{Ft}^3}{\text{Min}} \right) \times \text{Design Temperature Difference} (^\circ\text{F})$$

$$\text{Cooling Load (Ton)} = \text{Infiltration} \left( \frac{\text{Ft}^3}{\text{Min}} \right) \times \frac{1 \text{ Ton Cooling}}{400 \left( \frac{\text{Ft}^3}{\text{Min}} \right)}$$

$$\text{Heating Leakage Energy (Therms)} = \frac{\text{Heat Load} \left( \frac{\text{Btu}}{\text{Hr.}} \right) \times \text{HDD} (\text{Day } ^\circ\text{F}) \times 24 \left( \frac{\text{Hr.}}{\text{Day}} \right) \times (0.60)}{65 (^\circ\text{F}) \times \text{Fuel Heat Value} \left( \frac{\text{Btu}}{\text{Therms}} \right) \times \text{Heating Efficiency} (\%)}$$

$$\text{Cooling Leakage Energy (kWh)} = \frac{\text{Cooling Load (Ton)} \times \left( \frac{12,000 \text{ Btu}}{\text{Ton Hr.}} \right) \times \text{Full Load Cooling Hours}}{\frac{1000 \text{ W.h}}{\text{kWh}} \times \text{Cooling Efficiency (EER)}}$$

$$\text{Conductive Energy (Therms)} = \frac{\text{U - Value} \times \text{Area (Ft}^2\text{)} \times \text{HDD (Day }^\circ\text{F)} \times 24 \left( \frac{\text{Hr.}}{\text{Day}} \right) \times (0.60)}{65(^\circ\text{F}) \times \text{Fuel Heat Value} \left( \frac{\text{Btu}}{\text{Therms}} \right) \times \text{Heating Efficiency (\%)}}$$

$$\text{Heating Energy Cost} = \text{Total Heating Energy (Therms)} \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{Therms}} \right)$$

$$\text{Cooling Energy Cost} = \text{Total Cooling Energy (kWh)} \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{kWh}} \right)$$

<b>WINDOW REPLACEMENT CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Description:</b>	Existing Single Pane Windows	Double Pane Low-E Windows	
Window (SF)	2,052	2,052	
U-Value (BTU/HR/SF*°F)	1.0	0.45	0.55
Infiltration Rate (CFM/SF)	0.6	0.3	0.30
Indoor Temperature Heating (°F)	70	70	
Average Thermal Loss Rate Heating (BTU/HR)	51,593	23,217	28,376
Heating Degree Days (65°F)	4157	4157	
Thermal Losses Heating (kBtu)	263,428	118,542	144,885
Heating System Efficiency (%)	70.0%	70.0%	
Natural Gas Cost (\$/Therm)	\$0.93	\$0.93	-
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
Natural Gas Usage (Therm)	3,763	1,693	2,070
Energy Cost Savings (\$)	\$3,500	\$1,575	\$1,925
<b>Comments:</b>	1. Proposed window U-value Based on ASHRAE 90.1 - 2007 2. Savings Based on Avg. Monthly Temperature for Sep-11 to Aug-12		

**Energy Savings Summary:**

<b>ECM #4 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$88,920
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$88,920
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$1,925
<b>Total Yearly Savings (\$/Yr):</b>	\$1,925
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	46.2
<b>Simple Lifetime ROI</b>	-67.5%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$28,874
<b>Internal Rate of Return (IRR)</b>	-12%
<b>Net Present Value (NPV)</b>	(\$65,940.64)

## ECM #5: Set Computers to Automatic Stand-by or Hibernate Modes

### Description:

During the survey, it was noticed that the majority of the computers were left at ON position with the monitors at Screen Saver or OFF positions.

Many personal computers (PC) came equipped with automatic Sleep Mode or Hibernate (power down) mode features. Normally computers boot up from Sleep Mode or Hibernate mode much faster than powering up from Shut Down position.

Based on an independent study by the U.S. Department of Energy, Energy star® rated computers use approximately 70% less power during Sleep Mode. It is recommended to set up the PCs at this facility to switch into Sleep Mode after a short period of inactivity and Hibernate mode after a long period of inactivity.

This ECM includes configuring the computers in the classrooms and the offices such that they automatically switch into:

- Sleep Mode after 15 minutes of inactivity
- Hibernate after 60 minutes of inactivity

The inactivity times above can be adjusted based on experience or preference. Even though this ECM can be implemented easily in house, the calculations assume an independent computer technician performing the task at a typical market rate.

### Energy Savings Calculations:

No. of CRT Computers:	220
Operating Weeks per Yr:	42
Estimated percentage of computers left ON over night:	75%

$$\text{Electric Usage} = \frac{\# \text{ of Computers} \times \text{Computer Power (W)} \times \text{Operation (Hrs)}}{1000 \left( \frac{\text{W}}{\text{KW}} \right)}$$

$$\text{Energy Cost} = \text{Electric Usage (kWh)} \times \text{Ave Elec Cost} \left( \frac{\$}{\text{kWh}} \right)$$

The cost of configuring the computers to automatically sleep or hibernate is based on 10 minutes per computer per technician at an hourly rate indicated below.

Implementation Costs:       = # Computers X Configuration Time X Cost per Hour  
                                      = 220 Monitors X 10 Minutes/Computer X \$100 per Hour  
  
                                      = \$3,667

<b>AUTOMATIC SLEEP OR HIBERNATE MODES FOR COMPUTERS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	Manual Operation	Auto Power Save	-
<b># of Computers</b>	220	220	-
<b>% Computers left ON</b>	75%	75%	-
<b>Power when left ON (Watt)</b>	50	50	-
<b>Power at Stand-by (Watt)</b>	5	5	-
<b>Power at Hibernate (Watt)</b>	4	4	-
<b>Power when OFF (Watt)</b>	0	0	-
<b>Operating Weeks per Yr</b>	42	42	-
<b>Operating Hours per Week</b>	168	168	-
<b>Hours/Wk Computers ON</b>	120	20	-
<b>Hours/Wk at Sleep Mode</b>	0	20	-
<b>Hours/Wk at Hibernate Mode</b>	0	80	-
<b>Hours/Wk at Power Down</b>	48	48	-
<b>Elec Cost (\$/kWh)</b>	0.169	0.169	-
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Usage (kWh)</b>	41,580	7,623	33,957
<b>Energy Cost (\$)</b>	\$7,027	\$1,288	\$5,739
<b>COMMENTS:</b>	Calculation assumes computers currently run throughout work week and get shut down over the weekend.		



**Energy Savings Summary:**

<b>ECM #5 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$3,667
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$3,667
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$5,739
<b>Total Yearly Savings (\$/Yr):</b>	\$5,739
<b>Estimated ECM Lifetime (Yr):</b>	5
<b>Simple Payback</b>	0.6
<b>Simple Lifetime ROI</b>	682.5%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$28,695
<b>Internal Rate of Return (IRR)</b>	155%
<b>Net Present Value (NPV)</b>	\$22,615.94

## ECM #6: STEAM BOILER BURNER & CONTROLS UPGRADE

### Description:

All of the heating is provided to the school facility by Weil McLain 65 Boiler Horsepower (BHP) natural gas-fired boilers that produces steam for the heating season. The boilers are 1989 vintage and are well maintained and currently should be capable of achieving an efficiency rating of 70 to 75 percent while operating. Given the limitations of the current system burner and controls and the vast improvement in boiler controls today over what was available then, it is recommended that a burner and new controls upgrade be performed.

This ECM will install new Cleaver Brooks Profire burner with Honeywell, CB780E controls on each of these boilers with separate motors that will control fuel flow, excess air oxygen trim and variable speed on the blower. Installation of this system will result in improved operating efficiency of the boilers and less cycling of boilers since the boilers can operate closer to the demanded load requirement.

### Energy Savings Using Hand Calculations:

Annual Heating Energy Savings = Existing Fuel Consumption x 8% Efficiency Increase

Heating Cost Savings = Annual Heating Energy Savings x Fuel Cost (\$/Unit)**Error! Bookmark not defined.**

**Error! Bookmark not defined.**

### Energy Savings Summary:

ECM #6 - ENERGY SAVINGS SUMMARY	
Installation Cost (\$):	\$26,000
NJ Smart Start Equipment Incentive (\$):	\$0
Net Installation Cost (\$):	\$26,000
Maintenance Savings (\$/Yr):	\$0
Energy Savings (\$/Yr):	\$686
Total Yearly Savings (\$/Yr):	\$686
Estimated ECM Lifetime (Yr):	21
Simple Payback	37.9
Simple Lifetime ROI	-44.6%
Simple Lifetime Maintenance Savings	0
Simple Lifetime Savings	\$14,403
Internal Rate of Return (IRR)	-5%
Net Present Value (NPV)	(\$15,427.22)

**REM #1: 31.96 kW Solar System****Description:**

The Livingston Elementary School has available roof space that could accommodate a significant amount of solar generation. Based on the available areas a 31.96 kilowatt solar array could be installed, assuming the existing roof structure is capable of supporting an array. The array will produce approximately 36,931 kilowatt-hours annually that will reduce the overall electric usage of the facility by 17.94%.

**Energy Savings Calculations:**

See **Renewable / Distributed Energy Measures Calculations Appendix** for detailed financial summary and proposed solar layout areas. Financial results in table below are based on 100% financing of the system over a fifteen year period.

**Energy Savings Summary:**

<b>REM #1 - ENERGY SAVINGS SUMMARY</b>	
<b>System Size (KW<sub>DC</sub>):</b>	31.96
<b>Electric Generation (KWH/Yr):</b>	36,931
<b>Installation Cost (\$):</b>	\$202,527
<b>SREC Revenue (\$/Yr):</b>	\$7,057
<b>Energy Savings (\$/Yr):</b>	\$6,241
<b>Total Yearly Savings (\$/Yr):</b>	\$13,298
<b>ECM Analysis Period (Yr):</b>	15
<b>Simple Payback (Yrs):</b>	15.2
<b>Analysis Period Electric Savings (\$):</b>	\$116,082
<b>Analysis Period SREC Revenue (\$):</b>	\$102,228
<b>Net Present Value (NPV)</b>	<b>(\$68,468.24)</b>

## V. ADDITIONAL RECOMMENDATIONS

The following recommendations include no cost/low cost measures, Operation & Maintenance (O&M) items, and water conservation measures with attractive paybacks. These measures are not eligible for the Smart Start Buildings incentives from the office of Clean Energy but save energy none the less.

- A. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- B. Maintain all weather stripping on windows and doors.
- C. Clean all light fixtures to maximize light output.
- D. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.
- E. Turn off computers when not in use. Ensure computers are not running in screen saver mode which saves the monitor screen not energy.
- F. Ensure outside air dampers are functioning properly and only open during occupied mode.
- G. Replace any older model window air conditioning units with new energy star rated window air conditioning units.
- H. Steam Trap Replacement Survey and Analysis by Spirax/Sarco is a recommendation for the school to provide additional energy and operational savings.

**APPENDIX A**

**ECM COST & SAVINGS BREAKDOWN**

CONCORD ENGINEERING GROUP

New Brunswick Board of Education - Livingston Elementary School

ECM ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
ECM NO.	DESCRIPTION	INSTALLATION COST				YEARLY SAVINGS			ECM LIFETIME	LIFETIME ENERGY SAVINGS	LIFETIME MAINTENANCE SAVINGS	LIFETIME ROI	SIMPLE PAYBACK	INTERNAL RATE OF RETURN (IRR)	NET PRESENT VALUE (NPV)
		MATERIAL	LABOR	REBATES, INCENTIVES	NET INSTALLATION COST	ENERGY	MAINT. / SREC	TOTAL		(Yearly Saving * ECM Lifetime)	(Yearly Maint Saving * ECM Lifetime)	(Lifetime Savings - Net Cost) / (Net Cost)	(Net cost / Yearly Savings)	$\sum_{n=0}^N \frac{C_n}{[1 + IRR]^n}$	$\sum_{n=0}^N \frac{C_n}{[1 + DR]^n}$
		(\$)	(\$)	(\$)	(\$)	(\$/yr)	(\$/yr)	(\$/yr)		(Yr)	(\$)	(\$)	(%)	(Yr)	(\$)
ECM #1	Lighting Upgrade - Trailers	\$9,120	\$7,600	\$0	\$16,720	\$1,937	\$0	\$1,937	15	\$29,055	\$0	73.8%	8.6	7.86%	\$6,403.78
ECM #2	Gym Lighting Upgrade	\$2,500	\$5,050	\$1,000	\$6,550	\$659	\$0	\$659	15	\$9,887	\$0	50.9%	9.9	5.65%	\$1,318.29
ECM #3	Lighting Controls Upgrade	\$10,950	\$2,100	\$1,130	\$11,920	\$1,956	\$0	\$1,956	15	\$29,333	\$0	146.1%	6.1	14.15%	\$11,424.70
ECM #4	Window Replacement	\$82,080	\$6,840	\$0	\$88,920	\$1,925	\$0	\$1,925	15	\$28,874	\$0	-67.5%	46.2	-11.60%	(\$65,940.64)
ECM #5	Computer Automatic Standby or Hibernate Modes	\$0	\$3,667	\$0	\$3,667	\$5,739	\$0	\$5,739	5	\$28,695	\$0	682.5%	0.6	155.05%	\$22,615.94
ECM #6	Boiler Burner and Controls Upgrade	\$26,000	\$0	\$0	\$26,000	\$686	\$0	\$686	21	\$14,403	\$0	-44.6%	37.9	-4.84%	(\$15,427.22)
REM RENEWABLE ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
REM #1	31.96 KW PV System	\$202,527	\$0	\$0	\$202,527	\$6,241	\$7,057	\$13,298	15	\$199,474	\$105,854	-1.5%	15.2	-0.19%	(\$43,773.34)

- Notes:**
- 1) The variable Cn in the formulas for Internal Rate of Return and Net Present Value stands for the cash flow during each period.
  - 2) The variable DR in the NPV equation stands for Discount Rate
  - 3) For NPV and IRR calculations: From n=0 to N periods where N is the lifetime of ECM and Cn is the cash flow during each period.

**APPENDIX B**

# Concord Engineering Group, Inc.

520 BURNT MILL ROAD  
VOORHEES, NEW JERSEY 08043  
PHONE: (856) 427-0200  
FAX: (856) 427-6508



## SmartStart Building Incentives

The NJ SmartStart Buildings Program offers financial incentives on a wide variety of building system equipment. The incentives were developed to help offset the initial cost of energy-efficient equipment. The following tables show the current available incentives as of February 11, 2013:

### **Electric Chillers**

Water-Cooled Chillers	\$16 - \$170 per ton
Air-Cooled Chillers	\$8 - \$52 per ton

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Cooling**

Gas Absorption Chillers	\$185 - \$400 per ton
Gas Engine-Driven Chillers	Calculated through custom measure path)

### **Desiccant Systems**

\$1.00 per cfm – gas or electric
----------------------------------

### **Electric Unitary HVAC**

Unitary AC and Split Systems	\$73 - \$92 per ton
Air-to-Air Heat Pumps	\$73 - \$92 per ton
Water-Source Heat Pumps	\$81 per ton
Packaged Terminal AC & HP	\$65 per ton
Central DX AC Systems	\$40- \$72 per ton
Dual Enthalpy Economizer Controls	\$250
Occupancy Controlled Thermostat (Hospitality & Institutional Facility)	\$75 per thermostat
A/C Economizing Controls	≤ 5 tons \$85/unit; >5 tons \$170/unit

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Heating**

Gas Fired Boilers < 300 MBH	\$2.00 per MBH, but not less than \$300 per unit
Gas Fired Boilers ≥ 300 - 1500 MBH	\$1.75 per MBH
Gas Fired Boilers ≥1500 - ≤ 4000 MBH	\$1.00 per MBH
Gas Fired Boilers > 4000 MBH	(Calculated through Custom Measure Path)
Gas Furnaces	\$400 per unit, AFUE ≥ 95%
Boiler Economizing Controls	\$1,200 - \$2,700
Low Intensity Infrared Heating	\$300 - \$500 per unit



### Ground Source Heat Pumps

Closed Loop	\$450 per ton, EER $\geq$ 16
	\$600 per ton, EER $\geq$ 18
	\$750 per ton, EER $\geq$ 20

Energy Efficiency must comply with ASHRAE 90.1-2007

### Variable Frequency Drives

Variable Air Volume	\$65 - \$155 per hp
Chilled-Water Pumps	\$60 per VFD rated hp
Compressors	\$5,250 to \$12,500 per drive
Cooling Towers $\geq$ 10 hp	\$60 per VFD rated hp
Boiler Fans $\geq$ 5 HP	\$65 to \$155 per hp
Boiler Feed Water Pumps $\geq$ 5 HP	\$60 to \$155 per hp
Commercial Kitchen Hood up to 50 HP	Retrofit \$55 – \$300 per hp New Hood \$55 - \$250 per hp

### Natural Gas Water Heating

Gas Water Heaters $\leq$ 50 gallons, 0.67 energy factor or better	\$50 per unit
Gas-Fired Water Heaters $>$ 50 gallons	\$1.00 - \$2.00 per MBH
Gas-Fired Booster Water Heaters	\$17 - \$35 per MBH
Gas Fired Tankless Water Heaters	\$300 per unit

### Prescriptive Lighting

Retro fit of T12 to T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities (Expires 3/1/2013)	\$10 per fixture (1-4 lamps)
Replacement of T12 with new T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities (Expires 3/1/2013)	\$25 per fixture (1-4 lamps)
T-8 reduced Wattage (28w/25w 4', 1-4 lamps) Lamp & ballast replacement	\$10 per fixture
For retrofit of T-8 fixtures by permanent de-lamping & new reflectors (Electronic ballast replacement required)	\$15 per fixture
T-5 and T-8 High Bay Fixtures	\$16 - \$200 per fixture
Metal Halide w/Pulse Start Including Parking Lot	\$25 per fixture
HID $\geq$ 100w Retrofit with induction lamp, power coupler and generator (must be 30% less watts/fixture than HID system)	\$50 per fixture
HID $\geq$ 100w Replacement with new HID $\geq$ 100w	\$70 per fixture

### Prescriptive Lighting - LED

LED Display Case Lighting	\$30 per display case
LED Shelf-Mtd. Display & Task Lights	\$15 per linear foot
LED Portable Desk Lamp	\$20 per fixture
LED Wall-wash Lights	\$30 per fixture
LED Recessed Down Lights	\$35 per fixture
LED Outdoor Pole/Arm-Mounted Area and Roadway Luminaries	\$175 per fixture
LED Outdoor Pole/Arm-Mounted Decorative Luminaries	\$175 per fixture
LED Outdoor Wall-Mounted Area Luminaries	\$100 per fixture
LED Parking Garage Luminaries	\$100 per fixture
LED Track or Mono-Point Directional Lighting Fixtures	\$50 per fixture
LED High-Bay and Low-Bay Fixtures for Commercial & Industrial Bldgs.	\$150 per fixture
LED High-Bay-Aisle Lighting	\$150 per fixture
LED Bollard Fixtures	\$50 per fixture
LED Linear Panels (1x4, 2x2, 2x4 Troffers only)	\$100 per fixture
LED Fuel Pump Canopy	\$100 per fixture
LED Screw-based & Pin-based (PAR, MR, BR, R) Standards (A-Style) and Decorative Lamps	\$20 per lamp
LED Refrigerator/Freezer case lighting replacement of fluorescent in medium and low temperature display case	\$30 per 4 foot \$42 per 5 foot \$65 per 6 foot
LED Retrofit Kits	To be evaluated through the customer measure path

### Lighting Controls – Occupancy Sensors

Wall Mounted	\$20 per control
Remote Mounted	\$35 per control
Daylight Dimmers	\$25-\$50 per fixture
Occupancy Controlled hi-low Fluorescent Controls	\$25 per fixture controlled

### Lighting Controls – HID or Fluorescent Hi-Bay Controls

Occupancy hi-low	\$75 per fixture controlled
Daylight Dimming	\$75 per fixture controlled

### Premium Motors

Three-Phase Motors ( <i>Expires 3/1/2013</i> )	\$45 - \$700 per motor
Fractional HP Motors Electronic Commutated Motors (replacing shaded pole motors in refrigerator/freezer cases)	\$40 per electronic commutated motor

### Refrigeration Doors/Covers

Energy-Efficient Doors/Covers for Installation on Open Refrigerated Cases	\$100 per door
Aluminum Night Curtains for Installation on Open Refrigerated Cases	\$3.50 per linear foot

### Refrigeration Controls

Door Heater Controls	\$50 per control
Electric Defrost Controls	\$50 per control
Evaporator Fan Controls	\$75 per control
Novelty Cooler Shutoff	\$50 per control

### Other Equipment Incentives

Performance Lighting	\$1.00 per watt per SF below program incentive threshold, currently 5% more energy efficient than ASHRAE 90.1- 2007 for New Construction and Complete Renovation
Custom Electric and Gas Equipment Incentives	not prescriptive
Custom Measures	\$0.16 KWh and \$1.60/Therm of 1st year savings, or a buy down to a 1 year payback on estimated savings. Minimum required savings of 75,000 KWh or 1,500 Therms and an IRR of at least 10%.

**APPENDIX C**



# STATEMENT OF ENERGY PERFORMANCE

## 2-New Brunswick BOE - Livingston Elementary School

Building ID: 3415927

For 12-month Period Ending: October 31, 2012<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: February 04, 2013

**Facility**

2-New Brunswick BOE - Livingston  
Elementary School  
206 Delavan Street  
New Brunswick, NJ 08901

**Facility Owner**

New Brunswick Board of Education  
268 Baldwin Street 3rd Floor  
New Brunswick, NJ 08901

**Primary Contact for this Facility**

Jack Humma  
268 Baldwin Street 3rd Floor  
New Brunswick, NJ 08901

Year Built: 1922

Gross Floor Area (ft<sup>2</sup>): 40,000Energy Performance Rating<sup>2</sup> (1-100) 85**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase(kBtu)	708,285
Natural Gas (kBtu) <sup>4</sup>	1,726,714
Total Energy (kBtu)	2,434,999

**Energy Intensity<sup>4</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	61
Source (kBtu/ft <sup>2</sup> /yr)	104

**Emissions (based on site energy use)**

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	192
---	-----

**Electric Distribution Utility**

Public Service Electric &amp; Gas Co

**National Median Comparison**

National Median Site EUI	91
National Median Source EUI	155
% Difference from National Median Source EUI	-33%
Building Type	K-12 School

**Meets Industry Standards<sup>5</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

## Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Values represent energy intensity, annualized to a 12-month period.
5. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Certifying Professional**

Michael Fischette  
520 South Burnt Mill Road  
Voorhees, NJ 08043

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) or a Registered Architect (RA) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE or RA in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	2-New Brunswick BOE - Livingston Elementary School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	206 Delavan Street, New Brunswick, NJ 08901	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of a hospital, k-12 school, hotel and senior care facility) nor can they be submitted as representing only a portion of a building.		<input type="checkbox"/>
Livingston ES (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	40,000 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	220	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	0	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	20 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	100 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	10(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Electric & Gas Co

Fuel Type: Electricity		
<b>Meter: Electric Meter # 728010136 (kWh (thousand Watt-hours))</b>		
<b>Space(s):</b> Entire Facility		
<b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
09/16/2012	10/15/2012	12,080.00
08/16/2012	09/15/2012	9,440.00
07/16/2012	08/15/2012	8,800.00
06/16/2012	07/15/2012	20,800.00
05/16/2012	06/15/2012	13,120.00
04/16/2012	05/15/2012	12,880.00
03/16/2012	04/15/2012	11,120.00
02/16/2012	03/15/2012	11,840.00
01/16/2012	02/15/2012	11,440.00
12/16/2011	01/15/2012	10,640.00
11/16/2011	12/15/2011	12,840.00
<b>Electric Meter # 728010136 Consumption (kWh (thousand Watt-hours))</b>		<b>135,000.00</b>
<b>Electric Meter # 728010136 Consumption (kBtu (thousand Btu))</b>		<b>460,620.00</b>
<b>Meter: Electric Meter # 278004267 (kWh (thousand Watt-hours))</b>		
<b>Space(s):</b> Entire Facility		
<b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
09/16/2012	10/15/2012	1,935.00
08/16/2012	09/15/2012	6,660.00
07/16/2012	08/15/2012	1,890.00
06/16/2012	07/15/2012	2,190.00
05/16/2012	06/15/2012	2,265.00
04/16/2012	05/15/2012	2,505.00
03/16/2012	04/15/2012	4,230.00
02/16/2012	03/15/2012	7,515.00
01/16/2012	02/15/2012	9,570.00
12/16/2011	01/15/2012	14,220.00
11/16/2011	12/15/2011	5,025.00
<b>Electric Meter # 278004267 Consumption (kWh (thousand Watt-hours))</b>		<b>58,005.00</b>
<b>Electric Meter # 278004267 Consumption (kBtu (thousand Btu))</b>		<b>197,913.06</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>658,533.06</b>



Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
<b>Fuel Type: Natural Gas</b>		
<b>Meter: Gas Meter # 2283620 (therms)</b> <b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (therms)</b>
09/16/2012	10/15/2012	315.00
08/16/2012	09/15/2012	0.00
07/16/2012	08/15/2012	16.00
06/16/2012	07/15/2012	61.00
05/16/2012	06/15/2012	687.00
04/16/2012	05/15/2012	601.00
03/16/2012	04/15/2012	1,229.00
02/16/2012	03/15/2012	2,759.00
01/16/2012	02/15/2012	3,401.00
12/16/2011	01/15/2012	3,078.00
11/16/2011	12/15/2011	3,663.00
<b>Gas Meter # 2283620 Consumption (therms)</b>		<b>15,810.00</b>
<b>Gas Meter # 2283620 Consumption (kBtu (thousand Btu))</b>		<b>1,581,000.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>		<b>1,581,000.00</b>
Is this the total Natural Gas consumption at this building including all Natural Gas meters?		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same PE or RA that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

## Facility

2-New Brunswick BOE - Livingston Elementary School  
206 Delavan Street  
New Brunswick, NJ 08901

## Facility Owner

New Brunswick Board of Education  
268 Baldwin Street 3rd Floor  
New Brunswick, NJ 08901

## Primary Contact for this Facility

Jack Humma  
268 Baldwin Street 3rd Floor  
New Brunswick, NJ 08901

## General Information

2-New Brunswick BOE - Livingston Elementary School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	40,000
Year Built	1922
For 12-month Evaluation Period Ending Date:	October 31, 2012

## Facility Space Use Summary

Livingston ES	
Space Type	K-12 School
Gross Floor Area (ft <sup>2</sup> )	40,000
Open Weekends?	No
Number of PCs	220
Number of walk-in refrigeration/freezer units	0
Presence of cooking facilities	Yes
Percent Cooled	20
Percent Heated	100
Months °	10
High School?	No
School District °	new brunswick

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 10/31/2012)	Baseline (Ending Date 10/31/2012)	Rating of 75	Target	National Median
Energy Performance Rating	85	85	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	61	61	71	N/A	91
Source (kBtu/ft <sup>2</sup> )	104	104	121	N/A	155
Energy Cost					
\$/year	\$ 49,059.46	\$ 49,059.46	\$ 57,062.75	N/A	\$ 72,972.62
\$/ft <sup>2</sup> /year	\$ 1.23	\$ 1.23	\$ 1.43	N/A	\$ 1.83
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	192	192	223	N/A	286
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	5	5	6	N/A	7

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Median column presents energy performance data your building would have if your building had a median rating of 50.

### Notes:

- o - This attribute is optional.
- d - A default value has been supplied by Portfolio Manager.


# Statement of Energy Performance

## 2012

2-New Brunswick BOE - Livingston Elementary School  
206 Delavan Street  
New Brunswick, NJ 08901

Portfolio Manager Building ID: 3415927

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).



This building uses 104 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending October 2012

**Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.**

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification



**APPENDIX D**

# MAJOR EQUIPMENT LIST

## Concord Engineering Group

### Livingston Elementary School

#### Boilers

<b>Tag</b>	<b>B-1,2</b>		
<b>Unit Type</b>	Cast Iron Sectional Steam Boilers		
<b>Qty</b>	2		
<b>Location</b>	Boiler Room		
<b>Area Served</b>	Steam Heating Loop		
<b>Manufacturer</b>	Weil McClain		
<b>Model #</b>	H-988-WS		
<b>Serial #</b>	NJ4591-1-H		
<b>Input Capacity (Btu/Hr)</b>	2,713		
<b>Rated Output Capacity (Btu/Hr)</b>	1,882		
<b>Approx. Efficiency %</b>	70.0%		
<b>Fuel</b>	Natural Gas		
<b>Approx Age</b>	24		
<b>ASHRAE Service Life</b>	35		
<b>Remaining Life</b>	11		
<b>Comments</b>	Boilers are in fair condition		

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

# MAJOR EQUIPMENT LIST

## Concord Engineering Group

### Livingston Elementary School

#### Domestic Water Heaters

<b>Tag</b>	<b>HWH-1</b>		
<b>Unit Type</b>	Domestic Hot Water Heater		
<b>Qty</b>	1		
<b>Location</b>	Boiler Room		
<b>Area Served</b>	Domestic Hot Water Loop		
<b>Manufacturer</b>	A.O. Smith		
<b>Model #</b>	BTR 275 118		
<b>Serial #</b>	1109M000304		
<b>Size (Gallons)</b>	100 Gallons		
<b>Input Capacity (MBH/KW)</b>	275 MBH		
<b>Recovery (Gal/Hr)</b>	266.6 GPH		
<b>Efficiency %</b>	90%		
<b>Fuel</b>	Natural Gas		
<b>Approx Age</b>	2		
<b>ASHRAE Service Life</b>	12		
<b>Remaining Life</b>	10		
<b>Comments</b>	Hot water heater is in good condition		

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

## MAJOR EQUIPMENT LIST

**Concord Engineering Group**

**Livingston Elementary School**

### Pumps

Tag	P-1,2	VP-1,2	
Unit Type	Steam condensate receiver, boiler feed pumps	Steam condensate receiver, vacuum pumps	
Qty	2	2	
Location	Boiler Room	Boiler Room	
Area Served	Condensate return, boiler feed	Condensate return, boiler feed	
Manufacturer	Magnetec, M Century	Magnetec, M Century	
Model #	-	-	
Serial #	-	-	
Horse Power	3/4	3	
Flow	-	-	
Motor Info	Magnetec, M Century	Magnetec, M Century	
Electrical Power	208-230/460/3/60	208-230/460/3/60	
RPM	3450	3450	
Motor Efficiency %	-	-	
Approx Age	25	25	
ASHRAE Service Life	18	18	
Remaining Life	(7)	(7)	
Comments	Condensate tank and pumps are being replaced	Condensate tank and pumps are being replaced	

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

**APPENDIX E**



CEG Project #: 9C12064  
 Facility Name: Livingston Elementary School  
 Address: 206 Delavan Street  
 City, State, Zip: New Brunswick, NJ 08901

Fixture Reference #	Location	Average Burn Hours	Description	Existing Distances					Proposed Distances Retrofit					Retrofit Energy Savings			Lighting Retrofit Costs				Proposed Lighting Controls								
				Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Energy Savings, kWh	Energy Savings, \$	Material	Total Labor	Total All	Rebate Estimate	Simple Payback	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$	
222.21	209 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	290	\$49
222.21	208 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	290	\$49
222.21	210 Office	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	3	0.19	484	Existing to Remain	Existing to Remain	2	62	0	0.19	484	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	97	\$16
222.21	210 Office	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	1	0.06	161	Existing to Remain	Existing to Remain	2	62	0	0.06	161	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	32	\$5
222.21	210 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	7	0.43	1,128	Existing to Remain	Existing to Remain	2	62	0	0.43	1,128	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	226	\$38
242.21	211 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	4	107	4	0.43	1,113	Existing to Remain	Existing to Remain	4	107	0	0.43	1,113	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	223	\$38
242.21	212 Office	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	4	107	2	0.21	556	Existing to Remain	Existing to Remain	4	107	0	0.21	556	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	111	\$19
222.21	Main Office	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	3	0.19	484	Existing to Remain	Existing to Remain	2	62	0	0.19	484	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.11	Main Office Restroom	1200	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	1	0.06	74	Existing to Remain	Existing to Remain	2	62	0	0.06	74	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
222.21	Principal Office	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	3	0.19	484	Existing to Remain	Existing to Remain	2	62	0	0.19	484	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	97	\$16
222.21	Principal Office Restroom	1200	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	1	0.06	74	Existing to Remain	Existing to Remain	2	62	0	0.06	74	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
242.21	205 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	4	107	6	0.64	1,669	Existing to Remain	Existing to Remain	4	107	0	0.64	1,669	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	334	\$56
242.21	204 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	4	107	6	0.64	1,669	Existing to Remain	Existing to Remain	4	107	0	0.64	1,669	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	334	\$56
222.21	203 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	290	\$49
222.21	202 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	290	\$49
222.21	201 Nurse	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.11	Stairwell Restroom	2600	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.11	Stairwell Restroom	2600	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
222.21	304 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	290	\$49
242.21	303 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	4	107	6	0.64	1,669	Existing to Remain	Existing to Remain	4	107	0	0.64	1,669	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	334	\$56
242.21	302 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	4	107	6	0.64	1,669	Existing to Remain	Existing to Remain	4	107	0	0.64	1,669	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	334	\$56
232.21	301 Office	2600	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	3	86	3	0.26	671	Existing to Remain	Existing to Remain	3	86	0	0.26	671	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	134	\$23
222.21	305 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	6	0.37	967	Existing to Remain	Existing to Remain	2	62	0	0.37	967	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	193	\$33
222.21	306 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mat., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	290	\$49

Fixture Reference #	Location	Average Item Hours	Existing Fixtures					Proposed Fixtures Retrofit					Retrofit Energy Savings			Lighting Retrofit Costs				Simple Payback	Control Ref #	Proposed Lighting Controls							
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Energy Savings, kW	Energy Savings, kWh	Energy Savings, \$	Material			Total Labor	Total All	Rebate Estimate	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$
222.21	Library	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	8	0.50	1,290	Existing to Remain	Existing to Remain	2	62	0	0.50	1,290	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
232.21	307 Classroom	2600	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	6	0.52	1,342	Existing to Remain	Existing to Remain	3	86	0	0.52	1,342	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	268	\$45	
242.21	309 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	4	107	6	0.64	1,669	Existing to Remain	Existing to Remain	4	107	0	0.64	1,669	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	334	\$56	
222.21	310 Classroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	290	\$49	
222.21	311 Office	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	64	\$11	
242.21	312 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	4	107	6	0.64	1,669	Existing to Remain	Existing to Remain	4	107	0	0.64	1,669	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	334	\$56	
242.21	313 Classroom	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	4	107	6	0.64	1,669	Existing to Remain	Existing to Remain	4	107	0	0.64	1,669	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	334	\$56	
121.11	Trailer 1	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
121.11	Trailer 2	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
121.11	Trailer 3	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
121.11	Trailer 4	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
121.11	Trailer 5	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
121.11	Trailer 6	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
121.11	Trailer 7	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
121.11	Trailer 8	2600	1x4, 2 Lamp, 34w T12, Magnetic Ballast, Surface Mt., Prismatic Lens	2	78	19	1.48	3,853	Reballast & Relamp	Reballast & Relamp; 28w T8 Elec. Ballast	2	49	19	0.93	2,421	0.55	1,433	\$242	\$1,140.00	\$950.00	\$2,090.00	\$0.00	8.63	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$82
221.34	Basement Boiler Room	1200	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mt., No Lens	2	62	9	0.56	670	Existing to Remain	Existing to Remain	2	62	0	0.56	670	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
242.21	Basement Kitchen	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	4	107	9	0.96	2,504	Existing to Remain	Existing to Remain	4	107	0	0.96	2,504	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
617	Kitchen Hood	2600	Recessed Down Light, C/D/zw Quad CFL Lamp	2	52	2	0.10	270	Existing to Remain	Existing to Remain	2	52	0	0.10	270	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
222.21	Basement Boys Restroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	4	0.25	645	Existing to Remain	Existing to Remain	2	62	0	0.25	645	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
222.21	Basement Girls Restroom	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	3	0.19	484	Existing to Remain	Existing to Remain	2	62	0	0.19	484	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
242.11	Basement Custodial Office	1200	2x4, 4 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	4	107	1	0.11	128	Existing to Remain	Existing to Remain	4	107	0	0.11	128	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
222.21	Basement Music Room	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	6	0.37	967	Existing to Remain	Existing to Remain	2	62	0	0.37	967	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	193	\$33	
221.11	Basement Office 3A	2600	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	64	\$11	
242.11	Basement Office 3A	2600	2x4, 4 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	4	107	1	0.11	278	Existing to Remain	Existing to Remain	4	107	0	0.11	278	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	56	\$9	
221.11	Basement Music Office	2600	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	64	\$11	
768	Multi-Purpose Room	2600	2x2,400w MH, Recessed	1	465	10	4.65	12,090	Remove and Return	(1) 6 Lamp, 54w TSHO	6	315	10	3.15	8,190	1.50	3,900	\$659	\$2,500.00	\$5,050.00	\$7,550.00	\$1,000.00	9.94	0	No New Controls	0	0.0%	0	\$0

Fixture Reference #	Location	Average Burn Hours	Existing Fixtures					Proposed Fixtures Retrofit					Retrofit Energy Savings			Lighting Retrofit Costs				Simple Payback	Control Ref #	Proposed Lighting Controls								
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/Yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/Yr	Energy Savings, kW	Energy Savings, kWh	Energy Savings, \$	Material			Total Labor	Total All	Rebate Estimate	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$	
221.21	Stage	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
222.21	Girls Locker Room	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
222.21	Boys Locker Room	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
221.11	Storage	1200	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	1	0.06	74	Existing to Remain	Existing to Remain	2	62	0	0.06	74	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
232.22	Art Room	2600	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Parabolic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	537	\$91	
241.11	Art Room Office	2600	1x4, 4 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	4	107	1	0.11	278	Existing to Remain	Existing to Remain	4	107	0	0.11	278	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	56	\$9	
241.11	Art Room Storage	1200	1x4, 4 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	4	107	1	0.11	128	Existing to Remain	Existing to Remain	4	107	0	0.11	128	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
232.22	5 Classroom	2600	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Parabolic Lens	3	86	13	1.12	2,907	Existing to Remain	Existing to Remain	3	86	0	1.12	2,907	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	581	\$98	
221.41	5 Classroom Restroom	1200	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mt, Prismatic Lens	2	62	1	0.06	74	Existing to Remain	Existing to Remain	2	62	0	0.06	74	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
232.22	Teachers Room	2600	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Parabolic Lens	3	86	6	0.52	1,342	Existing to Remain	Existing to Remain	3	86	0	0.52	1,342	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	268	\$45	
221.21	Teachers Room	2600	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	1	0.06	161	Existing to Remain	Existing to Remain	2	62	0	0.06	161	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	32	\$5	
221.41	Teachers Room Restroom	1200	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mt, Prismatic Lens	2	62	1	0.06	74	Existing to Remain	Existing to Remain	2	62	0	0.06	74	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
222.21	Basement Corridor	3000	2x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	15	0.93	2,790	Existing to Remain	Existing to Remain	2	62	0	0.93	2,790	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
232.21	1st Floor Corridor	3000	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	13	1.12	3,354	Existing to Remain	Existing to Remain	3	86	0	1.12	3,354	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
232.21	2nd Floor Corridor	3000	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	11	0.95	2,838	Existing to Remain	Existing to Remain	3	86	0	0.95	2,838	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
221.11	Counselor Office	2600	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	1	0.06	161	Existing to Remain	Existing to Remain	2	62	0	0.06	161	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	32	\$5	
<b>TOTAL</b>						<b>445</b>	<b>38</b>	<b>99,297</b>						<b>162</b>	<b>32</b>	<b>83,936</b>	<b>6</b>	<b>15,361</b>	<b>2,596</b>	<b>11,620</b>	<b>12,650</b>	<b>24,270</b>	<b>1,000</b>	<b>9.35</b>			<b>42</b>		<b>11,571</b>	<b>1,956</b>

**APPENDIX F**

Location Description	Area (Sq FT)	Panel	Qty	Panel Sq Ft	Panel Total Sq Ft	Total KW <sub>DC</sub>	Total Annual kWh	Total KW <sub>AC</sub>	Panel Weight (41.9 lbs)	W/SQFT
Livingston ES	3350	SHARP NU-U235F2	136	17.5	2,386	31.96	36,931	25.9	5,698	13.40



Notes:

1. Estimated kWh based on the National Renewable Energy Laboratory PVWatts Version 1 Calculator Program.

**Project Name: LGEA Solar PV Project - Livingston ES**  
**Location: New Brunswick, NJ**  
**Description: Photovoltaic System 100% Financing - 15 year**

**Simple Payback Analysis**

	<b>Photovoltaic System 100% Financing - 15 year</b>
Total Construction Cost	\$202,527
Annual kWh Production	36,931
Annual Energy Cost Reduction	\$6,241
Average Annual SREC Revenue	\$7,057

Simple Payback: **15.23** Years

**Life Cycle Cost Analysis**

Analysis Period (years):	15	Financing %:	100%
Discount Rate:	3%	Maintenance Escalation Rate:	3.0%
Average Energy Cost (\$/kWh)	<b>\$0.169</b>	Energy Cost Escalation Rate:	3.0%
Financing Rate:	6.00%	Average SREC Value (\$/kWh)	\$0.191

Period	Additional Cash Outlay	Energy kWh Production	Energy Cost Savings	Additional Maint Costs	SREC Revenue	Interest Expense	Loan Principal	Net Cash Flow	Cumulative Cash Flow
0	\$0	0	0	0	\$0	0	0	0	0
1	\$0	36,931	\$6,241	\$0	\$9,233	\$11,918	\$8,591	(\$5,034)	(\$5,034)
2	\$0	36,746	\$6,429	\$0	\$9,187	\$11,388	\$9,120	(\$4,893)	(\$9,928)
3	\$0	36,563	\$6,621	\$0	\$9,141	\$10,826	\$9,683	(\$4,746)	(\$14,674)
4	\$0	36,380	\$6,820	\$0	\$9,095	\$10,228	\$10,280	(\$4,593)	(\$19,268)
5	\$0	36,198	\$7,025	\$373	\$9,049	\$9,594	\$10,914	(\$4,807)	(\$24,075)
6	\$0	36,017	\$7,235	\$371	\$7,203	\$8,921	\$11,587	(\$6,441)	(\$30,515)
7	\$0	35,837	\$7,452	\$369	\$7,167	\$8,206	\$12,302	(\$6,258)	(\$36,773)
8	\$0	35,658	\$7,676	\$367	\$7,132	\$7,448	\$13,061	(\$6,068)	(\$42,841)
9	\$0	35,479	\$7,906	\$365	\$7,096	\$6,642	\$13,866	(\$5,872)	(\$48,713)
10	\$0	35,302	\$8,144	\$364	\$5,295	\$5,787	\$14,722	(\$7,433)	(\$56,146)
11	\$0	35,125	\$8,388	\$362	\$5,269	\$4,879	\$15,630	(\$7,214)	(\$63,360)
12	\$0	34,950	\$8,639	\$360	\$5,242	\$3,915	\$16,594	(\$6,987)	(\$70,347)
13	\$0	34,775	\$8,899	\$358	\$5,216	\$2,891	\$17,617	(\$6,752)	(\$77,098)
14	\$0	34,601	\$9,166	\$356	\$3,460	\$1,805	\$18,704	(\$8,239)	(\$85,337)
15	\$0	34,428	\$9,441	\$355	\$3,443	\$651	\$19,857	(\$7,980)	(\$93,317)
<b>Totals:</b>		534,990	\$116,082	\$4,000	\$102,228	\$105,100	\$202,527	(\$93,317)	(\$677,428)
<b>Net Present Value (NPV)</b>								<b>(\$68,468)</b>	