

**NORTH BRUNSWICK TOWNSHIP  
PUBLIC SCHOOL DISTRICT**

**PARSONS ELEMENTARY SCHOOL**

**899 HOLLYWOOD STREET  
NORTH BRUNSWICK, NJ 08902**

**FACILITY ENERGY REPORT**

**TABLE OF CONTENTS**

I. HISTORIC ENERGY CONSUMPTION/COST..... 2

II. FACILITY DESCRIPTION ..... 7

III. MAJOR EQUIPMENT LIST ..... 9

IV. ENERGY CONSERVATION MEASURES..... 10

V. ADDITIONAL RECOMMENDATIONS ..... 32

Appendix A – ECM Cost & Savings Breakdown

Appendix B – New Jersey Smart Start® Program Incentives

Appendix C – Portfolio Manager “Statement of Energy Performance”

Appendix D – Major Equipment List

Appendix E – Investment Grade Lighting Audit

Appendix F – Renewable / Distributed Energy Measures Calculations

**I. HISTORIC ENERGY CONSUMPTION/COST**

The energy usage for the facility has been tabulated and plotted in graph form as depicted within this section. Each energy source has been identified and monthly consumption and cost noted per the information provided by the Owner.

Electric Utility Provider:	Public Service Electric & Gas
Electric Utility Rate Structure:	Large Power & Lighting Secondary (LPLS)
Third Party Supplier:	South Jersey Energy Company

Natural Gas Utility Provider:	Public Service Electric & Gas
Utility Rate Structure:	Large Volume Gas (LVG)
Third Party Supplier:	None


The electric usage profile represents the actual electrical usage for the facility. The electric utility measures consumption in kilowatt-hours (KWH) and maximum demand in kilowatts (KW). One KWH usage is equivalent to 1000 watts running for one hour. One KW of electric demand is equivalent to 1000 watts running at any given time. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges. Rates used in this report reflect the historical data received for the facility.

The gas usage profile within each facility report shows the actual natural gas energy usage for the facility. The gas utility measures consumption in cubic feet x 100 (CCF), and converts the quantity into Therms of energy. One Therm is equivalent to 100,000 BTUs of energy.

**Table 1  
Electricity Billing Data**

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: PSE&G			
Rate: LPLS			
Meter No: 778019791			
Account # E 42-123-503-00			
Third Party Utility Provider: South Jersey Energy Company			
TPS Meter / Acct No: -			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND KW</b>	<b>TOTAL BILL</b>
Aug-11	47,100	273.0	\$9,277
Sep-11	49,200	252.0	\$7,193
Oct-11	50,100	189.0	\$7,100
Nov-11	57,000	198.0	\$7,974
Dec-11	56,100	201.0	\$7,899
Jan-12	58,500	204.0	\$8,210
Feb-12	54,300	204.0	\$7,699
Mar-12	45,000	231.0	\$6,662
Apr-12	51,000	228.0	\$7,381
May-12	45,000	246.0	\$8,793
Jun-12	30,900	198.0	\$6,523
Jul-12	32,400	201.0	\$3,714
<b>Totals</b>	<b>576,600</b>	<b>273.0</b> Max	<b>\$88,425</b>
<b>AVERAGE DEMAND</b>		<b>218.8 KW average</b>	
<b>AVERAGE RATE</b>		<b>\$0.153 \$/kWh</b>	


**Figure 1**  
**Electricity Usage Profile**



**Table 4  
Natural Gas Billing Data**

<b>NATURAL GAS USAGE SUMMARY</b>		
Utility Provider: PSE&G		
Rate: LVG		
Meter No: 3567970		
Point of Delivery ID: G 42-123-503-0018		
Third Party Utility Provider: N/A		
TPS Meter No: N/A		
<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
Aug-11	172.00	\$233.47
Sep-11	1,127.00	\$964.66
Oct-11	3,384.00	\$3,896.51
Nov-11	4,833.00	\$5,346.90
Dec-11	5,713.00	\$5,260.02
Jan-12	5,077.00	\$4,513.05
Feb-12	3,370.00	\$3,155.88
Mar-12	2,153.00	\$1,377.58
Apr-12	1,116.00	\$762.72
May-12	138.00	\$186.25
Jun-12	81.00	\$153.84
Jul-12	91.00	\$163.02
<b>TOTALS</b>	<b>27,255.00</b>	<b>\$26,013.90</b>
<b>AVERAGE RATE:</b>	<b>\$0.95</b>	<b>\$/THERM</b>

**Figure 2**  
**Natural Gas Usage Profile**



## II. FACILITY DESCRIPTION

The Parsons Elementary School is located at 899 Hollywood Street in North Brunswick, New Jersey. The 84,079 SF Parsons Elementary School was built in the early 1960s with an addition in 2008. The building is a single story building and is comprised of office space for administrative use, a gymnasium, classrooms, a cafeteria, kitchen and mechanical rooms. In addition, there is a 2,030 square foot modular building on the campus.

### Occupancy Profile

The typical hours of operation for Parsons Elementary School are Monday through Friday between 8:00 am and 3:00 pm, with custodial services running until 8:00 pm. The elementary school has a 10 month occupancy with a student population of 669.

### Building Envelope

Exterior walls for the Parsons Elementary School are brick faced with a concrete block construction. The amount of insulation within the walls is unknown. The windows throughout the elementary school are in good condition and appear to be maintained. Typical windows throughout the elementary school are double pane, 1/4" clear glass with aluminum frames. Blinds are utilized throughout the school per occupant comfort. The blinds are valuable because they help to reduce heat loss in the winter and reduce solar heat in the summer. The roof is a flat, built up rubber roof where some of the HVAC equipment resides. Some of the roof has recently been refurbished and now has a layer of white gravel spread over the rubber. The amount of insulation below the roof is unknown.

### HVAC Systems

The offices adjacent to the cafeteria are served by two International Comfort Products packaged rooftop air conditioning units. The cooling capacity of these units is two tons each.

The classroom wings and offices in the original building are conditioned by unit ventilators with hot water and direct expansion coils.

The new wing is served by a Trane Intellipak rooftop unit. This unit is an 80 ton unit that provides cooling via a DX coil, and heating via a hot water coil fed from the boiler system.

Heating Hot Water for the building is generated by a boiler plant fitted with two Cleaver Brooks packaged boilers. The boilers are natural gas fired with input rating of 5,230 MBH. The boilers are both equipped with Power Flame Burners. Heating water is circulated via two 10 horsepower Bell and Gossett pumps.

The modular building is conditioned by a total of two (2) packaged heating and cooling units, mounted on the exterior of the structure. These units rarely operate, as the modular building is only currently used for storage.



### Exhaust System

Air is exhausted from the toilet rooms through the roof exhausters.

### HVAC System Controls

The Parsons Elementary School is controlled by a Novar DDC controls system. This is a non-web based control system that allows the facilities staff to set and monitor setpoints throughout the building. typical classrooms are set to 74°F for cooling and 72°F for heating. Offices typically are set to 74°F for heating and 70°F for cooling. Supplemental cooling systems are controlled by individual thermostats.

### Domestic Hot Water

Domestic hot water for the Parsons Elementary School is provided by one A.O. Smith HW 300 892 natural gas domestic water heater with a separate storage tank that has a capacity of 940 gallons.

### Lighting

Refer to the Investment Grade lighting Audit Appendix for a detailed list of the lighting throughout the facility and estimated operating hours per space.

### III. MAJOR EQUIPMENT LIST

The equipment list contains major energy consuming equipment that through implementation of energy conservation measures could yield substantial energy savings. The list shows the major equipment in the facility and all pertinent information utilized in energy savings calculations. An approximate age was assigned to the equipment in some cases if a manufactures date was not shown on the equipment's nameplate. The ASHRAE service life for the equipment along with the remaining useful life is also shown in the Appendix.

Refer to the **Major Equipment List Appendix** for this facility.

#### IV. ENERGY CONSERVATION MEASURES

Energy Conservation Measures are developed specifically for this facility. The energy savings and calculations are highly dependent on the information received from the site survey and interviews with operations personnel. The assumptions and calculations should be reviewed by the owner to ensure accurate representation of this facility. The following ECMs were analyzed:

**Table 1**  
**ECM Financial Summary**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST<sup>A</sup></b>	<b>ANNUAL SAVINGS<sup>B</sup></b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
ECM #1	Lighting Upgrade General	\$3,560	\$377	9.4	58.8%
ECM #2	Lighting Controls Upgrade	\$16,480	\$2,974	5.5	170.7%
ECM #3	NEMA Premium Motor Replacements	\$6,898	\$290	23.8	-24.3%
ECM #4	AC Unit Upgrades	\$27,186	\$1,913	14.2	5.6%
ECM #5	Boiler Upgrade	\$184,878	\$5,879	31.4	-20.5%
ECM #6	Computer Standby or Hibernate	\$2,450	\$3,471	0.7	2025.1%
ECM #7	Domestic Hot Water Heater Upgrade	\$13,500	\$1,043	12.9	-7.3%
<b>RENEWABLE ENERGY MEASURES (REM's)</b>					
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>NET INSTALLATION COST</b>	<b>ANNUAL SAVINGS</b>	<b>SIMPLE PAYBACK (Yrs)</b>	<b>SIMPLE LIFETIME ROI</b>
REM #1	125.96 kW Solar Array	\$794,424	\$51,121	15.5	-3.5%
<b>Notes:</b>	A. Cost takes into consideration applicable NJ Smart Start <sup>TM</sup> incentives.				
	B. Savings takes into consideration applicable maintenance savings.				

**Table 2  
ECM Energy Summary**

<b>ENERGY CONSERVATION MEASURES (ECM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
ECM #1	Lighting Upgrade General	1.2	3,042	0
ECM #2	Lighting Controls Upgrade	0	23,690	0
ECM #3	NEMA Premium Motor Replacements	0.2	687	0
ECM #4	AC Unit Upgrades	10.9	21,837	0
ECM #5	Boiler Upgrade	0.0	0	7,728
ECM #6	Computer Standby or Hibernate	0.0	26,085	0
ECM #7	Domestic Hot Water Heater Upgrade	0.0	0	1,098
<b>RENEWABLE ENERGY MEASURES (REM's)</b>				
<b>ECM NO.</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
		<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONSUMPTION (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
REM #1	125.96 kW Solar Array	126.0	148,571	0

**Table 3  
Facility Project Summary**

<b>ENERGY SAVINGS IMPROVEMENT PROGRAM - POTENTIAL PROJECT</b>					
<b>ENERGY CONSERVATION MEASURES</b>	<b>ANNUAL ENERGY SAVINGS (\$)</b>	<b>PROJECT COST (\$)</b>	<b>SMART START INCENTIVES</b>	<b>CUSTOMER COST</b>	<b>SIMPLE PAYBACK</b>
Lighting Upgrade General	\$377	\$3,560	\$0	\$3,560	9.4
Lighting Controls Upgrade	\$2,974	\$16,550	\$70	\$16,480	5.5
<del>NEMA Premium Motor Replacements</del>	<del>\$290</del>	<del>\$7,218</del>	<del>\$320</del>	<del>\$6,898</del>	<del>23.8</del>
AC Unit Upgrades	\$1,913	\$34,500	\$7,314	\$27,186	14.2
Boiler Upgrade	\$5,879	\$190,878	\$6,000	\$184,878	31.4
Computer Standby or Hibernate	\$3,471	\$2,450	\$0	\$2,450	0.7
Domestic Hot Water Heater Upgrade	\$1,043	\$14,000	\$500	\$13,500	12.9
<i>Design / Construction Extras (15%)</i>	<i>\$0</i>	<i>\$39,291</i>	<i>\$0</i>	<i>\$39,291</i>	
<b>Total Project</b>	<b>\$15,657</b>	<b>\$301,228</b>	<b>\$13,884</b>	<b>\$287,344</b>	<b>18</b>

Note: ECM's with the strike-through font are not included in the ESIP.

Design / Construction Extras is shown as an additional cost for the facility project summary. This cost is included to estimate the costs associated with construction management fees for a larger combined project.

## **ECM #1: Lighting Upgrade – General**

### **Description:**

The majority of the interior lighting throughout Parsons Elementary School is provided with fluorescent fixtures with 32W T8 lamps and electronic ballasts. In addition, there are a number of older and outdated fixtures with T12 lamps and magnetic ballasts. It is recommended to replace all of the T12 fixtures in these areas with higher efficiency fluorescent T8 fixtures with electronic ballasts.

This ECM includes retrofit of all older fluorescent fixtures with T8 or T5 fluorescent fixtures with electronic ballasts in the building. The new, energy efficient T8 fixtures will provide adequate lighting and will save on electrical costs due to better performance of the lamp and ballasts.

The ECM also includes replacement of any incandescent lamps with compact fluorescent lamps. Compact fluorescent lamps (CFL's) were designed to be direct replacements for the standard incandescent lamps which are common to table lamps, spot lights, hi-hats, bathroom vanity lighting, etc. The light output of the CFL has been designed to resemble the incandescent lamp. The color rendering index (CRI) of the CFL is much higher than standard fluorescent lighting, and therefore provides a much "truer" light. The CFL is available in a myriad of shapes and sizes depending on the specific application. Typical replacements are: a 13-Watt CFL for a 60-Watt incandescent lamp, an 18-Watt CFL for a 75-Watt incandescent lamp, and a 26-Watt CFL for a 100-Watt incandescent lamp. The CFL is also available for a number of "brightness colors" that is indicated by the Kelvin rating. A 2700K CFL is the "warmest" color available and is closest in color to the incandescent lamp. CFL's are also available in 3000K, 3500K, and 4100K. The 4100K would be the "brightest" or "coolest" output. A CFL can be chosen to screw right into existing fixtures, or hardwired into existing fixtures. Where the existing fixture is controlled by a dimmer switch, the CFL bulb must be compatible with a dimmer switch. In some locations the bulb replacement will need to be tested to make sure the larger base of the CFL will fit into the existing fixture. The energy usage of an incandescent compared to a compact fluorescent is approximately 3 to 4 times greater. In addition to the energy savings, compact fluorescent fixtures burn-hours are 8 to 15 times longer than incandescent fixtures ranging from 6,000 to 15,000 burn-hours compared to incandescent fixtures ranging from 750 to 1000 burn-hours. However, the maintenance savings due to reduced lamp replacement is offset by the higher cost of the CFL's compared to the incandescent lamps.

### **Energy Savings Calculations:**

The **Investment Grade Lighting Audit Appendix** outlines the hours of operation, proposed retrofits, costs, savings, and payback periods for each set of fixtures in the building.

**Energy Savings Summary:**

<b>ECM #1 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$3,560
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$3,560
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$377
<b>Total Yearly Savings (\$/Yr):</b>	\$377
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	9.4
<b>Simple Lifetime ROI</b>	58.8%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$5,655
<b>Internal Rate of Return (IRR)</b>	6%
<b>Net Present Value (NPV)</b>	\$940.60

## ECM #2: Lighting Controls Upgrade – Occupancy Sensors

### Description:

Some of the lights in the Parsons Elementary School are left on unnecessarily. In many cases the lights are left on because of the inconvenience to manually switch lights off when a room is left or on when a room is first occupied. This is common in rooms that are occupied for only short periods and only a few times per day. In some instances lights are left on due to the misconception that it is better to keep the lights on rather than to continuously switch lights on and off. Although increased switching reduces lamp life, the energy savings outweigh the lamp replacement costs. The payback timeframe for when to turn the lights off is approximately two minutes. If the lights are expected to be off for at least a two minute interval, then it pays to shut them off.

Lighting controls come in many forms. Sometimes an additional switch is adequate to provide reduced lighting levels when full light output is not needed. Occupancy sensors detect motion and will switch the lights on when the room is occupied. Occupancy sensors can either be mounted in place of a current wall switch, or on the ceiling to cover large areas.

The U.S. Department of Energy sponsored a study to analyze energy savings achieved through various types of building system controls. The referenced savings is based on the “Advanced Sensors and Controls for Building Applications: Market Assessment and Potential R&D Pathways,” document posted for public use April 2005. The study has found that commercial buildings have the potential to achieve significant energy savings through the use of building controls. The average energy savings are as follows based on the report:

- Occupancy Sensors for Lighting Control                      20% - 28% energy savings.

Savings resulting from the implementation of this ECM for energy management controls are estimated to be 20% of the total light energy controlled by occupancy sensors (The majority of the savings is expected to be after school hours when rooms are left with lights on)

This ECM includes installation of ceiling or switch mount sensors for individual offices, classrooms, large bathrooms, and Media Centers. Sensors shall be manufactured by SensorSwitch, Watt Stopper or equivalent. The **Investment Grade Lighting Audit Appendix** of this report includes the summary of lighting controls implemented in this ECM and outlines the proposed controls, costs, savings, and payback periods. The calculations adjust the lighting power usage by the applicable percent savings for each area that includes lighting controls.

### Energy Savings Calculations:

$$\text{Energy Savings} = (\% \text{ Savings} \times \text{Controlled Light Energy (kWh/Yr)})$$

$$\text{Savings.} = \text{Energy Savings (kWh)} \times \text{Ave Elec Cost} \left( \frac{\$}{\text{kWh}} \right)$$



**Rebates and Incentives:**

From the **NJ Smart Start<sup>®</sup> Program Incentives Appendix**, the installation of a lighting control device warrants the following incentive:

Smart Start Incentive

$$= (\# \text{ Wall mount sensors} \times \$20 \text{ per sensor})$$

$$+ (\# \text{ Ceiling mount sensors} \times \$35 \text{ per sensor})$$

**Energy Savings Summary:**

<b>ECM #2 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$16,550
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$70
<b>Net Installation Cost (\$):</b>	\$16,480
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$2,974
<b>Total Yearly Savings (\$/Yr):</b>	\$2,974
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	5.5
<b>Simple Lifetime ROI</b>	170.7%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$44,610
<b>Internal Rate of Return (IRR)</b>	16%
<b>Net Present Value (NPV)</b>	\$19,023.42

### ECM #3: Install NEMA Premium® Efficiency Motors

#### Description:

The improved efficiency of the NEMA Premium® efficient motors is primarily due to better designs with use of better materials to reduce losses. Surprisingly, the electricity used to power a motor represents 95 % of its total lifetime operating cost. Because many motors operate continuously 24 hours a day, even small increases in efficiency can yield substantial energy and dollar savings.

The electric motors driving the hot water pumps are candidates for replacing with premium efficiency motors. These standard efficiency motors run considerable amount of time over a year.

This energy conservation measure replaces existing inefficient electric motors with NEMA Premium® efficiency motors. NEMA Premium® is the most efficient motor designation in the marketplace today.

IMPLEMENTATION SUMMARY					
EQMT ID	FUNCTION	MOTOR HP	HOURS OF OPERATION	EXISTING EFFICIENCY	NEMA PREMIUM EFFICIENCY
P-1	Hot Water Pump	10	2,745	89.5%	92.4%
P-2	Hot Water Pump	10	2,745	89.5%	92.4%
P-1A	Hot Water Pump	3	2,745	86.5%	89.5%
P-2A	Hot Water Pump	3	2,745	85.5%	89.5%

#### Energy Savings Calculations:

**Error! Bookmark not defined.**

$$\text{Electric usage, kWh} = \frac{\text{HP} \times \text{LF} \times 0.746 \times \text{Hours of Operation}}{\text{Motor Efficiency}}$$

where, HP = Motor Nameplate Horsepower Rating

LF = Load Factor

Motor Efficiency = Motor Nameplate Efficiency

$$\text{Electric Usage Savings, kWh} = \text{Electric Usage}_{\text{Existing}} - \text{Electric Usage}_{\text{Proposed}}$$

$$\text{Electric Usage Savings, kWh} = \text{Electric Usage}_{\text{Existing}} - \text{Electric Usage}_{\text{Proposed}}$$

$$\text{Electric cost savings} = \text{Electric Usage Savings} \times \text{Electric Rate} \left( \frac{\$}{\text{kWh}} \right)$$

The calculations were carried out and the results are tabulated in the table below:

<b>PREMIUM EFFICIENCY MOTOR CALCULATIONS</b>							
<b>EQMT ID</b>	<b>MOTOR HP</b>	<b>LOAD FACTOR</b>	<b>EXISTING EFFICIENCY</b>	<b>NEMA PREMIUM EFFICIENCY</b>	<b>POWER SAVINGS kW</b>	<b>ENERGY SAVINGS kWh</b>	<b>COST SAVINGS</b>
P-1	10	90%	89.5%	92.4%	0.24	650	\$105
P-2	10	90%	89.5%	92.4%	0.24	650	\$105
P-1A	3	90%	86.5%	89.5%	0.08	215	\$35
P-2A	3	90%	85.5%	89.5%	0.11	291	\$47
<b>TOTAL</b>					<b>0.7</b>	<b>1,805</b>	<b>\$291</b>

### Equipment Cost and Incentives

Below is a summary of SmartStart Building® incentives for premium efficiency motors:

<b>INCENTIVES</b>	
<b>HORSE POWER</b>	<b>NJ SMART START INCENTIVE</b>
5	\$60
7.5	\$90
10	\$100
15	\$115
20	\$125
25	\$130
30	\$150
40	\$180

The following table outlines the summary of motor replacement costs and incentives:

<b>MOTOR REPLACEMENT SUMMARY</b>						
<b>EQMT ID</b>	<b>MOTOR POWER HP</b>	<b>INSTALLED COST</b>	<b>SMART START INCENTIVE</b>	<b>NET COST</b>	<b>TOTAL SAVINGS</b>	<b>SIMPLE PAYBACK</b>
P-1	10	\$2,560	\$100	\$2,460	\$105	23.5
P-2	10	\$2,560	\$100	\$2,460	\$105	23.5
P-1A	3	\$1,049	\$60	\$989	\$35	28.5
P-2A	3	\$1,049	\$60	\$989	\$47	21.1
<b>TOTAL</b>		<b>\$7,218</b>	<b>\$320</b>	<b>\$6,898</b>	<b>\$291</b>	<b>23.7</b>

**Energy Savings Summary:**

<b>ECM #3 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$7,218
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$320
<b>Net Installation Cost (\$):</b>	\$6,898
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$290
<b>Total Yearly Savings (\$/Yr):</b>	\$290
<b>Estimated ECM Lifetime (Yr):</b>	18
<b>Simple Payback</b>	23.8
<b>Simple Lifetime ROI</b>	-24.3%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$5,220
<b>Internal Rate of Return (IRR)</b>	-3%
<b>Net Present Value (NPV)</b>	<b>(\$2,909.48)</b>

## ECM #4: AC Unit Upgrades

### Description:

The Media Center and Computer Room are cooled by split systems at Parsons Elementary School. The unit capacities range from 2 tons to 3 tons. Please refer to the **Major Equipment List Appendix** for further information about these units.

These units are in average condition though the current units in operation are not high efficiency units. These units are approximately twenty-three years old and have surpassed their ASHRAE service life of fifteen years.

These units can be replaced with new higher efficiency units. New split system units provide higher full load and part load efficiencies due to advances in inverter motor technologies, heat exchangers and higher efficiency refrigerants such as R410A which would be used in place of R22 that is currently used in the units.

This ECM includes one-for-one replacement of the older split system units with new higher efficiency systems which include new evaporator coils and refrigerant lines. It is recommended to fully evaluate the capacity needed for all new systems prior to moving forward with this ECM. A summary of the unit replacements for this ECM can be found in the table below:

IMPLEMENTATION SUMMARY					
ECM INPUTS	SERVICE FOR	NUMBER OF UNITS	COOLING CAPACITY, BTU/HR	TOTAL CAPACITY, TONS	REPLACE UNIT WITH
SS	Media Center	2	30,000	5.0	Carrier 24ANA1
SS	Computer Room	2	36,000	6.0	Carrier 24ANA1
<b>Total</b>		<b>4</b>	<b>66,000</b>	<b>11.0</b>	

The manufacturers used as the basis for the calculation is Carrier. The unit pricing and install cost were estimated based on current rates quotes and labor rates. The payback may change based on actual unit pricing and install costs if the ECM is implemented.

### Energy Savings Calculations:

#### Cooling Energy Savings:

Seasonal energy consumption of the air conditioners at the cooling mode is calculated with the equation below:

$$\text{Energy Savings, kWh} = \text{Cooling Capacity, } \frac{\text{BTU}}{\text{Hr}} \times \left( \frac{1}{\text{SEER}_{\text{Old}}} - \frac{1}{\text{SEER}_{\text{New}}} \right) \times \frac{\text{Operation Hours}}{1000 \frac{\text{W}}{\text{kWh}}}$$

$$\text{Demand Savings, kW} = \frac{\text{Energy Savings (kWh)}}{\text{Hours of Cooling}}$$

$$\text{Cooling Cost Savings} = \text{Energy Savings, kWh} \times \text{Cost of Electricity} \left( \frac{\$}{\text{kWh}} \right)$$

ENERGY SAVINGS CALCULATIONS							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS SEER	SPLIT UNITS SEER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
SS	30,000	2,000	10 SEER	19 SEER	2	5,684	2.8
SS	36,000	2,000	10 SEER	19 SEER	2	6,821	3.4
<b>Total</b>					4	12,505	6.3

### Project Cost, Incentives and Maintenance Savings

From the NJ Smart Start<sup>®</sup> Program appendix, the rebate are \$92 per ton for units below 5.4 tons & \$73 per ton for units ranging from 5.4 tons to 11.25 tons..

Summary of cost, savings and payback for this ECM is below.

COST & SAVINGS SUMMARY							
ECM INPUTS	INSTALLED COST	# OF UNITS	TOTAL COST	REBATES	NET COST	ENERGY SAVING	PAY BACK YEARS
SS	\$20,700	2	\$20,700	\$6,348	\$14,352	\$870	16.5
SS	\$13,800	2	\$13,800	\$368	\$13,432	\$1,044	12.9
<b>Total</b>	<b>\$34,500</b>	<b>4</b>	<b>\$34,500</b>	<b>\$7,314</b>	<b>\$27,186</b>	<b>\$1,913</b>	<b>14.2</b>

### Energy Savings Summary:

<b>ECM #4 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$34,500
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$7,314
<b>Net Installation Cost (\$):</b>	\$27,186
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$1,913
<b>Total Yearly Savings (\$/Yr):</b>	\$1,913
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	14.2
<b>Simple Lifetime ROI</b>	5.6%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$28,695
<b>Internal Rate of Return (IRR)</b>	1%
<b>Net Present Value (NPV)</b>	<b>(\$4,348.73)</b>

## ECM #5: Condensing Boiler Installation

### Description:

The existing boiler plant consists of two packaged boilers which are used as the primary source of heat for Parsons Elementary School. The existing boilers are well beyond the life expectancy of cast iron boilers and could be considered for replacement. With the increased efficiency of the condensing boilers, the savings can be substantial.

New condensing boilers could substantially improve the operating efficiency of the heating system of the building. Condensing boiler's peak efficiency tops out at 99% depending on return water temperature. Due to the operating conditions of the building, the annual average operating efficiency of the proposed condensing boiler is expected to be 92%. The existing boiler's efficiency is approximately 70%, which makes the condensing boilers a 22% increase in efficiency. This ECM is based on variable supply water temperature adjusted based on outdoor temperature.

This ECM includes installation of two condensing gas fired boilers to replace the existing Cleaver Brooks CB.810 packaged boiler. As a result of this ECM, the one existing CB.800 Cleaver Brooks boiler will remain as a backup boiler. The basis for this ECM is Aercos condensing boiler; model number BMK – 3.0. The new Aercos boilers will be able to handle the main hot water load while the existing Cleaver Brooks will act as backup for any additional load the system requires fulfilling.

### Energy Savings Calculations:

Existing Heating Natural Gas: 25,879 Therms

$$\text{Bldg Heat Required} = \text{Existing Nat Gas (Therms)} \times \text{Heating Eff.}(\%) \times \text{Fuel Heat Value} \left( \frac{\text{BTU}}{\text{Therm}} \right)$$

$$\text{Proposed Heating Gas Usage} = \frac{\text{Bldg Heat Required (BTU)}}{\text{Heating Eff.}(\%) \times \text{Fuel Heat Value} \left( \frac{\text{BTU}}{\text{Therm}} \right)}$$

$$\text{Energy Cost} = \text{Heating Gas Usage (Therms)} \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{Therm}} \right)$$



<b>CONDENSING BOILER CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	Existing Cast Iron Boilers	New Condensing Boilers	
<b>Existing Nat Gas (Therms)</b>	25,879	0	
<b>Boiler Efficiency (%)</b>	70%	92%	22%
<b>Nat Gas Heat Value (BTU/Therm)</b>	100,000	100,000	
<b>Equivalent Building Heat Usage (MMBTUs)</b>	1,812	1,812	
<b>Gas Cost (\$/Therm)</b>	0.95	0.95	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Natural Gas Usage (Therms)</b>	25,879	19,691	6,188
<b>Energy Cost (\$)</b>	\$24,585	\$18,706	\$5,879
<b>COMMENTS:</b>			

From the **NJ Smart Start Appendix**, the installation of new condensing boilers warrants the following incentive: \$1.00 per MBH.

**Energy Savings Summary:**

<b>ECM #5 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$190,878
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$6,000
<b>Net Installation Cost (\$):</b>	\$184,878
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$5,879
<b>Total Yearly Savings (\$/Yr):</b>	\$5,879
<b>Estimated ECM Lifetime (Yr):</b>	25
<b>Simple Payback</b>	31.4
<b>Simple Lifetime ROI</b>	-20.5%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$146,975
<b>Internal Rate of Return (IRR)</b>	-2%
<b>Net Present Value (NPV)</b>	<b>(\$82,505.65)</b>

## ECM #6: Set Computers to Automatic Stand-by or Hibernate Modes

### Description:

During the survey, it was noticed that the majority of the computers were left at ON position with the monitors at Screen Saver or OFF positions.

Many personal computers (PC) came equipped with automatic Sleep Mode or Hibernate (power down) mode features. Normally computers boot up from Sleep Mode or Hibernate mode much faster than powering up from Shut Down position.

Based on an independent study by the U.S. Department of Energy, Energy star® rated computers use approximately 70% less power during Sleep Mode. It is recommended to set up the PCs at this facility to switch into Sleep Mode after a short period of inactivity and Hibernate mode after a long period of inactivity.

This ECM includes configuring the computers in the classrooms and the offices such that they automatically switch into:

- Sleep Mode after 15 minutes of inactivity
- Hibernate after 60 minutes of inactivity

The inactivity times above can be adjusted based on experience or preference. Even though this ECM can be implemented easily in house, the calculations assume an independent computer technician performing the task at a typical market rate.

### Energy Savings Calculations:

No. of Computers:	147
Operating Weeks per Yr:	42
Estimated percentage of computers left ON overnight:	75%

$$\text{Electric Usage} = \frac{\# \text{ of Computers} \times \text{Computer Power (W)} \times \text{Operation (Hrs)}}{1000 \left( \frac{\text{W}}{\text{KW}} \right)}$$

$$\text{Energy Cost} = \text{Electric Usage (kWh)} \times \text{Ave Elec Cost} \left( \frac{\$}{\text{kWh}} \right)$$

The cost of configuring the computers to automatically sleep or hibernate is based on 10 minutes per computer per technician at an hourly rate indicated below.

Implementation Costs: = # Computers X Configuration Time X Cost per Hour  
 = 147 Monitors X 10 Minutes/Computer X \$100 per Hour  
 = \$2450

<b>AUTOMATIC SLEEP OR HIBERNATE MODES FOR COMPUTERS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	Manual Operation	Auto Power Save	-
<b># of Computers</b>	147	147	-
<b>% Computers left ON</b>	75%	75%	-
<b>Power when left ON (Watt)</b>	50	50	-
<b>Power at Stand-by (Watt)</b>	5	5	-
<b>Power at Hibernate (Watt)</b>	4	4	-
<b>Power when OFF (Watt)</b>	0	0	-
<b>Operating Weeks per Yr</b>	42	42	-
<b>Operating Hours per Week</b>	168	168	-
<b>Hours/Wk Computers ON</b>	120	20	-
<b>Hours/Wk at Sleep Mode</b>	0	20	-
<b>Hours/Wk at Hibernate Mode</b>	0	80	-
<b>Hours/Wk at Power Down</b>	48	48	-
<b>Elec Cost (\$/kWh)</b>	0.153	0.153	-
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Usage (kWh)</b>	27,783	5,094	22,689
<b>Energy Cost (\$)</b>	\$4,251	\$779	\$3,471
<b>COMMENTS:</b>	Calculation assumes computers currently run throughout work week and are shut down over the weekend.		

**Energy Savings Summary:**

<b>ECM #6 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$2,450
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$0
<b>Net Installation Cost (\$):</b>	\$2,450
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$3,471
<b>Total Yearly Savings (\$/Yr):</b>	\$3,471
<b>Estimated ECM Lifetime (Yr):</b>	15
<b>Simple Payback</b>	0.7
<b>Simple Lifetime ROI</b>	2025.1%
<b>Simple Lifetime Maintenance Savings</b>	0
<b>Simple Lifetime Savings</b>	\$52,065
<b>Internal Rate of Return (IRR)</b>	142%
<b>Net Present Value (NPV)</b>	\$38,986.57

## ECM #7: High Efficiency Gas Hot Water Heater

### Description:

The Parsons Elementary School is supplied domestic hot water by an A.O. Smith water heater which provides 234 MBH of heat. This heater feeds a 940 gallon storage tank. This heater has surpassed its ASHRAE service life of 12 years and should be replaced with a new high efficiency, gas fired model.

This ECM will replace the one gas domestic water heater with one 97% thermal efficient Bradford White eF Series Natural Gas fired 250 MBH and 100 gallons of storage domestic water heater to be used in conjunction with the existing storage.

### Energy Savings Calculations:

<b>DOM. HOT WATER HEATER CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	Existing Gas Hot Water Heater	High Efficiency Heater	
<b>Building Type</b>	Education		
<b>Building Square-foot</b>	84,079	84,079	
<b>Domestic Water Usage, kBtu</b>	437,210.80	437,210.80	
<b>DHW Heating Fuel Type</b>	Gas	Gas	
<b>Heating Efficiency</b>	78%	97%	19%
<b>Total Usage (kBtu)</b>	560,527	450,733	109,794
<b>Nat Gas Cost (\$/Therm)</b>	\$ 0.950	\$ 0.950	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Natural Gas Usage (Therms)</b>	5,605	4,507	1,098
<b>Energy Cost (\$)</b>	\$5,325	\$4,282	\$1,043
<b>COMMENTS:</b>	Savings are based on Energy Information Administration Commercial Building Energy Consumption Survey 2003 Information		

Energy Density for “Education” type building = 5.2 kBtu / SF / year

$$DHW \text{ Heat Usage} = \text{Energy Density} \left( \frac{kBtu \text{ yr}}{SF} \right) \times \text{Building Square Footage (SF)}$$

$$DHW \text{ Total Usage} = \frac{\text{Dom HW Heat Cons. (Btu)}}{\text{Heating Eff. (\%)} \times \text{Fuel Heat Value} \left( \frac{BTU}{\text{Fuel Unit}} \right)}$$

$$\text{Energy Cost} = \text{Heating Fuel Usage (Fuel Units)} \times \text{Ave Fuel Cost} \left( \frac{\$}{\text{Fuel Unit}} \right)$$

**Energy Savings Summary:**

<b>ECM #7 - ENERGY SAVINGS SUMMARY</b>	
<b>Installation Cost (\$):</b>	\$14,000
<b>NJ Smart Start Equipment Incentive (\$):</b>	\$500
<b>Net Installation Cost (\$):</b>	\$13,500
<b>Maintenance Savings (\$/Yr):</b>	\$0
<b>Energy Savings (\$/Yr):</b>	\$1,043
<b>Total Yearly Savings (\$/Yr):</b>	\$1,043
<b>Estimated ECM Lifetime (Yr):</b>	12
<b>Simple Payback</b>	12.9
<b>Simple Lifetime ROI</b>	-7.3%
<b>Simple Lifetime Maintenance Savings</b>	\$0
<b>Simple Lifetime Savings</b>	\$12,516
<b>Internal Rate of Return (IRR)</b>	-1%
<b>Net Present Value (NPV)</b>	(\$3,117.97)

**REM #1: 125.96 kW Solar System****Description:**

Parsons Elementary School has available roof and parking lot space that could accommodate a significant amount of solar generation. Based on the available areas a 125.96 KW DC solar array could be installed, assuming the existing roof structure is capable of supporting an array. The array will produce approximately 148,571 kilowatt-hours annually that will reduce the overall electric usage of the facility by 25.77%.

**Energy Savings Calculations:**

See **Renewable / Distributed Energy Measures Calculations Appendix** for detailed financial summary and proposed solar layout areas. Financial results in table below are based on 100% financing of the system over a fifteen year period.

**Energy Savings Summary:**

<b>REM #1 - ENERGY SAVINGS SUMMARY</b>	
<b>System Size (KW<sub>DC</sub>):</b>	125.96
<b>Electric Generation (KWH/Yr):</b>	148,571
<b>Installation Cost (\$):</b>	\$794,424
<b>SREC Revenue (\$/Yr):</b>	\$28,390
<b>Energy Savings (\$/Yr):</b>	\$22,731
<b>Total Yearly Savings (\$/Yr):</b>	\$51,121
<b>ECM Analysis Period (Yr):</b>	15
<b>Simple Payback (Yrs):</b>	15.5
<b>Analysis Period Electric Savings (\$):</b>	\$422,779
<b>Analysis Period SREC Revenue (\$):</b>	\$411,258
<b>Net Present Value (NPV)</b>	<b>(\$284,952.58)</b>



## V. ADDITIONAL RECOMMENDATIONS

The following recommendations include no cost/low cost measures, Operation & Maintenance (O&M) items, and water conservation measures with attractive paybacks. These measures are not eligible for the Smart Start Buildings incentives from the office of Clean Energy but save energy none the less.

- A. Chemically clean the condenser and evaporator coils periodically to optimize efficiency. Poorly maintained heat transfer surfaces can reduce efficiency 5-10%.
- B. Maintain all weather stripping on windows and doors.
- C. Clean all light fixtures to maximize light output.
- D. Provide more frequent air filter changes to decrease overall system power usage and maintain better IAQ.
- E. Turn off computers when not in use. Ensure computers are not running in screen saver mode which saves the monitor screen not energy.
- F. Ensure outside air dampers are functioning properly and only open during occupied mode.

**APPENDIX A**

**ECM COST & SAVINGS BREAKDOWN**

CONCORD ENGINEERING GROUP

North Brunswick Township Public Schools - Parsons Elementary School

ECM ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
ECM NO.	DESCRIPTION	INSTALLATION COST				YEARLY SAVINGS			ECM LIFETIME	LIFETIME ENERGY SAVINGS	LIFETIME MAINTENANCE SAVINGS	LIFETIME ROI	SIMPLE PAYBACK	INTERNAL RATE OF RETURN	NET PRESENT VALUE (NPV)
		MATERIAL	LABOR	REBATES, INCENTIVES	NET INSTALLATION COST	ENERGY	MAINT. / SREC	TOTAL		(Yearly Saving * ECM Lifetime)	(Yearly Maint Saving * ECM Lifetime)	(Lifetime Savings - Net Cost) / (Net Cost)	(Net cost / Yearly Savings)	$\sum_{n=0}^N \frac{C_n}{[1 + DR]^n}$	$\sum_{n=0}^N \frac{C_n}{[1 + DR]^n}$
		(\$)	(\$)	(\$)	(\$)	(\$/yr)	(\$/yr)	(\$/yr)		(Yr)	(\$)	(\$)	(%)	(Yr)	(\$)
ECM #1	Lighting Upgrade General	\$1,080	\$2,480	\$0	\$3,560	\$377	\$0	\$377	15	\$5,655	\$0	58.8%	9.4	6.43%	\$940.60
ECM #2	Lighting Controls Upgrade	\$13,950	\$2,600	\$70	\$16,480	\$2,974	\$0	\$2,974	15	\$44,610	\$0	170.7%	5.5	16.13%	\$19,023.42
ECM #3	NEMA Premium Motor Replacements	\$4,254	\$2,964	\$320	\$6,898	\$290	\$0	\$290	18	\$5,220	\$0	-24.3%	23.8	-2.78%	(\$2,909.48)
ECM #4	AC Unit Upgrades	\$17,250	\$17,250	\$7,314	\$27,186	\$1,913	\$0	\$1,913	15	\$28,695	\$0	5.6%	14.2	0.68%	(\$4,348.73)
ECM #5	Boiler Upgrade	\$114,861	\$76,017	\$6,000	\$184,878	\$5,879	\$0	\$5,879	25	\$146,975	\$0	-20.5%	31.4	-1.69%	(\$82,505.65)
ECM #6	Computer Standby or Hibernate	\$0	\$2,450	\$0	\$2,450	\$3,471	\$0	\$3,471	15	\$52,065	\$0	2025.1%	0.7	141.67%	\$38,986.57
ECM #7	Domestic Hot Water Heater Upgrade	\$10,000	\$4,000	\$500	\$13,500	\$1,043	\$0	\$1,043	12	\$12,516	\$0	-7.3%	12.9	-1.15%	(\$3,117.97)
REM RENEWABLE ENERGY AND FINANCIAL COSTS AND SAVINGS SUMMARY															
REM #1	125.96 kW Solar Array	\$794,424	\$0	\$0	\$794,424	\$22,731	\$28,390	\$51,121	15	\$766,815	\$425,850	-3.5%	15.5	-1.88%	(\$284,953.82)

- Notes:
- 1) The variable Cn in the formulas for Internal Rate of Return and Net Present Value stands for the cash flow during each period.
  - 2) The variable DR in the NPV equation stands for Discount Rate
  - 3) For NPV and IRR calculations: From n=0 to N periods where N is the lifetime of ECM and Cn is the cash flow during each period.

**APPENDIX B**

# Concord Engineering Group, Inc.

520 BURNT MILL ROAD  
VOORHEES, NEW JERSEY 08043  
PHONE: (856) 427-0200  
FAX: (856) 427-6508



## SmartStart Building Incentives

The NJ SmartStart Buildings Program offers financial incentives on a wide variety of building system equipment. The incentives were developed to help offset the initial cost of energy-efficient equipment. The following tables show the current available incentives as of February 15, 2011:

### **Electric Chillers**

Water-Cooled Chillers	\$12 - \$170 per ton
Air-Cooled Chillers	\$8 - \$52 per ton

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Cooling**

Gas Absorption Chillers	\$185 - \$400 per ton
Gas Engine-Driven Chillers	Calculated through custom measure path)

### **Desiccant Systems**

\$1.00 per cfm – gas or electric
----------------------------------

### **Electric Unitary HVAC**

Unitary AC and Split Systems	\$73 - \$92 per ton
Air-to-Air Heat Pumps	\$73 - \$92 per ton
Water-Source Heat Pumps	\$81 per ton
Packaged Terminal AC & HP	\$65 per ton
Central DX AC Systems	\$40- \$72 per ton
Dual Enthalpy Economizer Controls	\$250
Occupancy Controlled Thermostat (Hospitality & Institutional Facility)	\$75 per thermostat

Energy Efficiency must comply with ASHRAE 90.1-2007

### **Gas Heating**

Gas Fired Boilers < 300 MBH	\$300 per unit
Gas Fired Boilers ≥ 300 - 1500 MBH	\$1.75 per MBH
Gas Fired Boilers ≥1500 - ≤ 4000 MBH	\$1.00 per MBH
Gas Fired Boilers > 4000 MBH	(Calculated through Custom Measure Path)
Gas Furnaces	\$300 - \$400 per unit, AFUE ≥ 92%

### Ground Source Heat Pumps

Closed Loop	\$450 per ton, EER $\geq$ 16
	\$600 per ton, EER $\geq$ 18
	\$750 per ton, EER $\geq$ 20

Energy Efficiency must comply with ASHRAE 90.1-2007

### Variable Frequency Drives

Variable Air Volume	\$65 - \$155 per hp
Chilled-Water Pumps	\$60 per VFD rated hp
Compressors	\$5,250 to \$12,500 per drive
Cooling Towers $\geq$ 10 hp	\$60 per VFD rated hp

### Natural Gas Water Heating

Gas Water Heaters $\leq$ 50 gallons, 0.67 energy factor or better	\$50 per unit
Gas-Fired Water Heaters $>$ 50 gallons	\$1.00 - \$2.00 per MBH
Gas-Fired Booster Water Heaters	\$17 - \$35 per MBH
Gas Fired Tankless Water Heaters	\$300 per unit

### Prescriptive Lighting

Retro fit of T12 to T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities	\$10 per fixture (1-4 lamps)
Replacement of T12 with new T-5 or T-8 Lamps w/Electronic Ballast in Existing Facilities	\$25 per fixture (1-4 lamps)
Replacement of incandescent with screw-in PAR 38 or PAR 30 (CFL) bulb	\$7 per bulb
T-8 reduced Wattage (28w/25w 4', 1-4 lamps) Lamp & ballast replacement	\$10 per fixture
Hard-Wired Compact Fluorescent	\$25 - \$30 per fixture
Metal Halide w/Pulse Start Including Parking Lot	\$25 per fixture
T-5 and T-8 High Bay Fixtures	\$16 - \$200 per fixture
HID $\geq$ 100w Retrofit with induction lamp, power coupler and generator (must be 30% less watts/fixture than HID system)	\$50 per fixture
HID $\geq$ 100w Replacement with new HID $\geq$ 100w	\$70 per fixture

**Prescriptive Lighting - LED**

LED New Exit Sign Fixture Existing Facility < 75 kw Existing Facility > 75 kw	\$20 per fixture \$10 per fixture
LED Display Case Lighting	\$30 per display case
LED Shelf-Mtd. Display & Task Lights	\$15 per linear foot
LED Portable Desk Lamp	\$20 per fixture
LED Wall-wash Lights	\$30 per fixture
LED Recessed Down Lights	\$35 per fixture
LED Outdoor Pole/Arm-Mounted Area and Roadway Luminaries	\$175 per fixture
LED Outdoor Pole/Arm-Mounted Decorative Luminaries	\$175 per fixture
LED Outdoor Wall-Mounted Area Luminaries	\$100 per fixture
LED Parking Garage Luminaries	\$100 per fixture
LED Track or Mono-Point Directional Lighting Fixtures	\$50 per fixture
LED High-Bay and Low-Bay Fixtures for Commercial & Industrial Bldgs.	\$150 per fixture
LED High-Bay-Aisle Lighting	\$150 per fixture
LED Bollard Fixtures	\$50 per fixture
LED Linear Panels (2x2 Troffers only)	\$100 per fixture
LED Fuel Pump Canopy	\$100 per fixture
LED Refrigerator/Freezer case lighting replacement of fluorescent in medium and low temperature display case	\$42 per 5 foot \$65 per 6 foot

### Lighting Controls – Occupancy Sensors

Wall Mounted	\$20 per control
Remote Mounted	\$35 per control
Daylight Dimmers	\$25 per fixture
Occupancy Controlled hi-low Fluorescent Controls	\$25 per fixture controlled

### Lighting Controls – HID or Fluorescent Hi-Bay Controls

Occupancy hi-low	\$75 per fixture controlled
Daylight Dimming	\$75 per fixture controlled
Daylight Dimming - office	\$50 per fixture controlled

### Premium Motors

Three-Phase Motors	\$45 - \$700 per motor
Fractional HP Motors Electronic Communicated Motors (replacing shaded pole motors in refrigerator/freezer cases)	\$40 per electronic communicated motor

### Other Equipment Incentives

Performance Lighting	\$1.00 per watt per SF below program incentive threshold, currently 5% more energy efficient than ASHRAE 90.1-2007 for New Construction and Complete Renovation
Custom Electric and Gas Equipment Incentives	not prescriptive
Custom Measures	\$0.16 KWh and \$1.60/Therm of 1st year savings, or a buy down to a 1 year payback on estimated savings. Minimum required savings of 75,000 KWh or 1,500 Therms and a IRR of at least 10%.
Multi Measures Bonus	15%



**APPENDIX C**



# STATEMENT OF ENERGY PERFORMANCE

## North Brunswick BOE - Parsons Elementary School

Building ID: 3316315  
 For 12-month Period Ending: July 31, 2012<sup>1</sup>  
 Date SEP becomes ineligible: N/A

Date SEP Generated: November 07, 2012

### Facility

North Brunswick BOE - Parsons  
 Elementary School  
 899 Hollywood Street  
 North Brunswick, NJ 08902

### Facility Owner

North Brunswick Township Board of  
 Education  
 300 Old Georges Road  
 North Brunswick, NJ 08902

### Primary Contact for this Facility

Susan Irons  
 300 Old Georges Road  
 North Brunswick, NJ 08902

Year Built: 1965

Gross Floor Area (ft<sup>2</sup>): 84,079

Energy Performance Rating<sup>2</sup> (1-100) 68

### Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu)	2,004,216
Natural Gas (kBtu) <sup>4</sup>	2,885,030
Total Energy (kBtu)	4,889,246

### Energy Intensity<sup>4</sup>

Site (kBtu/ft <sup>2</sup> /yr)	58
Source (kBtu/ft <sup>2</sup> /yr)	116

### Emissions (based on site energy use)

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	437
---	-----

### Electric Distribution Utility

Public Service Electric & Gas Co

### National Median Comparison

National Median Site EUI	69
National Median Source EUI	138
% Difference from National Median Source EUI	-16%
Building Type	K-12 School

### Meets Industry Standards<sup>5</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional

Based on the conditions observed at the  
 time of my visit to this building, I certify that  
 the information contained within this  
 statement is accurate.

### Certifying Professional

Michael Fischette  
 520 South Burnt Mill Road  
 Voorhees, NJ 08043

#### Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Values represent energy intensity, annualized to a 12-month period.
5. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) or a Registered Architect (RA) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE or RA in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	North Brunswick BOE - Parsons Elementary School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	899 Hollywood Street, North Brunswick, NJ 08902	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of a hospital, k-12 school, hotel and senior care facility) nor can they be submitted as representing only a portion of a building.		<input type="checkbox"/>
Parsons Elementary School (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	84,079 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	147	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	0	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	100 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	10(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Electric & Gas Co

Fuel Type: Electricity		
<b>Meter: electric (kWh (thousand Watt-hours))</b> <b>Space(s): Entire Facility</b> <b>Generation Method: Grid Purchase</b>		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
06/23/2012	07/22/2012	30,900.00
05/23/2012	06/22/2012	45,000.00
04/23/2012	05/22/2012	51,000.00
03/23/2012	04/22/2012	45,000.00
02/23/2012	03/22/2012	54,300.00
01/23/2012	02/22/2012	58,500.00
12/23/2011	01/22/2012	56,100.00
11/23/2011	12/22/2011	57,000.00
10/23/2011	11/22/2011	50,100.00
09/23/2011	10/22/2011	49,200.00
08/23/2011	09/22/2011	47,100.00
<b>electric Consumption (kWh (thousand Watt-hours))</b>		<b>544,200.00</b>
<b>electric Consumption (kBtu (thousand Btu))</b>		<b>1,856,810.40</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>1,856,810.40</b>
<b>Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?</b>		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: gas (therms)</b> <b>Space(s): Entire Facility</b>		
Start Date	End Date	Energy Use (therms)
06/23/2012	07/22/2012	81.00
05/23/2012	06/22/2012	138.00
04/23/2012	05/22/2012	1,116.00
03/23/2012	04/22/2012	2,153.00
02/23/2012	03/22/2012	3,370.00
01/23/2012	02/22/2012	5,077.00
12/23/2011	01/22/2012	5,713.00
11/23/2011	12/22/2011	4,833.00
10/23/2011	11/22/2011	3,384.00
09/23/2011	10/22/2011	1,127.00
08/23/2011	09/22/2011	172.00

gas Consumption (therms)	27,164.00
gas Consumption (kBtu (thousand Btu))	2,716,400.00
Total Natural Gas Consumption (kBtu (thousand Btu))	2,716,400.00
Is this the total Natural Gas consumption at this building including all Natural Gas meters?	<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same PE or RA that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

## Facility

North Brunswick BOE - Parsons  
Elementary School  
899 Hollywood Street  
North Brunswick, NJ 08902

## Facility Owner

North Brunswick Township Board of  
Education  
300 Old Georges Road  
North Brunswick, NJ 08902

## Primary Contact for this Facility

Susan Irons  
300 Old Georges Road  
North Brunswick, NJ 08902

## General Information

North Brunswick BOE - Parsons Elementary School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	84,079
Year Built	1965
For 12-month Evaluation Period Ending Date:	July 31, 2012

## Facility Space Use Summary

Parsons Elementary School	
Space Type	K-12 School
Gross Floor Area (ft <sup>2</sup> )	84,079
Open Weekends?	No
Number of PCs	147
Number of walk-in refrigeration/freezer units	0
Presence of cooking facilities	Yes
Percent Cooled	90
Percent Heated	100
Months °	10
High School?	No
School District °	North Brunswick Twp

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 07/31/2012)	Baseline (Ending Date 07/31/2012)	Rating of 75	Target	National Median
Energy Performance Rating	68	68	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	58	58	54	N/A	69
Source (kBtu/ft <sup>2</sup> )	116	116	108	N/A	138
Energy Cost					
\$/year	N/A	N/A	N/A	N/A	N/A
\$/ft <sup>2</sup> /year	N/A	N/A	N/A	N/A	N/A
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	437	437	408	N/A	522
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	5	5	5	N/A	6

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Median column presents energy performance data your building would have if your building had a median rating of 50.

### Notes:

- o - This attribute is optional.
- d - A default value has been supplied by Portfolio Manager.


# Statement of Energy Performance

## 2012

North Brunswick BOE - Parsons Elementary School  
899 Hollywood Street  
North Brunswick, NJ 08902

Portfolio Manager Building ID: 3316315

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).



This building uses 116 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending July 2012

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification





**APPENDIX D**

## MAJOR EQUIPMENT LIST

### Concord Engineering Group

#### Parsons Elementary School

### AC Units

Tag			
<b>Unit Type</b>	Condensing Unit	Condensing Unit for Heat Pump	Condensing Unit for Heat Pump
<b>Qty</b>	23	1	1
<b>Location</b>	Roof	Roof	Roof
<b>Area Served</b>	Classroom UVs	Office	Classroom
<b>Manufacturer</b>	Ducane	Sanyo	Sanyo
<b>Model #</b>	2AC13B36P-1A	CH1232	CH2432
<b>Serial #</b>	-	0069013	0017313
<b>Cooling Type</b>	DX, R-22	DX, R-22	DX, R-22
<b>Cooling Capacity (Tons)</b>	3 Tons	1 Ton	2 Tons
<b>Cooling Efficiency (SEER/EER)</b>	13 SEER	10 SEER	10 SEER
<b>Heating Type</b>	N/A	Electric	Electric
<b>Heating Input (MBH)</b>	N/A	13	25
<b>Efficiency</b>	N/A	-	-
<b>Fuel</b>	N/A	Electricity	Electricity
<b>Approx Age</b>	6	11	11
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	9	4	4
<b>Comments</b>	Typical Condensing Unit for Classroom Unit Ventilators		

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

## AC Units

<b>Tag</b>			
<b>Unit Type</b>	Condensing Unit	Condensing Unit	Condensing Unit
<b>Qty</b>	1	1	1
<b>Location</b>	Roof	Roof	Roof
<b>Area Served</b>	Classroom	Office	Office
<b>Manufacturer</b>	Rheem	Airedale	EMI
<b>Model #</b>	10AJB18A01	SCC09DMA0A0A0AA 0A	S1CA9000D00
<b>Serial #</b>	6931T270504042	1-03-F-3567-26	1-08-C-7541-12
<b>Cooling Type</b>	DX, R-22	DX, R-22	DX, R-22
<b>Cooling Capacity (Tons)</b>	1.5 Tons	.75 Tons	.75 Tons
<b>Cooling Efficiency (SEER/EER)</b>	-	-	-
<b>Heating Type</b>	N/A	N/A	N/A
<b>Heating Input (MBH)</b>	N/A	N/A	N/A
<b>Efficiency</b>	N/A	N/A	N/A
<b>Fuel</b>	N/A	N/A	N/A
<b>Approx Age</b>	7	9	4
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	8	6	11
<b>Comments</b>			

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

## AC Units

<b>Tag</b>			
<b>Unit Type</b>	Condensing Unit	Condensing Unit	Condensing Unit
<b>Qty</b>	2	2	1
<b>Location</b>	Roof	Roof	Roof
<b>Area Served</b>	Media Center	Computer Room	Library
<b>Manufacturer</b>	Trane	Trane	Rheem
<b>Model #</b>	TTD730B100A1	TTA036A300A0	RAKA-018JAZ
<b>Serial #</b>	D14228873	D17268320	5881F300312877
<b>Cooling Type</b>	DX, R-22	DX, R-22	DX, R-22
<b>Cooling Capacity (Tons)</b>	-	3 Tons	1.5 Tons
<b>Cooling Efficiency (SEER/EER)</b>	-	10 SEER	10 SEER
<b>Heating Type</b>	N/A	N/A	N/A
<b>Heating Input (MBH)</b>	N/A	N/A	N/A
<b>Efficiency</b>	N/A	N/A	N/A
<b>Fuel</b>	N/A	N/A	N/A
<b>Approx Age</b>	23	23	9
<b>ASHRAE Service Life</b>	15	15	15
<b>Remaining Life</b>	(8)	(8)	6
<b>Comments</b>			

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

## AC Units

<b>Tag</b>		
<b>Unit Type</b>	Packaged Unit	Packaged Unit
<b>Qty</b>	2	1
<b>Location</b>	Roof	New Wing Roof
<b>Area Served</b>	Offices	New Wing Classrooms and corridors
<b>Manufacturer</b>	ArcoAire	Trane
<b>Model #</b>	PAF024K000A	SLHFF75E4A77
<b>Serial #</b>	L9920 61826	CO7K10854
<b>Cooling Type</b>	DX, R-22	DX, R-22
<b>Cooling Capacity (Tons)</b>	2 Tons	80 Tons
<b>Cooling Efficiency (SEER/EER)</b>	-	9.5 EER
<b>Heating Type</b>	N/A	Hot Water
<b>Heating Input (MBH)</b>	N/A	-
<b>Efficiency</b>	N/A	-
<b>Fuel</b>	N/A	N/A
<b>Approx Age</b>	13	6
<b>ASHRAE Service Life</b>	15	15
<b>Remaining Life</b>	2	9
<b>Comments</b>		

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

# MAJOR EQUIPMENT LIST

## Concord Engineering Group

### Parsons Elementary School

#### Boilers

Tag	B-1	B-2	
Unit Type	Packaged Boiler	Packaged Boiler	
Qty	1	1	
Location	Boiler Room	Boiler Room	
Area Served	Building Heat	Building Heat	
Manufacturer	Cleaver Brooks	Cleaver Brooks	
Model #	CB.800-125	CB.810-125	
Serial #	L-65844	L36812	
Input Capacity (Btu/Hr)	5,230,000	5,230,000	
Rated Output Capacity (Btu/Hr)	-	-	
Approx. Efficiency %	-	-	
Fuel	Natural Gas	Natural Gas	
Approx Age	34	47	
ASHRAE Service Life	25	25	
Remaining Life	(9)	(22)	
Comments			

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

# MAJOR EQUIPMENT LIST

**Concord Engineering Group**

**Parsons Elementary School**

## Domestic Water Heaters

<b>Tag</b>			
<b>Unit Type</b>	Low Pressure Boiler		
<b>Qty</b>	1		
<b>Location</b>	Boiler Room		
<b>Area Served</b>	Building Domestic Hot Water		
<b>Manufacturer</b>	A.O. Smith		
<b>Model #</b>	HW 300 892		
<b>Serial #</b>	892 D 94 23933		
<b>Size (Gallons)</b>	-		
<b>Input Capacity (MBH/KW)</b>	300 MBH		
<b>Recovery (Gal/Hr)</b>	-		
<b>Efficiency %</b>	78%		
<b>Fuel</b>	Natural Gas		
<b>Approx Age</b>	18		
<b>ASHRAE Service Life</b>	12		
<b>Remaining Life</b>	(6)		
<b>Comments</b>			

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available

# MAJOR EQUIPMENT LIST

## Concord Engineering Group

### Parsons Elementary School

#### Pumps

<b>Tag</b>	<b>P1</b>	<b>P2</b>	<b>P1A</b>
<b>Unit Type</b>	End Suction	End Suction	End Suction
<b>Qty</b>	1	1	1
<b>Location</b>	Boiler Room	Boiler Room	Boiler Room
<b>Area Served</b>	Building Heat	Building Heat	Building Heat
<b>Manufacturer</b>	Bell and Gossett	Bell and Gossett	Bell and Gossett
<b>Model #</b>	K70	K70	
<b>Serial #</b>	-	-	-
<b>Horse Power</b>	10	10	3
<b>Flow</b>	180 GPM	180 GPM	
<b>Motor Info</b>	Marathon	Marathon	-
<b>Electrical Power</b>	200V / 3 Ph	200V / 3 Ph	208V / 3 Ph
<b>RPM</b>	1750	1750	1750
<b>Motor Efficiency %</b>	89.5%	89.5%	-
<b>Approx Age</b>	7	7	-
<b>ASHRAE Service Life</b>	20	20	20
<b>Remaining Life</b>	13	13	-
<b>Comments</b>			

**Note:**

"N/A" = Not Applicable.

"-" = Info Not Available



**Pumps**

<b>Tag</b>	<b>P2A</b>		
<b>Unit Type</b>	End Suction		
<b>Qty</b>	1		
<b>Location</b>	Boiler Room		
<b>Area Served</b>	Building Heat		
<b>Manufacturer</b>	Bell and Gossett		
<b>Model #</b>	1510		
<b>Serial #</b>	-		
<b>Horse Power</b>	3		
<b>Flow</b>	-		
<b>Motor Info</b>	A.O. Smith Century		
<b>Electrical Power</b>	200V / 3 Ph		
<b>RPM</b>	1740		
<b>Motor Efficiency %</b>	85.5%		
<b>Approx Age</b>	11		
<b>ASHRAE Service Life</b>	20		
<b>Remaining Life</b>	9		
<b>Comments</b>			

**Note:**

"N/A" = Not Applicable.

"- " = Info Not Available

**APPENDIX E**

CEG Project #: 9C12053  
 Facility Name: Parsons Elementary School  
 Address: 899 Hollowood Street  
 City, State, Zip: North Brunswick, NJ 08902

Fixture Reference #	Location	Average Burn Hours	Description	Existing Fixtures					Proposed Fixtures Retrofit					Retrofit Energy Savings					Lighting Retrofit Costs					Proposed Lighting Controls					
				Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Energy Savings, kW	Energy Savings, kWh	Energy Savings, \$	Material	Total Labor	Total All	Retrob Estimate	Simple Payback	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$
221.21	Boy's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	62	3	0.19	484	Existing to Remain	Existing to Remain	2	62	0	0.19	484	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mnt.	1	20.0%	97	\$15
221.21	Girl's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	62	3	0.19	484	Existing to Remain	Existing to Remain	2	62	0	0.19	484	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mnt.	1	20.0%	97	\$15
651	Custodial Closet	2000	*Industrial* Reflector, 26w CFL	1	26	1	0.03	52	Existing to Remain	Existing to Remain	1	26	0	0.03	52	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
242.11	Room 141 Office	2600	2x4, 4 Lamp, 32w TR, Elect. Ballast, Surface Mnt., Prismatic Lens	4	107	3	0.32	835	Existing to Remain	Existing to Remain	4	107	0	0.32	835	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mnt.	1	20.0%	167	\$26
242.11	Classroom 140	2600	2x4, 4 Lamp, 32w TR, Elect. Ballast, Surface Mnt., Prismatic Lens	4	107	12	1.28	3,338	Existing to Remain	Existing to Remain	4	107	0	1.28	3,338	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	668	\$102
232.22	Faculty Room	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Parabolic Lens	3	86	10	0.86	2,236	Existing to Remain	Existing to Remain	3	86	0	0.86	2,236	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
247.21	Boy's Restroom	2600	2x2, 4 Lamp, 17w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	4	68	2	0.14	354	Existing to Remain	Existing to Remain	4	68	0	0.14	354	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
222.21	Boy's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	62	1	0.06	161	Existing to Remain	Existing to Remain	2	62	0	0.06	161	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
247.21	Girl's Restroom	2600	2x2, 4 Lamp, 17w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	4	68	2	0.14	354	Existing to Remain	Existing to Remain	4	68	0	0.14	354	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
222.21	Girl's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	62	1	0.06	161	Existing to Remain	Existing to Remain	2	62	0	0.06	161	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
651	Custodial Closet	2000	*Industrial* Reflector, 26w CFL	1	26	1	0.03	52	Existing to Remain	Existing to Remain	1	26	0	0.03	52	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
651	Stage	2600	*Industrial* Reflector, 26w CFL	1	26	8	0.21	541	Existing to Remain	Existing to Remain	1	26	0	0.21	541	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.21	Boy's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.21	Girl's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
232.22	PE Office	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Parabolic Lens	3	86	3	0.26	671	Existing to Remain	Existing to Remain	3	86	0	0.26	671	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
232.22	Classroom 230	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Parabolic Lens	3	86	9	0.77	2,012	Existing to Remain	Existing to Remain	3	86	0	0.77	2,012	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
222.21	Storage 204	1200	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	62	1	0.06	74	Existing to Remain	Existing to Remain	2	62	0	0.06	74	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Faculty Restroom	1200	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Wallwasher	2	62	4	0.25	298	Existing to Remain	Existing to Remain	2	62	0	0.25	298	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 201	2600	1x4, 3 Lamp, 32w TR, Elect. Ballast, Pendant Mnt., Direct/Indirect	3	86	24	2.06	5,366	Existing to Remain	Existing to Remain	3	86	0	2.06	5,366	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 205	2600	1x4, 3 Lamp, 32w TR, Elect. Ballast, Pendant Mnt., Direct/Indirect	3	86	18	1.55	4,025	Existing to Remain	Existing to Remain	3	86	0	1.55	4,025	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 207	2600	1x4, 3 Lamp, 32w TR, Elect. Ballast, Pendant Mnt., Direct/Indirect	3	86	9	0.77	2,012	Existing to Remain	Existing to Remain	3	86	0	0.77	2,012	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 209	2600	1x4, 3 Lamp, 32w TR, Elect. Ballast, Pendant Mnt., Direct/Indirect	3	86	16	1.38	3,578	Existing to Remain	Existing to Remain	3	86	0	1.38	3,578	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
227.21	Classroom 209	2600	2x2, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Prismatic Lens	2	65	4	0.26	676	Existing to Remain	Existing to Remain	2	65	0	0.26	676	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Classroom 209 Restroom	1200	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 210	2600	1x4, 3 Lamp, 32w TR, Elect. Ballast, Pendant Mnt., Direct/Indirect	3	86	16	1.38	3,578	Existing to Remain	Existing to Remain	3	86	0	1.38	3,578	0.00	0	\$0	\$0.00	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0

Fixture Reference #	Location	Average Burn Hours	Existing Fixtures						Proposed Fixtures Retrofit						Retrofit Energy Savings			Lighting Retrofit Costs				Proposed Lighting Controls						
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Energy Savings kWh	Energy Savings kVA	Energy Savings \$	Material	Total Labor	Total All	Rebate Estimate	Simple Payback	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings kWh
227.21	Classroom 210	2600	2x2, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	2	65	4	0.26	676	Existing to Remain	Existing to Remain	2	65	0	0.26	676	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Classroom 210 Restroom	1200	2x4, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 211	2600	1x4, 3 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	3	86	16	1.38	3,578	Existing to Remain	Existing to Remain	3	86	0	1.38	3,578	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
227.21	Classroom 211	2600	2x2, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	2	65	4	0.26	676	Existing to Remain	Existing to Remain	2	65	0	0.26	676	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Classroom 211 Restroom	1200	2x4, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 212	2600	1x4, 3 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	3	86	16	1.38	3,578	Existing to Remain	Existing to Remain	3	86	0	1.38	3,578	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
227.21	Classroom 212	2600	2x2, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	2	65	4	0.26	676	Existing to Remain	Existing to Remain	2	65	0	0.26	676	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Classroom 212 Restroom	1200	2x4, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.33	Classroom 213	2600	1x4, 2 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	2	62	10	0.62	1,612	Existing to Remain	Existing to Remain	2	62	0	0.62	1,612	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Classroom 213 Restroom	1200	2x4, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 214	2600	1x4, 3 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	3	86	16	1.38	3,578	Existing to Remain	Existing to Remain	3	86	0	1.38	3,578	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
227.21	Classroom 214	2600	2x2, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	2	65	4	0.26	676	Existing to Remain	Existing to Remain	2	65	0	0.26	676	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Classroom 214 Restroom	1200	2x4, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
231.33	Classroom 215	2600	1x4, 3 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	3	86	16	1.38	3,578	Existing to Remain	Existing to Remain	3	86	0	1.38	3,578	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
227.21	Classroom 215	2600	2x2, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	2	65	4	0.26	676	Existing to Remain	Existing to Remain	2	65	0	0.26	676	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.29	Classroom 215 Restroom	1200	2x4, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.33	Classroom 217	2600	1x4, 2 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59
221.29	Classroom 217 Restroom	1200	2x4, 2 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Wallwasher	2	62	2	0.12	149	Existing to Remain	Existing to Remain	2	62	0	0.12	149	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
221.33	Classroom 219	2600	1x4, 2 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59
221.33	Classroom 218	2600	1x4, 2 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59
221.33	Classroom 216	2600	1x4, 2 Lamp, 32w TR, Elec. Ballast, Pendant Mnt., Direct/Indirect	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59
232.22	Classroom 220	2600	2x4, 3 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Parabolic Lens	3	86	4	0.34	894	Existing to Remain	Existing to Remain	3	86	0	0.34	894	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0
232.21	Classroom 186	2600	2x4, 3 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	537	\$82
232.21	Classroom 185	2600	2x4, 3 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	537	\$82
232.21	Classroom 184	2600	2x4, 3 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	537	\$82
232.21	Classroom 183	2600	2x4, 3 Lamp, 32w TR, Elec. Ballast, Recessed Mnt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	537	\$82

Fixture Reference #	Location	Average Burn Hours	Existing Fixtures					Proposed Fixtures Retrofit					Retrofit Energy Savings			Lighting Retrofit Costs				Proposed Lighting Controls									
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Energy Savings kWh	Energy Savings \$	Material	Total Labor	Total All	Rebate Estimate	Simple Payback	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings kWh	Energy Savings \$	
232.21	Classroom 182	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	537	\$82	
232.21	Classroom 181	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	537	\$82	
232.21	Classroom 180	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	537	\$82	
222.21	Girl's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	4	0.25	645	Existing to Remain	Existing to Remain	2	62	0	0.25	645	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	129	\$20	
222.21	Boy's Restroom	2600	2x4, 2 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	2	62	4	0.25	645	Existing to Remain	Existing to Remain	2	62	0	0.25	645	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	129	\$20	
121.34	Electrical Closet	1200	1x4, 2 Lamp, 34w T12, Mag. Ballast, Pendant Mt., No Lens	2	78	1	0.08	94	Reballast & Relamp	Reballast & Relamp; Sybuxia Lamp FO28841/SS/ECO	2	50	1	0.05	60	0.03	34	\$5	\$30.00	\$70.00	\$100.00	\$0.00	19.45	0	No New Controls	0	0.0%	0	\$0
121.34	Custodial Closet	2000	1x4, 2 Lamp, 34w T12, Mag. Ballast, Pendant Mt., No Lens	2	78	1	0.08	156	Reballast & Relamp	Reballast & Relamp; Sybuxia Lamp FO28841/SS/ECO	2	50	1	0.05	100	0.03	56	\$9	\$30.00	\$70.00	\$100.00	\$0.00	11.67	0	No New Controls	0	0.0%	0	\$0
200	Women's Restroom	1200	1x2, 2 Lamp, 17w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	34	1	0.03	41	Existing to Remain	Existing to Remain	2	34	0	0.03	41	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
221.11	Classroom 175	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	7	0.43	1,128	Existing to Remain	Existing to Remain	2	62	0	0.43	1,128	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	226	\$35	
232.21	Classroom 174	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	537	\$82	
232.21	Classroom 172	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	4	0.34	894	Existing to Remain	Existing to Remain	3	86	0	0.34	894	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	179	\$27	
232.22	Media Center	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Parabolic Lens	3	86	40	3.44	8,944	Existing to Remain	Existing to Remain	3	86	0	3.44	8,944	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	3	20.0%	1,789	\$274	
232.22	Media Center Office	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Parabolic Lens	3	86	4	0.34	894	Existing to Remain	Existing to Remain	3	86	0	0.34	894	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	179	\$27	
242.22	Media Center classroom	2600	2x4, 4 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Parabolic Lens	4	104	16	1.66	4,326	Existing to Remain	Existing to Remain	4	104	0	1.66	4,326	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	865	\$132	
221.33	Classroom 116	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Pendant Mt., Direct/ Indirect	2	62	14	0.87	2,257	Existing to Remain	Existing to Remain	2	62	0	0.87	2,257	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
221.33	Classroom 117	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Pendant Mt., Direct/ Indirect	2	62	6	0.37	967	Existing to Remain	Existing to Remain	2	62	0	0.37	967	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
221.33	Classroom 119	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Pendant Mt., Direct/ Indirect	2	62	23	1.43	3,708	Existing to Remain	Existing to Remain	2	62	0	1.43	3,708	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0	
232.21	Classroom 120A	2600	2x4, 3 Lamp, 32w TR, Elect. Ballast, Recessed Mt., Prismatic Lens	3	86	4	0.34	894	Existing to Remain	Existing to Remain	3	86	0	0.34	894	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mt.	1	20.0%	179	\$27	
221.11	Classroom 120	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	15	0.93	2,418	Existing to Remain	Existing to Remain	2	62	0	0.93	2,418	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	484	\$74	
221.11	Classroom 127	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	387	\$59	
221.11	Classroom 122	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	387	\$59	
221.11	Classroom 123	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	387	\$59	
221.11	Classroom 128	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	387	\$59	
221.11	Classroom 129	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	387	\$59	
221.11	Classroom 124	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	387	\$59	
221.11	Classroom 125	2600	1x4, 2 Lamp, 32w TR, Elect. Ballast, Surface Mt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mt.	1	20.0%	387	\$59	

Fixture Reference #	Location	Average Burn Hours	Existing Fixtures						Proposed Fixtures Retrofit						Retrofit Energy Savings						Lighting Retrofit Costs						Proposed Lighting Controls					
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Energy Savings, kWh	Energy Savings, kWh	Energy Savings, \$	Material	Total Labor	Total All	Rebate Estimate	Simple Payback	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$			
221.11	Classroom 130	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59				
231.33	Classroom 126	2600	1x4, 3 Lamp, 32w TS, Elec. Ballast, Pendant Mnt., Direct/Indirect	3	86	12	1.03	2,683	Existing to Remain	Existing to Remain	3	86	0	1.03	2,683	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	537	\$82				
242.21	Conference Room	2600	2x4, 4 Lamp, 32w TS, Elec. Ballast, Recessed Mnt., Prismatic Lens	4	104	3	0.31	811	Existing to Remain	Existing to Remain	4	104	0	0.31	811	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mnt.	1	20.0%	162	\$25				
221.11	Classroom 112	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59				
221.11	Classroom 113	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59				
221.11	Classroom 114	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59				
221.33	Classroom 115	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Pendant Mnt., Direct/Indirect	2	62	6	0.37	967	Existing to Remain	Existing to Remain	2	62	0	0.37	967	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0				
221.11	Classroom 110	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59				
221.11	Classroom 109	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59				
221.11	Classroom 108	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	12	0.74	1,934	Existing to Remain	Existing to Remain	2	62	0	0.74	1,934	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	387	\$59				
221.11	Nurse	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	7	0.43	1,128	Existing to Remain	Existing to Remain	2	62	0	0.43	1,128	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	226	\$35				
221.11	Copy	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0				
221.11	Main Office	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	9	0.56	1,451	Existing to Remain	Existing to Remain	2	62	0	0.56	1,451	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	290	\$44				
221.11	Principal's Office	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	2	0.12	322	Existing to Remain	Existing to Remain	2	62	0	0.12	322	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0				
227.21	Lobby	3000	2x2, 2 Lamp, 32w TS, Elec. Ballast, Recessed Mnt., Prismatic Lens	2	65	8	0.52	1,560	Existing to Remain	Existing to Remain	2	65	0	0.52	1,560	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0				
221.11	Kitchen	2600	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	16	0.99	2,579	Existing to Remain	Existing to Remain	2	62	0	0.99	2,579	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	516	\$79				
221.11	Boiler Room	3000	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	9	0.56	1,674	Existing to Remain	Existing to Remain	2	62	0	0.56	1,674	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0				
242.21	Office 164	2600	2x4, 4 Lamp, 32w TS, Elec. Ballast, Recessed Mnt., Prismatic Lens	4	104	4	0.42	1,082	Existing to Remain	Existing to Remain	4	104	0	0.42	1,082	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mnt.	1	20.0%	216	\$33				
242.21	Classroom 149	2600	2x4, 4 Lamp, 32w TS, Elec. Ballast, Recessed Mnt., Prismatic Lens	4	104	4	0.42	1,082	Existing to Remain	Existing to Remain	4	104	0	0.42	1,082	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	5	Dual Technology Occupancy Sensor - Switch Mnt.	1	20.0%	216	\$33				
100	Restroom (2)	2600	2 Vanity Light, 2 Lamp, 20w T12, Mag. Ballast, Wall Mnt., Glass Lens	2	42	2	0.08	218	Reballast & Relamp	Reballast & Relamp: 17w TS Elec. Ballast	2	33	2	0.07	172	0.02	47	\$7	\$60.00	\$100.00	\$0.00	22.35	0	No New Controls	0	0.0%	0	\$0				
222.21	Corridors	3000	2x4, 2 Lamp, 32w TS, Elec. Ballast, Recessed Mnt., Prismatic Lens	2	62	91	5.64	16,926	Existing to Remain	Existing to Remain	2	62	0	5.64	16,926	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0				
221.11	Corridors	3000	1x4, 2 Lamp, 32w TS, Elec. Ballast, Surface Mnt., Prismatic Lens	2	62	14	0.87	2,604	Existing to Remain	Existing to Remain	2	62	0	0.87	2,604	0.00	0	\$0	\$0.00	\$0.00	\$0.00	-	0	No New Controls	0	0.0%	0	\$0				
<b>PODS</b>																																
121.21	Classroom T3	2600	1x4, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	2	78	8	0.62	1,622	Reballast & Relamp	Reballast & Relamp: Sylvania Lamp FO28841/SS/ECO	2	50	8	0.40	1,040	0.22	582	\$89	\$240.00	\$560.00	\$800.00	\$0.00	8.98	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	208	\$32			
121.21	Classroom T4	2600	1x4, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	2	78	8	0.62	1,622	Reballast & Relamp	Reballast & Relamp: Sylvania Lamp FO28841/SS/ECO	2	50	8	0.40	1,040	0.22	582	\$89	\$240.00	\$560.00	\$800.00	\$0.00	8.98	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	208	\$32			
121.21	Classroom T5	2600	1x4, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	2	78	8	0.62	1,622	Reballast & Relamp	Reballast & Relamp: Sylvania Lamp FO28841/SS/ECO	2	50	8	0.40	1,040	0.22	582	\$89	\$240.00	\$560.00	\$800.00	\$0.00	8.98	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	208	\$32			
121.21	Classroom T6	2600	1x4, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	2	78	8	0.62	1,622	Reballast & Relamp	Reballast & Relamp: Sylvania Lamp FO28841/SS/ECO	2	50	8	0.40	1,040	0.22	582	\$89	\$240.00	\$560.00	\$800.00	\$0.00	8.98	4	Dual Technology Occupancy Sensor - Remote Mnt.	1	20.0%	208	\$32			
TOTAL						946	69	179,560				36	67.72	177,103	0.97	2,466	\$377	\$1,088.00	\$2,480.00	\$3,560.00	\$0.00	9.44		52		19,438	\$2,974					


CEG Project #: 9C12053  
 Facility Name: Parsons Elementary School  
 Address: 899 Hollowood Street  
 City, State, Zip: North Brunswick, NJ 08902

Fixture Reference #	Location	Average Burn Hours	Existing Fixtures						Proposed Fixtures Retrofit						Retrofit Energy Savings			Lighting Retrofit Costs				Proposed Lighting Controls							
			Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Work Description	Equipment Description	Lamps per Fixture	Watts per Fixture	Qty of Fixtures	Total kW	Usage kWh/yr	Energy Savings, kWh	Energy Savings, \$	Energy Savings, \$	Material	Total Labor	Total All	Rebate Estimate	Simple Payback	Control Ref #	Controls Description	Qty of Controls	Hour Reduction %	Energy Savings, kWh	Energy Savings, \$
745	Cafeteria	2600	250w MH, Prismatic Lens	1	295	28	8.26	21,476	Remove and Return	1x4, 4 Lamp, 54w TSHO, Elect. Ballast, Lo Bay	6	230	28	6.44	16,744	1.82	4,732	\$724	\$5,600.00	\$4,200.00	\$9,800.00	\$0.00	13.54	4	Dual Technology Occupancy Sensor - Remote Mt.	2	20.0%	3,349	\$512
745	Gym	2600	250w MH, Prismatic Lens	1	295	20	5.90	15,340	Remove and Return	1x4, 4 Lamp, 54w TSHO, Elect. Ballast, Lo Bay	6	230	20	4.60	11,960	1.30	3,380	\$517	\$4,000.00	\$3,000.00	\$7,000.00	\$0.00	13.54	4	Dual Technology Occupancy Sensor - Remote Mt.	3	20.0%	2,392	\$366
<b>TOTAL</b>						<b>48</b>	<b>14</b>	<b>36,816</b>					<b>48</b>	<b>11</b>	<b>28,704</b>	<b>3</b>	<b>8,112</b>	<b>\$1,241</b>	<b>\$9,600</b>	<b>\$7,200</b>	<b>\$16,800</b>	<b>\$0</b>				<b>5</b>	<b>0</b>	<b>5,741</b>	<b>\$878.34</b>

**APPENDIX F**



Location Description	Area (Sq FT)	Panel	Qty	Panel Sq Ft	Panel Total Sq Ft	Total KW <sub>DC</sub>	Total Annual kWh	Total KW <sub>AC</sub>	Panel Weight (41.9 lbs)	W/SQFT
Parsons Elementary	12200	SHARP NU-U235F2	536	17.5	9,402	125.96	148,571	102.0	22,458	13.40



= Proposed PV Layout       = Proposed Parking PV Layout

Notes:

1. Estimated kWh based on the National Renewable Energy Laboratory PVWatts Version 1 Calculator Program.

<b>Project Name: LGEA Solar PV Project - Parsons Elementary</b> <b>Location: New Brunswick, NJ</b> <b>Description: Photovoltaic System 100% Financing - 15 year</b>									
<b>Simple Payback Analysis</b>									
		<b>Photovoltaic System 100% Financing - 15 year</b>							
Total Construction Cost		\$794,424							
Annual kWh Production		148,571							
Annual Energy Cost Reduction		\$22,731							
Average Annual SREC Revenue		\$28,390							
Simple Payback:		<b>15.54</b>						Years	
<b>Life Cycle Cost Analysis</b>									
Analysis Period (years):		15				Financing %:		100%	
Discount Rate:		3%				Maintenance Escalation Rate:		3.0%	
Average Energy Cost (\$/kWh)		<b>\$0.153</b>				Energy Cost Escalation Rate:		3.0%	
Financing Rate:		6.00%				Average SREC Value (\$/kWh)		\$0.191	
Period	Additional Cash Outlay	Energy kWh Production	Energy Cost Savings	Additional Maint Costs	SREC Revenue	Interest Expense	Loan Principal	Net Cash Flow	Cumulative Cash Flow
0	\$0	0	0	0	\$0	0	0	0	0
1	\$0	148,571	\$22,731	\$0	\$37,143	\$46,749	\$33,697	(\$20,572)	(\$20,572)
2	\$0	147,828	\$23,413	\$0	\$36,957	\$44,670	\$35,775	(\$20,075)	(\$40,647)
3	\$0	147,089	\$24,116	\$0	\$36,772	\$42,464	\$37,982	(\$19,558)	(\$60,204)
4	\$0	146,354	\$24,839	\$0	\$36,588	\$40,121	\$40,324	(\$19,018)	(\$79,223)
5	\$0	145,622	\$25,584	\$1,500	\$36,405	\$37,634	\$42,811	(\$19,956)	(\$99,178)
6	\$0	144,894	\$26,352	\$1,492	\$28,979	\$34,994	\$45,452	(\$26,607)	(\$125,786)
7	\$0	144,169	\$27,142	\$1,485	\$28,834	\$32,190	\$48,255	(\$25,954)	(\$151,740)
8	\$0	143,448	\$27,957	\$1,478	\$28,690	\$29,214	\$51,232	(\$25,277)	(\$177,017)
9	\$0	142,731	\$28,795	\$1,470	\$28,546	\$26,054	\$54,391	(\$24,574)	(\$201,591)
10	\$0	142,017	\$29,659	\$1,463	\$21,303	\$22,699	\$57,746	(\$30,947)	(\$232,537)
11	\$0	141,307	\$30,549	\$1,455	\$21,196	\$19,138	\$61,308	(\$30,156)	(\$262,693)
12	\$0	140,601	\$31,466	\$1,448	\$21,090	\$15,356	\$65,089	(\$29,338)	(\$292,031)
13	\$0	139,898	\$32,409	\$1,441	\$20,985	\$11,342	\$69,104	(\$28,492)	(\$320,524)
14	\$0	139,198	\$33,382	\$1,434	\$13,920	\$7,080	\$73,366	(\$34,578)	(\$355,102)
15	\$0	138,502	\$34,383	\$1,427	\$13,850	\$2,555	\$77,891	(\$33,639)	(\$388,740)
<b>Totals:</b>		2,152,230	\$422,779	\$16,093	\$411,258	\$412,260	\$794,424	(\$388,740)	(\$2,807,584)
<b>Net Present Value (NPV)</b>							<b>(\$284,953)</b>		