

**PENNS GROVE – CARNEYS POINT REGIONAL SCHOOL DISTRICT
PENNS GROVE MIDDLE SCHOOL
ENERGY ASSESSMENT**

for

**NEW JERSEY
BOARD OF PUBLIC UTILITIES**

CHA PROJECT NO. 24510

October 2012

Prepared by:



6 Campus Drive
Parsippany, NJ 07054

(973) 538-2120

TABLE OF CONTENTS

| | |
|--|----|
| 1.0 EXECUTIVE SUMMARY | 1 |
| 2.0 INTRODUCTION AND BACKGROUND | 2 |
| 3.0 EXISTING CONDITIONS | 3 |
| 3.1 Building - General..... | 3 |
| 3.2 Utility Usage..... | 3 |
| 3.3 HVAC Systems | 4 |
| 3.4 Control Systems | 5 |
| 3.5 Lighting/Electrical Systems | 5 |
| 3.6 Plumbing Systems..... | 5 |
| 4.0 ENERGY CONSERVATION MEASURES..... | 6 |
| 4.1 ECM-1 Replace Steam Heating System with a Hydronic Heating System | 6 |
| 4.2 ECM-2 Replace Domestic Hot Water Heater | 6 |
| 4.3 ECM-3 Replace Exterior Door Seals & Sweeps..... | 7 |
| 4.4 ECM-4 Lighting Replacements/Upgrades | 7 |
| 4.5 ECM-5 Lighting Controls (Occupancy Sensors) | 8 |
| 4.6 ECM-6 Lighting Replacements/Upgrades & Controls (Occupancy Sensors)..... | 9 |
| 4.7 ECM-7 Water Conservation (Low Flow Fixtures) | 9 |
| 5.0 PROJECT INCENTIVES..... | 11 |
| 5.1 Incentives Overview..... | 11 |
| 5.1.1 New Jersey Pay For Performance Program..... | 11 |
| 5.1.2 New Jersey Smart Start Program | 12 |
| 5.1.3 Direct Install Program | 12 |
| 5.1.4 Energy Savings Improvement Plans (ESIP)..... | 13 |
| 6.0 ALTERNATIVE ENERGY SCREENING EVALUATION..... | 15 |
| 6.1 Solar | 15 |
| 6.1.1 Photovoltaic Rooftop Solar Power Generation..... | 15 |
| 6.1.2 Solar Thermal Hot Water Plant..... | 16 |
| 6.2 Demand Response Curtailment | 16 |

7.0 EPA PORTFOLIO MANAGER 18
8.0 CONCLUSIONS & RECOMMENDATIONS 20

APPENDICES

- A Utility Usage Analysis, Energy Suppliers List
- B Equipment Inventory
- C ECM Calculations
- D New Jersey Pay For Performance Incentive Program
- E Energy Savings Improvement Plan (ESIP)
- F Solar Photovoltaic Analysis
- G EPA Portfolio Manager

REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within $\pm 20\%$, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the facility was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing facility staff and spot measurements taken in the field.

1.0 EXECUTIVE SUMMARY

The Penns Grove – Carneys Point Regional School District recently engaged CHA to perform an energy audit in connection with the New Jersey Board of Public Utilities’ Local Government Energy Audit Program. This report details the results of the energy audit conducted for:

| Building Name | Address | Square Feet | Construction Date |
|---------------------------|---|------------------|----------------------------------|
| Penns Grove Middle School | 351 Maple Avenue Penns Grove, New Jersey | 65,540 20,000 | Original: 1935 Addition: 1954 |

The Energy Conservation Measures (ECMs) identified in this report will allow for a more efficient use of energy and if pursued have the opportunity to qualify for the New Jersey SmartStart Buildings Program and/or Direct Install Program. Potential annual savings of \$11,300 for the recommended ECMs may be realized with a payback of 8.4 years. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

| Summary of Energy Conservation Measures | | | | | | | |
|---|---|--------------------|---------------------------|-------------------------------|---------------------------|------------------------------|--------------------------------|
| Energy Conservation Measure | | Approx. Costs (\$) | Approx. Savings (\$/year) | Payback (Years) w/o Incentive | Potential Incentive (\$)* | Payback (Years) w/ Incentive | Recommended For Implementation |
| ECM-1 | Install a Condensing Boiler | 1,583,000 | 5,600 | >20 | 2,600 | >20 | |
| 2 | Replace Domestic Hot Water Heater | 14,000 | 3,500 | 4.0 | 600 | 3.8 | X |
| 3 | Replace Exterior Door Seals & Sweeps | 5,000 | 400 | 12.5 | 0 | 12.5 | X |
| 4 | Lighting Replacements/Upgrades | 59,000 | 3,400 | 17.4 | 5,000 | 15.9 | |
| 5 | Lighting Controls (Occupancy Sensors) | 11,000 | 6,000 | 1.8 | 2,000 | 1.5 | |
| 6 | Lighting Replacements/Upgrades & Controls (Occupancy Sensors) | 70,000 | 7,400 | 9.5 | 7,000 | 8.5 | X |
| 7 | Water Conservation (Low Flow Fixtures) | 65,000 | 3,600 | 18.1 | 0 | 18.1 | |

2.0 INTRODUCTION AND BACKGROUND

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

The Penns Grove Middle School located in Penns Grove, NJ, is a combined 85,540 square foot three story building having masonry construction. The original building was constructed in 1935 and was a 65,540 square foot building with an addition in 1954 that added 20,000 square feet. It contains classrooms, reception/office areas, a kitchen, cafeteria, high bay auditorium, high bay gymnasium and restrooms. Occupancy includes approximately 500 students and 90 faculty members. The building operates Monday through Friday from 7:30 am to approximately 3:30 pm with custodians working until around 10:30 pm. The building is closed on the weekends, and occupancy levels are reduced in summer months for each year.



3.0 EXISTING CONDITIONS

3.1 Building - General

Originally built in 1935 with an addition constructed in 1954, the Penns Grove Middle School is a combined 85,540 square foot three story flat roof building containing with classrooms, reception/office areas, a kitchen, cafeteria, high bay auditorium, high bay gymnasium and restrooms. The main entrance is has glass doors with metal frames that opens into the front main stair well area on the south side of the building.

The Penns Grove middle School building has approximately 500 students and 90 faculty and staff; the building was empty during the field visit. The building is assumed to be fully occupied from 7:30 am until 3:30 pm during the week. The hours of operation are:

- Monday thru Friday 7:30 am to 3:30 pm.
- Monday thru Friday until 10:30 pm (for custodians)

The building is constructed of some wood with structural block and a red brick veneer. The majority of the interior walls are painted block but some contain fiberglass insulation finished with gypsum board. The flat roof system is comprised of a structural steel framing with a metal deck having rigid foam board insulation with a dark colored EPDM membrane. Windows are significant all around the building wherever there are classrooms, offices or hallways and minimal on the exterior walls of the gymnasium and auditorium walls. There are columns with a small roof overhang in the front of the building main entrance on the south end of the building. Windows are thermo pane set in painted wooden frames. The main entrance doors are part glass, and part wood panel with wood frames. The majority of the one three building is 36' in height, with a shorter 25' two story addition.

3.2 Utility Usage

The utility consumption for the school includes electricity, natural gas and potable water. Electricity is delivered by Atlantic City Electric and supplied by New Energy Inc. and South Jersey Electric Company (during the billed period). Natural gas is delivered by South Jersey Gas and supplied by third party Woodruff Energy. Potable water is provided by the municipally owned water department at a charge.

For the 12-month period ranging from July 2011 through June 2012, the utilities usage for the building was as follows:

Actual Cost & Site Usage by Utility

| Electric | | |
|--------------------|---------|------------|
| Annual Usage | 462,201 | kWh/yr |
| Annual Cost | 56,801 | \$ |
| Blended Rate | 0.123 | \$/kWh |
| Consumption Rate | 0.096 | \$/kWh |
| Demand Rate | 6.11 | \$/kW |
| Peak Demand | 141.0 | kW |
| Min. Demand | 98.0 | kW |
| Avg. Demand | 126.9 | kW |
| Natural Gas | | |
| Annual Usage | 44,056 | Therms/yr |
| Annual Cost | 43,593 | \$ |
| Rate | 0.989 | \$/Therms |
| Water | | |
| Annual Usage | 776,000 | gallons/yr |
| Annual Cost | 2,669 | \$ |
| Rate | 5.881 | \$/gallon |

Both electrical and natural gas usages were generally higher in the winter months. See Appendix A for a detailed utility analysis.

Under New Jersey’s energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. With the supply portion open to competition, customers can shop around for the best price on their energy supplies. Their electric and natural gas distribution utilities will still deliver those supplies through their wires and pipes – and respond to emergencies, should they arise – regardless of where those supplies are purchased. Purchasing your energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of your service. Additional information on selecting a third party energy supplier is available here: <http://www.state.nj.us/bpu/commercial/shopping.html>. See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building’s service area.

3.3 HVAC Systems

The systems and equipment described below serve the Penns Grove Middle School building. Specifics on the mechanical equipment can be found within the equipment inventory located in Appendix B.

3.3.1 Heating Steam and Hot Water Systems

The main heating source of the building comes from a 6,968 MBH max output (168 BHP) H.B. Smith gas fired steam boiler installed in 2006. This boiler heats the original 1935 section of the building with low pressure steam , which has an area of 85,540 square feet. Classrooms in the 1935 construction are heated by wall-mounted radiators. The 1954 addition is heated by hot water which is created through a heat exchanger provided with steam from the steam boiler. Classrooms in the 1954 construction are heated by hot water coil unit ventilators. The gymnasium is heated by gas fired forced air, which was installed in 2005. The main offices are heated by hot water coil forced air unit ventilators. Approximately 76% of the building heating is supplied by steam with only 24% by hot water.

3.3.2 Air Conditioning Systems

The main offices are cooled by (2) 3 ton Carrier A/C units located on the ground level outside the offices that supply cooling to unit ventilators located inside the offices. There are several window A/C units in various rooms, but the majority of the building did not have any cooling. These units are manually controlled by school personnel.

3.3.3 Exhaust Systems

There is a kitchen exhaust hood used every day that is manually switched on and off by kitchen staff. There are some rooftop exhaust units in place for toilet rooms. The 1935 classrooms are ventilated through natural ventilation plenums within the walls.

3.4 Control Systems

The Penns Grove Middle School has full pneumatic controls in place to regulate both the hot water and steam heating systems with compressed air supplied by (1) 2 HP Baldor air compressor located in the mechanical room.

3.5 Lighting/Electrical Systems

The facility primarily utilizes fixtures with T-8 32 watt lamps with electronic ballasts; compact fluorescent fixtures and older style incandescent fixtures are also used in select areas. The gymnasium and auditorium are equipped with 250 watts high pressure sodium light fixtures. The primary sources of control for the lights are switches manually turned off at the end of the day.

Exterior lights consist of wall pack high pressure sodium fixtures on daylight sensors and timers. The wall pack lights are powered by the building's electrical system and are part of the lighting systems analysis.

3.6 Plumbing Systems

3.6.1 Domestic Hot Water System

The building contains one 18 kW Bradford White 120 gallon electric tank type hot water heater and one 1.65 kW State Industries Inc. 6 gallon electric tank type hot water heater. Hot water is provided to toilet rooms, the kitchen and custodial sinks. Domestic hot water temperature is maintained at 120°F.

3.6.2 Plumbing Fixtures

The building's lavatories, water closets, and urinals are original high flow plumbing fixtures that require upgrades. On average the faucets have a flow rate of 1.5 gallons per minute (gpm), urinals consume approximately 2.5 gallons per flush (gpf) and toilets typically use 3.5 gpf. It was determined that there are 18 faucets, 11 urinals and 34 toilets within the facility.

4.0 ENERGY CONSERVATION MEASURES

4.1 ECM-1 Replace Steam Heating System with a Hydronic Heating System

The main heating source of the building comes from a single 168 HP HB Smith gas fired steam boiler. The boiler is non-condensing with an estimated efficiency of 80% and an overall estimated system efficiency of 65%.

Due to the relatively low efficiency of the existing steam heating system, an assessment was made to replace the entire steam heating system with a modern hot water system that would include new high-efficiency condensing gas boilers (2) , hot water pumps having variable frequency drives, all new piping and new classroom unit ventilators. This is obviously a major reconstruction project, but should be considered if the school is to used long term.

Note: the added ventilation energy penalty which will result from implementing this ECM was not accounted for in these calculations. Only a comparison of boiler and system efficiencies are included. If this ECM is pursued, it will be necessary to include the added ventilation energy penalty in the building load calculations to predict actual annual fuel usage.

The boiler fuel consumption was calculated from the estimated system efficiency and the natural gas consumed annually per the utility bills. This was then compared to the improved efficiency of a new condensing boiler and hot water distribution system. The difference in fuel usage was the savings.

Natural gas-fired boilers have an expected life of 25 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 140,800 therms and \$139,300.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

| ECM-1 Replace steam heating system with hydronic heating system | | | | | | | | | | |
|--|------------------------|-------------|----------------|----------|-------------------------------|---------------|-----|-------------|-----------------------------|--------------------------|
| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) | Payback (with incentive) |
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | \$ | \$ | | \$ | Years | Years |
| \$ 45,000 | 0 | 0 | 5,600 | 5,600 | 0 | 5,600 | 2.1 | 2,600 | 8.0 | 7.6 |

* Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities.

This measure is not recommended based on energy savings. This measure is recommended if extensive building renovations are planned in the near future.

4.2 ECM-2 Replace Domestic Hot Water Heater

The building utilizes one 18 kW Bradford White 120 gallon electric tank type hot water heater and one 1.65 kW State Industries Inc. 6 gallon electric tank type hot water heater. During periods of little to no domestic hot water use, the units must still heat the water within their storage tank. Energy required

maintaining the amount of hot water temperature set point during times of zero demand is known as standby losses; replacing these units with higher efficiency natural gas units was evaluated.

According to the U.S. Department of Energy, 2.5% of stored capacity is lost every hour during HW heater standby. This value was applied to the total volume of the existing DHW heater storage tank to determine the annual standby losses. Proposed efficiency was based on a typical tank type, high efficiency, condensing hot water heater. The new water heater will require gas and water piping modifications, venting, and electrical connections.

Domestic hot water heaters have an expected life of 12 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 480,100 kWh, -13,300 therms (since the system is changed from electric to natural gas) and \$50,200.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2 Replace Domestic Water Heater

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|-------------------|------------------------|----------------|-------------------|-------------|-------------------------------------|------------------|-----|----------------|--|---|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 16,000 | 40,000 | 0 | -1,100 | 4,200 | 0 | 4,200 | 2.2 | 600 | 3.8 | 3.7 |

* Incentive shown is per the New Jersey SmartStart Program. See section 5.0 for other incentive opportunities.

This measure is recommended.

4.3 ECM-3 Replace Exterior Door Seals & Sweeps

The exterior doors have a 3/8” gap between the two leafs permitting outdoor air to infiltrate the building which adds load to the HVAC. This ECM includes adding new door seals and door sweeps to these main entrance doors to reduce the amount of infiltration.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-3 Replace Exterior Door Seals & Sweeps

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) Years | Payback (with Incentive) Years |
|-------------------|------------------------|-----|---------|-------|-------------------------------------|------------------|-------|-------------------------|--|---|
| | Electricity | | Nat Gas | Total | | | | | | |
| \$ | kW | kWh | Therms | \$ | \$ | \$ | | \$ | | |
| 5,000 | 0 | 0 | 400 | 400 | 0 | 400 | (0.6) | 0 | 12.5 | 12.5 |

* Incentive not applicable for this measure.

This measure is recommended.

4.4 ECM-4 Lighting Replacements/Upgrades

The Penns Grove Middle School utilizes mainly 32 watt T-8 fluorescent lamps with electronic ballasts. The gymnasium and auditorium contain 250 watt high pressure sodium lamps. There were some fluorescent T-12 40 watt lamps in several areas of the building that are recommended to be upgraded. A comprehensive fixture survey was conducted of the entire building. There is an opportunity to continue to reduce that consumption even more by upgrading the classrooms to super T-8 lamps and the metal halides in the high bay areas to high bay fluorescent fixtures.

Energy savings for this measure were calculated by applying the existing and proposed fixture wattages to estimated times of operation. The difference between energy requirements resulted in a total annual savings of 26,400 kWh. Supporting calculations, including assumptions for lighting hours and annual energy usage for each fixture, are provided in Appendix C.

Lighting has an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 396,300 kWh and \$51,000.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized as follows:

ECM-4 Lighting Replacement / Upgrades

| Budgetary Cost | Annual Utility Savings | | | | Estimated | Total | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|-------------------|------------------------|----------------|-------------------|-------------|------------------------------|---------------|-------|----------------|--|---|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | Maintenance Savings \$ | Savings \$ | | | | |
| \$ | | | | | | | | | | |
| 59,000 | 26,400 | 0 | 0 | 3,400 | 0 | 3,400 | (0.1) | 5,000 | 17.4 | 15.9 |

* Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM-6.

4.5 ECM-5 Lighting Controls (Occupancy Sensors)

The current Penns Grove Middle School Building lighting is mostly controlled by manual switches. Lights are generally turned on in the morning and shut off at night. During school hours, there are rooms that are not occupied, however the lights remain on. Adding occupancy controls to the individual rooms will automatically control the lights based on occupancy. The occupancy sensor can be wall mounted near the switch or placed at the ceiling for larger room coverage. All occupancy sensors are equipped with a manual override feature. These sensors are generally not recommended in public toilet rooms.

Lighting controls have an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 735,600 kWh and \$90,400.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-5 Install Lighting Controls (Occupancy Sensors)

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-----|-------------|-----------------------------|--------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | kWh | kW | Therms | \$ | \$ | \$ | \$ | Years | Years | |
| 11,000 | 49,000 | 0 | 0 | 6,000 | 0 | 6,000 | 7.0 | 2,000 | 1.8 | 1.5 |

* Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM-6.

4.6 ECM-6 Lighting Replacements/Upgrades & Controls (Occupancy Sensors)

Due to interactive effects, the energy and cost savings for occupancy sensors and lighting upgrades are not cumulative. This measure is a combination of ECM-4 and ECM-5 to reflect actual expected energy and demand reduction.

The lighting retrofits and controls have an expected lifetime of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 1,020,000 kWh and \$110,400.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized as follows:

ECM-6 Lighting Replacements & Lighting Controls (Occupancy Sensors)

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-----|-------------|-----------------------------|--------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | kWh | kW | Therms | \$ | \$ | \$ | \$ | Years | Years | |
| 70,000 | 68,000 | 0 | 0 | 7,400 | 0 | 7,400 | 0.6 | 7,000 | 9.5 | 8.5 |

* Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities.

This measure is recommended.

4.7 ECM-7 Water Conservation (Low Flow Fixtures)

Faucets, toilets and urinals installed before the mid-90s consume more water than modern plumbing fixtures. On average faucets have a flow rate of 1.5 gallons per minute (gpm), urinals consume approximately 2.5 gallons per flush (gpf) and toilets typically use 3.5 gpf. It was determined that there are 18 faucets, 11 urinals and 34 toilets within the facility. Per building occupancy, it was estimated that each toilet and faucet is utilized approximately nine times per day.

The water savings associated from replacing these fixtures with low-flow fixtures was calculated by taking the difference of the annual water usage for the proposed and base case. The basis of this calculation is the number of times each fixture is used, gallons per use, and number of fixtures. Replacing the existing fixtures in the restrooms with 0.5 gpm faucets, 0.5 gpf urinals and 1.6 gpf toilets would save \$3,600 annually.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-7 Water Conservation (Low Flow Fixtures)

| Budgetary Cost | Annual Utility Savings | | | Estimated Maintenance Savings | Total Savings | ROI | Potential Incentive* | Payback (without Incentive) | Payback (with Incentive) | |
|-------------------|------------------------|-----|-------|-------------------------------------|------------------|-------|-------------------------|-----------------------------------|--------------------------------|-------|
| | Electricity | | Water | | | | | | | Total |
| \$ | kW | kWh | Kgal | \$ | \$ | | \$ | Years | Years | |
| 65,000 | 0 | 0 | 610 | 3,600 | 0 | 3,600 | 0.1 | 0 | 18.1 | 18.1 |

* Incentive not applicable for this measure.

This measure is not recommended.

5.0 PROJECT INCENTIVES

5.1 Incentives Overview

5.1.1 New Jersey Pay For Performance Program

The facility will be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects applied to facilities whose demand in any of the preceding 12 months exceeds 100 kW. This average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations, however. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP).

- Incentive Amount: \$0.10/SF
- Minimum incentive: \$5,000
- Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved

Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved

Incentives #2 and #3 can be combined to yield additive savings.

Combining incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

Total P4P incentives are summarized below:

| Total Recommended Project Savings 14.4% | Incentives \$ | | |
|--|---------------|------------|----------------|
| | Elec | Gas | Total |
| Incentive #1 | \$0 | \$0 | \$5,000 |
| Incentive #2 | \$0 | \$0 | \$0 |
| Incentive #3 | \$0 | \$0 | \$0 |
| Total All Incentives | \$0 | \$0 | \$5,000 |

The current ECM's does not meet the minimum savings of 15% and therefore the building will not be eligible for incentives #2 and #3. See Appendix D for additional details.

5.1.2 New Jersey Smart Start Program

For this program, specific incentives for energy conservation measures are calculated on an individual basis utilizing the 2011 New Jersey Smart Start incentive program. This program provides incentives dependent upon mechanical and electrical equipment. If applicable, incentives from this program are reflected in the ECM summaries and attached appendices.

If the complex qualifies and enters into the New Jersey Pay for Performance Program, all energy savings will be included in the total site energy reduction, and savings will be applied towards the Pay for Performance incentive. A project is not applicable for both New Jersey incentive programs.

5.1.3 Direct Install Program

The Direct Install Program targets small and medium sized facilities where the peak electrical demand does not exceed 150 kW in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric or natural gas utility companies.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, natural gas, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can significantly reduce the implementation cost of energy conservation projects.

The program pays 70% of each project cost up to \$75,000 per electrical utility account; total funding for each year is capped at \$250,000 per customer. Installations must be completed by a Direct Install

participating contractor, a list of which can be found on the New Jersey Clean Energy Website at <http://www.njcleanenergy.com>. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this document.

The Penns Grove Middle School has a peak demand of 141 kW and therefore would be eligible for incentives under the Direct Install Program.

5.1.4 Energy Savings Improvement Plans (ESIP)

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use “energy savings obligations” to pay for the capital costs of energy improvements to their facilities. This can be done over a maximum term of 15 years. Energy savings obligations are not considered “new general obligation debt” of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding bonds or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The “Local Finance Notice” outlines how local governments can develop and implement an ESIP for their facilities (see Appendix E). The ESIP can be prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs.

6.0 ALTERNATIVE ENERGY SCREENING EVALUATION

6.1 Solar

6.1.1 Photovoltaic Rooftop Solar Power Generation

The facility was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The building's roof has sufficient room to install a large solar cell array. All rooftop areas have been replaced, and are in good condition. It is recommended to install a permanent PV array at this time.

The PVWATTS solar power generation model was utilized to calculate PV power generation. The closest city available in the model is Newark, New Jersey and a fixed tilt array type was utilized to calculate energy production. The PVWATT solar power generation model is provided in Appendix F.

Federal tax credits are also available for renewable energy projects up to 30% of installation cost. Since the facility is a non-profit organization, federal taxes are paid and this project is eligible for this incentive.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey solar renewable energy certificates program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. The average SREC value per credit is estimated to be about \$60/ SREC per year based on current market data, and this number was utilized in the cash flow for this report.

The existing available roof area justifies the use of 40 kW PV solar array. The system costs for PV installations were derived from contractor budgetary pricing in the state of New Jersey for estimates of total cost of system installation. It should be noted that the cost of installation is currently about \$4.00 per watt or \$4,000 per kW of installed system, for a 40 kW system. Other cost considerations will also need to be considered. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix F and summarized as follows:

Photovoltaic (PV) Rooftop Solar Power Generation

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | * Federal Tax Credit | New Jersey Renewable ** SREC | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|---------------|----------|--------------|-------------------------------------|------------------|-------------------------------|---------------------------------------|-----------------------------------|--------------------------------|
| | kW | kWh | therms | \$ | | | | | | |
| \$ | | | | \$ | \$ | \$ | \$ | Years | Years | |
| 160,000 | 40 | 52,600 | 0 | 6,500 | 0 | 6,500 | 0 | 3,200 | 24.8 | 16.6 |

This measure is not recommended due to the long payback time. It is suggested, however, that the market for SREC credits is closely monitored. This market is fluctuating, and if the value per SREC is increased the measure could potentially show for a shorter payback in the near future

6.1.2 Solar Thermal Hot Water Plant

Active solar thermal systems use solar collectors to gather the sun's energy to heat water, another fluid, or air. An absorber in the collector converts the sun's energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site's latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production. DHW is presently produced by gas-fired water heaters and, therefore, this measure would offer natural gas utility savings.

Currently, an incentive is not available for installation of thermal solar systems; a Federal tax credit of 30% of installation cost for the thermal applications is available. This is not recommended since the facility currently uses natural gas, the building is not occupied year-round, and domestic hot water demand is not excessive.

6.2 Demand Response Curtailment

Presently, electricity is delivered by South Jersey Energy Company, which receives the electricity from regional power grid RFC. South Jersey Energy Company is a regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the utility provider's regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and utility provider offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. From July 2011 through June 2012, the Penns Grove Middle School had a maximum electricity demand of 141 kW and a minimum of 98 kW. The monthly average over the observed 12 month period was 127 kW.

This measure is not recommended because the facility is not operating year round, and the building does not have back up/emergency generator power.

7.0 EPA PORTFOLIO MANAGER

The EPA Portfolio Manager benchmarking tool was used to assess the building's energy performance. Portfolio Manager provides a Site and Source Energy Use Intensity (EUI), as well as an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100, with 100 being the most efficient. In order for a building to receive an Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed ECMs, the Energy Star rating will increase.

The Site EUI is the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity (such as natural gas or oil), or as secondary energy, which is the product created from a raw fuel (such as electricity or district steam). Site EUI is a measure of a building's annual energy utilization per square foot. Site EUI is a good measure of a building's energy use and is utilized regularly for comparison of energy performance for similar building types.

$$\text{Site Energy Intensity} = \frac{\text{Electric Usage in kBtu} + \text{Natural Gas in kBtu}}{\text{Building Square Footage}}$$

To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, the Portfolio Manager uses the convention of Source EUIs. The source energy also accounts for all losses incurred in production, storage, transmission, and delivery of energy to the site; which provides an equivalent measure for various types of buildings with different energy sources.

$$\text{Source Energy Intensity} = \frac{\text{Electric Usage in kBtu} \times \text{Site/Source Ratio} + \text{Natural Gas in kBtu} \times \text{Site/Source Ratio}}{\text{Building Square Footage}}$$

The EPA Score, Site EUI, and Source EUI for the Penns Grove Middle School are as follows:

| Energy Intensity | Penns Grove Middle School | National Average |
|-----------------------|---------------------------|------------------|
| EPA Score | 27 | 50 |
| Site (kBtu/sf/year) | 63 | 52 |
| Source (kBtu/sf/year) | 109 | 89 |

The Penns Grove Middle School is considered a lower than average energy consumer by the EPA Portfolio Manager which gives it a higher than average EPA score. For the building to qualify for the Energy Star label the EPA score is required to be above 75. There are several energy conservation measures recommended in this report, that if implemented will further reduce the energy use intensity and increase the EPA score of the facility.

The Portfolio Manager account can be accessed by entering the username and password shown below at the login screen of the Portfolio Manager website (<https://www.energystar.gov/istar/pmpam/>).

Username: [REDACTED]
Password: [REDACTED]

A full EPA Energy Star Portfolio Manager Report is located in Appendix G.

The login information for the building's EPA Portfolio Manager Account has been provided to Frederick Weiss.

8.0 CONCLUSIONS & RECOMMENDATIONS

The Energy Conservation Measures (ECMs) identified in this report will allow for a more efficient use of energy and if pursued have the opportunity to qualify for the New Jersey SmartStart Buildings Program and/or Direct Install Program. Potential annual savings of \$11,300 for the recommended ECMs may be realized with a payback of 8.4 years. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

| Summary of Energy Conservation Measures | | | | | | | |
|---|---|--------------------|---------------------------|-------------------------------|---------------------------|------------------------------|--------------------------------|
| Energy Conservation Measure | | Approx. Costs (\$) | Approx. Savings (\$/year) | Payback (Years) w/o Incentive | Potential Incentive (\$)* | Payback (Years) w/ Incentive | Recommended For Implementation |
| ECM-1 | Install a Condensing Boiler | 1,583,000 | 5,600 | >20 | 2,600 | >20 | |
| 2 | Replace Domestic Hot Water Heater | 14,000 | 3,500 | 4.0 | 600 | 3.8 | X |
| 3 | Replace Exterior Door Seals & Sweeps | 5,000 | 400 | 12.5 | 0 | 12.5 | X |
| 4 | Lighting Replacements/Upgrades | 59,000 | 3,400 | 17.4 | 5,000 | 15.9 | |
| 5 | Lighting Controls (Occupancy Sensors) | 11,000 | 6,000 | 1.8 | 2,000 | 1.5 | |
| 6 | Lighting Replacements/Upgrades & Controls (Occupancy Sensors) | 70,000 | 7,400 | 9.5 | 7,000 | 8.5 | X |
| 7 | Water Conservation (Low Flow Fixtures) | 65,000 | 3,600 | 18.1 | 0 | 18.1 | |

APPENDIX A

Utility Usage Analysis, Energy Suppliers List

Penns Grove - Carneys Point Board of Education

100 Iona Ave, Penns Grove, NJ 08069

Utility Bills: Account Numbers

| <u>Account Number</u> | <u>School Building</u> | <u>Location</u> | <u>Type</u> | <u>Notes</u> |
|-----------------------|------------------------|---|-------------|------------------|
| 0142 0469 9996 | MS Stadium | S. Smith Ave Stadium, Penns Grove, NJ 08069 | Electric | Stadium Lighting |
| 0142 0289 9994 | Middle School | Maple & Virginia Ave, Penns Grove, NJ 08069 | Electric | |
| 2 12 35 2797 0 6 | PGR Middle School | Maple-Virginia Ave, Penns Grove, NJ | Gas | |
| 18-1586569-4 | Middle School | S. Virginia Ave, Penns Grove, NJ 08069 | Water | |

Penns Grove - Carneys Point Board of Education
 100 Iona Ave, Penns Grove, NJ 08069

Electric Service
 Delivery - ACE
 Supplier - New Energy Inc / SJ Energy Co


For Service at: MS Stadium
 Account No.: 0142 0469 9996
 Meter No.: 71411646

| Month | Consumption (kWh) | Demand (kW) | Charges | | | Unit Costs | | |
|--------------------|-------------------|-------------|-----------------|-----------------|-----------------|-----------------------|----------------------|----------------|
| | | | Total (\$) | Delivery (\$) | Supply (\$) | Blended Rate (\$/kWh) | Consumption (\$/kWh) | Demand (\$/kW) |
| July-11 | 0 | | \$5.21 | \$5.21 | | #DIV/0! | #DIV/0! | #DIV/0! |
| August-11 | 0 | | \$5.38 | \$5.38 | | #DIV/0! | #DIV/0! | #DIV/0! |
| September-11 | 237 | | \$44.54 | \$22.55 | \$21.99 | \$ 0.095 | \$ 0.188 | #DIV/0! |
| October-11 | 430 | | \$75.02 | \$33.27 | \$41.75 | \$ 0.174 | \$ 0.174 | #DIV/0! |
| November-11 | 372 | | \$64.68 | \$30.16 | \$34.52 | \$ 0.174 | \$ 0.174 | #DIV/0! |
| December-11 | 317 | | \$57.14 | \$27.72 | \$29.42 | \$ 0.180 | \$ 0.180 | #DIV/0! |
| January-12 | 0 | | \$5.73 | \$5.73 | | #DIV/0! | #DIV/0! | #DIV/0! |
| February-12 | 0 | | \$4.86 | \$4.86 | | #DIV/0! | #DIV/0! | #DIV/0! |
| March-12 | 0 | | \$5.56 | \$5.56 | | #DIV/0! | #DIV/0! | #DIV/0! |
| April-12 | 0 | | \$5.04 | \$5.04 | | #DIV/0! | #DIV/0! | #DIV/0! |
| May-12 | 0 | | \$5.21 | \$5.21 | | #DIV/0! | #DIV/0! | #DIV/0! |
| June-12 | 0 | | \$0.00 | | | #DIV/0! | #DIV/0! | #DIV/0! |
| | | | \$0.00 | | | #DIV/0! | #DIV/0! | #DIV/0! |
| | | | \$0.00 | | | #DIV/0! | #DIV/0! | #DIV/0! |
| | | | \$0.00 | | | #DIV/0! | #DIV/0! | #DIV/0! |
| | | | \$0.00 | | | #DIV/0! | #DIV/0! | #DIV/0! |
| Total (All) | 1,356 | 0.00 | \$278.37 | \$150.69 | \$127.68 | \$ 0.205 | \$ 0.205 | #DIV/0! |

Notes

Designates an Interpolated value (data missing)

Electric Usage - Middle School Stadium - 0142 0469 9996



Penns Grove - Carneys Point Board of Education
100 Iona Ave, Penns Grove, NJ 08069

Electric Service
Delivery - ACE
Supplier - New Energy Inc / SJ Energy Co


For Service at: Middle School
Account No.: 0142 0289 9994
Meter No.: 75766983

| Month | Consumption (kWh) | Demand (kW) | Charges | | | Unit Costs | | |
|--------------------|-------------------|---------------|--------------------|--------------------|--------------------|-----------------------|----------------------|----------------|
| | | | Total (\$) | Delivery (\$) | Supply (\$) | Blended Rate (\$/kWh) | Consumption (\$/kWh) | Demand (\$/kW) |
| July-11 | 34,800 | 123.00 | \$1,781.63 | \$1,781.63 | | \$ 0.051 | \$ 0.030 | \$ 5.93 |
| August-11 | 28,200 | 108.00 | \$4,100.73 | \$1,537.07 | \$2,563.66 | \$ 0.145 | \$ 0.122 | \$ 6.13 |
| September-11 | 35,700 | 98.00 | \$5,079.40 | \$1,833.91 | \$3,245.49 | \$ 0.051 | \$ 0.030 | \$ 7.69 |
| October-11 | 41,151 | 129.00 | \$1,956.31 | \$1,956.31 | \$0.00 | \$ 0.048 | \$ 0.030 | \$ 5.73 |
| November-11 | 39,300 | 126.00 | \$5,447.80 | \$1,875.04 | \$3,572.76 | \$ 0.139 | \$ 0.119 | \$ 6.13 |
| December-11 | 43,800 | 135.00 | \$6,044.24 | \$2,062.38 | \$3,981.86 | \$ 0.138 | \$ 0.119 | \$ 6.13 |
| January-12 | 44,100 | 135.00 | \$6,134.86 | \$2,125.73 | \$4,009.13 | \$ 0.139 | \$ 0.119 | \$ 6.52 |
| February-12 | 39,300 | 138.00 | \$5,432.18 | \$1,859.42 | \$3,572.76 | \$ 0.138 | \$ 0.119 | \$ 5.53 |
| March-12 | 38,550 | 135.00 | \$5,482.68 | \$1,882.64 | \$3,600.04 | \$ 0.142 | \$ 0.121 | \$ 5.92 |
| April-12 | 37,800 | 132.00 | \$5,342.26 | \$1,905.86 | \$3,436.40 | \$ 0.141 | \$ 0.119 | \$ 6.33 |
| May-12 | 38,100 | 123.00 | \$5,237.19 | \$1,773.52 | \$3,463.67 | \$ 0.137 | \$ 0.119 | \$ 5.73 |
| June-12 | 41,400 | 141.00 | \$4,761.66 | \$1,992.01 | \$2,769.65 | \$ 0.115 | \$ 0.095 | \$ 5.93 |
| Total (All) | 462,201 | 141.00 | \$56,800.94 | \$22,585.52 | \$34,215.42 | \$ 0.123 | \$ 0.096 | \$ 6.11 |

Notes

Designates an Interpolated value (data missing)

Electric Usage - Middle School 2 - 0142 0289 9994



Penns Grove - Carneys Point Board of Education
Maple & Virginia Ave, Penns Grove, NJ 08069

Gas Service
Delivery -
Supplier -

For Service at: PGR Middle School
Account No.: 2 12 35 2797 0 6
Meter No.: 0292403
0326049


| Month | Total (\$) | Delivery (\$) | Supply (\$) | Total Therms | \$/Therm |
|--------------|---------------------|---------------------|---------------------|------------------|----------------|
| Jul-11 | \$ 84.51 | \$ 50.75 | \$ 33.76 | 52.94 | \$ 1.60 |
| Aug-11 | \$ 81.25 | \$ 48.85 | \$ 32.40 | 50.81 | \$ 1.60 |
| Sep-11 | \$ 59.61 | \$ 41.02 | \$ 18.59 | 29.15 | \$ 2.04 |
| Oct-11 | \$ 135.69 | \$ 72.45 | \$ 63.24 | 99.17 | \$ 1.37 |
| Nov-11 | \$ 2,139.64 | \$ 948.01 | \$ 1,191.63 | 1,868.66 | \$ 1.15 |
| Dec-11 | \$ 5,377.38 | \$ 2,361.53 | \$ 3,015.85 | 4,729.33 | \$ 1.14 |
| Jan-12 | \$ 9,938.05 | \$ 4,872.89 | \$ 5,065.16 | 9,845.02 | \$ 1.01 |
| Feb-12 | \$ 9,530.73 | \$ 4,862.99 | \$ 4,667.74 | 9,921.65 | \$ 0.96 |
| Mar-12 | \$ 8,785.55 | \$ 4,604.66 | \$ 4,180.89 | 9,388.94 | \$ 0.94 |
| Apr-12 | \$ 5,365.20 | 2,841.90 | 2,523.30 | 5,774.36 | \$ 0.92 |
| May-12 | \$ 1,944.85 | \$ 1,079.14 | \$ 865.71 | 2,159.78 | \$ 0.90 |
| Jun-12 | \$ 150.34 | \$ 90.10 | \$ 60.24 | 135.85 | \$ 1.11 |
| Total | \$ 43,592.80 | \$ 21,874.29 | \$ 21,718.51 | 44,055.66 | \$ 0.99 |

Monthly annual
DHW 74 883
HHW Heating 43,173

Notes

Designates an interpolated value (no data given)

Natural Gas Usage - Penns Grove MS: 2 12 35 2797 0 6




Penns Grove - Carneys Point Board of Education
100 Iona Ave, Penns Grove, NJ 08069

For Service at: Middle School
Account No.: 18-1586569-4
Meter No.: 60580379 2 Inch

| Month | Total (\$) | Gallons (2 Inch) | \$/kGal |
|--------------|--------------------|-----------------------------|----------------|
| Aug-11 | \$ 107.72 | 11,000 | \$ 9.79 |
| Sep-11 | \$ 361.24 | 72,000 | \$ 5.02 |
| Oct-11 | \$ 872.11 | 195,000 | \$ 4.47 |
| Nov-11 | \$ 244.80 | 44,000 | \$ 5.56 |
| Dec-11 | \$ 469.14 | 98,000 | \$ 4.79 |
| Jan-12 | \$ 286.34 | 54,000 | \$ 5.30 |
| Feb-12 | \$ 356.97 | 71,000 | \$ 5.03 |
| Mar-12 | \$ 315.41 | 61,000 | \$ 5.17 |
| Apr-12 | \$ 302.96 | 58,000 | \$ 5.22 |
| May-12 | \$ 268.21 | 49,000 | \$ 5.47 |
| Jun-12 | \$ 277.64 | 46,000 | \$ 6.04 |
| Jul-12 | \$ 148.00 | 17,000 | \$ 8.71 |
| Jul-12 | | | #REF! |
| Aug-12 | | | #REF! |
| Sep-12 | | | #REF! |
| Total | \$ 2,669.47 | 776,000 | \$ 5.88 |

Water - Middle School



ATLANTIC CITY ELECTRIC SERVICE TERRITORY

Last Updated: 09/11/12

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I – INDUSTRIAL**

| Supplier | Telephone | *Customer |
|---|--|-------------------------------|
| Alpha Gas and Electric, LLC 641 5th Street Lakewood, NJ 08701 | (855) 553-6374 www.alphagasandelectric.com | R/C ACTIVE |
| Ambit Northeast, LLC 103 Carnegie Center Suite 300 Princeton, NJ 08540 | (877) 30-AMBIT (877) 302-6248 www.ambitenergy.com | R/C ACTIVE |
| American Powernet Management, LP 437 North Grove St. Berlin, NJ 08009 | (877) 977-2636 www.americanpowernet.com | C ACTIVE |
| Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621 | (201) 384-5552 | R/C/I ACTIVE |
| BBPC, LLC d/b/a Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540 | 888-651-4121 www.greateasternenergy.com | C/I ACTIVE |
| Champion Energy Services, LLC 72 Avenue L Newark, NJ 07105 | (877) 653-5090 www.championenergyservices.com | R/C/I ACTIVE |
| Clearview Electric, Inc. 505 Park Drive Woodbury, NJ 08096 | (888) CLR-VIEW (800) 746- 4702 www.clearviewenergy.com | R/C/I ACTIVE |
| ConEdison Solutions Cherry Tree Corporate Center 535 State Highway Suite 180 Cherry Hill, NJ 08002 | (888) 665-0955 www.conedsolutions.com | C/I ACTIVE |
| Constellation NewEnergy, Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446 | (866) 237-7693 www.constellation.com | R/C/I ACTIVE |
| Constellation Energy 900A Lake Street, Suite 2 Ramsey, NJ 07446 | (877) 997-9995 www.constellation.com | R ACTIVE |
| Direct Energy Business, LLC 120 Wood Avenue | (888) 925-9115 www.directenergybusiness.com | C/I ACTIVE |
| Direct Energy Services, LLC 120 Wood Avenue | (866) 547-2722 www.directenergy.com | C/I ACTIVE |
| Discount Energy Group, LLC 811 Church Road, Suite 149 | (800) 282-3331 www.discountenergygroup.com | R/C ACTIVE |
| DTE Energy Supply, Inc. One Gateway Center, Suite 2600 | 877-332-2450 www.dtesupply.com | C/I ACTIVE |
| Energy Plus Holdings LLC 309 Fellowship Road | (877) 866-9193 www.energypluscompany.com | R/C ACTIVE |
| Ethical Electric Benefit Co. d/b/a Ethical Electric | (888) 444-9452 www.ethicalelectric.com | R/C ACTIVE |
| FirstEnergy Solutions Corp. 300 Madison Avenue | (800) 977-0500 www.fes.com | C/I ACTIVE |
| Gateway Energy Services Corporation | (800) 805-8586 www.gesc.com | R/C/I ACTIVE |
| GDF SUEZ Energy Resources NA, Inc. | (866) 999-8374 www.gdfsuezenergyresources.com | C/I ACTIVE |
| Glacial Energy of New Jersey, Inc. Lafayette, NJ 07848 | (888) 452-2425 www.glacialenergy.com | C/I ACTIVE |

| | | |
|---|---|-----------------|
| Hess Corporation 1 Hess Plaza | (800) 437-7872 www.hess.com | C/I ACTIVE |
| HIKO Energy, LLC 655 Suffern Road | (888) 264-4908 www.hikoenergy.com | R/C ACTIVE |
| IDT Energy, Inc. 550 Broad Street | (973) 438-4380 www.idtenergy.com | R/C ACTIVE |
| Independence Energy Group, LLC | (877) 235-6708 www.chooseindependence.com | R/C ACTIVE |
| Integrus Energy Services, Inc. 99 Wood Avenue, South | (877) 769-9977 www.integrusenergy.com | C/I ACTIVE |
| Liberty Power Delaware, LLC 3000 Atrium Way, Suite 273 | (866) 769-3799 www.libertypowercorp.com | R/C/I ACTIVE |
| Liberty Power Holdings, LLC 3000 Atrium Way, Suite 273 | (866) 769-3799 www.libertypowercorp.com | R/C/I ACTIVE |
| Linde Energy Services 575 Mountain Avenue | (800) 247-2644 www.linde.com | C/I ACTIVE |
| NATGASCO, Inc. 532 Freeman St. | (973) 678-1800 x. 251 www.supremeenergyinc.com | R/C ACTIVE |
| NextEra Energy Services New Jersey, LLC | (877) 528-2890 Commercial (800) 882-1276 Residential | R/C/I ACTIVE |
| NJ Gas & Electric 1 Bridge Plaza fl. 2 | 866-568-0290 www.NJGandE.com | R/C/I ACTIVE |
| Noble Americas Energy Solutions The Mac-Cali Building | (877) 273-6772 www.noblesolutions.com | C/I ACTIVE |
| North American Power and Gas, LLC 222 Ridgedale Ave. | (888) 313-9086 www.napower.com | R/C/I ACTIVE |
| Palmco Power NJ, LLC One Greentree Centre | (877) 726-5862 www.PalmcoEnergy.com | R/C/I ACTIVE |
| Pepco Energy Services, Inc. 112 Main St. | (800) ENERGY-9 (363-7499) www.pepco-services.com | C/I ACTIVE |
| PPL EnergyPlus, LLC 811 Church Road | (800) 281-2000 www.pplenergyplus.com | C/I ACTIVE |
| Public Power & Utility of New Jersey, LLC | (888) 354-4415 www.ppandu.com | R/C/I ACTIVE |
| Reliant Energy | (877) 297-3795 (877) 297-3780 www.reliant.com/pjm | R C/I ACTIVE |
| ResCom Energy LLC 18C Wave Crest Ave. | (888) 238-4041 http://rescomenergy.com | R/C/I ACTIVE |
| Respond Power LLC 10 Regency CT | (877) 973-7763 www.respondpower.com | R/C/I ACTIVE |
| South Jersey Energy Company 1 South Jersey Plaza, Route 54 | (800) 266-6020 www.southjerseyenergy.com | C/I ACTIVE |
| Sperian Energy Corp. 1200 Route 22 East, Suite 2000 | (888) 682-8082 | R/C/I ACTIVE |
| Starion Energy PA Inc. 101 Warburton Avenue | (800) 600-3040 www.starionenergy.com | R/C/I ACTIVE |
| Stream Energy 309 Fellowship Road, Suite 200 | (877) 369-8150 www.streamenergy.net | R ACTIVE |
| UGI Energy Services, Inc. d/b/a GASMARK 224 Strawbridge Drive | (856) 273-9995 www.ugienergyservices.com | C/I ACTIVE |
| Verde Energy USA, Inc. 50 East Palisades Avenue | (800) 388-3862 www.lowcostpower.com | R/C/I ACTIVE |
| Viridian Energy 2001 Route 46, Waterview Plaza | (866) 663-2508 www.viridian.com | R/C/I ACTIVE |
| Xoom Energy New Jersey, LLC 744 Broad Street | 888-997-8979 www.xoomenergy.com | R/C/I ACTIVE |
| YEP Energy 89 Headquarters Plaza North | 855-363-7736 www.yepenergyNJ.com | R/C/I ACTIVE |
| Your Energy Holdings, LLC One International | (855) 732-2493 www.thisisyourenergy.com | R/C/I ACTIVE |

[Back to main supplier information page](#)

SOUTH JERSEY GAS SERVICE TERRITORY

Last Updated: 09/11/12

***CUSTOMER CLASS - R – RESIDENTIAL C – COMMERCIAL I - INDUSTRIAL**

| Supplier | Telephone | Customer |
|--|---|-----------------------|
| Alpha Gas and Electric, LLC 641 5th Street Lakewood, NJ 08701 | (855) 553-6374 www.alphagasandelectric.com | R/C ACTIVE |
| Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621 | 201- 384-5552 www.astralenergyllc.com | R/C/I ACTIVE |
| BBPC, LLC d/b/a Great Eastern Energy 116 Village Blvd. Suite 200 Princeton, NJ 08540 | 888-651-4121 www.greateasternenergy.com | C/I ACTIVE |
| Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave. Pennsauken, NJ 08110 | 800-746-4720 www.clearviewenergy.com | R/C ACTIVE |
| Colonial Energy, Inc. 83 Harding Road Wyckoff, NJ 07481 | 845-429-3229 www.colonialgroupinc.com | C/I ACTIVE |
| Commerce Energy, Inc. 7 Cedar Terrace Ramsey, NJ 07746 | (888) 817 8572 www.commerceenergy.com | R ACTIVE |
| Compass Energy Services, Inc. 1085 Morris Avenue, Suite 150 Union, NJ 07083 | 866-867-8328 908-638-6605 www.compassenergy.net | C/I ACTIVE |
| Consolidated Edison Solutions, Inc. Cherry Tree Corporate Center 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002 | 888-665-0955 www.conedsolutions.com | C/I ACTIVE |
| Constellation NewEnergy-Gas Division, LLC 900A Lake Street, Suite 2 Ramsey, NJ 07466 | (800) 900-1982 www.constellation.com | C/I ACTIVE |
| Direct Energy Business, LLC 120 Wood Avenue, Suite 611 Iselin, NJ 08830 | 888-925-9115 www.directenergy.com | C/I ACTIVE |
| Direct Energy Services, LLP 120 Wood Avenue, Suite 611 Iselin, NJ 08830 | 866-547-2722 www.directenergy.com | R/C/I INACTIVE |
| Energy Plus Natural Gas LP 309 Fellowship Road, East Gate Center, Suite 200 Mt. Laurel, NJ 08054 | (877) 866-9193 www.energypluscompany.com | R/C ACTIVE |
| Gateway Energy Services Corp. 44 Whispering Pines Lane Lakewood, NJ 08701 | 800-805-8586 www.gesc.com | R/C/I ACTIVE |
| UGI Energy Services, Inc. d/b/a GASMARK 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057 | 856-273-9995 www.ugienergyservices.com | C/I ACTIVE |
| Glacial Energy of New Jersey, Inc. 75 Route 15 Building E Lafayette, NJ 07848 | 888-452-2425 www.glacialenergy.com | C/I ACTIVE |
| Global Energy Marketing, LLC 129 Wentz Avenue Springfield, NJ 07081 | 800-542-0778 www.globalp.com | C/I ACTIVE |

| | | |
|---|--|---------------------|
| Great Eastern Energy 116 Village Blvd., Suite 200 Princeton, NJ 08540 | 888-651-4121 www.greateastern.com | C/I ACTIVE |
| Greenlight Energy 330 Hudson Street, Suite 4 Hoboken, NJ 07030 | 718-204-7467 www.greenlightenergy.us | C ACTIVE |
| Hess Energy, Inc. One Hess Plaza Woodbridge, NJ 07095 | 800-437-7872 www.hess.com | C/I ACTIVE |
| Hess Small Business Services, LLC One Hess Plaza Woodbridge, NJ 07095 | 888-494-4377 www.hessenergy.com | C/I ACTIVE |
| HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666 | (888) 264-4908 www.hikoenergy.com | R/C ACTIVE |
| IDT Energy, Inc. 550 Broad Street Newark, NJ 07102 | 973-438-4380 www.idtenergy.com | R/C ACTIVE |
| | | |
| Integrays Energy Services – Natural Gas, LLC 99 Wood Avenue South Suite #802 Iselin, NJ 08830 | (800) 536-0151 www.integraysenergy.com | C/I ACTIVE |
| Intelligent Energy 2050 Center Avenue, Suite 500 Fort Lee, NJ 07024 | 800-927-9794 www.intelligentenergy.org | R/C/I ACTIVE |
| Metromedia Energy, Inc. 6 Industrial Way Eatontown, NJ 07724 | 800-828-9427 www.metromediaenergy.com | C ACTIVE |
| MxEnergy, Inc. 900 Lake Street Ramsey, NJ 07446 | 800-758-4374 www.mxenergy.com | R/C/I ACTIVE |
| NATGASCO (Mitchell Supreme) 532 Freeman Street Orange, NJ 07050 | 800-840-4GAS www.natgasco.com | C ACTIVE |
| New Jersey Gas & Electric 1 Bridge Plaza, Fl. 2 Fort Lee, NJ 07024 | 866-568-0290 www.NJGandE.com | R/C ACTIVE |
| North American Power & Gas, LLC d/b/a North American Power 197 Route 18 South Ste. 3000 East Brunswick, NJ 08816 | (888) 313-9086 www.napower.com | C/I ACTIVE |
| Palmco Energy NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201 Marlton, NJ 08053 | 877-726-5862 www.PalmcoEnergy.com | R/C/I ACTIVE |
| Pepco Energy Services, Inc. 112 Main Street Lebanon, NJ 08833 | 800-363-7499 www.pepco-services.com | C/I ACTIVE |
| Plymouth Rock Energy, LLC 338 Maitland Avenue Teaneck, NJ 07666 | (855) 32-POWER (76937) www.plymouthenergy.com | R/C/I ACTIVE |
| PPL EnergyPlus, LLC 811 Church Road - Office 105 Cherry Hill, NJ 08002 | 800-281-2000 www.pplenergyplus.com | C/I ACTIVE |

| | | |
|--|---|-----------------------|
| Shell Energy North America (US) L.P. 17 Denison Street, Room 101B Highland Park, NJ 08904 | 800-281-2824 www.shell.com/us/energy | C/I ACTIVE |
| South Jersey Energy Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037 | 800-266-6020 www.southjerseyenergy.com | C/I ACTIVE |
| Sprague Energy Corp. 12 Ridge Road Chatham Township, NJ 07928 | 855-466-2842 www.spragueenergy.com | C/I ACTIVE |
| Stream Energy New Jersey, LLC 309 Fellowship Road Suite 200 Mt. Laurel, NJ 08054 | (973) 494-8097 www.streamenergy.net | R/C ACTIVE |
| Woodruff Energy 73 Water Street Bridgeton, NJ 08302 | 800- 557-1121 www.woodruffenergy.com | R/C/I ACTIVE |
| Woodruff Energy US LLC 73 Water Street, P.O. Box 777 Bridgeton, NJ 08302 | 856-455-1111 800-557-1121 www.woodruffenergy.com | C/I ACTIVE |
| Xoom Energy New Jersey, LLC 744 Broad Street Newark, NJ 07102 | 888-997-8979 www.xoomenergy.com | R/C/I ACTIVE |
| Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400 | (855) 732-2493 www.thisisyourenergy.com | R/C/I ACTIVE |

[Back to main supplier information page](#)

APPENDIX B

Equipment Inventory

New Jersey BPU Energy Audit Program
 CHA #24510
 Penns Grove-Carneys Point Regional School District
 Penns Grove Middle School
 Original Construction Date: 1935
 Renovation/Addition Date: 1954

| Description | QTY | Manufacturer Name | Model No. | Serial No. | Equipment Type / Utility | Capacity/Size/ Efficiency | Location | Areas/Equipment Served | Date Installed | Remaining Useful Life (years) | Other Info. |
|--------------------|-----|----------------------|-------------------|---------------|---------------------------------|----------------------------|---------------------------|------------------------|----------------|-------------------------------|-------------|
| Boiler-1 | 1 | H.B. Smith | M450L | N/A | Boiler | 2903 MBH Min /6968 MBH Max | Mechanical Equipment Room | School | 1954 | -23 | N/A |
| Air Compressor | 1 | Baldor | M3167T | 35B01-754 | Air Compressor | 2 HP | Mechanical Equipment Room | School | 1954 | -38 | N/A |
| DHW Heater | 1 | Bradford-White | MII120-18-3SF-39 | XB-01-1343 | Storage Tank Water Heater | 120 Gallons @180F /18 kW | Mechanical Equipment Room | School | 2000 | 8 | N/A |
| Motor | 1 | Baldor | M3219T | 36B01-194 | Air Compressor Motor | 7.5 HP /3-Phase | Mechanical Equipment Room | School | 1954 | -40 | N/A |
| DHW Heat Exchanger | 1 | Bell & Gossett | 10VLR2-5 | E7171-34902AF | Heat Exchanger | 3-Phase | Mechanical Equipment Room | School | 1954 | -34 | N/A |
| DHW Pump | 1 | Marathon Electric | HVL 56T34D55988 P | DMO 076 | Pump | 1.5 HP /3-Phase | Mechanical Equipment Room | School | 1995 | 3 | N/A |
| DHW Heater | 1 | State Industries Inc | CV 6 1SMS8 K | J95893201 | Electric Water Heater | 6 Gallons /1.65 kW | Custodial Room | School | 2000 | 8 | N/A |
| CU | 1 | Carrier | 24ACA330A300 | 2506E29949 | Condensor Unit | 3 Ton /13 SEER | Outside | School | 2006 | 14 | N/A |
| CU | 1 | Carrier | 24ANA736A300 | 2606E37444 | Condensor Unit | 5 Ton /17 SEER | Outside | School | 2006 | 14 | N/A |
| Window A/C | 1 | General Electric | AEH24DKH1 | FM883135 | Air Conditioning Unit /Electric | 1.9 Ton /8.5 EER | Faculty Room | School | N/A | N/A | Good |
| Window A/C | 1 | White-Westinghouse | N/A | N/A | Air Conditioning Unit /Electric | N/A | Faculty Room | School | N/A | N/A | Poor |
| Window A/C | 1 | Fedders | A6D24E7D-A | FV139952158X | Air Conditioning Unit /Electric | 2 Ton /8.5 EER | Faculty Room | School | N/A | N/A | Good |
| Window A/C | 1 | Fedders | A6D24E7A-L | CT518790089F | Air Conditioning Unit /Electric | 2 Ton /8.5 EER | Faculty Room | School | N/A | N/A | Fair |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

New Jersey BPU Energy Audit Program
 CHA #24510
 Penns Grove-Carneys Point Regional School District
 Penns Grove Middle School
 Original Construction Date: 1935
 Renovation/Addtion Date: 1954

| Description | QTY | Manufacturer Name | Model No. | Serial No. | Equipment Type / Utility | Capacity/Size/ Efficiency | Location | Areas/Equipment Served | Date Installed | Remaining Useful Life (years) | Other Info. |
|-------------|-----|-------------------|-----------|------------|--------------------------|---------------------------|----------|------------------------|----------------|-------------------------------|-------------|
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

APPENDIX C

ECM Calculations

Summary of Energy Conservation Measures

| Energy Conservation Measure | | Approx. Costs (\$) | Approx. Savings (\$/year) | Payback (Years) w/o Incentive | Potential Incentive (\$)* | Payback (Years) w/ Incentive | Recommended For Implementation |
|-----------------------------|--|--------------------|---------------------------|-------------------------------|---------------------------|------------------------------|--------------------------------|
| ECM-1 | Install a Condensing Boiler | 1,583,000 | 12,500 | >20 | 2,600 | >20 | |
| ECM-2 | Replace Domestic Hot Water Heater | 14,000 | 3,500 | 4.0 | 600 | 3.8 | X |
| ECM-3 | Replace Exterior Door Seals & Sweeps | 5,000 | 400 | 12.5 | 0 | 12.5 | X |
| ECM-4 | Lighting Replacement/Upgrades | 59,000 | 3,400 | 17.4 | 5,000 | 15.9 | |
| ECM-5 | Lighting Controls (Occupancy Sensors) | 11,000 | 6,000 | 1.8 | 2,000 | 1.5 | |
| ECM-6 | Lighting Replacement/Upgrades & Controls (Occupancy Sensors) | 70,000 | 7,400 | 9.5 | 7,000 | 8.5 | X |
| ECM-7 | Water Conservation (Low Flow Fixtures) | 65,000 | 3,600 | 18.1 | 0 | 18.1 | |

Penns Grove-Carneys Point Regional School District
CHA #24510
Penns Grove Middle School

ECM Summary Sheet

ECM-1 Install a Condensing Boiler

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-------|-------------|-----------------------------------|--------------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 1,583,000 | 0 | 0 | 12,700 | 12,500 | 0 | 12,500 | (0.8) | 2,600 | >20 | >20 |

ECM-2 Replace Domestic Hot Water Heater

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-----|-------------|-----------------------------------|--------------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 14,000 | 29,400 | 0 | -800 | 3,500 | 0 | 3,500 | 2.1 | 600 | 4.0 | 3.8 |

ECM-3 Replace Exterior Door Seals & Sweeps

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-------|-------------|-----------------------------------|--------------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 5,000 | 0 | 0 | 400 | 400 | 0 | 400 | (0.6) | 0 | 12.5 | 12.5 |

ECM-4 Lighting Replacement/Upgrades

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-------|-------------|-----------------------------------|--------------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 59,000 | 26,400 | 0 | 0 | 3,400 | 0 | 3,400 | (0.1) | 5,000 | 17.4 | 15.9 |

ECM-5 Lighting Controls (Occupancy Sensors)

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-----|-------------|-----------------------------------|--------------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 11,000 | 49,000 | 0 | 0 | 6,000 | 0 | 6,000 | 7.0 | 2,000 | 1.8 | 1.5 |

ECM-6 Lighting Replacement/Upgrades & Controls (Occupancy Sensors)

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-----|-------------|-----------------------------------|--------------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 70,000 | 68,000 | 0 | 0 | 7,400 | 0 | 7,400 | 0.6 | 7,000 | 9.5 | 8.5 |

ECM-7 Water Conservation (Low Flow Fixtures)

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | ROI | Incentive * | Payback (without incentive) Years | Payback (with incentive) Years |
|----------------|------------------------|-------------|----------------|----------|-------------------------------|---------------|-----|-------------|-----------------------------------|--------------------------------|
| | Electric kWh | Electric kW | Nat Gas Therms | Total \$ | | | | | | |
| \$ | | | | | \$ | \$ | | \$ | | |
| 65,000 | 0 | 0 | 0 | 3,600 | 0 | 3,600 | 0.1 | 0 | 18.1 | 18.1 |

| Utility Costs | Yearly Usage | MTCDE | Building Area | Annual Utility Cost | |
|-------------------------|--------------|------------|---------------|---------------------|-------------|
| \$ 0.123 \$/kWh blended | | 0.00042021 | 85,540 | Electric | Natural Gas |
| \$ 0.096 \$/kWh supply | 462,201 | 0.00042021 | | \$ 56,801 | \$ 43,593 |
| \$ 6.11 \$/kW | 141 | | | | |
| \$ 0.99 \$/Therm | 44,056 | 0.00533471 | | | |
| \$ 5.88 \$/kgals | 776 | | | | |

Penns Grove Middle School

| Item | Savings | | | | | | Cost | Simple Payback | MTCDE | Life Expectancy | NJ Smart Start Incentives | Direct Install Eligible (Y/N)* | Direct Install Incentives** | Max Incentives | Payback w/ Incentives*** | Simple Projected Lifetime Savings | | | | | | ROI | | | | | | | | | | | | | | | |
|---|---------|--------|--------|-------------|---------|-----------|--------------|----------------|-------|-----------------|---------------------------|--------------------------------|-----------------------------|----------------|--------------------------|-----------------------------------|---------------|---------------|-----------|------------|------------------|---------------------|-------------|--------------|--|---------------|--|----------------|---------------|-------------|--------------|------------------|----------------|------------|---------------|------------------|--------------|
| | kW | kWh | therms | cooling kWh | kgal/yr | \$ | | | | | | | | | | kW | kWh | therms | cooling | kgal/yr | \$ | | | | | | | | | | | | | | | | |
| ECM-1 | 0.0 | 0 | 12,670 | 0 | 0 | \$ 12,500 | \$ 1,582,800 | 126.6 | 67.6 | 25 | \$ 2,625 | Y | \$ 75,000 | \$ 2,625 | 126.4 | 0.0 | 0 | 316,756 | 0 | 0 | \$ 313,588 | (0.8) | | | | | | | | | | | | | | | |
| ECM-2 | 19.7 | 29,421 | -759 | 0 | 0 | \$ 3,500 | \$ 13,745 | 3.9 | 8.3 | 12 | \$ 600 | Y | \$ 9,600 | \$ 600 | 3.8 | 235.8 | 353,050 | (9,107) | 0 | 0 | \$ 42,166 | 2.1 | | | | | | | | | | | | | | | |
| ECM-3 | 0.0 | 0 | 426 | 0 | 0 | \$ 400 | \$ 5,352 | 13.4 | 2.3 | 5 | | | \$ - | \$ - | 13.4 | 0.0 | 0 | 2,130 | 0 | 0 | \$ 2,109 | (0.6) | | | | | | | | | | | | | | | |
| ECM-4 | 11.6 | 26,424 | 0 | 0 | 0 | \$ 3,400 | \$ 59,124 | 17.4 | 11.1 | 15.0 | \$ 5,010 | Y | \$ 41,400 | \$ 5,010 | 15.9 | 174.6 | 396,361 | 0 | 0 | 0 | \$ 50,851 | (0.1) | | | | | | | | | | | | | | | |
| ECM-5 | 0.0 | 49,044 | 0 | 0 | 0 | \$ 6,000 | \$ 11,340 | 1.9 | 20.6 | 15.0 | \$ 1,960 | Y | \$ 7,900 | \$ 1,960 | 1.6 | 0.0 | 735,657 | 0 | 0 | 0 | \$ 90,486 | 7.0 | | | | | | | | | | | | | | | |
| ECM-6 | 11.6 | 67,985 | 0 | 0 | 0 | \$ 7,400 | \$ 70,464 | 9.5 | 28.6 | 15.0 | \$ 6,970 | Y | \$ 49,300 | \$ 6,970 | 8.6 | 174.6 | 1,019,777 | 0 | 0 | 0 | \$ 110,699 | 0.6 | | | | | | | | | | | | | | | |
| ECM-7 | 0.0 | 0 | 0 | 0 | 608 | \$ 3,600 | \$ 65,076 | 18.1 | 0.0 | 20.0 | | Y | \$ 45,600 | \$ - | 18.1 | 0.0 | 0 | 0 | 0 | 12,167 | \$ 71,544 | 0.1 | | | | | | | | | | | | | | | |
| Total (Does Not Include ECM-13 & ECM-14) | | | | | | | | | | | | | | | | 31 | 97,406 | 12,337 | 0 | 608 | \$ 27,400 | \$ 1,737,437 | 63.4 | 106.7 | | 10,195 | | 179,500 | 10,195 | 63.0 | 410.4 | 1,372,827 | 309,780 | 0.0 | 12,167 | 540,106.3 | (0.7) |
| Total Measures with Payback <15 | | | | | | | | | | | | | | | | 31 | 97,406 | (333) | 0 | 0 | \$ 11,300 | \$ 89,561 | 7.9 | 39.2 | | 7,570 | | 58,900 | 7,570 | 7.3 | 410.4 | 1,372,827 | (6,976) | 0.0 | 0.0 | 154,974.4 | 0.7 |
| % of Existing | | | | | | | | | | | | | | | | 22% | 21% | 28% | 0% | 78% | | | | | | | | | | | | | | | | | |

**Penns Grove-Carneys Point Regional School District
CHA #24510
Penns Grove Middle School**

ECM-1: Steam heating system to hot water

Existing Fuel

Nat.Gas ▼

Proposed Fuel

Nat.Gas ▼

| Item | Value | Units | Formula/Comments |
|----------------------------------|-----------|---------|--|
| Baseline Fuel Cost | \$ 0.99 | / Therm | |
| Proposed Fuel Cost | \$ 0.99 | / Therm | |
| Baseline Fuel Use | 43,173 | Therms | Based on historical utility data |
| Existing Boiler Plant Efficiency | 65% | | Estimated or Measured |
| Baseline Boiler Load | 2,806,222 | Mbtu/yr | Baseline Fuel Use x Existing Efficiency x 100 Mbtu/Therms |
| Baseline Fuel Cost | \$ 42,741 | | |
| Proposed Boiler Plant Efficiency | 92% | | New Boiler Efficiency |
| Proposed Fuel Use | 30,502 | Therms | Baseline Boiler Load / Proposed Efficiency / 100 Mbtu/Therms |
| Proposed Fuel Cost | \$ 30,197 | | |

*Note to engineer: Link savings back to summary sheet in appropriate column.

| BOILER REPLACEMENT SAVINGS SUMMARY | | | | | |
|---|------------------------|-----------------------|----------------------|---------------|-------------------|
| | Electric Demand | Electric Usage | Nat Gas Usage | Maint. | Total Cost |
| | (kW) | (kWh) | (Therms) | (\$) | (\$) |
| Savings | 0 | 0 | 12,670 | \$0 | \$12,544 |

Penns Grove-Carneys Point Regional School District
 CHA #24510
 Penns Grove Middle School

| Multipliers | |
|-------------|------|
| Material: | 0.98 |
| Labor: | 1.22 |
| Equipment: | 1.09 |

ECM-1: Steam heating system to hot water

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|--------------------------------|-----|------|-------------|-------------|--------|----------------|------------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Demolition | 1 | LS | | \$ 50,000 | | | | | \$ 50,000 | |
| 3,000 MBH NG Condensing Boiler | 2 | EA | \$ 45,000 | \$ 45,000 | | | | | \$ 90,000 | |
| Flue Installation | 2 | EA | \$ 10,000.0 | \$ 5,000.00 | | \$ 19,520 | \$ 12,240 | \$ - | \$ 31,760 | |
| Controls | 2 | EA | \$ 1,500.0 | \$ 1,000.00 | | \$ 2,928 | \$ 2,448 | \$ - | \$ 5,376 | |
| Miscellaneous Electrical | 2 | LS | \$ 5,000 | \$ 15,000 | | \$ 9,760 | \$ 36,720 | \$ - | \$ 46,480 | |
| HW Piping | 1 | LS | \$ 150,000 | \$ 250,000 | | \$ 146,400 | \$ 306,000 | \$ - | \$ 452,400 | |
| primary pump | 2 | EA | \$ 1,500 | \$ 1,000 | | \$ 2,928 | \$ 2,448 | \$ - | \$ 5,376 | |
| Secondary pumps | 2 | EA | \$ 3,500 | \$ 2,000 | | \$ 6,832 | \$ 4,896 | \$ - | \$ 11,728 | |
| Hydronic Specialties | 1 | LS | \$ 10,000 | \$ 10,000 | | \$ 9,760 | \$ 12,240 | \$ - | \$ 22,000 | |
| Unit Ventilators | 40 | EA | \$ 5,000 | \$ 5,000 | | \$ 195,200 | \$ 244,800 | \$ - | \$ 440,000 | |
| Controls | 40 | EA | \$ 500 | \$ 500 | | \$ 19,520 | \$ 24,480 | \$ - | \$ 44,000 | |

Note: Costs are used for savings calculations only. Do not use for procurement

| | |
|---------------------|--------------------|
| \$ 1,199,120 | Subtotal |
| \$119,912.00 | 10% Contingency |
| \$263,806.40 | 20% Contractor O&P |
| \$ - | |
| \$ 1,582,800 | Total |

ECM-2: Replace two (2) Electric DHW Heaters w/ two (2) Tankless Condensing Gas-Fired DHW Heaters

Summary

* Replace Electric DHW Heater w/ Instantaneous, Condensing, Gas-Fired DHW Heater

| Item | Value | Units | Formula/Comments |
|---|----------------|---------------|---|
| Occupied days per week | 5 | days/wk | |
| Water supply Temperature | 55 | °F | Temperature of water coming into building |
| Hot Water Temperature | 120 | °F | |
| Hot Water Usage per day | 518 | gal/day | Calculated from usage below |
| Annual Hot Water Energy Demand | 72,852 | MBTU/yr | Energy required to heat annual quantity of hot water to setpoint |
| Existing Tank Size | 120 | Gallons | Per manufacturer nameplate |
| Hot Water Temperature | 150 | °F | Per building personnel |
| Average Room Temperature | 70 | °F | |
| Standby Losses (% by Volume) | 2.5% | | (2.5% of stored capacity per hour, per U.S. Department of Energy) |
| Standby Losses (Heat Loss) | 2.0 | MBH | |
| Annual Standby Hot Water Load | 17,520 | MBTU/yr | |
| Total Annual Hot Water Demand (w/ standby losses) | 90,372 | Mbtu/yr | Building demand plus standby losses |
| Existing Water Heater Efficiency | 90% | | Per Manufacturer |
| Total Annual Energy Required | 100,413 | Mbtu/yr | |
| Total Annual Electric Required | 29,421 | kWh/yr | Electrical Savings |
| Average Annual Electric Demand | 3.36 | kW | |
| Peak Electric Demand | 19.7 | kW | Per Manufacturer's Nameplate (Demand Savings) |
| New Tank Size | 0 | Gallons | tankless |
| Hot Water Temperature | 120 | °F | |
| Average Room Temperature | 70 | °F | |
| Standby Losses (% by Volume) | 2.5% | | (2.5% of stored capacity per hour, per U.S. Department of Energy) |
| Standby Losses (Heat Loss) | 0.0 | MBH | |
| Annual Standby Hot Water Load | 0 | MBTU/yr | |
| Prop Annual Hot Water Demand (w/ standby losses) | 72,852 | MBTU/yr | |
| Proposed Avg. Hot water heater efficiency | 96% | | Based on Navien CR180 instantaneous, condensing DHW Heater |
| Proposed Total Annual Energy Required | 75,888 | MBTU/yr | |
| Proposed Fuel Use | 759 | Therms/yr | Standby Losses and inefficient DHW heater eliminated |
| Elec Utility Demand Unit Cost | \$6.11 | \$/kW | |
| Elec Utility Supply Unit Cost | \$0.10 | \$/kWh | |
| NG Utility Unit Cost | \$0.99 | \$/Therm | |
| Existing Operating Cost of DHW | \$4,265 | \$/yr | |
| Proposed Operating Cost of DHW | \$751 | \$/yr | |
| Annual Utility Cost Savings | \$3,514 | \$/yr | |

Daily Hot Water Demand

| FIXTURE | *BASE WATER USE GPM | DURATION OF USE (MIN) | #USES PER DAY | | FULL TIME OCCUPANTS** | | TOTAL GAL/DAY | % HOT WATER | TOTAL HW GAL/DAY |
|--------------------------------------|---------------------|-----------------------|---------------|--------|-----------------------|--------|---------------|-------------|------------------|
| | | | MALE | FEMALE | MALE | FEMALE | | | |
| LAVATORY (Low-Flow Lavs use 0.5 GPM) | 2.5 | 0.25 | 3 | 3 | 245 | 245 | 919 | 50% | 459 |
| SHOWER | 2.5 | 5 | 1 | 1 | 0 | 0 | 0 | 75% | 0 |
| KITCHEN SINK | 2.5 | 0.5 | 1 | 1 | 3 | 3 | 8 | 75% | 6 |
| MOP SINK | 2.5 | 2 | 1 | 1 | 3 | 3 | 30 | 75% | 23 |
| Dishwasher (gal per u | 10 | 1 | 1 | 0 | 3 | 3 | 30 | 100% | 30 |
| TOTAL | | | | | | | 956 | | 518 |

Penns Grove-Carneys Point Regional School District
 CHA #24510
 Penns Grove Middle School

ECM-2 Replace electric water heaters with gas water heaters

| Multipliers | |
|-------------|------|
| Material: | 0.98 |
| Labor: | 1.22 |
| Equipment: | 1.09 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|--------------------------------------|-----|------|------------|----------|--------|----------------|----------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| Gas-Fired DHW Heater Removal | 2 | LS | | \$ 150 | | \$ - | \$ 367 | \$ - | \$ 367 | |
| High Efficiency Gas-Fired DHW Heater | 2 | LS | \$ 1,500 | \$ 1,000 | | \$ 2,928 | \$ 2,448 | \$ - | \$ 5,376 | |
| Miscellaneous Electrical | 2 | LS | \$ 300 | \$ 300 | | \$ 586 | \$ 734 | \$ - | \$ 1,320 | |
| Venting Kit | 2 | EA | \$ 450 | \$ 650 | | \$ 878 | \$ 1,591 | \$ - | \$ 2,470 | |
| Miscellaneous Piping and Valves | 2 | LS | \$ 200 | \$ 200 | | \$ 390 | \$ 490 | \$ - | \$ 880 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

Note: Costs are used for savings calculations only. Do not use for procurement

| | |
|------------------|--------------------|
| \$ 10,413 | Subtotal |
| \$ 1,041 | 10% Contingency |
| \$ 2,291 | 20% Contractor O&P |
| \$ - | |
| \$ 13,745 | Total |

Penns Grove-Carneys Point Regional School District
 CHA #24510
 Penns Grove Middle School

ECM-3: Install Door Seals

Existing: Lack of door seals result in excessive heat loss and infiltration
 Proposed: Install door seals and/or weather-stripping to reduce air infiltration

| | | | | | |
|-------------------------------|-------------|---------------------------------|-------------|-------------------------|---------------|
| Heating System Efficiency | 75% | Ex Occupied Clng Temp. | 70 *F | Ex Occupied Htg Temp. | 65 *F |
| Cooling System Efficiency | 0.00 kW/ton | Ex Unoccupied Clng Temp. | 78 *F | Ex Unoccupied Htg Temp. | 62 *F |
| Linear Feet of Door Edge | 248.75 | Cooling Occ Enthalpy Setpoint | 27.5 Btu/lb | Electricity | 0.12 \$/kWh |
| Existing Infiltration Factor* | 1.5 cfm/LF | Cooling Unocc Enthalpy Setpoint | 27.5 Btu/lb | Natural Gas | 0.99 \$/therm |
| Proposed Infiltration Factor* | 0.45 cfm/LF | | | | |

*Infiltration Factor per Carrier Handbook of Air Conditioning System Design based on average door seal gap calculated below.

| Avg Outdoor Air Temp. Bins *F | Avg Outdoor Air Enthalpy | Existing Equipment Bin Hours | Occupied Equipment Bin Hours | Unoccupied Equipment Bin Hours | EXISTING LOADS | | PROPOSED LOADS | | COOLING ENERGY | | HEATING ENERGY | |
|-------------------------------|--------------------------|------------------------------|------------------------------|--------------------------------|------------------------|------------------------|------------------------|------------------------|-------------------------|-------------------------|-------------------------|-------------------------|
| | | | | | Door Infiltration Load | Door Infiltration Load | Door Infiltration Load | Door Infiltration Load | Existing Cooling Energy | Proposed Cooling Energy | Existing Heating Energy | Proposed Heating Energy |
| | | | | | BTUH | BTUH | BTUH | BTUH | kWh | kWh | therms | therms |
| A | | B | C | D | E | F | G | H | I | J | K | L |
| 97.5 | 39.7 | 9 | 2 | 7 | -20,485 | -20,485 | -6,145 | -6,145 | 0 | 0 | 0 | 0 |
| 92.5 | 37.7 | 69 | 16 | 53 | -17,126 | -17,126 | -5,138 | -5,138 | 0 | 0 | 0 | 0 |
| 87.5 | 35.7 | 132 | 31 | 101 | -13,768 | -13,768 | -4,130 | -4,130 | 0 | 0 | 0 | 0 |
| 82.5 | 33.7 | 344 | 82 | 262 | -10,410 | -10,410 | -3,123 | -3,123 | 0 | 0 | 0 | 0 |
| 77.5 | 31.3 | 566 | 135 | 431 | -6,380 | 0 | -1,914 | 0 | 0 | 0 | 0 | 0 |
| 72.5 | 29.7 | 755 | 180 | 575 | -3,694 | 0 | -1,108 | 0 | 0 | 0 | 0 | 0 |
| 67.5 | 28 | 780 | 186 | 594 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 62.5 | 25.2 | 889 | 212 | 677 | 1,007 | 0 | 302 | 0 | 0 | 0 | 3 | 1 |
| 57.5 | 21.8 | 742 | 177 | 565 | 3,022 | 1,813 | 907 | 544 | 0 | 0 | 21 | 6 |
| 52.5 | 18.8 | 627 | 149 | 478 | 5,037 | 3,828 | 1,511 | 1,148 | 0 | 0 | 34 | 10 |
| 47.5 | 16.9 | 725 | 173 | 552 | 7,052 | 5,843 | 2,116 | 1,753 | 0 | 0 | 59 | 18 |
| 42.5 | 14.5 | 795 | 189 | 606 | 9,067 | 7,858 | 2,720 | 2,357 | 0 | 0 | 86 | 26 |
| 37.5 | 12.7 | 784 | 187 | 597 | 11,082 | 9,873 | 3,325 | 2,962 | 0 | 0 | 106 | 32 |
| 32.5 | 10.9 | 682 | 162 | 520 | 13,097 | 11,888 | 3,929 | 3,566 | 0 | 0 | 111 | 33 |
| 27.5 | 8.8 | 345 | 82 | 263 | 15,112 | 13,903 | 4,533 | 4,171 | 0 | 0 | 65 | 20 |
| 22.5 | 7.2 | 229 | 55 | 174 | 17,126 | 15,918 | 5,138 | 4,775 | 0 | 0 | 49 | 15 |
| 17.5 | 5.6 | 189 | 45 | 144 | 19,141 | 17,932 | 5,742 | 5,380 | 0 | 0 | 46 | 14 |
| 12.5 | 4.1 | 70 | 17 | 53 | 21,156 | 19,947 | 6,347 | 5,984 | 0 | 0 | 19 | 6 |
| 7.5 | 2.7 | 20 | 5 | 15 | 23,171 | 21,962 | 6,951 | 6,589 | 0 | 0 | 6 | 2 |
| 2.5 | 1.3 | 8 | 2 | 6 | 25,186 | 23,977 | 7,556 | 7,193 | 0 | 0 | 3 | 1 |
| TOTALS | | 8,760 | 2,086 | 6,674 | | | | | 0 | 0 | 609 | 183 |

| | |
|---------------------------------------|---------|
| Existing Door Infiltration | 373 cfm |
| Existing Unoccupied Door Infiltration | 373 cfm |
| Proposed Door Infiltration | 112 cfm |
| Proposed Unoccupied Door Infiltration | 112 cfm |

| | | |
|---------|------------|--------|
| Savings | 426 therms | \$ 422 |
| | 0 kWh | \$ - |
| | | \$ 422 |

**Penns Grove-Carneys Point Regional School District
CHA #24510
Penns Grove Middle School**

| Multipliers | |
|-------------|------|
| Material: | 0.98 |
| Labor: | 1.22 |
| Equipment: | 1.09 |

ECM- 3 replace door seals

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|-------------------------|-----|------|------------|----------|--------|----------------|----------|--------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| | | | | | | | | | \$ - | |
| Door Seals (3'x7') | 26 | ea | \$ 35 | \$ 50 | \$ - | \$ 888 | \$ 1,591 | \$ - | \$ 2,479 | |
| 36" Door Threshold Seal | 26 | ea | \$ 50.00 | \$ 45.00 | \$ - | \$ 1,269 | \$ 1,432 | \$ - | \$ 2,701 | |
| Side and Top Door Seal | 26 | ft | \$ 3.00 | \$ 3.00 | | \$ 76 | \$ 95 | \$ - | \$ 172 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

Note: Costs are used for savings calculations only. Do not use for procurement

| | |
|-----------------|--------------|
| \$ 5,352 | Subtotal |
| \$ - | |
| \$ - | |
| \$ - | |
| \$ 5,352 | Total |

Penns Grove-Carneys Point Regional School District
CHA #24510
Penns Grove Middle School

ECM-7 Replace urinals and flush valves with low flow

| EXISTING CONDITIONS | | |
|------------------------------------|--------|----------|
| Cost of Water / 1000 Gallons | \$5.88 | \$/ kGal |
| Urinals in Building | 11 | |
| Average Flushes / Urinal (per Day) | 20 | |
| Average Gallons / Flush | 3.0 | Gal |

| PROPOSED CONDITIONS | | |
|------------------------------------|----------|-----|
| Proposed Urinals to be Replaced | 11 | |
| Proposed Gallons / Flush | 0.5 | Gal |
| Proposed Material Cost | \$1,000 | |
| Proposed Installation Cost | \$228 | |
| Total cost of new urinals & valves | \$13,508 | |

| SAVINGS | | |
|---------------------------|----------|-------------|
| Current Urinal Water Use | 242 | kGal / year |
| Proposed Urinal Water Use | 40 | kGal / year |
| Water Savings | 202 | kGal / year |
| Cost Savings | \$1,187 | / year |
| Simple Payback | 11.37678 | years |

Penns Grove-Carneys Point Regional School District
CHA #24510
Penns Grove Middle School

ECM-7 Replace toilets and flush valves with low flow

| EXISTING CONDITIONS | | |
|------------------------------------|--------|----------|
| Cost of Water / 1000 Gallons | \$5.88 | \$/ kGal |
| Toilets in Building | 34 | |
| Average Flushes / Toilet (per Day) | 9 | |
| Average Gallons / Flush | 3.5 | Gal |

| PROPOSED CONDITIONS | | |
|--|----------|-----|
| Proposed Toilets to be Replaced | 34 | |
| Proposed Gallons / Flush | 1.6 | Gal |
| Proposed Material Cost of new Flush Valves | \$1,000 | |
| Proposed Installation cost of new Flush Valves | \$252 | |
| Total cost of new toilets & valves | \$42,568 | |

| SAVINGS | | |
|---------------------------|---------|-------------|
| Current Toilet Water Use | 377 | kGal / year |
| Proposed Toilet Water Use | 172 | kGal / year |
| Water Savings | 205 | kGal / year |
| Cost Savings | \$1,203 | / year |
| Simple Payback | 35.3801 | years |

Penns Grove-Carneys Point Regional School District
CHA #24510
Penns Grove Middle School

ECM-7: Replace faucets with low flow

| EXISTING CONDITIONS | | |
|---------------------------------|--------|----------|
| Cost of Water / 1000 Gallons | \$5.88 | \$/ kGal |
| Faucets in Building | 18 | |
| Average Uses / Faucet (per day) | 25 | Gal |
| Average Time of Use | 0.5 | min |
| Average Flowrate | 3.0 | gpm |

| PROPOSED CONDITIONS | | |
|---|---------|-----|
| Proposed Faucets to be Replaced | 18 | |
| Proposed Flowrate | 0.5 | gpm |
| Proposed Material Cost of new Faucets | \$250 | |
| Proposed Installation cost of new Faucets | \$250 | |
| Total cost of new faucets | \$9,000 | |

| SAVINGS | | |
|---------------------------|---------|-------------|
| Current Faucet Water Use | 242 | kGal / year |
| Proposed Faucet Water Use | 40 | kGal / year |
| Water Savings | 202 | kGal / year |
| Cost Savings | \$1,187 | / year |
| Simple Payback | 7.6 | years |

Energy Audit of Penns Grove Middle School
CHA Project No. 24510

ECM-4 Lighting Replacements

| Budgetary | Annual Utility Savings | | | | Estimated | Total | New Jersey | Payback | Payback |
|-----------------|------------------------|---------------|----------|----------------|-------------|----------------|----------------|---------------------|------------------|
| Cost | | | | | Maintenance | Savings | Incentive | (without incentive) | (with incentive) |
| | | | | | Savings | | | | |
| \$ | kW | kWh | therms | \$ | \$ | \$ | \$ | Years | Years |
| \$59,124 | 11.6 | 26,424 | 0 | \$4,101 | 0 | \$4,101 | \$5,010 | 14.4 | 13.2 |

*Incentive based on New Jersey Smart Start Prescriptive Lighting Measures

ECM-5 Install Occupancy Sensors

| Budgetary | Annual Utility Savings | | | | Estimated | Total | New Jersey | Payback | Payback |
|-----------------|------------------------|---------------|----------|----------------|-------------|----------------|----------------|---------------------|------------------|
| Cost | | | | | Maintenance | Savings | Incentive | (without incentive) | (with incentive) |
| | | | | | Savings | | | | |
| \$ | kW | kWh | therms | \$ | \$ | \$ | \$ | Years | Years |
| \$11,340 | 0.0 | 49,044 | 0 | \$6,027 | 0 | \$6,027 | \$1,960 | 1.9 | 1.6 |

*Incentive based on New Jersey Smart Start Prescriptive Lighting Measures

ECM-6 Lighting Replacements with Occupancy Sensors

| Budgetary | Annual Utility Savings | | | | Estimated | Total | New Jersey | Payback | Payback |
|-----------------|------------------------|---------------|----------|----------------|-------------|----------------|----------------|---------------------|------------------|
| Cost | | | | | Maintenance | Savings | Incentive | (without incentive) | (with incentive) |
| | | | | | Savings | | | | |
| \$ | kW | kWh | therms | \$ | \$ | \$ | \$ | Years | Years |
| \$70,464 | 11.6 | 67,985 | 0 | \$9,208 | 0 | \$9,208 | \$6,970 | 7.7 | 6.9 |

*Incentive based on New Jersey Smart Start Prescriptive Lighting Measures

Energy Audit of Penns Grove Middle School
 CHA Project No. 24510
 Existing Lighting

Cost of Electricity: **\$0.123** \$/kWh
\$6.11 \$/kW

| EXISTING CONDITIONS | | | | | | | | | | | | |
|---------------------|--|---|-------------------------------------|--|--|---|------------------------------|--------------------------|--|-------------------------|--------------------------------|-------|
| Field Code | Area Description | Usage | No. of Fixtures | Standard Fixture Code | NYSERDA Fixture Code | Watts per Fixture | kW/Space | Exist Control | Annual Hours | Retrofit Control | Annual kWh | Notes |
| | Unique description of the location - Room number/Room name: Floor number (if applicable) | Describe Usage Type using Operating Hours | No. of fixtures before the retrofit | "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Fixt No.) | Pre-inst. control device | Estimated annual hours for the usage group | Retrofit control device | (kW/space) * (Annual Hours) | |
| 13 | Closet | Storage Areas | 1 | S 32 P F 2 (ELE) | F42LL | 60 | 0.06 | SW | 1000 | C-OCC | 60 | |
| 18 | 230 | Classrooms | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.01 | SW | 2400 | C-OCC | 2,419 | |
| 18 | 229 | Classrooms | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.01 | SW | 2400 | C-OCC | 2,419 | |
| 71 | Womens Bathroom Closet (3rd Floor) | Storage Areas | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 1000 | C-OCC | 120 | |
| 18 | Womens Bathroom | Bath Room | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.34 | SW | 2000 | C-OCC | 672 | |
| 18 | 228 | Classrooms | 10 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.12 | SW | 2400 | NONE | 2,688 | |
| 18 | 227 | Classrooms | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.67 | SW | 2400 | NONE | 1,613 | |
| 18 | 227A | Classrooms | 4 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.45 | SW | 2400 | C-OCC | 1,075 | |
| 18 | B2 | Classrooms | 8 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.90 | SW | 2400 | C-OCC | 2,150 | |
| 18 | 126 | Classrooms | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.34 | SW | 2400 | C-OCC | 3,226 | |
| 71 | Closet | Storage Areas | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 1000 | C-OCC | 120 | |
| 18 | Hallway | Hallways | 16 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.79 | SW | 2280 | C-OCC | 4,086 | |
| X5 | Main Entrance | Hallways | 5 | CF42/1-L | CF42/1-L | 48 | 0.24 | SW | 2280 | C-OCC | 547 | |
| X5 | Main Entrance | Hallways | 4 | CF42/1-L | CF42/1-L | 48 | 0.19 | SW | 2280 | NONE | 438 | |
| 71 | Main Entrance | Hallways | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2280 | NONE | 274 | |
| 71 | Entrance | Hallways | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2280 | NONE | 274 | |
| 18 | 130 | Classrooms | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.34 | SW | 2400 | NONE | 3,226 | |
| 18 | 129 | Classrooms | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.34 | SW | 2400 | NONE | 3,226 | |
| 71 | Womens Bathroom Closet (2nd Floor) | Storage Areas | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 1000 | C-OCC | 120 | |
| 18 | Womens Bathroom | Bath Room | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.34 | SW | 2000 | C-OCC | 672 | |
| 18 | Library | Classrooms | 23 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.58 | SW | 2400 | C-OCC | 6,182 | |
| 16 | A2 | Classrooms | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.86 | SW | 2400 | NONE | 2,074 | |
| 141 | Auditorium | Auditorium | 24 | HPS 250 | HPS250/1 | 295 | 7.08 | SW | 1000 | NONE | 7,080 | |
| 71 | Auditorium | Auditorium | 4 | I 60 | I60/1 | 60 | 0.24 | SW | 1000 | NONE | 240 | |
| 16 | A1 | Classrooms | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.86 | SW | 2400 | C-OCC | 2,074 | |
| 18 | Nurse | Offices | 4 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.45 | SW | 2400 | NONE | 1,075 | |
| 16 | Nurse | Offices | 1 | T 34 R F 2 (MAG) | F42EE | 72 | 0.07 | SW | 2400 | C-OCC | 173 | |
| 35 | Main Office | Offices | 3 | T 32 R F 3 (ELE) | F43ILL/2 | 90 | 0.27 | SW | 2400 | NONE | 648 | |
| 35 | Main Office | Offices | 8 | T 32 R F 3 (ELE) | F43ILL/2 | 90 | 0.72 | SW | 2400 | C-OCC | 1,728 | |
| 35 | Vice Principal Office | Offices | 4 | T 32 R F 3 (ELE) | F43ILL/2 | 90 | 0.36 | SW | 2400 | NONE | 864 | |
| 35 | Main Office Bathroom | Bath Room | 1 | T 32 R F 3 (ELE) | F43ILL/2 | 90 | 0.09 | SW | 2000 | NONE | 180 | |
| 35 | Guidance Office | Offices | 8 | T 32 R F 3 (ELE) | F43ILL/2 | 90 | 0.72 | SW | 2400 | C-OCC | 1,728 | |
| 18 | 121 | Classrooms | 10 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.12 | SW | 2400 | C-OCC | 2,688 | |
| 18 | Mens Bathroom (2nd Floor) | Bath Room | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.34 | SW | 2000 | C-OCC | 672 | |
| 71 | Mens Bathroom (2nd Floor) | Bath Room | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2000 | C-OCC | 240 | |
| 71 | Mens Bathroom Closet (2nd Floor) | Storage Areas | 1 | I 60 | I60/1 | 60 | 0.06 | SW | 1000 | C-OCC | 60 | |
| 18 | Main Office | Offices | 2 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.22 | SW | 2400 | C-OCC | 538 | |
| X5 | Main Office Entrance | Hallways | 1 | CF42/1-L | CF42/1-L | 48 | 0.05 | SW | 2280 | C-OCC | 109 | |
| 71 | Exit | Hallways | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2280 | C-OCC | 274 | |
| 16 | 29 | Classrooms | 24 | T 34 R F 2 (MAG) | F42EE | 72 | 1.73 | SW | 2400 | C-OCC | 4,147 | |
| 18 | Hallway (2nd Floor) | Hallways | 26 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.91 | SW | 2280 | C-OCC | 6,639 | |
| 18 | Hallway (1st Floor) | Hallways | 26 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.91 | SW | 2280 | NONE | 6,639 | |
| 16 | 29-A Closet | Storage Areas | 4 | T 34 R F 2 (MAG) | F42EE | 72 | 0.29 | SW | 1000 | C-OCC | 288 | |
| 18 | 29-A | Classrooms | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.67 | SW | 2400 | C-OCC | 1,613 | |
| 71 | Womens Bathroom (1st Floor) | Bath Room | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2000 | NONE | 240 | |
| 18 | Womens Bathroom (1st Floor) | Bath Room | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.34 | SW | 2000 | NONE | 672 | |
| 18 | 27 | Classrooms | 19 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.13 | SW | 2400 | C-OCC | 5,107 | |
| 20 | Kitchen | Cafeteria | 29 | S 32 C F 1 (ELE) | F41LL | 32 | 0.93 | SW | 1600 | NONE | 1,485 | |
| 71 | Kitchen Exitway | Hallways | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2280 | NONE | 274 | |
| 71 | Kitchen Bathroom | Bath Room | 1 | I 60 | I60/1 | 60 | 0.06 | SW | 2000 | NONE | 120 | |
| 18 | Kitchen Breakroom | Staff Lounge | 4 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.45 | SW | 5000 | NONE | 2,240 | |
| 18 | Cafeteria | Cafeteria | 28 | T 32 R F 4 (ELE) | F44ILL | 112 | 3.14 | SW | 1600 | NONE | 5,018 | |

Energy Audit of Penns Grove Middle School
 CHA Project No. 24510
 Existing Lighting

Cost of Electricity: **\$0.123** \$/kWh
\$6.11 \$/kW

| EXISTING CONDITIONS | | | | | | | | | | | | |
|---------------------|--|---|-------------------------------------|---|--|---|---------------------------|--------------------------|--|-------------------------|-----------------------------|-------|
| Field Code | Area Description | Usage | No. of Fixtures | Standard Fixture Code | NYSERDA Fixture Code | Watts per Fixture | kW/Space | Exist Control | Annual Hours | Retrofit Control | Annual kWh | Notes |
| | Unique description of the location - Room number/Room name: Floor number (if applicable) | Describe Usage Type using Operating Hours | No. of fixtures before the retrofit | "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Fixt No.) | Pre-inst. control device | Estimated annual hours for the usage group | Retrofit control device | (kW/space) * (Annual Hours) | |
| 18 | 26 | Classrooms | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.34 | SW | 2400 | C-OCC | 3,226 | |
| 18 | 23 | Classrooms | 16 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.79 | SW | 2400 | C-OCC | 4,301 | |
| 18 | 22 | Classrooms | 18 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.02 | SW | 2400 | C-OCC | 4,838 | |
| 18 | Mens Bathroom (1st Floor) | Bath Room | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.34 | SW | 2000 | NONE | 672 | |
| 71 | Mens Bathroom (1st Floor) | Bath Room | 1 | I 60 | I60/1 | 60 | 0.06 | SW | 2000 | NONE | 120 | |
| 71 | Mens Bathroom Closet (1st Floor) | Storage Areas | 1 | I 60 | I60/1 | 60 | 0.06 | SW | 1000 | NONE | 60 | |
| 18 | 21 | Classrooms | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.34 | SW | 2400 | C-OCC | 3,226 | |
| 71 | Stair Tower 1 | Stairway | 8 | I 60 | I60/1 | 60 | 0.48 | SW | 3200 | NONE | 1,536 | |
| 71 | Stair Tower 2 | Stairway | 8 | I 60 | I60/1 | 60 | 0.48 | SW | 3200 | NONE | 1,536 | |
| 71 | Kitchen | Cafeteria | 8 | I 60 | I60/1 | 60 | 0.48 | SW | 1600 | NONE | 768 | |
| 47 | Girls Locker Room | Locker | 10 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.72 | SW | 2800 | NONE | 2,016 | |
| 71 | Hallway | Hallways | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2280 | NONE | 274 | |
| 71 | Hallway | Hallways | 2 | I 60 | I60/1 | 60 | 0.12 | SW | 2280 | NONE | 274 | |
| 47 | Mens Locker Room | Locker | 12 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.86 | SW | 2800 | NONE | 2,419 | |
| 13 | Office | Offices | 3 | S 32 P F 2 (ELE) | F42LL | 60 | 0.18 | SW | 2400 | C-OCC | 432 | |
| 71 | Office Bathroom | Bath Room | 1 | I 60 | I60/1 | 60 | 0.06 | SW | 2000 | NONE | 120 | |
| 18 | Exitway Gym | Hallways | 1 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.11 | SW | 2280 | NONE | 255 | |
| 18 | Exitway Gym | Hallways | 1 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.11 | SW | 2280 | NONE | 255 | |
| 35 | Principals Office | Offices | 12 | T 32 R F 3 (ELE) | F43ILL/2 | 90 | 1.08 | SW | 2400 | C-OCC | 2,592 | |
| 93 | Science Storage | Storage Areas | 1 | I 75 | I75/1 | 75 | 0.08 | SW | 1000 | NONE | 75 | |
| 18 | 220 | Classrooms | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.01 | SW | 2400 | C-OCC | 2,419 | |
| 18 | Mens Bathroom | Bath Room | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.34 | SW | 2000 | NONE | 672 | |
| 93 | Mens Bathroom Janitor Closet | inen/Utility/Wet/Janitor/Electrical | 2 | I 75 | I75/1 | 75 | 0.15 | SW | 1000 | NONE | 150 | |
| 18 | 221 | Classrooms | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.01 | SW | 2400 | C-OCC | 2,419 | |
| 16 | 222 | Classrooms | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.86 | SW | 2400 | C-OCC | 2,074 | |
| 18 | Stairway Room | Classrooms | 1 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.11 | SW | 2400 | C-OCC | 269 | |
| 18 | 224 | Classrooms | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.01 | SW | 2400 | C-OCC | 2,419 | |
| 16 | B-1 | Classrooms | 8 | T 34 R F 2 (MAG) | F42EE | 72 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 18 | Foster | Classrooms | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.67 | SW | 2400 | C-OCC | 1,613 | |
| 93 | Foster Bathroom | Bath Room | 1 | I 75 | I75/1 | 75 | 0.08 | SW | 2000 | NONE | 150 | |
| 18 | 223 | Classrooms | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.01 | SW | 2400 | C-OCC | 2,419 | |
| 47 | Main Womens Bathroom | Bath Room | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.14 | SW | 2000 | NONE | 288 | |
| 47 | Janitor Closet | inen/Utility/Wet/Janitor/Electrical | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.07 | SW | 1000 | NONE | 72 | |
| 18 | Main Boys Bathroom | Bath Room | 2 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.22 | SW | 2000 | NONE | 448 | |
| 20 | 112 | Classrooms | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 20 | 111 | Classrooms | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 20 | 114 | Classrooms | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 20 | 113 | Classrooms | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 20 | 116 | Classrooms | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 20 | 115 | Classrooms | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 47 | Roof Access / Supply Room | Storage Areas | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.14 | SW | 1000 | NONE | 144 | |
| 47 | LA/SS Supply Room | Storage Areas | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.14 | SW | 1000 | NONE | 144 | |
| 18 | Electrical and Paper Supply Room | Storage Areas | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.34 | SW | 1000 | NONE | 336 | |
| 20 | 117 | Classrooms | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.58 | SW | 2400 | C-OCC | 1,382 | |
| 47 | Faculty Lounge | Staff Lounge | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.07 | SW | 5000 | C-OCC | 360 | |
| 20 | Faculty Lounge | Staff Lounge | 10 | S 32 C F 1 (ELE) | F41LL | 32 | 0.32 | SW | 5000 | C-OCC | 1,600 | |
| 47 | Faculty Lounge Mens Bathroom | Bath Room | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.07 | SW | 2000 | NONE | 144 | |
| 47 | Faculty Lounge Womens Bathroom | Bath Room | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.07 | SW | 2000 | NONE | 144 | |
| 16 | 120 | Classrooms | 10 | T 34 R F 2 (MAG) | F42EE | 72 | 0.72 | SW | 2400 | C-OCC | 1,728 | |
| 47 | Girls Bathroom | Bath Room | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.14 | SW | 2000 | NONE | 288 | |
| 39 | Janitor Closet | inen/Utility/Wet/Janitor/Electrical | 1 | 2' 17 W F 2 (ELE) | F22ILL | 33 | 0.03 | SW | 1000 | NONE | 33 | |
| 18 | Boys Bathroom | Bath Room | 2 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.22 | SW | 2000 | NONE | 448 | |

Energy Audit of Penns Grove Middle School

CHA Project No. 24510

ECM-4 Lighting Replacements

Cost of Electricity: \$0.123 \$/kWh
 \$6.11 \$/kW

| Field Code | | EXISTING CONDITIONS | | | | | | | | | | RETROFIT CONDITIONS | | | | | | | COST & SAVINGS ANALYSIS | | | | | | |
|--|------------------------------------|-------------------------------------|--|--|---|---------------------------|--------------------------|---|-----------------------------|------------------------------------|--|--|---|-------------------------------------|-------------------------|--|-----------------------------|---|---|---|---|--------------------------------|---|---|----------------|
| | | Area Description | No. of Fixtures | Standard Fixture Code | NYSERDA Fixture Code | Watts per Fixture | kW/Space | Exist Control | Annual Hours | Annual kWh | Number of Fixtures | Standard Fixture Code | Fixture Code | Watts per Fixture | kW/Space | Retrofit Control | Annual Hours | Annual kWh | Annual kWh Saved | Annual kWh Saved | Annual \$ Saved | Retrofit Cost | NJ Smart Start Lighting Incentive | Simple Payback With Out Incentive | Simple Payback |
| Unique description of the location - Room number/Room name: Floor number (if applicable) | | No. of fixtures before the retrofit | "Lighting Fixture Code" Example = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Fixt No.) | Pre-inst. control device | Estimated daily hours for the usage group | (kW/Space) * (Annual Hours) | No. of fixtures after the retrofit | "Lighting Fixture Code" Example = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Number of Fixtures) | Retrofit control device | Estimated annual hours for the usage group | (kW/Space) * (Annual Hours) | (Original Annual kWh) - (Retrofit Annual kWh) | (Original Annual kWh) - (Retrofit Annual kWh) | (kW/Space) * (Annual Hours) - (Retrofit Annual kWh) | Cost for renovations to lighting system | Prescriptive Lighting Measures | Length of time for renovations cost to be recovered | Length of time for renovations cost to be recovered | |
| 13 | 13 | 1 | S 32 P F 2 (ELE) | F42LL | 60 | 0.1 | SW | 1000 | 60 | 1 | 0 | F42SILL | 48 | 0.0 | SW | 1,000 | 48 | 12 | 0.0 | \$ 2.35 | \$ 106.25 | \$10 | 45.1 | 8.0 | |
| 18 | 230 | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.0 | SW | 2400 | 2,419 | 9 | 0 | F44SILL | 96 | 0.9 | SW | 2,400 | 2,074 | 346 | 0.1 | \$ 53.03 | \$ 956.25 | \$90 | 18.0 | 2.5 | |
| 18 | 229 | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.0 | SW | 2400 | 2,419 | 9 | 0 | F44SILL | 96 | 0.9 | SW | 2,400 | 2,074 | 346 | 0.1 | \$ 53.03 | \$ 956.25 | \$90 | 18.0 | 2.5 | |
| 71 | Womens Bathroom Closet (3rd Floor) | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 1000 | 120 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 1,000 | 54 | 66 | 0.1 | \$ 12.95 | \$ 13.50 | \$0 | 1.0 | 0.2 | |
| 18 | Womens Bathroom | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SILL | 96 | 0.3 | SW | 2,000 | 576 | 96 | 0.0 | \$ 15.32 | \$ 318.75 | \$30 | 20.8 | 3.0 | |
| 18 | 228 | 10 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.1 | SW | 2400 | 2,688 | 10 | 0 | F44SILL | 96 | 1.0 | SW | 2,400 | 2,304 | 384 | 0.2 | \$ 58.92 | \$ 1,062.50 | \$100 | 18.0 | 2.5 | |
| 18 | 227 | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.7 | SW | 2400 | 1,613 | 6 | 0 | F44SILL | 96 | 0.6 | SW | 2,400 | 1,382 | 230 | 0.1 | \$ 35.35 | \$ 637.50 | \$60 | 18.0 | 2.5 | |
| 18 | 227A | 4 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.4 | SW | 2400 | 1,075 | 4 | 0 | F44SILL | 96 | 0.4 | SW | 2,400 | 922 | 154 | 0.1 | \$ 23.57 | \$ 425.00 | \$40 | 18.0 | 2.5 | |
| 18 | B2 | 8 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.9 | SW | 2400 | 2,150 | 8 | 0 | F44SILL | 96 | 0.8 | SW | 2,400 | 1,843 | 307 | 0.1 | \$ 47.14 | \$ 850.00 | \$80 | 18.0 | 2.5 | |
| 18 | 126 | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.3 | SW | 2400 | 3,226 | 12 | 0 | F44SILL | 96 | 1.2 | SW | 2,400 | 2,765 | 461 | 0.2 | \$ 70.70 | \$ 1,275.00 | \$120 | 18.0 | 2.5 | |
| 71 | Closet | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 1000 | 120 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 1,000 | 54 | 66 | 0.1 | \$ 12.95 | \$ 13.50 | \$0 | 1.0 | 0.2 | |
| 18 | Hallway | 16 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.8 | SW | 2280 | 4,086 | 16 | 0 | F44SILL | 96 | 1.5 | SW | 2,280 | 3,502 | 584 | 0.3 | \$ 90.50 | \$ 1,700.00 | \$160 | 18.8 | 2.6 | |
| X5 | Main Entrance | 5 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2280 | 547 | 5 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2,280 | 547 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| X5 | Main Entrance | 4 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2280 | 438 | 4 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2,280 | 438 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 71 | Main Entrance | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 2280 | 274 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 2,280 | 123 | 150 | 0.1 | \$ 23.33 | \$ 13.50 | \$0 | 0.6 | 0.1 | |
| 71 | Entrance | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 2280 | 274 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 2,280 | 123 | 150 | 0.1 | \$ 23.33 | \$ 13.50 | \$0 | 0.6 | 0.1 | |
| 18 | 130 | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.3 | SW | 2400 | 3,226 | 12 | 0 | F44SILL | 96 | 1.2 | SW | 2,400 | 2,765 | 461 | 0.2 | \$ 70.70 | \$ 1,275.00 | \$120 | 18.0 | 2.5 | |
| 18 | 129 | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.3 | SW | 2400 | 3,226 | 12 | 0 | F44SILL | 96 | 1.2 | SW | 2,400 | 2,765 | 461 | 0.2 | \$ 70.70 | \$ 1,275.00 | \$120 | 18.0 | 2.5 | |
| 71 | Womens Bathroom Closet (2nd Floor) | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 1000 | 120 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 1,000 | 54 | 66 | 0.1 | \$ 12.95 | \$ 13.50 | \$0 | 1.0 | 0.2 | |
| 18 | Womens Bathroom | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SILL | 96 | 0.3 | SW | 2,000 | 576 | 96 | 0.0 | \$ 15.32 | \$ 318.75 | \$30 | 20.8 | 3.0 | |
| 18 | Library | 23 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.6 | SW | 2400 | 6,182 | 23 | 0 | F44SILL | 96 | 2.2 | SW | 2,400 | 5,299 | 883 | 0.4 | \$ 135.51 | \$ 2,443.75 | \$230 | 18.0 | 2.5 | |
| 16 | A2 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | SW | 2400 | 2,074 | 12 | T 28 R F 2 | F42SILL | 48 | 0.6 | SW | 2,400 | 1,382 | 691 | 0.3 | \$ 106.05 | \$ 1,377.00 | \$120 | 13.0 | 1.8 | |
| 141 | Auditorium | 24 | HPS 250 | HPS250/1 | 295 | 7.1 | SW | 1000 | 7,080 | 24 | HPS 250 | HPS250/1 | 295 | 7.1 | SW | 1,000 | 7,080 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 71 | Auditorium | 4 | I 60/1 | I 60/1 | 60 | 0.2 | SW | 1000 | 240 | 4 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 1,000 | 108 | 132 | 0.1 | \$ 25.90 | \$ 27.00 | \$0 | 1.0 | 0.2 | |
| 16 | A1 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | SW | 2400 | 2,074 | 12 | T 28 R F 2 | F42SILL | 48 | 0.6 | SW | 2,400 | 1,382 | 691 | 0.3 | \$ 106.05 | \$ 1,377.00 | \$120 | 13.0 | 1.8 | |
| 18 | Nurse | 4 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.4 | SW | 2400 | 1,075 | 4 | 0 | F44SILL | 96 | 0.4 | SW | 2,400 | 922 | 154 | 0.1 | \$ 23.57 | \$ 425.00 | \$40 | 18.0 | 2.5 | |
| 16 | Nurse | 1 | T 34 R F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2400 | 173 | 1 | T 28 R F 2 | F42SILL | 48 | 0.0 | SW | 2,400 | 115 | 58 | 0.0 | \$ 8.84 | \$ 114.75 | \$10 | 13.0 | 1.8 | |
| 35 | Main Office | 3 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.3 | SW | 2400 | 648 | 3 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.3 | SW | 2,400 | 648 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 35 | Main Office | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2400 | 1,728 | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2,400 | 1,728 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 35 | Vice Principal Office | 4 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.4 | SW | 2400 | 864 | 4 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.4 | SW | 2,400 | 864 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 35 | Main Office Bathroom | 1 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.1 | SW | 2000 | 180 | 1 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.1 | SW | 2,000 | 180 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 35 | Guidance Office | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2400 | 1,728 | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2,400 | 1,728 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 18 | 121 | 10 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.1 | SW | 2400 | 2,688 | 10 | 0 | F44SILL | 96 | 1.0 | SW | 2,400 | 2,304 | 384 | 0.2 | \$ 58.92 | \$ 1,062.50 | \$100 | 18.0 | 2.5 | |
| 18 | Mens Bathroom (2nd Floor) | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SILL | 96 | 0.3 | SW | 2,000 | 576 | 96 | 0.0 | \$ 15.32 | \$ 318.75 | \$30 | 20.8 | 3.0 | |
| 71 | Mens Bathroom (2nd Floor) | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 2000 | 240 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 2,000 | 108 | 132 | 0.1 | \$ 21.06 | \$ 13.50 | \$0 | 0.6 | 0.1 | |
| 71 | Mens Bathroom Closet (2nd Floor) | 1 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 1000 | 60 | 1 | CF 26 | CFQ26/1-L | 27 | 0.0 | SW | 1,000 | 27 | 33 | 0.0 | \$ 6.47 | \$ 6.75 | \$0 | 1.0 | 0.2 | |
| 18 | Main Office | 2 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.2 | SW | 2400 | 538 | 2 | 0 | F44SILL | 96 | 0.2 | SW | 2,400 | 461 | 77 | 0.0 | \$ 11.78 | \$ 212.50 | \$20 | 18.0 | 2.5 | |
| X5 | Main Office Entrance | 1 | CF42/1-L | CF42/1-L | 48 | 0.0 | SW | 2280 | 109 | 1 | CF42/1-L | CF42/1-L | 48 | 0.0 | SW | 2,280 | 109 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 71 | Exit | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 2280 | 274 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 2,280 | 123 | 150 | 0.1 | \$ 23.33 | \$ 13.50 | \$0 | 0.6 | 0.1 | |
| 16 | 29 | 24 | T 34 R F 2 (MAG) | F42EE | 72 | 1.7 | SW | 2400 | 4,147 | 24 | T 28 R F 2 | F42SILL | 48 | 1.2 | SW | 2,400 | 2,765 | 1,382 | 0.6 | \$ 212.11 | \$ 2,754.00 | \$240 | 13.0 | 1.8 | |
| 18 | Hallway (2nd Floor) | 26 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.9 | SW | 2280 | 6,639 | 26 | 0 | F44SILL | 96 | 2.5 | SW | 2,280 | 5,691 | 948 | 0.4 | \$ 147.06 | \$ 2,762.50 | \$260 | 18.8 | 2.6 | |
| 18 | Hallway (1st Floor) | 26 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.9 | SW | 2280 | 6,639 | 26 | 0 | F44SILL | 96 | 2.5 | SW | 2,280 | 5,691 | 948 | 0.4 | \$ 147.06 | \$ 2,762.50 | \$260 | 18.8 | 2.6 | |
| 16 | 29-A Closet | 4 | T 34 R F 2 (MAG) | F42EE | 72 | 0.3 | SW | 1000 | 288 | 4 | T 28 R F 2 | F42SILL | 48 | 0.2 | SW | 1,000 | 192 | 96 | 0.1 | \$ 18.83 | \$ 459.00 | \$40 | 24.4 | 4.4 | |
| 18 | 29-A | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.7 | SW | 2400 | 1,613 | 6 | 0 | F44SILL | 96 | 0.6 | SW | 2,400 | 1,382 | 230 | 0.1 | \$ 35.35 | \$ 637.50 | \$60 | 18.0 | 2.5 | |
| 71 | Womens Bathroom (1st Floor) | 2 | I 60/1 | I 60/1 | 60 | 0.1 | SW | 2000 | 240 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | SW | 2,000 | 108 | 132 | 0.1 | \$ 21.06 | \$ 13.50 | \$0 | 0.6 | 0.1 | |
| 18 | Womens Bathroom (1st Floor) | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SILL | 96 | 0.3 | SW | 2,000 | 576 | 96 | 0.0 | \$ 15.32 | \$ 318.75 | \$30 | 20.8 | 3.0 | |
| 18 | 27 | 19 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.1 | SW | 2400 | 5,107 | 19 | 0 | F44SILL | 96 | 1.8 | SW | 2,400 | 4,378 | 730 | 0.3 | \$ 111.95 | \$ 2,018.75 | \$190 | 18.0 | 2.5 | |
| 20 | Kitchen | 29 | S 32 C F 1 (ELE) | F41LL | 32 | 0.9 | SW | 1600 | 1,485 | 29 | S 32 C F 1 (ELE) | F41LL | 32 | 0.9 | SW | 1,600 | 1,485 | 0 | 0.0 | \$ - | \$ - | \$0 | | | |
| 71 | Kitchen Exitway | 2 | I 60/1 | I 60/1 | 60 | | | | | | | | | | | | | | | | | | | | |

| Field Code | Area Description | No. of Fixtures | Standard Fixture Code | EXISTING CONDITIONS | | | | | | | RETROFIT CONDITIONS | | | | | | | COST & SAVINGS ANALYSIS | | | | | | |
|------------|--|-------------------------------------|---|--|---|---------------------------|--------------------------|--|-----------------------------|------------------------------------|---|--|---|-------------------------------------|-------------------------|--|-----------------------------|---|---|-----------------------|---|---|---|----------------|
| | | | | NYSERDA Fixture Code | Watts per Fixture | kW/Space | Exist Control | Annual Hours | Annual kWh | Number of Fixtures | Standard Fixture Code | Fixture Code | Watts per Fixture | kW/Space | Retrofit Control | Annual Hours | Annual kWh | Annual kWh Saved | Annual kWh Saved | Annual \$ Saved | Retrofit Cost | NJ Smart Start Lighting Incentive | Simple Payback With Out Incentive | Simple Payback |
| | Unique description of the location - Room number/Room name: Floor number (if applicable) | No. of fixtures before the retrofit | "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Fixt No.) | Pre-inst. control device | Estimated annual hours for the usage group | (kW/Space) * (Annual Hours) | No. of fixtures after the retrofit | "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Number of Fixtures) | Retrofit control device | Estimated annual hours for the usage group | (kW/Space) * (Annual Hours) | (Original Annual kWh) - (Retrofit Annual kWh) | (Original Annual kWh) - (Retrofit Annual kWh) | (kW Saved) * (\$/kWh) | Cost for renovations to lighting system | Length of time for renovations cost to be recovered | Length of time for renovations cost to be recovered | |
| 13 | Closet | 1 | S 32 P F 2 (ELE) | F42LL | 60 | 0.1 | SW | 1000 | 60.0 | 1 | S 32 P F 2 (ELE) | F42LL | 60 | 0.1 | NONE | 250 | 15.0 | 45.0 | 0.0 | \$5.53 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | 230 | 9 | T 32 R F 4 (ELE) | F44LL | 112 | 1.0 | SW | 2400 | 2,419.2 | 9 | T 32 R F 4 (ELE) | F44LL | 112 | 1.0 | C-OCC | 1680 | 1,693.4 | 725.8 | 0.0 | \$89.19 | \$202.50 | \$35.00 | 2.3 | 1.9 |
| 18 | 229 | 9 | T 32 R F 4 (ELE) | F44LL | 112 | 1.0 | SW | 2400 | 2,419.2 | 9 | T 32 R F 4 (ELE) | F44LL | 112 | 1.0 | C-OCC | 1680 | 1,693.4 | 725.8 | 0.0 | \$89.19 | \$202.50 | \$35.00 | 2.3 | 1.9 |
| 71 | Womens Bathroom Closet (3rd Floor) | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 1000 | 120.0 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 2000 | 120.0 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 18 | Womens Bathroom | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | SW | 2000 | 672.0 | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | NONE | 2000 | 672.0 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 18 | 228 | 10 | T 32 R F 4 (ELE) | F44LL | 112 | 1.1 | SW | 2400 | 2,688.0 | 10 | T 32 R F 4 (ELE) | F44LL | 112 | 1.1 | C-OCC | 1680 | 1,881.6 | 806.4 | 0.0 | \$99.10 | \$202.50 | \$35.00 | 2.0 | 1.7 |
| 18 | 227 | 6 | T 32 R F 4 (ELE) | F44LL | 112 | 0.7 | SW | 2400 | 1,612.8 | 6 | T 32 R F 4 (ELE) | F44LL | 112 | 0.7 | C-OCC | 1680 | 1,129.0 | 483.8 | 0.0 | \$59.46 | \$202.50 | \$35.00 | 3.4 | 2.8 |
| 18 | 227A | 4 | T 32 R F 4 (ELE) | F44LL | 112 | 0.4 | SW | 2400 | 1,075.2 | 4 | T 32 R F 4 (ELE) | F44LL | 112 | 0.4 | C-OCC | 1680 | 752.6 | 322.6 | 0.0 | \$39.64 | \$202.50 | \$35.00 | 5.1 | 4.2 |
| 18 | B2 | 8 | T 32 R F 4 (ELE) | F44LL | 112 | 0.9 | SW | 2400 | 2,150.4 | 8 | T 32 R F 4 (ELE) | F44LL | 112 | 0.9 | C-OCC | 1680 | 1,505.3 | 645.1 | 0.0 | \$79.28 | \$202.50 | \$35.00 | 2.6 | 2.1 |
| 18 | 126 | 12 | T 32 R F 4 (ELE) | F44LL | 112 | 1.3 | SW | 2400 | 3,225.6 | 12 | T 32 R F 4 (ELE) | F44LL | 112 | 1.3 | C-OCC | 1680 | 2,257.9 | 967.7 | 0.0 | \$118.92 | \$202.50 | \$35.00 | 1.7 | 1.4 |
| 71 | Closet | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 1000 | 120.0 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 250 | 30.0 | 90.0 | 0.0 | \$11.06 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | Hallway | 16 | T 32 R F 4 (ELE) | F44LL | 112 | 1.8 | SW | 2280 | 4,085.8 | 16 | T 32 R F 4 (ELE) | F44LL | 112 | 1.8 | NONE | 2280 | 4,085.8 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| X5 | Main Entrance | 5 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2280 | 547.2 | 5 | CF42/1-L | CF42/1-L | 48 | 0.2 | NONE | 2280 | 547.2 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| X5 | Main Entrance | 4 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2280 | 437.8 | 4 | CF42/1-L | CF42/1-L | 48 | 0.2 | NONE | 2280 | 437.8 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 71 | Main Entrance | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 2280 | 273.6 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 2280 | 273.6 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 71 | Entrance | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 2280 | 273.6 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 2280 | 273.6 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 18 | 130 | 12 | T 32 R F 4 (ELE) | F44LL | 112 | 1.3 | SW | 2400 | 3,225.6 | 12 | T 32 R F 4 (ELE) | F44LL | 112 | 1.3 | C-OCC | 1680 | 2,257.9 | 967.7 | 0.0 | \$118.92 | \$202.50 | \$35.00 | 1.7 | 1.4 |
| 18 | 129 | 12 | T 32 R F 4 (ELE) | F44LL | 112 | 1.3 | SW | 2400 | 3,225.6 | 12 | T 32 R F 4 (ELE) | F44LL | 112 | 1.3 | C-OCC | 1680 | 2,257.9 | 967.7 | 0.0 | \$118.92 | \$202.50 | \$35.00 | 1.7 | 1.4 |
| 71 | Womens Bathroom Closet (2nd Floor) | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 1000 | 120.0 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 250 | 30.0 | 90.0 | 0.0 | \$11.06 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | Womens Bathroom | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | SW | 2000 | 672.0 | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | NONE | 672 | 225.8 | 446.2 | 0.0 | \$54.84 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | Library | 23 | T 32 R F 4 (ELE) | F44LL | 112 | 2.6 | SW | 2400 | 6,182.4 | 23 | T 32 R F 4 (ELE) | F44LL | 112 | 2.6 | C-OCC | 1680 | 4,327.7 | 1,854.7 | 0.0 | \$227.93 | \$202.50 | \$35.00 | 0.9 | 0.7 |
| 16 | A2 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | SW | 2400 | 2,073.6 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | C-OCC | 1680 | 1,451.5 | 622.1 | 0.0 | \$76.45 | \$202.50 | \$35.00 | 2.6 | 2.2 |
| 141 | Auditorium | 24 | HPS 250 | HPS250/1 | 295 | 7.1 | SW | 1000 | 7,080.0 | 24 | HPS 250 | HPS250/1 | 295 | 7.1 | NONE | 750 | 5,310.0 | 1,770.0 | 0.0 | \$217.52 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 71 | Auditorium | 4 | I 60/1 | I60/1 | 60 | 0.2 | SW | 1000 | 240.0 | 4 | I 60/1 | I60/1 | 60 | 0.2 | NONE | 750 | 180.0 | 60.0 | 0.0 | \$7.37 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 16 | A1 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | SW | 2400 | 2,073.6 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | C-OCC | 1680 | 1,451.5 | 622.1 | 0.0 | \$76.45 | \$202.50 | \$35.00 | 2.6 | 2.2 |
| 18 | Nurse | 4 | T 32 R F 4 (ELE) | F44LL | 112 | 0.4 | SW | 2400 | 1,075.2 | 4 | T 32 R F 4 (ELE) | F44LL | 112 | 0.4 | C-OCC | 1200 | 537.6 | 537.6 | 0.0 | \$66.07 | \$202.50 | \$35.00 | 3.1 | 2.5 |
| 16 | Nurse | 1 | T 34 R F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2400 | 172.8 | 1 | T 34 R F 2 (MAG) | F42EE | 72 | 0.1 | C-OCC | 1200 | 86.4 | 86.4 | 0.0 | \$10.62 | \$202.50 | \$35.00 | 19.1 | 15.8 |
| 35 | Main Office | 3 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.3 | SW | 2400 | 648.0 | 3 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.3 | C-OCC | 1200 | 324.0 | 324.0 | 0.0 | \$39.82 | \$202.50 | \$35.00 | 5.1 | 4.2 |
| 35 | Main Office | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2400 | 1,728.0 | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | C-OCC | 1200 | 864.0 | 864.0 | 0.0 | \$106.18 | \$202.50 | \$35.00 | 1.9 | 1.6 |
| 35 | Vice Principal Office | 4 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.4 | SW | 2400 | 864.0 | 4 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.4 | C-OCC | 1200 | 432.0 | 432.0 | 0.0 | \$53.09 | \$202.50 | \$35.00 | 3.8 | 3.2 |
| 35 | Main Office Bathroom | 1 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.1 | SW | 2000 | 180.0 | 1 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.1 | NONE | 180 | 16.2 | 163.8 | 0.0 | \$20.13 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 35 | Guidance Office | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2400 | 1,728.0 | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | C-OCC | 1200 | 864.0 | 864.0 | 0.0 | \$106.18 | \$202.50 | \$35.00 | 1.9 | 1.6 |
| 18 | 121 | 10 | T 32 R F 4 (ELE) | F44LL | 112 | 1.1 | SW | 2400 | 2,688.0 | 10 | T 32 R F 4 (ELE) | F44LL | 112 | 1.1 | C-OCC | 1680 | 1,881.6 | 806.4 | 0.0 | \$99.10 | \$202.50 | \$35.00 | 2.0 | 1.7 |
| 18 | Mens Bathroom (2nd Floor) | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | SW | 2000 | 672.0 | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | NONE | 672 | 225.8 | 446.2 | 0.0 | \$54.84 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 71 | Mens Bathroom (2nd Floor) | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 2000 | 240.0 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 240 | 28.8 | 211.2 | 0.0 | \$25.95 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 71 | Mens Bathroom Closet (2nd Floor) | 1 | I 60/1 | I60/1 | 60 | 0.1 | SW | 1000 | 60.0 | 1 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 250 | 15.0 | 45.0 | 0.0 | \$5.53 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | Main Office | 2 | T 32 R F 4 (ELE) | F44LL | 112 | 0.2 | SW | 2400 | 537.6 | 2 | T 32 R F 4 (ELE) | F44LL | 112 | 0.2 | C-OCC | 1200 | 268.8 | 268.8 | 0.0 | \$33.03 | \$202.50 | \$35.00 | 6.1 | 5.1 |
| X5 | Main Office Entrance | 1 | CF42/1-L | CF42/1-L | 48 | 0.0 | SW | 2280 | 109.4 | 1 | CF42/1-L | CF42/1-L | 48 | 0.0 | NONE | 2280 | 109.4 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 71 | Exit | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 2280 | 273.6 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 2280 | 273.6 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 16 | 29 | 24 | T 34 R F 2 (MAG) | F42EE | 72 | 1.7 | SW | 2400 | 4,147.2 | 24 | T 34 R F 2 (MAG) | F42EE | 72 | 1.7 | C-OCC | 1680 | 2,903.0 | 1,244.2 | 0.0 | \$152.90 | \$202.50 | \$35.00 | 1.3 | 1.1 |
| 18 | Hallway (2nd Floor) | 26 | T 32 R F 4 (ELE) | F44LL | 112 | 2.9 | SW | 2280 | 6,639.4 | 26 | T 32 R F 4 (ELE) | F44LL | 112 | 2.9 | NONE | 2280 | 6,639.4 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 18 | Hallway (1st Floor) | 26 | T 32 R F 4 (ELE) | F44LL | 112 | 2.9 | SW | 2280 | 6,639.4 | 26 | T 32 R F 4 (ELE) | F44LL | 112 | 2.9 | NONE | 2280 | 6,639.4 | 0.0 | 0.0 | \$0.00 | \$0.00 | \$0.00 | #DIV/0! | #DIV/0! |
| 16 | 29-A Closet | 4 | T 34 R F 2 (MAG) | F42EE | 72 | 0.3 | SW | 1000 | 288.0 | 4 | T 34 R F 2 (MAG) | F42EE | 72 | 0.3 | NONE | 250 | 72.0 | 216.0 | 0.0 | \$26.54 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | 29-A | 6 | T 32 R F 4 (ELE) | F44LL | 112 | 0.7 | SW | 2400 | 1,612.8 | 6 | T 32 R F 4 (ELE) | F44LL | 112 | 0.7 | C-OCC | 1680 | 1,129.0 | 483.8 | 0.0 | \$59.46 | \$202.50 | \$35.00 | 3.4 | 2.8 |
| 71 | Womens Bathroom (1st Floor) | 2 | I 60/1 | I60/1 | 60 | 0.1 | SW | 2000 | 240.0 | 2 | I 60/1 | I60/1 | 60 | 0.1 | NONE | 240 | 28.8 | 211.2 | 0.0 | \$25.95 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | Womens Bathroom (1st Floor) | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | SW | 2000 | 672.0 | 3 | T 32 R F 4 (ELE) | F44LL | 112 | 0.3 | NONE | 672 | 225.8 | 446.2 | 0.0 | \$54.84 | \$0.00 | \$0.00 | 0.0 | 0.0 |
| 18 | 27 | 19 | T 32 R F 4 (ELE) | F44LL | 112 | 2.1 | SW | | | | | | | | | | | | | | | | | |

Energy Audit of Penns Grove Middle School
CHA Project No. 24510
ECM-6 Lighting Replacements with Occupancy Sensors

Cost of Electricity: \$0.123 \$/kWh
 \$6.11 \$/kW


| Field Code | Area Description | EXISTING CONDITIONS | | | | | | | | RETROFIT CONDITIONS | | | | | | | | COST & SAVINGS ANALYSIS | | | | | | | |
|--|------------------------------------|---|--|---|---------------------------|--------------------------|---|-----------------------------|------------------------------------|---|--|---|-------------------------------------|-------------------------|--|-----------------------------|---|---|----------------------|---|--------------------------------|---|---|----------------|--|
| | | No. of fixtures before retrofit | Standard Fixture Code | NYSERDA Fixture Code | Watts per Fixture | kW/Space | Exist Control | Annual Hours | Annual kWh | Number of Fixtures after retrofit | Standard Fixture Code | Fixture Code | Watts per Fixture | kW/Space | Retrofit Control | Annual Hours | Annual kWh | Annual kWh Saved | Annual kWh Saved | Annual \$ Saved | Retrofit Cost | NJ Smart Start Lighting Incentive | Simple Payback With Out Incentive | Simple Payback | |
| Unique description of the location - Room number/Room name: Floor number (if applicable) | No. of fixtures before retrofit | "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Fixt No.) | Pre-inst. control device | Estimated daily hours for the usage group | (kW/Space) * (Annual Hours) | No. of fixtures after the retrofit | "Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Number of Fixtures) | Retrofit control device | Estimated annual hours for the usage group | (kW/Space) * (Annual Hours) | (Original Annual kWh) - (Retrofit Annual kWh) | (Original Annual kWh) - (Retrofit Annual kWh) | (kWh Saved) (\$/kWh) | Cost for renovations to lighting system | Prescriptive Lighting Measures | Length of time for renovations cost to be recovered | Length of time for renovations cost to be recovered | | |
| 13 | Closet | 1 | S 32 P F 2 (ELE) | F42LL | 60 | 0.1 | SW | 1000 | 60 | 1 | 0 | F42SSILL | 48 | 0.0 | NONE | 250 | 12 | 48 | 0.0 | \$ 6.78 | \$ 106.25 | \$ 10 | 15.7 | 14.2 | |
| 18 | 230 | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.0 | SW | 2400 | 2,419 | 9 | 0 | F44SSILL | 96 | 0.9 | C-OCC | 1,680 | 1,452 | 968 | 0.1 | \$ 129.48 | \$ 1,158.75 | \$ 125 | 8.9 | 8.0 | |
| 18 | 230 | 9 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.0 | SW | 2400 | 2,419 | 9 | 0 | F44SSILL | 96 | 0.9 | C-OCC | 1,680 | 1,452 | 968 | 0.1 | \$ 129.48 | \$ 1,158.75 | \$ 125 | 8.9 | 8.0 | |
| 71 | Womens Bathroom Closet (3rd Floor) | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 1000 | 120 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 1,000 | 54 | 66 | 0.1 | \$ 12.95 | \$ 13.50 | \$ - | 1.0 | 1.0 | |
| 18 | Womens Bathroom | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SSILL | 96 | 1.0 | C-OCC | 2,000 | 576 | 96 | 0.0 | \$ 15.32 | \$ 318.75 | \$ 30 | 20.8 | 18.9 | |
| 18 | 228 | 10 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.1 | SW | 2400 | 2,688 | 10 | 0 | F44SSILL | 96 | 0.3 | C-OCC | 1,680 | 1,613 | 1,075 | 0.2 | \$ 143.86 | \$ 1,265.00 | \$ 135 | 8.8 | 7.9 | |
| 18 | 227 | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.7 | SW | 2400 | 1,813 | 6 | 0 | F44SSILL | 96 | 0.6 | C-OCC | 1,680 | 1,613 | 645 | 0.1 | \$ 86.32 | \$ 840.00 | \$ 95 | 9.7 | 8.6 | |
| 18 | 227A | 4 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.4 | SW | 2400 | 1,075 | 4 | 0 | F44SSILL | 96 | 0.4 | C-OCC | 1,680 | 645 | 430 | 0.1 | \$ 57.55 | \$ 627.50 | \$ 75 | 10.9 | 9.6 | |
| 18 | B2 | 8 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.9 | SW | 2400 | 2,150 | 8 | 0 | F44SSILL | 96 | 0.8 | C-OCC | 1,680 | 1,290 | 860 | 0.1 | \$ 115.09 | \$ 1,052.50 | \$ 115 | 9.1 | 8.1 | |
| 18 | 126 | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.3 | SW | 2400 | 3,226 | 12 | 0 | F44SSILL | 96 | 1.2 | C-OCC | 1,680 | 1,935 | 1,290 | 0.2 | \$ 172.64 | \$ 1,477.50 | \$ 155 | 8.6 | 7.7 | |
| 71 | Closet | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 1000 | 120 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 250 | 14 | 107 | 0.1 | \$ 17.93 | \$ 13.50 | \$ - | 0.8 | 0.8 | |
| 18 | Hallway | 16 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.8 | SW | 2280 | 4,086 | 16 | 0 | F44SSILL | 96 | 1.5 | NONE | 2,280 | 3,502 | 584 | 0.3 | \$ 90.50 | \$ 1,700.00 | \$ 160 | 18.8 | 17.0 | |
| X5 | Main Entrance | 5 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2280 | 547 | 5 | CF42/1-L | CF42/1-L | 48 | 0.2 | NONE | 2,280 | 547 | - | 0.0 | \$ - | \$ - | \$ - | - | - | |
| X5 | Main Entrance | 4 | CF42/1-L | CF42/1-L | 48 | 0.2 | SW | 2280 | 438 | 4 | CF42/1-L | CF42/1-L | 48 | 0.2 | NONE | 2,280 | 438 | - | 0.0 | \$ - | \$ - | \$ - | - | - | |
| 71 | Main Entrance | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 2280 | 274 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 2,280 | 123 | 150 | 0.1 | \$ 23.33 | \$ 13.50 | \$ - | 0.6 | 0.6 | |
| 71 | Entrance | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 2280 | 274 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 2,280 | 123 | 150 | 0.1 | \$ 23.33 | \$ 13.50 | \$ - | 0.6 | 0.6 | |
| 18 | 130 | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.3 | SW | 2400 | 3,226 | 12 | 0 | F44SSILL | 96 | 1.2 | C-OCC | 1,680 | 1,935 | 1,290 | 0.2 | \$ 172.64 | \$ 1,477.50 | \$ 155 | 8.6 | 7.7 | |
| 18 | 129 | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.3 | SW | 2400 | 3,226 | 12 | 0 | F44SSILL | 96 | 1.2 | C-OCC | 1,680 | 1,935 | 1,290 | 0.2 | \$ 172.64 | \$ 1,477.50 | \$ 155 | 8.6 | 7.7 | |
| 71 | Womens Bathroom Closet (2nd Floor) | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 1000 | 120 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 250 | 14 | 107 | 0.1 | \$ 17.93 | \$ 13.50 | \$ - | 0.8 | 0.8 | |
| 18 | Womens Bathroom | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SSILL | 96 | 0.3 | NONE | 672 | 194 | 478 | 0.0 | \$ 62.32 | \$ 318.75 | \$ 30 | 5.1 | 4.6 | |
| 18 | Library | 23 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.6 | SW | 2400 | 6,182 | 23 | 0 | F44SSILL | 96 | 2.2 | C-OCC | 1,680 | 3,709 | 2,473 | 0.4 | \$ 330.88 | \$ 2,646.25 | \$ 265 | 8.0 | 7.2 | |
| 16 | A2 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | SW | 2400 | 2,074 | 12 | T 28 R F 2 | F42SSILL | 48 | 0.6 | C-OCC | 1,680 | 968 | 1,106 | 0.3 | \$ 157.02 | \$ 1,579.50 | \$ 155 | 10.1 | 9.1 | |
| 141 | Auditorium | 24 | HPS 250 | HPS250/1 | 295 | 7.1 | SW | 1000 | 7,080 | 24 | HPS 250 | HPS250/1 | 295 | 7.1 | NONE | 750 | 5,310 | 1,770 | 0.0 | \$ 217.52 | \$ - | \$ - | - | 0.0 | |
| 71 | Auditorium | 4 | I 60 | I60/1 | 60 | 0.2 | SW | 1000 | 240 | 4 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 750 | 81 | 159 | 0.1 | \$ 29.22 | \$ 27.00 | \$ - | 0.9 | 0.9 | |
| 16 | A1 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | SW | 2400 | 2,074 | 12 | T 28 R F 2 | F42SSILL | 48 | 0.6 | C-OCC | 1,680 | 968 | 1,106 | 0.3 | \$ 157.02 | \$ 1,579.50 | \$ 155 | 10.1 | 9.1 | |
| 18 | Nurse | 4 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.4 | SW | 2400 | 1,075 | 4 | 0 | F44SSILL | 96 | 0.4 | C-OCC | 1,200 | 461 | 614 | 0.1 | \$ 80.20 | \$ 627.50 | \$ 75 | 7.8 | 6.9 | |
| 16 | Nurse | 1 | T 34 R F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2400 | 173 | 1 | T 28 R F 2 | F42SSILL | 48 | 0.0 | C-OCC | 1,200 | 58 | 115 | 0.0 | \$ 19.92 | \$ 317.25 | \$ 45 | 19.9 | 17.1 | |
| 35 | Main Office | 3 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.3 | SW | 2400 | 648 | 3 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.3 | C-OCC | 1,200 | 324 | 324 | 0.0 | \$ 39.82 | \$ 202.50 | \$ 35 | 5.1 | 4.2 | |
| 35 | Main Office | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2400 | 1,728 | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | C-OCC | 1,200 | 864 | 864 | 0.0 | \$ 106.18 | \$ 202.50 | \$ 35 | 1.9 | 1.6 | |
| 35 | Vice Principal Office | 4 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.4 | SW | 2400 | 864 | 4 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.4 | C-OCC | 1,200 | 432 | 432 | 0.0 | \$ 53.09 | \$ 202.50 | \$ 35 | 3.8 | 3.2 | |
| 35 | Main Office Bathroom | 1 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.1 | SW | 2000 | 180 | 1 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.1 | NONE | 180 | 16 | 164 | 0.0 | \$ 20.13 | \$ - | \$ - | - | 0.0 | |
| 35 | Guidance Office | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | SW | 2400 | 1,728 | 8 | T 32 R F 3 (ELE) | F43LL/2 | 90 | 0.7 | C-OCC | 1,200 | 864 | 864 | 0.0 | \$ 106.18 | \$ 202.50 | \$ 35 | 1.9 | 1.6 | |
| 18 | 121 | 10 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.1 | SW | 2400 | 2,688 | 10 | 0 | F44SSILL | 96 | 1.0 | C-OCC | 1,680 | 1,613 | 1,075 | 0.2 | \$ 143.86 | \$ 1,265.00 | \$ 135 | 8.8 | 7.9 | |
| 18 | Mens Bathroom (2nd Floor) | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SSILL | 96 | 0.3 | NONE | 672 | 194 | 478 | 0.0 | \$ 62.32 | \$ 318.75 | \$ 30 | 5.1 | 4.6 | |
| 71 | Mens Bathroom (2nd Floor) | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 2000 | 240 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 240 | 13 | 227 | 0.1 | \$ 32.74 | \$ 13.50 | \$ - | 0.4 | 0.4 | |
| 71 | Mens Bathroom Closet (2nd Floor) | 1 | I 60 | I60/1 | 60 | 0.1 | SW | 1000 | 60 | 1 | CF 26 | CFQ26/1-L | 27 | 0.0 | NONE | 250 | 7 | 53 | 0.0 | \$ 8.96 | \$ 6.75 | \$ - | 0.8 | 0.8 | |
| 18 | Main Office | 2 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.2 | SW | 2400 | 538 | 2 | 0 | F44SSILL | 96 | 0.2 | C-OCC | 1,200 | 230 | 307 | 0.0 | \$ 40.10 | \$ 415.00 | \$ 55 | 10.3 | 9.0 | |
| X5 | Main Office Entrance | 1 | CF42/1-L | CF42/1-L | 48 | 0.0 | SW | 2280 | 109 | 1 | CF42/1-L | CF42/1-L | 48 | 0.0 | NONE | 2,280 | 109 | - | 0.0 | \$ - | \$ - | \$ - | - | - | |
| 71 | Exit | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 2280 | 274 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 2,280 | 123 | 150 | 0.1 | \$ 23.33 | \$ 13.50 | \$ - | 0.6 | 0.6 | |
| 16 | 29 | 24 | T 34 R F 2 (MAG) | F42EE | 72 | 1.7 | SW | 2400 | 4,147 | 24 | T 28 R F 2 | F42SSILL | 48 | 1.2 | C-OCC | 1,680 | 1,935 | 2,212 | 0.6 | \$ 314.04 | \$ 2,956.50 | \$ 275 | 9.4 | 8.5 | |
| 18 | Hallway (2nd Floor) | 26 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.9 | SW | 2280 | 6,639 | 26 | 0 | F44SSILL | 96 | 2.5 | NONE | 2,280 | 5,691 | 948 | 0.4 | \$ 147.06 | \$ 2,762.50 | \$ 260 | 18.8 | 17.0 | |
| 18 | Hallway (1st Floor) | 26 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.9 | SW | 2280 | 6,639 | 26 | 0 | F44SSILL | 96 | 2.5 | NONE | 2,280 | 5,691 | 948 | 0.4 | \$ 147.06 | \$ 2,762.50 | \$ 260 | 18.8 | 17.0 | |
| 16 | 29-A Closet | 4 | T 34 R F 2 (MAG) | F42EE | 72 | 0.3 | SW | 1000 | 288 | 4 | T 28 R F 2 | F42SSILL | 48 | 0.2 | NONE | 250 | 48 | 240 | 0.1 | \$ 36.53 | \$ 459.00 | \$ 40 | 12.6 | 11.5 | |
| 18 | 29-A | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.7 | SW | 2400 | 1,613 | 6 | 0 | F44SSILL | 96 | 0.6 | C-OCC | 1,680 | 968 | 645 | 0.1 | \$ 86.32 | \$ 840.00 | \$ 95 | 9.7 | 8.6 | |
| 71 | Womens Bathroom (1st Floor) | 2 | I 60 | I60/1 | 60 | 0.1 | SW | 2000 | 240 | 2 | CF 26 | CFQ26/1-L | 27 | 0.1 | NONE | 240 | 13 | 227 | 0.1 | \$ 32.74 | \$ 13.50 | \$ - | 0.4 | 0.4 | |
| 18 | Womens Bathroom (1st Floor) | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2000 | 672 | 3 | 0 | F44SSILL | 96 | 0.3 | NONE | 672 | 194 | 478 | 0.0 | \$ 62.32 | \$ 318.75 | \$ 30 | 5.1 | 4.6 | |
| 18 | 27 | 19 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.1 | SW | 2400 | 5,107 | 19 | 0 | F44SSILL | 96 | 1.8 | C-OCC | 1,680 | 3,064 | 2,043 | 0.3 | \$ 273.34 | \$ 2,221.25 | \$ 225 | 8.1 | 7.3 | |
| 20 | Kitchen | 29 | S 32 C F 1 (ELE) | F41LL | 32 | 0.9 | SW | 1600 | 1,485 | 29 | S 32 C F 1 (ELE) | F41LL | 32 | 0.9 | NONE | 1,200 | 1,114 | 371 | | | | | | | |

| Field Code | Area Description | EXISTING CONDITIONS | | | | | | | RETROFIT CONDITIONS | | | | | | | COST & SAVINGS ANALYSIS | | | | | | | | | |
|------------|--|-------------------------------------|--|--|---|---------------------------|--------------------------|---|-----------------------------|---------------------------------------|--|--|---|-------------------------------------|-------------------------|--|-----------------------------|---|---|------------------------|---|-----------------------------------|---|---|---------|
| | | No. of Fixtures before the retrofit | Standard Fixture Code | NYSERDA Fixture Code | Watts per Fixture | kW/Space | Exist Control | Annual Hours | Annual kWh | Number of Fixtures after the retrofit | Standard Fixture Code | Fixture Code | Watts per Fixture | kW/Space | Retrofit Control | Annual Hours | Annual kWh | Annual kWh Saved | Annual kW Saved | Annual \$ Saved | Retrofit Cost | NJ Smart Start Lighting Incentive | Simple Payback With Out Incentive | Simple Payback | |
| | Unique description of the location - Room number/Room name: Floor number (if applicable) | | "Lighting Fixture Code" Example 2T 40 R F (U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Fixt No.) | Pre-inst. control device | Estimated daily hours for the usage group | (kW/Space) * (Annual Hours) | | "Lighting Fixture Code" Example 2T 40 R F (U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape | Code from Table of Standard Fixture Wattages | Value from Table of Standard Fixture Wattages | (Watts/Fixt) * (Number of Fixtures) | Retrofit control device | Estimated annual hours for the usage group | (kW/Space) * (Annual Hours) | (Original Annual kWh) - (Retrofit Annual kWh) | (Original Annual kW) - (Retrofit Annual kW) | (kWh Saved) * (\$/kWh) | Cost for renovations to lighting system | Prescriptive Lighting Measures | Length of time for renovations cost to be recovered | Length of time for renovations cost to be recovered | |
| 20 | 115 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | SW | 2400 | 1,382 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | C-OCC | 1,680 | 968 | 415 | 0.0 | \$ 50.97 | \$ 202.50 | \$ 35 | 4.0 | 3.3 | |
| 47 | Roof Access / Supply Room | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 1000 | 144 | 2 | 1B 28 C F 2 | F42SSILL | 48 | 0.1 | NONE | 250 | 24 | 120 | 0.0 | \$ 18.27 | \$ 256.50 | \$ - | 14.0 | 14.0 | |
| 47 | LA/SS Supply Room | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 1000 | 144 | 2 | 1B 28 C F 2 | F42SSILL | 48 | 0.1 | NONE | 250 | 24 | 120 | 0.0 | \$ 18.27 | \$ 256.50 | \$ - | 14.0 | 14.0 | |
| 18 | Electrical and Paper Supply Room | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 1000 | 336 | 3 | 0 | F44SSILL | 96 | 0.3 | NONE | 250 | 72 | 264 | 0.0 | \$ 35.96 | \$ 318.75 | \$ 30 | 8.9 | 8.0 | |
| 20 | 117 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | SW | 2400 | 1,382 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | C-OCC | 1,680 | 968 | 415 | 0.0 | \$ 50.97 | \$ 202.50 | \$ 35 | 4.0 | 3.3 | |
| 47 | Faculty Lounge | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 5000 | 360 | 1 | 1B 28 C F 2 | F42SSILL | 48 | 0.0 | C-OCC | 3,000 | 144 | 216 | 0.0 | \$ 28.30 | \$ 330.75 | \$ 35 | 11.7 | 10.4 | |
| 20 | Faculty Lounge | 10 | S 32 C F 1 (ELE) | F41LL | 32 | 0.3 | SW | 5000 | 1,600 | 10 | S 32 C F 1 (ELE) | F41LL | 32 | 0.3 | C-OCC | 3,000 | 960 | 640 | 0.0 | \$ 78.65 | \$ 202.50 | \$ 35 | 2.6 | 2.1 | |
| 47 | Faculty Lounge Mens Bathroom | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2000 | 144 | 1 | 1B 28 C F 2 | F42SSILL | 48 | 0.0 | NONE | 144 | 7 | 137 | 0.0 | \$ 18.61 | \$ 128.25 | \$ - | 6.9 | 6.9 | |
| 47 | Faculty Lounge Womens Bathroom | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2000 | 144 | 1 | 1B 28 C F 2 | F42SSILL | 48 | 0.0 | NONE | 144 | 7 | 137 | 0.0 | \$ 18.61 | \$ 128.25 | \$ - | 6.9 | 6.9 | |
| 16 | 120 | 10 | T 34 R F 2 (MAG) | F42EE | 72 | 0.7 | SW | 2400 | 1,728 | 10 | T 28 R F 2 | F42SSILL | 48 | 0.5 | C-OCC | 1,680 | 806 | 922 | 0.2 | \$ 130.85 | \$ 1,350.00 | \$ 135 | 10.3 | 9.3 | |
| 47 | Girls Bathroom | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2000 | 288 | 2 | 1B 28 C F 2 | F42SSILL | 48 | 0.1 | NONE | 288 | 28 | 260 | 0.0 | \$ 35.51 | \$ 256.50 | \$ - | 7.2 | 7.2 | |
| 39 | Janitor Closet | 1 | 2' 17 W F 2 (ELE) | F22ILL | 33 | 0.0 | SW | 1000 | 33 | 1 | 2' 17 W F 2 (ELE) | F22ILL | 33 | 0.0 | NONE | 500 | 17 | 17 | 0.0 | \$ 2.03 | \$ - | \$ - | 0.0 | 0.0 | |
| 18 | Boys Bathroom | 2 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.2 | SW | 2000 | 448 | 2 | 0 | F44SSILL | 96 | 0.2 | NONE | 448 | 86 | 362 | 0.0 | \$ 46.83 | \$ 212.50 | \$ 20 | 4.5 | 4.1 | |
| 20 | 12 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | SW | 2400 | 1,382 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | C-OCC | 1,680 | 968 | 415 | 0.0 | \$ 50.97 | \$ 202.50 | \$ 35 | 4.0 | 3.3 | |
| 18 | 10 | 24 | T 32 R F 4 (ELE) | F44ILL | 112 | 2.7 | SW | 2400 | 6,451 | 24 | 0 | F44SSILL | 96 | 2.3 | C-OCC | 1,680 | 3,871 | 2,580 | 0.4 | \$ 345.27 | \$ 2,752.50 | \$ 275 | 8.0 | 7.2 | |
| 16 | 10-Band Office | 3 | T 34 R F 2 (MAG) | F42EE | 72 | 0.2 | SW | 2400 | 518 | 3 | T 28 R F 2 | F42SSILL | 48 | 0.1 | C-OCC | 1,200 | 173 | 346 | 0.1 | \$ 47.75 | \$ 546.75 | \$ 65 | 11.5 | 10.1 | |
| 47 | 10-Band Office Storage | 1 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 1000 | 72 | 1 | 1B 28 C F 2 | F42SSILL | 48 | 0.0 | NONE | 250 | 12 | 60 | 0.0 | \$ 9.13 | \$ 128.25 | \$ - | 14.0 | 14.0 | |
| 11 | 10-Far Office | 2 | S 34 P F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2400 | 346 | 2 | C 28 P F 2 | F42SSILL | 48 | 0.1 | C-OCC | 1,200 | 115 | 230 | 0.0 | \$ 31.83 | \$ 415.00 | \$ 55 | 13.0 | 11.3 | |
| 11 | 10-Storage | 2 | S 34 P F 2 (MAG) | F42EE | 72 | 0.1 | SW | 1000 | 144 | 2 | C 28 P F 2 | F42SSILL | 48 | 0.1 | NONE | 250 | 24 | 120 | 0.0 | \$ 18.27 | \$ 212.50 | \$ 20 | 11.6 | 10.5 | |
| 47 | 11 | 2 | 1B 34 C F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2400 | 346 | 2 | 1B 28 C F 2 | F42SSILL | 48 | 0.1 | C-OCC | 1,680 | 161 | 184 | 0.0 | \$ 26.17 | \$ 459.00 | \$ 35 | 17.5 | 16.2 | |
| 20 | 13 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | SW | 2400 | 1,382 | 18 | S 32 C F 1 (ELE) | F41LL | 32 | 0.6 | C-OCC | 1,680 | 968 | 415 | 0.0 | \$ 50.97 | \$ 202.50 | \$ 35 | 4.0 | 3.3 | |
| 20 | 15 | 48 | S 32 C F 1 (ELE) | F41LL | 32 | 1.5 | SW | 2400 | 3,686 | 48 | S 32 C F 1 (ELE) | F41LL | 32 | 1.5 | C-OCC | 1,680 | 2,580 | 1,106 | 0.0 | \$ 135.91 | \$ 202.50 | \$ 35 | 1.5 | 1.2 | |
| 16 | 15-Storage | 2 | T 34 R F 2 (MAG) | F42EE | 72 | 0.1 | SW | 1000 | 144 | 2 | T 28 R F 2 | F42SSILL | 48 | 0.1 | NONE | 250 | 24 | 120 | 0.0 | \$ 18.27 | \$ 229.50 | \$ 20 | 12.6 | 11.5 | |
| 16 | Larson Office | 1 | T 34 R F 2 (MAG) | F42EE | 72 | 0.1 | SW | 2400 | 173 | 1 | T 28 R F 2 | F42SSILL | 48 | 0.0 | C-OCC | 1,200 | 58 | 115 | 0.0 | \$ 15.92 | \$ 317.25 | \$ 45 | 19.9 | 17.1 | |
| 18 | DL | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.7 | SW | 2400 | 1,613 | 6 | 0 | F44SSILL | 96 | 0.6 | C-OCC | 1,680 | 968 | 645 | 0.1 | \$ 86.32 | \$ 840.00 | \$ 95 | 9.7 | 8.6 | |
| 18 | DL1 | 12 | T 32 R F 4 (ELE) | F44ILL | 112 | 1.3 | SW | 2400 | 3,226 | 12 | 0 | F44SSILL | 96 | 1.2 | C-OCC | 1,680 | 1,935 | 1,290 | 0.2 | \$ 172.64 | \$ 1,477.50 | \$ 155 | 8.6 | 7.7 | |
| 18 | DL2 | 6 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.7 | SW | 2400 | 1,613 | 6 | 0 | F44SSILL | 96 | 0.6 | C-OCC | 1,680 | 968 | 645 | 0.1 | \$ 86.32 | \$ 840.00 | \$ 95 | 9.7 | 8.6 | |
| 18 | DL3 | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2400 | 806 | 3 | 0 | F44SSILL | 96 | 0.3 | C-OCC | 1,680 | 484 | 323 | 0.0 | \$ 43.16 | \$ 521.25 | \$ 65 | 12.1 | 10.6 | |
| 13 | DL Storage | 2 | S 32 P F 2 (ELE) | F42LL | 60 | 0.1 | SW | 1000 | 120 | 2 | 0 | F42SSILL | 48 | 0.1 | NONE | 250 | 24 | 96 | 0.0 | \$ 13.56 | \$ 212.50 | \$ 20 | 15.7 | 14.2 | |
| 18 | D Storage | 2 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.2 | SW | 1000 | 224 | 2 | 0 | F44SSILL | 96 | 0.2 | NONE | 250 | 48 | 176 | 0.0 | \$ 23.97 | \$ 212.50 | \$ 20 | 8.9 | 8.0 | |
| 16 | 20 | 12 | T 34 R F 2 (MAG) | F42EE | 72 | 0.9 | SW | 2400 | 2,074 | 12 | T 28 R F 2 | F42SSILL | 48 | 0.6 | C-OCC | 1,680 | 968 | 1,106 | 0.3 | \$ 157.02 | \$ 1,579.50 | \$ 155 | 10.1 | 9.1 | |
| 127 | 20 Upper Storage | 3 | I40/2 | | 80 | 0.2 | SW | 1000 | 240 | 3 | CF 13 | CFQ13/1-L | 15 | 0.0 | NONE | 250 | 11 | 229 | 0.2 | \$ 42.41 | \$ 60.75 | \$ - | 1.4 | 1.4 | |
| 16 | 20 Lower Storage | 2 | T 34 R F 2 (MAG) | F42EE | 72 | 0.1 | SW | 1000 | 144 | 2 | T 28 R F 2 | F42SSILL | 48 | 0.1 | NONE | 250 | 24 | 120 | 0.0 | \$ 18.27 | \$ 229.50 | \$ 20 | 12.6 | 11.5 | |
| 191 | Boiler Room | 4 | S 60 C F 2 (ELE) 8' | F82EE | 123 | 0.5 | SW | 1000 | 492 | 4 | S 60 C F 2 (ELE) 8' | F82EE | 123 | 0.5 | NONE | 1,000 | 492 | 0.0 | \$ - | \$ - | \$ - | - | - | - | |
| 141 | Coaches Office | 3 | T 32 R F 4 (ELE) | F44ILL | 112 | 0.3 | SW | 2400 | 806 | 3 | 0 | F44SSILL | 96 | 0.3 | C-OCC | 1,200 | 346 | 461 | 0.0 | \$ 60.15 | \$ 521.25 | \$ 65 | 8.7 | 7.6 | |
| 141 | Gym | 28 | HPS250/1 | HPS250/1 | 295 | 8.3 | SW | 2912 | 24,053 | 28 | HPS 250 | HPS250/1 | 295 | 8.3 | NONE | 2,912 | 24,053 | 0.0 | \$ - | \$ - | \$ - | - | - | - | |
| 228 | Gym Equipment Room | 1 | W60CF1 | F81EL | 60 | 0.1 | SW | 2912 | 175 | 1 | W60CF1 | F81EL | 60 | 0.1 | NONE | 2,912 | 175 | - | 0.0 | \$ - | \$ - | \$ - | - | - | |
| 228 | Gym PA Room | 1 | W60CF1 | F81EL | 60 | 0.1 | SW | 2912 | 175 | 1 | W60CF1 | F81EL | 60 | 0.1 | NONE | 2,912 | 175 | - | 0.0 | \$ - | \$ - | \$ - | - | - | |
| 228 | Gym Equipment Room | 1 | DC135C11 | I135/1 | 135 | 0.1 | SW | 2912 | 393 | 1 | DC135C11 | I135/1 | 135 | 0.1 | NONE | 2,912 | 393 | - | 0.0 | \$ - | \$ - | \$ - | - | - | |
| 142LED | Exterior | 2 | MH100/1 | MH100/1 | 128 | 0.3 | SW | 4368 | 1,118 | 2 | FXLED39 | FXLED39/1 | 39 | 0.1 | C-OCC | 4,368 | 341 | 778 | 0.2 | \$ 108.60 | \$ 1,099.50 | \$ 55 | 10.1 | 9.6 | |
| 236 | Exterior | 22 | R 75 C Q 1 | h75/1 | 75 | 1.7 | SW | 4368 | 7,207 | 22 | CF 26 | CFQ26/1-L | 27 | 0.6 | C-OCC | 4,368 | 2,595 | 4,613 | 1.1 | \$ 644.26 | \$ 351.00 | \$ 35 | 0.5 | 0.5 | |
| 236 | Exterior | 8 | R 75 C Q 1 | h75/1 | 75 | 0.6 | SW | 4368 | 2,621 | 8 | CF 26 | CFQ26/1-L | 27 | 0.2 | C-OCC | 4,368 | 943 | 1,677 | 0.4 | \$ 234.28 | \$ 256.50 | \$ 35 | 1.1 | 0.9 | |
| 93 | Exterior | 3 | I75/1 | I75/1 | 75 | 0.2 | SW | 4368 | 983 | 3 | CF 26 | CFQ26/1-L | 27 | 0.1 | C-OCC | 4,368 | 354 | 629 | 0.1 | \$ 87.85 | \$ 217.50 | \$ 35 | 2.5 | 2.1 | |
| | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! | |
| | | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! |
| | | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! |
| | | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! |
| | | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! |
| | | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! |
| | | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! |
| | | | | | | | | | | | | | | | | | | | | | | | | | #VALUE! |
| | | | | | | | | | | | | | | | | | | | | | | | | | |

APPENDIX D

**New Jersey Pay For Performance
Incentive Program**

HOME RESIDENTIAL **COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT** RENEWABLES



COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

EXISTING BUILDINGS

PARTICIPATION STEPS

APPLICATIONS AND FORMS

APPROVED PARTNERS

NEW CONSTRUCTION

FAQS

BECOME A PARTNER

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PILOT

ENERGY SAVINGS IMPROVEMENT PLAN

DIRECT INSTALL

ARRA

ENERGY BENCHMARKING

OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS

TEACH

EDA PROGRAMS

TECHNOLOGIES

TOOLS AND RESOURCES

PROGRAM UPDATES


Home » Commercial & Industrial » Programs » Pay for Performance

Pay for Performance - Existing Buildings

Download program applications and incentive forms.

The Greater the Savings, the Greater Your Incentives

Take a comprehensive, whole-building approach to saving energy in your existing facilities and earn incentives that are directly linked to your savings. Pay for Performance relies on a network of program partners who provide technical services under direct contract to you. Acting as your energy expert, your partner will develop an energy reduction plan for each project with a whole-building technical component of a traditional energy audit, a financial plan for funding the energy efficient measures and a construction schedule for installation.



Eligibility

Existing commercial, industrial and institutional buildings with a peak demand over 100 kW for any of the preceding twelve months are eligible to participate including hotels and casinos, large office buildings, multi-family buildings, supermarkets, manufacturing facilities, schools, shopping malls and restaurants. Buildings that fall into the following five customer classes are not required to meet the 100 kW demand in order

to participate in the program: hospitals, public colleges and universities, 501(c)(3) non-profits, affordable multifamily housing, and local governmental entities. Your energy reduction plan must define a comprehensive package of measures capable of reducing the existing energy consumption of your building by 15% or more.

Exceptions to the 15% threshold requirement may be made for certain industrial, manufacturing, water treatment and datacenter building types whose annual energy consumption is heavily weighted on process loads. Details are available in the high energy intensity section of the FAQ page.

ENERGY STAR Portfolio Manager

Pay for Performance takes advantage of the ENERGY STAR Program with Portfolio Manager, EPA's interactive tool that allows facility managers to track and evaluate energy and water consumption across all of their buildings. The tool provides the opportunity to load in the characteristics and energy usage of your buildings and determine an energy performance benchmark score. You can then assess energy management goals over time, identify strategic opportunities for savings, and receive EPA recognition for superior energy performance.



This rating system assesses building performance by tracking and scoring energy use in your facilities and comparing it to similar buildings. That can be a big help in locating opportunities for cost-justified energy efficiency upgrades. And, based on our findings, you may be invited to participate in the Building Performance with ENERGY STAR initiative and receive special recognition as an industry leader in energy efficiency.

Incentives

Pay for Performance incentives are awarded upon the satisfactory completion of three program milestones:

Incentive #1 - Submittal of complete energy reduction plan prepared by an approved program partner - Contingent on moving forward, incentives will be between \$5,000 and \$50,000 based on approximately \$.10 per square foot, not to exceed 50% of the facility's annual energy expense.

Incentive #2 - Installation of recommended measures - Incentives are based on the projected level of electricity and natural gas savings resulting from the installation of comprehensive energy-efficiency measures.

Incentive #3 - Completion of Post-Construction Benchmarking Report - A completed report verifying energy reductions based on one year of post-implementation results. Incentives for electricity and natural gas savings will be paid based on actual savings, provided that the minimum performance threshold of 15% savings has been achieved.



Program

Large Scale CHI Program Annour

2012 Large Ene Announcement

Economic Devel Introduces Revc Pay for Perform:

Incentives Now . Screw-in Lamps

Other updates pos

Featured Story

Mann
Mi

NJ SmartSt
custom me
study pre
Globalcon

A
and
D

SIGN UP

Follow Us:

CONTACT US

A detailed Incentive Structure document is available on the applications and forms page.


Energy Efficiency Revolving Loan Fund (EE RLF)

New Jersey-based commercial, institutional or industrial entities (including 501(c)(3) organizations) that have received an approved energy reduction plan under Pay for Performance may be eligible for supplemental financing through the EE RLF. The financing, in the form of low-interest loans, can be used to support up to 80% of total eligible project costs, not to exceed \$2.5 million or 100% of total eligible project costs from all public state funding sources. Visit the NJ EDA website for details.

Steps to Participation

[Click here](#) for a step-by-step description of the program.

[Home](#) | [Residential](#) | [Commercial & Industrial](#) | [Renewable Energy](#)
[About Us](#) | [Press Room](#) | [Library](#) | [FAQs](#) | [Calendar](#) | [Newsletters](#) | [Contact Us](#) | [Site Map](#)



2012 PAY FOR PERFORMANCE PROGRAM Existing Buildings Incentive Structure

Incentive #1: Energy Reduction Plan

Incentive Amount:..... \$0.10 per sq ft
Minimum Incentive:..... \$5,000
Maximum Incentive:..... \$50,000 or 50% of facility annual energy cost (whichever is less)

This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP) and is paid upon ERP approval. Incentive is contingent on implementation of recommended measures outlined in the ERP.

Incentive #2: Installation of Recommended Measures

Minimum Performance Target:..... 15%

Electric Incentives

Base Incentive based on 15% savings:.....\$0.09 per projected kWh saved
For each % over 15% add:.....\$0.005 per projected kWh saved
Maximum Incentive:.....\$0.11 per projected kWh saved

Gas Incentives

Base Incentive based on 15% savings:.....\$0.90 per projected Therm saved
For each % over 15% add:.....\$0.05 per projected Therm saved
Maximum Incentive:.....\$1.25 per projected Therm saved

Incentive Cap: 25% of total project cost

This incentive is based on projected energy savings outlined in the ERP. Incentive is paid upon successful installation of recommended measures.

Incentive #3: Post-Construction Benchmarking Report

Minimum Performance Target:..... 15%

Electric Incentives

Base Incentive based on 15% savings:.....\$0.09 per actual kWh saved
For each % over 15% add:.....\$0.005 per actual kWh saved
Maximum Incentive:.....\$0.11 per actual kWh saved

Gas Incentives

Base Incentive based on 15% savings:.....\$0.90 per actual Therm saved
For each % over 15% add:.....\$0.05 per actual Therm saved
Maximum Incentive:.....\$1.25 per actual Therm saved

Incentive Cap: 25% of total project cost

This incentive will be released upon submittal of a Post-Construction Benchmarking Report that verifies that the level of savings actually achieved by the installed measures meets or exceeds the minimum performance threshold. To validate the savings and achievement of the Energy Target, the EPA Portfolio Manager shall be used. Savings should be rounded to the nearest percent. Total value of Incentive #2 and Incentive #3 may not exceed 50% of the total project cost. Incentives will be limited to \$1 million per gas and electric account per building; maximum of \$2 million per project. See Participation Agreement for details.

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012. Building must have a minimum average electric demand of 100 kW. This minimum is waived for buildings owned by local governments or non-profit organizations. Values used in this calculation are for measures with a positive return on investment (ROI) only.

| | | | | |
|--------------------------------------|--------|---------------------------|--------|---------|
| Total Building Area (Square Feet) | 85,540 | Incentive #1 | | |
| Is this audit funded by NJ BPU (Y/N) | Yes | Audit is funded by NJ BPU | \$0.05 | \$/sqft |

Board of Public Utilities (BPU)

| | Annual Utilities | |
|--------------------------------------|------------------|----------|
| | kWh | Therms |
| Existing Cost (from utility) | \$56,801 | \$43,593 |
| Existing Usage (from utility) | 462,201 | 44,056 |
| Proposed Savings | 97,406 | -333 |
| Existing Total MMBtus | 5,983 | |
| Proposed Savings MMBtus | 299 | |
| % Energy Reduction | 5.0% | |
| Proposed Annual Savings | \$11,300 | |

| | Min (Savings = 15%) | | Increase (Savings > 15%) | | Max Incentive | | Achieved Incentive | |
|---------------------|---------------------|----------|--------------------------|----------|---------------|----------|--------------------|----------|
| | \$/kWh | \$/therm | \$/kWh | \$/therm | \$/kWh | \$/therm | \$/kWh | \$/therm |
| Incentive #2 | \$0.09 | \$0.90 | \$0.005 | \$0.05 | \$0.11 | \$1.25 | \$0.00 | \$0.00 |
| Incentive #3 | \$0.09 | \$0.90 | \$0.005 | \$0.05 | \$0.11 | \$1.25 | \$0.00 | \$0.00 |

| Total Recommended Project Savings 5.0% | Incentives \$ | | |
|---|---------------|------------|----------------|
| | Elec | Gas | Total |
| Incentive #1 | \$0 | \$0 | \$5,000 |
| Incentive #2 | \$0 | \$0 | \$0 |
| Incentive #3 | \$0 | \$0 | \$0 |
| Total All Incentives | \$0 | \$0 | \$5,000 |

| | |
|---------------------------|----------|
| Total Project Cost | \$89,561 |
|---------------------------|----------|

| | | Allowable Incentive |
|--|----------------|---------------------|
| % Incentives #1 of Utility Cost* | 5.0% | \$5,000 |
| % Incentives #2 of Project Cost** | 0.0% | \$0 |
| % Incentives #3 of Project Cost** | 0.0% | \$0 |
| Total Eligible Incentives*** | \$5,000 | |
| Project Cost w/ Incentives | \$84,561 | |

| Project Payback (years) | |
|-------------------------|---------------|
| w/o Incentives | w/ Incentives |
| 7.9 | 7.5 |

* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

** Maximum allowable amount of Incentive #2 is 25% of total project cost.

Maximum allowable amount of Incentive #3 is 25% of total project cost.

*** Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

APPENDIX E

Energy Savings Improvement Plan (ESIP)



Your Power to Save
At Home, for Business, and for the Future

HOME

RESIDENTIAL

COMMERCIAL, INDUSTRIAL
AND LOCAL GOVERNMENT

RENEWABLE ENERGY


[Home](#) » [Commercial & Industrial](#) » [Programs](#)

Energy Savings Improvement Plan

A new State law allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the "Energy Savings Improvement Program" (ESIP), provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

This [Local Finance Notice](#) outlines how local governments can develop and implement an ESIP for their facilities. Below are two sample RFPs:

- [Local Government](#)
- [School Districts \(K-12\)](#)

The Board also adopted [protocols](#) to measure energy savings.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Local units considering an ESIP should carefully review the Local Finance Notice, the law, and consult with qualified professionals to determine how they should approach the task.

FIRST STEP – ENERGY AUDIT

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. As explained in the Local Finance Notice, this may be done internally if an agency has qualified staff to conduct the audit. If not, the audit must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

Pursuing a [Local Government Energy Audit](#) through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach - and it's free. **Incentives provide 100% of the cost of the audit.**

ENERGY REDUCTION PLANS

If you have an ESIP plan you would like to submit to the Board of Public Utilities, please email it to ESIP@bpu.state.nj.us. Please limit the file size to 3MB (or break it into smaller files).

- [Frankford Township School District](#)
- [Northern Hunterdon-Voorhees Regional High School](#)
- [Manalapan Township \(180 MB - Right Click, Save As\)](#)

Program Updates

- [Board Order - Standby Charges for Distributed Generation Customers](#)
 - [T-12 Schools Lighting Replacement Initiative - Funding Allocation Reached](#)
- [Other updates posted.](#)

Featured Success Story

Rutgers University:
Continued Commitment to Saving Energy



Follow Us:



COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

PROGRAMS

- ▶ [NJ SMARTSTART BUILDINGS](#)
- ▶ [PAY FOR PERFORMANCE](#)
- ▶ [COMBINED HEAT & POWER AND FUEL CELLS](#)
- ▶ [LOCAL GOVERNMENT ENERGY AUDIT](#)
- ▶ [LARGE ENERGY USERS PILOT](#)
- ▶ [ENERGY SAVINGS IMPROVEMENT PLAN](#)
- ▶ [DIRECT INSTALL](#)
- ▶ [ENERGY BENCHMARKING](#)
- ▶ [T-12 SCHOOLS LIGHTING INITIATIVE](#)
- ▶ [OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS](#)
- ▶ [EDA PROGRAMS](#)
- ▶ [TEACH](#)
- ▶ [ARRA](#)
- ▶ [TECHNOLOGIES](#)
- ▶ [TOOLS AND RESOURCES](#)
- ▶ [PROGRAM UPDATES](#)
- ▶ [CONTACT US](#)

APPENDIX F

Solar Photovoltaic Analysis

Photovoltaic (PV) Solar Power Generation - Screening Assessment

**Penns Grove-Carneys Point Regional School District
Penns Grove Middle School**

| | | |
|---------------------|---------|--------|
| Cost of Electricity | \$0.123 | /kWh |
| Electricity Usage | 462,201 | kWh/yr |
| System Unit Cost | \$4,000 | /kW |

Photovoltaic (PV) Solar Power Generation - Screening Assessment

| Budgetary Cost | Annual Utility Savings | | | | Estimated Maintenance Savings | Total Savings | Federal Tax Credit | New Jersey Renewable ** SREC | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|--------|-----|---------|-------------------------------|---------------|--------------------|------------------------------|-----------------------------|--------------------------|
| | \$ | kW | kWh | therms | \$ | \$ | \$ | \$ | Years | Years |
| \$160,000 | 40.0 | 52,549 | 0 | \$6,464 | 0 | \$6,464 | \$0 | \$3,153 | 24.8 | 16.6 |

** Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$60 /1000kwh

Area Output*

1,730 m2
18,617 ft2

Perimeter Output*

364 m
1,193 ft

Available Roof Space for PV:

(Area Output - 10 ft x Perimeter) x 85%
5,685 ft2

Approximate System Size:

Is the roof flat? (Yes/No) **Yes**

8 watt/ft2
45,479 DC watts
40 kW Enter into PV Watts

PV Watts Inputs*

Array Tilt Angle 20 Enter into PV Watts (always 20 if flat, if pitched - enter estimated roof angle)
Array Azimuth 180 Enter into PV Watts (default)
Zip Code 07632 Enter into PV Watts
DC/AC Derate Factor 0.83 Enter into PV Watts



PV Watts Output

52,549 annual kWh calculated in PV Watts program

% Offset Calc

Usage 462,201 (from utilities)
PV Generation 52,549 (generated using PV Watts)
% offset 11%

* <http://www.freemaptools.com/area-calculator.htm>

**<http://www.flettexchange.com>



**AC Energy
&
Cost Savings**



Penns Grove Middle School - Penns Grove Board of Education

| Station Identification | | Results | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|---|---|-----------------|---|-----------------|-------------------|---|------|------|--------|---|------|------|--------|---|------|------|--------|---|------|------|--------|---|------|------|--------|---|------|------|--------|---|------|------|--------|---|------|------|--------|---|------|------|--------|----|------|------|--------|----|------|------|--------|----|------|------|--------|------|------|-------|---------|--|--|
| Cell ID: | 0266373 | <table border="1"> <thead> <tr> <th>Month</th> <th>Solar Radiation (kWh/m²/day)</th> <th>AC Energy (kWh)</th> <th>Energy Value (\$)</th> </tr> </thead> <tr><td>1</td><td>2.80</td><td>2901</td><td>356.82</td></tr> <tr><td>2</td><td>3.53</td><td>3338</td><td>410.57</td></tr> <tr><td>3</td><td>4.96</td><td>4999</td><td>614.88</td></tr> <tr><td>4</td><td>5.39</td><td>5119</td><td>629.64</td></tr> <tr><td>5</td><td>5.96</td><td>5691</td><td>699.99</td></tr> <tr><td>6</td><td>6.25</td><td>5602</td><td>689.05</td></tr> <tr><td>7</td><td>5.95</td><td>5458</td><td>671.33</td></tr> <tr><td>8</td><td>5.75</td><td>5258</td><td>646.73</td></tr> <tr><td>9</td><td>5.17</td><td>4684</td><td>576.13</td></tr> <tr><td>10</td><td>4.19</td><td>4075</td><td>501.23</td></tr> <tr><td>11</td><td>2.96</td><td>2863</td><td>352.15</td></tr> <tr><td>12</td><td>2.55</td><td>2561</td><td>315.00</td></tr> <tr> <td>Year</td> <td>4.63</td> <td>52549</td> <td>6463.53</td> </tr> </table> | Month | Solar Radiation (kWh/m ² /day) | AC Energy (kWh) | Energy Value (\$) | 1 | 2.80 | 2901 | 356.82 | 2 | 3.53 | 3338 | 410.57 | 3 | 4.96 | 4999 | 614.88 | 4 | 5.39 | 5119 | 629.64 | 5 | 5.96 | 5691 | 699.99 | 6 | 6.25 | 5602 | 689.05 | 7 | 5.95 | 5458 | 671.33 | 8 | 5.75 | 5258 | 646.73 | 9 | 5.17 | 4684 | 576.13 | 10 | 4.19 | 4075 | 501.23 | 11 | 2.96 | 2863 | 352.15 | 12 | 2.55 | 2561 | 315.00 | Year | 4.63 | 52549 | 6463.53 | | |
| Month | Solar Radiation (kWh/m ² /day) | | AC Energy (kWh) | Energy Value (\$) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | 2.80 | | 2901 | 356.82 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | 3.53 | | 3338 | 410.57 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | 4.96 | 4999 | 614.88 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | 5.39 | 5119 | 629.64 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | 5.96 | 5691 | 699.99 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | 6.25 | 5602 | 689.05 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | 5.95 | 5458 | 671.33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | 5.75 | 5258 | 646.73 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | 5.17 | 4684 | 576.13 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | 4.19 | 4075 | 501.23 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | 2.96 | 2863 | 352.15 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | 2.55 | 2561 | 315.00 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Year | 4.63 | 52549 | 6463.53 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| State: | New Jersey | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Latitude: | 39.8 ° N | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Longitude: | 75.3 ° W | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| PV System Specifications | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| DC Rating: | 40.0 kW | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| DC to AC Derate Factor: | 0.830 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| AC Rating: | 33.2 kW | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Array Type: | Fixed Tilt | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Array Tilt: | 20.0 ° | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Array Azimuth: | 180.0 ° | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Energy Specifications | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Cost of Electricity: | 12.3 ¢/kWh | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="button" value="Output Hourly Performance Data"/> | | <input type="button" value="Output Results as Text"/> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <i>(Gridded data is monthly, hourly output not available.)</i> | | Saving Text from a Browser | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="button" value="Run PVWATTS v.2 for another location"/> | | <input type="button" value="Run PVWATTS v.1"/> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |


Please send questions and comments to [Webmaster](#)
[Disclaimer and copyright notice.](#)



RRcDC home page (<http://rredc.nrel.gov>)

APPENDIX G

EPA Portfolio Manager



STATEMENT OF ENERGY PERFORMANCE

Penns Grove Middle School

Building ID: 3242244
For 12-month Period Ending: June 30, 2012¹
Date SEP becomes ineligible: N/A

Date SEP Generated: August 30, 2012

| | | |
|---|------------------------------|---|
| Facility Penns Grove Middle School 351 Maple Avenue Penns Grove, NJ 08069 | Facility Owner N/A | Primary Contact for this Facility N/A |
|---|------------------------------|---|

Year Built: 1935
Gross Floor Area (ft²): 85,540

Energy Performance Rating² (1-100) 27

Site Energy Use Summary³

| | |
|-----------------------------------|-----------|
| Electricity - Grid Purchase(kBtu) | 1,581,656 |
| Natural Gas (kBtu) ⁴ | 3,828,130 |
| Total Energy (kBtu) | 5,409,786 |

Energy Intensity⁴

| | |
|-----------------------------------|-----|
| Site (kBtu/ft ² /yr) | 63 |
| Source (kBtu/ft ² /yr) | 109 |

Emissions (based on site energy use)

| | |
|---|-----|
| Greenhouse Gas Emissions (MtCO ₂ e/year) | 428 |
|---|-----|

Electric Distribution Utility

Atlantic City Electric Co [Pepco Holdings Inc]

National Median Comparison

| | |
|--|----------------|
| National Median Site EUI | 52 |
| National Median Source EUI | 89 |
| % Difference from National Median Source EUI | 22% |
| Building Type | K-12 School |

| |
|--|
| |
| Stamp of Certifying Professional |
| Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate. |

Meets Industry Standards⁵ for Indoor Environmental Conditions:

| | |
|---|-----|
| Ventilation for Acceptable Indoor Air Quality | N/A |
| Acceptable Thermal Environmental Conditions | N/A |
| Adequate Illumination | N/A |

Certifying Professional
N/A

Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Values represent energy intensity, annualized to a 12-month period.
5. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) or a Registered Architect (RA) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE or RA in double-checking the information that the building owner or operator has entered into Portfolio Manager.

Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.

NOTE: You must check each box to indicate that each value is correct, OR include a note.

| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | <input checked="" type="checkbox"/> |
|---|---|---|-------|-------------------------------------|
| Building Name | Penns Grove Middle School | Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings? | | <input type="checkbox"/> |
| Type | K-12 School | Is this an accurate description of the space in question? | | <input type="checkbox"/> |
| Location | 351 Maple Avenue, Penns Grove, NJ 08069 | Is this address accurate and complete? Correct weather normalization requires an accurate zip code. | | <input type="checkbox"/> |
| Single Structure | Single Facility | Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of a hospital, k-12 school, hotel and senior care facility) nor can they be submitted as representing only a portion of a building. | | <input type="checkbox"/> |
| Penns Grove Middle School (K-12 School) | | | | |
| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | <input checked="" type="checkbox"/> |
| Gross Floor Area | 85,540 Sq. Ft. | Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area. | | <input type="checkbox"/> |
| Open Weekends? | No | Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days. | | <input type="checkbox"/> |
| Number of PCs | 75 | Is this the number of personal computers in the K12 School? | | <input type="checkbox"/> |
| Number of walk-in refrigeration/freezer units | 0 | Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas. | | <input type="checkbox"/> |
| Presence of cooking facilities | Yes | Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no". | | <input type="checkbox"/> |
| Percent Cooled | 0 % | Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment? | | <input type="checkbox"/> |
| Percent Heated | 100 % | Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment? | | <input type="checkbox"/> |
| Months | 10(Optional) | Is this school in operation for at least 8 months of the year? | | <input type="checkbox"/> |

| | | | |
|---------------------|----|--|--------------------------|
| High School? | No | Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'. | <input type="checkbox"/> |
|---------------------|----|--|--------------------------|

ENERGY STAR® Data Checklist for Commercial Buildings

Energy Consumption

Power Generation Plant or Distribution Utility: Atlantic City Electric Co [Pepco Holdings Inc]

| Fuel Type: Electricity | | |
|--|------------|--|
| Meter: Electric Stadium (0142 0469 9996) (kWh (thousand Watt-hours)) | | |
| Space(s): Entire Facility | | |
| Generation Method: Grid Purchase | | |
| Start Date | End Date | Energy Use (kWh (thousand Watt-hours)) |
| 06/01/2012 | 06/30/2012 | 0.00 |
| 05/01/2012 | 05/31/2012 | 0.00 |
| 04/01/2012 | 04/30/2012 | 0.00 |
| 03/01/2012 | 03/31/2012 | 0.00 |
| 02/01/2012 | 02/29/2012 | 0.00 |
| 01/01/2012 | 01/31/2012 | 0.00 |
| 12/01/2011 | 12/31/2011 | 317.00 |
| 11/01/2011 | 11/30/2011 | 372.00 |
| 10/01/2011 | 10/31/2011 | 430.00 |
| 09/01/2011 | 09/30/2011 | 237.00 |
| 08/01/2011 | 08/31/2011 | 0.00 |
| 07/01/2011 | 07/31/2011 | 0.00 |
| Electric Stadium (0142 0469 9996) Consumption (kWh (thousand Watt-hours)) | | 1,356.00 |
| Electric Stadium (0142 0469 9996) Consumption (kBtu (thousand Btu)) | | 4,626.67 |
| Meter: Electric (0142 0289 9994) (kWh (thousand Watt-hours)) | | |
| Space(s): Entire Facility | | |
| Generation Method: Grid Purchase | | |
| Start Date | End Date | Energy Use (kWh (thousand Watt-hours)) |
| 06/01/2012 | 06/30/2012 | 41,400.00 |
| 05/01/2012 | 05/31/2012 | 38,100.00 |
| 04/01/2012 | 04/30/2012 | 37,800.00 |
| 03/01/2012 | 03/31/2012 | 38,550.00 |
| 02/01/2012 | 02/29/2012 | 39,300.00 |
| 01/01/2012 | 01/31/2012 | 44,100.00 |
| 12/01/2011 | 12/31/2011 | 43,800.00 |
| 11/01/2011 | 11/30/2011 | 39,300.00 |
| 10/01/2011 | 10/31/2011 | 41,151.00 |
| 09/01/2011 | 09/30/2011 | 35,700.00 |
| 08/01/2011 | 08/31/2011 | 28,200.00 |
| 07/01/2011 | 07/31/2011 | 34,800.00 |
| Electric (0142 0289 9994) Consumption (kWh (thousand Watt-hours)) | | 462,201.00 |

| | | |
|--|--------------------------|----------------------------|
| Electric (0142 0289 9994) Consumption (kBtu (thousand Btu)) | 1,577,029.81 | |
| Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu)) | 1,581,656.48 | |
| Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters? | <input type="checkbox"/> | |
| Fuel Type: Natural Gas | | |
| Meter: Gas Meter (therms) Space(s): Entire Facility | | |
| Start Date | End Date | Energy Use (therms) |
| 06/01/2012 | 06/30/2012 | 135.85 |
| 05/01/2012 | 05/31/2012 | 2,159.78 |
| 04/01/2012 | 04/30/2012 | 0.00 |
| 03/01/2012 | 03/31/2012 | 9,388.94 |
| 02/01/2012 | 02/29/2012 | 9,921.65 |
| 01/01/2012 | 01/31/2012 | 9,845.02 |
| 12/01/2011 | 12/31/2011 | 4,729.33 |
| 11/01/2011 | 11/30/2011 | 1,868.66 |
| 10/01/2011 | 10/31/2011 | 99.17 |
| 09/01/2011 | 09/30/2011 | 29.15 |
| 08/01/2011 | 08/31/2011 | 50.81 |
| 07/01/2011 | 07/31/2011 | 52.94 |
| Gas Meter Consumption (therms) | | 38,281.30 |
| Gas Meter Consumption (kBtu (thousand Btu)) | | 3,828,130.00 |
| Total Natural Gas Consumption (kBtu (thousand Btu)) | | 3,828,130.00 |
| Is this the total Natural Gas consumption at this building including all Natural Gas meters? | | <input type="checkbox"/> |

| | |
|---|--------------------------|
| Additional Fuels | |
| Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility. | <input type="checkbox"/> |

| | |
|---|--------------------------|
| On-Site Solar and Wind Energy | |
| Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported. | <input type="checkbox"/> |

Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same PE or RA that signed and stamped the SEP.)

Name: _____ Date: _____

Signature: _____

Signature is required when applying for the ENERGY STAR.

FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

Facility
Penns Grove Middle School
351 Maple Avenue
Penns Grove, NJ 08069

Facility Owner
N/A

Primary Contact for this Facility
N/A

General Information

| Penns Grove Middle School | |
|--|---------------|
| Gross Floor Area Excluding Parking: (ft ²) | 85,540 |
| Year Built | 1935 |
| For 12-month Evaluation Period Ending Date: | June 30, 2012 |

Facility Space Use Summary

| Penns Grove Middle School | |
|---|---------------------------|
| Space Type | K-12 School |
| Gross Floor Area (ft ²) | 85,540 |
| Open Weekends? | No |
| Number of PCs | 75 |
| Number of walk-in refrigeration/freezer units | 0 |
| Presence of cooking facilities | Yes |
| Percent Cooled | 0 |
| Percent Heated | 100 |
| Months ° | 10 |
| High School? | No |
| School District ° | Penns Grove-Carneys Point |

Energy Performance Comparison

| Performance Metrics | Evaluation Periods | | Comparisons | | |
|---|-------------------------------------|--------------------------------------|--------------|--------|-----------------|
| | Current (Ending Date 06/30/2012) | Baseline (Ending Date 06/30/2012) | Rating of 75 | Target | National Median |
| Energy Performance Rating | 27 | 27 | 75 | N/A | 50 |
| Energy Intensity | | | | | |
| Site (kBtu/ft ²) | 63 | 63 | 40 | N/A | 52 |
| Source (kBtu/ft ²) | 109 | 109 | 69 | N/A | 89 |
| Energy Cost | | | | | |
| \$/year | \$ 95,306.91 | \$ 95,306.91 | \$ 60,915.64 | N/A | \$ 77,900.29 |
| \$/ft ² /year | \$ 1.11 | \$ 1.11 | \$ 0.71 | N/A | \$ 0.91 |
| Greenhouse Gas Emissions | | | | | |
| MtCO ₂ e/year | 428 | 428 | 274 | N/A | 350 |
| kgCO ₂ e/ft ² /year | 5 | 5 | 3 | N/A | 4 |

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Median column presents energy performance data your building would have if your building had a median rating of 50.

Notes:

- o - This attribute is optional.
- d - A default value has been supplied by Portfolio Manager.