# POMPTON LAKES BOARD OF EDUCATION LAKESIDE MIDDLE SCHOOL ENERGY ASSESSMENT

# FOR NEW JERSEY BOARD OF PUBLIC UTILITIES

November 2012

Prepared by:



6 Campus Drive Parsippany, NJ 07054 (973) 538-2120

**CHA PROJECT NO. 24698** 

# **TABLE OF CONTENTS**

1.0 EXE	ECUTIVE SUMMARY	1
2.0 INT	RODUCTION AND BACKGROUND	3
3.0 UTI	LITY	4
4.0 EXI	STING CONDITIONS & AREAS OF ENERGY OPPORTUNITY	6
4.1	Building Envelope	6
4.1.1	ECM-1 Replace Door & Window Seals	6
4.1.2	ECM-2 Replace Roof & Add Insulation	7
4.2	HVAC Systems	8
4.2.1	ECM-3 Boiler Replacement	8
4.3	Control Systems	9
4.3.1	ECM-4 Install Direct Digital Controls and Building Management System	10
4.4	Domestic Hot Water System	10
4.5	Lighting/Electrical Systems	11
4.5.1	ECM-5 Lighting Replacement / Upgrades	11
4.5.2	ECM-6 Install Lighting Controls (Occupancy Sensors)	12
4.5.3	ECM-7 Lighting Replacements with Controls (Occupancy Sensors)	13
4.5.4	ECM-8 Install Network Controller	13
4.6	Plumbing Systems	14
4.6.1	ECM-9 Install Low Flow Plumbing	14
4.7	Kitchen Equipment	15
4.7.1	ECM-10 Replace Electric Dishwasher Booster Heater to Natural Gas	15
5.0 PR	DJECT INCENTIVES	17
5.1	Incentives Overview	17
5.1.1	New Jersey Pay For Performance Program	17
5.1.2	New Jersey Smart Start Program	18
5.1.3	Direct Install Program	18
5.1.4	Energy Savings Improvement Plans (ESIP)	19
6.0 ALT	ERNATIVE ENERGY SCREENING EVALUATION	20
6.1	Solar	20
6.1.1	Photovoltaic Rooftop Solar Power Generation	20

6.1.2	Solar Thermal Hot Water Plant21	1
7.0 EPA	PORTFOLIO MANAGER	2
8.0 CON	CLUSIONS & RECOMMENDATIONS23	3
APPEND	ICES	
A B C D E F	Utility Usage Analysis Equipment Inventory ECM Calculations New Jersey Pay For Performance Incentive Program Photovoltaic (PV) Rooftop Solar Power Generation EPA Portfolio Manager	
LIST OF	TABLES	
	Summary of Energy Conservation Measures	
	Actual Cost & Site Utility Usage	
	FIGURES	
•	Lakeside Middle School	
	Annual Site Energy Usage	
9 0.	· ·····••· =···•· g, • • • · · · · · · · · · · · · · · · ·	_

### REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within ±20%, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the school was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing staff and spot measurements taken in the field.

#### 1.0 EXECUTIVE SUMMARY

This energy audit is performed by CHA in connection with the New Jersey Board of Public Utilities' Local Government Energy Audit Program for the Pompton Lakes Board of Education. The purpose of this report is to convey the findings of the energy audit to identify energy savings potential associated with major energy consumers and inefficient practices. This report details the results of the energy audit conducted for:

Building Name	Address	Square Feet	Construction Date
Lakeside Middle School	316 Lakeside Avenue Pompton Lakes, NJ 07442	38,105	1968

The Energy Conservation Measures (ECMs) and Operations and Maintenance Measures (OMMs) identified in this report are energy savings potential that if implemented will allow the school to use electricity and gas more effectively and efficiently. These measures if pursued may qualify for the New Jersey SmartStart Buildings Program and/or Direct Install Program. Ultimately the goal of this audit and the implementation of these measures is to facilitate the State of New Jersey's green initiative by reducing emissions, using less energy and lowering operating costs.

The potential annual energy cost savings for each energy conservation measure (ECM) is shown in Table 1. Each measure's annual savings are dependent on that measure alone. A total annual savings from implementing multiple measures is not equivalent to the summation of all of the measure's savings because of the interactive effects one measure has on another. A summary of the costs, savings, and paybacks for the recommended ECMs are detailed in Table 1 as follows:

**Table 1: Summary of Energy Conservation Measures** 

	Summary	of Energ	y Conser	vation Mea	sures		
E	Energy Conservation Measure	Approx. Costs (\$)	Approx. Savings (\$/year)	Payback (Years) w/o Incentive	Potential Incentive (\$)*	Payback (Years) w/ Incentive	Recommended For Implementation
ECM- 1	Door & Window Seals	17,000	2,900	6	0	6	Х
ECM-	Replace Roof	883,000	18,200	>20	0	>20	
ECM-	Boiler Replacement	318,000	8,900	>20	6,000	>20	Х
ECM- 4	Install DDC & BMS	310,000	4,900	>20	0	>20	
ECM- 5	Lighting Replacement / Upgrades	117,000	12,500	9	14,200	8	
ECM-	Install Lighting Controls (Occupancy Sensors)	20,000	6,400	3	4,700	2	
ECM-	Lighting Replacements with Lighting Controls (Occupancy Sensors)	137,000	15,800	9	18,900	7	Х
ECM-	Install Network Controller	2,000	1,600	1	0	1	Х
ECM- 9	Install Low Flow Plumbing Fixtures	223,000	800	>20	0	>20	
ECM- 10	Replace Kitchen Booster Heater	17,000	4,400	4	0	4	Х

The measures recommended by CHA are typically less than a 15 year payback period, however under the New Jersey Energy Savings Improvement Plan, payback periods up to 15 years may be incentivized. If the recommended measures are implemented a total potential annual savings of \$33,600 may be realized with a payback period of 14.6 years. This payback period is affected by the boiler replacement and roof replacement energy conservation measures which have high first costs; both measures are recommended because of their existing condition.

# 2.0 INTRODUCTION AND BACKGROUND

Lakeside Middle School is a 38,105 square foot building constructed in 1968. Comprised of two floors, the school serves grades 6 through 8 with approximately 400 students and 30 faculty and staff members. Lakeside School consists of the following spaces: classrooms, offices, multi-purpose room, kitchen, storage, toilet rooms and a media center. The school year hours of operation are from 8:00 AM - 11:00 PM Monday through Friday and 8:00 AM - 6:00PM Monday through Friday during the winter months of the school year. The summer hours of operation are 7:00AM to 3:00PM Monday through Friday.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.





# 3.0 UTILITY


Utilities include electricity, natural gas and water. Electricity is delivered and supplied by Jersey Central Power & Light. Natural gas is delivered and supplied by PSE&G.

For the 12-month period ending in August 2012, the utilities usage for the building was as follows:

Table 2: Actual Cost & Site Utility Usage

	Electric	
Annual Usage	453,759	kWh/yr
Annual Cost	70,339	\$
Blended Rate	0.155	\$/kWh
Consumption Rate	0.127	\$/kWh
Demand Rate	7.91	\$/kW
Peak Demand	234.0	kW
Min. Demand	78.7	kW
Avg. Demand	139.2	kW
	Natural Gas	
Annual Usage	32,745	Therms/yr
Annual Cost	29,990	\$
Rate	0.916	\$/Therm
	Water	
Annual Usage	792,000	gallons/yr
Annual Cost	1,208	\$
Rate	1.525	\$/kgallon

Electrical usage was generally higher in the summer months when air conditioning equipment was operational. Natural gas consumption was highest the in winter months because of building heating. See Appendix A for a detailed utility analysis.






Figure 2: Annual Site Energy Usage

Figure 3: Annual Energy Cost

Under New Jersey's energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. With the supply portion open to competition, customers can shop around for the best price on their energy supplies. Their electric and natural gas distribution utilities will still deliver those supplies through their wires and pipes – and respond to emergencies, should they arise – regardless of where those supplies are purchased. Purchasing your energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of your service. Additional information on selecting a third party energy supplier is available here: <a href="http://www.state.nj.us/bpu/commercial/shopping.html">http://www.state.nj.us/bpu/commercial/shopping.html</a>. See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building's service area.

# 4.0 EXISTING CONDITIONS & AREAS OF ENERGY OPPORTUNITY

Energy conservation measures (ECM) are energy savings improvement recommendations that require a financial investment. These recommendations are justified by the energy and/or cost savings realized over time. Operational and maintenance measures (OMM) are low or no cost operational opportunities, which can be implemented to have positive impacts on overall building operation, comfort levels, or energy usage.

# 4.1 Building Envelope

Lakeside Middle School is built of concrete masonry units with a brick veneer. There is no insulation in the walls and the interior of the building is painted concrete blocks. The rooms and hallways in the school, except for the all-purpose room, have dropped ceiling with insulation above the ceiling tiles.

Windows throughout the school building were originally single glazing aluminum framed operable and non-operable windows. A storm window was placed on top of the original windows to create double glazing. The additional pane was not properly sealed to the original frame and often leads to humidity between the two panes. The windows were noted by faculty and staff as "drafty and leaky." It was noted that the seals between the storm windows and regular windows were not properly sealed and the caulking between the window frame and the building needs to be repaired.

The roof of the school building consists of a flat black rubber membrane roofing system with white gravel stone. The roof is over 20 years old and leaks, during the site visit it was noted that the roof was in poor condition.

The doors in the school were replaced within the last 10 years.

The following energy conservation measures were identified for building envelope improvements:

# 4.1.1 ECM-1 Replace Door & Window Seals

The seals around exterior doors and windows over time fail. This leads to unwanted infiltration of unconditioned outside air and exfiltration of conditioned air resulting in increased heating and cooling energy usage. This measure calls for the replacement of all exterior door seals and window seals including caulking between the window frame and building, seals between the storm and regular window as well as seals for the operable window.

ECM-1 Door & Window Seals

Budgetary Cost	Annual U	Itility Savin	gs		Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
17,000	0	0	3,000	2,900	0	2,900	(0.1)	0	5.9	5.9

Expected
Life: \_\_\_\_\_5 \_ years
Lifetime
Savings: 0 kWh 15,000 therms \$ 14,500

This measure is recommended.

# 4.1.2 ECM-2 Replace Roof & Add Insulation

Flat rubber membrane roofs have an average life expectancy of 20 years. The roof at Lakeside Middle School has exceeded its life span and is poor condition. It is proposed that an insulated white reflective roof is installed to replace the flat black rubber membrane roofing with stone ballasts. In combination with the roof replacement, the measure also recommends insulations under the roof. Un-insulated area leads to increased heat loss from the space below. The installation insulation in the spaces below the roof will reduce the air exfiltration and will decrease the energy consumption of the heating and cooling systems.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2 Replace Roof

Budgetary Cost	Annual U	tility Savinç	js		Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
883,000	0	0	18,900	18,200	0	18,200	(0.5)	0	>20	>20

 Expected Life:
 20
 years

 Lifetime
 Savings:
 0
 kWh
 378,000
 therms
 \$ 364,000

This measure is not recommended because of the long payback period.

<sup>\*</sup> No incentives are available for this measure.

<sup>\*</sup> No incentives are available for this measure.

# 4.2 HVAC Systems

Lakeside Middle School has (2) Weil-McLain cast iron sectional natural gas fired hot water boilers. The capacity of each boiler is 3,480,000 BTU/Hour. The boilers operate in lead lag sequencing where the primary acts alone until the demand is higher than the capacity in which case the secondary boiler turns on. The two boilers cycle primary, secondary positions daily. Hot water is heated to 180°F and is returned around 120°F. The hot water is circulated throughout the building by two 7.5 HP pumps. The classrooms and hallways are served by unit ventilators with hot water coils. The unit ventilators are controlled with pneumatic valves, dampers and actuators. These controls are not precise because of the age of the system.

The kitchen and gym are heated and ventilated by indoor ventilation units with heating hot water coils. The Main offices including the Principal's office, Administrative office, Nurse's office and Guidance office have a packaged rooftop unit with natural gas direct fired heating and dx cooling.

The media center, music and faculty rooms have split dx air conditioners. The classrooms are predominantly not cooled, but a few have window A/C units.

There are 23 exhaust fans in the school to service the restrooms and the kitchen.

Specifics on mechanical equipment can be found within the equipment inventory located in Appendix B.

The following ECMs were identified as HVAC system improvements:

# 4.2.1 ECM-3 Boiler Replacement

The two natural gas fired hot water boilers located in the boiler room have a combined capacity of 6,960,000 BTU/Hour. The combined efficiency of these boilers de-rated for their age is approximately 65%. These boilers are past their service life which according to ASHRAE is 35 years. It is proposed to replace both existing steam boilers with new high efficiency natural gas fired condensing hot water boilers.

The high efficiency condensing hot water boilers have efficiencies between 90%-93% which would result in natural gas savings as the efficiency of the heating system increases. The savings calculations are based upon replacing the boilers with equal sized boilers. Additional savings may be recognized if the new boilers are sized per the system load. Further study is required to determine the system load and properly sized boilers.

ECM-3 Boiler Replacement

Budgetary Cost	Annual U	tility Savings	S		Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
318,000	0	0	9,200	8,900	0	8,900	(0.4)	6,000	>20	>20

Expected Life: 25 years

Lifetime

Savings: 0 kWh 230,000 therms \$ 222,500

This measure is recommended.

#### **OMM-1 HVAC Unit Maintenance**

Regular maintenance of HVAC units is necessary not only because it saves energy by keeping them operating at optimal efficiency, but also insures that the equipment does not fail. Some areas that reduce efficiency are: dirty condenser/evaporator coils, dirty filters and fan blades, air leaks and dirty heat transfer surfaces. Implementing a routine maintenance strategy will allow for better indoor air quality, increased efficiency and improved equipment life.

# 4.3 Control Systems

The building does not have a direct digital control system. The hydronic heating system including the classroom unit ventilators and the hot water boilers utilize pneumatic controls. The system includes valves, actuators and dampers controlled through the use of a 2.5 horsepower air compressor. The pneumatic system is old and outdated, does not function correctly and has depreciated with age. The packaged rooftop unit and split dx air conditioners have their own thermostats.

The pneumatic controls are on a timed schedule through the use of a clock and will reset the water temperature based on outside air temperature. The clock is utilized to set the occupied and unoccupied hours for the heating night set back. In the following table 3 displays the occupied and unoccupied hours and temperatures.

Table 3: Occupied & Unoccupied Hours & Setpoints

	Occupied	Unoccupied
Heating Setpoint	70°F	60°F
Time	7AM-6PM	6PM-7AM

The following ECMs identified are improvements to the school's HVAC control system:

<sup>\*</sup> Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities

# 4.3.1 ECM-4 Install Direct Digital Controls and Building Management System

Pneumatic control systems use compressed air as a medium to control HVAC equipment. This is accomplished by bleeding or draining the compressed air in the air lines going to the control devices such as sensors or thermostats to maintain a set line pressure. This in turn provides feedback in the loop to close or open dampers and actuators to meet the control set point. In addition to the age and inadequacies of the system, compressed air is an inefficient and expensive means of controlling a building's HVAC system.

New direct digital control (DDC) systems use electrical signals to manage HVAC equipment. In combination with a building management system (BMS) which allows for trending, scheduling and remote control, the DDC and BMS system will save natural gas and electrical energy. The new system will be able to set a schedule for occupied and unoccupied setpoints as well as schedule the HVAC equipment for shutdown/startup. It will also eliminate the compressed air system including the air compressor and compressed air dryer.

Savings are seen from temperature scheduling for occupied and unoccupied hours and from the elimination of the air compressor.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-4 Install DDC & BMS

Budgetary Cost	Annual Util	ity Savings			Estimated  Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings	3			incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
310,000	1,300	3	4,700	4,900	0	4,900	(8.0)	0	>20	>20

This measure is not recommended.

#### 4.4 Domestic Hot Water System

Lakeside Middle School has one domestic hot water heater located in the boiler room. The water heater is a State (SBF100 260) natural gas fired commercial domestic hot water heater with a capacity of 100 gallons. The thermal efficiency of the water heater is approximately 80% efficiency with an input of 260,000 BTU/Hour. The domestic hot water heater serves the kitchen, toilet rooms and sinks located throughout the school.

<sup>\*</sup> There are currently no incentives available for this measure.

# 4.5 Lighting/Electrical Systems

The majority of the lighting in the middle school is T-12 fluorescent tube fixtures with magnetic ballasts and incandescent lamps. Some of the school has updated lighting with T8 fluorescent fixtures. The multipurpose room is illuminated with 400 W metal halide high bay fixtures. The exterior lighting is a mixture of mercury vapor, metal halide and high pressure sodium lights. A comprehensive lighting survey can be found in Appendix B.

There are approximately 92 computers in the school. All of the computers have flat screen monitors.

The following ECMs identified are improvements to Lakeside Middle School's lighting system:

# 4.5.1 ECM-5 Lighting Replacement / Upgrades

The school utilizes T-12 fluorescent fixtures. Compared to T-8s these bulbs consume more energy and are less efficient. The ballasts are magnetic as well. Each switch and circuit was identified, and the number of fixtures, locations, and existing wattage established (Appendix B). There is an opportunity to reduce consumption by upgrading the lighting fixtures to a super T-8 fixture and all incandescent fixtures to compact fluorescent lamps. The exterior lighting is proposed to be changed from mixture of mercury vapor, metal halide and high pressure sodium lights to LED lights which has a longer life and consumes much less energy. To upgrade the T12 fixtures to super T8's the fixtures need to be re-lamped and re-ballasted and incandescent replacement only involves changing the bulbs to compact fluorescent bulbs. The exterior lighting would require a full fixture replacement to change to LED fixtures.

Energy savings for this measure were calculated by applying the existing and proposed fixture wattages to estimated times of operation. The difference between energy requirements resulted in a total annual savings of 10,156 kWh with an electrical demand reduction of about 29.5 kW. These calculations are based upon 1 to 1 replacements with the fixtures. They do not take into account lumen output and square footage. A more comprehensive study may be performed to determine correct lighting levels.

ECM-5 Lighting Replacement / Upgrades

Budgetary Cost	Annual Utility	Savings			Estimated  Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings	3			incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
117,000	81,901	29	0	12,500	0	12,500	0.6	14,200	9.4	8.2

Expected Life: 15 years

Lifetime Savings: 1,228,500 kWh 0 therms 187,500

This measure is not recommended in lieu of ECM-7.

# 4.5.2 ECM-6 Install Lighting Controls (Occupancy Sensors)

Review of the comprehensive lighting survey determined that lighting in classrooms and various other spaces are typically operational, regardless of occupancy. Therefore, installing an occupancy sensor in these spaces to turn off lights when the areas are unoccupied was assessed.

This measure recommends installing occupancy sensors for the current lighting system. Using a process similar to that utilized in section 4.5.1, the energy savings for this measure was calculated by applying the known fixture wattages in the space to the estimated existing and proposed times of operation for each fixture. The difference between the two values resulted in an annual savings of 42,600 kWh.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

**ECM-6** Install Lighting Controls (Occupancy Sensors)

Budgetary Cost	Annual Ut	ility Saving	js		Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
20,000	42,600	0	0	6,400	0	6,400	3.8	4,700	3.1	2.4

 Expected

 Life:
 15
 years

 Lifetime
 Savings:
 639,000
 kWh
 0
 therms
 \$ 96,000

This measure is not recommended in lieu of ECM-7.

<sup>\*</sup> Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities.

<sup>\*</sup> Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities.

# 4.5.3 ECM-7 Lighting Replacements with Controls (Occupancy Sensors)

This measure is a combination of ECM 4 and ECM 5; recommending to replace/upgrade the current lighting fixtures to more efficient ones and installing occupancy sensors on the new lights. Interactive effects of the higher efficiency lights and occupancy sensors lead the energy and cost savings for this measure to not be cumulative or equivalent to the sum of replacing the lighting fixtures alone and installing occupancy sensors without the lighting upgrade. The calculated annual savings is 108,411 kWh with a demand reduction of 29.2kW at a total of \$15,800.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-7 Lighting Replacements with Lighting Controls (Occupancy Sensors)

Budgetary Cost	Annual Utili	ty Savings			Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
137,000	108,400	29	0	15,800	0	15,800	0.7	18,900	8.7	7.5

Life:	15	years				
Lifetime						
Savings:	1,626,000	kWh	0	therms	\$ 237,000	

<sup>\*</sup> Incentive shown is per the New Jersey Smart Start Program. See section 5.0 for other incentive opportunities.

This measure is recommended.

## 4.5.4 ECM-8 Install Network Controller

Approximately 92 computers are utilized in the classrooms, offices, media centers and computer labs throughout Lakeside Middle School. These computers are left on for the entire day. A network controller is a remote power management system controlled via the internet. The controller has the ability to reduce total energy draw when computers are not being used which will result in significant energy savings. An evaluation was performed for installing a computer network controller to reduce electrical energy draw from the computer network system when computers are not in use.

Electronic controls have an expected life of 16 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 176,000 kWh and \$25,600.

**ECM-8** Install Network Controller

Budgetary Cost	Annual Ut	ility Saving	S		Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
2,000	11,000	0	0	1,600	0	1,600	12.7	0	1.3	1.3

Expected					
Life:	16	years			
Lifetime					
Savings:	176,000	kWh	0	therms	\$ 25,600

<sup>\*</sup> There are no incentives available for this measure.

This measure is recommended.

# OMM-2 Computer Energy Savings Plan

As an alternative solution to ECM 7, the school could implement an energy saving plan that includes mandating that all computers be manually turned off when they are not in use. If this plan is communicated to all staff members, the savings could potentially be the same as shown above without requiring software installation therefore eliminating the estimated budgetary cost.

# 4.6 Plumbing Systems

The school has older style fixtures in the restrooms. The older style fixtures consume more water than modern plumbing fixtures. It was determined that there is a combination of (27) toilets with an average water use of 5.5 gpf, (14) urinals with an average of 3 gpf and (35) faucets with a flow of 3 gpm. Per the number of occupants, it was estimated that each toilet and faucet is utilized approximately 4 times per day.

The following ECMs identified are improvements to the school's plumbing system:

# 4.6.1 ECM-9 Install Low Flow Plumbing

Faucets, toilets and urinals installed before the 90s consume more water than modern plumbing fixtures. On average faucets installed before the 90s have a flow rate of 3 gallons per minute (gpm), urinals consume approximately 3 gallons per flush (gpf) and toilets typically use 5.5 gpf.

The water savings associated from replacing these fixtures with low-flow fixtures was calculated by taking the difference of the annual water usage for the proposed and base line. The basis of this calculation is the number of times each fixture is used, gallons per use, and number of fixtures. Replacing the existing plumbing fixtures in the school with 1.28 gpf toilets, 0.125 gpf urinals and 0.5 gpm faucets would save 280 KGal annually.

**ECM-9** Install Low Flow Plumbing Fixtures

Budgetary Cost	Annual U	Itility Savin	gs		Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	Water	Total	Savings				incentive)	incentive)
\$	kWh	kW	kGal	\$	\$	\$		\$	Years	Years
223,000	0	0	600	800	0	800	(1.0)	0	>20	>20

This measure is not recommended.

### **OMM-3 Plumbing Upgrade Plan**

Although ECM-9 is not recommended because of the long payback period, low flow plumbing fixtures are still beneficial energy efficient equipment. It is advised that the school implement a plumbing upgrade plan in which new low flow fixtures are installed as the older toilets, urinals and faucet aerators fail.

# 4.7 Kitchen Equipment

Cooking equipment for the kitchen within the facility is fueled by electricity and natural gas. The oven, dishwasher, dishwasher booster heater, steam table, and slicer are all electric powered. The stove is natural gas fired.

The following ECMs identified are improvements to Lakeside Middle School's kitchen equipment:

# 4.7.1 ECM-10 Replace Electric Dishwasher Booster Heater to Natural Gas

Lakeside Middle School uses a 24 kW dishwasher booster heater for drying dishes. The school uses this heater approximately four hours per day for 180 days per year. Utilizing natural gas for the heater was assessed.

The calculation uses electrical consumption and annual electrical cost as the baseline, which was converted to natural gas for the proposed case. The difference between the two values is the energy savings.

<sup>\*</sup> There is no incentive available for this measure.

ECM-10 Replace Kitchen Booster Heater

Budgetary Cost	Annual Ut	ility Saving	js		Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	N. Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
17,000	27,400	24	-900	4,400	0	4,400	2.2	0	3.9	3.9

Expected
Life: 12 years
Lifetime
Savings: 328,800 kWh -10,800 therms \$ 52,800

This measure is recommended.

<sup>\*</sup> Does not qualify for an Incentive per the New Jersey SmartStart Program. See section 5.0 for other incentive opportunities.

# **5.0 PROJECT INCENTIVES**

#### 5.1 Incentives Overview

# 5.1.1 New Jersey Pay For Performance Program

The facility will be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects applied to facilities whose demand in any of the preceding 12 months exceeds 100 kW. This average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations, however. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP).

Incentive Amount: \$0.10/SFMinimum incentive: \$5.000

• Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures. Electric

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved

# Gas

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

# <u>Electric</u>

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/kWh per projected kWh saved

# <u>Gas</u>

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved

The table below shows the potential incentives available for the Lakeside Middle School through the Pay for Performance program:

	Ir	ncentives	\$			
	Elec Gas Total					
Incentive #1	\$0	\$0	\$7,200			
Incentive #2	\$13,556	\$1,932	\$15,488			
Incentive #3	\$13,556 \$1,932 \$15,48					
Total All Incentives	\$27,112 \$3,864 \$38,176					

If all recommended ECM's are implemented, the average annual savings exceeds the 15% threshold savings for the P4P program and therefore all incentives are available. Refer to appendix D for detailed analysis.

# 5.1.2 New Jersey Smart Start Program

For this report, some energy conservation measures are applicable to the 2012 Smart Start Incentive Program and associated savings are included. This program provides incentives for pre-approved mechanical and electrical equipment replacements and pre-approved custom measures. The program includes a wide variety of incentives ranging from chillers and boilers, variable frequency drives, unitary HVAC equipment and lighting retrofits. Each incentive must be applied for and approved by the NJBPU (or corresponding utility program) prior to the installation of the equipment. Incentive payments are made to the owner after the equipment is fully installed and paid for.

# 5.1.3 Direct Install Program

The Direct Install Program targets small and medium sized facilities where the peak electrical demand does not exceed 150 kW in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric utility companies.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can significantly reduce the implementation cost of energy conservation projects.

The program pays a maximum amount of \$75,000 per building, and up to \$250,000 per customer per year. Installations must be completed by a Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website at http://www.njcleanenergy.com. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this document.

Due to the demand exceeding the 150 kW threshold, this building is not eligible for Direct Install incentives.

# 5.1.4 Energy Savings Improvement Plans (ESIP)

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use "energy savings obligations" to pay for the capital costs of energy improvements to their facilities. This can be done over a maximum term of 15 years. Energy savings obligations are not considered "new general obligation debt" of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding bonds or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The "Local Finance Notice" outlines how local governments can develop and implement an ESIP for their facilities (see Appendix E). The ESIP can be prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs.

#### 6.0 ALTERNATIVE ENERGY SCREENING EVALUATION

#### 6.1 Solar

# 6.1.1 Photovoltaic Rooftop Solar Power Generation

The school was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology uses solar cell arrays to produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The building's roof has sufficient room to install a large solar cell array. However, there is not sufficient room to size a system to meet the demand of the building. For this analysis we will consider a 90 KW system to help reduce usage.

The PVWATTS solar power generation model was utilized to calculate PV power generation; this model is provided in Appendix F.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey solar renewable energy certificates program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for a period of 15 years from the date of installation. The average SREC value per credit is estimated to be about \$60/ SREC per year based on current market data, and this number was utilized in the cash flow for this report.

The available roof area justifies the use of 90 kW PV solar array. The system costs for PV installations were derived from contractor budgetary pricing in the state of New Jersey for estimates of total cost of system installation. It should be noted that the cost of installation is currently about \$4.00 per watt or \$4,000 per kW of installed system, for a 50 kW system. Other cost considerations will also need to be considered. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix F and summarized as follows:

Photovoltaic (PV) Rooftop Solar Power Generation - 130 kW System

Budgetary Cost	Annual Utility Savings				Total Savings	New Jersey Renewable Energy Incentive*	New Jersey Renewable SREC**	Payback (without incentive)	Payback (with incentives)
	Electricity		Natural Gas	Total					
\$	kW kWh		Therms	\$	\$	\$	\$	Years	Years
840,000	210	273,700	0	40,781	40,781	0	16,422	20.6	14.7

<sup>\* 30%</sup> federal tax credit

<sup>\*\*</sup> Solar Renewable Energy Certificate Program (SREC) for 2012 is \$82/1000kwh

At 100 square feet per kW of PV panels (rule of thumb), the proposed PV power generation system would require 9,000 square feet of open space. However, it would also require a structural analysis of the existing roof to ensure that it can support the additional weight of the panels. Due to the current SRECs rates we do not recommend this measure at this time.

#### 6.1.2 Solar Thermal Hot Water Plant

Active solar thermal systems use solar collectors to gather the sun's energy to heat water, another fluid, or air. An absorber in the collector converts the sun's energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted around the site's latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production. DHW is presently produced by gasfired water heaters and, therefore, this measure would offer natural gas utility savings.

### 7.0 EPA PORTFOLIO MANAGER

The EPA Portfolio Manager benchmarking tool was used to assess the building's energy performance. Portfolio Manager provides a site and source Energy Use Intensity (EUI), as well as an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100, with 100 being the most efficient. In order for a building to receive and Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed measures, the Energy Star rating will increase.

The site EUI is the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity, such as natural gas or oil; or as secondary energy, which is the product created from a raw fuel such as electricity or district steam. To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, Portfolio Manager uses the convention of source EUIs. The source energy also accounts for losses incurred in production, storage, transmission, and delivery of energy to the site, which provide an equivalent measure for various types of buildings with differing energy sources. The results of the Portfolio Manager benchmarking tool are contained in the table below.

Building	Site EUI kBtu/ft²/yr	Source EUI Btu/ft²/yr	Energy Star Rating (1-100)
Lakeside Middle School	121	205	14

The Lakeside Middle School has an below average Energy Star Rating (Median being 50%). This is attributed to older, inefficient HVAC equipment and controls and a poorly insulated building envelope. By implementing the measures discussed in this report, it is expected that the EUI can be reduced and the Energy Star Score increased.

The Portfolio Manager account can be accessed by entering the username and password shown below at the login screen of the Portfolio Manager website (<a href="https://www.energystar.gov/istar/pmpam/">https://www.energystar.gov/istar/pmpam/</a>). The account has been shared with the NYSERDABENCHMARKING master account.



A full EPA Energy Star Portfolio Manager Report is located in Appendix G.

# 8.0 CONCLUSIONS & RECOMMENDATIONS

The energy audit conducted by CHA at the Lakeside Middle School identified potential annual savings of \$33,600 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

#### ECM-1 Door & Window Seals

Budgetary	Annual U	Itility Savin	gs		Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
17,000	0	0	3,000	2,900	0	2,900	(0.0)	0	5.9	5.9

# **ECM-3** Boiler Replacement

Budgetary	Annual Ut	tility Saving	js		Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
318,000	0	0	9,200	8,900	0	8,900	(0.2)	6,000	>20	>20

# **ECM-7** Lighting Replacements with Lighting Controls (Occupancy Sensors)

Budgetary	Annual Ut	ility Saving	js		Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
137,000	108,400	29.2	0	15,800	0	15,800	0.7	18,900	8.7	7.5

# **ECM-8** Install Network Controller

Budgetary	Annual Utility Savings				Estimated	Total			Payback	Payback
Cost				Maintenance	Savings	ROI	Incentive *	(without	(with	
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
2,000	11,000	0	0	1,600	0	1,600	12.7	0	1.3	1.3

# ECM-10 Replace Kitchen Booster Heater

Budgetary	Annual Utility Savings				Estimated	Total			Payback	Payback
Cost			Maintenance	Savings	ROI	Incentive *	(without	(with		
	Florida	Florido	Nat	T-1-1	0				in a series (in an)	in a set (in a)
	Electric	Electric	Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
17,000	27,400	24	-900	4,400	0	4,400	2.2	0	3.9	3.9

# APPENDIX A

**Utility Usage Analysis and List of Alternate Suppliers** 

# Pompton Lakes Board of Education 237 Van Avenue, Pompton Lakes, NJ 07442

# Annual Utilities 12-month Summary

Electric								
Annual Usage	453,759	kWh/yr						
Annual Cost	70,339	\$						
Blended Rate	0.155	\$/kWh						
Consumption Rate	0.127	\$/kWh						
Demand Rate	7.91	\$/kW						
Peak Demand	234.0	kW						
Min. Demand	78.7	kW						
Avg. Demand	139.2	kW						
Na	atural Gas							
Annual Usage	32,745	Therm/year						
Annual Cost	29,990	\$						
Rate	0.916	\$/Therm						
Water								
Annual Usage	792,000	gallons/yr						
Annual Cost	1,208	\$						
Rate	1.525	\$/kgallon						

# Pompton Lakes Board of Education

237 Van Avenue, Pompton Lakes, NJ 07442

**Utility Bills: Account Numbers** 

Account Number	School Building	<b>Location</b>		<u>Type</u>	<b>Notes</b>
100004509632	Lakeside Middle School	316 Lakeside Avenue, F	Pompton Lakes, NJ 07442	Electricity	
100004509566	Lakeside Middle School	316 Lakeside Avenue, F	Pompton Lakes, NJ 07442	Electricity	
6634854718	Lakeside Middle School	316 Lakeside Avenue, F	Pompton Lakes, NJ 07442	Natural Gas	
323212	Lakeside Middle School	316 Lakeside Avenue, F	Pompton Lakes, NJ 07442	Water	

# Pompton Lakes Board of Education 237 Van Avenue, Pompton Lakes, NJ 07442

For Service at: Lakeside Middle School

 Account No.:
 Meter No.:
 Delivery JCP&L


 100004509632
 G28125066
 Supplier JCP&L

100004509632 G28125066 100004509566 G53357752

						Usage (kWh) vs	s. Demand			
			Provider Charges (kW) Charges		Unit Costs					
Month	Consumption (kWh)	Demand (kW)	Delivery (\$)	Supplier (\$)	Total (\$)	Consumption (\$)	Demand (\$)	Blended Rate (\$/kWh)	Consumption (\$/kWh)	Demand (\$/kW)
August-11	29,196	130.00	\$1,655.57	\$3,280.67	4,936.24	2,744.90	2,191.34	0.17	0.09	16.86
September-11	33,909	179.00	\$1,728.99	\$3,862.90	5,591.89	2,446.26	3,145.63	0.16	0.07	17.57
October-11	Included in Nov	ember Bill								
November-11	68,400	234.00	\$3,075.08	\$6,397.45	9,472.53	8,656.67	815.86	0.14	0.13	3.49
December-11	44,998	128.40	\$2,087.19	\$5,220.09	7,307.28	6,439.12	868.16	0.16	0.14	6.76
January-12	41,603	128.50	\$1,881.00	\$4,638.32	6,519.32	5,651.15	868.17	0.16	0.14	6.76
February-12	56,807	128.60	\$2,224.06	\$6,353.47	8,577.53	7,730.29	847.24	0.15	0.14	6.59
March-12	45,290	123.80	\$1,700.10	\$5,125.70	6,825.80	5,968.10	857.70	0.15	0.13	6.93
April-12	36,460	127.60	\$1,563.71	\$4,127.84	5,691.55	4,708.33	983.22	0.16	0.13	7.71
May-12	37,347	153.30	\$1,828.79	\$4,275.57	6,104.36	4,790.00	1,314.36	0.16	0.13	8.57
June-12	40,087	148.13	\$1,971.61	\$4,809.11	6,780.72	5,510.66	1,270.06	0.17	0.14	8.57
July-12	17,206	110.80	\$1,128.45	\$1,820.49	2,948.94	1,998.97	949.97	0.17	0.12	8.57
August-12	31,652	78.70	\$1,158.36	\$3,360.59	4,518.95	3,844.20	674.75	0.14	0.12	8.57
Total (All)	482,955	234.00	\$22,002.91	\$53,272.20	\$75,275.11	\$60,488.65	\$14,786.46	\$0.16	\$0.13	\$9.29
Total (last 12-months)	453,759	234.00	\$20,347.34	\$49,991.53	\$70,338.87	\$57,743.75	\$12,595.12	\$0.16	\$0.13	\$7.91
Notes	1	2	3	4	5	6	7	8	9	10

- 1.) Number of kWh of electric energy used p
- 2.) Number of kW of power measured
- 3.) Electric charges from Delivery provider
- 4.) Electric charges from Supply provider5.) Total charges (Delivery + Supplier)
- ver measured
- 9.) Consumption Charges (\$) / Consumption (kWh)
- 10.) Demand Charges (\$) / Demand (kW)
- 7.) Charges based on the number of kW of power measured
- 8.) Total Charges (\$) / Consumption (kWh)
- 6.) Charges based on the number of kWh of electric energy used

# **Electric Usage-Lakeside Middle School**



# Pompton Lakes Board of Education 237 Van Avenue, Pompton Lakes, NJ 07442


For Service at: Lakeside Middle School

**Account No.:** 6634854718 **Meter No.:** 3165792

**Natural Gas Service** 

Delivery - PSE&G Supplier - PSE&G

							Ble	ended	
								F	Rate
Month	Total Therms	ı	Delivery (\$)	Su	ipply (\$)	Total (\$)		\$/٦	Therm
Aug-11	88	\$	112	\$	59	\$	171	\$	1.95
Sep-11	153	\$	122	\$	95	\$	217	\$	1.42
Oct-11	1834	\$	1,520	\$	1,121	\$	2,641	\$	1.44
Nov-11	3968	\$	1,924	\$	3,968	\$	4,307	\$	1.21
Dec-11	6101	\$	2,328	\$	3,644	\$	5,972	\$	0.98
Jan-12	7424	\$	2,320	\$	4,252	\$	6,572	\$	0.89
Feb-12	6945	\$	2,302	\$	3,590	\$	5,892	\$	0.85
Mar-12	3231	\$	456	\$	1,592	\$	2,048	\$	0.63
Apr-12	2581	\$	394	\$	1,208	\$	1,601	\$	0.62
May-12	200	\$	128	\$	92	\$	220	\$	1.10
Jun-12	116	\$	116	\$	59	\$	175	\$	1.51
Jul-12	90	\$	112	\$	57	\$	170	\$	1.88
Aug-12	102	\$	114	\$	62	\$	176	\$	1.73
Total (12-months)	32,745	\$	11,836	\$	19,739	\$2	29,990	\$	0.92




# Pompton Lakes Board of Education 237 Van Avenue, Pompton Lakes, NJ 07442

For Service at: Lakeside Middle School

**Account No.:** 323212

Water Delivery -Supplier -

Month	Gallons	Total (\$)	\$/kGal
Oct-11	41,000	\$ 65.50	\$ 1.60
Jan-12	135,000	\$ 206.50	\$ 1.53
Apr-12	187,000	\$ 284.50	\$ 1.52
Jul-12	388,000	\$ 586.00	\$ 1.51
Oct-12	41,000	\$ 65.50	\$ 1.60
Total	792,000	\$ 1,208.00	\$ 1.53



#### JCP&L SERVICE TERRITORY Last Updated: 10/24/12

# $*\underline{\text{CUSTOMER CLASS}} \cdot R - RESIDENTIAL \ C - COMMERCIAL \ I - INDUSTRIAL$

Supplier	Telephone	*Customer
• •	& Web Site	Class
<b>AEP Energy, Inc.</b> 309 Fellowship Road, Fl.2	(866) 258-3782	C/I
Mount Laurel, NJ 08054	www.aepenergy.com	ACTIVE
<b>Alpha Gas and Electric, LLC</b> 641 5 <sup>th</sup> Street	(855) 553-6374	R/C
Lakewood, NJ 08701	www.alphagasandelectric.com	ACTIVE
Ambit Northeast, LLC 103 Carnegie Center	(877) 30-AMBIT (877) 302-6248	R/C
Suite 300 Princeton, NJ 08540	www.ambitenergy.com	ACTIVE
AP Gas & Electric, LLC 10 North Park Place, Suite 420	(855) 544-4895	R/C/I
Morristown, NJ 07960	www.apge.com	ACTIVE
Astral Energy LLC 16 Tyson Place	(201) 384-5552	R/C/I
Bergenfield, NJ 07621	www.astralenergyllc.com	ACTIVE
BBPC, LLC d/b/a Great Eastern Energy	(888) 651-4121	C/I
116 Village Blvd. Suite 200 Princeton, NJ 08540	www.greateasternenergy.com	ACTIVE
Champion Energy Services, LLC	(877) 653-5090	R/C/I
72 Avenue L Newark, NJ 07105	www.championenergyservices.com	ACTIVE
Choice Energy, LLC 4257 US Highway 9, Suite 6C	888-565-4490	R/C
Freehold, NJ 07728	www.4choiceenergy.com	ACTIVE
Clearview Electric, Inc. 505 Park Drive	(888) CLR-VIEW (800) 746-4702	R/C/I
Woodbury, NJ 08096	www.clearviewenergy.com	ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace	1-866-587-8674	R
Ramsey, NJ 07446	www.commerceenergy.com	ACTIVE

Charge Tree Corners Contag	(888) 665-0955	C/I
Cherry Tree Corporate Center 535 State Highway Suite 180	www.conedsolutions.com	ACTIVE
Cherry Hill, NJ 08002		
Constellation NewEnergy, Inc. 900A Lake Street, Suite 2	(866) 237-7693	R/C/I
Ramsey, NJ 07446	www.constellation.com	ACTIVE
Constellation Energy	(877) 997-9995	R
900A Lake Street, Suite 2 Ramsey, NJ 07446	www.constellation.com	ACTIVE
Direct Energy Business, LLC 120 Wood Avenue Suite 611	(888) 925-9115	C/I
Iselin, NJ 08830	www.directenergybusiness.com	ACTIVE
Direct Energy Services, LLC 120 Wood Avenue Suite 611	(866) 547-2722	C/I
Iselin, NJ 08830	www.directenergy.com	ACTIVE
Discount Energy Group, LLC	(800) 282-3331	R/C
811 Church Road, Suite 149 Cherry Hill, NJ 08002	www.discountenergygroup.com	ACTIVE
Dominion Retail, Inc.	(866) 275-4240	R/C
d/b/a Dominion Energy Solutions 395 Route 70 West, Suite 125 Lakewood, NJ 08701	www.dom.com/products	ACTIVE
DTE Energy Supply, Inc.	(877) 332-2450	C/I
One Gateway Center, Suite 2600 Newark, NJ 07102	www.dtesupply.com	ACTIVE
Energy Plus Holdings LLC 309 Fellowship Road East Gate Center, Suite 200	(877) 866-9193	R/C
Mt. Laurel, NJ 08054	www.energypluscompany.com	ACTIVE
Energy.me Midwest LLC	(855) 243-7270	R/C/I
90 Washington Blvd Bedminster, NJ 07921	www.energy.me	ACTIVE

Ethical Electric Benefit Co.	(888) 444-9452	R/C
d/b/a Ethical Electric	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	
100 Overlook Center, 2 <sup>nd</sup> Fl.	www.ethicalelectric.com	ACTIVE
Princeton, NJ 08540		
FirstEnergy Solutions Corp.	(800) 977-0500	C/I
300 Madison Avenue		
Morristown, NJ 07962	_	
	www.fes.com	ACTIVE
Gateway Energy Services	(800) 805-8586	R/C/I
Corp.		
44 Whispering Pines Lane		
Lakewood, NJ 08701	www.gesc.com	ACTIVE
GDF SUEZ Energy Resources	(866) 999-8374	C/I
NA, Inc.		
333 Thornall Street Sixth Floor		
Edison, NJ 08819	www.gdfsuezenergyresources.com	ACTIVE
	(888) 452-2425	C/I
Glacial Energy of New Jersey, Inc.	(888) 432-2423	C/1
75 Route 15 Building E		
Lafayette, NJ 07848	www.glacialenergy.com	ACTIVE
	<u>g</u>	11011,1
Green Mountain Energy	(866) 767-5818	C/I
Company		
211 Carnegie Center Drive		
Princeton, NJ 08540	www.greenmountain.com/commercial-	ACTIVE
	home	
Hess Corporation	(800) 437-7872	C/I
1 Hess Plaza	` `	
1 Hess Plaza Woodbridge, NJ 07095	www.hess.com	ACTIVE
1 Hess Plaza Woodbridge, NJ 07095 HIKO Energy, LLC	` `	
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road	<u>www.hess.com</u> (888) 264-4908	ACTIVE R/C
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666	www.hess.com (888) 264-4908 www.hikoenergy.com	ACTIVE  R/C  ACTIVE
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a	<u>www.hess.com</u> (888) 264-4908	ACTIVE R/C
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet	www.hess.com (888) 264-4908 www.hikoenergy.com	ACTIVE  R/C  ACTIVE
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet	www.hess.com (888) 264-4908 www.hikoenergy.com (877) 390-7155	ACTIVE  R/C  ACTIVE  R/C/I
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling	www.hess.com (888) 264-4908 www.hikoenergy.com	ACTIVE  R/C  ACTIVE
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue	www.hess.com (888) 264-4908 www.hikoenergy.com (877) 390-7155	ACTIVE R/C ACTIVE R/C/I
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling	www.hess.com (888) 264-4908 www.hikoenergy.com (877) 390-7155	ACTIVE  R/C  ACTIVE  R/C/I
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue	www.hess.com (888) 264-4908 www.hikoenergy.com (877) 390-7155	ACTIVE  R/C  ACTIVE  R/C/I
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue Ridgefield, NJ 07657	www.hess.com (888) 264-4908 www.hikoenergy.com (877) 390-7155	ACTIVE  R/C  ACTIVE  R/C/I
1 Hess Plaza Woodbridge, NJ 07095  HIKO Energy, LLC 655 Suffern Road Teaneck, NJ 07666  HOP Energy, LLC d/b/a Metro Energy, HOP Fleet Fueling, HOP Energy Fleet Fueling 1011 Hudson Avenue	www.hess.com           (888) 264-4908           www.hikoenergy.com           (877) 390-7155           www.hopenergy.com	ACTIVE  R/C  ACTIVE  R/C/I  ACTIVE

Independence Energy Group,	(877) 235-6708	R/C
LLC		
211 Carnegie Center Princeton, NJ 08540	www.chooseindependence.com	ACTIVE
Integrys Energy Services, Inc.	(877) 763-9977	C/I
99 Wood Ave, South, Suite 802	(011) 103-3311	C/1
Iselin, NJ 08830		
	www.integrysenergy.com	ACTIVE
Liberty Power Delaware, LLC	(866) 769-3799	R/C/I
3000 Atrium Way Suite 273		
Mt. Laurel, NJ 08054	www.libertypowercorp.com	ACTIVE
,	(866) 769-3799	R/C/I
<b>Liberty Power Holdings, LLC</b> 3000 Atrium Way	(000) 109-3199	N/C/I
Suite 273		ACTIVE
Mt. Laurel, NJ 08054	www.libertypowercorp.com	
Linde Energy Services	(800) 247-2644	C/I
575 Mountain Avenue		
Murray Hill, NJ 07974		
	www.linde.com	ACTIVE
Marathon Power LLC	(888) 779-7255	R/C/I
302 Main Street		A COUNTY
Paterson, NJ 07505	www.mecny.com	ACTIVE
NATGASCO, Inc.	(973) 678-1800 x. 251	R/C
532 Freeman St.	www.supromoonorovino.com	ACTIVE
Orange, NJ 07050	www.supremeenergyinc.com	
NextEra Energy Services New	(877) 528-2890 Commercial	R/C/I
Jersey, LLC 651 Jernee Mill Road	(800) 882-1276 Residential	
Sayreville, NJ 08872	www.nexteraenergyservices.com	ACTIVE
NJ Gas & Electric	(866) 568-0290	R/C/I
1 Bridge Plaza fl.2	(666) 266 6296	100/1
Fort Lee, NJ 07024	www.NJGandE.com	ACTIVE
Noble Americas Energy	(877) 273-6772	C/I
Solutions		
The Mac-Cali Building		
581 Main Street, 8th Floor	www.noblesolutions.com	ACTIVE
Woodbridge, NJ 07095		7.00
North American Power and	(888) 313-9086	R/C/I
Gas, LLC 222 Ridgedale Ave.		
Cedar Knolls, NJ 07927	www.napower.com	ACTIVE
- Coddi 13110115, 145 01721	- THE TRANSPORT OF THE PROPERTY OF THE PROPERT	1101111

Palmco Power NJ, LLC	(877) 726-5862	R/C/I
One Greentree Centre		
10,000 Lincoln Drive East,		
Suite 201 Marlton, NJ 08053	www.PalmcoEnergy.com	ACTIVE
Pepco Energy Services, Inc.	(800) ENERGY-9 (363-7499)	R/C
112 Main St.	(000) 21 (2101 ) (000 / 155)	
Lebanon, NJ 08833		
	www.pepco-services.com	ACTIVE
Plymouth Rock Energy, LLC	(855) 32-POWER (76937)	R/C/I
338 Maitland Avenue		
Teaneck, NJ 07666	www.plymouthenergy.com	ACTIVE
DDI E DI LI C	(900) 291 2000	СЛ
PPL EnergyPlus, LLC 811 Church Road	(800) 281-2000	C/I
Cherry Hill, NJ 08002		ACTIVE
, , , , , , , , , , , , , , , , , , , ,	www.pplenergyplus.com	
Public Power & Utility of New	(888) 354-4415	R/C/I
Jersey, LLC		
39 Old Ridgebury Rd. Suite 14		
Danbury, CT 06810	www.ppandu.com	ACTIVE
Reliant Energy	(877) 297-3795	R/C/I
211 Carnegie Center Princeton, NJ 08540	(877) 297-3780 www.reliant.com/pjm	ACTIVE
ResCom Energy LLC	(888) 238-4041	R/C/I
18C Wave Crest Ave.	(888) 238-4041	K/C/I
Winfield Park, NJ 07036	http://rescomenergy.com	ACTIVE
Respond Power LLC	(877) 973-7763	R/C/I
10 Regency CT		
Lakewood, NJ 08701	www.respondpower.com	ACTIVE
South Jersey Energy	(800) 800-266-6020	C/I
Company		
1 South Jersey Plaza Route 54		
Folsom, NJ 08037	www.southjerseyenergy.com	ACTIVE
Sperian Energy Corp.	(888) 682-8082	R/C/I
1200 Route 22 East, Suite 2000	(000) 002 0002	1001
Bridgewater, NJ 08807		ACTIVE
Starion Energy PA Inc.	(800) 600-3040	R/C/I
101 Warburton Avenue		
Hawthorne, NJ 07506	www.starionenergy.com	ACTIVE

Stream Energy	(877) 369-8150	R
309 Fellowship Road		
Suite 200		
Mt. Laurel, NJ 08054	www.streamenergy.net	ACTIVE
UGI Energy Services, Inc.	(856) 273-9995	C/I
d/b/a GASMARK		
224 Strawbridge Drive		
Suite 107		
Moorestown, NJ 08057	www.ugienergyservices.com	ACTIVE
Verde Energy USA, Inc.	(800) 388-3862	R/C/I
50 East Palisades Avenue		
Englewood, NJ 07631	www.lowcostpower.com	ACTIVE
Viridian Energy	(866) 663-2508	R/C/I
2001 Route 46		
Waterview Plaza		
Suite 310		
Parsippany, NJ 07054	www.viridian.com	ACTIVE
Xoom Energy New Jersey,	(888)997-8979	R/C/I
LLC		
744 Broad Street		
Newark, NJ 07102	www.xoomenergy.com	ACTIVE
YEP Energy	(855) 363-7736	R/C/I
89 Headquarters Plaza North		
#1463	www.yepenergyNJ.com	ACTIVE
Morristown, NJ 07960		
Your Energy Holdings, LLC	(855) 732-2493	R/C/I
One International Boulevard		
Suite 400	www.thisisyourenergy.com	ACTIVE
Mahwah, NJ 07495-0400		

#### PSE&G GAS SERVICE TERRITORY Last Updated: 10/24/12

#### $*\underline{CUSTOMER\ CLASS} - R - RESIDENTIAL\ C - COMMERCIAL\ I - INDUSTRIAL$

Supplier	Telephone & Web Site	*Customer Class
Ambit Northeast, LLC 103 Carnegie Center Suite 300	(877)-30-AMBIT (877) 302-6248	R/C
Princeton, NJ 08540	www.ambitenergy.com	ACTIVE
Astral Energy LLC 16 Tyson Place Bergenfield, NJ 07621	888-850-1872 www.astralenergyllc.com	R/C/I ACTIVE
BBPC, LLC Great Eastern Energy 116 Village Blvd. Suite 200	888-651-4121	C/I
Princeton, NJ 08540	www.greateasternenergy.com	ACTIVE
Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave.	800-746-4720	R/C
Pennsauken, NJ 08110	www.clearviewenergy.com	ACTIVE
Colonial Energy, Inc. 83 Harding Road	845-429-3229	C/I
Wyckoff, NJ 07481	www.colonialgroupinc.com	ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace	(888) 817-8572	R
Ramsey, NJ 07746	www.commerceenergy.com	ACTIVE
Compass Energy Services, Inc. 1085 Morris Avenue, Suite 150 Union, NJ 07083	866-867-8328 908-638-6605 <u>www.compassenergy.net</u>	C/I ACTIVE
ConocoPhillips Company 224 Strawbridge Drive, Suite 107	800-646-4427	C/I
Moorestown, NJ 08057	www.conocophillips.com	ACTIVE
Consolidated Edison Energy, Inc. d/b/a Con Edison Solutions 535 State Highway 38, Suite 140	888-686-1383 x2130 www.conedenergy.com	
Cherry Hill, NJ 08002	www.conedenergy.com	

Consolidated Edison Solutions, Inc.	888-665-0955	C/I		
Cherry Tree Corporate Center 535 State Highway 38, Suite 140 Cherry Hill, NJ 08002	www.conedsolutions.com	ACTIVE		
Constellation NewEnergy-Gas	(800) 900-1982	C/I		
Division, LLC 900A Lake Street, Suite 2 Ramsey, NJ 07466	www.constellation.com	ACTIVE		
Direct Energy Business, LLC	888-925-9115	C/I		
120 Wood Avenue, Suite 611 Iselin, NJ 08830	www.directenergy.com	ACTIVE		
Direct Energy Services, LLP	866-348-4193	R		
120 Wood Avenue, Suite 611 Iselin, NJ 08830	www.directenergy.com	ACTIVE		
Gateway Energy Services Corp.	800-805-8586	R/C/I		
44 Whispering Pines Lane Lakewood, NJ 08701	www.gesc.com	ACTIVE		
UGI Energy Services, Inc.	856-273-9995	C/I		
d/b/a GASMARK 224 Strawbridge Drive, Suite 107 Moorestown, NJ 08057	www.ugienergyservices.com	ACTIVE		
Global Energy Marketing, LLC	800-542-0778	C/I		
129 Wentz Avenue Springfield, NJ 07081	www.globalp.com	ACTIVE		
Great Eastern Energy	888-651-4121	C/I		
116 Village Blvd., Suite 200 Princeton, NJ 08540	www.greateastern.com	ACTIVE		
Greenlight Energy	718-204-7467	С		
330 Hudson Street, Suite 4 Hoboken, NJ 07030	www.greenlightenergy.us	ACTIVE		
Hess Energy, Inc.	800-437-7872	C/I		
One Hess Plaza Woodbridge, NJ 07095	www.hess.com	ACTIVE		
Hess Small Business Services, LLC One Hess Plaza	888-494-4377	C/I		
Woodbridge, NJ 07095	www.hessenergy.com	ACTIVE		
HIKO Energy, LLC 655 Suffern Road	(888) 264-4908	R/C		
Teaneck, NJ 07666	www.hikoenergy.com ACTIVE			

Hudson Energy Services, LLC 7 Cedar Street	877- Hudson 9	С
Ramsey, NJ 07446	www.hudsonenergyservices.com	ACTIVE
IDT Energy, Inc.	877-887-6866	R/C
550 Broad Street Newark, NJ 07102	www.idtenergy.com	ACTIVE
Integrys Energy Services – Natural	800-536-0151	C/I
Gas, LLC 99 Wood Avenue South		
Suite #802 Iselin, NJ 08830	www.integrysenergy.com	ACTIVE
Intelligent Energy	800-927-9794	R/C/I
2050 Center Avenue, Suite 500 Fort Lee, NJ 07024	www.intelligentenergy.org	ACTIVE
Keil & Sons, Inc.	1-877-797-8786	R/C/I
d/b/a Systrum Energy 1 Bergen Blvd.		
Fairview, NJ 07022	www.systrumenergy.com	ACTIVE
Major Energy Services, LLC 10 Regency CT	888-625-6760	R/C/I
Lakewood, NJ 08701	www.majorenergy.com	ACTIVE
Marathon Power LLC	888-779-7255	R/C/I
302 Main Street Paterson, NJ 07505	www.mecny.com	ACTIVE
Metromedia Energy, Inc.	800-828-9427	С
6 Industrial Way Eatontown, NJ 07724	www.metromediaenergy.com	ACTIVE
Metro Energy Group, LLC	888-53-Metro	R/C
14 Washington Place Hackensack, NJ 07601	www.metroenergy.com	ACTIVE
MxEnergy, Inc.	800-758-4374	R/C/I
900 Lake Street Ramsey, NJ 07446	www.mxenergy.com	ACTIVE
NATGASCO (Mitchell Supreme) 532 Freeman Street	800-840-4GAS	С
Orange, NJ 07050	www.natgasco.com	ACTIVE
New Energy Services LLC	800-660-3643	R/C/I
101 Neptune Avenue Deal, New Jersey 07723	www.newenergyservicesllc.com	ACTIVE

New Jersey Gas & Electric	866-568-0290	R/C
1 Bridge Plaza, Fl. 2 Fort Lee, NJ 07024	www.NJGandE.com	ACTIVE
Noble Americas Energy Solutions The Mac-Cali Building 581 Main Street, 8th fl.	877-273-6772	C/I
Woodbridge, NJ 07095	www.noblesolutions.com	ACTIVE
North American Power & Gas, LLC d/b/a North American Power 197 Route 18 South Ste. 3000 East Brunswick, NJ 08816	(888) 313-9086 <u>www.napower.com</u>	R/C/I ACTIVE
Palmco Energy NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201	877-726-5862	R/C/I
Marlton, NJ 08053	www.PalmcoEnergy.com	ACTIVE
Pepco Energy Services, Inc. 112 Main Street	800-363-7499	C/I
Lebanon, NJ 08833	www.pepco-services.com	ACTIVE
Plymouth Rock Energy, LLC 338 Maitland Avenue	855-32-POWER (76937)	R/C/I
Teaneck, NJ 07666	www.plymouthenergy.com	ACTIVE
PPL EnergyPlus, LLC 811 Church Road - Office 105 Cherry Hill, NJ 08002	800-281-2000 www.pplenergyplus.com	C/I ACTIVE
Respond Power LLC	(877) 973-7763	R/C/I
10 Regency CT Lakewood, NJ 08701	www.respondpower.com	ACTIVE
South Jersey Energy Company 1 South Jersey Plaza, Route 54	800-266-6020	C/I
Folsom, NJ 08037	www.southjerseyenergy.com	ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4	800-695-0666	R/C
Barrington, NJ 08007	www.sjnaturalgas.com	ACTIVE
Spark Energy Gas, L.P. 2105 CityWest Blvd, Ste 100	800-411-7514	R/C/I
Houston, Texas 77042	www.sparkenergy.com	ACTIVE
Sprague Energy Corp. 12 Ridge Road	855-466-2842	C/I
Chatham Township, NJ 07928	www.spragueenergy.com	ACTIVE

Stuyvesant Energy LLC	800-640-6457	C
10 West Ivy Lane, Suite 4 Englewood, NJ 07631	www.stuyfuel.com	ACTIVE
Stream Energy New Jersey, LLC	(973) 494-8097	R/C
309 Fellowship Road Suite 200	www.stroomonorgy.not	ACTIVE
Mt. Laurel, NJ 08054	www.streamenergy.net	ACTIVE
Systrum Energy	877-797-8786	R/C/I
1 Bergen Blvd. Fairview, NJ 07022	www.systrumenergy.com	ACTIVE
Woodruff Energy	800-557-1121	R/C/I
73 Water Street	1 66	A CONTENT
Bridgeton, NJ 08302	www.woodruffenergy.com	ACTIVE
Woodruff Energy US LLC	856-455-1111	C/I
73 Water Street, P.O. Box 777	800-557-1121	
Bridgeton, NJ 08302	www.woodruffenergy.com	ACTIVE
Xoom Energy New Jersey, LLC	888-997-8979	R/C/I
744 Broad Street		
Newark, NJ 07102	<u>www.xoomenergy.com</u>	ACTIVE
Your Energy Holdings, LLC	(855) 732-2493	R/C/I
One International Boulevard		
Suite 400		
Mahwah, NJ 07495-0400	www.thisisyourenergy.com	ACTIVE

Back to main supplier information page

#### **APPENDIX B**

**Equipment Inventory** 

### Lakeside Middle School CHA Project#24698 316 Lakeside Avenue Pompton, NJ 07442

Description	QTY	Manufacturer Name	Model No.	Serial No.	Equipment Type / Utility	Capacity/Size /Efficiency	Location	Areas/Equipment Served
Air Compressor	1	Ingersoll Rand	2-234D4	30T735653	Air Compressor / Electric	2.5/80%	Boiler Room	HVAC Pneumatics
Heating Hot Water Boiler 1	1	Weil McLain	BG-1394WF	2	Boiler/NG	3508MBH	Boiler Room	
Heating Hot Water Boiler 2	1	Weil McLain	BG-1394WF	1	Boiler/NG	3508MBH	Boiler Room	
Heating Hot Water Pump 1	1	Century	SC-254U-KAA		HVAC /Electric	7.5HP/80%	Boiler Room	
Heating Hot Water Pump 2	1	Century	SC-254U-KAA		HVAC /Electric	7.5HP/80%	Boiler Room	
DHW	1	Weiss	SBF100 260 NET1	A97102216	DHW	100 Gallons	Boiler Room	
HV-1	1	Audivent	H-22-WSF	468889-02	Ventilation/Electric	641RPM	Ventilation Room	
HV-2	1	Trane	L3	K132035	Ventilation/Electric		Ventilation Room	
RTU-6	1	Lennox	HS26-030-2P	5899G 58331	HVAC/DX Cooling	2.5 Tons	Roof	
RTU-7	1		AUC-306B	C81F-13766	HVAC/DX Cooling		Roof	
RTU-1	1	Carrier	48TME006-A-501	3205G30208	HVAC/DX Cooling, NG Heating	115,000BTUH/80%	Roof	
RTU-2	1	Lennox	GCS16-090-200-2Y	5601G00617	HVAC/DX Cooling, NG Heating	200,000BTUH/80%	Roof	
AC-1	1	Sanyo		44512	HVAC/DX Cooling		Roof	
EF1-EF23	15				Exhaust/Electric	Varies	Roof	
UV1-UV35	35				HVAC/Hot Water Heating		Classrooms & Hallways	

Cost of Electricity:

\$0.124 \$/kWh \$6.76 \$/kW

Consumption Demand

							EXISTING	CONDITIONS					
	Aroa Doscription	Heado	No. of Switches	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Retrofit Control	Annual kWh	
Field	Area Description Unique description of the location - Room	Usage Describe Usage Type	Number of	No. of	"Lighting Fixture Code"	Code from Table of	Value from	kW/Space (Watts/Fixt) * (Fixt	Pre-inst. control	Estimated	Retrofit contro	(kW/space) *	Not
Code	number/Room name: Floor number (if	using Operating Hours	Switches in Room			Standard Fixture Wattages	Table of	No.)	device	annual hours	device	(Annual Hours)	140
	applicable)	3 1 3			R F(U) = 2'x2' Troff 40 w	j .	Standard	,		for the usage		<b> </b> `	
					Recess. Floor 2 lamps U shape		Fixture			group			
							Wattages						
		0:			1.100	1400/4	400	2.12	0)4/	4000	000	100	
80  02	Boiler Room Gym	Storage Classroom	1 14	1 1 1 1	I 100 High Bay MH 400	I100/1 MH400/1	100 458	0.10 6.41	SW BR	1000 2400	OSR OSR	100 15,389	
36	Girl's Locker Room	Locker	14	6	S 34 P F 2 (MAG)	F42EE	72	0.43	SW	2800	OSR	1,210	
91	Girl's Locker Room-Shower	Locker	1	6	175	175/1	75	0.45	SW	2800	OSR	1,260	
36	Girl's Gym Office Entrance	Office	1	1	S 34 P F 2 (MAG)	F42EE	72	0.07	SW	2400	OSR	173	
36	Girl's Gym Office Entrance	Office	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	2400	OSR	173	
24	Girl's Gym Office Bathroom	Bathroom	1	1	W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	Gym Storage	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.14	SW	1000	OSR	144	
36	Gym Storage	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
36	Boy's Gym Office Entrance	Office	1		S 34 P F 2 (MAG)	F42EE	72	0.14	SW	2400	OSR	346	
36	Boy's Gym Office	Office	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	2400	OSR	173	
24	Boy's Gym Office Bathroom	Bathroom	1		W 20 C F 2	F22SS	56	0.11	SW	2000	N/A	224	
36	Boy's Locker Room	Locker	1		S 34 P F 2 (MAG)	F42EE	72	0.79	SW	2800	OSR	2,218	
36	Kitchen Storage	Cafeteria	3		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	1600	OSR	1,728	
36	Kitchen Storage	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
24 36	Kitchen Bathroom Storage Room	Bathroom Storage	1		W 20 C F 2 S 34 P F 2 (MAG)	F22SS F42EE	56 72	0.06 0.07	SW SW	2000 1000	N/A OSR	112 72	
24	114 (Art)	Classroom	3		W 20 C F 2	F22SS	56	1.68	SW	2400	OSR	4,032	
36	Art Storage	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
36	Music	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	2.09	SW	2400	OSR	5,011	
36	Music Storage	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.29	SW	1000	OSR	288	
6	Music Office	Office	1		S 34 P F 2 (MAG)	F42EE	72	0.14	SW	2400	OSR	346	
6	Music Office 2	Office	1		S 34 P F 2 (MAG)	F42EE	72	0.14	SW	2400	OSR	346	
6	Music Storage 2	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
3	Stairway Near Music	Stairway	1	2	T 32 R F 3 (ELE)	F43ILL	89	0.18	SW	3200	N/A	570	
4	Stairway Near Music	Stairway	-	1	W 20 C F 2	F22SS	56	0.06	SW	3200	N/A	179	
9	107	Classroom	3	21	2B 34 R F 2 (u) (MAG)	FU2EE	72	1.51	SW	2400	OSR	3,629	
69	107 Office	Office	1		2B 34 R F 2 (u) (MAG)	FU2EE	72	0.07	SW	2400	OSR	173	
69	107 Storage	Storage	1		2B 34 R F 2 (u) (MAG)	FU2EE	72	0.14	SW	1000	OSR	144	
36	105	Classroom	3		S 34 P F 2 (MAG)	F42EE	72	1.73	SW	2400	OSR	4,147	
36	103	Classroom	3	24	S 34 P F 2 (MAG)	F42EE	72	1.73	SW	2400	OSR	4,147	
36	103 Storage	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.58	SW	1000	OSR	576	
36	101	Classroom	3		S 34 P F 2 (MAG)	F42EE	72	1.73	SW	2400	OSR	4,147	
36	Server Room	Storage	1	1	S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
24	1st Floor Boy's Bathroom	Bathroom	1	1	W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	1st Floor Boy's Bathroom	Bathroom	1	3	S 34 P F 2 (MAG)	F42EE	72	0.22	SW	2000	N/A	432	
36	1st Floor Maintenance	Storage	1	1	S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
4	1st Floor Girl's Bathroom	Bathroom	1	1	W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
86	1st Floor Girl's Bathroom	Bathroom	1	3	S 34 P F 2 (MAG)	F42EE	72	0.22	SW	2000	N/A	432	
18	Nurse	Office	2	5	T 32 R F 4 (ELE)	F44ILL	112	0.56	SW	2400	OSR	1,344	
4	Nurse Bathroom	Office	1	1	W 20 C F 2	F22SS	56	0.06	SW	2400	OSR	134	
8	Entryway  Principal's Office	Hallway	1	1	F42ILL	F42ILL	59	0.06	SW	2280	N/A	135	
3	Principal's Office	Office	1	b 4	T 32 R F 3 (ELE)	F43ILL	89	0.53	SW	2400	OSR	1,282	
24	Principal's Bathroom	Bathroom	1	1	W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
43	Main Office  Main Office Bathroom	Office	2	10	T 32 R F 3 (ELE)	F43ILL	89	0.89	SW	2400	OSR	2,136	
24	Main Office Bathroom  Main Office Closet	Bathroom	1	1	W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36 43	Assistant Principal's Office	Storage Office	1	<u> </u>	S 34 P F 2 (MAG) T 32 R F 3 (ELE)	F42EE F43ILL	72 89	0.14 0.36	SW SW	1000 2400	OSR OSR	144 854	
43	Office	Office	1	4	T 32 R F 3 (ELE)	F43ILL F43ILL	89	0.36	SW	2400	OSR	214	
43 43	Office	Office	1	1	T 32 R F 3 (ELE)	F43ILL F43ILL	89	0.09	SW	2400	OSR	214	

11/12/2012 Page 1, Existing

Cost of Electricity:

\$0.124 \$/kWh \$6.76 \$/kW

Consumption Demand

							EXISTING	CONDITIONS					
				No. of			Wette ner				Dotrofit		
	Area Description	Usage	No. of Switches	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	Exist Control	Annual Hours	Retrofit Control	Annual kWh	
Field	Unique description of the location - Room	Describe Usage Type	Number of	No. of	"Lighting Fixture Code"	Code from Table of	Value from	(Watts/Fixt) * (Fixt	Pre-inst. control	Estimated	Retrofit control	(kW/space) *	Notes
Code	number/Room name: Floor number (if	using Operating Hours	Switches in Room		Example 2T 40	Standard Fixture Wattages	Table of	No.)	device	annual hours	device	(Annual Hours)	
	applicable)				R F(U) = $2'x2'$ Troff 40 w		Standard			for the usage			
				retrofit	Recess. Floor 2 lamps U shape		Fixture Wattages			group			
20	102	Classroom	2	4.5		E40EE		4.00	CW	0.400	OCD	2.502	
36 36	102 104	Classroom Classroom	2		S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.08 1.08	SW SW	2400 2400	OSR OSR	2,592 2,592	
36	106	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	1st Floor Girl's Bathroom	Bathroom	1		S 34 P F 2 (MAG)	F42EE	72	0.22	SW	2000	N/A	432	
24	1st Floor Girl's Bathroom Entrance	Bathroom	1		W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	1st Floor Boy's Bathroom	Bathroom	1		S 34 P F 2 (MAG)	F42EE	72	0.22	SW	2000	N/A	432	
24	1st Floor Boy's Bathroom Entrance	Bathroom	1		W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	Maintenance Room	Storage	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
36	108	Classroom	3		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	110 112	Classroom	3		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36 69	Hallway	Classroom Hallway	3		S 34 P F 2 (MAG) 2B 34 R F 2 (u) (MAG)	F42EE FU2EE	72 72	1.51 3.89	SW SW	2400 2280	OSR N/A	3,629 8,865	
69	1st Entry	Hallway	-		2B 34 R F 2 (u) (MAG)	FU2EE	72	0.22	SW	2280	N/A	492	
69	Stairway	Stairway	-		2B 34 R F 2 (u) (MAG)	FU2EE	72	0.07	SW	3200	N/A	230	
69	Stairway	Stairway	-		2B 34 R F 2 (u) (MAG)	FU2EE	72	0.07	SW	3200	N/A	230	
43	Stairwell	Stairway	-	2	T 32 R F 3 (ELE)	F43ILL	89	0.18	SW	3200	N/A	570	
43	Stairwell	Stairway	-	2	T 32 R F 3 (ELE)	F43ILL	89	0.18	SW	3200	N/A	570	
43	Stairwell	Stairway	-	2	T 32 R F 3 (ELE)	F43ILL	89	0.18	SW	3200	N/A	570	
36	219 Faculty Room	Classroom	4	30	S 34 P F 2 (MAG) T 32 R F 3 (ELE)	F42EE	72	2.16 0.71	SW	2400	OSR	5,184	
43 80	Faculty Room	Office Storage	3	8	1 32 R F 3 (ELE)	F43ILL I100/1	89 100	0.71	SW SW	2400 1000	OSR OSR	1,709 500	
36	2nd Floor Men's Bathroom	Bathroom	1	1	S 34 P F 2 (MAG)	F42EE	72	0.07	SW	2000	N/A	144	
24	2nd Floor Men's Bathroom	Bathroom	<u> </u>		W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	216	Classroom	2	18	S 34 P F 2 (MAG)	F42EE	72	1.30	SW	2400	OSR	3,110	
24	2nd Floor Women's Bathroom Entrance	Bathroom	1		W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	2nd Floor Women's Bathroom Storage	Bathroom	1		S 34 P F 2 (MAG)	F42EE	72	0.07	SW	2000	N/A	144	
36	2nd Floor Women's Bathroom 2nd Boy's Bathroom Entrance	Bathroom Bathroom	1		S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.14 0.06	SW SW	2000	N/A N/A	288	
24 36	2nd Boy's Bathroom	Bathroom	1		S 34 P F 2 (MAG)	F42EE	72	0.06	SW	2000	N/A N/A	112 576	
36	214	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	212	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	2nd Floor Maintenance Closet	Storage	1	1	S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
24	2nd Floor Girl's Bathroom Entrance	Bathroom	1		W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	2nd Floor Girl's Bathroom	Bathroom	1		S 34 P F 2 (MAG)	F42EE	72	0.29	SW	2000	N/A	576	
36	210 208	Classroom Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW SW	2400	OSR OSR	2,592 2,592	
36 36	208	Classroom	2		S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.08 1.08	SW	2400 2400	OSR	2,592	
36	204A	Classroom	1		S 34 P F 2 (MAG)	F42EE	72	0.14	SW	2400	OSR	346	
70	Periodical Room	Classroom	1		2T 32 R F 2 (u) (ELE)	FU2ILL	59	0.24	SW	2400	OSR	566	
36	204	Classroom	2	15	S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	202	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
42	Media Center	Classroom	-	25	T 34 R F 3 (MAG)	F43EE	115	2.88	SW	2400	OSR	6,900	
36 36	Media Center Office  Media Center Conference Room	Office Office	1		S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.29 0.43	SW SW	2400 2400	OSR OSR	691 1,037	
36 36	Media Center Conference Room  Media Center Storage	Storage	1		S 34 P F 2 (MAG)	F42EE F42EE	72	0.43	SW SW	1000	OSR	72	
36	PC Lab	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	203	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
70	2nd Floor Hallway	Hallway	-	50	2T 32 R F 2 (u) (ELE)	FU2ILL	59	2.95	SW	2280	N/A	6,726	
36	205A	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	0.43	SW	2400	OSR	1,037	
36	205	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	207	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36 36	209 211	Classroom Classroom	2		S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.08 1.08	SW SW	2400 2400	OSR OSR	2,592 2,592	
36	411	CiassiUUIII		10	0 04 F F Z (IVIAU)	F4ZEE	12	1.00	344	<u> </u>	UOK	2,592	

11/12/2012 Page 2, Existing

**Cost of Electricity:** 

\$0.124 \$/kWh \$6.76 \$/kW

Consumption Demand

_													
Field	Area Description	Usage	No. of Switches  Number of	No. of Fixtures	Standard Fixture Code	Fixture Code  Code from Table of	Watts per Fixture	kW/Space (Watts/Fixt) * (Fixt	Exist Control Pre-inst. control	Annual Hours		Annual kWh	Notes
Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	Describe Usage Type using Operating Hours	Switches in Room	fixtures before the		Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	No.)	device	Estimated annual hours for the usage group		(kW/space) * (Annual Hours)	Notes
24	2nd Floor Girl's Bathroom Entrance	Bathroom	1	1	W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	2nd Floor Girl's Bathroom	Bathroom	1	4	S 34 P F 2 (MAG)	F42EE	72	0.29	SW	2000	N/A	576	
36	Maintenance Room	Storage	1	1	S 34 P F 2 (MAG)	F42EE	72	0.07	SW	1000	OSR	72	
36	213	Classroom	2	10	S 34 P F 2 (MAG)	F42EE	72	0.72	SW	2400	OSR	1,728	
24	2nd Floor Boy's Bathroom Entrance	Bathroom	1	1	W 20 C F 2	F22SS	56	0.06	SW	2000	N/A	112	
36	2nd Floor Boy's Bathroom	Bathroom	1	4	S 34 P F 2 (MAG)	F42EE	72	0.29	SW	2000	N/A	576	
36	215	Classroom	2		S 34 P F 2 (MAG)	F42EE	72	1.08	SW	2400	OSR	2,592	
36	217	Classroom	2	18	S 34 P F 2 (MAG)	F42EE	72	1.30	SW	2400	OSR	3,110	
82	Exterior	Outdoor Lighting	-	22	WP100 I 2	i100/2	200	4.40	BR	4368	N/A	19,219	
108	Exterior	Outdoor Lighting	-	7	100W Mercury Vapor	MV100/1	125	0.88	BR	4368	N/A	3,822	
96	Exterior	Outdoor Lighting	-	11	175 MH POLE	MH175/1	215	2.37	BR	4368	N/A	10,330	
75	Exterior	Outdoor Lighting	-	4	HPS 150	HPS150/1	188	0.75	BR	4368	N/A	3,285	
	Total			925				77.85				197,999	

11/12/2012 Page 3, Existing

#### **APPENDIX C**

#### **ECM Calculations**

Summary o	of Energy Conservation Measures						
	Energy Conservation Measure	Approx. Costs	Approx. Savings (\$/year)	Payback (Years) w/o Incentive	Incentive	(Years)	Recommended For Implementation
		(\$)				w/ Incentive	
ECM-1	Door & Window Seals	17,000	2,900	6	0	6	X
ECM-2	Replace Roof	883,000	18,200	>20	0	>20	
ECM-3	Boiler Replacement	318,000	8,900	>20	6,000	>20	X
ECM-4	Install DDC & BMS	310,000	4,900	>20	0	>20	
ECM-5	Lighting Replacement / Upgrades	117,000	12,500	9	14,200	8	
ECM-6	Install Lighting Controls (Occupancy Sensors)	20,000	6,400	3	4,700	2	
ECM-7	Lighting Replacements with Lighting Controls	137,000	15,800	9	18,900	7	X
ECM-8	Install Network Controller	2,000	1,600	1	0	1	X
ECM-9	Install Low Flow Plumbing Fixtures	223,000	800	>20	0	>20	
ECM-10	Replace Kitchen Booster Heater	17,000	4,400	4	0	4	X

#### Pompton Lakes-Lakeside MS - NJBPU CHA Project #24698 Lakeside Middle School

#### **ECM Summary Sheet**

#### ECM-1 Door & Window Seals

Budgetary Cost	Annual Utility S	avings			Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
17,000	0	0	3,000	2,900	0	2,900	(0.1)	0	5.9	5.9

Expected Life: 5 years

Lifetime Savings: 0 kWh 15,000 therms \$ 14,500

ECM-2 Replace Roof

Budgetary Cost	Annual Utility S	avings			Estimated Maintenance	Total Savings	ROI	Incentive *	Payback (without	Payback (with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
883,000	0	0	18,900	18,200	0	18,200	(0.6)	0	>20	>20

Expected Life: 20 years

Lifetime Savings: 0 kWh 378,000 therms \$364,000

ECM-3 Boiler Replacement

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
318,000	0	0	9,200	8,900	0	8,900	(0.3)	6,000	>20	>20

Expected Life: 25 years

Lifetime Savings: 0 kWh 230,000 therms \$222,500

#### ECM-4 Install DDC & BMS

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
310,000	1,300	3	4,700	4,900	0	4,900	(0.7)	0	>20	>20

Expected Life: 16 years

Lifetime Savings: 20,800 kWh 75,200 therms \$ 78,400

#### ECM-5 Lighting Replacement / Upgrades

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
117,000	81,901	29	0	12,500	0	12,500	0.6	14,200	9.4	8.2

Expected Life: 15 years

Lifetime Savings: 1,228,500 kWh 0 therms \$ 187,500

ECM-6 Install Lighting Controls (Occupancy Sensors)

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
20,000	42,600	0	0	6,400	0	6,400	3.8	4,700	3.1	2.4

Expected Life: 15 years

Lifetime Savings: 639,000 kWh 0 therms \$ 96,000

ECM-7 Lighting Replacements with Lighting Controls

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
137,000	108,400	29	0	15,800	0	15,800	0.7	18,900	8.7	7.5

Expected Life: 15 years

Lifetime Savings: 1,626,000 kWh 0 therms \$237,000

ECM-8 Install Network Controller

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
2,000	11,000	0	0	1,600	0	1,600	13.9	0	1.3	1.3

Expected Life: 16 years

Lifetime Savings: 176,000 kWh 0 therms \$ 25,600

ECM-9 Install Low Flow Plumbing Fixtures

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Water	Total	Savings				incentive)	incentive)
\$	kWh	kW	kGal	\$	\$	\$		\$	Years	Years
223,000	0	0	600	800	0	800	(1.0)	0	>20	>20

Expected Life: 15 years

Lifetime Savings: 0 kWh 9,000 kGal \$ 12,000

ECM-10 Replace Kitchen Booster Heater

Budgetary	Annual Utility S	avings			Estimated	Total			Payback	Payback
Cost					Maintenance	Savings	ROI	Incentive *	(without	(with
	Electric	Electric	Nat Gas	Total	Savings				incentive)	incentive)
\$	kWh	kW	Therms	\$	\$	\$		\$	Years	Years
17,000	27,400	24	-900	4,400	0	4,400	2.2	0	3.9	3.9

Expected Life: 12 years

Lifetime Savings: 328,800 kWh -10,800 therms \$ 52,800

Paterson, NJ 2012 RS Means							
01							
25							
.00							

U	tility Costs	Yearly Usage	MTCDE
\$ 0.149	\$/kWh blended		0.0004
\$ 0.124	\$/kWh consumption	386,100.0	0.0004
\$ 6.760	\$/kW	153.3	0.0000
\$ 0.964	\$/Therm	32,745.0	0.0053
\$ 1.525	\$/kGallon Water	792.0	


Building Area	nual Utility C	ost
72,000	Electric	Natural Gas
	386,100	32,745

			Lakeside Mid	ddle Schoo	ı															
	Item										NJ Smart									
				Savings			Cost	Simple		Life	Start	Direct Install	Direct Instal	Max		Payback w/	Incentives			ROI
		kW	kWh	therms	kGal	\$		Payback	MTCDE	Expectancy	Incentives	Eligible (Y/N)*	Incentives**	Incentives	ncentives**	kW	kWh	therms	\$	
ECM-1	Door & Window Seals	0.0	0	3,025.92	0.00	\$ 2,900	\$ 16,553	5.7	16.1	5	\$	- N	\$ -	\$ -	5.7	0.0	0	15,130	\$ 14,585	(0.1)
ECM-2	Replace Roof	0.0	0	18,916.05	0.00	\$ 18,200	\$ 883,141	48.5	100.9	20	\$	- N	\$ -	\$ -	48.5	0.0	0	378,321	\$ 364,701	(0.6)
	Boiler Replacement	0.0	0	9,221.97	0.00	\$ 8,900	\$ 318,188	35.8	49.2	25	\$ 6,000	) N	\$ -	\$ -	35.8	0.0	0	230,549	\$ 222,249	(0.3)
ECM-4	Install DDC & BMS	2.5	1,250	4,713.45	0.00	\$ 4,900	\$ 309,510	63.2	25.7	16	\$	- N	\$ -	\$ -	63.2	40.0	20,000	75,415	\$ 78,425	(0.7)
	Lighting Replacement / Upgrades	29.2	81,901	0.00	0.00	\$ 12,500	\$ 116,874	9.3	34.4	15	\$ 14,24	5 N	\$ -	\$ -	9.3	438.0	1,228,515	0	\$ 187,866	0.6
	Install Lighting Controls (Occupancy Sensors)		42,649	0.00	0.00	\$ 6,400	\$ 19,950	3.1	17.9	15	\$ 4,65	5 N	\$ -	\$ -	3.1	0.0	639,735	0	\$ 95,321	3.8
	Lighting Replacements with Lighting Controls	29.2	108,411	0.00	0.00	\$ 15,800	\$ 136,824	8.7	45.6	15	\$ 18,900	) N	\$ -	\$ -	8.7	438.0	1,626,165	0	\$ 237,175	0.7
ECM-8	Install Network Controller	0.0	11,040	0.00	0.00	\$ 1,600	\$ 1,770	1.1	4.6	16	\$	- N	\$ -	\$ -	1.1	0.0	176,640	0	\$ 26,319	13.9
ECM-9	Install Low Flow Plumbing Fixtures	0.0	0	0.00	516.44	\$ 800	\$ 222,569	278.2	0.0	15	\$	- N	\$ -	\$ -	278.2	0.0	0	0	\$ -	(1.0)
ECM-10	Replace Kitchen Booster Heater	24.0	27,360	-933.52	0.00	\$ 4,400	\$ 16,596	3.8	6.5	12	\$	- N	\$ -	\$ -	3.8	288.0	328,320	(11,202)	\$ 53,275	2.2
	Total (Does Not Include ECM-5 & ECM-6)	55.7	148,061.00	34,943.86	516.44	53,100.0	1,888,554.2													
								35.6		15.5	\$ 43,800		\$ -	\$ -	35.6	1,204.0	4,019,375	688,213	\$1,259,508	(0.3)
	Total Measures with Payback <15	53.2	146,811.0	2,092.4	0.0	24,700.0	171,742.1	7.0		13.0	\$ 37,800	)	\$ -	\$ -	7.0	1,164.0	3,999,375	3,927	\$ 614,541	2.6
	% of Existing	36%	38%	107%											•					

# **ECM 1-Door & Window Seals**

Existing: Lack of door seals result in excessive heat loss and infiltration Proposed: Install door seals and/or weather-stripping to reduce air infiltration

Heating System Efficiency
Linear Feet of Door & Window Edge
Existing Door Infiltration Factor\*
Proposed Door Infiltration Factor\*



Heating System Efficiency
Heating On Temp.
Ex Occupied Htg Temp.
Ex Unoccupied Htg Temp.
Electricity
Natural Gas

	65%	
	60	*F
	72	*F
	72	*F
\$	0.149	\$/kWh
\$	0.96	\$/therm

\*Infiltration Factor per Carrier Handbook of Air Conditioning System Design based on average door seal gap calculated below.

Ü	or oddr gap dardarat				EXISTING	LOADS	PROPOSE	D LOADS	HEATING	ENERGY
					Occupied	Unoccupied	Occupied	Unoccupied		
		Existing	Occupied	Unoccupied						
Avg Outdoor Air	Avg Outdoor Air	<b>Equipment Bin</b>	<b>Equipment Bin</b>	Equipment Bin	Door Infiltration	Door Infiltration	Door Infiltration	Door Infiltration	Existing Heating	Proposed Heating
Temp. Bins °F	Enthalpy	Hours	Hours	Hours	Load BTUH	Load BTUH	Load BTUH	Load BTUH	Energy therms	Energy therms
Α		В	С	D	E	F	G	Н	K	L
102.5	50.1	0	0	0	0	0	0	0	0	0
97.5	42.5	3	1	2	0	0	0	0	0	0
92.5	39.5	34	12	22	0	0	0	0	0	0
87.5	36.6	131	47	84	0	0	0	0	0	0
82.5	34.0	500	179	321	0	0	0	0	0	0
77.5	31.6	620	221	399	0	0	0	0	0	0
72.5	29.2	664	237	427	0	0	0	0	0	0
67.5	27.0	854	305	549	0	0	0	0	0	0
62.5	24.5	927	331	596	0	0	0	0	0	0
57.5	21.4	600	214	386	10,273	10,273		2,311	95	21
52.5	18.7	610	218	392	13,815	13,815	3,108	3,108	130	29
47.5	16.2	611	218	393	17,358	17,358	3,905	3,905	163	37
42.5	14.4	656	234	422	20,900	20,900	4,703	4,703	211	47
37.5	12.6	1,023	365	658	24,443	24,443	5,500	5,500	385	87
32.5	10.7	734	262	472	27,985	27,985	6,297	6,297	316	71
27.5	8.6	334	119	215	31,527	31,527	7,094	7,094	162	
22.5	6.8	252	90	162	35,070	35,070	7,891	7,891	136	31
17.5	5.5	125	45	80	38,612	38,612	8,688	8,688	74	17
12.5	4.1	47	17	30	42,155	42,155	9,485	9,485	30	7
7.5	2.6	22	8	14	45,697	45,697	10,282	10,282	15	3
2.5	1.0	13	5	8	49,239	49,239	11,079	11,079	10	2
-2.5	0.0	0	0	0	52,782	52,782	11,876	11,876		C
-7.5	-1.5	0	0	0	56,324	56,324	12,673	12,673		
TOTALS		8,760	3,129	5,631				<u>.                                      </u>	1,727	389

Existing Door Infiltration
Existing Unoccupied Door Infiltration
Proposed Door Infiltration
Proposed Unoccupied Door Infiltration

656 cfm 656 cfm 148 cfm 148 cfm

Savings	1,339 therms	\$ 1 7401	

Door	Width (ft)	Height (ft)	Linear Feet (LF)	gap (in)	gap location	LF of gap	% door w/ gap	Average gap for door (in)
1a	3	7	20	0.0625	Seams	0.125	1%	0.000390625
1b	3	7	20	0.0625	Seams	0.125	1%	0.000390625
2a	3	7	20	0.0625	Seams	0.125	1%	0.000390625
2b	3	7	20	0.0625	Seams	0.125	1%	0.000390625
3a	3	7	20	0.0625	Seams	0.125	1%	0.000390625
3b	3	7	20	0.0625	Seams	0.125	1%	0.000390625
4a	3	7	20	0.0625	Seams	0.125	1%	0.000390625
4b	3	7	20	0.0625	Seams	0.125	1%	0.000390625
5a	3	7	20	0.0625	Seams	0.125	1%	0.000390625
5b	3	7	20	0.0625	Seams	0.125	1%	0.000390625
6a	3	7	20	0.0625	Seams	0.125	1%	0.000390625
6b	3	7	20	0.0625	Seams	0.125	1%	0.000390625
7a	3	7	20	0.0625	Seams	0.125	1%	0.000390625
7b	3	7	20	0.0625	Seams	0.125	1%	0.000390625
8	5	7	24	0.0625	Seams	0.125	1%	0.000325521
9	5	7	24	0.0625	Seams	0.125	1%	0.000325521
Total	52	112	328	0.063		2	1%	0.00038249

Note: Doors labeled 'a', 'b', etc. are a part of the same door assembly.

based on average door seal gap calculated below.

# **ECM 1-Door & Window Seals**

Existing: Lack of door seals result in excessive heat loss and infiltration Proposed: Install door seals and/or weather-stripping to reduce air infiltration

Heating System Efficiency Linear Feet of Window Edge Existing Window Infiltration Factor Proposed Window Infiltration Factor\*

3,204.0 0.3 cfm/LF 0.1 cfm/LF \*Infiltration Factor per Carrier Handbook of Air Conditioning System Design

Heating System Efficiency Heating On Temp. Ex Occupied Htg Temp.
Ex Unoccupied Htg Temp. Electricity Natural Gas

65%	
60	*F
72	*F
72	*F
\$ 0.149	\$/kWh
\$ 0.96	\$/thern

					EXISTING	G LOADS	PROPOSE	D LOADS	HEATING	ENERGY
					Occupied	Unoccupied	Occupied	Unoccupied		
Avg Outdoor Air Temp. Bins °F	Avg Outdoor Air Enthalpy	Existing Equipment Bin Hours	Occupied Equipment Bin Hours	Unoccupied Equipment Bin Hours	Door Infiltration Load BTUH		Door Infiltration Load BTUH		Existing Heating Energy therms	Proposed Heating Energy therms
A		В	С	D	E	F	G	Н	K	L
102.5	50.1	0	0	0	0	0	0	0	0	0
97.5	42.5	3	1	2	١	0	0	0	0	0
97.5 92.5	39.5	34	12	22	l o	0	0	0	0	0
87.5	36.6	131	47	84	0	0	0	0	0	0
82.5	34.0	500	179	321	0	0	0	0	0	0
77.5	31.6	620	221	399	0	0	0	0	0	0
72.5	29.2	664	237	427	0	0	0	0	0	0
67.5	27.0	854	305	549	0	0	0	0	0	0
62.5	24.5	927	331	596	0	0	0	0	0	0
57.5	21.4	600	214	386	15,052	15,052	5,017	5,017	139	46
52.5	18.7	610	218	392	20,243	20,243	6,748	6,748	190	63
47.5	16.2	611	218	393	25,433	25,433	8,478	8,478	239	80
42.5	14.4	656	234	422	30,624	30,624	10,208	10,208	309	103
37.5	12.6	1,023	365	658	35,814	35,814	11,938	11,938	564	188
32.5	10.7	734	262	472	41,005	,	· ·	13,668		154
27.5	8.6	334	119	215	46,195	46,195		15,398		79
22.5	6.8	252	90	162	51,386			17,129		
17.5	5.5	125	45	80	56,576	,		18,859		36
12.5	4.1	47	17	30	61,767	,	,	20,589		
7.5	2.6	22	8	14	66,957	66,957		22,319		
2.5	1.0	13	5	8	72,148	,		24,049	14	5
-2.5	0.0	0	0	0	77,338	,		25,779	0	0
-7.5	-1.5	0	0	0	82,529	82,529	27,510	27,510	0	0
TOTALS		8,760	3,129	5,631					2,531	844

Existing Window Infiltration
Existing Unoccupied Window Infiltration Proposed Window Infiltration Proposed Unoccupied Window Infiltration 961 cfm 961 cfm 320 cfm 320 cfm

Window ID	Location	Quantity	Width (ft)	Height (ft)	Linear Feet (LF)
1a	Exterior Wall	117	3	1	936.0
1b	Exterior Wall	117	3	3	1404.0
2	Exterior Wall	48	4	5	864.0
Total		282	10	9	3,204.0

Savings   1,007   therms   \$ 1,027	Savings	1,687 therms	\$	1,627
-------------------------------------	---------	--------------	----	-------

Multipliers		
	Material:	1.01
	Labor:	1.25
	Equipment:	1.00

# ECM 1-Door & Window Seals Cost

Description	OTV	QTY UNIT UNIT COSTS				OTAL COSTS	TOTAL COST	DEMVDKS	
Description	QII	OIVII	MAT.	LABOR	EQUIP.	MAT.	LABOR EQU	JIP.	INLIVIATING
								\$ -	
Door Seals	656	LS	\$ 20	\$ -	\$ -	\$ 13,304	\$ - \$	- \$ 13,304	
Window Seals	3,204	LF	\$ 1	\$ -	\$ -	\$ 3,249	\$ - \$	- \$ 3,249	

\$ 16,553	Subtotal
\$ 1	
\$ 1	
\$	
\$ 16,553	Total

Note: pricing is for energy calculations only -do not use for procurement

#### **ECM-2 Roof Replacement**

Existing: Ceiling can lead to increased energy consumption due to infiltration/exfiltration and heat gain/loss. Proposed: Install EPDM roofing membrane system to reduce heat transfer.

Area of ceiling **Existing Infiltration Factor Proposed Infiltration Factor Existing U Value** 

36,289 SF 0.30 cfm/SF 0.20 cfm/SF 0.214 Btuh/SF/°F

(No insulation, 4"LW Concrete, from Trace)

Proposed U Value

0.030 Btuh/SF/°F

(Fiberglass Batt Insulation R-4.1/inch, Trace)

Heating System Efficiency 65% Heating On Point 60 \*F 72 \*F Ex Occupied Htg Temp. Ex Unoccupied Htg Temp. 60 \*F

Electricity 0.149 \$/kWh Natural Gas 0.96 \$/Therm

						G LOADS		ED LOADS	HEATING	S ENERGY
					Occupied	Unoccupied	Occupied	Unoccupied		
Avg Outdoor Air Temp. Bins °F A	Avg Outdoor Air Enthalpy	Existing Equipment Bin Hours B	Occupied Equipment Bin Hours C	Unoccupied Equipment Bin Hours D	Wall Infiltration & Heat Load BTUH E	Wall Infiltration & Heat Load BTUH F	Wall Infiltration & Heat Load BTUH G	Wall Infiltration & Heat Load BTUH H	Existing Heating Energy Therm K	Proposed Heating Energy Therm
^		B	C	D	_	r	G	п	K	-
97.5	42.5	0	0	0	0	0	0	0	-	-
92.5	39.5	36	10	26	0	0	0	0	-	-
87.5	36.6	123	33	90	0	0	0	0	-	-
82.5	34.0	477	128	349	0	0	0	0	-	-
77.5	31.6	656	176	480	0	0	0	0	-	-
72.5	29.2	742	199	543	0	0	0	0	-	-
67.5	27.0	784	210	574	0	0	0	0	-	-
62.5	24.5	983	263	720	0	0	0	0	-	-
57.5	21.4	625	167	458	282,989	48,791	129,445	22,318	1,072	491
52.5	18.7	438	117	321	380,572	146,374	174,081	66,954	1,409	645
47.5	16.2	559	150	409	478,154	243,956	218,717	111,590	2,638	1,206
42.5	14.4	671	180	491	575,736	341,539	263,353	156,226	4,173	1,909
37.5	12.6	1,067	286	781	673,319	439,121	307,989	200,862	8,238	3,768
32.5	10.7	685	183	502	770,901	536,703	352,625	245,498	6,317	2,890
27.5	8.6	369	99	270	868,484	634,286	397,261	290,134	3,957	1,810
22.5	6.8	321	86	235	966,066	731,868	441,897	334,771	3,924	1,795
17.5	5.5	184	49	135	1,063,649	829,451	486,533	379,407	2,526	1,155
12.5	4.1	40	11	29	1,161,231	927,033	531,169	424,043	609	279
7.5	2.6	0	0	0	1,258,813	1,024,616	575,805	468,679	-	-
2.5	1.0	0	0	0	1,356,396	1,122,198	620,441	513,315	-	-
-2.5	0.0	0	0	0	1,453,978	1,219,780	665,077	557,951	-	-
-7.5	-1.5	0	0	0	1,551,561	1,317,363	709,714	602,587	-	-
TOTALS		8,760	2,346	6,414					34,863	15,947

**Existing Ceiling Infiltration Existing Ceiling Heat Transfer Proposed Ceiling Infiltration Proposed Ceiling Heat Transfer**  10,887 cfm 7,759 Btuh/°F 7,258 cfm 1,089 Btuh/°F

Savings	18,916	Therm	\$ 18,235
	0	kWh	\$ -
,		-	\$ 18.235

Multipliers		
	Material:	1.01
	Labor:	1.25
	Equipment:	1.00

# ECM 1-Door & Window Seals Cost

Description	OTV		QTY	OTV	OTV	UNIT	Į	JNIT COSTS		SUBTO	TAL COS	STS	TOTAL COST REMARKS
Description	QII	CIVII	MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	TOTAL COST	INLIMANNO			
Roof Replacement	36,289	SF	\$ 20	\$	\$ -	\$ 735,951	\$ -	\$ -	\$ 735,951				

\$ 735,951	Subtotal
\$ 147,190	20% Contingency
\$ -	
\$ -	
\$ 883,141	Total

ECM 3- Boiler Replacement

Utility Costs
\$ 0.149 \$/kWh blended
\$ 0.124 \$/kWh consumption
\$ 6.760 \$/kW
\$ 0.964 \$/Therm
\$ 1.525 \$/kGallon Water

Existing Fuel	Nat. Gas
Proposed Fuel	Nat. Gas

<u>Item</u>	<u>Value</u>	<u>Units</u>	Formula/Comments
Baseline Fuel Cost	\$ 0.96	/ Therm	
Proposed Fuel Cost	\$ 0.96	/ Therm	
Baseline Fuel Use	31,423	Therms	Based on historical utility data
Existing Boiler Plant Efficiency	65%		Estimated or Measured
Baseline Boiler Load	2,042,495	Mbtu/yr	Baseline Fuel Use x Existing Efficiency x 100 Mbtu/Therms
Baseline Fuel Cost	\$ 30,292		
Proposed Boiler Plant Efficiency	92%		New Boiler Efficiency
Proposed Fuel Use	22,201	Therms	Baseline Boiler Load / Proposed Efficiency / 100 Mbtu/Therms
Proposed Fuel Cost	\$ 21,402		

<sup>\*</sup>Note to engineer: Link savings back to summary sheet in appropriate column.

BOILER REPLACEMENT SAVINGS SUMMARY								
	Electric	Electric	Nat Gas					
	Demand	Usage	Usage	Maint.	<b>Total Cost</b>			
(kW) (kWh) (Therms) (\$) (\$								
Savings	0	0	9,222	\$0	\$8,890			

Multipliers		
	Material:	1.01
	Labor:	1.25
	Equipment:	1.00

# **ECM 3- Boiler Replacement Cost**

Description	ОТУ	UNIT	UNIT COSTS			SUBT	OTAL CO	STS	TOTAL COST	DEMARKS	
Description	QII	UNIT	MAT.		LABOR	EQUIP.	MAT.	LABOR	EQUIP.	TOTAL COST	KEWAKKS
Demo existing boilers	2	EA	\$ -	\$	10,000	\$ -					
3,000 MBH NG Condensing Boiler	2	EA	\$ 45,000	\$	40,000	\$ -	\$91,260	\$99,600	\$ -	\$ 190,860	
Venting & Combustion Air	2	LS	\$ 5,000	\$	2,500	\$ -	\$10,140	\$ 6,225	\$ -	\$ 16,365	
Pumps	2	EA	\$ 2,500	\$	1,500	\$ -	\$ 5,070	\$ 3,735	\$ -	\$ 8,805	
Miscellaneous Electrical	2	LS	\$ 500	\$	250	\$ -	\$ 1,014	\$ 623	\$ -	\$ 1,637	
Miscellaneous HW Piping	2	LS	\$ 5,000	\$	15,000	\$ -	\$10,140	\$37,350	\$ -	\$ 47,490	
							\$ -	\$ -	\$ -	\$ -	
							\$ -	\$ -	\$ -	\$ -	

\$ 265,157	Subtotal
\$ 53,031.30	20% Contingency
-	
-	
\$ 318,188	Total

#### ECM 4- Install DDC & BMS

Utility Costs						
\$	0.149	\$/kWh blended				
\$	0.124	\$/kWh consumption				
\$	6.760	\$/kW				
\$	0.964	\$/Therm				

EXISTING CONDITIONS			-
Electricity Consumed by Air Compressor	1,250	kWh	5kW * 500 hours
Natural Gas Consumed by HVAC System	31,423	Therms <sup>1</sup>	From Utility Analysis
SAVINGS			-
Electric Savings	1,250	kWh <sup>2</sup>	
Electric Demand Savings	3	$kW^2$	
Natural Gas Savings	4,713	Therms <sup>3</sup>	
Total Cost Savings	\$ 4,902		
Estimated Total Project Cost	\$ 309,510	4,5	
Simple Payback	63.1	years	

#### Assumptions

- Natural Gas consumption based on utility data, boiler capacity & operating hours
  Electric savings from removing the air compressor

  Natural Gas consumption based on utility data, boiler capacity & operating hours
  Electric savings from removing the air compressor

  Approximate natural gas savings from night setback & temperature scheduling
  Project cost is an estimate, includes cost of replacing non- programmbale thermostats with programmbale thermostats
- control work cost

Multipliers		
	Material:	1.01
	Labor:	1.25
	Equipment:	1.00

# ECM 4- Install DDC & BMS Cost

Description	QTY UNIT			UNIT COSTS				вто	TAL COSTS	3	ТО	TOTAL COST	DEMADKS
Description	QII	UNIT	MAT.		_ABOR	EQUIP.	MAT.		LABOR	EQUIP.		TAL COST	KEWAKKS
							\$ -	\$	-	\$ -	\$	-	
Control System	1	LS	\$ 150,000	\$	50,000	\$ -	\$152,100	\$	62,250	\$ -	\$	214,350	
Removing Pneumatics	1	LS		\$	10,000	\$ -	\$ -	\$	12,450	\$ -	\$	12,450	
Programming	1	LS	\$ -	\$	25,000	\$ -	\$ -	\$	31,125	\$ -	\$	31,125	
							\$ -	\$	-	\$ -	\$	-	
							\$ -	\$	-	\$ -	\$	-	
							\$ -	\$	-	\$ -	\$	-	
							\$ -	\$	-	\$ -	\$	-	
							\$ -	\$	-	\$ -	\$	-	
							\$ -	\$	-	\$ -	\$	-	
							\$ -	\$	-	\$ -	\$	-	

\$ 257,925	Subtotal
\$ 51,585.00	20% Contingency
-	
-	
\$ 309,510	Total

#### **ECM-8: Install Network Controller**

Background Data	
Average Consumption and Savings Figures	kWh
Average Total Consumption per PC per Year	500-700
Average Energy and Cost Waste per PC per Year	350-450
Average savings transparantly available via Surveyor	120

Number of PCs	92
Return on Investment Analysis	
	kWh
Annual Energy Savings	11,040

#### Notes:

- 1. Savings are for the installation of a centralized computer management system installed on the client server that will centralize the power management functions that are native to the Windows environment.
- Energy savings per computer are based on historical information from previous installations encompassing tens of thousands of computers.
- 3. There are approximately 60 computers in all

#### City cost multipliers from 2012 RS Means

Multipliers	
Material:	1.00
Labor:	1.24
Equipment:	0.98

Utility Costs				
\$ 0.138	\$/kWh blended			
\$ 0.113	\$/kWh consumption			
\$ 6.044	\$/kW			
\$ 1.036	\$/Therm			

#### **ECM-8: Install Network Controller Cost**

ECM Description Summary

Description	QTY	UNIT	UNIT COSTS		SUBTOTAL COSTS			тот	AL COST	REMARKS					
			MA	Τ.	LA	BOR	EQUIP.	١	ΛΑΤ.	L/	ABOR	EQUIP.	101	AL COST	REWARKS
								\$	-	\$	-	\$ -	\$	-	
Network Controller	92	EA	\$	8	\$	-		\$	733	\$	-	\$ -	\$	733	
IT Deployment	1	EA	\$	-	\$	600		\$	-	\$	742	\$ -	\$	742	
								\$	-	\$	-	\$ -	\$	-	

Note: Costs are for energy savings only. Do not use for procurement

\$ 1,475	Subtotal
\$ 295	20% Contingency
\$ 1,770	Total

# ECM-8: Replace Plumbing with Low Flow Toilets

EXISTING	CONDITIONS		
Cost of Water / 1000 Gallons		\$1.53	\$ / kGal
Toilets in Building		27	
Average Flushes / Toilet (per Day)		4	
Average Gallons / Flush		5.5	Gal

PROPOSED CONDITIONS		
Proposed Toilets to be Replaced	27	
Proposed Gallons / Flush	1.3	Gal

SAVINGS		
Current Urinal Water Use	594	kGal / year
Proposed Urinal Water Use	138	kGal / year
Water Savings	456	kGal / year
Cost Savings	\$695	/ year

# ECM-8: Replace Plumbing with Low Flow

# <u>Urinals</u>

EXISTING CONDITION:	S	
Cost of Water / 1000 Gallons	\$1.53	\$ / kGal
Urinals in Building	14	
Average Flushes / Urinal (per Day)	4	
Average Gallons / Flush	3.0	Gal

PROPOSED	CONDITION	S	
Proposed Urinals to be Replaced		14	
Proposed Gallons / Flush		0.5	Gal

SAVINGS		
Current Urinal Water Use	61	kGal / year
Proposed Urinal Water Use	10	kGal / year
Water Savings	51	kGal / year
Cost Savings	\$78	/ year

# ECM-8: Replace Plumbing with Low Flow

# <u>Faucets</u>

EXISTING CONDITIONS							
Cost of Water / 1000 Gallons	\$1.53	\$ / kGal					
Faucets in Building	35						
Average Uses / Faucet (per day)	1	Gal					
Average Time of Use	0.5	min					
Average Flowrate	3.0	gpm					

PROPOSED CONDITI	ONS	
Proposed Faucets to be Replaced	35	
Proposed Flowrate	1.5	gpm

SAVINGS		
Current Faucet Water Use	19	kGal / year
Proposed Faucet Water Use	10	kGal / year
Water Savings	10	kGal / year
Cost Savings	\$15	/ year

Pompton Lakes-Lakeside MS - NJBPU CHA Project #24698

Multipliers	
Ma	terial: 1.01
l	_abor: 1.25
Equip	ment: 1.00

### **ECM 9: Low Flow Plumbing Cost**

Description	OTV	UNIT	Ų	JNIT COSTS		SUBT	TOTAL COST	S	TOTAL COST	DEMVDK6
Description	QII	0.111	MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	TOTAL COST	REWARKS
Flush Valves & Toilets	27	EA	\$ 1,400.00	\$ 1,000.00	\$ -		\$ 33,615.00		\$ 71,944	
Urinals & Valves	14	EΑ	\$ 1,200.00	\$ 1,000.00	\$ -	\$ 17,035.20			\$ 34,465	
Faucets	35	EΑ	\$ 1,000.00	\$ 1,000.00	\$ -	\$ 35,490.00	\$ 43,575.00	\$ -	\$ 79,065	
									\$ -	
									\$ -	
									\$ -	
									\$ -	
									\$ -	
									\$ -	
									\$ -	

\$ 222,569	Total
-	
-	
\$ 37,094.88	20% Contingency
\$ 185,474	Subtotal

Pompton Lakes-Lakeside MS - NJBPU CHA Project #24698

**Existing Fuel** Proposed Fuel

### ECM-10: Replace Electric Booster Heater

	Utility Costs
\$0.149	\$/kWh blended
\$0.124	\$/kWh consumption
\$6.760	\$/kW
\$ 0.964	\$/Therm
\$ 1.525	\$/kGallon Water

		_	
<u>ltem</u>	<u>Value</u>	<u>Units</u>	<u>Formula/Comments</u>
Baseline Fuel Cost	\$ 0.12	/ kWh	
Baseline Fuel Cost	\$ 6.76	/ kW	
Proposed Fuel Cost	\$ 0.96	/ Therm	
Kitchen Equipment			
- Dishwasher Booster Heater	24.0	kW	Based on equipment nameplat data
- Total Equipmetn kW	24.0	kW	
Kitchen Annual Operating Hours	1,140	hours	6 hours per day x 5 days per week x 38 weeks per year
Baseline Equipment Efficiency	100%		
Baseline Annual Electric Use	27,360	kWh	
Baseline Annual Electric Cost	\$ 5,340		
Proposed Equipment Efficiency	80%		Approxmiation
Proposed Fuel Use	934	Therms	Baseline Electric Use x 3,412 BTU/kWh / 100,000 BTU/Therm
Proposed Fuel Cost	\$ 900		
Annual Savings	\$ 4,440		
Natural Gas Equipment Project Cost	\$16,596		
Simple Payback	3.7	Years	

Electric

Nat.Gas



<sup>\*</sup>Note to engineer: Link savings back to summary sheet in appropriate column.

Multipliers		
	Material:	1.01
	Labor:	1.25
	Equipment:	1.00

### ECM 9- Replace Electric Kitchen Equip. Cost

Description	QTY	LINIT	l	JNIT	r costs		5	SUB	TOTAL COSTS	3		тот	AL COST	REMARKS
Description	QII	UNIT	MAT.		LABOR	EQUIP.	MAT.		LABOR	EQl	JIP.	101	AL COST	REIVIARNO
Dishwasher Booster Heater-Natural Gas	1	EΑ	\$ 5,000	\$	1,500	\$ -	\$5,070	\$	1,868	\$	-	\$	6,938	
Venting	1	EA	\$ 1,500	\$	500		\$1,521	\$	623	\$	-	\$	2,144	
Natural Gas Hookup	1	EA	\$ 500	\$	1,500		\$ 507	\$	1,868	\$	-	\$	2,375	
Electric wiring	1	EA	\$ 500	\$	1,500		\$ 507	\$	1,868	\$	-	\$	2,375	
							\$ -	\$	-	\$	-	\$	-	
							\$ -	\$	-	\$	-	\$	-	
							\$ -	\$	-	\$	-	\$	-	
							\$ -	\$	-	\$	-	\$		

\$ 13,830	Subtotal
\$ 2,766.00	20% Contingency
-	
-	
\$ 16,596	Total

CHA Project No.24698 Cost of Electricity: \$0.124 \$/kWh Consumption

ECM-5 Lighting Replacements \$6.76 \$/kW Demand

				RETROFIT CONDITIONS								COST & SAVINGS ANALYSIS												
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	location - Room number/Room name: Floor	No. of fixtures before the retrofit	"Lighting Fixture Code" Example: 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	, ·	Pre-inst. control device	d daily	Hours)	No. of fixtures after the retrofit	"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	control	annual	(kW/space ) * (Annual Hours)	Annual kWh) -	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	lighting	ve	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
80	Boiler Room	1	I 100	I100/1	100	0.1	SW	1000	100	1	CF 26	CFQ26/1-L	27	0.0	SW	1,000	27	73	0.1	\$ 14.97	\$ 6.75	\$0	0.5	0.1
102	Gym	14	High Bay MH 400	MH400/1	458	6.4	BR	2400	15,389	14	C 54 C F 6	F46GHL	351	4.9	BR	2,400	11,794			\$ 567.32		·	13.7	1.8
36	Girl's Locker Room	6	S 34 P F 2 (MAG)	F42EE	72	0.4	SW	2800	1,210	6	C 28 P F 2	F42SSILL	48	0.3	SW	2,800	806	403	0.1	\$ 61.68	\$ 637.50	\$60	10.3	1.4
91	Girl's Locker Room-Shower	6	l 75	I75/1	75	0.5	SW	2800	1,260	6	CF 26	CFQ26/1-L	27	0.2	SW	2,800	454	<b>†</b>		\$ 123.36			0.3	0.0
36	Girl's Gym Office Entrance	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	173	1	C 28 P F 2	F42SSILL	48	0.0	SW	2,400	115	<b>†</b>	0.0	\$ 9.09			11.7	1.7
36	Girl's Gym Office Entrance	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	173	1	C 28 P F 2	F42SSILL	48	0.0	SW	2,400	115		0.0	\$ 9.09			11.7	1.7
24 36	Girl's Gym Office Bathroom Gym Storage	1	W 20 C F 2 S 34 P F 2 (MAG)	F22SS F42EE	56 72	0.1	SW SW	2000 1000	112 144	2	W 17 W C 2 C 28 P F 2	F22ILL F42SSILL	33	0.0	SW SW	2,000 1,000	66 96	<b>†</b>	0.0	\$ 7.57 \$ 9.85			13.4 21.6	4.0
36	Gym Storage	1	S 34 P F 2 (MAG)	F42EE	72	0.1 0.1	SW	1000	72	1	C 28 P F 2	F42SSILL	_	0.1	SW	1,000	48		0.0	\$ 4.92			21.6	4.0
36	Boy's Gym Office Entrance	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	346	2	C 28 P F 2	F42SSILL		0.1	SW	2,400	230	1		\$ 18.18			11.7	1.7
36	Boy's Gym Office	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	173	1	C 28 P F 2	F42SSILL	48	0.0	SW	2,400	115	58	0.0	\$ 9.09	\$ 106.25	\$10	11.7	1.7
24	Boy's Gym Office Bathroom	2	W 20 C F 2	F22SS	56	0.1	SW	2000	224	2	W 17 W C 2	F22ILL	33	0.1	SW	2,000	132	92	0.0	\$ 15.14	\$ 202.50	\$20	13.4	2.0
36	Boy's Locker Room	11	S 34 P F 2 (MAG)	F42EE	72	0.8	SW	2800	2,218	11	C 28 P F 2	F42SSILL	48	0.5	SW	2,800	1,478	1		\$ 113.08	,		10.3	1.4
36	Kitchen	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	1600	1,728	15	C 28 P F 2	F42SSILL	_	0.7	SW	1,600	1,152			\$ 100.63			15.8	2.5
36 24	Kitchen Storage Kitchen Bathroom	1 1	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1 0.1	SW SW	1000 2000	72 112	1	C 28 P F 2 W 17 W C 2	F42SSILL F22ILL	33	0.0	SW SW	1,000 2,000	48 66	+	0.0	\$ 4.92 \$ 7.57	· ·		21.6 13.4	2.0
36	Storage Room	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72	1	C 28 P F 2	F42SSILL		0.0	SW	1,000	48		0.0	\$ 4.92			21.6	4.0
24	114 (Art)	30	W 20 C F 2	F22SS	56	1.7	SW	2400	4,032	30	W 17 W C 2	F22ILL	33	1.0	SW	2,400	2,376			\$ 261.32			11.6	1.7
36	Art Storage	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	SW	1,000	48	24	0.0	\$ 4.92	\$ 106.25	\$10	21.6	4.0
36	Music	29	S 34 P F 2 (MAG)	F42EE	72	2.1	SW	2400	5,011	29	C 28 P F 2	F42SSILL		1.4	SW	2,400	3,341	<del>                                     </del>		\$ 263.59			11.7	1.7
36	Music Storage	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	1000	288	4	C 28 P F 2	F42SSILL		0.2	SW	1,000	192			\$ 19.69			21.6	4.0
36	Music Office  Music Office 2	2	S 34 P F 2 (MAG)	F42EE F42EE	72	0.1	SW	2400 2400	346	2	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL		0.1	SW SW	2,400 2,400	230			\$ 18.18			11.7 11.7	1.7
36 36	Music Storage 2	1	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE	72 72	0.1	SW SW	1000	346 72	1	C 28 P F 2	F42SSILL		0.1	SW	1,000	230 48	1	0.0	\$ 18.18 \$ 4.92			21.6	4.0
43	Stairway Near Music	2	T 32 R F 3 (ELE)	F43ILL	89	0.1	SW	3200	570	2	T 32 R F 3 (ELE)	F43ILL	89	0.0	SW	3,200	570	+	0.0	\$ -		\$0	21.0	4.0
24	Stairway Near Music		W 20 C F 2	F22SS	56	0.1	SW	3200	179	1	W 17 W C 2	F22ILL	33	0.0	SW	3,200	106		0.0	\$ 10.99			9.2	1.2
69	107	21	2B 34 R F 2 (u) (MAG)	FU2EE	72	1.5	SW	2400	3,629		2T 17 R F 2 (ELE)	F22ILL	33	0.7	SW	2,400	1,663	1,966	0.8	\$ 310.17	\$ 2,126.25	\$210	6.9	1.0
69	107 Office	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	SW	2400	173		2T 17 R F 2 (ELE)		33	0.0	SW	2,400	79			\$ 14.77		-	6.9	1.0
69 36	107 Storage 105	2 24	2B 34 R F 2 (u) (MAG) S 34 P F 2 (MAG)	FU2EE F42EE	72 72	0.1 1.7	SW SW	1000 2400	144 4,147	2 24	2T 17 R F 2 (ELE) C 28 P F 2	F22ILL F42SSILL	33	0.1 1.2	SW SW	1,000 2,400	2,765			\$ 16.00 \$ 218.14	· · · · · · · · · · · · · · · · · · ·		12.7 11.7	2.3 1.7
36	103	24	S 34 P F 2 (MAG)	F42EE	72	1.7	SW	2400	4,147	24	C 28 P F 2	F42SSILL	_	1.2	SW	2,400	2,765			\$ 218.14			11.7	1.7
36	103 Storage	8	S 34 P F 2 (MAG)	F42EE	72	0.6	SW	1000	576	8	C 28 P F 2	F42SSILL	_	0.4	SW	1,000	384			\$ 39.38		-	21.6	4.0
36	101	24	S 34 P F 2 (MAG)	F42EE	72	1.7	SW	2400	4,147	24	C 28 P F 2	F42SSILL	_	1.2	SW	2,400	2,765	· · · · · · · · · · · · · · · · · · ·		\$ 218.14		-	11.7	1.7
36	Server Room	1	S 34 P F 2 (MAG)	F42EE	72 56	0.1	SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	SW	1,000	48	1	0.0	\$ 4.92			21.6	4.0
24 36	1st Floor Boy's Bathroom 1st Floor Boy's Bathroom	3 J	W 20 C F 2 S 34 P F 2 (MAG)	F22SS F42EE	56 72	0.1	SW SW	2000 2000	112 432		W 17 W C 2 C 28 P F 2	F22ILL F42SSILL	ئة 48	0.0	SW SW	2,000 2,000	288		0.0	\$ 7.57 \$ 23.70			13.4 13.5	2.0
36	1st Floor Boy's Bathroom  1st Floor Maintenance	3 1	S 34 P F 2 (MAG)	F42EE	72	0.2	SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.1	SW	1,000	<u>200</u>		0.0	\$ 4.92			21.6	4.0
24	1st Floor Girl's Bathroom	<u>'</u> 1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	SW	2,000	66		0.0	\$ 7.57			13.4	2.0
36	1st Floor Girl's Bathroom	3	S 34 P F 2 (MAG)	F42EE	72	0.2	SW	2000	432	3	C 28 P F 2	F42SSILL	48	0.1	SW	2,000	288	1		\$ 23.70			13.5	2.0
48	Nurse	5	T 32 R F 4 (ELE)	F44ILL	112	0.6	SW	2400	1,344	5	0	F44SSILL	96	0.5	SW	2,400	1,152		0.1	\$ 30.30			17.5	2.5
24	Nurse Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2400	134	1	W 17 W C 2	F22ILL	33	0.0	SW	2,400	79	<del>-</del>	0.0	\$ 8.71	\$ 101.25	\$10	11.6	1.7
38	Entryway	1	F42ILL	F42ILL	59	0.1	SW	2280	135	1	F42ILL	F42ILL	59	0.1	SW	2,280	135		0.0	\$ -		<b>\$</b> 0		
43 24	Principal's Office	6	T 32 R F 3 (ELE) W 20 C F 2	F43ILL F22SS	89 56	0.5	SW SW	2400 2000	1,282	6	T 32 R F 3 (ELE) W 17 W C 2	F43ILL F22ILL	89 33	0.5	SW SW	2,400 2,000	1,282 66		0.0	\$ - \$ 7.57	7	\$0 \$10	13.4	2.0
43	Principal's Bathroom  Main Office	10	T 32 R F 3 (ELE)	F22SS F43ILL	89	0.1 0.9	SW	2400	2,136	10	T 32 R F 3 (ELE)	F22ILL F43ILL	89	0.0	SW	2,000	2,136		0.0	φ 1.51 \$ -		\$10 \$0	13.4	2.0
24	Main Office Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	SW	2,000	66	1	0.0	\$ 7.57	*	7 -	13.4	2.0
36	Main Office Closet	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	144	2	C 28 P F 2	F42SSILL		0.1	SW	1,000	96				\$ 212.50		21.6	4.0
43	Assistant Principal's Office	4	T 32 R F 3 (ELE)	F43ILL	89	0.4	SW	2400	854		T 32 R F 3 (ELE)	F43ILL	89	0.4	SW	2,400	854		0.0	\$ -		<b>\$</b> 0		
43	Office	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	SW	2400	214	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	SW	2,400	214	1	0.0	\$ -	\$ -	\$0		
43	Office	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	SW	2400	214	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	SW	2,400	214	1	0.0			\$0		
36	102	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	SW	2,400	1,728	864	0.4	\$ 136.34	\$ 1,593.75	\$150	11.7	1.7

CHA Project No.24698 Cost of Electricity: \$0.124 \$/kWh Consumption

ECM-5 Lighting Replacements \$6.76 \$/kW Demand

<b></b>				EXISTIN	<b>G CONDITIO</b>	NS						RETR	DITIONS			COST & SAVINGS ANALYSIS								
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	location - Room number/Room name: Floor	No. of fixtures before the retrofit		Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt ) * (Fixt No.)	Pre-inst. control device	Estimate d daily hours for the usage group	Hours)		"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	control	annual	(kW/space ) * (Annual Hours)	Annual kWh) - (Retrofit	(Original Annual kW) - (Retrofit Annual kW)	Saved) * (\$/kWh)	renovations to lighting	ve Lighting	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
36	104	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2		48	0.7	SW	2,400	1,728	+		\$ 136.34	\$ 1,593.75		11.7	1.7
36 36	106 1st Floor Girl's Bathroom	15 3	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1 0.2	SW SW	2400 2000	2,592 432	15 3	C 28 P F 2 C 28 P F 2		48 48	0.7	SW SW	2,400 2,000	1,728 288			\$ 136.34 \$ 23.70	\$ 1,593.75 \$ 318.75		11.7 13.5	1.7 2.0
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2		33	0.0	SW	2,000	66			\$ 7.57	·		13.4	2.0
36	1st Floor Boy's Bathroom	3	S 34 P F 2 (MAG)	F42EE	72	0.2	SW	2000	432	3	C 28 P F 2	F42SSILL	48	0.1	SW	2,000	288	144	0.1	\$ 23.70	\$ 318.75	\$30	13.5	2.0
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2		33	0.0	SW	2,000	66			\$ 7.57	·		13.4	2.0
36 36	Maintenance Room 108	1 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.1 1.1	SW SW	1000 2400	72 2,592	1 15	C 28 P F 2 C 28 P F 2		48 48	0.0	SW SW	1,000 2,400	48 1,728			\$ 4.92 \$ 136.34	•		21.6 11.7	4.0 1.7
36	110	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2		48	0.7	SW	2,400	1,728			\$ 136.34	. ,		11.7	1.7
36	112	21	S 34 P F 2 (MAG)	F42EE	72	1.5	SW	2400	3,629	21	C 28 P F 2		48	1.0	SW	2,400	2,419	· · · · · · · · · · · · · · · · · · ·		¥	\$ 2,231.25		11.7	1.7
69 69	Hallway 1st Entry	<u>54</u>	2B 34 R F 2 (u) (MAG) 2B 34 R F 2 (u) (MAG)	FU2EE FU2EE	72 72	3.9 0.2	SW SW	2280 2280	8,865 492	54	2T 17 R F 2 (ELE) 2T 17 R F 2 (ELE)		33 33	1.8 0.1	SW SW	2,280 2,280	4,063 226	· · · · · · · · · · · · · · · · · · ·		\$ 766.25 \$ 42.57	. ,	•	7.1 7.1	1.0
69	Stairway	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	SW	3200	230	1	2T 17 R F 2 (ELE)		33	0.0	SW	3,200	106			\$ 18.64	\$ 303.73 \$ 101.25	-	5.4	0.7
69	Stairway	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	SW	3200	230	1	2T 17 R F 2 (ELE)		33	0.0	SW	3,200	106			\$ 18.64	\$ 101.25	\$10	5.4	0.7
43	Stairwell	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	SW	3200	570	2	T 32 R F 3 (ELE)		89	0.2	SW	3,200	570	+	0.0	\$ -	\$ -	\$0		
43	Stairwell Stairwell	2	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL F43ILL	89 89	0.2	SW SW	3200 3200	570 570	2	T 32 R F 3 (ELE)		89 89	0.2	SW SW	3,200 3,200	570 570		0.0	\$ -		\$0 \$0		
36	219	30	S 34 P F 2 (MAG)	F42EE	72	2.2	SW	2400	5,184	30	C 28 P F 2		48	1.4	SW	2,400	3,456			\$ 272.68			11.7	1.7
43	Faculty Room	8	T 32 R F 3 (ELE)	F43ILL	89	0.7	SW	2400	1,709	8	T 32 R F 3 (ELE)		89	0.7	SW	2,400	1,709		0.0	\$ -	T	\$0		
80 36	Fan Room 2nd Floor Men's Bathroom	5	I 100 S 34 P F 2 (MAG)	I100/1 F42EE	100 72	0.5 0.1	SW SW	1000 2000	500 144	5	CF 26 C 28 P F 2	CFQ26/1-L F42SSILL	48	0.1	SW	1,000 2,000	135 96			\$ 74.87 \$ 7.90			0.5 13.5	0.1 2.0
24	2nd Floor Men's Bathroom	<u>'</u> 1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2		33	0.0	SW	2,000	66			\$ 7.57	·		13.4	2.0
36	216	18	S 34 P F 2 (MAG)	F42EE	72	1.3	SW	2400	3,110	18	C 28 P F 2		48	0.9	SW	2,400	2,074			\$ 163.61	\$ 1,912.50	•	11.7	1.7
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2		33	0.0	SW	2,000	66			\$ 7.57			13.4	2.0
36	Storage	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2000	144	1	C 28 P F 2		48	0.0	SW	2,000	96			\$ 7.90	•		13.5	2.0
	2nd Floor Women's Bathroom 2nd Boy's Bathroom Entrance	1	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1 0.1	SW	2000	288 112	1	C 28 P F 2 W 17 W C 2		48 33	0.1	SW	2,000 2,000	192 66			\$ 15.80 \$ 7.57			13.5 13.4	2.0
36	2nd Boy's Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576	4	C 28 P F 2		48	0.0	SW	2,000	384			\$ 31.60	•	-	13.5	2.0
36	214	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2		48	0.7	SW	2,400	1,728	+		\$ 136.34	\$ 1,593.75		11.7	1.7
36	212	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2		48	0.7	SW	2,400	1,728			\$ 136.34	,		11.7	1.7
36 2 24	2nd Floor Maintenance Closet Entrance	<u> </u>	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1 0.1	SW SW	1000 2000	72 112	1	C 28 P F 2 W 17 W C 2	F42SSILL F22ILL	48	0.0	SW	1,000 2,000	48 66			\$ 4.92 \$ 7.57			21.6 13.4	4.0 2.0
36	2nd Floor Girl's Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576	4	C 28 P F 2		48	0.0	SW	2,000	384			\$ 31.60	·		13.5	2.0
36	210	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2		48	0.7	SW	2,400	1,728		0.4	\$ 136.34	\$ 1,593.75	\$150	11.7	1.7
36 36	208 206	15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	SW	2400 2400	2,592 2,592	15 15	C 28 P F 2 C 28 P F 2		48 48	0.7 0.7	SW SW	2,400 2,400	1,728 1,728			\$ 136.34 \$ 136.34	\$ 1,593.75 \$ 1,593.75		11.7 11.7	1.7
36	206 204A	15 2	S 34 P F 2 (MAG)	F42EE	72	1.1 0.1	SW	2400	346	2	C 28 P F 2		48	0.7	SW	2,400	230			\$ 130.34	· · · · · · · · · · · · · · · · · · ·	-	11.7	1.7
70	Periodical Room	4	2T 32 R F 2 (u) (ELE)	FU2ILL	59	0.2	SW	2400	566	4	2T 32 R F 2 (u) (EL	FU2ILL	59	0.2	SW	2,400	566	-	0.0	\$ -	\$ -	\$0		
36	204	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2		48	0.7	SW	2,400	1,728			\$ 136.34	\$ 1,593.75	-	11.7	1.7
36 42	202 Media Center	15 25	S 34 P F 2 (MAG) T 34 R F 3 (MAG)	F42EE F43EE	72 115	1.1 2.9	SW	2400 2400	2,592 6,900	15 25	C 28 P F 2 1B 28	F42SSILL F43SSILL	48 72	0.7 1.8	SW SW	2,400 2,400	1,728 4,320			\$ 136.34 \$ 407.12	\$ 1,593.75 \$ 2,968.75	•	11.7 7.3	1.7
36	Media Center Office	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2400	691	4	C 28 P F 2		48	0.2	SW	2,400	461	230		\$ 36.36	. ,	•	11.7	1.7
36	Room	6	S 34 P F 2 (MAG)	F42EE	72	0.4	SW	2400	1,037	6	C 28 P F 2		48	0.3	SW	2,400	691			\$ 54.54			11.7	1.7
36 36	Media Center Storage PC Lab	1 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.1 1.1	SW	1000 2400	72 2,592	1	C 28 P F 2 C 28 P F 2		48 48	0.0 0.7	SW SW	1,000 2,400	48 1,728			\$ 4.92 \$ 136.34		•	21.6 11.7	4.0 1.7
36	203	15	S 34 P F 2 (MAG)	F42EE F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2		48	0.7	SW	2,400	1,728			\$ 136.34		-	11.7	1.7
70	2nd Floor Hallway	50	2T 32 R F 2 (u) (ELE)	FU2ILL	59	3.0	SW	2280	6,726	50	2T 32 R F 2 (u) (EL	FU2ILL	59	3.0	SW	2,280	6,726		0.0	\$ -		\$0		
36	205A	6	S 34 P F 2 (MAG)	F42EE	72	0.4	SW	2400	1,037	6	C 28 P F 2		48	0.3	SW	2,400	691	346		\$ 54.54		•	11.7	1.7
36	205	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2	F42SSILL	_	0.7	SW	2,400	1,728			<del>                                     </del>	\$ 1,593.75		11.7	1.7
36	207 209	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	SW	2400	2,592 2,592	15 15	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL		0.7	SW	2,400 2,400	1,728 1,728			<del>                                     </del>	\$ 1,593.75 \$ 1,593.75		11.7 11.7	1.7
36 36	209	15	S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	SW SW	2400 2400	2,592	15 15	C 28 P F 2	F42SSILL F42SSILL	_	0.7 0.7	SW SW	2,400	1,728	+		+ +	\$ 1,593.75 \$ 1,593.75		11.7	1.7 1.7
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112		W 17 W C 2	F22ILL		0.0	SW	2,000	66			\$ 7.57			13.4	2.0

CHA Project No.24698 Cost of Electricity: \$0.124 \$/kWh Consumption

ECM-5 Lighting Replacements \$6.76 \$/kW Demand

				EXISTIN	G CONDITIO	NS						RETR	OFIT CONI	DITIONS						COST & S	AVINGS ANAL	YSIS		
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cos	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	location - Room number/Room name: Floor	before the	"Lighting Fixture Code" Example: 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	, ,	control device	d daily	,		Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Number of Fixtures)	control device	Estimated annual hours for the usage group	(kW/space ) * (Annual Hours)	Annual kWh) - (Retrofit Annual	` 5	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescripti ve Lighting Measures	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
36	2nd Floor Girl's Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576	4	C 28 P F 2	F42SSILL	48	0.2	SW	2,000	384	192	0.1	\$ 31.60	\$ 425.00	\$40	13.5	2.0
36	Maintenance Room	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	SW	1,000	48	24	0.0	\$ 4.92	\$ 106.25	\$10	21.6	4.0
36	213	10	S 34 P F 2 (MAG)	F42EE	72	0.7	SW	2400	1,728	10	C 28 P F 2	F42SSILL	48	0.5	SW	2,400	1,152	576	0.2	\$ 90.89	\$ 1,062.50	\$100	11.7	1.7
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	SW	2,000	66	46	0.0	\$ 7.57	\$ 101.25	\$10	13.4	2.0
36	2nd Floor Boy's Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576	4	C 28 P F 2	F42SSILL	48	0.2	SW	2,000	384	192	0.1	\$ 31.60	\$ 425.00	\$40	13.5	2.0
36	215	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	SW	2,400	1,728	864	0.4	\$ 136.34	\$ 1,593.75	\$150	11.7	1.7
36	217	18	S 34 P F 2 (MAG)	F42EE	72	1.3	SW	2400	3,110	18	C 28 P F 2	F42SSILL	48	0.9	SW	2,400	2,074	1,037	0.4	\$ 163.61	\$ 1,912.50	\$180	11.7	1.7
82	Exterior	22	WP100 I 2	i100/2	200	4.4	BR	4368	19,219	22	13W LED WP	WPLED13/1	13	0.3	BR	4,368	1,249	17,970	4.1	\$2,562.00	\$ 7,974.45	\$0	3.1	0.4
108	Exterior	7	100W Mercury Vapor	MV100/1	125	0.9	BR	4368	3,822	7	FXLED39	FXLED39/1	39	0.3	BR	4,368	1,192	· · · · · ·		\$ 374.90	<u> </u>		11.3	1.6
96	Exterior	11	175 MH POLE	MH175/1	215	2.4	BR	4368	10,330	11	52W LED Pole Light		52	0.6	BR	4,368	2,498	,		\$1,116.59	\$ 8,409.11		7.5	1.1
75	Exterior		HPS 150	HPS150/1	188	0.8	BR	4368	3,285	4	FXLED39	FXLED39/1		0.2	BR	4,368	681			\$ 371.16			6.5	0.9
	Total	925				77.9			197,999	925			5,851	48.6			116,098	81,901	29.2	\$12,528	\$111,486	\$9,145		
																	Demand			29.2	\$2,373			
																	kWh S			81,901	\$10,156			
																	Total s	avings			\$12,528		8.9	8.2

CHA Project No.24698 Cost of Electricity: \$ 0.149 \$/kWh Blended

ECM-6 Install Occupancy Sensors \$ 0.124 \$/kWh Consumption

\$ 6.760 \$/kW Demand

		\$ 6.760 \$/kW Demand  EXISTING CONDITIONS										RETROFIT CONDITIONS								COST & SAVINGS ANALYSIS						
,				EXISTING	CONDITION	15						KEI	ROFII CONI	DITIONS						COST &	SAVINGS AN	ALTOIO				
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback		
Field Code	the location - Room number/Room name: Floor number (if	No. of fixtures before the retrofit	Example 2T 40 R F(U) = $2'x2'$ Troff	Code from Table of Standard Fixture Wattages	Standard	(Watts/Fi xt) * (Fixt No.)		Estimated annual hours for the usage group	`	ixtures after he retrofit	Example 2T 40 R F(U) = $2'x2'$ Troff 40 w Recess. Floor 2 lamps	Table of Standard Fixture	Standard	" UNiimper of	Retrofit control device	for the usage	(kW/space) * (Annual Hours)	Annual kWh)	- (Retrofit	(kW Saved) * (\$/kWh)	Cost for renovations to lighting system		renovations cost	Length of time for renovations cost to be recovered		
80	Boiler Room	1	I 100	I100/1	100	0.1	SW	1000	100.0	1	I 100	I100/1	100	0.1	OSR	250	25.0	75.0	0.0	\$9.30	\$150.00	\$35.00	16.1	12.4		
102	Gym	 14	High Bay MH 400	MH400/1	458	6.4	BR	2400	15,388.8	14	High Bay MH 400	MH400/1	458	6.4	OSR		10,772.2	4,616.6			\$2,100.00	\$490.00	3.7	2.8		
36	Girl's Locker Room	6	S 34 P F 2 (MAG)	F42EE	72	0.4	SW	2800	1,209.6		S 34 P F 2 (MAG)	F42EE	72	0.4	OSR		864.0	345.6			\$150.00	\$35.00	3.5	2.7		
91	Shower	6	175	I75/1	75	0.5	SW	2800	1,260.0	6	l 75	175/1	75	0.5	OSR		900.0	360.0				\$35.00	3.4	2.6		
36	Entrance	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	172.8	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR	1500	108.0	64.8	0.0	\$8.04	\$150.00	\$35.00	18.7	14.3		
36	Entrance	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	172.8	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR	1500	108.0	64.8	0.0		\$150.00	\$35.00	18.7	14.3		
24	Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0			\$0.00	\$0.00				
36	Gym Storage	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	144.0	2	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR		36.0	108.0			\$150.00	\$35.00	11.2	8.6		
36 36	Gym Storage Entrance	<u>1</u>	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.1	SW SW	1000 2400	72.0 345.6	2	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.1	OSR OSR		18.0 216.0	54.0 129.6			\$150.00 \$150.00	\$35.00 \$35.00	9.3	17.2 7.2		
36	Boy's Gym Office	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	172.8	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR		108.0	64.8			\$150.00	\$35.00	18.7	14.3		
24	Bathroom	2	W 20 C F 2	F22SS	56	0.1	SW	2000	224.0	2	W 20 C F 2	F22SS	56	0.1	N/A		224.0	0.0			\$0.00	\$0.00	10.1	11.0		
36	Boy's Locker Room	 11	S 34 P F 2 (MAG)	F42EE	72	0.8	SW	2800	2,217.6	11	S 34 P F 2 (MAG)	F42EE	72	0.8	OSR		1,584.0			-	\$150.00	\$35.00	1.9	1.5		
36	Kitchen	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	1600	1,728.0		S 34 P F 2 (MAG)	F42EE	72	1.1	OSR	1200	1,296.0				\$450.00	\$105.00	8.4	6.4		
36	Kitchen Storage	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72.0	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR		18.0	54.0			\$150.00	\$35.00	22.4	17.2		
24	Kitchen Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0			\$0.00	\$0.00		<del></del>		
36 24	Storage Room 114 (Art)	1 30	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1 1.7	SW	1000 2400	72.0 4,032.0	<u>1</u> 30	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1 1.7	OSR OSR		18.0 2,822.4	54.0 1,209.6			\$150.00 \$450.00	\$35.00 \$105.00	22.4 3.0	17.2 2.3		
36	Art Storage	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72.0	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR		18.0	54.0		-	\$150.00	\$35.00	22.4	17.2		
36	Music	29	S 34 P F 2 (MAG)	F42EE	72	2.1	SW	2400	5,011.2	29	S 34 P F 2 (MAG)	F42EE	72	2.1	OSR		3,507.8	1,503.4				\$70.00	1.6	1.2		
36	Music Storage	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	1000	288.0	4	S 34 P F 2 (MAG)	F42EE	72	0.3	OSR	250	72.0	216.0	0.0	\$26.78	\$150.00	\$35.00	5.6	4.3		
36	Music Office	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	345.6	2	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR	1500	216.0	129.6	0.0	\$16.07	\$150.00	\$35.00	9.3	7.2		
36	Music Office 2	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	345.6	2	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR	1500	216.0	129.6	0.0	\$16.07	\$150.00	\$35.00	9.3	7.2		
36	Music Storage 2	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72.0	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR	250	18.0	54.0	0.0	\$6.70	\$150.00	\$35.00	22.4	17.2		
43	Stairway Near Music	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	SW	3200	569.6	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	N/A	3200	569.6	0.0	0.0	\$0.00	\$0.00	\$0.00				
24	Stairway Near Music	1	W 20 C F 2	F22SS	56	0.1	SW	3200	179.2	1	W 20 C F 2	F22SS	56	0.1	N/A	3200	179.2	0.0	0.0	\$0.00	\$0.00	\$0.00				
69	107	21	2B 34 R F 2 (u) (MAG)	FU2EE	72	1.5	SW	2400	3,628.8		2B 34 R F 2 (u) (MAG)	FU2EE	72	1.5	OSR		2,540.2	1,088.6			\$450.00	\$105.00	3.3	2.6		
69 69	107 Office 107 Storage	1	2B 34 R F 2 (u) (MAG) 2B 34 R F 2 (u) (MAG)	FU2EE FU2EE	72 72	0.1	SW SW	2400 1000	172.8 144.0		2B 34 R F 2 (u) (MAG) 2B 34 R F 2 (u) (MAG)	FU2EE FU2EE	72 72	0.1 0.1	OSR OSR		108.0 36.0	64.8 108.0		-	\$150.00 \$150.00	\$35.00 \$35.00	18.7 11.2	14.3 8.6		
36	107 Storage	24	S 34 P F 2 (MAG)	F42EE	72	1.7	SW	2400	4,147.2		S 34 P F 2 (MAG)	F42EE	72	1.7	OSR		2,903.0				\$450.00	\$105.00	2.9	2.2		
36	103	24	S 34 P F 2 (MAG)	F42EE	72	1.7	SW	2400	4,147.2		S 34 P F 2 (MAG)	F42EE	72	1.7	OSR		2,903.0	1,244.2		-	\$450.00	\$105.00	2.9	2.2		
36	103 Storage	8	S 34 P F 2 (MAG)	F42EE	72	0.6	SW	1000	576.0		S 34 P F 2 (MAG)	F42EE	72	0.6	OSR		144.0			-	\$150.00	\$35.00	2.8	2.1		
36	101	24	S 34 P F 2 (MAG)	F42EE	72	1.7	SW	2400	4,147.2		S 34 P F 2 (MAG)	F42EE	72	1.7	OSR		2,903.0	1,244.2				\$105.00	2.9	2.2		
36	Server Room	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72.0	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR		18.0	54.0			\$150.00	\$35.00	22.4	17.2		
24	Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0			\$0.00	\$0.00				
36	Bathroom	3	S 34 P F 2 (MAG)	F42EE	72	0.2	SW	2000	432.0		S 34 P F 2 (MAG)	F42EE	72	0.2	N/A		432.0	0.0				\$0.00	20. 4	47.0		
36	Maintenance	11	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1	SW SW	1000 2000	72.0 112.0	1	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1	OSR N/A		18.0 112.0	54.0 0.0			\$150.00 \$0.00	\$35.00 \$0.00	22.4	17.2		
24	Bathroom	<u> </u>		F22SS F42EE		0.1		2000		2	S 34 P F 2 (MAG)	F2255 F42EE			1							\$0.00				
36	Bathroom	<u> </u>	S 34 P F 2 (MAG)		72	0.2	SW		432.0		,		72	0.2	N/A		432.0	0.0				ľ	4.0	2.7		
48	Nurse	5	T 32 R F 4 (ELE)	F44ILL	112	0.6	SW	2400	1,344.0	5	T 32 R F 4 (ELE)	F44ILL	112	0.6	OSR		840.0	504.0				\$70.00	4.8	3.7		
38	Nurse Bathroom Entryway	1 1	W 20 C F 2 F42ILL	F22SS F42ILL	56 59	0.1	SW	2400 2280	134.4 134.5	1	W 20 C F 2 F42ILL	F22SS F42ILL	56 59	0.1 0.1	OSR N/A		84.0 134.5	50.4 0.0			\$150.00 \$0.00	\$35.00 \$0.00	24.0	18.4		
43	Principal's Office	6	T 32 R F 3 (ELE)	F42ILL F43ILL	89	0.1	SW	2400	1,281.6	6	T 32 R F 3 (ELE)	F43ILL	89	0.1	OSR		801.0	+		-	1	\$35.00	2.5	1.9		
24	Principal's Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A		112.0	0.0		-	\$0.00	\$0.00				
43	Main Office	10	T 32 R F 3 (ELE)	F43ILL	89	0.9	SW	2400	2,136.0	10	T 32 R F 3 (ELE)	F43ILL	89	0.9	OSR	1500	1,335.0	801.0	0.0	\$99.32	\$300.00	\$70.00	3.0	2.3		
24	Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0	0.0	\$0.00	\$0.00	\$0.00				
36	Main Office Closet	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	144.0	2	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR	250	36.0	108.0	0.0	\$13.39	\$150.00	\$35.00	11.2	8.6		
43	Office	4	T 32 R F 3 (ELE)	F43ILL	89	0.4	SW	2400	854.4	4	T 32 R F 3 (ELE)	F43ILL	89	0.4	OSR	1500	534.0	320.4	0.0	\$39.73	\$150.00	\$35.00	3.8	2.9		
43	Office	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	SW	2400	213.6	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	OSR	1500	133.5	80.1	0.0	\$9.93	\$150.00	\$35.00	15.1	11.6		
43	Office	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	SW	2400	213.6	1	T 32 R F 3 (ELE)	F43ILL	89	0.1	OSR	1500	133.5	80.1	0.0	\$9.93	\$150.00	\$35.00	15.1	11.6		

CHA Project No.24698 Cost of Electricity: \$ 0.149 \$/kWh Blended

ECM-6 Install Occupancy Sensors \$ 0.124 \$/kWh Consumption

\$ 6.760 \$/kW Demand

	1			EVICTING	CONDITION	60 \$/kW Demand				RETROFIT CONDITIONS COST & SAVINGS ANALYSIS														
				EXISTING	CONDITION	NS						KEI	ROFII COM	DITIONS						COST &	SAVINGS ANA	ALTSIS		
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	the location - Room number/Room name: Floor number (if	No. of fixtures before the retrofit	R F(U) = 2'x2' Troff	Code from Table of Standard Fixture Wattages		(Watts/Fi xt) * (Fixt No.)		Estimated annual hours for the usage group	`	fixtures after	Example 2T 40 R F(U) = $2'x2'$ Troff	Table of Standard Fixture	Standard	" UNiimper of	Retrofit control device	for the usage	(kW/space) * (Annual Hours)	Annual kWh)	- (Retrofit	(kW Saved) * (\$/kWh)	Cost for renovations to lighting system		Length of time for renovations cost to be recovered	renovations cost to be
36	102	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		1,814.4					\$70.00	3.1	2.4
36 36	104 106	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	SW SW	2400 2400	2,592.0 2,592.0	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	OSR OSR	1680 1680	1,814.4 1,814.4	777.6 777.6				\$70.00 \$70.00	3.1 3.1	2.4
36	Bathroom	3	S 34 P F 2 (MAG)	F42EE	72	0.2	SW	2000	432.0		S 34 P F 2 (MAG)	F42EE	72	0.2	N/A		432.0	1				\$0.00	0.1	2.7
24	Bathroom Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0	0.0	\$0.00	\$0.00	\$0.00		
36	Bathroom	3	S 34 P F 2 (MAG)	F42EE	72	0.2	SW	2000	432.0	3	S 34 P F 2 (MAG)	F42EE	72	0.2	N/A	i i	432.0					\$0.00		
24 36	Bathroom Entrance  Maintenance Room	1	W 20 C F 2 S 34 P F 2 (MAG)	F22SS F42EE	56 72	0.1 0.1	SW SW	2000 1000	112.0 72.0	1 1	W 20 C F 2 S 34 P F 2 (MAG)	F22SS F42EE	56 72	0.1 0.1	N/A OSR	2000 250	112.0 18.0			-	•	\$0.00 \$35.00	22.4	17.2
36	108	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		1,814.4					\$105.00	4.7	3.6
36	110	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		1,814.4					\$105.00	4.7	3.6
36 69	112 Hallway	21	S 34 P F 2 (MAG) 2B 34 R F 2 (u) (MAG)	F42EE FU2EE	72 72	1.5 3.9	SW	2400 2280	3,628.8 8,864.6	21 54	S 34 P F 2 (MAG) 2B 34 R F 2 (u) (MAG)	F42EE FU2EE	72 72	1.5 3.9	OSR N/A		2,540.2 8,864.6					\$105.00 \$0.00	3.3	2.6
69	1st Entry	3	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.2	SW	2280	492.5		2B 34 R F 2 (u) (MAG)	FU2EE	72	0.2	N/A		492.5					\$0.00		
69	Stairway	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	SW	3200	230.4	1	2B 34 R F 2 (u) (MAG)	FU2EE	72	0.1	N/A		230.4					\$0.00		
69 43	Stairway Stairwell	1	2B 34 R F 2 (u) (MAG)	FU2EE F43ILL	72 89	0.1 0.2	SW	3200	230.4 569.6	1	2B 34 R F 2 (u) (MAG) T 32 R F 3 (ELE)	FU2EE F43ILL	72 89	0.1	N/A N/A		230.4 569.6					\$0.00 \$0.00		
43	Stairweil	2	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL F43ILL	89	0.2	SW	3200 3200	569.6	2	T 32 R F 3 (ELE)	F43ILL F43ILL	89 	0.2	N/A N/A		569.6					\$0.00		
43	Stairwell	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	SW	3200	569.6	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	N/A		569.6	0.0				\$0.00		
36	219	30	S 34 P F 2 (MAG)	F42EE	72	2.2	SW	2400	5,184.0	30	S 34 P F 2 (MAG)	F42EE	72	2.2	OSR		3,628.8	.,		•		\$140.00	3.1	2.4
43	Faculty Room	8	T 32 R F 3 (ELE)	F43ILL	89	0.7	SW	2400	1,708.8	8	T 32 R F 3 (ELE)	F43ILL	89	0.7	OSR		1,068.0					\$105.00	5.7	4.3
80 36	Fan Room Bathroom	5 1	I 100 S 34 P F 2 (MAG)	I100/1 F42EE	100 72	0.5 0.1	SW	1000 2000	500.0 144.0	5 1	I 100 S 34 P F 2 (MAG)	I100/1 F42EE	100 72	0.5 0.1	OSR N/A	250 2000	125.0 144.0	375.0				\$35.00 \$0.00	3.2	2.5
24	Bathroom	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	<u>'</u> 1	W 20 C F 2	F22SS	56	0.1	N/A		112.0	0.0				\$0.00		
36	216	18	S 34 P F 2 (MAG)	F42EE	72	1.3	SW	2400	3,110.4	18	S 34 P F 2 (MAG)	F42EE	72	1.3	OSR		2,177.3					\$70.00	2.6	2.0
24	Bathroom Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0				\$0.00		
36	Bathroom Storage	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2000	144.0	1	S 34 P F 2 (MAG)	F42EE	72	0.1	N/A	2000	144.0					\$0.00		
36 24	Bathroom Entrance	1	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1	SW SW	2000	288.0 112.0	<u>2</u> 1	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1	N/A N/A	2000 2000	288.0 112.0	0.0				\$0.00 \$0.00		
36	2nd Boy's Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576.0	4	S 34 P F 2 (MAG)	F42EE	72	0.3	N/A		576.0					\$0.00		
36	214	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		1,814.4					\$70.00	3.1	2.4
36	212	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		1,814.4					\$70.00	3.1	2.4
24	Maintenance Closet  Bathroom Entrance	1	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1	SW SW	1000 2000	72.0 112.0	1	S 34 P F 2 (MAG) W 20 C F 2	F42EE F22SS	72 56	0.1	OSR N/A		18.0 112.0	54.0 0.0				\$35.00 \$0.00	22.4	17.2
36	Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576.0	4	S 34 P F 2 (MAG)	F42EE	72	0.3	N/A		576.0					\$0.00		
36	210	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		1,814.4	_		•		\$70.00	3.1	2.4
36 36	208 206	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	SW SW	2400 2400	2,592.0 2,592.0	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	OSR OSR		1,814.4 1,814.4					\$70.00 \$70.00	3.1	2.4
36	204A	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2400	345.6	2	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR		241.9			•	•	\$35.00	11.7	8.9
70	Periodical Room	4	2T 32 R F 2 (u) (ELE)	FU2ILL	59	0.2	SW	2400	566.4		2T 32 R F 2 (u) (ELE)	FU2ILL	59	0.2	OSR		396.5			-	•	\$35.00	7.1	5.5
36 36	204 202	15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	SW	2400 2400	2,592.0 2,592.0	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	OSR OSR		1,814.4 1,814.4					\$70.00 \$70.00	3.1 3.1	2.4
42	Media Center	25	T 34 R F 3 (MAG)	F42EE F43EE	115	2.9	SW	2400	6,900.0	25	T 34 R F 3 (MAG)	F42EE F43EE	115	2.9	OSR		4,830.0			•		\$0.00	0.0	0.0
36	Media Center Office	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2400	691.2	4	S 34 P F 2 (MAG)	F42EE	72	0.3	OSR		432.0	· ·				\$35.00	4.7	3.6
36	Conference Room	6	S 34 P F 2 (MAG)	F42EE	72	0.4	SW	2400	1,036.8	6	S 34 P F 2 (MAG)	F42EE	72	0.4	OSR		648.0					\$35.00	3.1	2.4
36 36	Storage PC Lab	1 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.1	SW SW	1000 2400	72.0 2,592.0	1 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.1 1.1	OSR OSR		18.0 1,814.4			•		\$35.00 \$70.00	22.4 3.1	17.2 2.4
36	203	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		1,814.4	777.6				\$70.00	3.1	2.4
70	2nd Floor Hallway	50	2T 32 R F 2 (u) (ELE)	FU2ILL	59	3.0	SW	2280	6,726.0	50	2T 32 R F 2 (u) (ELE)	FU2ILL	59	3.0	N/A	2280	6,726.0	0.0	0.0	\$0.00	\$0.00	\$0.00		
36	205A		S 34 P F 2 (MAG)	F42EE	72	0.4		2400	1,036.8		S 34 P F 2 (MAG)	F42EE	72	0.4	OSR							\$70.00	7.8	6.0
36	205	15 15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0		S 34 P F 2 (MAG)	F42EE	72	1.1	OSR		•					\$70.00	3.1	2.4
36 36	207 209	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1 1.1	SW SW	2400 2400	2,592.0 2,592.0		S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	OSR OSR		•					\$70.00 \$70.00	3.1 3.1	2.4
36	211	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0		S 34 P F 2 (MAG)	F42EE	72	1.1	OSR			1				\$70.00	3.1	2.4
24	Bathroom Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0	0.0	\$0.00	\$0.00	\$0.00		

CHA Project No.24698 Cost of Electricity: \$ 0.149 \$/kWh Blended

ECM-6 Install Occupancy Sensors \$ 0.124 \$/kWh Consumption

\$ 6.760 \$/kW Demand

			EXISTING CONDITIONS							RET	ROFIT CON	DITIONS						COST &	SAVINGS AN	ALYSIS				
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	number/Room name:	No. of fixtures before the retrofit	Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps	Code from Table of Standard Fixture Wattages	Standard	(Watts/Fi xt) * (Fixt No.)		Estimated annual hours for the usage group	`		"Lighting Fixture Code"  Example 2T 40  R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Table of Standard	Value from Table of Standard Fixture Wattages	" (INUmber of	Retrofit control device	Estimated annual hours for the usage group	(kW/space) * (Annual Hours)	(Original Annual kWh) - (Retrofit Annual kWh)	- (Retrofit	(kW Saved) * (\$/kWh)	Cost for renovations to lighting system			Length of time for renovations cost to be recovered
36	Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576.0	4	S 34 P F 2 (MAG)	F42EE	72	0.3	N/A	2000	576.0	0.0	0.0	\$0.00	\$0.00	\$0.00		
36	Maintenance Room	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72.0	1	S 34 P F 2 (MAG)	F42EE	72	0.1	OSR	250	18.0	54.0	0.0	\$6.70	\$150.00	\$35.00	22.4	17.2
36	213	10	S 34 P F 2 (MAG)	F42EE	72	0.7	SW	2400	1,728.0	10	S 34 P F 2 (MAG)	F42EE	72	0.7	OSR	1680	1,209.6	518.4	0.0	\$64.28	\$300.00	\$70.00	4.7	3.6
24	Bathroom Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112.0	1	W 20 C F 2	F22SS	56	0.1	N/A	2000	112.0	0.0	0.0	\$0.00	\$0.00	\$0.00		
36	Bathroom	4	S 34 P F 2 (MAG)	F42EE	72	0.3	SW	2000	576.0	4	S 34 P F 2 (MAG)	F42EE	72	0.3	N/A	2000	576.0	0.0	0.0	\$0.00	\$0.00	\$0.00		
36	215	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592.0	15	S 34 P F 2 (MAG)	F42EE	72	1.1	OSR	1680	1,814.4	777.6	0.0	\$96.42	\$300.00	\$70.00	3.1	2.4
36	217	18	S 34 P F 2 (MAG)	F42EE	72	1.3	SW	2400	3,110.4	18	S 34 P F 2 (MAG)	F42EE	72	1.3	OSR	1680	2,177.3	933.1	0.0	\$115.71	\$300.00	\$70.00	2.6	2.0
82	Exterior	22	WP100 I 2	i100/2	200	4.4	BR	4368	19,219.2	22	WP100 I 2	i100/2	200	4.4	N/A	4368	,	0.0	0.0	\$0.00	\$0.00	\$0.00		
108	Exterior	7	100W Mercury Vapor	MV100/1	125	0.9	BR	4368	3,822.0	7	100W Mercury Vapor	MV100/1	125	0.9	N/A	4368	3,822.0	0.0	0.0	\$0.00	\$0.00	\$0.00		
96	Exterior	11	175 MH POLE	MH175/1	215	2.4	BR	4368	10,330.3	11	175 MH POLE	MH175/1	215	2.4	N/A	4368	· ·	0.0	0.0	\$0.00	\$0.00	\$0.00		
75	Exterior	4	HPS 150	HPS150/1	188	0.8	BR	4368	3,284.7		HPS 150	HPS150/1	188	0.8	N/A	4368		0.0	0.0		\$0.00	\$0.00		
	Total	921				77.1			194,714	921				77			1	42,649	0		\$19,950	4,655		
																		l Savings		0.0	\$0			
																		Savings		42,649	\$6,355	1		
																	Total S	Savings			\$6,355		3.1	2.4

CHA Project No.24698

Cost of Electricity: \$0.124 \$/kWh

ECM-7 Lighting Replacements with Occupancy Sensors

\$6.76 \$/kW

	1			EXISTING (	CONDITIONS							RETR	OFIT COND	ITIONS						COST & SA	VINGS ANALY	SIS		
	Area Description	No. of Fixtures	dard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	fixtures hefore the	nting Fixture Code" le 2T 40 = 2'x2' Troff 40 ess. Floor 2 lamps U shape	Code from Table of Standard		`	Pre-inst. control device	Estimated daily hours for the usage group	(kW/space) * (Annual Hours)	No. of fixtures after the retrofit	"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt ) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kW/ space) * (Annual Hours)	(Original Annual kWh) (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
80	Boiler Room	1 I 100		I100/1	100	0.1	SW	1000	100	1	CF 26	CFQ26/1-L	27	0.0	OSR	250	7	93	0.1	\$ 17.48	\$ 156.75	\$ 35	9.0	7.0
102	Gym	14 High Bay	y MH 400	MH400/1	458	6.4	BR	2400	15,389	14	C 54 C F 6	F46GHL	351	4.9	OSR	1,680	8,256	7,133	1.5	\$ 1,006.04	\$ 9,849.00	\$ 1,890	9.8	7.9
36	Girl's Locker Room		2 (MAG)	F42EE	72	0.4	SW	2800	1,210	6	C 28 P F 2	F42SSILL	48	0.3	OSR	2,000	576	634		\$ 90.25	\$ 787.50	\$ 95	8.7	7.7
91 36	Girl's Locker Room-Shower Girl's Gym Office Entrance	6   175 1   S 34 P F	- 2 (MAG)	I75/1 F42EE	75	0.5	SW SW	2800 2400	1,260 173	1	CF 26 C 28 P F 2	CFQ26/1-L F42SSILL	27 48	0.2	OSR OSR	2,000 1,500	324 72	936 101		\$ 139.43 \$ 14.45	\$ 182.40 \$ 256.25	\$ 35 \$ 45	1.3 17.7	1.1
36	Girl's Gym Office Entrance		= 2 (MAG)	F42EE	72	0.1	SW	2400	173	1	C 28 P F 2	F42SSILL	48	0.0	OSR	1,500	72	101		\$ 14.45	\$ 256.25	\$ 45	17.7	14.6
24	Girl's Gym Office Bathroom	1 W 20 C		F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
36 36	Gym Storage Gym Storage		= 2 (MAG) = 2 (MAG)	F42EE F42EE	72 72	0.1 0.1	SW SW	1000 1000	144 72	2	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.1	OSR OSR	250 250	24 12	120 60		\$ 18.77 \$ 9.39	\$ 362.50 \$ 256.25	\$ 55 \$ 45	19.3 27.3	16.4 22.5
36	Boy's Gym Office Entrance		= 2 (MAG)	F42EE	72	0.1	SW	2400	346	2	C 28 P F 2	F42SSILL	48	0.0	OSR	1,500	144	202		\$ 28.89	\$ 362.50	\$ 45 \$ 55	12.5	10.6
36	Boy's Gym Office	1 S 34 P F	2 (MAG)	F42EE	72	0.1	SW	2400	173	1	C 28 P F 2	F42SSILL	48	0.0	OSR	1,500	72	101	0.0	\$ 14.45	\$ 256.25	\$ 45	17.7	14.6
24	Boy's Gym Office Bathroom	2 W 20 C		F22SS	56	0.1	SW	2000	224	2	W 17 W C 2	F22ILL	33	0.1	N/A	2,000	132	92		\$ 15.14	·	\$ 20	13.4	12.1
36 36	Boy's Locker Room Kitchen		= 2 (MAG) = 2 (MAG)	F42EE F42EE	72 72	0.8 1.1	SW SW	2800 1600	2,218 1,728	11 15	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.5	OSR OSR	2,000 1,200	1,056 864	1,162 864		\$ 165.45 \$ 136.34	\$ 1,318.75 \$ 2,043.75	\$ 145 \$ 255	8.0 15.0	7.1
36	Kitchen Storage	1 S 34 P F	2 (MAG)	F42EE	72		SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	OSR	250	12	60		\$ 9.39	\$ 256.25	\$ 45	27.3	22.5
24	Kitchen Bathroom	1 W 20 C		F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
36 24	Storage Room 114 (Art)	1 S 34 P F 30 W 20 C	F 2 (MAG) F 2	F42EE F22SS	72 56	0.1 1.7	SW SW	1000 2400	72 4,032	30	C 28 P F 2 W 17 W C 2	F42SSILL F22ILL	48 33	0.0 1.0	OSR OSR	250 1.680	12 1,663	60 2,369		\$ 9.39 \$ 349.70	\$ 256.25 \$ 3,487.50		27.3 10.0	22.5 8.8
36	Art Storage	1 S 34 P F	2 (MAG)	F42EE	72		SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	OSR	250	12	60	0.0	\$ 9.39	\$ 256.25	·		22.5
36	Music		2 (MAG)	F42EE	72	2.1	SW	2400	5,011	29	C 28 P F 2	F42SSILL	48	1.4	OSR	1,680	2,339	2,673		\$ 387.87	\$ 3,381.25	\$ 360	8.7	7.8
36 36	Music Storage  Music Office		= 2 (MAG) = 2 (MAG)	F42EE F42EE	72	0.3	SW SW	1000 2400	288 346	2	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48	0.2	OSR OSR	250 1 500	48 144	240 202		\$ 37.55 \$ 28.89	\$ 575.00 \$ 362.50	\$ 75 \$ 55	15.3 12.5	13.3 10.6
36	Music Office 2		= 2 (MAG)	F42EE	72	0.1	SW	2400	346	2	C 28 P F 2	F42SSILL	48	0.1	OSR	1,500	144	202		\$ 28.89	\$ 362.50	\$ 55	12.5	10.6
36	Music Storage 2	1 S 34 P F	- 2 (MAG)	F42EE	72	0.1	SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	OSR	250	12	60	0.0	\$ 9.39	\$ 256.25	\$ 45	27.3	22.5
43	Stairway Near Music		- 3 (ELE)	F43ILL F22SS	89	0.2	SW	3200	570	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	N/A	3,200	570		0.0	\$ -	\$ -	\$ -	0.0	0.0
69	Stairway Near Music 107	1 W 20 C 21 2B 34 R	F 2 (u) (MAG)	FU2EE	56 72		SW SW	3200 2400	179 3,629	21	W 17 W C 2 2T 17 R F 2 (ELE)	F22ILL F22ILL	33 33	0.0	N/A OSR	3,200 1,680	106 1,164	74 2,465		\$ 10.99 \$ 372.04	\$ 101.25 \$ 2,576.25	•	9.2 6.9	8.3 6.1
69	107 Office		F 2 (u) (MAG)	FU2EE FU2EE	72		SW	2400	173		2T 17 R F 2 (ELE)	F22ILL	33	0.0	OSR	1,500	50 17	123 128		\$ 18.45		<u>'</u>		11.2 13.4
69 36	107 Storage 105		F 2 (u) (MAG) F 2 (MAG)	F42EE	72 72		SW SW	1000 2400	144 4,147	24	2T 17 R F 2 (ELE) C 28 P F 2	F22ILL F42SSILL	33 48	0.1 1.2	OSR OSR	250 1,680	1,935	2,212		\$ 22.14 \$ 320.99	\$ 352.50 \$ 3,000.00		15.9 9.3	8.3
36	103		2 (MAG) 2 (MAG)	F42EE F42EE		1.7 0.6	SW SW	2400 1000	4,147 576	24	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	1.2 0.4	OSR OSR	1,680 250	1,935 96	2,212 480		\$ 320.99 \$ 75.10	\$ 3,000.00 \$ 1.000.00	•	9.3 13.3	8.3 11.8
36 36	103 Storage 101		- 2 (MAG) - 2 (MAG)	F42EE	72		SW	2400	4,147	24	C 28 P F 2	F42SSILL F42SSILL	48	1.2	OSR	1,680	1,935	2,212		\$ 75.10	\$ 1,000.00	'	9.3	8.3
36	Server Room		2 (MAG)	F42EE	72		SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	OSR	250	12	60		\$ 9.39	\$ 256.25		27.3	22.5
24	1st Floor Boy's Bathroom  1st Floor Boy's Bathroom	1 W 20 C	F 2 F 2 (MAG)	F22SS F42EE	56	0.1	SW SW	2000	112 432	1 3	W 17 W C 2 C 28 P F 2	F22ILL F42SSILL	33 48	0.0	N/A N/A	2,000 2,000	66 288	46 144		\$ 7.57 \$ 23.70	\$ 101.25 \$ 318.75	\$ 10 \$ 30	13.4 13.5	12.1 12.2
36	1st Floor Maintenance		= 2 (MAG) = 2 (MAG)	F42EE F42EE	72		SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	OSR	250	12	60		\$ 9.39	\$ 256.25	\$ 45	27.3	22.5
24	1st Floor Girl's Bathroom	1 W 20 C		F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
36 48	1st Floor Girl's Bathroom Nurse		= 2 (MAG) = 4 (ELE)	F42EE F44ILL	72 112	0.2	SW SW	2000 2400	432 1,344	3 5	C 28 P F 2	F42SSILL F44SSILL	48 96	0.1 0.5	N/A OSR	2,000 1,500	288 720	144 624		\$ 23.70 \$ 83.87	\$ 318.75 \$ 831.25	\$ 30 \$ 120	13.5 9.9	12.2 8.5
24	Nurse Bathroom	1 W 20 C	` ,	F22SS	56	0.1	SW	2400	134	1	W 17 W C 2	F22ILL	33	0.0	OSR	1,500	50	85	0.0	\$ 12.39	\$ 251.25	·	20.3	16.6
38 43	Entryway Principal's Office	1 F42ILL 6 T 32 R F	3 (ELE)	F42ILL F43ILL	59 89	0.1 0.5	SW SW	2280 2400	135 1,282	<u>1</u>	F42ILL T 32 R F 3 (ELE)	F42ILL F43ILL	59 89	0.1	N/A OSR	2,280 1,500	135 801	- 481	0.0	\$ - \$ 59.59	\$ - \$ 150.00	\$ - \$ 35	2.5	1.9
24	Principal's Bathroom	1 W 20 C	F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46	0.0	\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
43 24	Main Office Main Office Bathroom	10 T 32 R F 1 W 20 C	F 3 (ELE) F 2	F43ILL F22SS	89 56	0.9	SW SW	2400 2000	2,136 112	10 1	T 32 R F 3 (ELE) W 17 W C 2	F43ILL F22ILL	89 33	0.9	OSR N/A	1,500 2,000	1,335 66	801 46		\$ 99.32 \$ 7.57	\$ 300.00 \$ 101.25		3.0 13.4	2.3
36	Main Office Closet	2 S 34 P F	2 (MAG)	F42EE	72		SW	1000	144	2	C 28 P F 2	F42SSILL	48	0.1	OSR	250	24	120	0.0	\$ 18.77	\$ 362.50	·		16.4
43	Assistant Principal's Office		3 (ELE) 3 (ELE)	F43ILL F43ILL	89	0.4	SW	2400	854 214	4	T 32 R F 3 (ELE) T 32 R F 3 (ELE)	F43ILL F43ILL	89	0.4	OSR OSR	1,500	534	320		\$ 39.73	\$ 150.00 \$ 150.00	\$ 35 \$ 35	3.8	2.9 11.6
43	Office Office		3 (ELE)	F43ILL F43ILL	89 89		SW SW	2400 2400	214 214	11	T 32 R F 3 (ELE)	F43ILL F43ILL	89 89	0.1	OSR	1,500	134 134	80 80	0.0	\$ 9.93 \$ 9.93	\$ 150.00	\$ 35	15.1	11.6
36 36	102	15 S 34 P F	= 2 (MAG) = 2 (MAG)	F42EE F42EE	-	1.1	SW	2400 2400	2,592 2,592		C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.7	OSR OSR	1,680	1,210 1,210	1,382 1,382		•	\$ 1,893.75 \$ 1,893.75	\$ 220		8.3
36	104 106		- 2 (MAG) - 2 (MAG)	F42EE F42EE		1.1	SW SW	2400	2,592 2,592	15 15	C 28 P F 2	F42SSILL F42SSILL	48	0.7	OSR	1,680 1,680	1,210	1,382			\$ 1,893.75 \$ 1,893.75		9.4	8.3 8.3
36	1st Floor Girl's Bathroom		2 (MAG)	F42EE	72		SW	2000	432		C 28 P F 2	F42SSILL	48	0.1	N/A	2,000	288	144		\$ 23.70			13.5	12.2
24	Entrance	1 W 20 C		F22SS	56		SW	2000	112		W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	· ·	·	13.4	12.1
36	1st Floor Boy's Bathroom	3  S 34 P F	- 2 (MAG)	F42EE	72	0.2	SW	2000	432	3	C 28 P F 2	F42SSILL	48	0.1	N/A	2,000	288	144	0.1	\$ 23.70	\$ 318.75	\$ 30	13.5	12.2

CHA Project No.24698

Cost of Electricity: \$0.124 \$/kWh

ECM-7 Lighting Replacements with Occupancy Sensors

\$6.76 \$/kW

_				EXISTING	CONDITIONS			_				RETR	OFIT COND	ITIONS						COST & SA	AVINGS ANALY	SIS		
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Exist Control	Annual Hours	Annual kWh	Number of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/ Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	NJ Smart Start Lighting Incentive	Simple Payback With Out Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	"Lighting Fixture Code"  Example 2T 40  R F(U) = 2'x2' Troff 40  w Recess. Floor 2 lamps U  shape		Standard	(Watts/Fi xt) * (Fixt No.)	Pre-inst. control device	Estimated daily hours for the usage group	(kW/space) * (Annual Hours)	No. of fixtures after the retrofit	"Lighting Fixture Code" Example 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt ) * (Number of Fixtures)	Retrofit control device	Estimated annual hours for the usage group	(kW/ space) * (Annual Hours)	(Original Annual kWh) (Retrofit Annual kWh)	(Original Annual kW) - (Retrofit Annual kW)	(kWh Saved) * (\$/kWh)	Cost for renovations to lighting system	Prescriptive Lighting Measures	Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	\$ 101.25	•		12.1
36 36	Maintenance Room 108	1 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	0.1 1.1	SW	1000 2400	72 2,592	1 15	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.0	OSR OSR	250 1.680	12 1,210	60 1,382		\$ 9.39 \$ 200.62				22.5 8.9
36	110	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382	0.4	\$ 200.62	\$ 2,043.75	\$ 255	10.2	8.9
36	112 Hallway	21	S 34 P F 2 (MAG)	F42EE FU2EE	72 72	1.5	SW	2400	3,629	21 54	C 28 P F 2 2T 17 R F 2 (ELE)	F42SSILL	48	1.0	OSR	1,680	1,693	1,935 4,802		\$ 280.87 \$ 766.25	\$ 2,681.25 \$ 5,467.50			8.4
69 69	1st Entry	54 3	2B 34 R F 2 (u) (MAG) 2B 34 R F 2 (u) (MAG)	FU2EE	72		SW SW	2280 2280	8,865 492	3	2T 17 R F 2 (ELE)	F22ILL F22ILL	33 33	1.8 0.1	N/A N/A	2,280 2,280	4,063 226	4,802		\$ 700.25			7.1 7.1	6.4
69	Stairway	1	2B 34 R F 2 (u) (MAG)	FU2EE	72		SW	3200	230	1	2T 17 R F 2 (ELE)	F22ILL	33	0.0	N/A	3,200	106	125		\$ 18.64	\$ 101.25	\$ 10		4.9
69 43	Stairway Stairwell	1 2	2B 34 R F 2 (u) (MAG) T 32 R F 3 (ELE)	FU2EE F43ILL	72 89		SW SW	3200 3200	230 570	1	2T 17 R F 2 (ELE) T 32 R F 3 (ELE)	F22ILL F43ILL	33 89	0.0	N/A N/A	3,200 3,200	106 570	125	0.0	\$ 18.64 \$ -	\$ 101.25 \$ -	\$ 10	5.4	4.9
43	Stairwell	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	SW	3200	570	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	N/A	3,200	570		0.0	\$ -	\$ -	\$ -		
43	Stairwell	2	T 32 R F 3 (ELE)	F43ILL	89		SW	3200	570	2	T 32 R F 3 (ELE)	F43ILL	89	0.2	N/A	3,200	570		0.0	\$ - \$ 404.24	\$ -	\$ -	0.4	- 0 2
36 43	219 Faculty Room	30 8	S 34 P F 2 (MAG) T 32 R F 3 (ELE)	F42EE F43ILL	72 89		SW SW	2400 2400	5,184 1,709	30 8	C 28 P F 2 T 32 R F 3 (ELE)	F42SSILL F43ILL	48 89	1.4 0.7	OSR OSR	1,680 1,500	2,419 1,068	2,765 641		\$ 401.24 \$ 79.46				8.3 4.3
80	Fan Room	5	I 100	I100/1	100		SW	1000	500	5	CF 26	CFQ26/1-L	27	0.1	OSR	250	34	466		\$ 87.42		•		1.7
36	2nd Floor Men's Bathroom	1	S 34 P F 2 (MAG)	F42EE	72		SW	2000	144	1	C 28 P F 2	F42SSILL	48	0.0	N/A	2,000	96	48		\$ 7.90	\$ 106.25		13.5	12.2
24 36	2nd Floor Men's Bathroom 216	1 18	W 20 C F 2 S 34 P F 2 (MAG)	F22SS F42EE	56 72	0.1 1.3	SW SW	2000 2400	112 3,110	1 18	W 17 W C 2 C 28 P F 2	F22ILL F42SSILL	33 48	0.0	N/A OSR	2,000 1,680	66 1,452	46 1,659		\$ 7.57 \$ 240.74	\$ 101.25 \$ 2,212.50	·	13.4 9.2	12.1 8.2
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	10	W 17 W C 2	F22ILL	33	0.9	N/A	2.000	1,452	1,039		\$ 7.57	\$ 2,212.30	\$ 230	13.4	12.1
36	Storage	<u>'</u> 1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2000	144	<del>'</del> 1	C 28 P F 2	F42SSILL	48	0.0	N/A	2,000	96	48		\$ 7.90	\$ 106.25	\$ 10	13.5	12.2
36	2nd Floor Women's Bathroom	2	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	2000	288	2	C 28 P F 2	F42SSILL	48	0.1	N/A	2,000	192	96	0.0	\$ 15.80	\$ 212.50	\$ 20	13.5	12.2
24	2nd Boy's Bathroom Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
36 36	2nd Boy's Bathroom 214	<u>4</u> 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72		SW SW	2000 2400	576 2,592	4 15	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.2	N/A OSR	2,000 1,680	384 1,210	192 1,382		\$ 31.60 \$ 200.62	\$ 425.00 \$ 1,893.75			12.2 8.3
36	212	15	S 34 P F 2 (MAG)	F42EE	72		SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382		\$ 200.62		·		8.3
36	2nd Floor Maintenance Closet	1	S 34 P F 2 (MAG)	F42EE	72	0.1	SW	1000	72	1	C 28 P F 2	F42SSILL	48	0.0	OSR	250	12	60	0.0	\$ 9.39	\$ 256.25	\$ 45	27.3	22.5
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
36 36	2nd Floor Girl's Bathroom 210	<u>4</u> 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72		SW SW	2000 2400	576 2,592	<u>4</u> 15	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.2	N/A OSR	2,000	384 1,210	192 1,382		\$ 31.60 \$ 200.62	\$ 425.00 \$ 1,893.75	т -	13.5 9.4	12.2 8.3
36	208	15	S 34 P F 2 (MAG)	F42EE	72		SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382		\$ 200.62	\$ 1,893.75		9.4	8.3
36	206	15	S 34 P F 2 (MAG)	F42EE	72		SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382		\$ 200.62	\$ 1,893.75		9.4	8.3
36 70	204A Periodical Room	<u>2</u> 4	S 34 P F 2 (MAG) 2T 32 R F 2 (u) (ELE)	F42EE FU2ILL	72 59		SW SW	2400 2400	346 566	<u>2</u> 4	C 28 P F 2 2T 32 R F 2 (u) (ELI	F42SSILL FU2ILL	48 59	0.1 0.2	OSR OSR	1,680 1,680	161 396	184 170		\$ 26.75 \$ 21.07	\$ 362.50 \$ 150.00	•	13.6 7.1	11.5 5.5
36	204	15	S 34 P F 2 (MAG)	F42EE	72		SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382		\$ 200.62	\$ 1,893.75	\$ 220	9.4	8.3
36 42	202 Media Center	15 25	S 34 P F 2 (MAG) T 34 R F 3 (MAG)	F42EE F43EE	72 115	1.1 2.9	SW SW	2400 2400	2,592 6,900	15 25	C 28 P F 2 1B 28	F42SSILL F43SSILL	48 72	0.7 1.8	OSR OSR	1,680 1,680	1,210 3,024	1,382 3,876		\$ 200.62 \$ 567.83	\$ 1,893.75 \$ 2,968.75	т -		8.3 4.6
36	Media Center Office	4	S 34 P F 2 (MAG)	F42EE	72		SW	2400	691	4	C 28 P F 2	F42SSILL	48	0.2	OSR	1,500	288	403		\$ 57.78				8.7
36	Media Center Conference Room	6	S 34 P F 2 (MAG)	F42EE	72	0.4	SW	2400	1,037	6	C 28 P F 2	F42SSILL	48	0.3	OSR	1,500	432	605		\$ 86.68	\$ 787.50	\$ 95	9.1	8.0
36 36	Media Center Storage PC Lab	1 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72		SW SW	1000 2400	72 2,592	1 15	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.0	OSR OSR	250 1.680	12 1,210	60 1,382		\$ 9.39 \$ 200.62	\$ 256.25 \$ 1,893.75			22.5 8.3
36	203	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15 15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382		\$ 200.62	\$ 1,893.75	\$ 220	9.4	8.3
70	2nd Floor Hallway	50	2T 32 R F 2 (u) (ELE)	FU2ILL	59	3.0	SW	2280	6,726	50	2T 32 R F 2 (u) (ELI	FU2ILL	59	3.0	N/A	2,280	6,726	-	0.0	\$ -	\$ -	\$ -		
36	205A	6	S 34 P F 2 (MAG)	F42EE	72		SW	2400	1,037	6	C 28 P F 2	F42SSILL	48	0.3	OSR	1,680	484	553	1	\$ 80.25	\$ 937.50			10.1
36	205	15	S 34 P F 2 (MAG)	F42EE	72	1.1	SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382		\$ 200.62	\$ 1,893.75		9.4	8.3
36 36	207 209	15 15	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72	1.1	SW SW	2400 2400	2,592 2,592	15 15	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.7 0.7	OSR OSR	1,680 1,680	1,210 1,210	1,382 1,382		\$ 200.62 \$ 200.62	\$ 1,893.75 \$ 1,893.75	\$ 220 \$ 220	9.4 9.4	8.3 8.3
36	211	15	S 34 P F 2 (MAG)	F42EE	72		SW	2400	2,592	15	C 28 P F 2	F42SSILL	48	0.7	OSR	1,680	1,210	1,382		\$ 200.62	+ /	•		8.3
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46		\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
36	2nd Floor Girl's Bathroom	4	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72		SW SW	2000	576	4	C 28 P F 2	F42SSILL	48	0.2	N/A	2,000	384	192		\$ 31.60	\$ 425.00	•	13.5	12.2
36 36	Maintenance Room 213	10	S 34 P F 2 (MAG)	F42EE F42EE	72 72		SW	1000 2400	72 1,728	10	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.0 0.5	OSR OSR	1,680	12 806	60 922		\$ 9.39 \$ 133.75	\$ 256.25 \$ 1,362.50	•	27.3 10.2	22.5 8.9
24	Entrance	1	W 20 C F 2	F22SS	56	0.1	SW	2000	112	1	W 17 W C 2	F22ILL	33	0.0	N/A	2,000	66	46	0.0	\$ 7.57	\$ 101.25	\$ 10	13.4	12.1
36	2nd Floor Boy's Bathroom	4	S 34 P F 2 (MAG)	F42EE	72		SW	2000	576	4	C 28 P F 2	F42SSILL	48	0.2	N/A	2,000	384	192		\$ 31.60		·	13.5	12.2
36 36	215 217	15 18	S 34 P F 2 (MAG) S 34 P F 2 (MAG)	F42EE F42EE	72 72		SW SW	2400 2400	2,592 3,110	15 18	C 28 P F 2 C 28 P F 2	F42SSILL F42SSILL	48 48	0.7 0.9	OSR OSR	1,680 1,680	1,210 1,452	1,382 1,659			\$ 1,893.75 \$ 2,212.50			8.3 8.2
82	Exterior	22	WP100 I 2	i100/2	200	4.4	BR	4368	19,219	22	13W LED WP	WPLED13/1	13	0.9	N/A	4,368	1,249	17,970	4.1	\$ 2,562.00	\$ 7,974.45	\$ -	3.1	3.1
108	Exterior	7	100W Mercury Vapor	MV100/1		0.9	BR	4368	3,822	7	FXLED39	FXLED39/1	39	0.3	N/A	4,368	1,192	2,630		•	\$ 4,238.33		11.3	11.3
96 75	Exterior Exterior	11 4	175 MH POLE HPS 150	MH175/1 HPS150/1	188	2.4 0.8	BR BR	4368 4368	10,330 3,285	11 4	52W LED Pole Ligh FXLED39	ALED52/1 FXLED39/1	52 39	0.6 0.2	N/A N/A	4,368 4,368	2,498 681	7,832 2,603			\$ 8,409.11 \$ 2,421.90		7.5 6.5	7.5 6.5
	Total	925				77.9			194,714	921				48.6		,- 20	86,303		29.2	16,138	131,436	\$13,800		
																		d Savings Savings		29.2 108,411	\$2,373 \$13,443			<del></del>
																	- KWh						_	1

### **APPENDIX D**

# New Jersey Pay For Performance Incentive Program

About Us | Press Room | Library | FAQs | Calendar | Newsletters | (

AND COOK GOVERNMENT HOME RESIDENTIAL RENEWABL

### COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

**PROGRAMS** 

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

**EXISTING BUILDINGS** 

PARTICIPATION STEPS

APPLICATIONS AND FORMS

APPROVED PARTNERS

**NEW CONSTRUCTION** 

FAQS

**BECOME A PARTNER** 

**COMBINED HEAT & POWER AND FUEL CELLS** 

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PILOT

**ENERGY SAVINGS IMPROVEMENT** PLAN

DIRECT INSTALL

ARRA

**ENERGY BENCHMARKING** 

OIL, PROPANE & MUNICIPAL **ELECTRIC CUSTOMERS** 

TEACH

**EDA PROGRAMS** 

**TECHNOLOGIES** 

**TOOLS AND RESOURCES** 

PROGRAM UPDATES

Home » Commercial & Industrial » Programs » Pay for Performance

### Pay for Performance - Existing Buildings

Download program applications and incentive forms.

#### The Greater the Savings, the Greater Your Incentives

Take a comprehensive, whole-building approach to saving energy in your existing facilities and eam incentives that are directly linked to your savings. Pay for Performance relies on a network of

> program partners who provide technical services under direct contract to you. Acting as your energy expert, your partner will develop an energy reduction plan for each project with a whole-building technical component of a traditional energy audit, a financial plan for funding the energy efficient measures and a construction schedule for installation.

### Eligibility

Existing commercial, industrial and institutional buildings with a peak demand over 100 kW for any of the preceding twelve months are eligible to participate including hotels and casinos, large office buildings, multifamily buildings, supermarkets, manufacturing facilities, schools, shopping malls and restaurants. Buildings that fall into the following five customer classes are not required to meet the 100 kW demand in order

to participate in the program: hospitals, public colleges and universities, 501(c)(3) non-profits, affordable multifamily housing, and local governmental entities. Your energy reduction plan must define a comprehensive package of measures capable of reducing the existing energy consumption of your building by 15% or more.

Exceptions to the 15% threshold requirement may be made for certain industrial, manufacturing, water treatment and datacenter building types whose annual energy consumption is heavily weighted on process loads. Details are available in the high energy intensity section of the FAQ

### **ENERGY STAR Portfolio Manager**

Pay for Performance takes advantage of the ENERGY STAR Program with Portfolio Manager, EPA's interactive tool that allows facility managers to track and evaluate energy and water consumption across all of their buildings. The tool provides the opportunity to load in the characteristics and energy usage of your buildings and determine an energy performance benchmark score. You can then assess energy management goals over time, identify strategic opportunities for savings, and receive EPA recognition for superior energy performance.

This rating system assesses building performance by tracking and scoring energy use in your facilities and comparing it to similar buildings. That can be a big help in locating opportunities for cost-justified energy efficiency upgrades. And, based on our findings, you may be invited to participate in the Building Performance with ENERGY STAR initiative and receive special recognition as an industry leader in energy efficiency.

#### Incentives

Pay for Performance incentives are awarded upon the satisfactory completion of three program milestones:

Incentive #1 - Submittal of complete energy reduction plan prepared by an approved program partner - Contingent on moving forward, incentives will be between \$5,000 and \$50,000 based on approximately \$.10 per square foot, not to exceed 50% of the facility's annual energy expense.

Incentive #2 - Installation of recommended measures -Incentives are based on the projected level of electricity and natural gas savings resulting from the installation of comprehensive energy-efficiency measures.

Incentive #3 - Completion of Post-Construction Benchmarking Report - A completed report verifying energy reductions based on one year of post-

implementation results. Incentives for electricity and natural gas savings will be paid based on actual savings, provided that the minimum performance threshold of 15% savings has been achieved

Program


Large Scale CHI Program Annour

2012 Large Ene Announcement

Economic Devel Introduces Revo Pay for Performa

Incentives Now. Screw-in Lamps

Other updates pos







Follow Us:

CONTACT US

A detailed Incentive Structure document is available on the applications and forms page.

### **Energy Efficiency Revolving Loan Fund (EE RLF)**

New Jersey-based commercial, institutional or industrial entities (including 501(c)(3) organizations) that have received an approved energy reduction plan under Pay for Performance may be eligible for supplemental financing through the EE RLF. The financing, in the form of low-interest loans, can be used to support up to 80% of total eligible project costs, not to exceed \$2.5 million or 100% of total eligible project costs from all public state funding sources. Visit the NJ EDA website for details.

### Steps to Participation

Click here for a step-by-step description of the program.

Home | Residential | Commercial & Industrial | Renewable Energy
About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site Map







# 2012 PAY FOR PERFORMANCE PROGRAM Existing Buildings Incentive Structure

### Incentive #1: Energy Reduction Plan

Incentive Amount:.....\$0.10 per sq ft

Minimum Incentive:......\$5,000

This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP) and is paid upon ERP approval. Incentive is contingent on implementation of recommended measures outlined in the ERP.

### **Incentive #2: Installation of Recommended Measures**

Minimum Performance Target:.....15%

### **Electric Incentives**

## Base Incentive based on 15% savings:.....\$0.09 per projected kWh saved For each % over 15% add:......\$0.005 per projected kWh saved Maximum Incentive:......\$0.11 per projected kWh saved

### **Gas Incentives**

Base Incentive based on 15% savings:	\$0.90 per projected Therm save	ed
For each % over 15% add:	\$0.05 per projected Therm save	d
Maximum Incentive:	\$1.25 per projected Therm save	ed

Incentive Cap: ......25% of total project cost

This incentive is based on projected energy savings outlined in the ERP. Incentive is paid upon successful installation of recommended measures.

### **Incentive #3: Post-Construction Benchmarking Report**

Minimum Performance Target:.....15%

### **Electric Incentives**

## Base Incentive based on 15% savings:.....\$0.09 per actual kWh saved For each % over 15% add:.....\$0.005 per actual kWh saved Maximum Incentive:.....\$0.11 per actual kWh saved

### **Gas Incentives**

Base Incentive based on 15% sa	avings:\$0.90 per actual Therm saved
For each % over 15% add:	\$0.05 per actual Therm saved
Maximum Incentive	\$1.25 per actual Therm saved

Incentive Cap: ......25% of total project cost

This incentive will be released upon submittal of a Post-Construction Benchmarking Report that verifies that the level of savings actually achieved by the installed measures meets or exceeds the minimum performance threshold. To validate the savings and achievement of the Energy Target, the EPA Portfolio Manager shall be used. Savings should be rounded to the nearest percent. Total value of Incentive #2 and Incentive #3 may not exceed 50% of the total project cost. Incentives will be limited to \$1 million per gas and electric account per building; maximum of \$2 million per project. See Participation Agreement for details.

### New Jersey Pay For Performance Incentive Program

**Note:** The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012. Building must have a minimum average electric demand of 100 kW. This minimum is waived for buildings owned by local governments or non-profit organizations.

Values used in this calculation are for measures with a positive return on investment (ROI) only.

Total Building Area (Square Feet)	72,000
Is this audit funded by NJ BPU (Y/N)	Yes

Incentive	e #1	
Audit is funded by NJ BF	\$0.10	\$/sqft

Board of Public Utilites (BPU)

	Annua	Utilities		
	kWh	Therms		
Existing Cost (from utility)	\$386,100	\$32,745		
Existing Usage (from utility)	386,100	32,745		
Proposed Savings	146,811	2,092		
Existing Total MMBtus	4,	592		
Proposed Savings MMBtus	7	'10		
% Energy Reduction	15	5.5%		
Proposed Annual Savings	\$24,700			

	Min (Savi	ngs = 15%)	Increas	se (Savings >	Max Ince	ntive	Achi	ieved
	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm
Incentive #2	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.09	\$0.92
Incentive #3	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.09	\$0.92

	l	ncentives \$	
	Elec	Gas	Total
Incentive #1	\$0	\$0	\$7,200
Incentive #2	\$13,556	\$1,932	\$15,488
Incentive #3	\$13,556	\$1,932	\$15,488
Total All Incentives	\$27,112	\$3,864	\$38,176

Total Project Cost	\$171,742

		Allowable		
		Incentive		
% Incentives #1 of Utility Cost*	1.7%	\$7,200		
% Incentives #2 of Project Cost**	9.0%	\$15,488		
% Incentives #3 of Project Cost**	9.0%	\$15,488		
Total Eligible Incentives***	\$38,176			
Project Cost w/ Incentives	\$133,566			

Project Payb	ack (years)
w/o Incentives	w/ Incentives
7.0	5.4

<sup>\*</sup> Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

Maximum allowable amount of Incentive #3 is 25% of total project cost.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

<sup>\*\*</sup> Maximum allowable amount of Incentive #2 is 25% of total project cost.

 $<sup>^{\</sup>star\star\star}$  Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

### APPENDIX E

**Energy Savings Improvement Plan (ESIP)** 



### Your Power to Save At Home, for Business, and for the Future

HOME RESIDENTIAL COMMERCIAL, INDUSTRIAL RENEWABLE ENERGY





### COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

- **PROGRAMS** 
  - NJ SMARTSTART BUILDINGS
  - PAY FOR PERFORMANCE
  - COMBINED HEAT & POWER AND FUEL CELLS
  - LOCAL GOVERNMENT ENERGY

LARGE ENERGY USERS PILOT

ENERGY SAVINGS IMPROVEMENT PLAN

DIRECT INSTALL

**ENERGY BENCHMARKING** 

T-12 SCHOOLS LIGHTING INITIATIVE

OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS

EDA PROGRAMS

- **TEACH**
- **►** ARRA
- **TECHNOLOGIES**
- TOOLS AND RESOURCES

PROGRAM UPDATES

**CONTACT US** 

Home » Commercial & Industrial » Programs

### **Energy Savings Improvement Plan**

A new State law allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the "Energy Savings Improvement Program" (ESIP), provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

This Local Finance Notice outlines how local governments can develop and implement an ESIP for their facilities. Below are two sample RFPs:

- Local Government
- School Districts (K-12)

The Board also adopted protocols to measure energy savings.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Local units considering an ESIP should carefully review the Local Finance Notice, the law, and consult with qualified professionals to determine how they should approach the task.

### FIRST STEP - ENERGY AUDIT

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. As explained in the Local Finance Notice, this may be done internally if an agency has qualified staff to conduct the audit. If not, the audit must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach - and it's free. **Incentives provide 100% of the cost of the audit.** 

### **ENERGY REDUCTION PLANS**

If you have an ESIP plan you would like to submit to the Board of Public Utilities, please email it to ESIP@bpu.state.nj.us. Please limit the file size to 3MB (or break it into smaller files).

- Frankford Township School District
- Northern Hunterdon-Voorhees Regional High School
- Manalapan Township (180 MB Right Click, Save As)

### **Program Updates**

- Board Order Standby Charges for Distributed Generation Customers
- T-12 Schools Lighting Replacement Initiative - Funding Allocation Reached

Other updates posted.

**Featured Success Story** 

### Rutgers University:

Continued
Commitment to
Saving Energy





Follow Us:



Home | Residential | Commercial & Industrial | Renewable Energy
About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site Map

### **APPENDIX F**

### Photovoltaic (PV) Rooftop Solar Power Generation

### **Pompton Lakes Public School Lakeside Middle School**

Cost of Electricity \$0.149 /kWh Electricity Usage 386,100 kWh/yr System Unit Cost \$4,000 /kW

### Photovoltaic (PV) Solar Power Generation - Screening Assessment

Budgetary		Annual Utility S	avings		Estimated	Total	Federal Tax	New Jersey Renewable	Payback (without	Payback (with
Cost					Maintenance	Savings	Credit	** SREC	incentive)	incentive)
					Savings					
\$	kW	kWh	therms	\$	\$	\$	\$	\$	Years	Years
\$840,000	210.0	273,700	0	\$40,781	0	\$40,781	\$0	\$16,422	20.6	14.7

<sup>\*\*</sup> Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$60 /1000kwh

**Area Output\*** 

3,383 m2

36,416 ft2

**Perimeter Output\*** 

<mark>167</mark> m 547 ft

**Available Roof Space for PV:** 

(Area Output - 10 ft x Perimeter) x 85%

26,302 ft2

**Approximate System Size:** 

Is the roof flat? (Yes/No) Yes

watt/ft2 210,417 DC watts

> 210 kW Enter into PV Watts

**PV Watts Inputs\*** 

Enter into PV Watts (always 20 if flat, if Array Tilt Angle pitched - enter estimated roof angle) 20 Array Azimuth Enter into PV Watts (default) 180 Zip Code 07442 Enter into PV Watts DC/AC Derate Factor Enter info PV Watts 0.83

**PV Watts Output** 

273,700 annual kWh calculated in PV Watts program

% Offset Calc

386,100 (from utilities) Usage


PV Generation 273,700 (generated using PV Watts)

% offset 71%

http://www.freemaptools.com/area-calculator.htm

http://www.flettexchange.com

http://gisatnrel.nrel.gov/PVWatts\_Viewer/index.html





# AC Energy & Cost Savings



(Type comments here to appear on printout; maximum 1 row of 90 characters.)

1>

Station Identification	cation 0268370		Sola
State:	New Jersey	Month	Radiat
Latitude:	40.9 ° N		1
Longitude:	74.2 ° W	2	
PV System Specifications	ns	ω	
DC Rating:	210.0 kW	4	5 64
DC to AC Derate Factor:	0.830	J.	
AC Rating:	174.3 kW	6	
Array Type:	Fixed Tilt	7	
Array Tilt:	20.0 °	8	
Array Azimuth:	180.0°	9	
<b>Energy Specifications</b>	Š	10	
Cost of Electricity:	17.2 ¢/kWh	=	
		12	

Year	12	11	10	9	8	7	6	5	4	3	2	_	Month	
4.54	2.46	2.82	4.14	5.04	5.55	5.87	6.32	5.93	5.28	4.83	3.47	2.65	Solar Radiation (kWh/m²/day)	H
273700	13379	14343	21357	24287	27133	28501	30280	30156	26431	25786	17375	14671	AC Energy (kWh)	Results
47076.40	2301.19	2467.00	3673.40	4177.36	4666.88	4902.17	5208.16	5186.83	4546.13	4435.19	2988.50	2523.41	Energy Value (\$)	

# APPENDIX G EPA Portfolio Manager



### STATEMENT OF ENERGY PERFORMANCE Lakeside Middle School

**Building ID: 3310460** 

For 12-month Period Ending: August 31, 20121

Date SEP becomes ineligible: N/A

Date SEP Generated: November 16, 2012

**Facility** Lakeside Middle School 316 Lakeside Avenue Pompton Lakes, NJ 07442 **Facility Owner** N/A

**Primary Contact for this Facility** 

Year Built: 1968

Gross Floor Area (ft2): 38,105

Energy Performance Rating<sup>2</sup> (1-100) 17

Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu) 1,317,373 3,274,500 Natural Gas (kBtu)4 Total Energy (kBtu) 4,591,873

Energy Intensity<sup>4</sup>

Site (kBtu/ft²/yr) 121 Source (kBtu/ft²/yr) 205

Emissions (based on site energy use) Greenhouse Gas Emissions (MtCO2e/year) 361

**Electric Distribution Utility** 

Jersey Central Power & Light Co [FirstEnergy Corp]

**National Median Comparison** 

National Median Site EUI 87 National Median Source EUI 149 % Difference from National Median Source EUI 38% **Building Type** K-12 School Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

Meets Industry Standards<sup>5</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality N/A Acceptable Thermal Environmental Conditions N/A Adequate Illumination N/A Certifying Professional N/A

- 1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA. 2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.

- 2. The EFA Energy retromation rounding 15 based on the second state of the EFA Energy retromation annualized to a 12-month period.

  4. Values represent energy intensity, annualized to a 12-month period.

  5. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

The government estimates the average time needed to fill out this form is 6 hours (includes the time for entering energy data, Licensed Professional facility inspection, and notarizing the SEP) and welcomes suggestions for reducing this level of effort. Send comments (referencing OMB control number) to the Director, Collection Strategies Division, U.S., EPA (2822T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) or a Registered Architect (RA) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE or RA in double-checking the information that the building owner or operator has entered into Portfolio Manager.

Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.

NOTE: You must check each box to indicate that each value is correct, OR include a note.

VALUE AS ENTERED IN

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	$\overline{\mathbf{V}}$
Building Name	Lakeside Middle School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		
Туре	K-12 School	Is this an accurate description of the space in question?		
Location	316 Lakeside Avenue, Pompton Lakes, NJ 07442	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		
Single Structure	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of a hospital, k-12 school, hotel and senior care facility) nor can they be submitted as representing only a portion of a building.		
Lakeside Middle Scho				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	$\overline{\mathbf{V}}$
Gross Floor Area	38,105 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		
Open Weekends?	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		
Number of PCs	100	Is this the number of personal computers in the K12 School?		
Number of walk-in refrigeration/freezer units	1	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		
Presence of cooking facilities	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		
Percent Cooled	30 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		
Percent Heated	100 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		
Months	10(Optional)	Is this school in operation for at least 8 months of the year?		

High School?	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		
--------------	----	--	--	--

# ENERGY STAR® Data Checklist for Commercial Buildings

### **Energy Consumption**

Power Generation Plant or Distribution Utility: Jersey Central Power & Light Co [FirstEnergy Corp]

Me	ter: Electric Meter (kWh (thousand Watt-h Space(s): Entire Facility Generation Method: Grid Purchase	ours))
Start Date	End Date	Energy Use (kWh (thousand Watt-hours)
08/01/2012	08/31/2012	31,560.00
07/01/2012	07/31/2012	17,160.00
06/01/2012	06/30/2012	25,860.00
05/01/2012	05/31/2012	34,560.00
04/01/2012	04/30/2012	34,080.00
03/01/2012	03/31/2012	39,240.00
02/01/2012	02/29/2012	43,800.00
01/01/2012	01/31/2012	35,040.00
12/01/2011	12/31/2011	39,000.00
11/01/2011	11/30/2011	26,040.00
10/01/2011	10/31/2011	26,040.00
09/01/2011	09/30/2011	33,720.00
lectric Meter Consumption (kWh (thousan	386,100.00	
lectric Meter Consumption (kBtu (thousan	1,317,373.20	
otal Electricity (Grid Purchase) Consumpt	ion (kBtu (thousand Btu))	1,317,373.20
s this the total Electricity (Grid Purchase) o		1,317,373.20
s this the total Electricity (Grid Purchase) c Electricity meters?		1,317,373.20
Total Electricity (Grid Purchase) Consumptions this the total Electricity (Grid Purchase) of Electricity meters?  Fuel Type: Natural Gas		1,317,373.20
s this the total Electricity (Grid Purchase) c Electricity meters?	consumption at this building including all  Meter: Natural Gas (therms)	1,317,373.20  Energy Use (therms)
s this the total Electricity (Grid Purchase) of Electricity meters?  Fuel Type: Natural Gas	Meter: Natural Gas (therms) Space(s): Entire Facility	
s this the total Electricity (Grid Purchase) of Electricity meters?  Fuel Type: Natural Gas  Start Date	Meter: Natural Gas (therms) Space(s): Entire Facility End Date	Energy Use (therms)
s this the total Electricity (Grid Purchase) of Electricity meters?  Fuel Type: Natural Gas  Start Date  08/01/2012	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  08/31/2012	Energy Use (therms) 102.00
s this the total Electricity (Grid Purchase) of Electricity meters?  Fuel Type: Natural Gas  Start Date  08/01/2012  07/01/2012	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  08/31/2012  07/31/2012	Energy Use (therms) 102.00 90.00
s this the total Electricity (Grid Purchase) of Electricity meters?  Fuel Type: Natural Gas  Start Date  08/01/2012  07/01/2012	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  08/31/2012  07/31/2012  06/30/2012	Energy Use (therms) 102.00 90.00 116.00
s this the total Electricity (Grid Purchase) of Electricity meters?  Fuel Type: Natural Gas  Start Date  08/01/2012  07/01/2012  06/01/2012  05/01/2012	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  08/31/2012  06/30/2012  05/31/2012	Energy Use (therms) 102.00 90.00 116.00 200.00
s this the total Electricity (Grid Purchase) of Electricity meters?  Start Date  08/01/2012  07/01/2012  05/01/2012  04/01/2012	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  08/31/2012  07/31/2012  06/30/2012  05/31/2012  04/30/2012	Energy Use (therms)  102.00  90.00  116.00  200.00  2,581.00
Start Date  08/01/2012  05/01/2012  04/01/2012  03/01/2012	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  08/31/2012  07/31/2012  06/30/2012  05/31/2012  04/30/2012  03/31/2012	Energy Use (therms)  102.00  90.00  116.00  200.00  2,581.00  3,231.00
Start Date  08/01/2012  06/01/2012  04/01/2012  03/01/2012  02/01/2012	Meter: Natural Gas (therms) Space(s): Entire Facility  End Date  08/31/2012  07/31/2012  06/30/2012  05/31/2012  04/30/2012  03/31/2012  02/29/2012	Energy Use (therms)  102.00  90.00  116.00  200.00  2,581.00  3,231.00  6,945.00

10/01/2011	10/31/2011	1,834.00
09/01/2011	09/30/2011	153.00
Natural Gas Consumption (therms)		32,745.00
Natural Gas Consumption (kBtu (thousand Btu	1))	3,274,500.00
Total Natural Gas Consumption (kBtu (thousar	nd Btu))	3,274,500.00
Is this the total Natural Gas consumption at th	is building including all Natural Gas meters?	
Additional Fuels		
Do the fuel consumption totals shown above repre- Please confirm there are no additional fuels (distric		
On-Site Solar and Wind Energy		
Do the fuel consumption totals shown above incluc your facility? Please confirm that no on-site solar o list. All on-site systems must be reported.		
Certifying Professional (When applying for the ENERGY STAR, the Certify	ying Professional must be the same PE or RA tha	at signed and stamped the SEP.)
Name:	Date:	
Signature:		

### FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

Facility Lakeside Middle School 316 Lakeside Avenue Pompton Lakes, NJ 07442 Facility Owner

Primary Contact for this Facility N/A

#### **General Information**

Lakeside Middle School	
Gross Floor Area Excluding Parking: (ft²)	38,105
Year Built	1968
For 12-month Evaluation Period Ending Date:	August 31, 2012

**Facility Space Use Summary** 

racinty opace ose outlinary							
Lakeside Middle School							
Space Type	K-12 School						
Gross Floor Area (ft²)	38,105						
Open Weekends?	No						
Number of PCs	100						
Number of walk-in refrigeration/freezer units	1						
Presence of cooking facilities	Yes						
Percent Cooled	30						
Percent Heated	100						
Months °	10						
High School?	No						
School District °	Pompton Lakes						

**Energy Performance Comparison** 

	Evaluatio	n Periods	Comparisons					
Performance Metrics	Current (Ending Date 08/31/2012)	Baseline (Ending Date 07/31/2012)	Rating of 75	Target	National Median			
Energy Performance Rating	17	14	75	N/A	50			
Energy Intensity								
Site (kBtu/ft²)	121	128	68	N/A	87			
Source (kBtu/ft²)	205	212	116	N/A	149			
Energy Cost								
\$/year	\$ 93,242.67	\$ 93,459.92	\$ 52,753.18	N/A	\$ 67,461.86			
\$/ft²/year	\$ 2.45	\$ 2.45	\$ 1.39	N/A	\$ 1.77			
Greenhouse Gas Emissions								
MtCO <sub>2</sub> e/year	361	375	204	N/A	261			
kgCO <sub>2</sub> e/ft²/year	9	10	5	N/A	7			

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Median column presents energy performance data your building would have if your building had a median rating of 50.

### Notes:

- o This attribute is optional.
- d A default value has been supplied by Portfolio Manager.