




# Local Government Energy Audit: Combined Heat and Power Plant Evaluation



Copyright ©2017 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

**Ocean County College**

One College Drive

Toms River, New Jersey

March 14, 2017

Report by:

**TRC Energy Services**

## Disclaimer

---

The intent of this report is to identify energy savings opportunities and operational enhancement associated with the facility's combined heat and power plant. Approximate savings are included in this report to make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. It should be noted that detailed design efforts are required in order to implement several of the improvements evaluated as part of this analysis.

The energy savings opportunities and estimates of energy consumption contained in this report have been reviewed for technical accuracy. However, all estimates contained herein of energy consumption at the site are not guaranteed, because energy consumption ultimately depends on behavioral factors, the weather, and many other uncontrollable variables. The energy assessor and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy consumption vary from the estimated consumption shown herein.

Estimated installation costs are based on a variety of sources, including our own experience at similar facilities, our own pricing research using local contractors and vendors, and cost estimating handbooks such as those provided by RS Means. The cost estimates represent our best judgment for the proposed action. The Owner is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for a particular installation, and for conditions which cannot be known prior to in-depth investigation and design, the energy assessor does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates and are based on program information available at the time this report is written. The NJBPU reserves the right to extend, modify, or terminate programs without prior or further notice, including incentive levels and eligibility requirements. The Owner should review available program incentives and requirements prior to selecting and/or installing any recommended measures.

# Table of Contents

---

<b>Introduction .....</b>	<b>4</b>
<b>Evaluated Modes of Operation .....</b>	<b>4</b>
Utility – No Cogeneration .....	4
Existing Cogeneration Plant Configuration and Operation .....	4
Existing Cogeneration with Full Absorption Chiller Capacity .....	4
Simultaneous Chiller Operation.....	4
Existing Cogeneration Plant Configuration Heating Only .....	5
Heating Only Cogeneration Plant with New Heat Recovery .....	5
Existing Cogeneration Plant Configuration with Additional Generation .....	5
Additional Generation Cogeneration Plant Configuration with New Heat Recovery .....	5
<b>Results .....</b>	<b>6</b>
<b>Analysis Methodology .....</b>	<b>7</b>
Existing load profiles .....	7
Combined Heat and Power Model .....	8
Assumptions .....	9

Appendix A: CHP Model

## INTRODUCTION

---

The New Jersey Board of Public Utilities (NJBP) has sponsored a Local Government Energy Audit (LGEA) Report for Ocean County College (OCC). As part of the LGEA, TRC was enlisted to review the operation of the campus's new combined heat and power (CHP) plant. The CHP plant has had a history of operational issues that limited the benefit it could provide to campus. OCC requested that TRC provides an economic analysis of the CHP plant and central plant to help determine the optimal mode of operation.

The CHP plant is comprised of a Waukesha APG1000 reciprocating engine-generator and a Broad BHE85 single-stage absorption chiller. The central plant is comprised of three York YMC2 magnetic bearing variable speed chillers and four Aerco BMK 6000 condensing boilers.

## EVALUATED MODES OF OPERATION

---

TRC developed a model that simulates typical OCC demand for electricity, hot water, and chilled water throughout the day and the year. The performance of the CHP plant and central plant were overlaid atop the campus load profiles to simulate how the campus loads could be served. We evaluated the economics of seven modes of operation.

### Utility – No Cogeneration

This mode of operation establishes a baseline model where all electricity is provided by the utility, all hot water is provided by the condensing boiler plant, and all chilled water is provided by the electric centrifugal chillers. The energy consumption and cost of the model was tuned to align with historical utility bills.

### Existing Cogeneration Plant Configuration and Operation

This mode of operation mirrors the current plant configuration, equipment performance, and sequence of operations. As such:

- The absorption chiller and electric chillers are not allowed to operate simultaneously.
- The absorption chiller has a bias to produce chilled water whenever possible.
- The absorption chiller is limited to 43% of design capacity based on actual supplied exhaust and jacket water temperatures.
- The generator's electric output is restricted to maintain a 250 kW minimum import from the utility.

### Existing Cogeneration with Full Absorption Chiller Capacity

This the same as the existing cogeneration model, except, the plant performance limitations have been corrected and the equipment is capable of operating at full-load design conditions. All other models that use the absorption chiller assume it is capable of meeting design performance.

### Simultaneous Chiller Operation

Due to condenser water flow limitations, the absorption chiller and electric chillers cannot currently operate simultaneously. This model evaluates plant economics if both the CHP plant and central plant could produce chilled water simultaneously.

## **Existing Cogeneration Plant Configuration Heating Only**

This mode of operation evaluates if the CHP plant only produces hot water with the single-stage absorption chiller and all chilled water is produced by the electric chillers. It should be noted that the variable-speed magnetic-bearing electric chillers are very efficient at producing chilled water (0.582 kW/ton) and have excellent part load performance, while a single-stage absorption chiller is not very efficient at producing chilled water (2.32 kW/ton equivalent) and performs worse at part load.

## **Heating Only Cogeneration Plant with New Heat Recovery**

The existing absorption chiller is capable of taking exhaust and jacket water from the engine to produce hot water, however, since this is not its primary function, it is not very efficient at the process. Based on design drawings for the plant, the absorption chiller has an effective efficiency of 41.5% when converting engine waste heat into heating hot water. Task specific exhaust heat recovery systems are extremely effective at producing hot water with very little exhaust pressure drop.

This mode evaluates modifying the CHP plant to include a high-efficiency heat recovery system. We conservatively assume the new system would recover 80% (nearly double) of the same heat provided to the absorption chiller.

## **Existing Cogeneration Plant Configuration with Additional Generation**

This mode evaluates installing additional generation capacity, effectively increasing the electric output of the plant. The model assumes a new 200 kW peaking engine-generator is added to the plant and it has the same performance characteristics of the existing Waukesha.

## **Additional Generation Cogeneration Plant Configuration with New Heat Recovery**

This model evaluates installing the peaking engine-generator and the new high-efficiency heat recovery system, effectively increasing the electric and hot water output of the plant.

## RESULTS

Due to the high cost of electricity and low cost of natural gas, OCC saves significant money using the CHP plant. The table below summarizes the economics associated with optimizing the CHP plant.

### CHP Economic Analysis - Summary

	Utility (no cogen)	Existing Cogen (cooling bias)	Full ABS Cap (cooling bias)	Simultaneous Chillers	Heating only w/ ABS	Heating only w/ New HR	Existing Cogen Additional Gen	Add Gen w/ New HR
Annual Electricity (kWh/yr)	10,902,000	10,823,000	10,795,000	10,652,000	10,902,000	10,902,000	10,795,000	10,902,000
Utility Electricity (kWh/yr)	10,902,000	4,330,000	4,302,000	4,159,000	4,409,000	4,409,000	3,909,000	4,017,000
Annual Natural Gas (Th/yr)	217,000	755,000	722,000	732,000	696,000	662,000	767,000	706,000
	-	-	-	-	-	-	-	-
Electric Energy Cost	\$1,059,000	420,000	\$418,000	\$404,000	\$428,000	\$428,000	\$380,000	\$390,000
Demand Cost	\$126,000	\$66,000	\$66,000	\$66,000	\$66,000	\$66,000	\$66,000	\$66,000
Natural Gas Cost	\$168,000	\$585,000	\$559,000	\$567,000	\$538,000	\$512,000	\$593,000	\$547,000
Total Utility Cost	\$1,353,000	\$1,071,000	\$1,043,000	\$1,037,000	\$1,032,000	\$1,006,000	\$1,039,000	\$1,003,000
Savings (compared to existing)			\$28,000	\$34,000	\$39,000	\$65,000	\$32,000	\$68,000
Implementation Cost			\$50,000	\$50,000	\$0	\$300,000	\$200,000	\$500,000
Simple Payback (yrs)			1.8	1.5	0.0	4.6	6.3	7.4

The campus hot water load profile indicates there is a continuous demand for hot water. Using engine exhaust and jacket water to satisfy the campus heating load is the most efficient way to use the engine waste heat. Our analysis shows that using the existing magnetic bearing chillers to produce chilled water and installing a dedicated high-efficiency exhaust heat recovery system is the most expeditious way to optimize CHP plant performance. Ideally, the exhaust system could be modified to allow the absorption chiller to be used as a backup device. This recommendation is driven by the low efficiency of a single stage absorption chiller.

Note that that exhaust system back pressure is a critical system design element and further analysis should be performed to ensure modifications to the exhaust system will not negatively affect engine performance.

The campus electric load profile indicates there are times when the campus could make use of additional generation capacity. There are also times when a smaller generator could operate and provide benefit. Installing a smaller engine generator or microturbine adds versatility to plant operations. Just installing additional generation capacity provides some additional savings, but paring additional generation with a dedicated high-efficiency exhaust heat recovery system provides the best opportunity to maximize CHP plant performance.




# ANALYSIS METHODOLOGY



## Existing load profiles

Existing campus load profiles were developed for electricity, hot water, and chilled water. The load profiles are based extensively on hourly trend data and sequence of operations provided by the campus, equipment capacities, and historical weather data.

- The electrical load profile is based on the site’s JCP&L meter, Enernoc’s revenue meter, and the engine’s generation meter. The energy associated with the creation of chilled water was removed to facilitate the comparison of different modes of CHP operation.
- The hot water load profile is based on boiler plant trend data.
- The chilled water load profile is based on equipment capacity, site operational data, and 30-year average weather data. Chilled water trends were not available.

The data was compiled to create average daily load profiles for each month. Annual totals were compared against utility data to ensure reasonability.





### Combined Heat and Power Model

We created a model that compares the cost of operating the CHP in different modes of operation. The model is based primarily on the campus load profiles, equipment performance data, and sequences of operation. Each mode of operation follows an identical analysis process where we determine the operational and energy state of the campus for each *typical* hour of a *typical* day each month.

The following order of analysis is considered for each hour:

- 1) Cogen Operation – Based on the mode of operation, the engine is on or off.
- 2) Cogen Electric Output (kW) – We maximize generator output while accounting for the minimum engine load, maximum engine load, and minimum utility import.



- 3) Electric Utility Import (kW) – The difference between campus load and generator output. This does not include the energy required to operate the centrifugal chillers.
- 4) Cogen Fuel Purchase (kBtu/hr) – A generic engine performance curve was scaled to the full load performance of the campus's Waukesha AGP1000.
- 5) ABS Operation – Based on the mode of operation, the absorption chiller is heating, cooling, or off.
- 6) ABS Heat Output (kBtu/hr) – The full load heat output of the absorption chiller is scaled based on the engine the fuel flow.
- 7) Boiler Fuel Purchase (kBtu/hr) – The difference between campus load and absorption chiller hot water output. The efficiency of the boiler is used to convert from heat to fuel.
- 8) ABS Cooling Output (kBtu/hr) – The full load cooling output of the absorption chiller is scaled based on the engine the fuel flow.
- 9) Centrifugal Chiller Energy (tons) – The difference between campus load and absorption chiller chilled water output. This was converted to tons to make the next step easier.
- 10) Centrifugal Chiller Electricity (kW) – A performance curve for generic magnetic bearing chiller was scaled to the full load performance of the campus chillers (York YMC2). The load on the chiller plant is split amongst the fewest number of chillers.
- 11) Total Utility Electric Purchase (kW) – The sum of the utility import and chiller plant energy. This is a conservative approach that underestimates CHP generation potential.
- 12) Total Utility Natural Gas Purchase (kW) – The sum of natural gas used for the engine and the boiler plant.
- 13) Utility Cost – utility rates are applied based on rate schedules and historical rates.
- 14) Daily averages are extrapolated to monthly and yearly totals.

## Assumptions

The following is a list of key assumptions used in our analysis:

### Electric Load Profile

- Electric data was missing for March and December so average values from adjacent months were used.

### Chilled Water Load Profile

- The chilled water system is drained November through March.
- Below 55°F outside air temperature, chilled water is not required.
- The campus maximum chilled water demand is 475 tons.

### Utility Rates

- JCP&L General Service Primary for Transmission and Distribution
  - \$0.164143 per kWh (year round)
  - \$5.65 per maximum KW during June through September
  - \$5.23 per maximum KW during October through May
  - Included a \$0.07/kWh fee to tune rate schedule to historic bills
- Direct Energy for commodity: flat fee of \$0.07435 per kWh
- New Jersey Natural Gas Company General Service Large: 12-month ave. \$0.7446 /th

Reciprocating Engine-generator: Waukesha AGP1000

- Full load performance matches manufacturer’s data sheet.
- The engine’s part load performance follows a curved derived from multiple IC engines of similar sizes.
- The engine-generator has a minimum load of 750 kW.
- The campus has a 250 kW minimum import requirement.

Absorption Chiller: Broad BHE85

- Full load performance matches the Equipment Schedule drawing from Concord Engineering Group dated 9/29/10.
- Output is linear with engine fuel flow.
- Actual operation is based on the following conditions:

Design Exhaust In	776	°F
Actual Exhaust In	750	°F
Design Exhaust Out	320	°F
Actual Exhaust Heat	94%	
Design JW In	210	°F
Actual JW In	177	°F
Design JW Out	198	°F
Actual JW Heat	0%	
Actual ABS Capacity	43%	

Chillers: York YMC2

- Full load performance matches the Equipment Schedule drawing from Concord Engineering.
- The chillers part load performance follows a curved derived from similar magnetic bearing variable speed chillers.
- The chillers have a minimum speed of 20%.

Boilers: Aerco BMK 6000

- Full load performance matches the Equipment Schedule drawing from Concord Engineering.

## Appendix A: CHP Model

**Ocean County College**  
**CHP Economic Analysis - Summary**

	<b>Utility (no cogen)</b>	<b>Existing Cogen (cooling bias)</b>	<b>Full ABS Cap (cooling bias)</b>	<b>Simultaneous Chillers</b>	<b>Heating only w/ ABS</b>	<b>Heating only w/ New HR</b>	<b>Existing Cogen Additional Gen</b>	<b>Add Gen w/ New HR</b>
Annual Electricity (kWh/yr)	10,902,000	10,823,000	10,795,000	10,652,000	10,902,000	10,902,000	10,795,000	10,902,000
Utility Electricity (kWh/yr)	10,902,000	4,330,000	4,302,000	4,159,000	4,409,000	4,409,000	3,909,000	4,017,000
Annual Natural Gas (Th/yr)	217,000	755,000	722,000	732,000	696,000	662,000	767,000	706,000
	-	-	-	-	-	-	-	-
Electric Energy Cost	\$1,059,000	420,000	\$418,000	\$404,000	\$428,000	\$428,000	\$380,000	\$390,000
Demand Cost	\$126,000	\$66,000	\$66,000	\$66,000	\$66,000	\$66,000	\$66,000	\$66,000
Natural Gas Cost	\$168,000	\$585,000	\$559,000	\$567,000	\$538,000	\$512,000	\$593,000	\$547,000
<b>Total Utility Cost</b>	<b>\$1,353,000</b>	<b>\$1,071,000</b>	<b>\$1,043,000</b>	<b>\$1,037,000</b>	<b>\$1,032,000</b>	<b>\$1,006,000</b>	<b>\$1,039,000</b>	<b>\$1,003,000</b>

Ocean County College  
Existing Campus Load Profiles

Electricity - w/o Chillers																								
kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Month 1 Jan	840	786	783	774	771	781	975	1,073	1,104	1,125	1,137	1,139	1,147	1,144	1,134	1,116	1,113	1,129	1,153	1,124	1,080	1,042	1,021	929
2 Feb	812	762	760	751	749	771	970	1,057	1,102	1,156	1,202	1,210	1,209	1,210	1,202	1,184	1,169	1,154	1,166	1,167	1,134	1,080	1,039	929
3 Mar	760	708	705	695	689	748	909	964	1,009	1,102	1,169	1,197	1,206	1,212	1,209	1,197	1,180	1,159	1,144	1,119	1,095	1,042	989	883
4 Apr	708	653	649	638	629	724	847	871	916	1,023	1,106	1,150	1,164	1,176	1,178	1,173	1,163	1,164	1,121	1,071	1,055	1,003	939	836
5 May	926	875	868	881	868	955	1,110	1,128	1,170	1,269	1,333	1,355	1,385	1,374	1,385	1,382	1,380	1,367	1,340	1,308	1,306	1,273	1,198	1,059
6 Jun	967	932	923	912	904	1,042	1,267	1,279	1,345	1,440	1,498	1,529	1,555	1,558	1,535	1,546	1,547	1,546	1,522	1,503	1,484	1,441	1,372	1,149
7 Jul	1,074	1,055	1,052	1,046	1,041	1,173	1,441	1,435	1,484	1,558	1,596	1,583	1,591	1,601	1,630	1,636	1,647	1,634	1,618	1,572	1,561	1,535	1,481	1,269
8 Aug	1,056	1,031	1,020	1,011	1,001	1,168	1,490	1,451	1,492	1,580	1,635	1,641	1,676	1,674	1,706	1,726	1,724	1,702	1,638	1,612	1,625	1,587	1,513	1,287
9 Sep	1,017	999	988	979	970	1,108	1,394	1,410	1,448	1,538	1,627	1,642	1,660	1,660	1,672	1,689	1,677	1,667	1,636	1,599	1,612	1,544	1,459	1,240
10 Oct	909	880	871	857	841	958	1,169	1,206	1,226	1,301	1,383	1,435	1,459	1,475	1,493	1,498	1,490	1,464	1,449	1,436	1,417	1,343	1,251	1,071
11 Nov	811	767	771	764	762	909	1,072	1,091	1,137	1,222	1,206	1,345	1,387	1,409	1,399	1,411	1,398	1,368	1,328	1,260	1,238	1,179	1,114	947
12 Dec	826	777	777	769	767	845	1,024	1,082	1,121	1,174	1,172	1,242	1,267	1,277	1,267	1,264	1,256	1,249	1,241	1,192	1,159	1,111	1,068	938

HHW																								
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
Month 1 Jan	3,626	3,650	3,791	3,905	3,693	3,918	4,068	4,341	4,223	3,771	3,134	2,948	2,520	2,569	2,587	2,803	2,854	3,165	3,397	3,369	3,449	3,622	3,598	3,756
2 Feb	3,461	3,552	3,553	3,543	3,675	4,021	4,143	4,293	4,019	3,574	3,266	2,935	2,823	2,857	3,062	3,070	3,050	3,370	3,833	3,747	3,703	3,744	3,857	3,896
3 Mar	2,956	2,974	3,113	3,208	3,156	3,435	4,023	3,852	3,103	2,344	2,325	2,609	2,168	2,168	2,301	2,184	2,199	2,422	3,221	2,872	3,298	3,162	3,137	3,205
4 Apr	2,722	2,368	2,604	2,687	2,742	2,846	3,193	2,952	2,268	1,756	1,797	1,788	1,757	1,814	1,744	1,695	1,789	1,788	2,094	2,273	2,808	2,785	2,782	2,755
5 May	1,673	1,669	1,689	1,825	1,827	1,778	2,007	2,091	1,601	1,637	1,647	1,468	1,440	1,391	1,500	1,355	1,488	1,406	1,470	1,490	1,688	2,044	1,844	1,855
6 Jun	908	707	840	927	912	1,178	1,378	1,250	1,421	1,218	1,110	1,192	1,119	946	1,079	1,091	1,133	1,093	941	985	1,270	1,246	1,331	1,530
7 Jul	1,116	855	963	1,120	1,131	1,071	1,193	1,403	1,383	1,103	1,033	1,131	931	1,095	1,028	959	1,071	935	1,274	1,150	1,192	1,361	1,272	1,326
8 Aug	849	763	725	752	807	890	958	1,157	1,090	1,071	920	918	879	930	855	827	774	845	879	824	971	1,213	958	1,068
9 Sep	873	713	685	745	871	828	995	1,251	1,408	1,075	966	947	1,067	965	842	864	888	967	1,047	1,062	1,146	1,212	1,229	1,318
10 Oct	1,610	1,569	1,620	1,813	1,762	1,747	2,142	2,468	2,165	1,725	1,255	1,194	1,193	1,306	1,384	1,234	1,466	1,361	1,498	2,190	1,920	1,881	2,014	2,031
11 Nov	1,719	1,810	1,867	2,016	1,808	2,255	2,747	2,675	2,045	948	575	458	257	264	351	552	540	748	1,143	1,325	1,171	1,388	1,684	1,901
12 Dec	2,673	2,730	2,829	2,961	2,751	3,087	3,408	3,508	3,134	2,360	1,855	1,703	1,389	1,417	1,469	1,678	1,697	1,957	2,270	2,347	2,310	2,505	2,641	2,829











**Ocean County College**  
**CHP Economic Analysis - No CHP Operation**

---

Annual Electricity	10,902,396 kWh/yr	\$0.1758 / kWh
Utility Electricity	10,902,396 kWh/yr	\$0.1758 / kWh
Annual Natural Gas	184,428.71 Th/yr	\$0.7446 / Th
Electric Energy Cost	\$ 1,789,551.99 /yr	
Demand Cost (Jun-Sep)	\$ 44,431.60 /yr	
Demand Cost (Oct- May)	\$ 82,257.44 /yr	
Natural Gas Cost	\$ 137,324.08 /yr	
<b>Total Utility Cost</b>	<b>\$ 2,053,565.11 /yr</b>	







Ocean County College

CHP Economic Analysis - Existing Cogen with ABS Cooling Bias (ABS limited capacity, can not run ABS and Centrif)

---

Annual Electricity	10,822,796	kWh/yr	\$0.0450 / kWh
Utility Electricity	4,329,626	kWh/yr	\$0.1125 /kWh
Annual Natural Gas	755,459.11	Th/yr	\$0.7740 / Th
Electric Energy Cost	\$ 420,419.67	/yr	
Demand Cost (Jun-Sep)	\$ 23,413.60	/yr	
Demand Cost (Oct- May)	\$ 43,346.24	/yr	
Natural Gas Cost	\$ 584,725.35	/yr	
Total Utilty Cost	\$ 1,071,904.86	/yr	







Ocean County College  
CHP Economic Analysis - Existing Cogen with Full ABS Capacity (ABS Cooling Bias and can not run ABS and Centrif)

Centrifugal Chiller Energy tons. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 0 to 439.

Centrifugal Chiller Electricity kW. Minimum chiller load = 20%. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 0 to 217.

Total Utility Electric Purchase kW. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 812 to 938.

Summary table for Total Utility Electric Purchase with columns: Max, per day, per month. Values range from 975 to 938.

Total Utility Natural Gas Purchase kBtu/hr. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 4,615 to 3,600.

Summary table for Total Utility Natural Gas Purchase with columns: per day, per month. Values range from 207,143 to 189,015.

Ocean County College

CHP Economic Analysis - Existing Cogen with Full ABS Capacity (ABS Cooling Bias and can not run ABS and Centrif)

---

Annual Electricity	10,794,820	kWh/yr	\$0.0449 / kWh
Utility Electricity	4,301,650	kWh/yr	\$0.1126 /kWh
Annual Natural Gas	722,236.20	Th/yr	\$0.7740 / Th
Electric Energy Cost	\$ 417,703.12	/yr	
Demand Cost (Jun-Sep)	\$ 23,413.60	/yr	
Demand Cost (Oct- May)	\$ 43,346.24	/yr	
Natural Gas Cost	\$ 559,010.82	/yr	
Total Utilty Cost	\$ 1,043,473.78	/yr	



Ocean County College  
 CHP Economic Analysis - Simultaneous Chiller operation (ABS Cooling Bias)

ABS Operation	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
2 Feb	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
3 Mar	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
4 Apr	-	-	-	-	-	-	-	-	-	C	C	C	C	C	C	C	C	C	H	H	H	H	H	-
5 May	-	-	-	-	-	-	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
6 Jun	-	-	-	-	-	H	C	H	H	H	C	C	C	C	C	C	C	H	H	H	C	C	C	C
7 Jul	H	H	H	H	H	H	H	H	C	C	C	C	C	C	C	C	C	C	C	H	H	H	H	H
8 Aug	H	H	H	H	H	H	C	H	C	C	C	C	C	C	C	C	C	H	H	H	H	C	C	C
9 Sep	C	-	-	-	-	C	C	C	C	H	H	H	H	H	H	H	H	C	C	C	C	C	C	C
10 Oct	-	-	-	-	-	-	H	H	C	C	C	C	C	C	C	C	C	C	C	H	H	H	H	H
11 Nov	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
12 Dec	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H

ABS Heat Out	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	1,166	1,203	1,228	1,242	1,244	1,254	1,250	1,238	1,217	1,213	1,232	1,261	1,226	1,174	1,129	1,104	-
2 Feb	-	-	-	-	-	-	-	1,147	1,200	1,265	1,319	1,329	1,328	1,329	1,319	1,298	1,280	1,262	1,276	1,278	1,238	1,174	1,125	-
3 Mar	-	-	-	-	-	-	-	-	1,090	1,200	1,280	1,313	1,324	1,331	1,328	1,313	1,293	1,268	1,250	1,221	1,192	1,129	-	-
4 Apr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1,274	1,223	1,164	1,144	1,083	-	-
5 May	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6 Jun	-	-	-	-	-	1,129	-	1,250	1,421	1,218	-	-	-	-	-	-	1,133	1,093	941	-	-	-	-	-
7 Jul	1,116	855	963	1,120	1,128	1,071	1,193	1,403	-	-	-	-	-	-	-	-	-	1,274	1,150	1,192	1,361	1,272	1,326	-
8 Aug	849	763	725	752	807	890	-	1,157	-	-	-	-	-	-	-	-	-	845	879	824	971	-	-	-
9 Sep	-	-	-	-	-	-	-	-	1,075	966	947	1,067	965	842	864	888	-	-	-	-	-	-	-	-
10 Oct	-	-	-	-	-	-	1,280	1,324	-	-	-	-	-	-	-	-	-	1,495	1,495	1,495	1,487	1,377	1,164	-
11 Nov	-	-	-	-	-	-	1,165	1,187	1,242	948	575	458	257	264	351	552	540	748	1,143	1,325	1,171	1,292	1,215	-
12 Dec	-	-	-	-	-	-	1,108	1,177	1,223	1,286	1,284	1,367	1,389	1,408	1,396	1,393	1,383	1,375	1,366	1,307	1,268	1,211	1,160	-

Boiler Fuel Purchase	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	3,920	3,946	4,098	4,222	3,992	4,236	4,398	3,432	3,265	2,749	2,045	1,842	1,369	1,426	1,458	1,715	1,774	2,090	2,309	2,317	2,459	2,695	2,696	4,061
2 Feb	3,742	3,840	3,841	3,830	3,973	4,347	4,479	3,401	3,048	2,496	2,105	1,736	1,616	1,652	1,884	1,916	1,914	2,279	2,764	2,669	2,665	2,778	2,954	4,212
3 Mar	3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	2,176	1,237	1,130	1,401	912	905	1,052	942	979	1,248	2,131	1,785	2,277	2,198	3,391	3,465
4 Apr	2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	1,898	1,943	1,933	1,899	1,961	1,885	1,832	1,934	556	942	1,199	1,799	1,840	3,008	2,978
5 May	1,809	1,804	1,826	1,973	1,975	1,922	2,170	2,261	1,731	1,770	1,781	1,587	1,557	1,504	1,622	1,465	1,609	1,520	1,589	1,611	1,825	2,210	1,994	2,005
6 Jun	982	764	908	1,002	986	53	1,490	-	-	-	1,200	1,289	1,210	1,023	1,166	1,179	-	-	-	1,065	1,373	1,347	1,439	1,654
7 Jul	-	-	-	-	3	-	-	-	1,495	1,192	1,117	1,223	1,006	1,184	1,111	1,037	1,158	1,011	-	-	-	-	-	-
8 Aug	-	-	-	-	-	-	1,036	-	1,178	1,158	995	992	950	1,005	924	894	837	-	-	-	-	1,311	1,036	1,155
9 Sep	944	771	741	805	942	895	1,076	1,352	1,522	-	-	-	-	-	-	-	-	1,045	1,132	1,148	1,239	1,310	1,329	1,425
10 Oct	1,741	1,696	1,751	1,960	1,905	1,889	932	1,237	2,341	1,865	1,357	1,291	1,290	1,412	1,496	1,334	1,585	1,471	3	751	459	426	689	937
11 Nov	1,858	1,957	2,018	2,179	1,955	2,438	1,710	1,609	868	-	-	-	-	-	-	-	-	-	-	-	-	104	507	2,055
12 Dec	2,890	2,951	3,058	3,201	2,974	3,337	2,486	2,520	2,066	1,161	617	363	-	10	79	308	339	629	977	1,124	1,126	1,399	1,601	3,058

ABS Cooling Out	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	1,275	1,463	1,650	1,856	1,821	1,787	1,736	1,411	-	-	-	-	-	-	-
5 May	-	-	-	-	-	-	1,770	2,317	2,847	3,257	3,541	3,589	3,589	3,589	3,589	3,530	3,308	2,983	2,454	2,061	1,787	1,668	1,411	1,326
6 Jun	-	-	-	-	-	-	3,325	-	-	-	3,589	3,589	3,589	3,589	3,589	3,589	-	-	-	3,462	3,222	3,052	2,983	2,898
7 Jul	-	-	-	-	-	-	-	-	3,589	3,589	3,589	3,589	3,589	3,589	3,589	3,589	3,589	3,589	3,589	-	-	-	-	-
8 Aug	-	-	-	-	-	-	3,589	-	3,589	3,589	3,589	3,589	3,589	3,589	3,589	3,589	3,589	-	-	-	-	3,589	3,581	3,409
9 Sep	1,975	-	-	-	-	1,445	2,043	2,847	3,496	-	-	-	-	-	-	-	-	3,376	2,966	2,607	2,385	2,180	2,061	1,975
10 Oct	-	-	-	-	-	-	-	-	1,257	1,787	1,975	2,163	2,351	2,197	2,061	1,907	1,531	1,189	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-



**Ocean County College**  
**CHP Economic Analysis - Simultaneous Chiller operation (ABS Cooling Bias)**

---

Annual Electricity	10,652,491 kWh/yr	\$0.0704 / kWh
Utility Electricity	4,159,321 kWh/yr	\$0.1802 / kWh
Annual Natural Gas	703,991.05 Th/yr	\$0.7446 / Th
Electric Energy Cost	\$ 682,723.43 /yr	
Demand Cost (Jun-Sep)	\$ 23,413.60 /yr	
Demand Cost (Oct- May)	\$ 43,346.24 /yr	
Natural Gas Cost	\$ 524,185.87 /yr	
<b>Total Utility Cost</b>	<b>\$ 1,273,669.14 /yr</b>	

Ocean County College  
CHP Economic Analysis - ABS Heating

Electric primarily from CHP. Absorption chillers produces hot water when ever possible. Hot water from boilers as needed. All chilled water from centrif chiller.

Cogen Operation on/off	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
2 Feb	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
3 Mar	-	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-	-
4 Apr	-	-	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
5 May	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
6 Jun	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
7 Jul	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
8 Aug	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
9 Sep	1	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
10 Oct	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
11 Nov	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
12 Dec	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Cogen Electric Output kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	823	854	875	887	889	897	894	884	866	863	879	903	874	830	792	771	-
2 Feb	-	-	-	-	-	-	-	807	852	906	952	960	959	960	952	934	919	904	916	917	884	830	789	-
3 Mar	-	-	-	-	-	-	-	759	852	919	947	956	962	959	947	930	909	894	869	845	792	-	-	
4 Apr	-	-	-	-	-	-	-	-	773	856	900	914	926	928	923	913	914	871	821	805	753	-	-	
5 May	-	-	-	-	-	860	878	920	1,019	1,083	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,090	1,058	1,056	1,023	948	809	
6 Jun	-	-	-	-	-	792	1,017	1,029	1,095	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	
7 Jul	824	805	802	796	791	923	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,019	
8 Aug	806	781	770	761	751	918	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,037	
9 Sep	767	-	-	-	-	858	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	990	
10 Oct	-	-	-	-	-	919	956	976	1,051	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,093	1,001	821	
11 Nov	-	-	-	-	-	822	841	887	972	956	1,095	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,078	988	929	864	-	
12 Dec	-	-	-	-	-	774	832	871	924	922	992	1,017	1,027	1,017	1,014	1,006	999	991	942	909	861	818	-	

Max	per day	per month
903	13,781 31	427,211
960	14,441 28	404,348
962	12,540 31	388,740
928	11,297 30	338,910
1100	18,444 31	571,764
1100	20,232 30	606,960
1100	24,660 31	764,460
1100	24,524 31	760,244
1100	21,315 30	639,450
1100	18,917 31	586,427
1100	17,042 30	511,260
1027	15,916 31	493,396
6,493,170		

Electric Utility Import - does not include centrifugal chiller plant load kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	840	786	783	774	771	781	975	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
2 Feb	812	762	760	751	749	771	970	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
3 Mar	760	708	705	695	689	748	909	964	250	250	250	250	250	250	250	250	250	250	250	250	250	250	989	883
4 Apr	708	653	649	638	629	724	847	871	916	250	250	250	250	250	250	250	250	250	250	250	250	939	836	
5 May	926	875	868	881	868	955	250	250	250	250	250	255	285	274	285	282	280	267	250	250	250	250	250	250
6 Jun	967	932	923	912	904	250	250	250	250	340	398	429	455	458	435	446	447	446	422	403	384	341	272	250
7 Jul	250	250	250	250	250	341	335	384	458	496	483	491	501	530	536	547	534	518	472	461	435	381	250	
8 Aug	250	250	250	250	250	390	351	392	480	535	541	576	574	606	626	624	602	538	512	525	487	413	250	
9 Sep	250	999	988	979	970	250	294	310	348	438	527	542	560	560	572	589	577	567	536	499	512	444	359	250
10 Oct	909	880	871	857	841	958	250	250	250	250	283	335	359	375	393	398	390	364	349	336	317	250	250	250
11 Nov	811	767	771	764	762	909	250	250	250	250	250	250	287	309	299	311	298	268	250	250	250	250	947	
12 Dec	826	777	777	769	767	845	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	938	

Cogen Fuel Purchase kbtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	7,453	7,687	7,844	7,933	7,948	8,007	7,985	7,911	7,776	7,754	7,873	8,052	7,836	7,506	7,218	7,057	-
2 Feb	-	-	-	-	-	-	-	7,332	7,672	8,074	8,412	8,471	8,464	8,471	8,412	8,280	8,170	8,059	8,148	8,155	7,911	7,506	7,195	-
3 Mar	-	-	-	-	-	-	-	-	6,964	7,672	8,170	8,376	8,442	8,485	8,464	8,376	8,251	8,096	7,985	7,799	7,619	7,218	-	-
4 Apr	-	-	-	-	-	-	-	-	-	7,072	7,702	8,029	8,133	8,221	8,236	8,199	8,126	8,133	7,814	7,438	7,317	6,918	-	-
5 May	-	-	-	-	-	7,732	7,866	8,177	8,899	9,359	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,409	9,180	9,166	8,928	8,383	7,347
6 Jun	-	-	-	-	-	7,218	8,885	8,972	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,022
7 Jul	7,461	7,317	7,294	7,248	7,210	8,199	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,899
8 Aug	7,324	7,133	7,049	6,980	6,902	8,163	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,029
9 Sep	7,026	-	-	-	-	7,717	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,689
10 Oct	-	-	-	-	-	-	8,170	8,442	8,588	9,130	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,431	8,769	7,438
11 Nov	-	-	-	-	-	-	7,446	7,589	7,933	8,558	8,442	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,324	8,834	8,675	8,244	7,762	-
12 Dec	-	-	-	-	-	-	7,080	7,521	7,814	8,207	8,192	8,704	8,885	8,957	8,885	8,863	8,805	8,755	8,697	8,339	8,096	7,739	7,415	-

Ocean County College  
 CHP Economic Analysis - ABS Heating

ABS Operation		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1 Jan	Cool/Heat/Off	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
2 Feb		-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
3 Mar		-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
4 Apr		-	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
5 May		-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
6 Jun		-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
7 Jul		H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
8 Aug		H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
9 Sep		H	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
10 Oct		-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
11 Nov		-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
12 Dec		-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-

ABS Heat Out		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	kBtu/hr	-	-	-	-	-	-	-	1,166	1,203	1,228	1,242	1,244	1,254	1,250	1,238	1,217	1,213	1,232	1,261	1,226	1,174	1,129	1,104	-
2 Feb		-	-	-	-	-	-	-	1,147	1,200	1,265	1,319	1,329	1,328	1,329	1,319	1,298	1,280	1,262	1,276	1,278	1,238	1,174	1,125	-
3 Mar		-	-	-	-	-	-	-	-	1,090	1,200	1,280	1,313	1,324	1,331	1,328	1,313	1,293	1,268	1,250	1,221	1,192	1,129	-	-
4 Apr		-	-	-	-	-	-	-	-	1,106	1,205	1,257	1,274	1,288	1,291	1,285	1,273	1,274	1,223	1,164	1,144	1,083	-	-	-
5 May		-	-	-	-	-	-	1,210	1,231	1,281	1,399	1,475	1,468	1,440	1,391	1,495	1,355	1,488	1,406	1,470	1,445	1,443	1,404	1,314	1,149
6 Jun		-	-	-	-	-	1,129	1,378	1,250	1,421	1,218	1,110	1,192	1,119	946	1,079	1,091	1,133	1,093	941	985	1,270	1,246	1,331	1,256
7 Jul		1,116	855	963	1,120	1,128	1,071	1,193	1,403	1,383	1,103	1,033	1,131	931	1,095	1,028	959	1,071	935	1,274	1,150	1,192	1,361	1,272	1,326
8 Aug		849	763	725	752	807	890	958	1,157	1,090	1,071	920	918	879	930	855	827	774	845	879	824	971	1,213	958	1,068
9 Sep		873	-	-	-	-	828	995	1,251	1,408	1,075	966	947	1,067	965	842	864	888	967	1,047	1,062	1,146	1,212	1,229	1,318
10 Oct		-	-	-	-	-	-	1,280	1,324	1,348	1,437	1,255	1,194	1,193	1,306	1,384	1,234	1,466	1,361	1,495	1,495	1,495	1,487	1,377	1,164
11 Nov		-	-	-	-	-	-	1,165	1,187	1,242	948	575	458	257	264	351	552	540	748	1,143	1,325	1,171	1,292	1,215	-
12 Dec		-	-	-	-	-	-	1,108	1,177	1,223	1,286	1,284	1,367	1,389	1,408	1,396	1,393	1,383	1,375	1,366	1,307	1,268	1,211	1,160	-

Boiler Fuel Purchase		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	kBtu/hr	3,920	3,946	4,098	4,222	3,992	4,236	4,398	3,432	3,265	2,749	2,045	1,842	1,369	1,426	1,458	1,715	1,774	2,090	2,309	2,317	2,459	2,695	2,696	4,061
2 Feb		3,742	3,840	3,841	3,830	3,973	4,347	4,479	3,401	3,048	2,496	2,105	1,736	1,616	1,652	1,884	1,916	1,914	2,279	2,764	2,669	2,665	2,778	2,954	4,212
3 Mar		3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	2,176	1,237	1,130	1,401	912	905	1,052	942	979	1,248	2,131	1,785	2,277	2,198	3,391	3,465
4 Apr		2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	703	640	574	522	569	490	443	558	556	942	1,199	1,799	1,840	3,008	2,978
5 May		1,809	1,804	1,826	1,973	1,975	1,922	862	930	346	257	186	-	-	-	5	-	-	-	-	49	265	692	573	763
6 Jun		982	764	908	1,002	986	53	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	296
7 Jul		-	-	-	-	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8 Aug		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9 Sep		-	771	741	805	942	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10 Oct		1,741	1,696	1,751	1,960	1,905	1,889	932	1,237	883	311	-	-	-	-	-	-	-	-	3	751	459	426	689	937
11 Nov		1,858	1,957	2,018	2,179	1,955	2,438	1,710	1,609	868	-	-	-	-	-	-	-	-	-	-	-	-	104	507	2,055
12 Dec		2,890	2,951	3,058	3,201	2,974	3,337	2,486	2,520	2,066	1,161	617	363	-	10	79	308	339	629	977	1,124	1,126	1,399	1,601	3,058

ABS Cooling Out		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	kBtu/hr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5 May		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6 Jun		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7 Jul		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8 Aug		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9 Sep		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10 Oct		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11 Nov		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-



Ocean County College  
CHP Economic Analysis - ABS Heating

Centrifugal Chiller Energy tons	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	106	122	138	155	152	149	145	118	-	-	-	-	-	-	-
5 May	106	101	96	-	-	103	148	193	237	271	296	310	310	311	307	294	276	249	205	172	149	139	118	111
6 Jun	226	224	220	210	209	237	277	323	357	381	402	420	422	421	422	410	392	360	330	289	269	254	249	242
7 Jul	311	298	291	286	274	301	341	377	407	434	449	468	475	474	466	459	439	415	391	371	360	345	333	327
8 Aug	281	274	269	263	254	257	300	364	405	431	452	459	461	462	455	444	425	395	365	337	318	307	298	287
9 Sep	165	150	142	135	122	120	170	237	291	330	355	373	378	374	360	344	318	281	247	217	199	182	172	165
10 Oct	-	-	-	-	-	-	-	-	105	149	165	180	196	183	172	159	128	99	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Centrifugal Chiller Electricity kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	25	29	34	39	38	37	36	28	-	-	-	-	-	-	-
5 May	25	24	23	-	-	25	36	51	69	87	101	111	111	112	109	100	89	75	55	44	37	34	28	26
6 Jun	64	64	62	58	57	69	90	120	147	169	191	211	214	212	214	199	181	150	125	97	85	78	75	71
7 Jul	112	103	98	95	88	105	134	165	196	228	248	136	139	138	271	262	235	206	179	160	150	137	127	123
8 Aug	92	88	85	82	78	79	104	153	195	224	252	262	263	265	256	240	217	184	155	130	116	109	103	96
9 Sep	42	37	35	33	29	29	43	69	98	125	146	161	167	163	150	136	116	92	74	61	53	47	44	42
10 Oct	-	-	-	-	-	-	-	-	25	37	42	47	52	48	44	40	31	24	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Total Utility Electric Purchase kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	840	786	783	774	771	781	975	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
2 Feb	812	762	760	751	749	771	970	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
3 Mar	760	708	705	695	689	748	909	964	250	250	250	250	250	250	250	250	250	250	250	250	250	250	989	883
4 Apr	708	653	649	638	629	724	847	871	916	275	279	284	289	288	287	286	278	250	250	250	250	250	939	836
5 May	951	899	891	881	868	980	286	301	319	337	351	366	396	386	394	382	369	342	305	294	287	284	278	276
6 Jun	1,031	996	985	970	961	319	340	370	397	509	589	640	669	670	649	645	628	596	547	500	469	419	347	321
7 Jul	362	353	348	345	338	355	475	500	580	686	744	619	630	639	801	798	782	740	697	632	611	572	508	373
8 Aug	342	338	335	332	328	329	494	504	587	704	787	803	839	839	862	866	841	786	693	642	641	596	516	346
9 Sep	292	1,036	1,023	1,012	999	279	337	379	446	563	673	703	727	723	722	725	693	659	610	560	565	491	403	292
10 Oct	909	880	871	857	841	958	250	250	275	287	325	382	411	423	437	438	421	388	349	336	317	250	250	250
11 Nov	811	767	771	764	762	909	250	250	250	250	250	250	287	309	299	311	298	268	250	250	250	250	250	947
12 Dec	826	777	777	769	767	845	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	938

Total Utility Natural Gas Purchase kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	3,920	3,946	4,098	4,222	3,992	4,236	4,398	10,885	10,952	10,593	9,978	9,790	9,376	9,411	9,369	9,491	9,528	9,963	10,361	10,153	9,965	9,913	9,753	4,061
2 Feb	3,742	3,840	3,841	3,830	3,973	4,347	4,479	10,733	10,720	10,570	10,517	10,207	10,080	10,123	10,296	10,196	10,084	10,338	10,912	10,824	10,576	10,284	10,149	4,212
3 Mar	3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	9,140	8,909	9,300	9,777	9,354	9,390	9,516	9,318	9,230	9,344	10,116	9,584	9,896	9,416	3,391	3,465
4 Apr	2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	7,775	8,342	8,603	8,655	8,790	8,726	8,642	8,684	8,689	8,756	8,637	9,116	8,758	3,008	2,978
5 May	1,809	1,804	1,826	1,973	1,975	1,922	8,594	8,796	8,523	9,156	9,545	9,481	9,481	9,481	9,486	9,481	9,481	9,481	9,409	9,229	9,431	9,620	8,956	8,110
6 Jun	982	764	908	1,002	986	7,271	8,885	8,972	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,318
7 Jul	7,461	7,317	7,294	7,248	7,213	8,199	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,899
8 Aug	7,324	7,133	7,049	6,980	6,902	8,163	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,029
9 Sep	7,026	771	741	805	942	7,717	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,689
10 Oct	1,741	1,696	1,751	1,960	1,905	1,889	9,102	9,679	9,471	9,441	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,484	10,232	9,940	9,857	9,458	8,375
11 Nov	1,858	1,957	2,018	2,179	1,955	2,438	9,156	9,198	8,801	8,558	8,442	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,324	8,834	8,675	8,348	8,269	2,055
12 Dec	2,890	2,951	3,058	3,201	2,974	3,337	9,566	10,041	9,880	9,368	8,809	9,067	8,885	8,967	8,964	9,171	9,144	9,384	9,674	9,463	9,222	9,138	9,016	3,058

Max	per day	per month
975	10,639	31 329,809
970	10,504	28 294,112
989	11,550	31 358,050
939	11,926	30 357,780
980	11,423	31 354,113
1031	14,567	30 437,010
801	13,488	31 418,128
866	14,350	31 444,850
1036	14,912	30 447,360
958	11,355	31 352,005
947	10,253	30 307,590
938	9,949	31 308,419

4,409,226

	per day	per month
192,355	31	5,962,992
198,873	28	5,568,431
168,028	31	5,208,879
144,516	30	4,335,491
177,050	31	5,488,542
180,267	30	5,408,021
214,808	31	6,659,056
213,757	31	6,626,467
187,867	30	5,636,021
181,830	31	5,636,724
168,396	30	5,051,891
179,232	31	5,556,187

67,138,703

**Ocean County College**  
**CHP Economic Analysis - ABS Heating**

---

Annual Electricity	10,902,396	kWh/yr	\$0.0725 / kWh
Utility Electricity	4,409,226	kWh/yr	\$0.1793 / kWh
Annual Natural Gas	671,387.03	Th/yr	\$0.7446 / Th
Electric Energy Cost	\$ 723,743.58	/yr	
Demand Cost (Jun-Sep)	\$ 23,413.60	/yr	
Demand Cost (Oct- May)	\$ 43,346.24	/yr	
Natural Gas Cost	\$ 499,909.19	/yr	
Total Utility Cost	\$ 1,290,412.61	/yr	

Ocean County College  
 CHP Economic Analysis - Add High Efficiency Exhaust Heat Recovery

Electric primarily from CHP. High efficiency exhaust heat recovery produces hot water when ever possible. Hot water from boilers as needed. All chilled water from centrif chiller.

Cogen Operation	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
2 Feb	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
3 Mar	-	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-	-
4 Apr	-	-	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
5 May	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
6 Jun	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
7 Jul	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
8 Aug	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
9 Sep	1	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
10 Oct	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
11 Nov	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
12 Dec	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-

Cogen Electric Output	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	823	854	875	887	889	897	894	884	866	863	879	903	874	830	792	771	-
2 Feb	-	-	-	-	-	-	-	807	852	906	952	960	959	960	952	934	919	904	916	917	884	830	789	-
3 Mar	-	-	-	-	-	-	-	759	852	919	947	956	962	959	947	930	909	894	869	845	792	-	-	
4 Apr	-	-	-	-	-	-	-	-	773	856	900	914	926	928	923	913	914	871	821	805	753	-	-	
5 May	-	-	-	-	-	860	878	920	1,019	1,083	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,090	1,058	1,056	1,023	948	809	
6 Jun	-	-	-	-	-	792	1,017	1,029	1,095	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	
7 Jul	824	805	802	796	791	923	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,019	
8 Aug	806	781	770	761	751	918	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,037	
9 Sep	767	-	-	-	-	858	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	990	
10 Oct	-	-	-	-	-	919	956	976	1,051	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,093	1,001	821	
11 Nov	-	-	-	-	-	822	841	887	972	956	1,095	1,100	1,100	1,100	1,100	1,100	1,100	1,100	1,078	1,010	988	929	864	
12 Dec	-	-	-	-	-	774	832	871	924	922	992	1,017	1,027	1,017	1,014	1,006	999	991	942	909	861	818	-	

Max	per day	per month
903	13,781	31
960	14,441	28
962	12,540	31
928	11,297	30
1100	18,444	31
1100	20,232	30
1100	24,660	31
1100	24,524	31
1100	21,315	30
1100	18,917	31
1100	17,042	30
1027	15,916	31
<u>6,493,170</u>		

Electric Utility Import - does not include centrifugal chiller plant load	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	840	786	783	774	771	781	975	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
2 Feb	812	762	760	751	749	771	970	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
3 Mar	760	708	705	695	689	748	909	964	250	250	250	250	250	250	250	250	250	250	250	250	250	250	989	883
4 Apr	708	653	649	638	629	724	847	871	916	250	250	250	250	250	250	250	250	250	250	250	250	939	836	
5 May	926	875	868	881	868	955	250	250	250	250	250	255	285	274	285	282	280	267	250	250	250	250	250	250
6 Jun	967	932	923	912	904	250	250	250	250	340	398	429	455	458	435	446	447	446	422	403	384	341	272	250
7 Jul	250	250	250	250	250	341	335	384	458	496	483	491	501	530	536	547	534	518	472	461	435	381	250	
8 Aug	250	250	250	250	250	390	351	392	480	535	541	576	574	606	626	624	602	538	512	525	487	413	250	
9 Sep	250	999	988	979	970	250	294	310	348	438	527	542	560	560	572	589	577	567	536	499	512	444	359	250
10 Oct	909	880	871	857	841	958	250	250	250	250	283	335	359	375	393	398	390	364	349	336	317	250	250	250
11 Nov	811	767	771	764	762	909	250	250	250	250	250	250	287	309	299	311	298	268	250	250	250	250	250	947
12 Dec	826	777	777	769	767	845	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	938

Cogen Fuel Purchase	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	7,453	7,687	7,844	7,933	7,948	8,007	7,985	7,911	7,776	7,754	7,873	8,052	7,836	7,506	7,218	7,057	-
2 Feb	-	-	-	-	-	-	-	7,332	7,672	8,074	8,412	8,471	8,464	8,471	8,412	8,280	8,170	8,059	8,148	8,155	7,911	7,506	7,195	-
3 Mar	-	-	-	-	-	-	-	-	6,964	7,672	8,170	8,376	8,442	8,485	8,464	8,376	8,251	8,096	7,985	7,799	7,619	7,218	-	-
4 Apr	-	-	-	-	-	-	-	-	7,072	7,702	8,029	8,133	8,221	8,236	8,199	8,126	8,133	7,814	7,438	7,317	6,918	-	-	
5 May	-	-	-	-	-	7,732	7,866	8,177	8,899	9,359	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,409	9,180	9,166	8,928	8,383	7,347	
6 Jun	-	-	-	-	-	7,218	8,885	8,972	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,022
7 Jul	7,461	7,317	7,294	7,248	7,210	8,199	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,899
8 Aug	7,324	7,133	7,049	6,980	6,902	8,163	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,029
9 Sep	7,026	-	-	-	-	7,717	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,689
10 Oct	-	-	-	-	-	-	8,170	8,442	8,588	9,130	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,431	8,769	7,438
11 Nov	-	-	-	-	-	-	7,446	7,589	7,933	8,558	8,442	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,324	8,834	8,675	8,244	7,762	-
12 Dec	-	-	-	-	-	-	7,080	7,521	7,814	8,207	8,192	8,704	8,885	8,957	8,885	8,863	8,805	8,755	8,697	8,339	8,096	7,739	7,415	-

Ocean County College  
CHP Economic Analysis - Add High Efficiency Exhaust Heat Recovery

Heat Recovery Operation		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1 Jan	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
2 Feb	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
3 Mar	-	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
4 Apr	-	-	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
5 May	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
6 Jun	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
7 Jul	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
8 Aug	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
9 Sep	H	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
10 Oct	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
11 Nov	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
12 Dec	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-

Heat Recovery		Heat exchanger efficiency = 80%																							
kBtu/hr		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	2,234	2,305	2,353	2,380	2,384	2,403	2,396	2,373	2,332	2,325	2,362	2,416	2,350	2,250	2,164	2,116	-
2 Feb	-	-	-	-	-	-	-	-	2,198	2,300	2,423	2,528	2,546	2,544	2,546	2,528	2,487	2,453	2,419	2,446	2,448	2,373	2,250	2,157	-
3 Mar	-	-	-	-	-	-	-	-	-	2,088	2,300	2,325	2,517	2,168	2,168	2,301	2,184	2,199	2,422	2,396	2,339	2,284	2,164	-	-
4 Apr	-	-	-	-	-	-	-	-	-	-	1,756	1,797	1,788	1,757	1,814	1,744	1,695	1,789	1,788	2,094	2,230	2,193	2,075	-	-
5 May	-	-	-	-	-	-	2,007	2,091	1,601	1,637	1,647	1,468	1,440	1,391	1,500	1,355	1,488	1,406	1,470	1,490	1,688	2,044	1,844	1,855	-
6 Jun	-	-	-	-	-	1,178	1,378	1,250	1,421	1,218	1,110	1,192	1,119	946	1,079	1,091	1,133	1,093	941	985	1,270	1,246	1,331	1,530	-
7 Jul	1,116	855	963	1,120	1,131	1,071	1,193	1,403	1,383	1,103	1,033	1,131	931	1,095	1,028	959	1,071	935	1,274	1,150	1,192	1,361	1,272	1,326	-
8 Aug	849	763	725	752	807	890	958	1,157	1,090	1,071	920	918	879	930	855	827	774	845	879	824	971	1,213	958	1,068	-
9 Sep	873	-	-	-	-	828	995	1,251	1,408	1,075	966	947	1,067	965	842	864	888	967	1,047	1,062	1,146	1,212	1,229	1,318	-
10 Oct	-	-	-	-	-	-	2,142	2,468	2,165	1,725	1,255	1,194	1,193	1,306	1,384	1,234	1,466	1,361	1,498	2,190	1,920	1,881	2,014	2,031	-
11 Nov	-	-	-	-	-	-	2,232	2,275	2,045	948	575	458	257	264	351	552	540	748	1,143	1,325	1,171	1,388	1,684	-	-
12 Dec	-	-	-	-	-	-	2,123	2,255	2,343	2,360	1,855	1,703	1,389	1,417	1,469	1,678	1,697	1,957	2,270	2,347	2,310	2,321	2,223	-	-

Boiler Fuel Purchase																										
kBtu/hr		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1 Jan	3,920	3,946	4,098	4,222	3,992	4,236	4,398	2,278	2,074	1,533	815	610	126	187	231	509	572	868	1,061	1,102	1,296	1,576	1,602	4,061	-	
2 Feb	3,742	3,840	3,841	3,830	3,973	4,347	4,479	2,265	1,858	1,244	798	421	302	336	577	630	645	1,028	1,499	1,404	1,438	1,615	1,838	4,212	-	
3 Mar	3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	1,097	48	-	99	-	-	-	-	-	-	892	576	1,096	1,079	3,391	3,465	-	
4 Apr	2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	-	-	-	-	-	-	-	-	-	-	-	46	665	768	3,008	2,978	-
5 May	1,809	1,804	1,826	1,973	1,975	1,922	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6 Jun	982	764	908	1,002	986	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7 Jul	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8 Aug	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9 Sep	-	771	741	805	942	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10 Oct	1,741	1,696	1,751	1,960	1,905	1,889	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11 Nov	1,858	1,957	2,018	2,179	1,955	2,438	557	432	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	2,055	-
12 Dec	2,890	2,951	3,058	3,201	2,974	3,337	1,389	1,355	855	-	-	-	-	-	-	-	-	-	-	-	-	-	199	452	3,058	-

ABS Cooling Out																										
kBtu/hr		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5 May	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6 Jun	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7 Jul	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8 Aug	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9 Sep	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10 Oct	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Ocean County College  
 CHP Economic Analysis - Add High Efficiency Exhaust Heat Recovery

Centrifugal Chiller Energy																								
tons	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	106	122	138	155	152	149	145	118	-	-	-	-	-	-	-
5 May	106	101	96	-	-	103	148	193	237	271	296	310	310	311	307	294	276	249	205	172	149	139	118	111
6 Jun	226	224	220	210	209	237	277	323	357	381	402	420	422	421	422	410	392	360	330	289	269	254	249	242
7 Jul	311	298	291	286	274	301	341	377	407	434	449	468	475	474	466	459	439	415	391	371	360	345	333	327
8 Aug	281	274	269	263	254	257	300	364	405	431	452	459	461	462	455	444	425	395	365	337	318	307	298	287
9 Sep	165	150	142	135	122	120	170	237	291	330	355	373	378	374	360	344	318	281	247	217	199	182	172	165
10 Oct	-	-	-	-	-	-	-	-	105	149	165	180	196	183	172	159	128	99	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Centrifugal Chiller Electricity																								
kW	Minimum chiller load = 20%																							
	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	25	29	34	39	38	37	36	28	-	-	-	-	-	-	-
5 May	25	24	23	-	-	25	36	51	69	87	101	111	111	112	109	100	89	75	55	44	37	34	28	26
6 Jun	64	64	62	58	57	69	90	120	147	169	191	211	214	212	214	199	181	150	125	97	85	78	75	71
7 Jul	112	103	98	95	88	105	134	165	196	228	248	136	139	138	271	262	235	206	179	160	150	137	127	123
8 Aug	92	88	85	82	78	79	104	153	195	224	252	262	263	265	256	240	217	184	155	130	116	109	103	96
9 Sep	42	37	35	33	29	29	43	69	98	125	146	161	167	163	150	136	116	92	74	61	53	47	44	42
10 Oct	-	-	-	-	-	-	-	-	25	37	42	47	52	48	44	40	31	24	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Total Utility Electric Purchase																								
kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	840	786	783	774	771	781	975	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
2 Feb	812	762	760	751	749	771	970	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
3 Mar	760	708	705	695	689	748	909	964	250	250	250	250	250	250	250	250	250	250	250	250	250	250	989	883
4 Apr	708	653	649	638	629	724	847	871	916	275	279	284	289	288	287	286	278	250	250	250	250	250	939	836
5 May	951	899	891	881	868	980	286	301	319	337	351	366	396	386	394	382	369	342	305	294	287	284	278	276
6 Jun	1,031	996	985	970	961	319	340	370	397	509	589	640	669	670	649	645	628	596	547	500	469	419	347	321
7 Jul	362	353	348	345	338	355	475	500	580	686	744	619	630	639	801	798	782	740	697	632	611	572	508	373
8 Aug	342	338	335	332	328	329	494	504	587	704	787	803	839	839	862	866	841	786	693	642	641	596	516	346
9 Sep	292	1,036	1,023	1,012	999	279	337	379	446	563	673	703	727	723	722	725	693	659	610	560	565	491	403	292
10 Oct	909	880	871	857	841	958	250	250	275	287	325	382	411	423	437	438	421	388	349	336	317	250	250	250
11 Nov	811	767	771	764	762	909	250	250	250	250	250	250	287	309	299	311	298	268	250	250	250	250	250	947
12 Dec	826	777	777	769	767	845	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	938

Max	per day	per month
975	10,639	31 329,809
970	10,504	28 294,112
989	11,550	31 358,050
939	11,926	30 357,780
980	11,423	31 354,113
1031	14,567	30 437,010
801	13,488	31 418,128
866	14,350	31 444,850
1036	14,912	30 447,360
958	11,355	31 352,005
947	10,253	30 307,590
938	9,949	31 308,419

4,409,226

Total Utility Natural Gas Purchase																								
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	3,920	3,946	4,098	4,222	3,992	4,236	4,398	9,731	9,761	9,377	8,748	8,558	8,133	8,172	8,142	8,285	8,326	8,741	9,113	8,938	8,802	8,794	8,659	4,061
2 Feb	3,742	3,840	3,841	3,830	3,973	4,347	4,479	9,597	9,530	9,318	9,210	8,892	8,766	8,807	8,989	8,910	8,815	9,087	9,647	9,559	9,349	9,121	9,033	4,212
3 Mar	3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	8,061	7,720	8,170	8,475	8,442	8,485	8,464	8,376	8,251	8,096	8,877	8,375	8,715	8,297	3,391	3,465
4 Apr	2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	7,072	7,702	8,029	8,133	8,221	8,236	8,199	8,126	8,133	7,814	7,484	7,982	7,686	3,008	2,978
5 May	1,809	1,804	1,826	1,973	1,975	1,922	7,732	7,866	8,177	8,899	9,359	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,409	9,180	9,166	8,928	8,383	7,347
6 Jun	982	764	908	1,002	986	7,218	8,885	8,972	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,022
7 Jul	7,461	7,317	7,294	7,248	7,210	8,199	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,899
8 Aug	7,324	7,133	7,049	6,980	6,902	8,163	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,029
9 Sep	7,026	771	741	805	942	7,717	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	8,689
10 Oct	1,741	1,696	1,751	1,960	1,905	1,889	8,170	8,442	8,588	9,130	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	9,481	7,438
11 Nov	1,858	1,957	2,018	2,179	1,955	2,438	8,003	8,021	7,933	8,558	8,442	9,445	9,481	9,481	9,481	9,481	9,481	9,481	9,324	8,834	8,675	8,244	7,762	2,055
12 Dec	2,890	2,951	3,058	3,201	2,974	3,337	8,469	8,876	8,669	8,207	8,192	8,704	8,885	8,957	8,885	8,863	8,805	8,755	8,697	8,339	8,096	7,938	7,867	3,058

per day	per month
173,152	31 5,367,725
178,995	28 5,009,067
152,544	31 4,728,865
135,162	30 4,054,854
172,122	31 5,335,788
179,918	30 5,397,545
214,805	31 6,658,955
213,757	31 6,626,467
187,867	30 5,636,021
175,201	31 5,431,219
164,588	30 4,937,632
166,674	31 5,166,894

64,351,032

**Ocean County College**  
**CHP Economic Analysis - Add High Efficiency Exhaust Heat Recovery**

---

Annual Electricity	10,902,396 kWh/yr	\$0.0725 / kWh
Utility Electricity	4,409,226 kWh/yr	\$0.1793 / kWh
Annual Natural Gas	643,510.32 Th/yr	\$0.7446 / Th
Electric Energy Cost	\$ 723,743.58 /yr	
Demand Cost (Jun-Sep)	\$ 23,413.60 /yr	
Demand Cost (Oct- May)	\$ 43,346.24 /yr	
Natural Gas Cost	\$ 479,152.42 /yr	
<b>Total Utility Cost</b>	<b>\$ 1,269,655.84 /yr</b>	

Ocean County College  
 CHP Economic Analysis - Additional Generation Capacity

Electric primarily from expanded CHP. Absorption chillers produces chilled water when ever possible. ABS and Centrif chillers can NOT run together. Hot water from boilers as needed.

Cogen Operation on/off	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1 Jan	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
2 Feb	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
3 Mar	-	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-	-
4 Apr	-	-	-	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-	-
5 May	-	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
6 Jun	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
7 Jul	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
8 Aug	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
9 Sep	1	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
10 Oct	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
11 Nov	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-
12 Dec	-	-	-	-	-	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	-

Cogen Electric Output kW	Added Generation Capacity = 200 kW																								
	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1 Jan	-	-	-	-	-	-	-	823	854	875	887	889	897	894	884	866	863	879	903	874	830	792	771	771	-
2 Feb	-	-	-	-	-	-	-	807	852	906	952	960	959	960	952	934	919	904	916	917	884	830	789	-	-
3 Mar	-	-	-	-	-	-	-	759	852	919	947	956	962	959	947	930	909	894	869	845	792	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	773	856	900	914	926	928	923	913	914	871	821	805	753	-	-	-	-
5 May	-	-	-	-	-	-	860	878	920	1,019	1,083	1,105	1,135	1,124	1,135	1,132	1,130	1,117	1,090	1,058	1,056	1,023	948	809	
6 Jun	-	-	-	-	-	792	1,017	1,029	1,095	1,190	1,248	1,279	1,300	1,300	1,285	1,296	1,297	1,296	1,272	1,253	1,234	1,191	1,122	899	
7 Jul	824	805	802	796	791	923	1,191	1,185	1,234	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,285	1,231	1,019	
8 Aug	806	781	770	761	751	918	1,240	1,201	1,242	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,263	1,037	-	
9 Sep	767	-	-	-	-	858	1,144	1,160	1,198	1,288	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,300	1,294	1,209	990	-	
10 Oct	-	-	-	-	-	-	919	956	976	1,051	1,133	1,185	1,209	1,225	1,243	1,248	1,240	1,214	1,199	1,186	1,167	1,093	1,001	821	
11 Nov	-	-	-	-	-	-	822	841	887	972	956	1,095	1,137	1,159	1,149	1,161	1,148	1,118	1,078	1,010	988	929	864	-	
12 Dec	-	-	-	-	-	-	774	832	871	924	922	992	1,017	1,027	1,017	1,014	1,006	999	991	942	909	861	818	-	

Max		per day	per month
903	13,781	31	427,211
960	14,441	28	404,348
962	12,540	31	388,740
928	11,297	30	338,910
1135	18,622	31	577,282
1300	22,395	30	671,850
1300	27,686	31	858,266
1300	27,670	31	857,770
1300	24,208	30	726,240
1248	20,066	31	622,046
1161	17,314	30	519,420
1027	15,916	31	493,396
			6,885,479

Electric Utility Import - does not include centrifugal chiller plant load kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	840	786	783	774	771	781	975	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
2 Feb	812	762	760	751	749	771	970	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	929
3 Mar	760	708	705	695	689	748	909	964	250	250	250	250	250	250	250	250	250	250	250	250	250	250	989	883
4 Apr	708	653	649	638	629	724	847	871	916	250	250	250	250	250	250	250	250	250	250	250	250	250	939	836
5 May	926	875	868	881	868	955	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250
6 Jun	967	932	923	912	904	250	250	250	250	250	250	250	255	258	250	250	250	250	250	250	250	250	250	250
7 Jul	250	250	250	250	250	250	250	250	250	258	296	283	291	301	330	336	347	334	318	272	261	250	250	250
8 Aug	250	250	250	250	250	250	250	250	250	280	335	341	376	374	406	426	424	402	338	312	325	287	250	250
9 Sep	250	999	988	979	970	250	250	250	250	250	327	342	360	360	372	389	377	367	336	299	312	250	250	250
10 Oct	909	880	871	857	841	958	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250
11 Nov	811	767	771	764	762	909	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	947
12 Dec	826	777	777	769	767	845	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	938

Cogen Fuel Purchase kBTu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	7,653	7,896	8,060	8,153	8,169	8,230	8,207	8,130	7,990	7,967	8,091	8,277	8,052	7,708	7,407	7,239	-
2 Feb	-	-	-	-	-	-	-	7,527	7,881	8,300	8,652	8,713	8,705	8,713	8,652	8,515	8,400	8,284	8,377	8,384	8,130	7,708	7,383	-
3 Mar	-	-	-	-	-	-	-	-	7,143	7,881	8,400	8,614	8,682	8,728	8,705	8,614	8,484	8,323	8,207	8,013	7,826	7,407	-	-
4 Apr	-	-	-	-	-	-	-	-	-	7,256	7,912	8,254	8,361	8,453	8,469	8,430	8,354	8,361	8,029	7,637	7,511	7,095	-	-
5 May	-	-	-	-	-	-	7,943	8,083	8,407	9,157	9,633	9,794	10,014	9,934	10,014	9,992	9,978	9,883	9,684	9,448	9,433	9,187	8,621	7,542
6 Jun	-	-	-	-	-	7,407	9,142	9,232	9,721	10,414	10,832	11,055	11,205	11,205	11,098	11,176	11,183	11,176	11,004	10,868	10,732	10,421	9,919	8,246
7 Jul	7,661	7,511	7,487	7,439	7,399	8,430	10,421	10,378	10,732	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,098	10,710	9,157
8 Aug	7,519	7,320	7,231	7,159	7,079	8,392	10,775	10,494	10,789	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	10,940	9,291	
9 Sep	7,207	-	-	-	-	7,928	10,080	10,197	10,472	11,119	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,162	10,552	8,939	
10 Oct	-	-	-	-	-	-	8,400	8,682	8,834	9,396	10,000	10,378	10,552	10,667	10,796	10,832	10,775	10,588	10,479	10,385	10,247	9,706	9,022	7,637
11 Nov	-	-	-	-	-	-	7,645	7,795	8,153	8,803	8,682	9,721	10,029	10,189	10,116	10,204	10,109	9,890	9,596	9,090	8,924	8,476	7,975	-
12 Dec	-	-	-	-	-	-	7,264	7,724	8,029	8,438	8,423	8,954	9,142	9,217	9,142	9,120	9,060	9,007	8,947	8,576	8,323	7,951	7,614	-

Ocean County College  
 CHP Economic Analysis - Additional Generation Capacity

ABS Operation																								
Cool/Heat/Off	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
2 Feb	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
3 Mar	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-	-
4 Apr	-	-	-	-	-	-	-	-	-	C	C	C	C	C	C	C	C	H	H	H	H	H	-	-
5 May	-	-	-	-	-	-	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C
6 Jun	-	-	-	-	-	H	C	H	H	H	H	H	H	H	H	H	H	H	H	H	C	C	C	C
7 Jul	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H
8 Aug	H	H	H	H	H	C	C	H	H	H	H	H	H	H	H	H	H	H	H	H	H	C	C	C
9 Sep	C	-	-	-	-	C	C	C	H	H	H	H	H	H	H	H	H	C	C	C	C	C	C	C
10 Oct	-	-	-	-	-	-	H	H	C	C	C	C	C	C	C	C	C	C	C	H	H	H	H	H
11 Nov	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
12 Dec	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-

ABS Heat Out																								
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	1,166	1,203	1,228	1,242	1,244	1,254	1,250	1,238	1,217	1,213	1,232	1,261	1,226	1,174	1,129	1,104	-
2 Feb	-	-	-	-	-	-	-	1,147	1,200	1,265	1,319	1,329	1,328	1,329	1,319	1,298	1,280	1,262	1,276	1,278	1,238	1,174	1,125	-
3 Mar	-	-	-	-	-	-	-	-	1,090	1,200	1,280	1,313	1,324	1,331	1,328	1,313	1,293	1,268	1,250	1,221	1,192	1,129	-	-
4 Apr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1,274	1,223	1,164	1,144	1,083	-	-
5 May	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6 Jun	-	-	-	-	-	1,129	-	1,250	1,421	1,218	1,110	1,192	1,119	946	1,079	1,091	1,133	1,093	941	-	-	-	-	-
7 Jul	1,116	855	963	1,120	1,128	1,071	1,193	1,403	1,383	1,103	1,033	1,131	931	1,095	1,028	959	1,071	935	1,274	1,150	1,192	1,361	1,272	1,326
8 Aug	849	763	725	752	807	-	-	1,157	1,090	1,071	920	918	879	930	855	827	774	845	879	824	971	-	-	-
9 Sep	-	-	-	-	-	-	-	1,408	1,075	966	947	1,067	965	842	864	888	-	-	-	-	-	-	-	-
10 Oct	-	-	-	-	-	-	1,280	1,324	-	-	-	-	-	-	-	-	-	-	1,498	1,597	1,575	1,487	1,377	1,164
11 Nov	-	-	-	-	-	-	1,165	1,187	1,242	948	575	458	257	264	351	552	540	748	1,143	1,325	1,171	1,292	1,215	-
12 Dec	-	-	-	-	-	-	1,108	1,177	1,223	1,286	1,284	1,367	1,389	1,408	1,396	1,393	1,383	1,375	1,366	1,307	1,268	1,211	1,160	-

Boiler Fuel Purchase																								
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	3,920	3,946	4,098	4,222	3,992	4,236	4,398	3,432	3,265	2,749	2,045	1,842	1,369	1,426	1,458	1,715	1,774	2,090	2,309	2,317	2,459	2,695	2,696	4,061
2 Feb	3,742	3,840	3,841	3,830	3,973	4,347	4,479	3,401	3,048	2,496	2,105	1,736	1,616	1,652	1,884	1,916	1,914	2,279	2,764	2,669	2,665	2,778	2,954	4,212
3 Mar	3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	2,176	1,237	1,130	1,401	912	905	1,052	942	979	1,248	2,131	1,785	2,277	2,198	3,391	3,465
4 Apr	2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	1,898	1,943	1,933	1,899	1,961	1,885	1,832	1,934	556	942	1,199	1,799	1,840	3,008	2,978
5 May	1,809	1,804	1,826	1,973	1,975	1,922	2,170	2,261	1,731	1,770	1,781	1,587	1,557	1,504	1,622	1,465	1,609	1,520	1,589	1,611	1,825	2,210	1,994	2,005
6 Jun	982	764	908	1,002	986	53	1,490	-	-	-	-	-	-	-	-	-	-	-	-	1,065	1,373	1,347	1,439	1,654
7 Jul	-	-	-	-	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8 Aug	-	-	-	-	-	962	1,036	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1,311	1,036	1,155
9 Sep	944	771	741	805	942	895	1,076	1,352	-	-	-	-	-	-	-	-	-	-	1,045	1,132	1,148	1,239	1,310	1,329
10 Oct	1,741	1,696	1,751	1,960	1,905	1,889	932	1,237	2,341	1,865	1,357	1,291	1,290	1,412	1,496	1,334	1,585	1,471	-	641	373	426	689	937
11 Nov	1,858	1,957	2,018	2,179	1,955	2,438	1,710	1,609	868	-	-	-	-	-	-	-	-	-	-	-	-	104	507	2,055
12 Dec	2,890	2,951	3,058	3,201	2,974	3,337	2,486	2,520	2,066	1,161	617	363	-	10	79	308	339	629	977	1,124	1,126	1,399	1,601	3,058

ABS Cooling Out																								
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	-	1,275	1,463	1,650	1,856	1,821	1,787	1,736	1,411	-	-	-	-	-	-
5 May	-	-	-	-	-	-	1,770	2,317	2,847	3,257	3,541	3,603	3,689	3,658	3,684	3,530	3,308	2,983	2,454	2,061	1,787	1,668	1,411	1,326
6 Jun	-	-	-	-	-	-	3,325	-	-	-	-	-	-	-	-	-	-	-	-	3,462	3,222	3,052	2,983	2,898
7 Jul	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8 Aug	-	-	-	-	-	3,070	3,598	-	-	-	-	-	-	-	-	-	-	-	-	-	-	3,684	3,581	3,409
9 Sep	1,975	-	-	-	-	1,445	2,043	2,847	-	-	-	-	-	-	-	-	-	-	3,376	2,966	2,607	2,385	2,180	1,975
10 Oct	-	-	-	-	-	-	-	-	1,257	1,787	1,975	2,163	2,351	2,197	2,061	1,907	1,531	1,189	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-



Ocean County College  
CHP Economic Analysis - Additional Generation Capacity

Centrifugal Chiller Energy tons. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 0 to 422.

Centrifugal Chiller Electricity kW. Minimum chiller load = 20%. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 0 to 228.

Total Utility Electric Purchase kW. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 840 to 1,031.

Summary table with columns: Max, per day, per month. Rows 975 to 938.

3,909,341

Total Utility Natural Gas Purchase kBtu/hr. Table with columns 0-23 and rows 1 Jan to 12 Dec. Values range from 3,920 to 2,890.

Summary table with columns: per day, per month. Rows 195,744 to 183,209.

73,995,833

**Ocean County College**  
**CHP Economic Analysis - Additional Generation Capacity**

---

Annual Electricity	10,794,820 kWh/yr	\$0.0656 / kWh
Utility Electricity	3,909,341 kWh/yr	\$0.1812 / kWh
Annual Natural Gas	739,958.33 Th/yr	\$0.7446 / Th
Electric Energy Cost	\$ 641,690.96 /yr	
Demand Cost (Jun-Sep)	\$ 23,413.60 /yr	
Demand Cost (Oct- May)	\$ 43,346.24 /yr	
Natural Gas Cost	\$ 550,966.81 /yr	
Total Utility Cost	\$ 1,259,417.61 /yr	

Ocean County College  
CHP Economic Analysis - Additional Generation Capacity and High Efficiency Exhaust Heat Recovery

Electric primarily from expanded CHP. High efficiency exhaust heat recovery produces hot water when ever possible. Hot water from boilers as needed. All chilled water from centrif chiller.

Cogen Operation on/off table with columns 0-23 and rows for months Jan-Dec.

Cogen Electric Output kW table with columns 0-23 and rows for months Jan-Dec, including 'Added Generation Capacity = 200 kW'.

Summary table with columns Max, per day, per month and rows for months Jan-Dec.

Electric Utility Import - does not include centrifugal chiller plant load kW table with columns 0-23 and rows for months Jan-Dec.

Cogen Fuel Purchase kbtu/hr table with columns 0-23 and rows for months Jan-Dec.

Ocean County College  
CHP Economic Analysis - Additional Generation Capacity and High Efficiency Exhaust Heat Recovery

Heat Recovery Operation		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
Cool/Heat/Off																										
1 Jan	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
2 Feb	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
3 Mar	-	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
4 Apr	-	-	-	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
5 May	-	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
6 Jun	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
7 Jul	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
8 Aug	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
9 Sep	H	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
10 Oct	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
11 Nov	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-
12 Dec	-	-	-	-	-	-	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	H	-

Heat Recovery		Heat exchanger efficiency = 80%																									
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23			
1 Jan	-	-	-	-	-	-	-	2,234	2,305	2,353	2,380	2,384	2,403	2,396	2,373	2,332	2,325	2,362	2,416	2,350	2,250	2,164	2,116	-			
2 Feb	-	-	-	-	-	-	-	2,198	2,300	2,423	2,528	2,546	2,544	2,546	2,528	2,487	2,453	2,419	2,446	2,448	2,373	2,250	2,157	-			
3 Mar	-	-	-	-	-	-	-	-	2,088	2,300	2,325	2,517	2,168	2,168	2,301	2,184	2,199	2,422	2,396	2,339	2,284	2,164	-	-			
4 Apr	-	-	-	-	-	-	-	-	-	1,756	1,797	1,788	1,757	1,814	1,744	1,695	1,789	1,788	2,094	2,230	2,193	2,075	-	-			
5 May	-	-	-	-	-	-	2,007	2,091	1,601	1,637	1,647	1,468	1,440	1,391	1,500	1,355	1,488	1,406	1,470	1,490	1,688	2,044	1,844	1,855			
6 Jun	-	-	-	-	-	1,178	1,378	1,250	1,421	1,218	1,110	1,192	1,119	946	1,079	1,091	1,133	1,093	941	985	1,270	1,246	1,331	1,530			
7 Jul	1,116	855	963	1,120	1,131	1,071	1,193	1,403	1,383	1,103	1,033	1,131	931	1,095	1,028	959	1,071	935	1,274	1,150	1,192	1,361	1,272	1,326			
8 Aug	849	763	725	752	807	890	958	1,157	1,090	1,071	920	918	879	930	855	827	774	845	879	824	971	1,213	958	1,068			
9 Sep	873	-	-	-	-	828	995	1,251	1,408	1,075	966	947	1,067	965	842	864	888	967	1,047	1,062	1,146	1,212	1,229	1,318			
10 Oct	-	-	-	-	-	-	2,142	2,468	2,165	1,725	1,255	1,194	1,193	1,306	1,384	1,234	1,466	1,361	1,498	2,190	1,920	1,881	2,014	2,031			
11 Nov	-	-	-	-	-	-	2,232	2,275	2,045	948	575	458	257	264	351	552	540	748	1,143	1,325	1,171	1,388	1,684	-			
12 Dec	-	-	-	-	-	-	2,123	2,255	2,343	2,360	1,855	1,703	1,389	1,417	1,469	1,678	1,697	1,957	2,270	2,347	2,310	2,321	2,223	-			

Boiler Fuel Purchase																											
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23			
1 Jan	3,920	3,946	4,098	4,222	3,992	4,236	4,398	2,278	2,074	1,533	815	610	126	187	231	509	572	868	1,061	1,102	1,296	1,576	1,602	4,061			
2 Feb	3,742	3,840	3,841	3,830	3,973	4,347	4,479	2,265	1,858	1,244	798	421	302	336	577	630	645	1,028	1,499	1,404	1,438	1,615	1,838	4,212			
3 Mar	3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	1,097	48	-	-	99	-	-	-	-	-	892	576	1,096	1,079	3,391	3,465			
4 Apr	2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	-	-	-	-	-	-	-	-	-	-	-	46	665	768	3,008	2,978		
5 May	1,809	1,804	1,826	1,973	1,975	1,922	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
6 Jun	982	764	908	1,002	986	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
7 Jul	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
8 Aug	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
9 Sep	-	771	741	805	942	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
10 Oct	1,741	1,696	1,751	1,960	1,905	1,889	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
11 Nov	1,858	1,957	2,018	2,179	1,955	2,438	557	432	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	2,055		
12 Dec	2,890	2,951	3,058	3,201	2,974	3,337	1,389	1,355	855	-	-	-	-	-	-	-	-	-	-	-	-	199	452	3,058	-		

ABS Cooling Out																											
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23			
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
4 Apr	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5 May	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
6 Jun	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
7 Jul	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
8 Aug	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
9 Sep	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
10 Oct	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		

Ocean County College  
 CHP Economic Analysis - Additional Generation Capacity and High Efficiency Exhaust Heat Recovery

Centrifugal Chiller Energy																								
tons	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	106	122	138	155	152	149	145	118	-	-	-	-	-	-	-
5 May	106	101	96	-	-	103	148	193	237	271	296	310	310	311	307	294	276	249	205	172	149	139	118	111
6 Jun	226	224	220	210	209	237	277	323	357	381	402	420	422	421	422	410	392	360	330	289	269	254	249	242
7 Jul	311	298	291	286	274	301	341	377	407	434	449	468	475	474	466	459	439	415	391	371	360	345	333	327
8 Aug	281	274	269	263	254	257	300	364	405	431	452	459	461	462	455	444	425	395	365	337	318	307	298	287
9 Sep	165	150	142	135	122	120	170	237	291	330	355	373	378	374	360	344	318	281	247	217	199	182	172	165
10 Oct	-	-	-	-	-	-	-	-	105	149	165	180	196	183	172	159	128	99	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Centrifugal Chiller Electricity																								
kW	Minimum chiller load = 20%																							
	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2 Feb	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3 Mar	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4 Apr	-	-	-	-	-	-	-	-	-	25	29	34	39	38	37	36	28	-	-	-	-	-	-	-
5 May	25	24	23	-	-	25	36	51	69	87	101	111	111	112	109	100	89	75	55	44	37	34	28	26
6 Jun	64	64	62	58	57	69	90	120	147	169	191	211	214	212	214	199	181	150	125	97	85	78	75	71
7 Jul	112	103	98	95	88	105	134	165	196	228	248	136	139	138	271	262	235	206	179	160	150	137	127	123
8 Aug	92	88	85	82	78	79	104	153	195	224	252	262	263	265	256	240	217	184	155	130	116	109	103	96
9 Sep	42	37	35	33	29	29	43	69	98	125	146	161	167	163	150	136	116	92	74	61	53	47	44	42
10 Oct	-	-	-	-	-	-	-	-	25	37	42	47	52	48	44	40	31	24	-	-	-	-	-	-
11 Nov	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12 Dec	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Total Utility Electric Purchase																									
kW	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	
1 Jan	840	786	783	774	771	781	975	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250
2 Feb	812	762	760	751	749	771	970	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250
3 Mar	760	708	705	695	689	748	909	964	250	250	250	250	250	250	250	250	250	250	250	250	250	250	989	883	
4 Apr	708	653	649	638	629	724	847	871	916	275	279	284	289	288	287	286	278	250	250	250	250	250	939	836	
5 May	951	899	891	881	868	980	286	301	319	337	351	361	361	362	359	350	339	325	305	294	287	284	278	276	
6 Jun	1,031	996	985	970	961	319	340	370	397	419	441	461	469	470	464	449	431	400	375	347	335	328	325	321	
7 Jul	362	353	348	345	338	355	384	415	446	486	544	419	430	439	601	598	582	540	497	432	411	387	377	373	
8 Aug	342	338	335	332	328	329	354	403	445	504	587	603	639	639	662	666	641	586	493	442	441	396	353	346	
9 Sep	292	1,036	1,023	1,012	999	279	293	319	348	375	473	503	527	523	522	525	493	459	410	360	365	297	294	292	
10 Oct	909	880	871	857	841	958	250	250	275	287	292	297	302	298	294	290	281	274	250	250	250	250	250	250	
11 Nov	811	767	771	764	762	909	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	947	
12 Dec	826	777	777	769	767	845	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	250	938	

Max	per day	per month	
975	10,639	31	329,809
970	10,504	28	294,112
989	11,550	31	358,050
939	11,926	30	357,780
980	11,245	31	348,595
1031	12,404	30	372,120
601	10,462	31	324,322
666	11,204	31	347,324
1036	12,019	30	360,570
958	10,206	31	316,386
947	9,981	30	299,430
938	9,949	31	308,419

4,016,917

Total Utility Natural Gas Purchase																								
kBtu/hr	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1 Jan	3,920	3,946	4,098	4,222	3,992	4,236	4,398	9,931	9,970	9,593	8,968	8,779	8,356	8,394	8,361	8,499	8,539	8,959	9,338	9,154	9,004	8,983	8,841	4,061
2 Feb	3,742	3,840	3,841	3,830	3,973	4,347	4,479	9,792	9,739	9,544	9,450	9,134	9,007	9,049	9,229	9,145	9,045	9,312	9,876	9,788	9,568	9,323	9,221	4,212
3 Mar	3,196	3,215	3,365	3,468	3,412	3,714	4,349	4,164	8,240	7,929	8,400	8,713	8,682	8,728	8,765	8,614	8,484	8,323	9,099	8,589	8,922	8,486	3,391	3,465
4 Apr	2,943	2,560	2,815	2,905	2,964	3,077	3,452	3,191	2,452	7,256	7,912	8,254	8,361	8,453	8,469	8,430	8,354	8,361	8,029	7,683	8,176	7,863	3,008	2,978
5 May	1,809	1,804	1,826	1,973	1,975	1,922	7,943	8,083	8,407	9,157	9,633	9,794	10,014	9,934	10,014	9,992	9,978	9,883	9,684	9,448	9,433	9,187	8,621	7,542
6 Jun	982	764	908	1,002	986	7,407	9,142	9,232	9,721	10,414	10,832	11,055	11,205	11,205	11,098	11,176	11,183	11,176	11,004	10,868	10,732	10,421	9,919	8,246
7 Jul	7,661	7,511	7,487	7,439	7,399	8,430	10,421	10,378	10,732	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,098	10,710	9,157
8 Aug	7,219	7,320	7,231	7,159	7,079	8,392	10,775	10,494	10,789	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	10,940	9,291
9 Sep	7,207	771	741	805	942	7,928	10,080	10,197	10,472	11,119	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,205	11,162	10,552	8,939
10 Oct	1,741	1,696	1,751	1,960	1,905	1,889	8,400	8,682	8,834	9,396	10,000	10,378	10,552	10,667	10,796	10,832	10,775	10,588	10,479	10,385	10,247	9,706	9,022	7,637
11 Nov	1,858	1,957	2,018	2,179	1,955	2,438	8,202	8,227	8,153	8,803	8,682	9,721	10,029	10,189	10,116	10,204	10,109	9,890	9,596	9,090	8,924	8,476	7,975	2,055
12 Dec	2,890	2,951	3,058	3,201	2,974	3,337	8,653	9,079	8,884	8,438	8,423	8,954	9,142	9,217	9,142	9,120	9,060	9,007	8,947	8,576	8,323	8,150	8,066	3,058

	per day	per month
176,541	31	5,472,784
182,487	28	5,109,643
155,654	31	4,825,275
137,946	30	4,138,374
178,056	31	5,519,742
200,678	30	6,020,345
242,883	31	7,529,373
242,654	31	7,522,274
214,169	30	6,425,081
188,318	31	5,837,846
170,847	30	5,125,402
170,651	31	5,290,181

68,816,320

**Ocean County College**  
**CHP Economic Analysis - Additional Generation Capacity and High Efficiency Exhaust Heat Recovery**

---

Annual Electricity	10,902,396 kWh/yr	\$0.0666 / kWh
Utility Electricity	4,016,917 kWh/yr	\$0.1808 / kWh
Annual Natural Gas	688,163.20 Th/yr	\$0.7446 / Th
Electric Energy Cost	\$ 659,348.81 /yr	
Demand Cost (Jun-Sep)	\$ 23,413.60 /yr	
Demand Cost (Oct- May)	\$ 43,346.24 /yr	
Natural Gas Cost	\$ 512,400.58 /yr	
Total Utility Cost	\$ 1,238,509.23 /yr	

**Ocean County College  
CHP and Central Plant Performance Data**

---

**Engine: Waukesha AGP1000**

Size	1100 kW	(from Manufacturers datasheet)
Fuel Consumption	9481 kBtu/h	(from Manufacturers datasheet)
Heat Rate (LHV)	8619 Btu/kWh	(from Manufacturers datasheet)

Generic 1 MW Recip Performance

Load	100%	75%	50%
Heat Rate	9238	9671	10232 btu/kWh

HR Curve based on the part load performance of multiple 1 MW engines

HR Curve:  $y = 1020x^2 - 3519x + 11737$  (x is % engine load)

A	B	C
1020	-3519	11737


Heat Rate Adjustment (LHV)                      619    Btu/kWh (tuning generic IC curve to AGP1000)

AGP1000 Recip Performance (based on Generic Recip Performance)

Load	100%	75%	50%
Electric	1,100	825	550 kW
Heat Rate	8619	9052	9613 btu/kWh
Fuel In (LHV)	9481	7468	5287 kBtu/hr
Fuel %	100%	79%	56%

Fuel % Curve (used to scale Cogen heat output and ABS output)

m	b
0.000787	0.124412



Minimum utility import                              250 kW  
Minimum engine load                                750 kW

**Ocean County College  
CHP and Central Plant Performance Data**

---

**Absorption Chiller: Broad BHE85**

**Design Performance**

Exhaust In 1637 kBtu/hr  
 JW In 1980 kBtu/hr  
 Elect In 6.8 kW  
 Total In 3640 kBtu/hr

HHW Flow 151 gpm  
 HHW in 160 °F  
 HHW out 180 °F  
 HHW Cap 1510 kBtu/hr

CHW Flow 725 gpm  
 CHW in 54 °F  
 CHW out 44 °F  
 CHW Cap 3625 kBtu/hr

**Actual Condition**

Design Exhaust In 776 °F  
 Actual Exhaust In 750 °F  
 Design Exhaust Out 320 °F  
 Actual Capacity 94%

Design JW In 210 °F  
 Actual JW In 177 °F  
 Design JW Out 198 °F  
 Actual Capacity 0%

**Actual Performance**

Exhaust In 1544 kBtu/hr  
 JW In 0 kBtu/hr  
 Elect In 6.8 kW  
 Total In 1567 kBtu/hr  
 Capacity 43%

HHW Cap 650 kBtu/hr

CHW Cap 1561 kBtu/hr

HHW Eff	41.5%
---------	-------

CHW COP based on plant design data and performce data for a Broad BE chiller

Exh Temp	CHW Temp	CW Temp	ABS Load	COP	
932	44	85	100%	1.5	<<< does SCR design prevents higher Exh Temp ???
775	44	85	75%	1.48	
775	46	85	87%	1.47	
775	45	85	81%	1.475	<<< Ave Design Performance
				2.32	<<< Equivalent kW/ton



**Ocean County College  
CHP and Central Plant Performance Data**

**Chillers: York YMC2**

Size 467 tons  
 Eff 0.582 kW/ton  
 Qnty 3  
 CW Temp 85 °F  
 CHW Temp 44 °F


Curve based on plant design data and single compressor mag chillers  
 kW/ton Curve:  $y = 0.5212x^2 - 0.1944x + 0.2563$  (x is % chiller load)

A	B	C
0.5212	-0.1944	0.2563

Operation / Sequence

55 °F OSA Min load (full OSA econ)  
 20% Min chiller load  
 93.40 Min chiller load (tons)  
 475 Peak load (tons)

Load	10%	15%	20%	25%	30%	35%	40%	45%	50%	55%	60%	65%	70%	75%	80%
kW/ton	0.24	0.237	0.237	0.241	0.247	0.256	0.266	0.278	0.291	0.306	0.321	0.343	0.373	0.404	0.436



**Boilers: Aerco BMK 6000**

Size 5445 kBtu/hr  
 Eff 92.5% (@ 80 to 180)  
 Eff 88.0% Boiler Eff @ 130°F  
 Qnty 4