



# Local Government Energy Audit: Energy Audit Report



Copyright ©2016 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

## South District Police Precinct

City of Jersey City  
191 Bergen Avenue  
Jersey City, NJ 07305

February 19, 2018

Final Report by:  
**TRC Energy Services**

## Disclaimer

---

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

# Table of Contents

---

<b>1</b>	<b>Executive Summary.....</b>	<b>6</b>
1.1	Facility Summary .....	6
1.2	Your Cost Reduction Opportunities.....	6
	Energy Conservation Measures.....	6
	Energy Efficient Practices .....	7
	Self-Generation Measures .....	8
1.3	Implementation Planning.....	8
<b>2</b>	<b>Facility Information and Existing Conditions .....</b>	<b>10</b>
2.1	Project Contacts .....	10
2.2	General Site Information.....	10
2.3	Building Occupancy .....	10
2.4	Building Envelope .....	10
2.5	On-site Generation.....	11
2.6	Energy-Using Systems .....	11
	Lighting System .....	11
	Water/Steam System .....	11
	Air Conditioning System .....	11
	Domestic Hot Water.....	12
	Refrigeration .....	12
	Plug Load & Vending Machines.....	12
2.7	Water-Using Systems .....	12
<b>3</b>	<b>Site Energy Use and Costs.....</b>	<b>13</b>
3.1	Total Cost of Energy .....	13
3.2	Electricity Usage .....	14
3.3	Natural Gas Usage .....	15
3.4	Benchmarking.....	16
3.5	Energy End-Use Breakdown .....	17
<b>4</b>	<b>ENERGY CONSERVATION MEASURES .....</b>	<b>18</b>
4.1	Recommended ECMs .....	18
4.1.1	Lighting Upgrades.....	19
	ECM 1: Install LED Fixtures .....	19
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers .....	20
	ECM 3: Retrofit Fixtures with LED Lamps .....	20
	ECM 4: Install LED Exit Signs.....	21
4.1.2	Lighting Control Measures .....	21
	ECM 5: Install Occupancy Sensor Lighting Controls .....	22
4.1.3	Electric Unitary HVAC Measures .....	22
	ECM 6: Install High Efficiency Electric AC.....	23
4.1.4	Domestic Water Heating Upgrade .....	23

ECM 7: Install Low-Flow DHW Devices.....	23
4.1.5 Plug Load Equipment Control - Vending Machine .....	24
ECM 8: Vending Machine Control .....	24
<b>5 Energy Efficient Practices .....</b>	<b>25</b>
Reduce Air Leakage .....	25
Close Doors and Windows .....	25
Use Window Treatments/Coverings .....	25
Perform Proper Lighting Maintenance.....	25
Ensure Lighting Controls Are Operating Properly .....	25
Perform Routine Motor Maintenance .....	26
Use Fans to Reduce Cooling Load .....	26
Practice Proper Use of Thermostat Schedules and Temperature Resets .....	26
Clean and/or Replace HVAC Filters .....	26
Perform Proper Boiler Maintenance.....	26
Perform Proper Water Heater Maintenance .....	26
Plug Load Controls.....	27
Water Conservation .....	27
<b>6 Self-Generation Measures.....</b>	<b>28</b>
6.1 Photovoltaic.....	28
6.2 Combined Heat and Power .....	29
<b>7 Demand Response .....</b>	<b>30</b>
<b>8 Project Funding / Incentives .....</b>	<b>31</b>
8.1 SmartStart .....	32
8.2 Direct Install .....	33
8.3 Energy Savings Improvement Program.....	33
<b>9 Energy Purchasing and Procurement Strategies .....</b>	<b>35</b>
9.1 Retail Electric Supply Options.....	35
9.2 Retail Natural Gas Supply Options .....	35

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

# Table of Figures

---

Figure 1 – Previous 12 Month Utility Costs..... 6

Figure 2 – Potential Post-Implementation Costs ..... 6

Figure 3 – Summary of Energy Reduction Opportunities ..... 7

Figure 4 – Project Contacts ..... 10

Figure 5 - Building Schedule..... 10

Figure 6 - Utility Summary ..... 13

Figure 7 - Energy Cost Breakdown ..... 13

Figure 8 - Electric Usage & Demand..... 14

Figure 9 - Electric Usage & Demand..... 14

Figure 10 - Natural Gas Usage..... 15

Figure 11 - Natural Gas Usage..... 15

Figure 12 - Energy Use Intensity Comparison – Existing Conditions..... 16

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures ..... 16

Figure 14 - Energy Balance (% and kBtu/SF) ..... 17

Figure 15 – Summary of Recommended ECMs..... 18

Figure 16 – Summary of Lighting Upgrade ECMs..... 19

Figure 17 – Summary of Lighting Control ECMs ..... 21

Figure 18 - Summary of Unitary HVAC ECMs..... 22

Figure 19 - Summary of Domestic Water Heating ECMs ..... 23

Figure 20 - Photovoltaic Screening ..... 28

Figure 21 - Combined Heat and Power Screening ..... 29

Figure 22 - ECM Incentive Program Eligibility..... 31

# I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for South District Police Precinct. The goal of a LGEA is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and put you in a position to implement the ECMs. The LGEA also sets you on the path to receive financial incentives from New Jersey’s Clean Energy Program (NJCEP) for implementing the ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local government in controlling energy costs and protecting our environment by offering a full spectrum of energy management options.

## I.1 Facility Summary

The South District Police Precinct is a single-floor building comprised of 6,000 square feet. Construction of the building was completed in 1954. The building has a flat roof. Exterior walls are finished with brick masonry. The windows are aluminum-framed, double-pane glazed, double-hung units. Exterior doors are constructed of metal and are in good condition.


Interior lighting consists of mainly T8 and T12 fluorescent fixtures and lamps with both electronic and magnetic ballasts. Lighting control is provided by manual wall switches. Heating is provided by one hot water boiler. The cooling system consists of ten window air conditioning units. A thorough description of the facility and our observations are located in Section 2.

## I.2 Your Cost Reduction Opportunities


### Energy Conservation Measures

TRC eight (8) projects which represent an opportunity for South District Police Precinct to reduce annual energy costs by \$3,578 and annual greenhouse gas emissions by 26,532 lbs CO<sub>2</sub>e. The measures would pay for themselves in 5.3 years. The breakdown of existing and potential utility costs is illustrated in Figure 1 and Figure 2, respectively. These projects represent an opportunity to reduce South District Police Precinct’s annual energy use by 9.4%.

*Figure 1 – Previous 12 Month Utility Costs*



*Figure 2 – Potential Post-Implementation Costs*



A detailed description of South District Police Precinct’s existing energy use can be found in Section 3.

The evaluated measures have been listed and grouped into major categories as shown in Figure 3. Brief descriptions of the categories can be found below and descriptions of the individual opportunities can be found in Section 4. Measures without an “ECM #” in the table below have been evaluated, but are not recommended for implementation.

**Figure 3 – Summary of Energy Reduction Opportunities**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>14,626</b>	<b>3.8</b>	<b>0.0</b>	<b>\$2,226.36</b>	<b>\$7,645.28</b>	<b>\$495.00</b>	<b>\$7,150.28</b>	<b>3.21</b>	<b>14,728</b>
ECM 1   Install LED Fixtures	Yes	206	0.1	0.0	\$31.39	\$318.26	\$0.00	\$318.26	10.14	208
ECM 2   Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	8,659	2.5	0.0	\$1,318.05	\$4,545.33	\$0.00	\$4,545.33	3.45	8,719
ECM 3   Retrofit Fixtures with LED Lamps	Yes	5,738	1.2	0.0	\$873.48	\$2,674.13	\$495.00	\$2,179.13	2.49	5,778
ECM 4   Install LED Exit Signs	Yes	23	0.0	0.0	\$3.44	\$107.56	\$0.00	\$107.56	31.26	23
<b>Lighting Control Measures</b>		<b>1,609</b>	<b>0.5</b>	<b>0.0</b>	<b>\$244.99</b>	<b>\$2,126.00</b>	<b>\$355.00</b>	<b>\$1,771.00</b>	<b>7.23</b>	<b>1,621</b>
ECM 5   Install Occupancy Sensor Lighting Controls	Yes	1,609	0.5	0.0	\$244.99	\$2,126.00	\$355.00	\$1,771.00	7.23	1,621
<b>Electric Unitary HVAC Measures</b>		<b>2,060</b>	<b>1.3</b>	<b>0.0</b>	<b>\$313.62</b>	<b>\$8,165.70</b>	<b>\$0.00</b>	<b>\$8,165.70</b>	<b>26.04</b>	<b>2,075</b>
ECM 6   Install High Efficiency Electric AC	Yes	2,060	1.3	0.0	\$313.62	\$8,165.70	\$0.00	\$8,165.70	26.04	2,075
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>52.4</b>	<b>\$495.20</b>	<b>\$394.56</b>	<b>\$0.00</b>	<b>\$394.56</b>	<b>0.80</b>	<b>6,141</b>
ECM 7   Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	52.4	\$495.20	\$394.56	\$0.00	\$394.56	0.80	6,141
<b>Plug Load Equipment Control - Vending Machine</b>		<b>1,954</b>	<b>0.0</b>	<b>0.0</b>	<b>\$297.50</b>	<b>\$1,437.60</b>	<b>\$0.00</b>	<b>\$1,437.60</b>	<b>4.83</b>	<b>1,968</b>
ECM 8   Vending Machine Control	Yes	1,954	0.0	0.0	\$297.50	\$1,437.60	\$0.00	\$1,437.60	4.83	1,968
<b>TOTALS</b>		<b>20,250</b>	<b>5.6</b>	<b>52.4</b>	<b>\$3,577.67</b>	<b>\$19,769.14</b>	<b>\$850.00</b>	<b>\$18,919.14</b>	<b>5.29</b>	<b>26,532</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

**Lighting Upgrades** generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

**Lighting Controls** measures generally involve the installation of automated controls to turn off lights or reduce light output when conditions allow. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

**Electric Unitary HVAC** measures generally involve replacing old inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide cooling equivalent to older air condition systems, but use less energy. These measures save energy by reducing the power used by the air condition system due to improved electrical efficiency.

**Domestic Water Heating** upgrade measures generally involve replacing old inefficient domestic water heating systems with modern energy efficient systems. New domestic water heating systems can provide equivalent or greater capacity as older systems, but use less energy. These measures save energy by reducing the fuel used by the domestic water heating systems due to improved efficiency or the removal of standby losses.

**Plug Load Equipment** control measures generally involve installing automation that limits the power use or operation of equipment plugged into an electrical receptacle based on occupancy.

### Energy Efficient Practices

TRC also identified 13 low (or no) cost energy efficient practices. A facility’s energy performance can be significantly improved by employing certain behavioral and operational adjustments as well as performing routine maintenance on building systems. Through these practices equipment lifetime can be extended;

occupant comfort, health and safety can be improved; and annual energy, operation, and maintenance costs can be reduced. Opportunities identified at South District Police Precinct include:

- Reduce Air Leakage
- Close Doors and Windows
- Use Window Treatments/Coverings
- Perform Proper Lighting Maintenance
- Ensure Lighting Controls Are Operating Properly
- Perform Routine Motor Maintenance
- Use Fans to Reduce Cooling Load
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean and/or Replace HVAC Filters
- Perform Proper Boiler Maintenance
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

### **Self-Generation Measures**

TRC evaluated the potential for installing self-generation sources for South District Police Precinct. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and the self-generation potential, please refer to Section 6.

## **I.3 Implementation Planning**

To realize the energy savings from the ECMs listed in this report, the equipment changes outlined for each ECM need to be selected and installed through project implementation. One of the first considerations is if there is capital available for project implementation. Another consideration is whether to pursue individual ECMs, a group of ECMs, or a comprehensive approach wherein all ECMs are pursued, potentially in conjunction with other facility projects or improvements.

Rebates, incentives, and financing are available from the NJBPU, NJCEP, as well as some of the state's investor-owned utilities, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any project, please review the appropriate incentive program guidelines before proceeding. This is important because in most cases you will need to submit an application for the incentives before purchasing materials and beginning installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities with capital available for implementation of selected individual measures or phasing implementation of selected measures over multiple years, incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to design the ECM(s), select the equipment and apply for the incentive(s). Program pre-approval is required for some SmartStart incentives, so only after receiving approval may the ECM(s) be



installed. The incentive values listed above in Figure 3 represent the SmartStart program and will be explained further in Section 7, as well as the other programs as mentioned below.

This facility also qualifies for the Direct Install program which, through an authorized network of participating contractors, can assist with the implementation of a group of measures versus installing individual measures or phasing implementation. This program is designed to be turnkey and will provide an incentive up to 70% of the cost of the project identified by the designated contractor.

For facilities without capital available to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with external project development, design, and implementation services as well as financing for implementing ECMs. This LGEA report is the first step for participating in ESIP and should help you determine next steps. Refer to Section 8.3 for additional information on the ESIP Program.

Additional descriptions of all relevant incentive programs are located in Section 8 or: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

To ensure projects are implemented such that maximum savings and incentives are achieved, bids and specifications should be reviewed by your procurement personnel and/or consultant(s) to ensure that selected equipment coincides with LGEA recommendations, as well as applicable incentive program guidelines and requirements.

## 2 FACILITY INFORMATION AND EXISTING CONDITIONS

### 2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
<b>Customer</b>			
John Mercer	Assistant Business Administrator	jmercer@cnj.org	201-547-4417
<b>Designated Representative</b>			
PO Frank Ranelli	Facility Police Officer	franelli@njjpf.org	201-547-5454
<b>TRC Energy Services</b>			
Moussa Traore	Auditor	mtraore@trcsolutions.com	732-855-2879

### 2.2 General Site Information

On July 15, 2016, TRC performed an energy audit at South District Police Precinct located in Jersey City, New Jersey. TRC’s auditor met with Police Officer Frank Ranelli to review the facility operations and focus the investigation on specific energy-using systems.

The South District Police Precinct is a 6,000 square foot facility. The building was constructed in 1954. The building is single floor and includes offices, front desk (reception area), locker rooms, and the basement mechanical space.



### 2.3 Building Occupancy

The Police Station is an emergency service building, as a result it is open 24 hours a day, seven (7) days a week. The typical schedule is presented in the table below.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
South District Police Precinct	Weekday	12:00 AM - 12:00 AM
South District Police Precinct	Weekend	12:00 AM - 12:00 AM

### 2.4 Building Envelope

The building’s foundation consists of cast-in-place concrete perimeter wall footings with masonry foundation walls. The foundation system includes reinforced concrete column pads. We noticed moisture in the basement (locker room wall). The Police Station should consider finding a solution to the moisture problem as it may lead to significant damage over time.



The building has a flat roof. We were not able to get access to the roof and cannot describe its condition. Exterior walls are finished with brick masonry. The windows are aluminum-framed, double-pane glazed, double-hung units. They are in good condition and show no signs of outside air infiltration. Exterior doors are constructed of metal and are in good condition. The building envelope was found to be in good condition.

## 2.5 On-site Generation

South District Police Precinct does not have any on-site electric generation capacity.

## 2.6 Energy-Using Systems

### Lighting System

The facility interior lighting consists mostly of T8 and T12 fluorescent lamps and with both electronic and magnetic ballasts. Most of the building spaces use 2, 4-lamp, 4-foot long recessed troffers and T8 U-bend lamps. The police station is a 24-hour facility and much of the lighting remains on all the time. Lighting control is provided by manual wall switches.

Significant energy savings could be achieved by replacing the existing lighting system with LED linear tubes and LED lamps fixtures. Installing occupancy sensors in select areas will yield additional energy savings.

Please refer to Appendix A: Equipment Inventory & Recommendations for an inventory of your equipment.

### Water/Steam System

Hot water for heating is supplied by one (1) gas-fired, non-condensing hot water boiler located in the basement (boiler room). The boiler has rated output capacity of 528 MBH. Hot water is distributed by a two-pipe system to radiators. A single manual thermostat controlled the temperature.



### Air Conditioning System

There are ten (10) window AC units, none of which are ENERGY STAR labeled. The four (4) units that serve the front desk, captain's office, supervisor's office, and the gymnasium have been proposed for replacement as they were observed running with a minimum efficiency. When the remaining units are in need of replacement, the facility should consider replacing with ENERGY STAR® labeled air conditioners.



### Domestic Hot Water

The domestic hot water system consists of one (1) Rheem gas-fired, non-condensing hot water heater with an input rating of 50 kBtu/hr and a nominal efficiency of 68%. The water heater is in good condition

### Refrigeration

The Front Desk has one refrigerator that was running in good condition.

### Plug Load & Vending Machines

There are 25 computer work stations in the facility and the computers are desktop units with LCD monitors. There is no centralized PC power management software installed. There are two (2) vending machines located near the front desk.



## 2.7 Water-Using Systems

There are four (4) restrooms at this facility. Faucets are rated for 2.5 gallons per minute (gpm), the toilets are rated at 2.5 gallons per flush (gpf) and the urinals are rated at 2 gpf.

### 3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost/ft<sup>2</sup> and energy use/ft<sup>2</sup>. These energy use indices are indicative of the relative energy effectiveness of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy use for other facilities identified as: Emergency Services. Specific local climate conditions, daily occupancy hours of the facility, seasonal fluctuations in occupancy, daily operating hours of energy use systems, and the behavior of the occupants with regard to operating systems that impact energy use such as turning off appliances and leaving windows open. Please refer to the Benchmarking section within Section 3.4 for additional information.

#### 3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12 month period of utility usage data that was provided for each utility. The annual consumption and cost was developed from this information.

*Figure 6 - Utility Summary*

Utility Summary for South District Police Precinct		
Fuel	Usage	Cost
Electricity	107,814 kWh	\$17,469
Natural Gas	9,290 Therms	\$8,772
<b>Total</b>		<b>\$26,241</b>

The current utility cost for this site is \$26,241 as shown in the chart below.

*Figure 7 - Energy Cost Breakdown*



### 3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost (combined for commodity, transmission and distribution) for the past 12 months is \$0.152/kWh, which is the blended rate used throughout the analyses in this report. The monthly electricity consumption and peak demand is represented graphically in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for South District Police Precinct					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
11/18/15	29	7,261	19	\$81	\$874
10/20/15	29	7,897	21	\$92	\$968
9/21/15	32	12,428	25	\$109	\$2,354
8/20/15	29	12,248	25	\$109	\$2,377
7/22/15	30	12,106	27	\$115	\$2,523
6/22/15	32	10,813	24	\$105	\$2,292
5/21/15	28	6,760	17	\$75	\$943
4/23/15	31	7,248	17	\$76	\$991
3/23/15	31	7,735	17	\$74	\$1,034
2/20/15	29	7,265	16	\$70	\$975
1/22/15	34	8,427	17	\$73	\$1,099
12/19/14	31	7,626	18	\$79	\$1,039
<b>Totals</b>	<b>365</b>	<b>107,814</b>	<b>27</b>	<b>\$1,058</b>	<b>\$17,469</b>
<b>Annual</b>	<b>365</b>	<b>107,814</b>	<b>27</b>	<b>\$1,058</b>	<b>\$17,469</b>

### 3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.944/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is represented graphically in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for South District Police Precinct			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
11/18/15	29	83	\$74
10/20/15	29	19	\$27
9/21/15	32	18	\$25
8/20/15	29	22	\$28
7/22/15	30	22	\$28
6/22/15	32	53	\$51
5/21/15	28	459	\$366
4/23/15	31	1,310	\$1,158
3/23/15	31	2,594	\$2,353
2/20/15	29	2,306	\$2,202
1/22/15	34	1,472	\$1,529
12/19/14	31	930	\$929
<b>Totals</b>	<b>365</b>	<b>9,290</b>	<b>\$8,772</b>
<b>Annual</b>	<b>365</b>	<b>9,290</b>	<b>\$8,772</b>

### 3.4 Benchmarking

This facility was benchmarked through Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and compares its performance against a yearly baseline, national medians, or similar buildings in your portfolio. Metrics used in this comparison are the energy use intensity (EUI) and ENERGY STAR® Score.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more energy than similar buildings on a square foot basis or if that building performs better than the median. EUI is presented in both site energy and source energy. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy is the raw fuel consumed to generate the energy consumed at the site, factoring in energy production and distribution losses.

**Figure 12 - Energy Use Intensity Comparison – Existing Conditions**

Energy Use Intensity Comparison - Existing Conditions		
	South District Police Precinct	National Median Building Type: Emergency Services
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	355.1	154.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	216.1	88.3

By implementing all recommended measures covered in this reporting, the Project’s estimated post-implementation EUI improves as shown in the table below:

**Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures**

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	South District Police Precinct	National Median Building Type: Emergency Services
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	309.8	154.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	195.9	88.3

Many buildings can also receive a 1 – 100 ENERGY STAR® score. This score compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide — and may be eligible for ENERGY STAR® certification. This building type does not currently qualify to receive a score. The Portfolio Manager, Statement of Energy Performance can be found in Appendix B: ENERGY STAR® Statement of Energy Performance.


A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.



### 3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building and determine their proportional contribution to overall building energy usage. This visual representation of energy end uses highlights systems that may benefit most from energy efficiency projects.

*Figure 14 - Energy Balance (% and kBtu/SF)*



## 4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify potential energy projects, help prioritize specific measures for implementation, and set South District Police Precinct on the path to receive financial incentives. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is considered sufficient to make decisions and to prioritize energy projects. Savings are based on the New Jersey Board of Public Utilities New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016. Further analysis or investigation may be required to calculate more accurate savings to support any custom SmartStart, Pay for Performance, or Large Energy Users incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJ prescriptive SmartStart program. Depending on your implementation strategy, the project may be eligible for more lucrative incentives through other programs as identified in Section 7.

The following sections describe the evaluated measures.

### 4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

*Figure 15 – Summary of Recommended ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>14,626</b>	<b>3.8</b>	<b>0.0</b>	<b>\$2,226.36</b>	<b>\$7,645.28</b>	<b>\$495.00</b>	<b>\$7,150.28</b>	<b>3.21</b>	<b>14,728</b>
ECM 1	Install LED Fixtures	206	0.1	0.0	\$31.39	\$318.26	\$0.00	\$318.26	10.14	208
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	8,659	2.5	0.0	\$1,318.05	\$4,545.33	\$0.00	\$4,545.33	3.45	8,719
ECM 3	Retrofit Fixtures with LED Lamps	5,738	1.2	0.0	\$873.48	\$2,674.13	\$495.00	\$2,179.13	2.49	5,778
ECM 4	Install LED Exit Signs	23	0.0	0.0	\$3.44	\$107.56	\$0.00	\$107.56	31.26	23
<b>Lighting Control Measures</b>		<b>1,609</b>	<b>0.5</b>	<b>0.0</b>	<b>\$244.99</b>	<b>\$2,126.00</b>	<b>\$355.00</b>	<b>\$1,771.00</b>	<b>7.23</b>	<b>1,621</b>
ECM 5	Install Occupancy Sensor Lighting Controls	1,609	0.5	0.0	\$244.99	\$2,126.00	\$355.00	\$1,771.00	7.23	1,621
<b>Electric Unitary HVAC Measures</b>		<b>2,060</b>	<b>1.3</b>	<b>0.0</b>	<b>\$313.62</b>	<b>\$8,165.70</b>	<b>\$0.00</b>	<b>\$8,165.70</b>	<b>26.04</b>	<b>2,075</b>
ECM 6	Install High Efficiency Electric AC	2,060	1.3	0.0	\$313.62	\$8,165.70	\$0.00	\$8,165.70	26.04	2,075
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>52.4</b>	<b>\$495.20</b>	<b>\$394.56</b>	<b>\$0.00</b>	<b>\$394.56</b>	<b>0.80</b>	<b>6,141</b>
ECM 7	Install Low-Flow Domestic Hot Water Devices	0	0.0	52.4	\$495.20	\$394.56	\$0.00	\$394.56	0.80	6,141
<b>Plug Load Equipment Control - Vending Machine</b>		<b>1,954</b>	<b>0.0</b>	<b>0.0</b>	<b>\$297.50</b>	<b>\$1,437.60</b>	<b>\$0.00</b>	<b>\$1,437.60</b>	<b>4.83</b>	<b>1,968</b>
ECM 8	Vending Machine Control	1,954	0.0	0.0	\$297.50	\$1,437.60	\$0.00	\$1,437.60	4.83	1,968
<b>TOTALS</b>		<b>20,250</b>	<b>5.6</b>	<b>52.4</b>	<b>\$3,577.67</b>	<b>\$19,769.14</b>	<b>\$850.00</b>	<b>\$18,919.14</b>	<b>5.29</b>	<b>26,532</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

## 4.1.1 Lighting Upgrades

Lighting Upgrades include several “submeasures” as outlined in Figure 16 below.

*Figure 16 – Summary of Lighting Upgrade ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>14,626</b>	<b>3.8</b>	<b>0.0</b>	<b>\$2,226.36</b>	<b>\$7,645.28</b>	<b>\$495.00</b>	<b>\$7,150.28</b>	<b>3.21</b>	<b>14,728</b>
ECM 1	Install LED Fixtures	206	0.1	0.0	\$31.39	\$318.26	\$0.00	\$318.26	10.14	208
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	8,659	2.5	0.0	\$1,318.05	\$4,545.33	\$0.00	\$4,545.33	3.45	8,719
ECM 3	Retrofit Fixtures with LED Lamps	5,738	1.2	0.0	\$873.48	\$2,674.13	\$495.00	\$2,179.13	2.49	5,778
ECM 4	Install LED Exit Signs	23	0.0	0.0	\$3.44	\$107.56	\$0.00	\$107.56	31.26	23

### **ECM 1: Install LED Fixtures**

#### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	206	0.1	0.0	\$31.39	\$318.26	\$0.00	\$318.26	10.14	208
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0

#### *Measure Description*

This measure evaluates replacing existing fixtures containing fluorescent (excluding T12), HID, and incandescent lamps with new high performance LED light fixtures. This measure saves energy by installing LED sources which use less power than other technologies with a comparable light output.

Maintenance savings are anticipated since LED sources have burn hours which are generally more than twice that of a fluorescent source and more than ten (10) times incandescent sources. Maintenance savings may be partially offset by the higher material costs associated with LED sources.

During planning and design for the installation of new fixtures, we recommend a holistic approach that considers both the technology of the lighting sources and how they are controlled.

## **ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers**

### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	8,659	2.5	0.0	\$1,318.05	\$4,545.33	\$0.00	\$4,545.33	3.45	8,719
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0

### *Measure Description*

This measure evaluates replacing linear fluorescent T12 lamps, ballasts, and reflectors with LED tube lamps, reflectors, and drivers specifically designed for existing linear fluorescent fixtures. The retrofit uses the existing fixture housing but replaces the rest of the components with an efficient source and reflectors designed for LEDs. This measure saves energy by installing LED sources which use less power than other technologies with a comparable light output and efficiently projects the light into the space.

Maintenance savings are anticipated since LED sources have burn hours which are more than twice that of a fluorescent source. Maintenance savings may be partially offset by the higher material costs associated with LED sources.

During retrofit planning and design, we recommend a holistic approach that considers both the technology of the lighting sources and how they are controlled.

## **ECM 3: Retrofit Fixtures with LED Lamps**

### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	5,738	1.2	0.0	\$873.48	\$2,674.13	\$495.00	\$2,179.13	2.49	5,778
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0

### *Measure Description*

This measure evaluates replacing linear T8 fluorescent lamps with LED tube lamps and replacing incandescent and halogen screw-in/plug-in based lamps with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed although there is a fluorescent fixture ballast in place. Other tube lamps require that fluorescent fixture ballasts be removed or replaced with LED drivers. Screw-in/plug-in LED lamps can be used as a direct replacement for most other screw-in/plug-in lamps. This measure saves energy by installing LED sources which use less power than other technologies with a comparable light output.

Maintenance savings are anticipated since LED sources have burn hours which are more than twice that of a fluorescent source and more than ten (10) times incandescent sources. LED lamps that use the existing fluorescent fixture ballast will be constrained by the remaining hours of the ballast. Maintenance savings may be partially offset by the higher material costs associated with LED sources.

During retrofit planning and design, we recommend a holistic approach that considers both the technology of the lighting sources and how they are controlled.

#### **ECM 4: Install LED Exit Signs**

##### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	23	0.0	0.0	\$3.44	\$107.56	\$0.00	\$107.56	31.26	23
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0

##### *Measure Description*

This measure evaluates replacing incandescent and compact fluorescent lighting in exit signs with LEDs. LED sources require virtually no maintenance and LED exit signs have a life expectancy of at least 20 years. Many manufacturers can provide retrofit kits that meet fire and safety code requirements. Retrofit kits are less expensive and simpler to install than replacement signs, however, new fixtures would have a longer useful life and are therefore recommended.

A reduction in maintenance costs will be realized with the proposed retrofit because lamps will not have to be replaced as frequently.

#### **4.1.2 Lighting Control Measures**

Lighting control measures include several “submeasures” as outlined in Figure 17 below.

**Figure 17 – Summary of Lighting Control ECMs**

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>		<b>1,609</b>	<b>0.5</b>	<b>0.0</b>	<b>\$244.99</b>	<b>\$2,126.00</b>	<b>\$355.00</b>	<b>\$1,771.00</b>	<b>7.23</b>	<b>1,621</b>
ECM 5	Install Occupancy Sensor Lighting Controls	1,609	0.5	0.0	\$244.99	\$2,126.00	\$355.00	\$1,771.00	7.23	1,621

## ECM 5: Install Occupancy Sensor Lighting Controls

### Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
1,609	0.5	0.0	\$244.99	\$2,126.00	\$355.00	\$1,771.00	7.23	1,621

### Measure Description

This measure evaluates installing occupancy sensors to control light fixtures that are currently manually controlled in restrooms, storage rooms, and private offices. Sensors detect occupancy using ultrasonic and/or infrared wave technologies. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Occupants will also be able to manually turn off fixtures. Energy savings result from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. Ceiling-mounted or remote-mounted sensors require the use of low voltage switching relays or a wireless signal to the switch. In general, use wall switch replacement sensors for single occupant offices and other small rooms. Install ceiling-mounted or remote mounted sensors in locations without local switching, in situations where the existing wall switches are not in the line-of-sight of the main work area, and in large spaces. We recommend a holistic design approach that considers both the technology of the lighting sources and how they are controlled.

Maintenance savings are anticipated due to reduced lamp operation, however, additional maintenance costs may be incurred because the occupancy sensors may require periodic adjustment; it is anticipated that the net effect on maintenance costs will be negligible.

### 4.1.3 Electric Unitary HVAC Measures

Unitary HVAC measures include several “submeasures” as outlined in Figure 18 below.

Figure 18 - Summary of Unitary HVAC ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Electric Unitary HVAC Measures</b>	<b>2,060</b>	<b>1.3</b>	<b>0.0</b>	<b>\$313.62</b>	<b>\$8,165.70</b>	<b>\$0.00</b>	<b>\$8,165.70</b>	<b>26.04</b>	<b>2,075</b>
ECM 6   Install High Efficiency Electric AC	2,060	1.3	0.0	\$313.62	\$8,165.70	\$0.00	\$8,165.70	26.04	2,075

## ECM 6: Install High Efficiency Electric AC

### Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
2,060	1.3	0.0	\$313.62	\$8,165.70	\$0.00	\$8,165.70	26.04	2,075

### Measure Description

This measure evaluates replacing window air conditioners with high efficiency window air conditioners. There have been significant improvements in both compressor and fan motor efficiencies in the past several years. Therefore, electricity savings can be achieved by replacing old units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the old and new unit, the cooling load, and the annual operating hours.

## 4.1.4 Domestic Water Heating Upgrade

Domestic water heating measures include several “submeasures” as outlined in Figure 19 below.

Figure 19 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Domestic Water Heating Upgrade	0	0.0	52.4	\$495.20	\$394.56	\$0.00	\$394.56	0.80	6,141
ECM 7   Install Low-Flow Domestic Hot Water Devices	0	0.0	52.4	\$495.20	\$394.56	\$0.00	\$394.56	0.80	6,141

## ECM 7: Install Low-Flow DHW Devices

### Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
0	0.0	52.4	\$495.20	\$394.56	\$0.00	\$394.56	0.80	6,141

### Measure Description

This measure evaluates the savings from installing low flow domestic water devices to reduce overall water flow in general and hot water flow in particular. Low flow showerheads and faucet aerators reduce the water flow, relative to standard showerheads and aerators, from the fixture. Pre-rinse spray valves—often used in commercial and institutional kitchens—are designed to remove food waste from dishes prior to dishwashing. Replacing standard pre-rinse spray valves with low flow valves will reduce water use.

Installing low flow faucets or faucet aerators, low flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

#### 4.1.5 Plug Load Equipment Control - Vending Machine

##### **ECM 8: Vending Machine Control**

###### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
1,954	0.0	0.0	\$297.50	\$1,437.60	\$0.00	\$1,437.60	4.83	1,968

###### *Measure Description*

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor based controls to reduce the energy use. These controls power down the machine when the surrounding area is vacant, then monitor the surrounding temperature and power up the cooling system at regular intervals to keep the product cool. Savings are a function of the activity level around the vending machine.



## 5 ENERGY EFFICIENT PRACTICES

---

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of low or no-cost efficiency strategies. By employing certain behavioral and operational adjustments as well as performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and annual energy, operation, and maintenance costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

### Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

### Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

### Use Window Treatments/Coverings

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

### Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

### Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

## **Perform Routine Motor Maintenance**

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

## **Use Fans to Reduce Cooling Load**

Utilizing ceiling fans to supplement cooling is a low cost strategy to reduce cooling load considerably. Thermostat settings can be increased by 4°F with no change in overall occupant comfort when the wind chill effect of moving air is employed for cooling.

## **Practice Proper Use of Thermostat Schedules and Temperature Resets**

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

## **Clean and/or Replace HVAC Filters**

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

## **Perform Proper Boiler Maintenance**

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up in order to sustain efficiency and equipment life.

## **Perform Proper Water Heater Maintenance**

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any

signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

### **Plug Load Controls**

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips.

### **Water Conservation**

Installing dual flush or low flow toilets and low flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gpf and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard). Refer to Section 4.1.4 for any low-flow ECM recommendations.

## 6 SELF-GENERATION MEASURES

Self-generation measures include both renewable (e.g., solar, wind) and non-renewable (e.g., microturbines) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


### 6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a low potential for installing a PV array.

In order to be cost-effective, a solar PV array generally needs a minimum of 4,000 square feet of flat or south-facing rooftop, or other unshaded space, on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

**Figure 20 - Photovoltaic Screening**



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-fags>
- **Approved Solar Installers in the NJ Market:** [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1)

## 6.2 Combined Heat and Power

In non-industrial settings, combined heat and power (CHP) is the on-site generation of electricity and recovery of heat which is put to beneficial use. Common prime movers in CHP applications include reciprocating engines, microturbines, fuel cells, and (at large facilities) gas turbines. Electricity is typically interconnected to the sites local distribution system. Heat is recovered from the exhaust stream and the ancillary cooling system and interconnected to the existing hot water (or steam) distribution system.


CHP systems are typically used to produce a portion of the electricity needed by a facility, with the balance of electric needs satisfied by purchase from the grid. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility’s ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a low potential for installing a cost-effective CHP system.

Lack of space near the existing thermal generation are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in NJ specializing in commercial CHP cost assessment and installation, go to: [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/.](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/)

**Figure 21 - Combined Heat and Power Screening**



## 7 DEMAND RESPONSE

---

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for Mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

## 8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and others, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s 1999 Electricity Restructuring Law which requires all customers of investor-owned electric and gas utilities to pay this charge on their monthly energy bills. As a contributor to the fund you were able to participate in the LGEA program and are also eligible to utilize the equipment incentive programs. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 22 for a list of the eligible programs identified for each recommended ECM.

*Figure 22 - ECM Incentive Program Eligibility*

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install
ECM 1	Install LED Fixtures			x
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers			x
ECM 3	Retrofit Fixtures with LED Lamps	x		x
ECM 4	Install LED Exit Signs			x
ECM 5	Install Occupancy Sensor Lighting Controls	x		x
ECM 6	Install High Efficiency Electric AC			x
ECM 7	Install Low-Flow Domestic Hot Water Devices			x
ECM 8	Vending Machine Control			x

SmartStart is generally well suited for implementation of individual or small sets of measures, with the flexibility to install projects at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities to bundle measures and simplify participation, but requires the use of pre-approved contractors.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent comparison of available incentives.

Brief descriptions of all relevant alternative financing and incentive programs are located in the sections below. You may also check the following website for further information, including most current program availability, requirements, and incentive levels: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 8.1 SmartStart

### Overview

The SmartStart program is comprised of new construction and retrofit components that offer incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives for various energy efficiency equipment based on national/market trends, new technologies or changes in efficiency baselines.

### **Prescriptive Equipment Incentives Available:**

*Electric Chillers*

*Electric Unitary HVAC*

*Gas Cooling*

*Gas Heating*

*Gas Water Heating*

*Ground Source Heat Pumps*

*Lighting*

*Lighting Controls*

*Refrigeration Doors*

*Refrigeration Controls*

*Refrigerator/Freezer Motors*

*Food Service Equipment*

*Variable Frequency Drives*

All customer sizes and types may be served by this program. This program provides an effective mechanism for securing incentives for individual projects that may be completed at once or over several years.

### Incentives

The prescriptive path provides fixed incentives for specific energy efficiency measures whereas the custom measure path provides incentives for unique or specialized technologies that are not addressed through prescriptive offerings.

Since your facility is an existing building, only the Retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at the lesser of 50% of the total installed incremental project cost, or a buy down to a one year payback. Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

### How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB).



## 8.2 Direct Install

### Overview

Direct Install is a turnkey program available to existing small to mid-sized facilities with a peak electric demand that did not exceed 200 kW in the preceding 12 months. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and install those measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

### Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

### How to Participate

To participate in the Direct Install program you will need to contact the participating contractor assigned to the county where your facility is located; a complete list is provided on the Direct Install website identified below. The contractor will be paid the program incentive directly which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps mentioned above, and the remaining 30% of the cost is your responsibility to the contractor.

Since Direct Install offers a free assessment, LGEA applicants that do not meet the audit program eligibility requirements, but do meet the Direct Install requirements, may be moved directly into this program.

Detailed program descriptions and applications can be found at: [www.njcleanenergy.com/DI](http://www.njcleanenergy.com/DI).

## 8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: [www.njcleanenergy.com/ESIP](http://www.njcleanenergy.com/ESIP).

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize the incentive programs to help further reduce costs when compiling the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

## 9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

### 9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

# Appendix A: Equipment Inventory & Recommendations

## Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Front Entrance	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,000	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,000	0.03	149	0.0	\$22.71	\$58.50	\$10.00	2.14
Front Entrance	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,000	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,000	0.01	79	0.0	\$12.04	\$35.90	\$5.00	2.57
Front Desk	14	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	4,000	Relamp	No	14	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	4,000	0.64	3,544	0.0	\$539.43	\$1,331.87	\$280.00	1.95
Supervisor Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.22	765	0.0	\$116.45	\$439.67	\$20.00	3.60
Supervisor Room	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,500	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,500	0.02	82	0.0	\$12.47	\$63.20	\$0.00	5.07
Evidence Room	2	CFL Screw-In Lamps: Recessed CAN 1x13W	Wall Switch	13	2,500	Fixture Replacement	Yes	2	LED - Fixtures: Downlight Solid State Retrofit	Occupancy Sensor	5	1,750	0.02	54	0.0	\$8.17	\$243.30	\$20.00	27.33
Captain's Office	4	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.44	1,530	0.0	\$232.91	\$763.33	\$20.00	3.19
Captain's Office Bathroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,500	Relamp	Yes	1	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,750	0.03	110	0.0	\$16.73	\$179.20	\$20.00	9.52
Clerk Office	6	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	2,500	Relamp & Reballast	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,750	0.33	1,148	0.0	\$174.68	\$818.00	\$20.00	4.57
Holding Cell	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.22	765	0.0	\$116.45	\$439.67	\$20.00	3.60
Holding Cell	1	CFL Screw-In Lamps: Ceiling Mounted 26W	Wall Switch	26	2,500	Fixture Replacement	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	9	2,500	0.01	48	0.0	\$7.31	\$63.65	\$0.00	8.71
Detective Com Office	4	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.44	1,530	0.0	\$232.91	\$763.33	\$20.00	3.19
Detective Com Office	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,500	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,500	0.02	82	0.0	\$12.47	\$63.20	\$0.00	5.07
Detective Com Office Bath	1	CFL Screw-In Lamps: Ceiling Mounted 26W	Wall Switch	26	2,500	Fixture Replacement	Yes	1	LED - Fixtures: Downlight Solid State Retrofit	Occupancy Sensor	9	1,750	0.02	56	0.0	\$8.47	\$179.65	\$20.00	18.85
Investigation Office	5	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	Yes	5	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.55	1,913	0.0	\$291.13	\$925.17	\$20.00	3.11
Interview Room	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,500	Relamp	Yes	1	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,750	0.03	110	0.0	\$16.73	\$179.20	\$20.00	9.52
Executive Office	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.22	765	0.0	\$116.45	\$439.67	\$20.00	3.60
Communication Room	1	CFL Screw-In Lamps: Spiral CFL 32W	Wall Switch	32	2,500	Fixture Replacement	Yes	1	LED - Fixtures: Downlight Solid State Retrofit	Occupancy Sensor	9	1,750	0.02	73	0.0	\$11.05	\$179.65	\$20.00	14.45
Basement Stairway	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,500	0.10	333	0.0	\$50.74	\$161.83	\$0.00	3.19
Men's locker Room (Basement)	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,500	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.12	415	0.0	\$63.13	\$306.27	\$60.00	3.90
Women's Locker Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,500	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.12	415	0.0	\$63.13	\$306.27	\$60.00	3.90
Men's Bathroom	1	Linear Fluorescent - T12: 8' T12 (75W) - 1L	Wall Switch	92	2,500	Relamp & Reballast	Yes	1	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	1,750	0.05	189	0.0	\$28.73	\$282.00	\$20.00	9.12
Men's Bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,500	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,750	0.03	118	0.0	\$17.93	\$174.50	\$30.00	8.06
Men's Locker Room 2 (Basement)	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,500	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,750	0.24	829	0.0	\$126.26	\$650.53	\$115.00	4.24
Men's Locker Room 2 (Basement)	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,500	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,500	0.08	280	0.0	\$42.57	\$175.50	\$30.00	3.42

Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis											
Location	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	2,500	Relamp & Reballast	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,500	0.19	667	0.0	\$101.49	\$323.67	\$0.00	3.19
Storage Room	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	2,500	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,500	0.05	167	0.0	\$25.37	\$117.00	\$0.00	4.61
Front Desk	1	Exit Signs: Incandescent	Wall Switch	14	2,500	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	Wall Switch	6	2,500	0.01	23	0.0	\$3.44	\$107.56	\$0.00	31.26

### Motor Inventory & Recommendations

Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis										
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Building	1	Heating Hot Water Pump	1.0	79.0%	No	2,745	No	79.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Electric HVAC Inventory & Recommendations

Existing Conditions		Proposed Conditions											Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Front Desk	Front Desk	1	Window AC	2.00		Yes	1	Window AC	2.00		12.00		No	0.30	477	0.0	\$72.65	\$2,177.52	\$0.00	29.97
Supervisor Room	Supervisor Room	1	Window AC	1.67		Yes	1	Window AC	1.50		12.00		No	0.38	602	0.0	\$91.58	\$1,633.14	\$0.00	17.83
Capitaine Office	Capitaine Office	1	Window AC	2.00		Yes	1	Window AC	2.00		12.00		No	0.30	477	0.0	\$72.65	\$2,177.52	\$0.00	29.97
Clerk Office	Clerk Office	1	Window AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Detective Com Office	Detective Com Office	1	Window AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Investigation Office	Investigation Office	1	Window AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Executif Office	Executif office	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Gym Room	Gym Room	1	Window AC	2.00		Yes	1	Window AC	2.00		12.00		No	0.32	504	0.0	\$76.74	\$2,177.52	\$0.00	28.38
Women's Locker Room	Women's Locker Room	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Men's Locker Room	Men's Locker Room	1	Window AC	1.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Precinct	1	Non-Condensing Hot Water Boiler	528.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis					
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement	Precinct	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis							
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Bathrooms	3	Faucet Aerator (Lavatory)	2.50	1.00	0.00	0	6.4	\$60.39	\$21.51	\$0.00	0.36	
Bathrooms	3	Pre-Rinse Spray Valve	2.50	1.15	0.00	0	46.1	\$434.81	\$373.05	\$0.00	0.86	

### Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis							
	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Front Desk	1	Stand-Up Refrigerator, Solid Door (16 - 30 cu. ft.)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	

### Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Front Desk	1	Flat screen TV	128.0	Yes
Front Desk	1	Office Multi Function Printer	1,440.0	Yes
Front Desk	1	Office Multi Function Printer	1,440.0	Yes
Front Desk	9	Desktop	110.0	Yes
Front Desk	1	Office Coffee Machine	700.0	Yes
Front Desk	1	Microwave	1,000.0	No
Supervisor Room	1	Flat screen TV	128.0	Yes
Captain's Office	1	Desktop	110.0	Yes
Captain's Office	1	Microwave	1,000.0	No
Clerk Office	4	Desktop	110.0	Yes
Clerk Office	1	Office Multi Function Printer	760.0	Yes
Clerk Office	1	Paper Schredder Machine	300.0	Yes
Clerk Office	1	Small Freezer	45.0	Yes
Clerk Office	1	Flat screen TV	128.0	Yes
Detective Com Office	1	Small Office Printer	20.0	Yes
Detective Com Office	1	Desktop	110.0	Yes
Detective Com Office	1	Paper Schredder Machine	300.0	Yes
Investigation Office	8	Desktop	110.0	Yes
Investigation Office	1	Fax Machine	45.0	Yes
Investigation Office	1	Office Multi Function Printer	1,440.0	Yes
Investigation Office	1	Small Office Printer	760.0	Yes
Investigation Office	1	Toaster Machine	800.0	Yes
Investigation Office	1	Flat screen TV	128.0	Yes
Investigation Office	1	Small Freezer	45.0	Yes
Investigation Office	1	Microwave	1,000.0	No
Executif Office	1	Small Office Printer	760.0	Yes
Executif Office	2	Desktop	110.0	Yes
Executif Office	1	Flat screen TV	128.0	Yes
Gym Room	1	Flat screen TV	128.0	Yes
Men's Locker Room	1	Microwave	1,000.0	No
Men's Locker Room	1	Microwave	1,000.0	No
Men's Locker Room	1	Flat screen TV	128.0	Yes
Men's Locker Room	1	Small Freezer	45.0	Yes
Women's Locker Room	1	Microwave	1,000.0	No

### Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Front Desk	1	Non-Refrigerated	Yes	0.00	343	0.0	\$52.14	\$718.80	\$0.00	13.79
Front Desk	1	Refrigerated	Yes	0.00	1,612	0.0	\$245.36	\$718.80	\$0.00	2.93



# Appendix B: ENERGY STAR® Statement of Energy Performance

## ENERGY STAR® Statement of Energy Performance

LEARN MORE AT [energystar.gov](http://energystar.gov)

N/A

### South District Police Precinct

**Primary Property Type:** Police Station  
**Gross Floor Area (ft²):** 6,000  
**Built:** 1954

**For Year Ending:** October 31, 2015  
**Date Generated:** November 29, 2016

**ENERGY STAR® Score<sup>1</sup>**

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
<b>Property Address</b>	<b>Property Owner</b>	<b>Primary Contact</b>
South District Police Precinct 191 Bergen Ave Jersey City, New Jersey 07305	_____	_____
	( ) - _____	( ) - _____
<b>Property ID:</b> 5082938		

Energy Consumption and Energy Use Intensity (EUI)			
<b>Site EUI</b> 110 kBtu/ft²	<b>Annual Energy by Fuel</b>		<b>National Median Comparison</b>
	Natural Gas (kBtu)	293,381 (44%)	National Median Site EUI (kBtu/ft²)
	Electric - Grid (kBtu)	366,569 (56%)	National Median Source EUI (kBtu/ft²)
			69.8
			154.4
			58%
<b>Source EUI</b> 243.2 kBtu/ft²			<b>Annual Emissions</b>
			Greenhouse Gas Emissions (Metric Tons CO2e/year)
			58

### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**Licensed Professional**

\_\_\_\_\_  
 ( ) - \_\_\_\_\_  
 \_\_\_\_\_



**Professional Engineer Stamp (if applicable)**