



Local Government Energy Audit: Energy Audit Report



Copyright ©2017 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Clearview Administration Building

420 Cedar Road

Mullica Hill, NJ 08062

Clearview Regional High School

District

May 2, 2018

Final Report by: **TRC Energy Services**

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	5
2.1	Project Contacts	5
2.2	General Site Information.....	5
2.3	Building Occupancy	5
2.4	Building Envelope	5
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems	6
	Lighting System	6
	Hot Water Heating System.....	7
	Packaged Heating and Direct Expansion Air Conditioning System (DX).....	7
	Domestic Water Heating System	8
	Building Plug Load	8
2.7	Water-Using Systems	9
3	Site Energy Use and Costs.....	10
3.1	Total Cost of Energy	10
3.2	Electricity Usage	11
3.3	Natural Gas Usage	12
3.4	Benchmarking.....	13
3.5	Energy End-Use Breakdown	14
4	Energy Conservation Measures	15
4.1	Recommended ECMs	15
4.1.1	Lighting Upgrades.....	16
	ECM 1: Install LED Fixtures	16
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	17
	ECM 3: Retrofit Fixtures with LED Lamps.....	17
	ECM 4: Install LED Exit Signs.....	18
4.1.2	Lighting Control Measures	18
	ECM 5: Install Occupancy Sensor Lighting Controls	19
4.1.3	Domestic Hot Water Heating System Upgrades	20
	ECM 6: Install Low-Flow DHW Devices.....	20
4.2	ECMs Evaluated But Not Recommended	20

Install High Efficiency Air Conditioning Units	21
Install High Efficiency Gas Water Heater.....	21
5 Energy Efficient Practices	22
Use Window Treatments/Coverings	22
Perform Proper Lighting Maintenance.....	22
Develop a Lighting Maintenance Schedule	22
Ensure Lighting Controls Are Operating Properly	22
Use Fans to Reduce Cooling Load	22
Practice Proper Use of Thermostat Schedules and Temperature Resets	23
Clean Evaporator/Condenser Coils on AC Systems	23
Clean and/or Replace HVAC Filters	23
Check for and Seal Duct Leakage	23
Perform Proper Boiler Maintenance.....	23
Perform Proper Water Heater Maintenance	24
Plug Load Controls.....	24
Replace Computer Monitors	24
Water Conservation	24
6 On-Site Generation Measures	25
6.1 Photovoltaic.....	25
6.2 Combined Heat and Power	26
7 Demand Response	27
8 Project Funding / Incentives	28
8.1 SmartStart	29
8.2 Direct Install	30
8.3 Energy Savings Improvement Program	31
9 Energy Purchasing and Procurement Strategies	32
9.1 Retail Electric Supply Options.....	32
9.2 Retail Natural Gas Supply Options	32

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs 2

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Project Contacts 5

Figure 5 - Building Schedule..... 5

Figure 6 - Utility Summary 10

Figure 7 - Energy Cost Breakdown 10

Figure 8 - Electric Usage & Demand..... 11

Figure 9 - Electric Usage & Demand..... 11

Figure 10 - Natural Gas Usage..... 12

Figure 11 - Natural Gas Usage..... 12

Figure 12 - Energy Use Intensity Comparison – Existing Conditions..... 13

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 13

Figure 14 - Energy Balance (% and kBtu/SF) 14

Figure 15 – Summary of Recommended ECMs..... 15

Figure 16 – Summary of Lighting Upgrade ECMs..... 16

Figure 17 – Summary of Lighting Control ECMs 18

Figure 18 - Summary of Domestic Water Heating ECMs 20

Figure 19 – Summary of Measures Evaluated, But Not Recommended 20

Figure 20 - Photovoltaic Screening 25

Figure 21 - Combined Heat and Power Screening 26

Figure 22 - ECM Incentive Program Eligibility..... 28

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPUB) has sponsored this Local Government Energy Audit (LGEA) Report for Clearview Administration Building.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey school districts in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Clearview Administration Building is a two-story, 5,260 square foot building comprised of various space types including offices, conference rooms, a small kitchen with eating area, and basement mechanical space with storage. The building was constructed in 1991 and has not had any major renovations.

Lighting at Clearview Administration Building consists of primarily first generation T8 linear fluorescent fixtures mixed with some LED and compact fluorescent fixtures. Some of the HVAC equipment is original to the building, but still in good condition. Heating is supplied mostly by hot water coils within packaged units located in the attic, with two hot water boilers located in the basement. Cooling is provided by split system air conditioning units. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated eight measures and recommends six measures which together represent an opportunity for Clearview Administration Building to reduce annual energy costs by \$7,044 and annual greenhouse gas emissions by 40,987 lbs CO₂e. We estimate that if all recommended measures were implemented, the project would pay for itself in 3.2 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Clearview Administration Building's annual energy use by 23%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Clearview Administration Building’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		36,743	8.5	0.0	0.0	0.0	0.0	\$6,358.48	\$22,495.03	\$2,240.00	\$20,255.03	3.2	37,000
ECM 1	Install LED Fixtures	1,840	0.3	0.0	0.0	0.0	0.0	\$318.37	\$1,172.03	\$300.00	\$872.03	2.7	1,853
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	3,623	1.4	0.0	0.0	0.0	0.0	\$627.05	\$4,386.00	\$190.00	\$4,196.00	6.7	3,649
ECM 3	Retrofit Fixtures with LED Lamps	29,988	6.7	0.0	0.0	0.0	0.0	\$5,189.58	\$15,969.00	\$1,750.00	\$14,219.00	2.7	30,198
ECM 4	Install LED Exit Signs	1,291	0.1	0.0	0.0	0.0	0.0	\$223.48	\$968.00	\$0.00	\$968.00	4.3	1,300
Lighting Control Measures		3,526	0.9	0.0	0.0	0.0	0.0	\$610.23	\$2,392.00	\$320.00	\$2,072.00	3.4	3,551
ECM 5	Install Occupancy Sensor Lighting Controls	3,526	0.9	0.0	0.0	0.0	0.0	\$610.23	\$2,392.00	\$320.00	\$2,072.00	3.4	3,551
Electric Unitary HVAC Measures		3,296	2.0	0.0	0.0	0.0	0.0	\$570.39	\$19,286.16	\$782.00	\$18,504.16	32.4	3,319
	Install High Efficiency Electric AC	3,296	2.0	0.0	0.0	0.0	0.0	\$570.39	\$19,286.16	\$782.00	\$18,504.16	32.4	3,319
Domestic Water Heating Upgrade		2,900	1.4	-8.4	0.0	0.0	-8.4	\$408.65	\$2,827.14	\$50.00	\$2,777.14	6.8	1,935
	Install High Efficiency Gas Water Heater	2,467	1.4	-8.4	0.0	0.0	-8.4	\$333.63	\$2,812.80	\$50.00	\$2,762.80	8.3	1,498
ECM 6	Install Low-Flow Domestic Hot Water Devices	434	0.0	0.0	0.0	0.0	0.0	\$75.03	\$14.34	\$0.00	\$14.34	0.2	437
TOTAL FOR RECOMMENDED MEASURES		40,703	9.3	0.0	0.0	0.0	0.0	\$7,043.73	\$24,901.37	\$2,560.00	\$22,341.37	3.2	40,987
TOTAL FOR ALL MEASURES		46,465	12.6	-8.4	0.0	0.0	-8.4	\$7,947.75	\$47,000.33	\$3,392.00	\$43,608.33	5.5	45,605

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measure save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Electric Unitary HVAC measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air conditioning systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

Domestic Hot Water upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

Energy Efficient Practices

TRC also identified 14 low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Clearview Administration Building include:

- Use Window Treatments/Coverings
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Use Fans to Reduce Cooling Load
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Check for and Seal Duct Leakage
- Perform Proper Boiler Maintenance
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Replace Computer Monitors
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Clearview Administration Building. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SS incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8 or: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Esther Pennell	Business Administrator	pennelles@clearviewregional.edu	856-223-2764
Steve Nicolella	Facility Director	nicoellast@clearviewregional.edu	856-223-2784
TRC Energy Services			
Alexander Kliev Erik	Auditor	aklieverik@trcsolutions.com	732-855-0033

2.2 General Site Information

On November 9, 2017, TRC performed an energy audit at Clearview Administration Building located in Mullica Hill, New Jersey. TRC’s team met with Steve Nicolella to review the facility operations and help focus our investigation on specific energy-using systems.

Clearview Administration Building is a two-story, 5,260 square foot facility comprised of various space types including offices, conference rooms, a small kitchen with eating area, and basement mechanical space with storage. The building was constructed in 1991 and has not had any major renovations.

2.3 Building Occupancy

The administration building is open Monday through Friday and closed on weekends. The typical schedule is presented in the table below. The building is used year round, and closed on holidays. During a typical day, the facility is occupied by approximately eight staff members.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Clearview Administration Building	Weekday	7:00 AM to 4:00 PM
Clearview Administration Building	Weekend	None

2.4 Building Envelope

The building is constructed of concrete block and light-frame wood construction with a lower brick and upper cement plaster facade. The building has a pitched roof with asphalt shingles that is in good condition. The building has double pane windows which are in good condition and show little sign of excessive infiltration. The main entrance doors are constructed of wood with aluminum cladding and full pane glass. The other entry doors are made of aluminum. All doors are in good condition except that the door seals have worn out which increases the level of outside air infiltration.



Image 1 - Envelope

2.5 On-Site Generation

Clearview Administration Building does not have any on-site electric generation capacity.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Lighting is provided by a combination of 40 Watt linear fluorescent T12 lamps, 32-Watt linear fluorescent T8 lamps, 32-Watt U-bend fluorescent T8 lamps with electronic ballasts as well as some compact fluorescent lamps (CFL). Most of the linear and U-bend fixtures are 2-lamp or 3-lamp, 2-foot or 4-foot long troffers with diffusers. Most of the compact fluorescent fixtures are pin-style connections, only allowing for the installation of higher efficiency lamps.

Lighting control in all spaces is provided by wall switches. The staff is generally conscious about turning lights off in spaces that are not occupied, but some lighting was observed to be on in unoccupied rooms.

The building's exterior lighting is minimal and consists primarily of high pressure sodium (HPS) fixtures and compact fluorescent lamps that are controlled by a timer.



Image 2 - Lighting

Hot Water Heating System

The hot water system consists of two Weil-McLain 92 kBtu/hr output, natural draft boilers (BR1 & 2). The boilers have a combustion efficiency of 87.6%. The boilers are configured in a constant flow primary distribution with two ¼ hp hot water pumps (HHWP1 & 2). Hot water is supplied at 185°F when the outside air temperature is below 60°F. The boilers provide hot water to coils within air handlers 1, 2, 3 and 4 as well as to the basement unit heaters.

The boilers are controlled by an accompanying Weil-McLain Energy Management Control System, and operate in a lead/lag configuration. Both boilers may be required during cold weather. The lead boiler is rotated manually. The boilers are in good operating condition and well maintained.



Image 3 – Hot Water Heating System

Packaged Heating and Direct Expansion Air Conditioning System (DX)

There are six direct-expansion (DX) split system units, and one cooling-only mini split system. The split system units vary in size from 2 to 5 tons and provide constant air volume with a ¼ hp supply fan in each housing. The units utilize a scroll compressor and a DX coil for cooling. Two of the split system units have a gas fired furnace component located in the attic on the building. The gas fired furnace provides heating as needed.

The mini split system is a cooling only unit located in the server room on the second floor and is controlled by a thermostat located in the room. The unit operates on demand to maintain a space temperature setpoint around 70°F (adjustable by staff).



Image 4 – Packaged Furnace and DX Cooling System

Domestic Water Heating System

The domestic hot water heating system for the building consists of one Bradford White electric DHW heater with an input rating of 4.5 kW and a 40 gallon capacity storage tank. The DHW heater is approximately two years old and in good working condition. There is no recirculation pump present at this building.



Image 5 – Domestic Hot Water System

Building Plug Load

There are 12 computer work stations throughout the building. Roughly 90% of the computers are desktop units with LCD monitors. Throughout the building there are eight desk printers, two projectors, and one large photocopier. There is no centralized PC power management software installed.

There is one server closet located on the second floor of the building. Cooling for the server room is provided by a dedicated split system manufactured by Sanyo, with a 24,200 Btu cooling capacity.

The building has a small kitchen with an upright refrigerator, a microwave, a toaster, and an electric oven.

2.7 Water-Using Systems

There are three restrooms in this building. An inspection of the restrooms found that the men's and women's restrooms have faucets rated at 0.5 gallons per minute (gpm). The administration office restroom faucet, and the kitchen sink faucet have ratings of 2.5 gpm. The toilets are all rated at 2.5 gallons per flush (gpf).

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Clearview Administration Building		
Fuel	Usage	Cost
Electricity	100,162 kWh	\$17,333
Natural Gas	2,536 Therms	\$2,809
Total		\$20,143

The current annual energy cost for this facility is \$20,143 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by Atlantic City Electric. The average electric cost over the past 12 months was \$0.173/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Clearview Administration Building					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
3/7/16	27	6,446	21	\$0	\$1,118
4/8/16	31	7,271	30	\$0	\$1,282
5/9/16	30	7,205	29	\$0	\$1,261
6/8/16	29	7,855	33	\$0	\$1,323
7/8/16	29	9,092	36	\$0	\$1,517
8/9/16	31	11,306	40	\$0	\$1,839
9/9/16	30	11,060	38	\$0	\$1,803
10/10/16	30	8,438	35	\$0	\$1,493
11/8/16	28	6,474	34	\$0	\$1,213
12/8/16	29	7,071	22	\$0	\$1,281
1/11/17	33	8,016	22	\$0	\$1,451
2/6/17	25	6,361	22	\$0	\$1,134
Totals	352	96,595	40.2	\$0	\$16,716
Annual	365	100,162	40.2	\$0	\$17,333

3.3 Natural Gas Usage

Natural Gas is provided by South Jersey Gas. The average gas cost for the past 12 months is \$1.108/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for Clearview Administration Building			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
3/7/16	27	511	\$504
4/8/16	31	282	\$295
5/9/16	30	81	\$104
6/8/16	29	46	\$71
7/8/16	29	10	\$39
8/9/16	31	1	\$32
9/9/16	30	2	\$32
10/10/16	30	21	\$50
11/8/16	28	123	\$153
12/8/16	29	305	\$341
1/11/17	33	644	\$656
2/6/17	25	421	\$433
Totals	352	2,446	\$2,709
Annual	365	2,536	\$2,809

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Clearview Administration Building	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	254.6	148.1
Site Energy Use Intensity (kBtu/ft ²)	113.2	67.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Clearview Administration Building	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	171.7	148.1
Site Energy Use Intensity (kBtu/ft ²)	86.8	67.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. This building received a score of 33.

A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Clearview Administration Building regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		36,743	8.5	0.0	\$6,358.48	\$22,495.03	\$2,240.00	\$20,255.03	3.2	37,000
ECM 1	Install LED Fixtures	1,840	0.3	0.0	\$318.37	\$1,172.03	\$300.00	\$872.03	2.7	1,853
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	3,623	1.4	0.0	\$627.05	\$4,386.00	\$190.00	\$4,196.00	6.7	3,649
ECM 3	Retrofit Fixtures with LED Lamps	29,988	6.7	0.0	\$5,189.58	\$15,969.00	\$1,750.00	\$14,219.00	2.7	30,198
ECM 4	Install LED Exit Signs	1,291	0.1	0.0	\$223.48	\$968.00	\$0.00	\$968.00	4.3	1,300
Lighting Control Measures		3,526	0.9	0.0	\$610.23	\$2,392.00	\$320.00	\$2,072.00	3.4	3,551
ECM 5	Install Occupancy Sensor Lighting Controls	3,526	0.9	0.0	\$610.23	\$2,392.00	\$320.00	\$2,072.00	3.4	3,551
Domestic Water Heating Upgrade		434	0.0	0.0	\$75.03	\$14.34	\$0.00	\$14.34	0.2	437
ECM 6	Install Low-Flow Domestic Hot Water Devices	434	0.0	0.0	\$75.03	\$14.34	\$0.00	\$14.34	0.2	437
TOTALS		40,703	9.3	0.0	\$7,043.73	\$24,901.37	\$2,560.00	\$22,341.37	3.2	40,987

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommended upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		36,743	8.5	0.0	\$6,358.48	\$22,495.03	\$2,240.00	\$20,255.03	3.2	37,000
ECM 1	Install LED Fixtures	1,840	0.3	0.0	\$318.37	\$1,172.03	\$300.00	\$872.03	2.7	1,853
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	3,623	1.4	0.0	\$627.05	\$4,386.00	\$190.00	\$4,196.00	6.7	3,649
ECM 3	Retrofit Fixtures with LED Lamps	29,988	6.7	0.0	\$5,189.58	\$15,969.00	\$1,750.00	\$14,219.00	2.7	30,198
ECM 4	Install LED Exit Signs	1,291	0.1	0.0	\$223.48	\$968.00	\$0.00	\$968.00	4.3	1,300

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	1,840	0.3	0.0	\$318.37	\$1,172.03	\$300.00	\$872.03	2.7	1,853

Measure Description

We recommend replacing existing exterior fixtures containing HID lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	3,623	1.4	0.0	\$627.05	\$4,386.00	\$190.00	\$4,196.00	6.7	3,649
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used in retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

ECM 3: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	25,753	6.1	0.0	\$4,456.62	\$14,472.44	\$1,700.00	\$12,772.44	2.9	25,933
Exterior	4,235	0.7	0.0	\$732.96	\$1,496.56	\$50.00	\$1,446.56	2.0	4,265

Measure Description

We recommend retrofitting existing incandescent, HID or other lighting technologies with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

ECM 4: Install LED Exit Signs

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	1,291	0.1	0.0	\$223.48	\$968.00	\$0.00	\$968.00	4.3	1,300
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend replacing all incandescent or compact fluorescent exit signs with LED exit signs. LED exit signs require virtually no maintenance and have a life expectancy of at least 20 years. This measure saves energy by installing LED fixtures, which use less power than other technologies with an equivalent lighting output.

4.1.2 Lighting Control Measures

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures	3,526	0.9	0.0	\$610.23	\$2,392.00	\$320.00	\$2,072.00	3.4	3,551
ECM 5 Install Occupancy Sensor Lighting Controls	3,526	0.9	0.0	\$610.23	\$2,392.00	\$320.00	\$2,072.00	3.4	3,551

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 5: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,526	0.9	0.0	\$610.23	\$2,392.00	\$320.00	\$2,072.00	3.4	3,551

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in the curriculum office, the administration office conference rooms, server room, and basement area. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.1.3 Domestic Hot Water Heating System Upgrades

Our recommendations for domestic water heating system improvements are summarized in Figure 18 below.

Figure 18 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade	434	0.0	0.0	\$75.03	\$14.34	\$0.00	\$14.34	0.2	437
ECM 6 Install Low-Flow Domestic Hot Water Devices	434	0.0	0.0	\$75.03	\$14.34	\$0.00	\$14.34	0.2	437

ECM 6: Install Low-Flow DHW Devices

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
434	0.0	0.0	\$75.03	\$14.34	\$0.00	\$14.34	0.2	437

Measure Description

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators and low-flow showerheads can reduce hot water usage, relative to standard showerheads and aerators, which saves energy.

Low-flow devices reduce the overall water flow from the fixture, while still adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

4.2 ECMs Evaluated But Not Recommended

The measures below have been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in each measure description section.

Figure 19 – Summary of Measures Evaluated, But Not Recommended

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Electric Unitary HVAC Measures	3,296	2.0	0.0	\$570.39	\$19,286.16	\$782.00	\$18,504.16	32.4	3,319
Install High Efficiency Electric AC	3,296	2.0	0.0	\$570.39	\$19,286.16	\$782.00	\$18,504.16	32.4	3,319
Domestic Water Heating Upgrade	2,467	1.4	-8.4	\$333.63	\$2,812.80	\$50.00	\$2,762.80	8.3	1,498
Install High Efficiency Gas Water Heater	2,467	1.4	-8.4	\$333.63	\$2,812.80	\$50.00	\$2,762.80	8.3	1,498
TOTALS	5,763	3.3	-8.4	\$904.02	\$22,098.96	\$832.00	\$21,266.96	23.5	4,818

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Install High Efficiency Air Conditioning Units

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,296	2.0	0.0	\$570.39	\$19,286.16	\$782.00	\$18,504.16	32.4	3,319

Measure Description

We generally recommend replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units when cost effective. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. This should be done in the course of replacing failed equipment. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Reasons for not Recommending

We are not currently recommending the installation of high efficiency AC units due to the long project payback period, which exceeds the useful life of the equipment.

Install High Efficiency Gas Water Heater

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
2,467	1.4	-8.4	\$333.63	\$2,812.80	\$50.00	\$2,762.80	8.3	1,498

Measure Description

We generally recommend replacing existing tank water heaters with high efficiency tank water heater when cost effective. Improvements in combustion efficiency and reductions in heat losses have improved the overall efficiency of storage water heaters. Energy savings results from using less gas to heat water, due to higher unit efficiency, and fewer run hours to maintain the tank water temperature.

Reasons for not Recommending

We are not currently recommending the installation of a high efficiency gas fired water heater due to the limited use of domestic hot water at the building, and that the existing water heater is only 2 years old. This measure should be considered when replacing the water heater in the future.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Use Window Treatments/Coverings

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Use Fans to Reduce Cooling Load

Utilizing ceiling fans to supplement cooling is a low cost strategy to reduce cooling load considerably. Thermostat settings can be increased by 4°F with no change in overall occupant comfort when the wind chill effect of moving air is employed for cooling.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Check for and Seal Duct Leakage

Duct leakage in commercial buildings typically accounts for 5% to 25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building, significantly increasing cooling and heating costs. By sealing sources of leakage, cooling, heating, and ventilation energy use can be reduced significantly, depending on the severity of air leakage.

Perform Proper Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up in order to sustain efficiency and equipment life.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

Replace Computer Monitors

Replacing old computer monitors or displays with efficient monitors will reduce energy use. ENERGY STAR® rated monitors have specific requirements for on mode power consumption as well as idle and sleep mode power. According to the ENERGY STAR® website monitors that have earned the ENERGY STAR® label are 25% more efficient than standard monitors.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gpf and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.3 for any low-flow ECM recommendations.

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a Low potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

Figure 20 - Photovoltaic Screening



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-fags>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power


Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.

CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility's ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a Low potential for installing a cost-effective CHP system.

The low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

Figure 21 - Combined Heat and Power Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 22 for a list of the eligible programs identified for each recommended ECM.

Figure 22 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	X		X			
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X		X			
ECM 3	Retrofit Fixtures with LED Lamps	X		X			
ECM 4	Install LED Exit Signs			X			
ECM 5	Install Occupancy Sensor Lighting Controls	X		X			
ECM 6	Install Low-Flow Domestic Hot Water Devices			X			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for any recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

How to Participate

To participate in the Direct Install program you will need to contact the participating contractor who the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since Direct Install offers a free assessment of eligible measures, Direct Install is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at:

www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Curriculum Office	5	Linear Fluorescent - T8: 2 T8 (17W) - 3L	Wall Switch	53	3,000	Relamp	Yes	5	LED - Linear Tubes: (3) 2' Lamps	Occupancy Sensor	26	2,100	0.14	617	0.0	\$106.75	\$578.50	\$110.00	4.39
Curriculum Office	6	Linear Fluorescent - T12: 2 T12 (20W) - 2L	Wall Switch	50	3,000	Relamp & Reballast	Yes	6	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,100	0.18	802	0.0	\$138.86	\$912.00	\$95.00	5.88
Curriculum Office	1	Linear Fluorescent - T8: 2 T8 (17W) - 2L	Wall Switch	33	3,000	Relamp	Yes	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,100	0.02	74	0.0	\$12.82	\$48.20	\$45.00	0.25
Admin Office	1	Exit Signs: Incandescent	None	20	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	143	0.0	\$24.83	\$107.56	\$0.00	4.33
Admin Office	2	Compact Fluorescent: Pin-Style (26W) - 2L	Wall Switch	52	3,000	Relamp	Yes	2	LED Screw-In Lamps: GX24 (15W) - 2L	Occupancy Sensor	15	2,100	0.07	291	0.0	\$50.42	\$215.01	\$55.00	3.17
Admin Office	19	U-Bend Fluorescent - T12: U T12 (34W) - 2L	Wall Switch	72	3,000	Relamp & Reballast	Yes	19	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	2,100	0.74	3,261	0.0	\$564.35	\$2,493.00	\$35.00	4.36
Admin Office	3	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	3	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	2,100	0.09	410	0.0	\$70.89	\$189.60	\$35.00	2.18
Admin Office	12	Incandescent: Screw-in (60W) - 1L	Wall Switch	60	3,000	Relamp	Yes	12	LED Screw-In Lamps: A19 (9W) - 1L	Occupancy Sensor	9	2,100	0.51	2,262	0.0	\$391.42	\$915.04	\$95.00	2.10
Small Conference Room	2	Exit Signs: Incandescent	None	20	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.02	287	0.0	\$49.66	\$215.11	\$0.00	4.33
Small Conference Room	10	Incandescent: Screw-in (65W) - 1L	Wall Switch	65	3,000	Relamp	Yes	10	LED Screw-In Lamps: A19 (9W) - 1L	Occupancy Sensor	1	2,100	0.51	2,257	0.0	\$390.57	\$807.53	\$85.00	1.85
Small Conference Room	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.60	2,635	0.0	\$455.93	\$1,053.00	\$215.00	1.84
Bathroom	1	Linear Fluorescent - T8: 2 T8 (17W) - 1L	Wall Switch	22	365	Relamp	No	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	365	0.01	6	0.0	\$1.00	\$31.90	\$5.00	26.96
Lobby Storage Room	1	Incandescent: Screw-in (60W) - 1L	Wall Switch	60	3,000	Relamp	No	1	LED Screw-In Lamps: A19 (9W) - 1L	Wall Switch	9	3,000	0.04	179	0.0	\$30.98	\$53.75	\$5.00	1.57
Men's Restroom	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	40	365	None	No	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	40	365	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Women's Restroom	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	40	365	None	No	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	40	365	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Lunch/Copy Room	3	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	No	3	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	3,000	0.07	305	0.0	\$52.85	\$189.60	\$0.00	3.59
Large Conference Room	36	Compact Fluorescent: Pin-Style (26W) - 2L	Wall Switch	52	3,000	Relamp	Yes	36	LED Screw-In Lamps: GX24 (15W) - 2L	Occupancy Sensor	15	2,100	1.19	5,244	0.0	\$907.48	\$4,140.22	\$395.00	4.13
Large Conference Room	30	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	30	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	1.00	4,391	0.0	\$759.88	\$2,025.00	\$335.00	2.22
Large Conference Room	2	Exit Signs: Incandescent	None	20	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.02	287	0.0	\$49.66	\$215.11	\$0.00	4.33
Stairway	1	Exit Signs: Incandescent	None	20	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	143	0.0	\$24.83	\$107.56	\$0.00	4.33
Stairway	2	Compact Fluorescent: Pin-Style (18W) - 2L	Wall Switch	36	3,000	Relamp	No	2	LED Screw-In Lamps: GX24 (9W) - 2L	Wall Switch	18	3,000	0.03	126	0.0	\$21.87	\$215.01	\$20.00	8.92
Stairway	2	LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture	Wall Switch	40	3,000	None	No	2	LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture	Wall Switch	40	3,000	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2nd Floor Area	25	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	No	25	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	3,000	0.98	4,344	0.0	\$751.68	\$1,880.00	\$375.00	2.00
2nd Floor Conference Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.20	878	0.0	\$151.98	\$416.80	\$80.00	2.22
2nd Floor Offices	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	No	5	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	3,000	0.20	869	0.0	\$150.34	\$376.00	\$75.00	2.00

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
2nd Floor Server Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.10	439	0.0	\$75.99	\$266.40	\$50.00	2.85
2nd Floor Attic Space	4	Incandescent - Screw-in (60W) - 1L	Wall Switch	60	365	Relamp	No	4	LED Screw-In Lamps: A19 (9W) - 1L	Wall Switch	9	365	0.16	87	0.0	\$15.08	\$215.01	\$20.00	12.94
Basement Hallway	3	Incandescent - Screw-in (60W) - 1L	Wall Switch	60	3,000	Relamp	No	3	LED Screw-In Lamps: A19 (9W) - 1L	Wall Switch	9	3,000	0.12	537	0.0	\$92.93	\$161.26	\$15.00	1.57
Basement Hallway	1	Exit Signs: Incandescent	None	20	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	143	0.0	\$24.83	\$107.56	\$0.00	4.33
Boiler Room	3	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	365	Relamp & Reballast	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	365	0.14	76	0.0	\$13.08	\$351.00	\$30.00	24.54
Basement Storage	10	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	365	Relamp & Reballast	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	256	0.54	289	0.0	\$50.03	\$1,440.00	\$135.00	26.08
Basement Storage	1	Exit Signs: Incandescent	None	20	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	143	0.0	\$24.83	\$107.56	\$0.00	4.33
Basement Storage	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	365	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	365	0.11	56	0.0	\$9.76	\$234.00	\$40.00	19.89
Exterior Front	3	Compact Fluorescent - Pin-Style (18W) - 1L	Wall Switch	18	4,380	Relamp	No	3	LED Screw-In Lamps: GX24 (9W) - 1L	Wall Switch	9	4,380	0.02	138	0.0	\$23.94	\$161.26	\$0.00	6.73
Exterior Front	2	Compact Fluorescent - Pin-Style (26W) - 2L	Wall Switch	52	4,380	Relamp	No	2	LED Screw-In Lamps: GX24 (15W) - 2L	Wall Switch	15	4,380	0.06	379	0.0	\$65.63	\$215.01	\$0.00	3.28
Exterior Front	1	High-Pressure Sodium: (1) 150W Lamp	Wall Switch	188	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	45	4,380	0.11	733	0.0	\$126.82	\$390.68	\$100.00	2.29
Vestibule	2	Compact Fluorescent - Pin-Style (26W) - 2L	Wall Switch	52	3,000	Relamp	No	2	LED Screw-In Lamps: GX24 (15W) - 2L	Wall Switch	15	3,000	0.06	260	0.0	\$44.95	\$215.01	\$0.00	4.78
Vestibule	1	Exit Signs: Incandescent	None	20	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	143	0.0	\$24.83	\$107.56	\$0.00	4.33
Admin Lobby	17	Compact Fluorescent - Pin-Style (26W) - 2L	Wall Switch	52	3,000	Relamp	No	17	LED Screw-In Lamps: GX24 (15W) - 2L	Wall Switch	15	3,000	0.50	2,208	0.0	\$382.06	\$1,827.60	\$0.00	4.78
Exterior Side	3	Incandescent: Flood Light (65W) 2L	Wall Switch	130	4,380	Relamp	No	3	LED Screw-In Lamps: PAR30 (12.5W) - 2L	Wall Switch	13	4,380	0.28	1,806	0.0	\$312.61	\$381.91	\$30.00	1.13
Exterior Side	1	High-Pressure Sodium: (1) 100W Lamp	Wall Switch	138	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	30	4,380	0.09	553	0.0	\$95.78	\$390.68	\$100.00	3.03
Exterior Side	1	Compact Fluorescent - Pin-Style (18W) - 1L	Wall Switch	18	4,380	Relamp	No	1	LED Screw-In Lamps: GX24 (9W) - 1L	Wall Switch	9	4,380	0.01	46	0.0	\$7.98	\$53.75	\$0.00	6.73
Exterior Back	2	Compact Fluorescent - Pin-Style (18W) - 1L	Wall Switch	18	4,380	Relamp	No	2	LED Screw-In Lamps: GX24 (9W) - 1L	Wall Switch	9	4,380	0.01	92	0.0	\$15.96	\$107.51	\$0.00	6.73
Exterior Back	3	Compact Fluorescent - Pin-Style (26W) - 2L	Wall Switch	52	4,380	Relamp	No	3	LED Screw-In Lamps: GX24 (15W) - 2L	Wall Switch	15	4,380	0.09	569	0.0	\$98.44	\$322.52	\$0.00	3.28
Exterior Basement Side	2	Incandescent: Flood Light (65W) 2L	Wall Switch	130	4,380	Relamp	No	2	LED Screw-In Lamps: PAR30 (12.5W) - 2L	Wall Switch	13	4,380	0.19	1,204	0.0	\$208.40	\$254.60	\$20.00	1.13
Exterior Basement Side	1	High-Pressure Sodium: (1) 100W Lamp	Wall Switch	138	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	30	4,380	0.09	553	0.0	\$95.78	\$390.68	\$100.00	3.03

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Attic space	Whole Building	2	Supply Fan	0.8	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Attic space	Whole Building	1	Supply Fan	0.8	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Attic space	Whole Building	2	Supply Fan	0.8	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Attic space	Whole Building	1	Supply Fan	0.8	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Whole Building / Heating System	2	Heating Hot Water Pump	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis								
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Server Room / Outdoor	Whole Building	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Outdoors	Whole Building	2	Packaged AC	5.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Outdoors	Whole Building	1	Packaged AC	3.50		Yes	1	Packaged AC	3.50		14.00		No	0.80	1,357	0.0	\$234.87	\$7,941.36	\$322.00	32.44
Outdoors	Whole Building	1	Packaged AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Outdoors	Whole Building	1	Packaged AC	2.00		Yes	1	Packaged AC	2.00		14.00		No	0.46	776	0.0	\$134.21	\$4,537.92	\$184.00	32.44
Outdoors	Whole Building	1	Packaged AC	3.00		Yes	1	Packaged AC	3.00		14.00		No	0.69	1,163	0.0	\$201.31	\$6,806.88	\$276.00	32.44

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis								
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years		
Boiler Room	Whole Building	2	Non-Condensing Hot Water Boiler	92.00	No								0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Attic	Whole Building	2	Furnace	75.00	No								0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Whole Building	1	Storage Tank Water Heater (≤ 50 Gal)	Yes	1	Storage Tank Water Heater (≤ 50 Gal)	Natural Gas	67.00%	EF	1.35	2,467	-8.4	\$333.63	\$2,812.80	\$50.00	8.28


Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis							
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Admin Bathroom	1	Faucet Aerator (Lavatory)	2.50	1.00	0.00	434	0.0	\$75.03	\$7.17	\$0.00	0.10	
Lunch Room	1	Faucet Aerator (Kitchen)	2.20	2.20	0.00	0	0.0	\$0.00	\$7.17	\$0.00	0.00	

Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Offices	12	Desktop Computers	150.0	Yes
Offices	5	Medium Sized Printers	60.0	Yes
Offices	3	Small Printers	20.0	Yes
Offices	2	Projectors	200.0	No
Lunch Room	1	Large Printer	600.0	Yes
Lunch Room	1	Microwave	1,000.0	No
Lunch Room	1	Toaster	850.0	No
Lunch Room	1	Electric Oven	1,200.0	No
Lunch Room	1	Refrigerator	690.0	No

Appendix B: ENERGY STAR® Statement of Energy Performance



LEARN MORE AT energystar.gov

ENERGY STAR® Statement of Energy Performance

33

ENERGY STAR®
Score¹

Clearview Regional Administration Building

Primary Property Type: Office
Gross Floor Area (ft²): 5,260
Built: 1991

For Year Ending: January 31, 2017
Date Generated: December 19, 2017

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address	Property Owner	Primary Contact
Clearview Regional Administration Building 420 Cedar Road Mullica Hill, New Jersey 08062	Clearview Regional High School District 420 Cedar Road Mullica Hill, NJ 08062 (856) 223-2762	Esther Pennell 420 Cedar Road Mullica Hill, NJ 08062 (856) 223-2762 pennelles@clearviewregional.edu

Property ID: 6173933

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
109.3 kBtu/ft ²	Electric - Grid (kBtu) 331,077 (58%) Natural Gas (kBtu) 243,930 (42%)	National Median Site EUI (kBtu/ft ²) 96.6 National Median Source EUI (kBtu/ft ²) 217.7 % Diff from National Median Source EUI 13%
Source EUI		Annual Emissions
246.3 kBtu/ft ²		Greenhouse Gas Emissions (Metric Tons CO ₂ e/year) 50