



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Central Early Childhood Center

1447 Delsea Drive

Deptford, NJ 08096

Deptford Township BOE

July 30, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	4
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	6
2.1	Project Contacts	6
2.2	General Site Information.....	6
2.3	Building Occupancy	6
2.4	Building Envelope	7
2.5	On-Site Generation.....	7
2.6	Energy-Using Systems	7
	Lighting System	8
	Hot Water Heating System.....	8
	Direct Expansion Air Conditioning System (DX)	9
	Domestic Water Heating System	9
	Food Service & Refrigeration	10
	Building Plug Load	10
2.7	Water-Using Systems	10
3	Site Energy Use and Costs	11
3.1	Total Cost of Energy	11
3.2	Electricity Usage	12
3.3	Natural Gas Usage	13
3.4	Benchmarking.....	14
3.5	Energy End-Use Breakdown	15
4	Energy Conservation Measures	16
4.1	Recommended ECMs	16
4.1.1	Lighting Upgrades.....	17
	ECM 1: Install LED Fixtures.....	17
	ECM 2: Retrofit Fixtures with LED Lamps.....	18
4.1.2	Lighting Control Measures	19
	ECM 3: Install Occupancy Sensor Lighting Controls	19
4.1.3	Variable Frequency Drive Measures	20
	ECM 4: Install VFDs on Hot Water Pumps.....	20
4.1.4	Plug Load Equipment Control - Vending Machines.....	21
	ECM 5: Vending Machine Control	21

4.2	ECMs Evaluated But Not Recommended	22
	Install High Efficiency Air Conditioning Units	22
5	Energy Efficient Practices	23
	Close Doors and Windows	23
	Use Window Treatments/Coverings	23
	Perform Proper Lighting Maintenance.....	23
	Practice Proper Use of Thermostat Schedules and Temperature Resets	23
	Ensure Economizers are Functioning Properly.....	24
	Clean Evaporator/Condenser Coils on AC Systems	24
	Perform Proper Boiler Maintenance	24
	Perform Proper Water Heater Maintenance	24
	Plug Load Controls.....	24
	Water Conservation	25
6	On-Site Generation Measures	26
6.1	Photovoltaic.....	26
6.2	Combined Heat and Power	28
7	Demand Response	29
8	Project Funding / Incentives	30
8.1	SmartStart	31
8.2	Pay for Performance - Existing Buildings.....	32
8.3	SREC Registration Program.....	33
8.4	Energy Savings Improvement Program	34
9	Energy Purchasing and Procurement Strategies	35
9.1	Retail Electric Supply Options.....	35
9.2	Retail Natural Gas Supply Options	35

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs 2

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Photovoltaic Potential..... 4

Figure 5 – Project Contacts 6

Figure 6 - Building Schedule..... 6

Figure 7 - Utility Summary 11

Figure 8 - Energy Cost Breakdown 11

Figure 9 - Electric Usage & Demand..... 12

Figure 10 - Electric Usage & Demand..... 12

Figure 11 - Natural Gas Usage..... 13

Figure 12 - Natural Gas Usage..... 13

Figure 13 - Energy Use Intensity Comparison – Existing Conditions..... 14

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 14

Figure 15 - Energy Balance (% and kBtu/SF) 15

Figure 16 – Summary of Recommended ECMs..... 16

Figure 17 – Summary of Lighting Upgrade ECMs..... 17

Figure 18 – Summary of Lighting Control ECMs 19

Figure 19 – Summary of Variable Frequency Drive ECMs 20

Figure 20 – Summary of Plug Load Equipment Control ECMs 21

Figure 21 – Summary of Measures Evaluated, But Not Recommended 22

Figure 22 - Photovoltaic Screening 26

Figure 23 - Combined Heat and Power Screening 28

Figure 24 - ECM Incentive Program Eligibility..... 30

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for Central Early Childhood Center.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey school districts in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Central Early Childhood Center is a 71,000 square foot facility comprised of classrooms, offices, a gym, media center, restrooms, closets, hallways and a mechanical space. The building functions from 9:00 AM to 4:00 PM on the weekdays. There are rarely activities during the weekends. There is summer school during the months of June, July and August. The building was constructed in 2004.

The building is heated using two gas-fired non-condensing hot water boilers located in the boiler room, and cooling is provided by a mixture of several roof top packaged units and smaller packaged units for the classrooms. The lighting in the building primarily consists of aging and inefficient T8 linear tube lighting, Compact fluorescent lamp (CFL) fixtures and metal halide wall packs (on the exterior) are in need of replacement with more efficient sources. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated six measures and recommends five measures which together represent an opportunity for Central Early Childhood Center to reduce annual energy costs by roughly \$27,162 and annual greenhouse gas emissions by 131,680 lbs CO₂e. We estimate that if all recommended measures were implemented, the project would pay for itself in roughly 3.6 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Central Early Childhood Center's annual energy use by 11%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Central Early Childhood Center’s existing energy use can be found in Section 3. Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. . A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		108,248	34.0	0.0	\$22,484.77	\$99,550.93	\$19,060.00	\$80,490.93	3.6	109,005
ECM 1 Install LED Fixtures	Yes	27,547	3.6	0.0	\$5,722.03	\$29,300.78	\$7,500.00	\$21,800.78	3.8	27,740
ECM 2 Retrofit Fixtures with LED Lamps	Yes	80,700	30.5	0.0	\$16,762.75	\$70,250.15	\$11,560.00	\$58,690.15	3.5	81,265
Lighting Control Measures		10,026	3.8	0.0	\$2,082.50	\$10,222.00	\$1,335.00	\$8,887.00	4.3	10,096
ECM 3 Install Occupancy Sensor Lighting Controls	Yes	10,026	3.8	0.0	\$2,082.50	\$10,222.00	\$1,335.00	\$8,887.00	4.3	10,096
Variable Frequency Drive (VFD) Measures		9,268	1.2	0.0	\$1,925.16	\$9,022.95	\$0.00	\$9,022.95	4.7	9,333
ECM 4 Install VFDs on Hot Water Pumps	Yes	9,268	1.2	0.0	\$1,925.16	\$9,022.95	\$0.00	\$9,022.95	4.7	9,333
Electric Unitary HVAC Measures		1,545	1.5	0.0	\$320.99	\$159,042.38	\$4,103.27	\$154,939.11	482.7	1,556
Install High Efficiency Electric AC	No	1,545	1.5	0.0	\$320.99	\$159,042.38	\$4,103.27	\$154,939.11	482.7	1,556
Plug Load Equipment Control - Vending Machine		3,224	0.0	0.0	\$669.61	\$460.00	\$0.00	\$460.00	0.7	3,246
ECM 5 Vending Machine Control	Yes	3,224	0.0	0.0	\$669.61	\$460.00	\$0.00	\$460.00	0.7	3,246
TOTAL OF ALL EVALUATED ECMS		132,311	40.5	0.0	\$27,483.03	\$278,298.26	\$24,498.27	\$253,799.99	9.2	133,236
TOTAL OF ALL RECOMMENDED ECMS		130,765	39	0	\$ 27,162.04	\$119,255.88	\$ 20,395.00	\$ 98,860.88	3.6	131,680
TOTAL OF ALL NON-RECOMMENDED ECMS		1,545	1	0	\$ 320.99	\$159,042.38	\$ 4,103.27	\$ 154,939.11	482.7	1,556

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Variable Frequency Drives (VFDs) are motor control devices. These measures control the speed of a motor so that the motor spins at peak efficiency during partial load conditions. Sensors adapt the speed to flow, temperature, or pressure settings which is much more efficient than using a valve or damper to control flow rates, or running the motor at full speed when only partial power is needed. These measures save energy by controlling motor usage more efficiently.

Electric Unitary HVAC measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air conditioning systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

HVAC System Improvements generally involve the installation of automated controls to reduce heating and cooling demand during periods of reduced demand. These measures could encompass changing temperature setpoints, using outside air for free cooling, or limiting excessive outside air during extreme outdoor air temperature conditions. These measures save energy by reducing the demand on HVAC systems and the amount of time systems operate.

Plug Load Equipment control measures generally involve installing automated devices that limit the power usage or operation of equipment that is plugged into an electric outlet when not in use.

Energy Efficient Practices

TRC also identified 10 low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Central Early Childhood Center include:

- Close Doors and Windows
- Use Window Treatments/Coverings
- Perform Proper Lighting Maintenance
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Ensure Economizers are Functioning Properly
- Clean Evaporator/Condenser Coils on AC Systems
- Perform Proper Boiler Maintenance
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Central Early Childhood Center. Based on the configuration of the site and its loads there is a high potential for installing a photovoltaic (PV) array.

Figure 4 – Photovoltaic Potential

Potential	High	
System Potential	250	kW DC STC
Electric Generation	297,843	kWh/yr
Displaced Cost	\$25,910	/yr
Installed Cost	\$650,000	

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Pay for Performance - Existing Building (P4P)
- SREC (Solar Renewable Energy Certificate) Registration Program (SRP)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

Larger facilities with an interest in a more comprehensive whole building approach to energy conservation should consider participating in the Pay for Performance (P4P) program. Projects eligible for this project program must meet minimum savings requirements. Final incentives are calculated based on actual measured performance achieved at the end of the project. The application process is more involved, and it requires working with a qualified P4P contractor, but the process may result in greater energy savings overall and more lucrative incentives, up to 50% of project's total cost.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.4 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8 or: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 5 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
William Blatchley	Business Administrator	blatchley.w@deptford.k12.nj.us	856-232-2700 x 3007
Designated Representative			
Samuel Ringelberg	Development Engineer	Sam.Ringelberg@schneider-electric.com	717-579-0958
TRC Energy Services			
Smruti Srinivasan	Auditor	ssrinivasan@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On May 2, 2017, TRC performed an energy audit at Central Early Childhood Center located in Deptford, New Jersey. TRC’s team met with Gary Noelen to review the facility operations and help focus our investigation on specific energy-using systems.

Central Early Childhood Center is a 71,000 square foot facility comprised of classrooms, offices, a gym, media center, restrooms, closets, hallways and a mechanical space. The building functions from 9:00 AM to 4:00 PM on the weekdays. There are rarely activities during the weekends. There is summer school during the months of June, July and August. The building was constructed in 2004.

The building is heated using two gas-fired non-condensing hot water boilers located in the boiler room, and cooling is provided by a mixture of several roof top packaged units and smaller packaged units for the classrooms. The lighting in the building primarily consists of aging and inefficient T8 linear tube lighting, Compact fluorescent lamp (CFL) fixtures and metal halide wall packs (on the exterior) are in need of replacement with more efficient sources.

2.3 Building Occupancy

The typical schedule is presented in the table below. The building serves students from Pre-K to first grade. There is summer school during the months of June, July and August. During a typical day, the facility is occupied by approximately 75 staff and 633 students.

Figure 6 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Central Early Childhood Center	Weekday	9:00 AM - 4:00 PM
Central Early Childhood Center	Weekend	No operation

2.4 Building Envelope

The core of the building is constructed of concrete block and structural steel with a brick facade. The buildings have flat roof sections covered with various types of membranes in different areas. One part has slag roof and other has asphalts layers. The roof was observed to be in good condition. The building has double pane windows and aluminum framed glass doors that are in good condition and show no sign of excessive infiltration.



Image 1 - Envelope

2.5 On-Site Generation

Central Early Childhood Center does not have any on-site electric generation systems currently installed.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Lighting is provided mostly by 32-Watt linear fluorescent T8 lamps with electronic ballasts as well as some compact fluorescent lamps (CFL). Most of the fixtures are 2-lamp, 3-lamp or 4-lamp 4-foot long troffers. Areas like hallways, main entrance and libraries area lit using are primarily lit with 24-Watt or 26-Watt CFL lamps in recessed can ceiling mounted fixtures.

Lighting control in all of the spaces is provided by manual switches. The building's exterior lighting consists of 70-Watt or 100-Watt metal halide wall packs and 26-Watt CFL canopy fixtures controlled using photo cells and timers. Exit signs at the facility are 2-Watt LED fixtures.



Image 2 - Lighting

Hot Water Heating System

The hot water system consists of two gas fired non-condensing hot water boilers from HB Smith with an output capacity of 1166 MBh and a combustion efficiency of 78%. The hot water is circulated using three 3 hp constant speed hot water pumps (two main and one back up). Hot water is supplied at 180°F when the outside air temperature is below 20°F and the setpoint is reset to 140°F when the outside air is above 50°F. The boilers provide hot water to the unit ventilators in the building for distribution.

The boilers are 14 years old, in good condition and well maintained.



Image 3 - Heating

Direct Expansion Air Conditioning System (DX)

The space cooling is provided by packaged cooling units of various sizes. Areas including the nurse's office, main office, teacher's work room, hallways, library and gymnasium are served by roof top packaged units ranging from 2 tons to 30 tons. Units were manufactured either by Carrier or Addison.

All the classrooms have self-contained unit ventilators with hot water coils and DX coils. Smaller classrooms have 3 ton cooling capacities in these units and bigger rooms have 6 ton units. The building uses free cooling during the spring and fall seasons. All of the cooling units are 14 years old. The rooftop packaged units were evaluated for replacement.

All of the space temperatures are controlled using the building automation system.



Image 4 – Air Conditioning

Domestic Water Heating System

The domestic hot water heating system for the facility consists of two gas fired domestic water heaters serving the kitchen and the restrooms. The units are manufactured by AO Smith with input capacities of 720 MBh and 300 MBh and an efficiency of 80%. Both units have a tank capacity of 200 gallons. The equipment is 13 years old, in good condition and well maintained.



Image 5 – Domestic Hot Water

Food Service & Refrigeration

The school has an all-electric kitchen that is only used to heat and serve food. The equipment includes a Blodgett electric convection, a double door stand up refrigerator, and a milk cooler.



Image 6 – Kitchen Equipment

Building Plug Load

There are roughly 95 computer work stations throughout the facility. Other office and classroom plug loads includes printers, paper shredders, projectors and smart boards. The kitchenette equipment in the facility include refrigerators, coffee machines, toasters, toaster oven and microwave ovens. There is one refrigerated vending machine in the faculty work room. No controls were found on these.

2.7 Water-Using Systems

A sampling of restrooms found that the faucets are rated for 2.2 gallons per minute (gpm) or lower, the toilets are rated at 1.6 gallons per flush (gpf) and the urinals are rated at 1.6 gpf.

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 7 - Utility Summary

Utility Summary for Central Early Childhood Center		
Fuel	Usage	Cost
Electricity	622,008 kWh	\$129,201
Natural Gas	20,159 Therms	\$19,158
Total		\$148,359

The current annual energy cost for this facility is \$148,359 as shown in the chart below.

Figure 8 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.208/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The third party electric supply was provided by South Jersey Energy Company. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 9 - Electric Usage & Demand




Figure 10 - Electric Usage & Demand

Electric Billing Data for Central Early Childhood Center					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
10/29/15	30	49,977	278	\$1,009	\$9,620
12/1/15	33	56,388	312	\$1,131	\$10,257
1/2/16	32	51,503	202	\$1,462	\$9,461
2/1/16	30	51,258	202	\$1,462	\$9,450
3/2/16	30	52,627	168	\$609	\$9,518
4/1/16	30	53,362	280	\$1,026	\$10,295
5/2/16	31	56,611	275	\$1,008	\$10,531
6/1/16	30	55,733	278	\$1,020	\$10,299
6/30/16	29	50,036	280	\$3,506	\$13,183
8/1/16	32	35,291	149	\$1,842	\$10,042
8/30/16	29	42,011	277	\$3,427	\$12,082
9/29/16	30	68,915	315	\$3,965	\$14,816
Totals	366	623,712	315.2	\$21,467	\$129,555
Annual	365	622,008	315.2	\$21,409	\$129,201

3.3 Natural Gas Usage

Natural gas is provided by South Jersey Gas. The average gas cost for the past 12 months is \$0.950/therm, which is the blended rate used throughout the analyses in this report. The third party gas supplier is Direct Energy. The monthly gas consumption is shown in the chart below.

Figure 11 - Natural Gas Usage




Figure 12 - Natural Gas Usage

Gas Billing Data for Central Early Childhood Center			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
10/22/15	30	302	\$309
11/20/15	29	1,801	\$1,706
12/21/15	31	2,485	\$2,357
1/21/16	31	4,233	\$3,996
2/18/16	28	4,412	\$4,147
3/21/16	32	3,274	\$3,091
4/21/16	31	2,281	\$2,149
5/19/16	28	944	\$890
6/21/16	33	124	\$146
7/21/16	30	104	\$124
8/22/16	32	94	\$117
9/21/16	30	104	\$125
Totals	365	20,159	\$19,158
Annual	365	20,159	\$19,158

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 13 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Central Early Childhood Center	National Median Building Type: School (K-12)
Source Energy Use Intensity (kBtu/ft ²)	123.7	141.4
Site Energy Use Intensity (kBtu/ft ²)	58.3	58.2

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Central Early Childhood Center	National Median Building Type: School (K-12)
Source Energy Use Intensity (kBtu/ft ²)	102.4	141.4
Site Energy Use Intensity (kBtu/ft ²)	51.5	58.2

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. This facility has a current score of 34.

A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 15 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Central Early Childhood Center regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 16 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		108,248	34.0	0.0	\$22,484.77	\$99,550.93	\$19,060.00	\$80,490.93	3.6	109,005
ECM 1	Install LED Fixtures	27,547	3.6	0.0	\$5,722.03	\$29,300.78	\$7,500.00	\$21,800.78	3.8	27,740
ECM 2	Retrofit Fixtures with LED Lamps	80,700	30.5	0.0	\$16,762.75	\$70,250.15	\$11,560.00	\$58,690.15	3.5	81,265
Lighting Control Measures		10,026	3.8	0.0	\$2,082.50	\$10,222.00	\$1,335.00	\$8,887.00	4.3	10,096
ECM 3	Install Occupancy Sensor Lighting Controls	10,026	3.8	0.0	\$2,082.50	\$10,222.00	\$1,335.00	\$8,887.00	4.3	10,096
Variable Frequency Drive (VFD) Measures		9,268	1.2	0.0	\$1,925.16	\$9,022.95	\$0.00	\$9,022.95	4.7	9,333
ECM 4	Install VFDs on Hot Water Pumps	9,268	1.2	0.0	\$1,925.16	\$9,022.95	\$0.00	\$9,022.95	4.7	9,333
Plug Load Equipment Control - Vending Machine		3,224	0.0	0.0	\$669.61	\$460.00	\$0.00	\$460.00	0.7	3,246
ECM 5	Vending Machine Control	3,224	0.0	0.0	\$669.61	\$460.00	\$0.00	\$460.00	0.7	3,246
TOTAL OF ALL RECOMMENDED ECMS		130,765	39	0	\$ 27,162.04	\$119,255.88	\$ 20,395.00	\$ 98,860.88	3.6	131,680

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 17 below.

Figure 17 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		107,986	34.0	0.0	\$22,430.37	\$99,550.93	\$19,060.00	\$80,490.93	3.6	108,741
ECM 1	Install LED Fixtures	27,547	3.6	0.0	\$5,722.03	\$29,300.78	\$7,500.00	\$21,800.78	3.8	27,740
ECM 2	Retrofit Fixtures with LED Lamps	80,438	30.4	0.0	\$16,708.34	\$70,250.15	\$11,560.00	\$58,690.15	3.5	81,001

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	27,547	3.6	0.0	\$5,722.03	\$29,300.78	\$7,500.00	\$21,800.78	3.8	27,740

Measure Description

We recommend replacing existing exterior fixtures containing HID lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

ECM 2: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	80,257	30.4	0.0	\$16,670.68	\$70,035.14	\$11,560.00	\$58,475.14	3.5	80,818
Exterior	181	0.0	0.0	\$37.67	\$215.01	\$0.00	\$215.01	5.7	183

Measure Description

We recommend retrofitting existing linear T8 tubes and halogen incandescent lamps with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 18 below.

Figure 18 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		10,026	3.8	0.0	\$2,082.50	\$10,222.00	\$1,335.00	\$8,887.00	4.3	10,096
ECM 3	Install Occupancy Sensor Lighting Controls	10,026	3.8	0.0	\$2,082.50	\$10,222.00	\$1,335.00	\$8,887.00	4.3	10,096

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 3: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
10,026	3.8	0.0	\$2,082.50	\$10,222.00	\$1,335.00	\$8,887.00	4.3	10,096

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in all restrooms, storage rooms, classrooms and offices areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.1.3 Variable Frequency Drive Measures

Our recommendations for variable frequency drive (VFD) measures are summarized in Figure 19 below.

Figure 19 – Summary of Variable Frequency Drive ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		9,268	1.2	0.0	\$1,925.16	\$9,022.95	\$0.00	\$9,022.95	4.7	9,333
ECM 4	Install VFDs on Hot Water Pumps	9,268	1.2	0.0	\$1,925.16	\$9,022.95	\$0.00	\$9,022.95	4.7	9,333

ECM 4: Install VFDs on Hot Water Pumps

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
9,268	1.2	0.0	\$1,925.16	\$9,022.95	\$0.00	\$9,022.95	4.7	9,333

Measure Description

We recommend installing a variable frequency drives (VFD) to control the 3 hp hot water pumps. This measure requires that a majority of the hot water coils be served by 2-way valves and that a differential pressure sensor is installed in the hot water loop. As the hot water valves close, the differential pressure increases. The VFD modulates pump speed to maintain a differential pressure setpoint. Energy savings results from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

4.1.4 Plug Load Equipment Control - Vending Machines

Our recommendations for plug load equipment controls are summarized in Figure 20 below.

Figure 20 – Summary of Plug Load Equipment Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Plug Load Equipment Control - Vending Machine	3,224	0.0	0.0	\$669.61	\$460.00	\$0.00	\$460.00	0.7	3,246
ECM 5 Vending Machine Control	3,224	0.0	0.0	\$669.61	\$460.00	\$0.00	\$460.00	0.7	3,246

ECM 5: Vending Machine Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,224	0.0	0.0	\$669.61	\$460.00	\$0.00	\$460.00	0.7	3,246

Measure Description

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor controls to reduce the energy use. These controls power down vending machines when the vending machine area has been vacant for some time, then power up at regular intervals, as needed, to turn machine lights on or keep the product cool. Energy savings are a dependent on vending machine and activity level in the area surrounding the machines.

4.2 ECMs Evaluated But Not Recommended

The measures below have been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in each measure description section.

Figure 21 – Summary of Measures Evaluated, But Not Recommended

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Electric Unitary HVAC Measures	1,545	1.5	0.0	\$320.99	\$159,042.38	\$4,103.27	\$154,939.11	482.7	1,556
Install High Efficiency Electric AC	1,545	1.5	0.0	\$320.99	\$159,042.38	\$4,103.27	\$154,939.11	482.7	1,556
TOTALS	1,545	1.5	0.0	\$320.99	\$159,042.38	\$4,103.27	\$154,939.11	482.7	1,556

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Install High Efficiency Air Conditioning Units

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,545	1.5	0.0	\$320.99	\$159,042.38	\$4,103.27	\$154,939.11	482.7	1,556

Measure Description

We evaluated replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Reasons for not Recommending

Although we evaluated the replacements of the rooftop packaged units, the payback period on these exceed the useful life of the equipment itself. When the existing equipment come to the end of their useful life, we recommend replacing them with high efficiency HVAC units.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Use Window Treatments/Coverings

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Ensure Economizers are Functioning Properly

Economizers, when properly configured, can be used to significantly reduce mechanical cooling. However, if the outdoor thermostat or enthalpy control is malfunctioning or the damper is stuck or improperly adjusted, benefits from the economizer may not be fully realized. As such, periodic inspection and maintenance is required to ensure proper operation. This maintenance should be scheduled with maintenance of the facility's air conditioning system and should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position. A malfunctioning economizer can significantly increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Perform Proper Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up in order to sustain efficiency and equipment life.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gpf and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a **High** potential for installing a PV array.

The amount of free area, ease of installation (location), and the lack of shading elements contribute to the high potential for PV at the site. A PV array located on the roof of the main building/ground next to the building/over the main parking lot may be feasible. If Central Early Childhood Center is interested in pursuing the installation of PV, we recommended a full feasibility study be conducted.

Figure 22 - Photovoltaic Screening



Potential	High	
System Potential	250	kW DC STC
Electric Generation	297,843	kWh/yr
Displaced Cost	\$25,910	/yr
Installed Cost	\$650,000	

Solar projects must register their projects in the SREC (Solar Renewable Energy Certificate) Registration Program (SRP) prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey’s solar marketplace provides market participants with information about developed new solar projects and insight into future SREC pricing. Refer to Section 8.4 for additional information.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility's ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a **Low** potential for installing a cost-effective CHP system.

Lack of gas service, low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

Figure 23 - Combined Heat and Power Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion this facility is not a good candidate for the Demand Response program.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 24 for a list of the eligible programs identified for each recommended ECM.

Figure 24 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Pay For Performance Existing Buildings
ECM 1	Install LED Fixtures	x		x
ECM 2	Retrofit Fixtures with LED Lamps	x		x
ECM 3	Install Occupancy Sensor Lighting Controls	x		x
ECM 4	Install VFDs on Hot Water Pumps		x	x
ECM 5	Vending Machine Control	x		x

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Pay for Performance - Existing Buildings

Overview

The Pay for Performance – Existing Buildings (P4P EB) program is designed for larger customers with a peak demand over 200 kW in any of the preceding 12 months. Under this program the minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings. **However, for this building additional measures would be needed to reach the 15% savings apart from what has been identified in this audit.**

P4P is generally a good option for medium to large sized facilities looking to implement as many measures as possible under a single project in order to achieve deep energy savings. This program has an added benefit of evaluating a broad spectrum of measures that may not otherwise qualify under other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also utilize the P4P program.

Incentives

Incentives are calculated based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50% total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

How to Participate

To participate in the P4B EB program you will need to contact one of the pre-approved consultants and contractors (“Partners”). Under direct contract to you, the Partner will help further evaluate the measures identified in this report through development of the Energy Reduction Plan (ERP), assist you in implementing selected measures, and verify actual savings one year after the installation. At each of these three milestones your Partner will also facilitate securing program incentives.

Approval of the final scope of work is required by the program prior to installation completion. Although installation can be accomplished by a contractor of your choice (some P4P Partners are also contractors) or by internal personnel, the Partner must remain involved to ensure compliance with the program guidelines and requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: www.njcleanenergy.com/P4P.

8.3 SREC Registration Program

The SREC (Solar Renewable Energy Certificate) Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SRP prior to the start of construction in order to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number which enables it to generate New Jersey SRECs. SREC's are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SREC's to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar RPS. One way they can meet the RPS requirements is by purchasing SRECs. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period can and will fluctuate depending on supply and demand.

Information about the SRP can be found at: www.njcleanenergy.com/srec.

8.4 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler room	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.22	584	0.0	\$121.40	\$585.00	\$100.00	4.00
Custodial office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.09	234	0.0	\$48.56	\$234.00	\$40.00	4.00
Locker room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.02	58	0.0	\$12.14	\$58.50	\$10.00	4.00
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	780	0.02	30	0.0	\$6.15	\$58.50	\$10.00	7.89
Electrical room	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	520	Relamp	No	8	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	520	0.17	158	0.0	\$32.79	\$468.00	\$80.00	11.83
Faculty dining	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	8	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.26	701	0.0	\$145.67	\$601.60	\$120.00	3.31
Men's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	780	0.02	30	0.0	\$6.15	\$58.50	\$10.00	7.89
Women's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	780	0.02	30	0.0	\$6.15	\$58.50	\$10.00	7.89
Storage	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	208	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	208	0.04	16	0.0	\$3.28	\$117.00	\$20.00	29.58
APR entrance and stage	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.26	701	0.0	\$145.67	\$702.00	\$120.00	4.00
APR	36	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,540	Relamp	No	36	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,540	1.32	3,570	0.0	\$741.62	\$3,424.80	\$720.00	3.65
Kitchen	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,540	Relamp	No	8	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,540	0.29	793	0.0	\$164.80	\$761.07	\$160.00	3.65
Kitchen	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.09	234	0.0	\$48.56	\$234.00	\$40.00	4.00
PE teacher's office	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,078	0.16	443	0.0	\$92.04	\$416.80	\$80.00	3.66
Storage	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	208	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	208	0.09	32	0.0	\$6.56	\$234.00	\$40.00	29.58
Custodial closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	52	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	52	0.02	2	0.0	\$0.41	\$58.50	\$10.00	118.32
OT/PT room	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.19	526	0.0	\$109.26	\$451.20	\$90.00	3.31
Main entrance	28	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	28	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.61	1,636	0.0	\$339.91	\$1,638.00	\$280.00	4.00
Main office	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.19	526	0.0	\$109.26	\$451.20	\$90.00	3.31
Main office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.09	234	0.0	\$48.56	\$234.00	\$40.00	4.00
Principal	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,078	0.16	443	0.0	\$92.04	\$416.80	\$80.00	3.66
Men's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	780	0.02	30	0.0	\$6.15	\$58.50	\$10.00	7.89
Women's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	780	0.02	30	0.0	\$6.15	\$58.50	\$10.00	7.89
Conference room	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	880	Relamp	No	4	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	880	0.13	200	0.0	\$41.62	\$300.80	\$60.00	5.79
C106	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.04	117	0.0	\$24.28	\$117.00	\$20.00	4.00

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
VP office	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	4	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.13	351	0.0	\$72.84	\$300.80	\$60.00	3.31
C109	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.06	175	0.0	\$36.42	\$150.40	\$30.00	3.31
C107	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.06	175	0.0	\$36.42	\$150.40	\$30.00	3.31
C140 - Nurse's office	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	12	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.39	1,052	0.0	\$218.51	\$902.40	\$180.00	3.31
C140 - Nurse's office	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.02	58	0.0	\$12.14	\$58.50	\$10.00	4.00
Library	54	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	54	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	1.17	3,156	0.0	\$655.54	\$3,159.00	\$540.00	4.00
Library	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.19	526	0.0	\$109.26	\$451.20	\$90.00	3.31
Library lavatory	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.06	175	0.0	\$36.42	\$175.50	\$30.00	4.00
Library lavatory	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	3	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.10	263	0.0	\$54.63	\$225.60	\$45.00	3.31
Electrical room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.02	58	0.0	\$12.14	\$58.50	\$10.00	4.00
Custodial closet	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.04	117	0.0	\$24.28	\$117.00	\$20.00	4.00
C122	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.04	117	0.0	\$24.28	\$117.00	\$20.00	4.00
CR 1,2,3,4,5	70	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	Yes	70	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,078	2.87	7,754	0.0	\$1,610.70	\$6,614.00	\$1,225.00	3.35
CR 1,2,3,4,5	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,078	0.27	739	0.0	\$153.40	\$585.00	\$135.00	2.93
Hallway	2	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	2	LED Screw-In Lamps: 2 lamps	Wall Switch	18	1,540	0.04	120	0.0	\$24.87	\$215.01	\$0.00	8.65
Main Entrance	15	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	15	LED Screw-In Lamps: 2 lamps	Wall Switch	18	1,540	0.33	898	0.0	\$186.51	\$1,612.59	\$0.00	8.65
Hallway	6	Halogen Incandescent: 1 lamp	Wall Switch	100	1,540	Relamp	No	6	LED Screw-In Lamps: 1 lamp	Wall Switch	15	1,540	0.33	903	0.0	\$187.61	\$469.52	\$30.00	2.34
Library	8	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	8	LED Screw-In Lamps: 2 lamps	Wall Switch	18	1,540	0.18	479	0.0	\$99.47	\$860.05	\$0.00	8.65
Hallway	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.22	584	0.0	\$121.40	\$585.00	\$100.00	4.00
Hallway	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	7	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.15	409	0.0	\$84.98	\$409.50	\$70.00	4.00
CR 6,7,8,9	56	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	Yes	14	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,078	3.13	8,468	0.0	\$1,759.02	\$2,132.80	\$350.00	1.01
CR 6,7,8,9	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,078	0.30	807	0.0	\$167.53	\$117.00	\$55.00	0.37
CR 10,11,13,14	56	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	Yes	14	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,078	3.13	8,468	0.0	\$1,759.02	\$2,132.80	\$350.00	1.01
CR 10,11,13,14	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,078	0.30	807	0.0	\$167.53	\$117.00	\$55.00	0.37
CR 12	14	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	Yes	14	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,078	0.57	1,551	0.0	\$322.14	\$1,322.80	\$245.00	3.35

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
CR 12	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,078	0.05	148	0.0	\$30.68	\$117.00	\$55.00	2.02
Hallway	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.06	175	0.0	\$36.42	\$175.50	\$30.00	4.00
B110	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.19	526	0.0	\$109.26	\$451.20	\$90.00	3.31
B109	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.19	526	0.0	\$109.26	\$451.20	\$90.00	3.31
Hallway	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.26	701	0.0	\$145.67	\$702.00	\$120.00	4.00
CR 19,20,17,18	56	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,540	Relamp	Yes	56	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,078	2.69	7,280	0.0	\$1,512.07	\$6,407.47	\$1,260.00	3.40
CR 21, 22, 23, 24	56	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,540	Relamp	Yes	56	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,078	2.69	7,280	0.0	\$1,512.07	\$6,407.47	\$1,260.00	3.40
A115	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	No	12	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,540	0.39	1,052	0.0	\$218.51	\$902.40	\$180.00	3.31
Boys restroom	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	546	0.22	299	0.0	\$62.16	\$738.00	\$115.00	10.02
Girls restroom	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	546	0.22	299	0.0	\$62.16	\$738.00	\$115.00	10.02
Electrical room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.04	117	0.0	\$24.28	\$117.00	\$20.00	4.00
CR 26, 27	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,078	0.33	886	0.0	\$184.08	\$1,242.00	\$190.00	5.71
Community room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.04	117	0.0	\$24.28	\$117.00	\$20.00	4.00
Hallway	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.19	526	0.0	\$109.26	\$526.50	\$90.00	4.00
CR 28, 29, 30, 31	48	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,540	Relamp	Yes	48	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,078	2.31	6,240	0.0	\$1,296.06	\$5,646.40	\$1,100.00	3.51
CR 32, 33, 34, 35	48	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,540	Relamp	Yes	48	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,078	2.31	6,240	0.0	\$1,296.06	\$5,646.40	\$1,100.00	3.51
Main hallway	27	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	27	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.58	1,578	0.0	\$327.77	\$1,579.50	\$270.00	4.00
Custodial closet	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.04	117	0.0	\$24.28	\$117.00	\$20.00	4.00
Faculty work room	7	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,540	Relamp	Yes	7	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,078	0.29	775	0.0	\$161.07	\$796.40	\$140.00	4.08
Faculty work room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,078	0.03	74	0.0	\$15.34	\$58.50	\$45.00	0.88
Men's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	780	0.02	30	0.0	\$6.15	\$58.50	\$10.00	7.89
Women's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	780	0.02	30	0.0	\$6.15	\$58.50	\$10.00	7.89
Hallway	13	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	13	LED Screw-In Lamps: 2 lamps	Wall Switch	36	1,540	0.13	359	0.0	\$74.60	\$1,397.58	\$0.00	18.73
Hallway	2	Compact Fluorescent: 4 lamps	Wall Switch	96	1,540	Relamp	No	2	LED Screw-In Lamps: 4 lamps	Wall Switch	67	1,540	0.04	102	0.0	\$21.19	\$430.02	\$0.00	20.29
Hallway	8	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	8	LED Screw-In Lamps: 2 lamps	Wall Switch	36	1,540	0.08	221	0.0	\$45.91	\$860.05	\$0.00	18.73

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Hallway	4	Compact Fluorescent: 4 lamps	Wall Switch	96	1,540	Relamp	No	4	LED Screw-In Lamps: 4 lamps	Wall Switch	67	1,540	0.08	204	0.0	\$42.38	\$860.05	\$0.00	20.29
Hallway	2	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	2	LED Screw-In Lamps: 2 lamps	Wall Switch	36	1,540	0.02	55	0.0	\$11.48	\$215.01	\$0.00	18.73
B110	1	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	1	LED Screw-In Lamps: 2 lamps	Wall Switch	36	1,540	0.01	28	0.0	\$5.74	\$107.51	\$0.00	18.73
B109	1	Compact Fluorescent: 2 lamps	Wall Switch	52	1,540	Relamp	No	1	LED Screw-In Lamps: 2 lamps	Wall Switch	36	1,540	0.01	28	0.0	\$5.74	\$107.51	\$0.00	18.73
Hallway	4	Compact Fluorescent: 2 lamps	Wall Switch	48	1,540	Relamp	No	4	LED Screw-In Lamps: 2 lamps	Wall Switch	34	1,540	0.04	102	0.0	\$21.19	\$430.02	\$0.00	20.29
Hallway	4	Compact Fluorescent: 4 lamps	Wall Switch	104	1,540	Relamp	No	4	LED Screw-In Lamps: 4 lamps	Wall Switch	73	1,540	0.08	221	0.0	\$45.91	\$860.05	\$0.00	18.73
Hallway	8	Compact Fluorescent: 2 lamps	Wall Switch	48	1,540	Relamp	No	8	LED Screw-In Lamps: 2 lamps	Wall Switch	34	1,540	0.08	204	0.0	\$42.38	\$860.05	\$0.00	20.29
Hallway	4	Compact Fluorescent: 4 lamps	Wall Switch	104	1,540	Relamp	No	4	LED Screw-In Lamps: 4 lamps	Wall Switch	73	1,540	0.08	221	0.0	\$45.91	\$860.05	\$0.00	18.73
Main hallway	6	Compact Fluorescent: 2 lamps	Wall Switch	48	1,540	Relamp	No	6	LED Screw-In Lamps: 2 lamps	Wall Switch	34	1,540	0.06	153	0.0	\$31.78	\$645.04	\$0.00	20.29
Main hallway	1	Compact Fluorescent: 4 lamps	Wall Switch	104	1,540	Relamp	No	1	LED Screw-In Lamps: 4 lamps	Wall Switch	73	1,540	0.02	55	0.0	\$11.48	\$215.01	\$0.00	18.73
Exterior Play Area	9	Metal Halide: (1) 100W Lamp	Wall Switch	128	4,380	Fixture Replacement	No	9	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	30	4,380	0.58	4,443	0.0	\$922.81	\$3,516.09	\$900.00	2.83
A122	16	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,540	Relamp	No	16	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,540	0.59	1,587	0.0	\$329.61	\$1,522.13	\$320.00	3.65
A122	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	5	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.11	292	0.0	\$60.70	\$292.50	\$50.00	4.00
A100	23	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,540	Relamp	No	23	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,540	0.50	1,344	0.0	\$279.21	\$1,345.50	\$230.00	4.00
Girls restroom	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	546	0.19	262	0.0	\$54.39	\$679.50	\$105.00	10.56
Boys restroom	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	780	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	546	0.19	262	0.0	\$54.39	\$679.50	\$105.00	10.56
Exterior	33	Metal Halide: (1) 70W Lamp	Wall Switch	95	4,380	Fixture Replacement	No	33	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	36	4,380	1.28	9,807	0.0	\$2,037.08	\$12,892.34	\$3,300.00	4.71
Exterior	33	Metal Halide: (1) 100W Lamp	Wall Switch	128	4,380	Fixture Replacement	No	33	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	48	4,380	1.73	13,298	0.0	\$2,762.14	\$12,892.34	\$3,300.00	3.47
Exterior	2	Compact Fluorescent: 2 lamps	Wall Switch	26	4,380	Relamp	No	2	LED Screw-In Lamps: 2 lamps	Wall Switch	8	4,380	0.02	181	0.0	\$37.67	\$215.01	\$0.00	5.71
All school	28	Exit Signs: LED - 2 W Lamp	None	2	8,760	None	No	28	Exit Signs: LED - 2 W Lamp	None	2	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler room	Boiler	2	Other	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler room	Hot water supply	3	Heating Hot Water Pump	3.0	86.5%	No	2,745	No	86.5%	Yes	3	1.17	9,268	0.0	\$1,925.16	\$9,022.95	\$0.00	4.69
Rooftop	All school	10	Exhaust Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Classrooms	6 ton self contained units - hot water coil	25	Supply Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Classrooms	3 ton self contained units - hot water coil	12	Supply Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main office and library	Main office and library	10	Other	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Teachers' work room	2	Supply Fan	0.8	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Main office	2	Supply Fan	1.5	86.5%	Yes	2,745	No	86.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	A hall	1	Supply Fan	2.0	86.5%	No	2,745	No	86.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Gym	1	Supply Fan	15.0	92.5%	No	3,391	No	92.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Gym	1	Exhaust Fan	5.0	89.5%	No	2,745	No	89.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions										Energy Impact & Financial Analysis						
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Electrical room	Electrical room	1	Electric Resistance Heat		10.20	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Nurse's office	1	Packaged AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Main office	1	Packaged AC	5.30		Yes	1	Packaged AC	5.30		14.00		No	0.90	1,238	0.0	\$257.22	\$12,025.49	\$487.60	44.86
Roof	Teachers' work room	1	Packaged AC	3.67		Yes	1	Packaged AC	3.67		14.00		No	0.62	857	0.0	\$177.95	\$8,319.52	\$337.33	44.86
Roof	A hall	1	Packaged AC	6.17		Yes	1	Packaged AC	6.17		11.50		No	0.28	480	0.0	\$99.63	\$10,989.65	\$450.17	105.79
Roof	Hallway	1	Packaged AC	5.33		Yes	1	Packaged AC	5.33		14.00		No	0.91	1,558	0.0	\$323.55	\$12,101.12	\$490.67	35.88
Roof	Corner CR 12	1	Packaged AC	3.67		Yes	1	Packaged AC	3.67		14.00		No	0.62	857	0.0	\$177.95	\$8,319.52	\$337.33	44.86
Roof	Library	1	Packaged AC	15.00		Yes	1	Packaged AC	15.00		11.50		No	0.68	933	0.0	\$193.87	\$20,907.75	\$1,185.00	101.73
Roof	Lobby hallway	1	Packaged AC	11.17		Yes	1	Packaged AC	11.17		11.50		No	0.51	869	0.0	\$180.41	\$19,900.18	\$815.17	105.79
Roof	Gym	1	Packaged AC	30.00		Yes	1	Packaged AC	30.00		9.50		No	-3.06	-5,246	0.0	-\$1,089.60	\$66,479.15	\$0.00	-61.01
Faculty dining	Faculty dining	1	Packaged AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
CR 1,2,3,4,5	CR 1,2,3,4,5	5	Packaged AC	6.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
CR 6,7,8,9,10,11,13,14	CR 6,7,8,9,10,11,13,14	8	Packaged AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
B110, B109, A115	B110, B109, A115	3	Packaged AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
CR 17,18,19,20,21,22,23,24	CR 17,18,19,20,21,22,23,24	8	Packaged AC	6.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
CR 26,27,28,29,30,31,32,33,34,35	CR 26,27,28,29,30,31,32,33,34,35	10	Packaged AC	6.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Art room A122	Art room A122	1	Packaged AC	6.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Music room A100	Music room A100	1	Packaged AC	6.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler room	All school	2	Non-Condensing Hot Water Boiler	1,166.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis					
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler room	Kitchen and restrooms	1	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler room	Kitchen and restrooms	1	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis							
	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Kitchen	1	Stand-Up Refrigerator, Solid Door (31 - 50 cu. ft.)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	
Kitchen	2	Refrigerator Chest	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	

Cooking Equipment Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions	Energy Impact & Financial Analysis							
	Quantity	Equipment Type		High Efficiency Equipment?	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	2	Electric Convection Oven (Half Size)		Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Central Early Childhood Center	95	Computer	145.0	Yes
Central Early Childhood Center	108	Laptop	45.0	Yes
Central Early Childhood Center	33	Printer small	20.0	Yes
Central Early Childhood Center	3	Printer large	200.0	Yes
Central Early Childhood Center	1	Paper shredder	150.0	Yes
Central Early Childhood Center	31	Projector	200.0	Yes
Central Early Childhood Center	11	Microwave oven	1,000.0	No
Central Early Childhood Center	2	Refrigerator -small	150.0	No
Central Early Childhood Center	3	Refrigerator - medium	170.0	No
Central Early Childhood Center	1	Refrigerator - large	218.0	No
Central Early Childhood Center	2	Coffee machine	900.0	Yes
Central Early Childhood Center	1	Toaster	850.0	No
Central Early Childhood Center	2	Toaster oven	1,200.0	No
Central Early Childhood Center	3	Standing fan	100.0	No
Central Early Childhood Center	35	Smart board	5.0	Yes

Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Teachers' lounge	2	Refrigerated	Yes	0.00	3,224	0.0	\$669.61	\$460.00	\$0.00	0.69

Appendix B: ENERGY STAR® Statement of Energy Performance

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

34

ENERGY STAR®
Score¹

Central Early Childhood Center

Primary Property Type: K-12 School
Gross Floor Area (ft²): 71,000
Built: 2004

For Year Ending: October 31, 2016
Date Generated: December 14, 2017

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address	Property Owner	Primary Contact
Central Early Childhood Center 1447 Delsea Drive Deptford, New Jersey 08096	_____ () - _____	_____ () - _____
Property ID: 6136205		

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
57.1 kBtu/ft ²	Electric - Grid (kBtu) 2,073,258 (51%)	National Median Site EUI (kBtu/ft ²) 49.7
	Natural Gas (kBtu) 1,982,008 (49%)	National Median Source EUI (kBtu/ft ²) 105.4
		% Diff from National Median Source EUI 15%
Source EUI		
121 kBtu/ft ²	Annual Emissions	
		Greenhouse Gas Emissions (Metric Tons CO ₂ e/year) 335

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

() - _____



Professional Engineer Stamp
(if applicable)