



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Broad Street Elementary School

Greenwich Township Board of Education

255 West Broad Street

Gibbstown, New Jersey 08027

October 8, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	4
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	6
2.1	Project Contacts	6
2.2	General Site Information.....	6
2.3	Building Occupancy	6
2.4	Building Envelope	7
2.5	On-Site Generation.....	7
2.6	Energy-Using Systems	7
	Lighting System	8
	Steam Heating System	8
	Air Conditioning System (DX)	9
	Domestic Water Heating System	10
	Food Service & Refrigeration	10
	Building Plug Load	10
2.7	Water-Using Systems	10
3	Site Energy Use and Costs.....	11
3.1	Total Cost of Energy	11
3.2	Electricity Usage	12
3.3	Natural Gas Usage	13
3.4	Benchmarking.....	14
3.5	Energy End-Use Breakdown	15
4	Energy Conservation Measures	16
4.1	Recommended ECMs	16
4.1.1	Lighting Upgrades.....	17
	ECM 1: Install LED Fixtures.....	17
	ECM 2: Retrofit Fixtures with LED Lamps.....	18
4.1.2	Lighting Control Measures	19
	ECM 3: Install Occupancy Sensor Lighting Controls	19
	ECM 4: Install High/Low Lighting Controls	20
4.1.3	Domestic Hot Water Heating System Upgrades	21
	ECM 5: Install Low-Flow DHW Devices.....	21
4.1.4	Plug Load Equipment Control - Vending Machines.....	22

ECM 6: Vending Machine Control	22
4.2 ECMs Evaluated but Not Recommended	23
Install High Efficiency Air Conditioning Units	23
Install High Efficiency Steam Boilers	24
5 Energy Efficient Practices	25
Reduce Air Leakage	25
Close Doors and Windows	25
Ensure Lighting Controls Are Operating Properly	25
Perform Routine Motor Maintenance	25
Practice Proper Use of Thermostat Schedules and Temperature Resets	25
Perform Proper Boiler Maintenance	26
Perform Proper Water Heater Maintenance	26
Water Conservation	26
6 On-Site Generation Measures	27
6.1 Photovoltaic.....	27
6.2 Combined Heat and Power	29
7 Demand Response	30
8 Project Funding / Incentives	31
8.1 SmartStart	32
8.2 Direct Install	33
8.3 SREC Registration Program.....	34
8.4 Energy Savings Improvement Program	35
9 Energy Purchasing and Procurement Strategies	36
9.1 Retail Electric Supply Options.....	36
9.2 Retail Natural Gas Supply Options	36

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs 2

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Photovoltaic Potential..... 4

Figure 5 – Project Contacts 6

Figure 6 - Building Schedule..... 6

Figure 7 - Utility Summary 11

Figure 8 - Energy Cost Breakdown 11

Figure 9 - Electric Usage & Demand..... 12

Figure 10 - Electric Usage & Demand..... 12

Figure 11 - Natural Gas Usage..... 13

Figure 12 - Natural Gas Usage..... 13

Figure 13 - Energy Use Intensity Comparison – Existing Conditions..... 14

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 14

Figure 15 - Energy Balance (% and kBtu/SF) 15

Figure 16 – Summary of Recommended ECMs..... 16

Figure 17 – Summary of Lighting Upgrade ECMs..... 17

Figure 18 – Summary of Lighting Control ECMs 19

Figure 19 - Summary of Domestic Water Heating ECMs 21

Figure 20-Summary of Plug Load Equipment Control ECMs..... 22

Figure 21 – Summary of Measures Evaluated, but Not Recommended..... 23

Figure 22 - Photovoltaic Screening 27

Figure 23 - Combined Heat and Power Screening 29

Figure 24 - ECM Incentive Program Eligibility..... 31

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for the Broad Street Elementary School.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey school districts in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Broad Street Elementary School is a two-story building totaling 86,400 square foot, originally constructed in 1926. The building has a flat roof with a small pitched roof section. Exterior walls are finished with stone brick and brick masonry. The windows throughout the facility are double-paned with aluminum frames. Interior lighting is provided mainly by linear fluorescent fixtures which are primarily controlled by manual wall switches. Heating is provided by two steam boilers, and the cooling system consists of window air conditioners and split system ACs.

A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated eight measures. Six measures were recommended for implementation which together represent an opportunity for Broad Street Elementary School to reduce annual energy costs by roughly \$31,499 and annual greenhouse gas emissions by 195,873 lbs CO₂e. We estimate that if all measures were implemented as recommended, the project would pay for itself in roughly 2.6 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Broad Street Elementary School's annual energy use by 14%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Broad Street Elementary School’s existing energy use can be found in Section 3. Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		159,139	32.9	0.0	0.0	0.0	0.0	\$25,890.99	\$82,167.56	\$11,255.00	\$70,912.56	2.7	160,251
ECM 1 Install LED Fixtures	Yes	31,981	5.1	0.0	0.0	0.0	0.0	\$5,203.09	\$22,855.27	\$1,560.00	\$21,295.27	4.1	32,204
ECM 2 Retrofit Fixtures with LED Lamps	Yes	127,158	27.8	0.0	0.0	0.0	0.0	\$20,687.90	\$59,312.29	\$9,695.00	\$49,617.29	2.4	128,047
Lighting Control Measures		23,045	5.1	0.0	0.0	0.0	0.0	\$3,749.27	\$13,470.00	\$1,635.00	\$11,835.00	3.2	23,206
ECM 3 Install Occupancy Sensor Lighting Controls	Yes	18,374	4.0	0.0	0.0	0.0	0.0	\$2,989.37	\$10,470.00	\$1,635.00	\$8,835.00	3.0	18,503
ECM 4 Install High/Low Lighting Controls	Yes	4,671	1.0	0.0	0.0	0.0	0.0	\$759.89	\$3,000.00	\$0.00	\$3,000.00	3.9	4,703
Electric Unitary HVAC Measures		3,494	2.6	0.0	0.0	0.0	0.0	\$568.47	\$10,473.54	\$644.00	\$9,829.54	17.3	3,519
Install High Efficiency Electric AC	No	3,494	2.6	0.0	0.0	0.0	0.0	\$568.47	\$10,473.54	\$644.00	\$9,829.54	17.3	3,519
Gas Heating (HVAC/Process) Replacement		0	0.0	174.6	0.0	0.0	174.6	\$1,543.10	\$125,675.98	\$2,779.00	\$122,896.98	79.6	20,440
Install High Efficiency Steam Boilers	No	0	0.0	174.6	0.0	0.0	174.6	\$1,543.10	\$125,675.98	\$2,779.00	\$122,896.98	79.6	20,440
Domestic Water Heating Upgrade		9,018	0.0	14.6	0.0	0.0	14.6	\$1,596.35	\$250.95	\$0.00	\$250.95	0.2	10,792
ECM 5 Install Low-Flow Domestic Hot Water Devices	Yes	9,018	0.0	14.6	0.0	0.0	14.6	\$1,596.35	\$250.95	\$0.00	\$250.95	0.2	10,792
Plug Load Equipment Control - Vending Machine		1,612	0.0	0.0	0.0	0.0	0.0	\$262.24	\$230.00	\$0.00	\$230.00	0.9	1,623
ECM 6 Vending Machine Control	Yes	1,612	0.0	0.0	0.0	0.0	0.0	\$262.24	\$230.00	\$0.00	\$230.00	0.9	1,623
TOTALS FOR RECOMMENDED MEASURES		192,813	38	15	0	0	15	\$31,499	\$96,119	\$12,890	\$83,229	2.6	195,873
TOTALS FOR ALL EVALUATED MEASURES		196,307	40.6	189.2	0.0	0.0	189.2	\$33,610.42	\$232,268.03	\$16,313.00	\$215,955.03	6.4	219,831

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Electric Unitary HVAC measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air condition systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

Gas Heating (HVAC/Process) measures generally involve replacing older inefficient hydronic heating systems with modern energy efficient systems. Gas heating systems can provide equivalent heating compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel demands for heating, due to improved combustion and heat transfer efficiency.

Domestic Hot Water upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

Plug Load Equipment control measures generally involve installing automated devices that limit the power usage or operation of equipment that is plugged into an electric outlets when not in use.

Energy Efficient Practices

TRC also identified eight low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Broad Street Elementary School include:

- Reduce Air Leakage
- Close Doors and Windows
- Ensure Lighting Controls Are Operating Properly
- Perform Routine Motor Maintenance
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Perform Proper Boiler Maintenance
- Perform Proper Water Heater Maintenance
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Broad Street Elementary School. Based on the configuration of the site and its loads there is a high potential for installing a photovoltaic (PV) array.

Figure 4 – Photovoltaic Potential

Potential	High	
System Potential	143	kW DC STC
Electric Generation	170,366	kWh/yr
Displaced Cost	\$14,820	/yr
Installed Cost	\$371,800	

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- SREC (Solar Renewable Energy Certificate) Registration Program (SRP)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.4 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8 or: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 5 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Scott Campbell	School Business Administrator	scampbell@ns.greenwich.k12.nj.us	856-224-4920 x2120
Designated Representative			
Gerardo Batista	Interim Supervisor of Buildings & Grounds	gbatista@greenwich.k.12.nj.us	856-224-4920 x2129
TRC Energy Services			
Moussa Traore	Auditor	mtraore@trcsolutions.com	732-855-0033

2.2 General Site Information

On November 17, 2017, TRC performed an energy audit at Broad Street Elementary School located in Gibbstown, New Jersey. TRC’s auditor met with Gerardo Batista to review the facility operations and help focus our investigation on specific energy-using systems.

The 86,400 square foot elementary school building is a two-story facility and is comprised of administrative offices, gymnasium, auditorium, classrooms, library, locker rooms, kitchen, storage and mechanical rooms. The original building was constructed in 1926. Other sections were added in 1930 and 1956 to accommodate additional classrooms and other spaces. The building is used primarily for elementary programs.

2.3 Building Occupancy

The school operates on a 12 month schedule and is open Monday through Friday. The typical schedule is presented in the table below. During a typical day, the school is occupied by approximately 360 students and staff.

Figure 6 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Broad Street Elementary School	Weekday	6:00 AM - 8:00 PM
Broad Street Elementary School	Weekend	Closed

2.4 Building Envelope

The foundation consists of cast-in-place concrete perimeter wall. The original building has a pitched roof covered with asphalt shingles. The 1930 and 1956 additions have flat roof sections covered with a white membrane and white light stone which appear to be in good condition. The exterior walls consist of stone brick and masonry brick which are well maintained. The windows throughout the facility are double-paned with aluminum frames and are in good condition. Exterior doors are constructed of metal. The door seals were found to be in good condition. Overall, the building's envelope is in good condition.



Image 1: Building Envelope

2.5 On-Site Generation

Broad Street Elementary School does not have any on-site electric generation capacity.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's lighting equipment.

Lighting System

Lighting is provided mainly by 32-Watt linear fluorescent T8 lamps with electronic ballasts as well as some compact fluorescent and incandescent lamps. Most of the fixtures are 2-lamp or 4-lamp, 4-foot long troffers with diffusers. The gymnasium is illuminated with a combination of 32-Watt linear fluorescent lamps and 400-Watt metal halide lamps while the auditorium is primarily lit with LED downlight fixtures. Some 60-Watt incandescent and compact fluorescent lamps are found in the spaces such as the gymnasium office, boy's locker room, auditorium, storage room and the main office. Lighting control is provided by manual wall switches except for the restrooms which are controlled by occupancy sensors. Exit signs in the facility use LED sources. Facility exterior lighting consists of 55-Watt LED, 150-Watt halogen incandescent, and 200-Watt and 400-Watt high pressure sodium wall mounted fixtures. Also, there are six 400-Watt metal halide pole lighting fixtures. Exterior lighting is controlled with timers and photocells.

Steam Heating System

The steam system consists of two Smith forced draft steam boilers plus the associated distribution system. One boiler provides 2,779 MBh output at an estimated combustion efficiency of 80%. It is 20 years old and appears to be in fair condition. The second boiler provides 4,320 MBh output, manufactured in 1956. This boiler has an estimated combustion efficiency of 75%. Each boiler has a 3 hp combustion air fan. The boilers operate in a lead/lag configuration.

Steam is supplied to the radiators, heating baseboards and heating unit ventilators at 15 psi and there are three constant speed condensate pumps, approximately 0.75 hp each. Heating hot water is supplied to the air handlers serving the auditorium and the gymnasium through a heat exchanger. Four constant speed hot water supply pumps, roughly 0.75 hp each, supply heating hot water to the air handlers.

Local thermostats are used to control the temperature in spaces. The school should consider re-evaluating the building heating load and installing modular steam boilers when replacing the current inefficient boilers.



Image 2: Heating System

Air Conditioning System (DX)



Image 3: Air Conditioning System

The cooling system consists mainly of window air conditioners. There are 49 window ACs ranging from 0.42 to 1.5 ton and they all appear in good condition. In addition to the window ACs, there are three split system ACs ranging from 0.75 to 4 ton serving the second-floor teacher room (0.75 ton), room 207 (3 ton) and the old CST office (4 Ton). The 3 ton and the 4 ton units are 17 and 22 years old respectively and have passed their useful service life.

Domestic Water Heating System

The domestic water heating system for the facility consists of two Bradford White electric storage tank water heaters, plus one electric and two gas fired tankless flow control water heaters. The Bradford White storage tank water heaters have 40 and 19 gallon storage tanks with 4.5 kW and 1.5 kW inputs capacity respectively. The two gas fired tankless heaters have an input capacity of 180 MBh each and serve the kitchen and the cafeteria. The electric tankless hot water heater serves the boys and girls restrooms. The domestic water heating system appear in good condition.




Image 4: Domestic Water Heating

Food Service & Refrigeration

The school houses one small institutional kitchen. The kitchen includes gas convection ovens, a gas fryer, an electric griddle, insulated food holding cabinets, one stand-up refrigerator and one walk in medium temperature freezer. The kitchen is well maintained.

Building Plug Load

The building has approximately 109 computers with LCD monitors that are used daily, plus a server, five large photocopiers, and 12 printers. The computers, monitors, and printers seemed to be all recent models designed with power management software to reduce power when they sit idle for more than a few minutes. The building has two vending machines located in the teacher room.

2.7 Water-Using Systems

There are several restrooms at this facility. A sampling of restrooms found that all of the faucets are rated for 2.2 gallons per minute (gpm) or higher, the toilets are rated at 2.5 gallons per flush (gpf) and the urinals are rated at 2 gpf.

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 7 - Utility Summary

Utility Summary for Broad Street Elementary School		
Fuel	Usage	Cost
Electricity	427,997 kWh	\$69,633
Natural Gas	46,362 Therms	\$40,982
Total		\$110,615

The current annual energy cost for this facility is \$110,615 as shown in the chart below.

Figure 8 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by Atlantic City Electric. The average electric cost over the past 12 months was \$0.163/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below. The electricity use profile reflects high occupancy in the summer months and this confirm the building 12 month schedule.

Figure 9 - Electric Usage & Demand




Figure 10 - Electric Usage & Demand

Electric Billing Data for Broad Street Elementary School				
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Total Electric Cost
3/1/16	31	32,819	142	\$5,350
4/1/16	30	32,156	143	\$5,194
5/2/16	31	33,353	144	\$5,469
6/1/16	30	36,844	144	\$6,016
6/30/16	31	39,344	143	\$6,139
8/1/16	31	43,475	145	\$6,799
8/31/16	30	44,692	145	\$7,187
10/3/16	31	30,740	141	\$5,281
11/1/16	30	30,234	141	\$5,169
12/1/16	31	33,314	141	\$5,465
1/3/17	31	37,786	142	\$6,180
1/31/17	28	33,240	142	\$5,383
Totals	365	427,997	145.38	\$69,633
Annual	365	427,997	145.38	\$69,633

3.3 Natural Gas Usage

Natural gas is provided by South Jersey Gas. The average gas cost for the past 12 months is \$0.841/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below. The gas use profile is typical for a facility with a significant heating load relative to other end uses.

Figure 11 - Natural Gas Usage




Figure 12 - Natural Gas Usage

Gas Billing Data for Broad Street Elementary School			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
3/1/16	30	9,878	\$7,003
4/1/16	30	4,513	\$3,626
5/2/16	31	2,895	\$1,702
6/1/16	30	427	\$263
6/30/16	31	56	\$119
8/1/16	30	27	\$68
8/31/16	31	19	\$50
10/3/16	32	98	\$544
11/1/16	30	1,125	\$3,014
12/1/16	30	5,414	\$3,269
1/3/17	30	12,532	\$12,221
1/31/17	30	9,378	\$9,103
Totals	365	46,362	\$40,982
Annual	365	46,362	\$40,982

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager®, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager® analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 13 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Broad Street Elementary School	National Median Building Type: School (K-12)
Source Energy Use Intensity (kBtu/ft ²)	109.4	141.4
Site Energy Use Intensity (kBtu/ft ²)	70.6	58.2

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Broad Street Elementary School	National Median Building Type: School (K-12)
Source Energy Use Intensity (kBtu/ft ²)	85.3	141.4
Site Energy Use Intensity (kBtu/ft ²)	62.8	58.2

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. This facility has a current score of 79.

A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager® account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager® regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 15 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Broad Street Elementary School regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 16 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		159,139	32.9	0.0	\$25,890.99	\$82,167.56	\$11,255.00	\$70,912.56	2.7	160,251
ECM 1	Install LED Fixtures	31,981	5.1	0.0	\$5,203.09	\$22,855.27	\$1,560.00	\$21,295.27	4.1	32,204
ECM 2	Retrofit Fixtures with LED Lamps	127,158	27.8	0.0	\$20,687.90	\$59,312.29	\$9,695.00	\$49,617.29	2.4	128,047
Lighting Control Measures		23,045	5.1	0.0	\$3,749.27	\$13,470.00	\$1,635.00	\$11,835.00	3.2	23,206
ECM 3	Install Occupancy Sensor Lighting Controls	18,374	4.0	0.0	\$2,989.37	\$10,470.00	\$1,635.00	\$8,835.00	3.0	18,503
ECM 4	Install High/Low Lighting Controls	4,671	1.0	0.0	\$759.89	\$3,000.00	\$0.00	\$3,000.00	3.9	4,703
Domestic Water Heating Upgrade		9,018	0.0	14.6	\$1,590.04	\$250.95	\$0.00	\$250.95	0.2	10,792
ECM 5	Install Low-Flow Domestic Hot Water Devices	9,018	0.0	14.6	\$1,590.04	\$250.95	\$0.00	\$250.95	0.2	10,792
Plug Load Equipment Control - Vending Machine		1,612	0.0	0.0	\$262.24	\$230.00	\$0.00	\$230.00	0.9	1,623
ECM 6	Vending Machine Control	1,612	0.0	0.0	\$262.24	\$230.00	\$0.00	\$230.00	0.9	1,623
TOTALS		192,813	38.0	14.6	\$31,492.54	\$96,118.51	\$12,890.00	\$83,228.51	2.6	195,873

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 17 below.

Figure 17 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		159,139	32.9	0.0	\$25,890.99	\$82,167.56	\$11,255.00	\$70,912.56	2.7	160,251
ECM 1	Install LED Fixtures	31,981	5.1	0.0	\$5,203.09	\$22,855.27	\$1,560.00	\$21,295.27	4.1	32,204
ECM 2	Retrofit Fixtures with LED Lamps	127,158	27.8	0.0	\$20,687.90	\$59,312.29	\$9,695.00	\$49,617.29	2.4	128,047

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	10,961	2.4	0.0	\$1,783.35	\$7,621.22	\$60.00	\$7,561.22	4.2	11,038
Exterior	21,019	2.7	0.0	\$3,419.74	\$15,234.05	\$1,500.00	\$13,734.05	4.0	21,166

Measure Description

We recommend replacing existing fixtures containing HID lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

ECM 2: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	125,732	27.6	0.0	\$20,455.99	\$59,044.04	\$9,695.00	\$49,349.04	2.4	126,612
Exterior	1,425	0.2	0.0	\$231.92	\$268.25	\$0.00	\$268.25	1.2	1,435

Measure Description

We recommend retrofitting existing linear fluorescent lamps, incandescent, halogen, and compact fluorescent lamps with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 18 below.

Figure 18 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		23,045	5.1	0.0	\$3,749.27	\$13,470.00	\$1,635.00	\$11,835.00	3.2	23,206
ECM 3	Install Occupancy Sensor Lighting Controls	18,374	4.0	0.0	\$2,989.37	\$10,470.00	\$1,635.00	\$8,835.00	3.0	18,503
ECM 4	Install High/Low Lighting Controls	4,671	1.0	0.0	\$759.89	\$3,000.00	\$0.00	\$3,000.00	3.9	4,703

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 3: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
18,374	4.0	0.0	\$2,989.37	\$10,470.00	\$1,635.00	\$8,835.00	3.0	18,503

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in storage rooms, classrooms, and offices. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 4: Install High/Low Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
4,671	1.0	0.0	\$759.89	\$3,000.00	\$0.00	\$3,000.00	3.9	4,703

Measure Description

We recommend installing occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons. Typical areas for such lighting control are stairwells, interior corridors.

Lighting fixtures with these controls operate at default low levels when the area is not occupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. The lighting systems are switched to full lighting levels whenever an occupant is detected. Fixtures are automatically switched back to low level after an area has been vacant for a preset period of time. Energy savings results from only providing full lighting levels when it is required.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage needs to be provided to ensure that lights turn on in each area as an occupant approaches.

Additional savings from reduced lighting maintenance may also result from this measure, due to reduced lamp operation.

4.1.3 Domestic Hot Water Heating System Upgrades

Our recommendations for domestic water heating system improvements are summarized in Figure 19 below.

Figure 19 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		9,018	0.0	14.6	\$1,590.04	\$250.95	\$0.00	\$250.95	0.2	10,792
ECM 5	Install Low-Flow Domestic Hot Water Devices	9,018	0.0	14.6	\$1,590.04	\$250.95	\$0.00	\$250.95	0.2	10,792

ECM 5: Install Low-Flow DHW Devices

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
9,018	0.0	14.6	\$1,590.04	\$250.95	\$0.00	\$250.95	0.2	10,792

Measure Description

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators can reduce hot water usage, relative to standard aerators, which saves energy. Low-flow devices reduce the overall water flow from the fixture, while still adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

4.1.4 Plug Load Equipment Control - Vending Machines

Our recommendations for plug load equipment measures are summarized in Figure 20 below.

Figure 20-Summary of Plug Load Equipment Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Plug Load Equipment Control - Vending Machine		1,612	0.0	0.0	\$262.24	\$230.00	\$0.00	\$230.00	0.9	1,623
ECM 6	Vending Machine Control	1,612	0.0	0.0	\$262.24	\$230.00	\$0.00	\$230.00	0.9	1,623

ECM 6: Vending Machine Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,612	0.0	0.0	\$262.24	\$230.00	\$0.00	\$230.00	0.9	1,623

Measure Description

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor controls to reduce the energy use. These controls power down vending machines when the vending machine area has been vacant for some time, then power up at regular intervals, as needed, to turn machine lights on or keep the product cool. Energy savings are a dependent on vending machine and activity level in the area surrounding the machines.

4.2 ECMs Evaluated but Not Recommended

The measures below have been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in each measure description section.

Figure 21 – Summary of Measures Evaluated, but Not Recommended

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Electric Unitary HVAC Measures	3,494	2.6	0.0	\$568.47	\$10,473.54	\$644.00	\$9,829.54	17.3	3,519
Install High Efficiency Electric AC	3,494	2.6	0.0	\$568.47	\$10,473.54	\$644.00	\$9,829.54	17.3	3,519
Gas Heating (HVAC/Process) Replacement	0	0.0	174.6	\$1,543.10	\$125,675.98	\$2,779.00	\$122,896.98	79.6	20,440
Install High Efficiency Steam Boilers	0	0.0	174.6	\$1,543.10	\$125,675.98	\$2,779.00	\$122,896.98	79.6	20,440
TOTALS	3,494	2.6	174.6	\$2,111.58	\$136,149.52	\$3,423.00	\$132,726.52	62.9	23,958

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Install High Efficiency Air Conditioning Units

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,494	2.6	0.0	\$568.47	\$10,473.54	\$644.00	\$9,829.54	17.3	3,519

Measure Description

We evaluated replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Reasons for not Recommending

The simple payback of this measure exceeds the expected useful life of the equipment and is therefore not recommended on the basis of energy savings alone.

Install High Efficiency Steam Boilers

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
0	0.0	174.6	\$1,543.10	\$125,675.98	\$2,779.00	\$122,896.98	79.6	20,440

Measure Description

We evaluated replacing older inefficient steam boilers with high efficiency steam boilers. Significant improvements have been made in combustion technology resulting in increases in overall boiler efficiency. Energy savings results from improved combustion efficiency and reduced standby losses at low loads.

Reasons for not Recommending

The simple payback of this measure exceeds the expected useful life of the equipment and is therefore not recommended on the basis of energy savings alone. Boilers today tend to be smaller, modular units with sophisticated controls to ensure optimal sequencing to meet varying heating needs. We recommend a detailed study of the boiler and distribution system be performed as the Board of Education considers options for boiler replacement.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Perform Routine Motor Maintenance

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Perform Proper Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up in order to sustain efficiency and equipment life.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gpf and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.3 for any low-flow ECM recommendations.

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a **High** potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear meet these minimum criteria for cost-effective PV installation.

Figure 22 - Photovoltaic Screening



Potential	High	
System Potential	143	kW DC STC
Electric Generation	170,366	kWh/yr
Displaced Cost	\$14,820	/yr
Installed Cost	\$371,800	

Solar projects must register their projects in the SREC (Solar Renewable Energy Certificate) Registration Program (SRP) prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey’s solar marketplace provides market participants with information about developed new solar projects and insight into future SREC pricing. Refer to Section 8.3 for additional information.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility's ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a **Low** potential for installing a cost-effective CHP system.

Low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/.

Figure 23 - Combined Heat and Power Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion, this facility has a low potential for DR curtailment.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 24 for a list of the eligible programs identified for each recommended ECM.

Figure 24 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	X		X			
ECM 2	Retrofit Fixtures with LED Lamps	X		X			
ECM 3	Install Occupancy Sensor Lighting Controls	X		X			
ECM 4	Install High/Low Lighting Controls			X			
ECM 5	Install Low-Flow Domestic Hot Water Devices			X			
ECM 6	Vending Machine Control			X			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for any recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to **70%** of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

How to Participate

To participate in the Direct Install program you will need to contact the participating contractor who the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since Direct Install offers a free assessment of eligible measures, Direct Install is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 SREC Registration Program

The SREC (Solar Renewable Energy Certificate) Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SRP prior to the start of construction in order to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number which enables it to generate New Jersey SRECs. SREC's are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SREC's to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar RPS. One way they can meet the RPS requirements is by purchasing SRECs. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period can and will fluctuate depending on supply and demand.

Information about the SRP can be found at: www.njcleanenergy.com/srec.

8.4 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third-party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility is purchasing electricity from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility is purchasing natural gas from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	4	LED - Fixtures: Downlight Pendant	Wall Switch	54	2,600	None	No	4	LED - Fixtures: Downlight Pendant	Wall Switch	54	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	1	Metal Halide: (1) 250W Lamp	Wall Switch	295	2,600	Fixture Replacement	No	1	LED - Fixtures: Downlight Pendant	Wall Switch	125	2,600	0.11	508	0.0	\$82.70	\$608.58	\$5.00	7.30
Boiler Room	2	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	9	2,600	None	No	2	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	9	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	1	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.03	152	0.0	\$24.81	\$53.75	\$5.00	1.97
Boiler Room	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - Exit 20	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - Exit 20	7	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	7	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	1,820	0.34	1,536	0.0	\$249.94	\$865.93	\$140.00	2.90
Main Corridor	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Corridor	30	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	30	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	1,820	1.44	6,584	0.0	\$1,071.18	\$3,454.00	\$600.00	2.66
Corridor - Kind.	5	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	5	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	1,820	0.24	1,097	0.0	\$178.53	\$675.67	\$100.00	3.22
Corridor - 2nd Grade	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	1,820	0.19	878	0.0	\$142.82	\$580.53	\$80.00	3.50
Corridor - Kind.	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - 2nd Grade	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Auditorium Lobby	10	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	10	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	1,820	0.48	2,195	0.0	\$357.06	\$1,151.33	\$200.00	2.66
Auditorium Lobby	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	48	0.0	\$7.78	\$48.20	\$10.00	4.91
Auditorium Lobby	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.16	748	0.0	\$121.71	\$467.00	\$80.00	3.18
Main Office	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	48	0.0	\$7.78	\$48.20	\$10.00	4.91
Main Office	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Office	1	Compact Fluorescent: Circle Shape	Wall Switch	40	2,600	Fixture Replacement	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	25	2,600	0.01	45	0.0	\$7.30	\$63.65	\$0.00	8.72
Main Office	1	Compact Fluorescent: Circle Shape	Wall Switch	32	2,600	Fixture Replacement	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	20	2,600	0.01	36	0.0	\$5.84	\$63.65	\$0.00	10.90
Main Office	1	Compact Fluorescent: Circle Shape	Wall Switch	22	2,600	Fixture Replacement	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	15	2,600	0.00	21	0.0	\$3.41	\$63.65	\$0.00	18.69
Main Entrance	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,820	0.10	465	0.0	\$75.69	\$368.80	\$20.00	4.61
Faculty Restroom	1	Compact Fluorescent: Circle Shape	Wall Switch	32	2,600	Fixture Replacement	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	20	2,600	0.01	36	0.0	\$5.84	\$63.65	\$0.00	10.90
Faculty Restroom	1	Compact Fluorescent: Circle Shape	Wall Switch	22	2,600	Fixture Replacement	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	15	2,600	0.00	21	0.0	\$3.41	\$63.65	\$0.00	18.69

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Teacher Lunch	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Teacher Lunch	1	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	40	2,600	None	No	1	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	40	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Storage Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.11	499	0.0	\$81.14	\$350.00	\$40.00	3.82
School Area	20	Incandescent: Screen in lamp	Wall Switch	100	2,600	Relamp	No	20	LED Screw-In Lamps: Screw in Lamp	Wall Switch	15	2,600	1.11	5,083	0.0	\$826.98	\$1,075.06	\$100.00	1.18
Printing Room	1	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.03	152	0.0	\$24.81	\$53.75	\$5.00	1.97
Girls Locker Room	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Girls Locker Room	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.19	873	0.0	\$142.00	\$525.50	\$90.00	3.07
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,184	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,184	0.02	83	0.0	\$13.48	\$58.50	\$10.00	3.60
Gymnasium	13	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	13	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	0.63	2,853	0.0	\$464.18	\$1,352.73	\$280.00	2.31
Gymnasium	11	Metal Halide: (1) 400W Lamp	Wall Switch	458	2,600	Fixture Replacement	Yes	11	LED - Fixtures: Downlight Pendant	Occupancy Sensor	145	1,820	2.57	11,725	0.0	\$1,907.64	\$9,664.38	\$440.00	4.84
Gymnasium Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Gymnasium Office	6	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	Yes	6	LED Screw-In Lamps: Screw in Lamp	Occupancy Sensor	9	1,820	0.21	963	0.0	\$156.74	\$438.52	\$50.00	2.48
Gymnasium	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Storage Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Boys Locker Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.11	499	0.0	\$81.14	\$350.00	\$60.00	3.57
Boys Locker Room	3	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	Yes	3	LED Screw-In Lamps: Screw in Lamp	Occupancy Sensor	9	1,820	0.11	482	0.0	\$78.37	\$277.26	\$35.00	3.09
Boys Locker Room	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,184	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,184	0.02	83	0.0	\$13.48	\$58.50	\$10.00	3.60
Office	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	48	0.0	\$7.78	\$48.20	\$10.00	4.91
Janitorial	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.07	335	0.0	\$54.48	\$190.27	\$40.00	2.76
Girls Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,184	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,184	0.06	249	0.0	\$40.45	\$175.50	\$30.00	3.60
Room 102	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
CST Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	0.29	1,317	0.0	\$214.24	\$686.80	\$140.00	2.55
Library	9	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	9	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.37	1,683	0.0	\$273.85	\$792.80	\$155.00	2.33
Library	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Storage Room	2	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	2	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.07	305	0.0	\$49.62	\$107.51	\$10.00	1.97
Room 104	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 106	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Room 107	20	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	20	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.55	2,494	0.0	\$405.70	\$1,402.00	\$240.00	2.86
PTA Room	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Girls Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,184	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,184	0.04	166	0.0	\$26.97	\$117.00	\$20.00	3.60
Room 108	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Boys Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	114	2,184	Relamp	No	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,184	0.07	261	0.0	\$45.77	\$190.27	\$40.00	3.28
Room 110	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Maintenance Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.11	499	0.0	\$81.14	\$350.00	\$60.00	3.57
Janitorial	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Corridor Old Section	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	48	0.0	\$7.78	\$48.20	\$10.00	4.91
Corridor Old Section	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	1,820	0.10	439	0.0	\$71.41	\$390.27	\$40.00	4.90
Corridor Old Section	1	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.03	152	0.0	\$24.81	\$53.75	\$5.00	1.97
Corridor Old Section	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,120	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,120	0.04	237	0.0	\$38.53	\$117.00	\$20.00	2.52
Restroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	48	0.0	\$7.78	\$48.20	\$10.00	4.91
Electrical Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.07	335	0.0	\$54.48	\$190.27	\$40.00	2.76
Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.08	374	0.0	\$60.86	\$445.50	\$65.00	6.25
Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	0.14	658	0.0	\$107.12	\$555.40	\$95.00	4.30
Room 111	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Room 112	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.04	167	0.0	\$27.24	\$95.13	\$20.00	2.76
Room 113	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room 116	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 118	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Nurse Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Nurse Office	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.04	167	0.0	\$27.24	\$95.13	\$20.00	2.76
Nurse Office	3	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	Yes	3	LED Screw-In Lamps: Screw in Lamp	Occupancy Sensor	9	1,820	0.11	482	0.0	\$78.37	\$277.26	\$35.00	3.09
Nurse Office	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.02	87	0.0	\$14.11	\$63.20	\$0.00	4.48
Room 115	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Room 120	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Auditorium	8	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	8	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Auditorium	10	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	Yes	10	LED Screw-In Lamps: Screw in Lamp	Occupancy Sensor	9	1,820	0.35	1,606	0.0	\$261.23	\$653.53	\$70.00	2.23
Auditorium	40	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	9	2,600	None	Yes	40	LED - Fixtures: Downlight Solid State Retrofit	Occupancy Sensor	9	1,820	0.07	323	0.0	\$52.54	\$232.00	\$40.00	3.65
Auditorium	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.11	499	0.0	\$81.14	\$350.00	\$60.00	3.57
Auditorium	8	Halogen Incandescent: Spot Light	Wall Switch	150	2,600	Relamp	No	8	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	23	2,600	0.67	3,038	0.0	\$494.24	\$429.20	\$0.00	0.87
Auditorium Stage	120	Incandescent: Screen in lamp	Wall Switch	100	2,600	Relamp	No	120	LED Screw-In Lamps: Screw in Lamp	Wall Switch	15	2,600	6.69	30,498	0.0	\$4,961.86	\$6,450.36	\$600.00	1.18
Stairwell Exit 6	2	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.04	173	0.0	\$28.21	\$126.40	\$0.00	4.48
Stairwell Exit 6	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.02	99	0.0	\$16.05	\$58.50	\$10.00	3.02
Corridor	9	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	Yes	9	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	1,820	0.12	568	0.0	\$92.38	\$633.80	\$90.00	5.89
Corridor	16	Compact Fluorescent: Screen in lamp	Wall Switch	23	2,600	Relamp	Yes	16	LED Screw-In Lamps: Screw in Lamp	High/Low Control	15	1,820	0.13	598	0.0	\$97.29	\$1,260.05	\$80.00	12.13
Corridor	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Corridor	22	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	22	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	1,820	1.06	4,828	0.0	\$785.53	\$2,692.93	\$440.00	2.87
Main Corridor	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	1,820	0.16	748	0.0	\$121.71	\$551.00	\$60.00	4.03
Main Corridor	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Music Room	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	3	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.10	444	0.0	\$72.24	\$225.60	\$45.00	2.50
Music Room	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.49	2,244	0.0	\$365.13	\$1,169.00	\$200.00	2.65
Music Room	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room 202	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.44	1,995	0.0	\$324.56	\$1,052.00	\$180.00	2.69
Room 201	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.44	1,995	0.0	\$324.56	\$1,052.00	\$180.00	2.69
Room 204	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 203	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 208	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 205	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 210	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 207	9	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	0.43	1,975	0.0	\$321.35	\$972.20	\$200.00	2.40
Room 209	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 211	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 212	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Girls Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,184	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,184	0.04	166	0.0	\$26.97	\$117.00	\$20.00	3.60
Teacher Lunch 2nd Floor	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.02	87	0.0	\$14.11	\$63.20	\$0.00	4.48
Teacher Lunch 2nd Floor	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.08	374	0.0	\$60.86	\$266.40	\$50.00	3.56
Art Room	11	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	11	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.45	2,057	0.0	\$334.71	\$943.20	\$185.00	2.27
Boys Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,184	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,184	0.04	166	0.0	\$26.97	\$117.00	\$20.00	3.60
Room 214	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 215	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Closet	1	Compact Fluorescent: Screen in lamp	Wall Switch	18	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	12	2,600	0.00	18	0.0	\$2.92	\$53.75	\$5.00	16.70
Old CST Office	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.08	374	0.0	\$60.86	\$291.50	\$50.00	3.97
Old CST Office	18	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	Yes	18	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,820	0.25	1,136	0.0	\$184.76	\$963.60	\$200.00	4.24
Old CST Office	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Old CST Office	1	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.03	152	0.0	\$24.81	\$53.75	\$5.00	1.97
Room 216	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 217	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room 219	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Faculty Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Room 217	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.14	623	0.0	\$101.43	\$408.50	\$70.00	3.34
Room 217	1	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.03	152	0.0	\$24.81	\$53.75	\$5.00	1.97
Room 218	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Room 220	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.33	1,496	0.0	\$243.42	\$818.00	\$140.00	2.79
Facility Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.11	499	0.0	\$81.14	\$350.00	\$60.00	3.57
Facility Office	1	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.03	152	0.0	\$24.81	\$53.75	\$5.00	1.97
Room 222	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Room 225	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Room 224	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.38	1,746	0.0	\$283.99	\$935.00	\$160.00	2.73
Stairwell Exit 5	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Stairwell Exit 3	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.04	167	0.0	\$27.24	\$95.13	\$20.00	2.76
Stairwell Exit 3	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.02	99	0.0	\$16.05	\$58.50	\$10.00	3.02
Stairwell Exit 17	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.04	167	0.0	\$27.24	\$95.13	\$20.00	2.76
Stairwell Exit 17	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	197	0.0	\$32.11	\$117.00	\$20.00	3.02
Stairwell Exit 2	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.04	167	0.0	\$27.24	\$95.13	\$20.00	2.76
Stairwell Exit 2	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.02	99	0.0	\$16.05	\$58.50	\$10.00	3.02
Stairwell Exit 2	1	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.03	152	0.0	\$24.81	\$53.75	\$5.00	1.97
Storage Room	2	Incandescent: Screen in lamp	Wall Switch	60	2,600	Relamp	No	2	LED Screw-In Lamps: Screw in Lamp	Wall Switch	9	2,600	0.07	305	0.0	\$49.62	\$107.51	\$10.00	1.97
Exterior Wall Pack	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Day light Dimming	55	4,380	None	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Day light Dimming	55	4,380	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Exterior Wall Pack	3	Incandescent: Outdoor Wall-Mounted Area Fixture	Day light Dimming	40	4,380	Relamp	No	3	LED - Fixtures: Downlight Solid State Retrofit	Day light Dimming	9	4,380	0.06	468	0.0	\$76.21	\$160.95	\$0.00	2.11
Exterior Wall Pack	2	Halogen Incandescent: Outdoor Wall-Mounted Area Fixture	Day light Dimming	150	4,380	Relamp	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Day light Dimming	55	4,380	0.12	957	0.0	\$155.70	\$107.30	\$0.00	0.69
Exterior Wall Pack	6	High-Pressure Sodium: (1) 400W Lamp	Day light Dimming	465	4,380	Fixture Replacement	No	6	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Day light Dimming	145	4,380	1.26	9,671	0.0	\$1,573.43	\$2,344.06	\$600.00	1.11
Garage	1	Compact Fluorescent: Screen in lamp	Wall Switch	32	2,340	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	20	2,340	0.01	32	0.0	\$5.25	\$53.75	\$5.00	9.28

Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis						
Location	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Garage	1	Incandescent: Screen in lamp	Wall Switch	100	2,340	Relamp	No	1	LED Screw-In Lamps: Screw in Lamp	Wall Switch	15	2,340	0.06	229	0.0	\$37.21	\$53.75	\$5.00	1.31
Exterior Pole Lighting	6	Metal Halide: (1) 400W Lamp	Daylight Dimming	458	4,380	Fixture Replacement	No	6	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Daylight Dimming	145	4,380	1.23	9,459	0.0	\$1,539.01	\$11,717.96	\$600.00	7.22
Exterior Wall Pack	3	High-Pressure Sodium: (1) 200W Lamp	Daylight Dimming	250	4,380	Fixture Replacement	No	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	125	4,380	0.25	1,889	0.0	\$307.31	\$1,172.03	\$300.00	2.84
Exterior Wall Pack	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	9	4,380	None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	9	4,380	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Boilers	2	Combustion Air Fan	3.0	82.5%	No	1,105	No	82.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Boilers	2	Other	2.0	80.0%	No	1,105	No	80.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Boilers	2	Other	1.5	80.0%	No	1,105	No	80.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Boilers	2	Heating Hot Water Pump	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Boilers	1	Exhaust Fan	2.0	82.0%	No	1,105	No	82.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Air Compressor	1	Air Compressor	1.5	80.0%	No	1,105	No	80.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Condensate System	2	Other	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	Kitchen	2	Exhaust Fan	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	Kitchen	1	Other	1.5	82.0%	No	1,105	No	82.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Gymnasium	Gymnasium	2	Supply Fan	2.0	82.0%	No	1,105	No	82.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Gymnasium	Gymnasium	2	Exhaust Fan	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
School	School	49	Supply Fan	0.2	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Auditorium	Auditorium	2	Heating Hot Water Pump	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Art Room	Art Room	1	Exhaust Fan	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	Kitchen	1	Kitchen Hood Exhaust Fan	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Storage Room	1	Exhaust Fan	0.3	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Locker Room	1	Exhaust Fan	0.3	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Maintenance Room	Condensate System	1	Other	0.8	78.0%	No	1,105	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions										Energy Impact & Financial Analysis						
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Principal Office	Principal Office	1	Window AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Teacher Lunch	Teacher Lunch	2	Window AC	1.25		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Janitorial	Janitorial	1	Window AC	1.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Janitorial	Janitorial	1	Window AC	0.42		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 100A	Room 100A	1	Window AC	0.42		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 101	Room 101	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 102	Room 102	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 100	Room 100	1	Window AC	1.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 102	Room 102	1	Window AC	1.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
CST Room	CST Room	1	Window AC	0.42		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
CST Room	CST Room	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Library	Library	2	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Music Room	Music Room	2	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 202	Room 202	2	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 203	Room 203	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 204	Room 204	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 205	Room 205	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 206	Room 206	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 201	Room 201	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 208	Room 208	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

		Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room 209	Room 209	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 210	Room 210	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Teacher Lunch 2nd Floor	Teacher Lunch 2nd Floor	1	Split-System AC	0.75		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 212	Room 212	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Art Room	Art Room	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 213	Room 213	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 215	Room 215	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Old CST Office	Old CST Office	1	Split-System AC	4.00		Yes	1	Split-System AC	4.00		14.00		No	1.49	1,997	0.0	\$324.84	\$5,984.88	\$368.00	17.29
Room 216	Room 216	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 217	Room 217	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 219	Room 219	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Facility Manager Office	Facility Manager Office	1	Window AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 207	Room 207	1	Split-System AC	3.00		Yes	1	Split-System AC	3.00		14.00		No	1.11	1,497	0.0	\$243.63	\$4,488.66	\$276.00	17.29
Room 104	Room 104	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 106	Room 106	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 107	Room 107	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
PTA Room	PTA Room	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 108	Room 108	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 111	Room 111	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 112	Room 112	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

		Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room 113	Room 113	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 116	Room 116	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 118	Room 118	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Nurse Office	Nurse Office	1	Window AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room114	Room114	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room115	Room115	1	Window AC	1.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room110	Room110	1	Window AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Server Room	Server Room	1	Window AC	1.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

		Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Boiler Room	School Building	1	Forced Draft Steam Boiler	2,779.00	Yes	1	Forced Draft Steam Boiler	2,779.00	81.00%	Et	0.00	0	37.9	\$318.76	\$51,651.39	\$2,779.00	153.32	
Boiler Room	School Building	1	Forced Draft Steam Boiler	4,320.00	Yes	1	Forced Draft Steam Boiler	4,320.00	81.00%	Et	0.00	0	292.9	\$2,462.45	\$74,024.59	\$0.00	30.06	

DHW Inventory & Recommendations

		Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Art Room & Restrooms	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
School	School	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
School	Boys & Girls Restroom	1	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
School	Cafeteria	2	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis						
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
School	25	Faucet Aerator (Lavatory)	2.20	1.00	0.00	9,018	0.0	\$1,467.12	\$179.25	\$0.00	0.12
School	10	Faucet Aerator (Lavatory)	2.20	1.00	0.00	0	14.6	\$122.92	\$71.70	\$0.00	0.58

Walk-In Cooler/Freezer Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions			Energy Impact & Financial Analysis						
	Cooler/Freezer Quantity	Case Type/Temperature	Install EC Evaporator Fan Motors?	Install Electric Defrost Control?	Install Evaporator Fan Control?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Medium Temp Freezer (0F to 30F)	No	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis						
	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Stand-Up Refrigerator, Solid Door (31 - 50 cu. ft.)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	1	Refrigerator Chest	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Cooking Equipment Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Equipment Type	High Efficiency Equipment?	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Gas Fryer	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	1	Electric Griddle (4 Feet Width)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	1	Gas Convection Oven (Half Size)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	1	Insulated Food Holding Cabinet (Full Size)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Dishwasher Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Dishwasher Type	Water Heater Fuel Type	Booster Heater Fuel Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Payback w/ Incentives in Years
Dishwasher Room	1	Single Tank Conveyor (High Temp)	Electric	N/A	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
School	14	Refrigerators	115.0	Yes
School	12	Printers	145.0	Yes
School	8	Microwave	1,000.0	No
School	5	Copy Machine	700.0	Yes
School	5	Water Cooler	272.0	Yes
School	109	Desktop with LCD Monitore	191.0	Yes
School	4	Coffee Makers	850.0	No
School	4	Toaster	900.0	No
School	1	Electric Laminator	800.0	No
Diswasher	1	Electric Hot Water Booster	36,000.0	No
Kitchen	1	Combo Washer-Dryer	2,500.0	No
Kitchen	1	Electric Steam Table	1,000.0	No
Closet	1	Electric Unit Heater	5,000.0	No
School	4	Electric Baseboard	780.0	No

Vending Machine Inventory & Recommendations

Existing Conditions			Proposed Conditions	Energy Impact & Financial Analysis						
Location	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Teacher Lunch	1	Refrigerated	Yes	0.00	1,612	0.0	\$262.24	\$230.00	\$0.00	0.88
Teacher Lunch	1	Non-Refrigerated	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Appendix B: ENERGY STAR® Statement of Energy Performance

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

79

ENERGY STAR®
Score¹

Broad Street Elementary School

Primary Property Type: K-12 School
Gross Floor Area (ft²): 86,400
Built: 1926

For Year Ending: December 31, 2016
Date Generated: January 15, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address Broad Street Elementary School 255 West Broad Street Gibbstown, New Jersey 08027	Property Owner Greenwich Township Board of Education (Gloucester County) 415 Swedesboro Road Gibbstown, NJ 08027 856-224-4920	Primary Contact Scott Campbell 415 Swedesboro Road Gibbstown, NJ 08027 856-224-4920 Ext. 2120 scampbell@ns.greenwich.k12.nj.us
---	---	--

Property ID: 6196288

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
71.9 kBtu/ft ²	Electric - Grid (kBtu) 1,440,333 (23%) Natural Gas (kBtu) 4,775,382 (77%)	National Median Site EUI (kBtu/ft ²) 96 National Median Source EUI (kBtu/ft ²) 147.4 % Diff from National Median Source EUI -25%
Source EUI		Annual Emissions
110.4 kBtu/ft ²		Greenhouse Gas Emissions (Metric Tons CO ₂ e/year) 413

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

() - _____



Professional Engineer Stamp
(if applicable)