



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Board of Education Administrative Offices

151 Donnor Blvd

Jackson, NJ 08527

Jackson Township BOE

June 22, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	3
2	Facility Information and Existing Conditions	5
2.1	Project Contacts	5
2.2	General Site Information.....	5
2.3	Building Occupancy	5
2.4	Building Envelope	5
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems	6
	Lighting System	6
	Direct Expansion Air Conditioning System (DX) and Electric Heating	6
	Domestic Hot Water Heating System.....	6
	Building Plug Load	6
2.7	Water-Using Systems	6
3	Site Energy Use and Costs.....	7
3.1	Total Cost of Energy	7
3.2	Electricity Usage	8
3.3	Benchmarking.....	9
3.4	Energy End-Use Breakdown	10
4	Energy Conservation Measures	11
4.1	Recommended ECMs	11
4.1.1	Lighting Upgrades.....	12
	ECM 1: Install LED Fixtures	12
	ECM 2: Retrofit Fixtures with LED Lamps.....	13
4.1.2	Lighting Control Measures	14
	ECM 3: Install Occupancy Sensor Lighting Controls	14
4.1.3	HVAC System Upgrades.....	15
	ECM 4: Install Dual-Enthalpy Economizers.....	15
4.1.4	Plug Load Equipment Control - Vending Machines.....	16
	ECM 5: Vending Machine Control	16
4.2	ECMs Evaluated But Not Recommended	17
	Install High/Low Lighting Controls	17
	Install High Efficiency Air Conditioning Units	18

5	Energy Efficient Practices	19
	Use Window Treatments/Coverings	19
	Practice Proper Use of Thermostat Schedules and Temperature Resets	19
	Clean and/or Replace HVAC Filters	19
	Perform Proper Water Heater Maintenance	19
	Plug Load Controls.....	20
	Water Conservation	20
6	On-Site Generation Measures	21
6.1	Photovoltaic.....	21
6.2	Combined Heat and Power	22
7	Demand Response	23
8	Project Funding / Incentives	24
8.1	SmartStart	25
8.2	Direct Install	26
8.3	SREC Registration Program.....	27
8.4	Energy Savings Improvement Program	28
9	Energy Purchasing and Procurement Strategies	29
9.1	Retail Electric Supply Options.....	29
9.2	Retail Natural Gas Supply Options	29

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 1

Figure 2 – Potential Post-Implementation Costs 1

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Photovoltaic Potential..... 3

Figure 5 – Project Contacts 5

Figure 6 - Building Schedule..... 5

Figure 7 - Utility Summary 7

Figure 8 - Energy Cost Breakdown 7

Figure 9 - Electric Usage & Demand..... 8

Figure 10 - Electric Usage & Demand..... 8

Figure 11 - Energy Use Intensity Comparison – Existing Conditions..... 9

Figure 12 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 9

Figure 13 - Energy Balance (% and kBtu/SF) 10

Figure 14 – Summary of Recommended ECMs..... 11

Figure 15 – Summary of Lighting Upgrade ECMs..... 12

Figure 16 – Summary of Lighting Control ECMs 14

Figure 17 - Summary of HVAC System Improvement ECMs 15

Figure 18 - Summary of HVAC System Improvement ECMs 16

Figure 19 – Summary of Measures Evaluated, But Not Recommended 17

Figure 20 - Photovoltaic Screening 21

Figure 21 - ECM Incentive Program Eligibility 24

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Board of Education Administrative Offices.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey’s Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey school boards in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Board of Education Administrative Offices is a 10,200 square foot facility comprised offices, restrooms, storage rooms and conference rooms. This is a one story facility. The payroll department works out of a trailer behind the main office building. The building is occupied from 8:00 AM to 4:00 PM all year.

The space heating in the building for the spaces in the perimeter is provided by electric baseboard heaters. The cooling in these areas are provided using window AC units. The inner rooms including the conference room are heated (electric heater) and cooled using rooftop units. Lighting at Board of Education Administrative Offices consists of linear T8 tubes and incandescent lamps.

A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated seven measures and recommends five measures which together represent an opportunity for Board of Education Administrative Offices to reduce annual energy costs by roughly \$4,952 and annual greenhouse gas emissions by 39,196 lbs. CO₂e. We estimate that if all measures were implemented as recommended, the project would pay for itself in roughly 12.2 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Board of Education Administrative Offices’ annual energy use by 19%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Board of Education Administrative Offices' existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			24,649	6.2	0.0	\$3,029.22	\$16,381.58	\$3,035.00	\$13,346.58	4.4	24,821
ECM 1	Install LED Fixtures	Yes	5,432	0.8	0.0	\$667.58	\$3,906.38	\$600.00	\$3,306.38	5.0	5,470
ECM 2	Retrofit Fixtures with LED Lamps	Yes	19,217	5.3	0.0	\$2,361.64	\$12,475.20	\$2,435.00	\$10,040.20	4.3	19,351
Lighting Control Measures			5,161	1.4	0.0	\$634.24	\$5,712.00	\$600.00	\$5,112.00	8.1	5,197
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	4,896	1.4	0.0	\$601.64	\$4,712.00	\$600.00	\$4,112.00	6.8	4,930
	Install High/Low Lighting Controls	No	265	0.1	0.0	\$32.60	\$1,000.00	\$0.00	\$1,000.00	30.7	267
Electric Unitary HVAC Measures			5,338	3.2	0.0	\$656.06	\$42,123.61	\$985.50	\$41,138.11	62.7	5,376
	Install High Efficiency Electric AC	No	5,338	3.2	0.0	\$656.06	\$42,123.61	\$985.50	\$41,138.11	62.7	5,376
HVAC System Improvements			2,164	0.5	0.0	\$265.93	\$750.00	\$250.00	\$500.00	1.9	2,179
ECM 4	Install Dual Enthalpy Outside Economizer Control	Yes	2,164	0.5	0.0	\$265.93	\$750.00	\$250.00	\$500.00	1.9	2,179
Plug Load Equipment Control - Vending Machine			1,612	0.0	0.0	\$198.09	\$230.00	\$0.00	\$230.00	1.2	1,623
ECM 5	Vending Machine Control	Yes	1,612	0.0	0.0	\$198.09	\$230.00	\$0.00	\$230.00	1.2	1,623
TOTALS			38,924	11.3	0.0	\$4,951.90	\$65,197.19	\$4,870.50	\$60,326.69	12.2	39,196
TOTAL OF ALL RECOMMENDED MEASURES			33,320	8	0	4,095	22,074	3,885	18,189	4.4	33,553
TOTAL OF ALL NON-RECOMMENDED MEASURES			5,604	3	0	689	43,124	986	42,138	61.2	5,643

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Electric Unitary HVAC measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air condition systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

HVAC System Improvements generally involve the installation of automated controls to reduce heating and cooling demand during periods of reduced demand. These measures could encompass changing temperature setpoints, using outside air for free cooling, or limiting excessive outside air during extreme outdoor air temperature conditions. These measures save energy by reducing the demand on HVAC systems and the amount of time systems operate.

Plug Load Equipment control measures generally involve installing automated devices that limit the power usage or operation of equipment that is plugged into an electric outlets when not in use.

Energy Efficient Practices

TRC also identified six low cost (or no cost) energy efficient practices. A facility’s energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Board of Education Administrative Offices include:

- Use Window Treatments/Coverings
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean and/or Replace HVAC Filters
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Board of Education Administrative Offices. Based on the configuration of the site and its loads there is a high potential for installing a photovoltaic (PV) array.

Figure 4 – Photovoltaic Potential

Potential	High	
System Potential	69	kW DC STC
Electric Generation	82,204	kWh/yr
Displaced Cost	\$7,150	/yr
Installed Cost	\$179,400	

For details on our evaluation and on-site generation potential, please refer to Section 6.

I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- SREC (Solar Renewable Energy Certificate) Registration Program (SRP)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.4 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is in Section 8 or: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 5 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Michelle Richardson	Business Administrator	mrichardson@jacksonsd.org	732-833-4600
John Blair	Energy Education Specialist	jblair@jacksonsd.org	732-833-4600 Ext:n:4380
TRC Energy Services			
Smruti Srinivasan	Auditor	ssrinivasan@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On December 11, 2017, TRC performed an energy audit at Board of Education Administrative Offices located in Jackson, New Jersey. TRC’s team met with John Blair to review the facility operations and help focus our investigation on specific energy-using systems.

Board of Education Administrative Offices is a one-story, 10,200 square foot facility comprised offices, restrooms, storage rooms and conference rooms. The payroll department works out of a trailer behind the main office building.

The building was constructed in 1979. The perimeter space heating is provided by electric baseboard heaters. Cooling is provided with window air conditioning (AC) units. The inner rooms including the conference room are electrically heated and cooled using rooftop units. Lighting at consists of linear T8 fixtures and incandescent lamps.

2.3 Building Occupancy

The typical schedule is presented in the table below. During a typical day, the facility is occupied by approximately 25 staff members

Figure 6 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Admin Building	Weekday	8AM - 4PM
Admin Building	Weekend	No Operation

2.4 Building Envelope

The building is constructed of concrete block and structural steel with a concrete masonry facade. The buildings have flat roof covered with rubber membrane. The buildings have single pane windows with blinds which are in good condition and show little sign of excessive infiltration. The exterior doors are constructed of aluminum and in good condition.

2.5 On-Site Generation

Board of Education Administrative Offices does not have any on-site electric generation systems currently installed in the building.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Lighting is provided mostly by 32-Watt linear fluorescent T8 lamps with electronic ballasts as well as some incandescent lamps (40-Watt and 60-Watt). Most of the fixtures are 2-lamp or 4-lamp, 4-foot long troffers with diffusers. Lighting control in most spaces is provided by a combination of wall switches and occupancy sensors. The occupancy sensors are either wall or ceiling mounted depending on the space layout.

The building's exterior lighting consists of high pressure sodium wall packs with 150-Watt bulbs. Parking lot has pole fixtures with high pressure sodium 400-watt bulbs. The exterior lighting is controlled using photocells and timers.

Direct Expansion Air Conditioning System (DX) and Electric Heating

Space cooling and electric heating in the building is provided differently to the two different zones of the building (core of the building and perimeter office spaces). The core of the building is conditioned using a 6-ton (Trane) and a 7.5-ton (York) packaged rooftop units (DX cooling and electric heating). The perimeter offices are cooled using 1-ton window AC units and heated using 2kW electric baseboard heaters. The trailer has one packaged unit doing both cooling (3 tons) and electric heating. The space temperatures are controlled using individual thermostats in the respective zones.

Domestic Hot Water Heating System

The domestic hot water heating system for the facility consists of one 40-gallon AO Smith electric water heater with an input capacity 4.5 kW. This water heater is 18 years old.

Building Plug Load

There are 29 computer work stations throughout the facility. Other office plug loads include printers, paper shredders, televisions and projectors. The kitchenette plug loads include refrigerators, microwaves, coffee machine, toaster oven, cooking range and water dispenser.

The facility has one refrigerated beverage vending machine and one non-refrigerated vending machine. No controls have been installed on these.

2.7 Water-Using Systems

The restrooms have faucets that are rated for 2.2 gallons per minute (gpm) or lower, the toilets are rated at 1.6 gallons per flush (gpf) and the urinals are rated at 1 gpf.

3 SITE ENERGY USE AND COSTS

Utility data for electricity was analyzed to identify opportunities for savings. In addition, data for electricity was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking narrative within Section 3.3 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 7 - Utility Summary

Utility Summary for Board of Education Administrative Offices		
Fuel	Usage	Cost
Electricity	200,720 kWh	\$24,668
Total		\$24,668

The current annual energy cost for this facility is \$24,668 as shown in the chart below.

Figure 8 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by JCP&L. The average electric cost over the past 12 months was \$0.123/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The third party electric provider at the facility is Constellation Energy. The monthly electricity consumption and peak demand are shown in the chart below. The annual usage profile is normal for an all-electric commercial building.

Figure 9 - Electric Usage & Demand




Figure 10 - Electric Usage & Demand

Electric Billing Data for Board of Education Administrative Offices					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
1/31/16	30	17,600	81		\$2,186
2/29/16	29	27,040	95		\$3,189
3/31/16	31	23,520	92		\$2,831
4/30/16	30	24,800	82		\$2,903
5/31/16	31	6,800	90		\$1,176
6/30/16	30	13,200	71		\$1,725
7/31/16	31	11,040	43		\$1,396
8/31/16	31	11,360	44		\$1,439
9/30/16	30	11,040	41		\$1,390
10/31/16	31	9,600	43		\$1,265
11/30/16	30	11,600	63		\$1,584
12/31/16	31	33,120	81		\$3,585
Totals	365	200,720	94.6	\$0	\$24,668
Annual	365	200,720	94.6	\$0	\$24,668

3.3 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 11 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Board of Education Administrative Offices	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	210.8	148.1
Site Energy Use Intensity (kBtu/ft ²)	67.1	67.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 12 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Board of Education Administrative Offices	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	175.8	148.1
Site Energy Use Intensity (kBtu/ft ²)	56.0	67.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. This facility has a current score of 20.

A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.4 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 13 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Board of Education Administrative Offices regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 14 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		24,649	6.2	0.0	\$3,029.22	\$16,381.58	\$3,035.00	\$13,346.58	4.4	24,821
ECM 1	Install LED Fixtures	5,432	0.8	0.0	\$667.58	\$3,906.38	\$600.00	\$3,306.38	5.0	5,470
ECM 2	Retrofit Fixtures with LED Lamps	19,217	5.3	0.0	\$2,361.64	\$12,475.20	\$2,435.00	\$10,040.20	4.3	19,351
Lighting Control Measures		4,896	1.4	0.0	\$601.64	\$4,712.00	\$600.00	\$4,112.00	6.8	4,930
ECM 3	Install Occupancy Sensor Lighting Controls	4,896	1.4	0.0	\$601.64	\$4,712.00	\$600.00	\$4,112.00	6.8	4,930
HVAC System Improvements		2,164	0.5	0.0	\$265.93	\$750.00	\$250.00	\$500.00	1.9	2,179
ECM 4	Install Dual Enthalpy Outside Economizer Control	2,164	0.5	0.0	\$265.93	\$750.00	\$250.00	\$500.00	1.9	2,179
Plug Load Equipment Control - Vending Machine		1,612	0.0	0.0	\$198.09	\$230.00	\$0.00	\$230.00	1.2	1,623
ECM 5	Vending Machine Control	1,612	0.0	0.0	\$198.09	\$230.00	\$0.00	\$230.00	1.2	1,623
TOTALS		33,320	8.0	0.0	\$4,094.88	\$22,073.58	\$3,885.00	\$18,188.58	4.4	33,553

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 15 below.

Figure 15 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		24,649	6.2	0.0	\$3,029.22	\$16,381.58	\$3,035.00	\$13,346.58	4.4	24,821
ECM 1	Install LED Fixtures	5,432	0.8	0.0	\$667.58	\$3,906.38	\$600.00	\$3,306.38	5.0	5,470
ECM 2	Retrofit Fixtures with LED Lamps	19,217	5.3	0.0	\$2,361.64	\$12,475.20	\$2,435.00	\$10,040.20	4.3	19,351

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	5,432	0.8	0.0	\$667.58	\$3,906.38	\$600.00	\$3,306.38	5.0	5,470

Measure Description

We recommend replacing existing fixtures containing HID lamps with new high-performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have life cycles that are much longer than most lighting systems

ECM 2: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	19,217	5.3	0.0	\$2,361.64	\$12,475.20	\$2,435.00	\$10,040.20	4.3	19,351
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing linear T8 tubes and incandescent lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy because LEDs use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		4,896	1.4	0.0	\$601.64	\$4,712.00	\$600.00	\$4,112.00	6.8	4,930
ECM 3	Install Occupancy Sensor Lighting Controls	4,896	1.4	0.0	\$601.64	\$4,712.00	\$600.00	\$4,112.00	6.8	4,930

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 3: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
4,896	1.4	0.0	\$601.64	\$4,712.00	\$600.00	\$4,112.00	6.8	4,930

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in restrooms, storage rooms and conference rooms. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.1.3 HVAC System Upgrades

Our recommendations for HVAC system improvement are summarized in Figure 17 below.

Figure 17 - Summary of HVAC System Improvement ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
HVAC System Improvements	2,164	0.5	0.0	\$265.93	\$750.00	\$250.00	\$500.00	1.9	2,179
ECM 4 Install Dual Enthalpy Outside Economizer Control	2,164	0.5	0.0	\$265.93	\$750.00	\$250.00	\$500.00	1.9	2,179

ECM 4: Install Dual-Enthalpy Economizers

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
2,164	0.5	0.0	\$265.93	\$750.00	\$250.00	\$500.00	1.9	2,179

Measure Description

Dual enthalpy economizers are used to control a ventilation system’s outside air intake in order to reduce a facility’s total cooling load. A dual-enthalpy economizer monitors the air temperature and humidity of both the outside and return air. The control supplies the lowest energy (temperature and humidity) air to the air handling system. When outside air conditions allow, outside air can be used for cooling instead of running the air handling system’s compressor. This reduces the demand on the cooling system, lowering its usage hours and saving energy. We recommend installing dual enthalpy economizers in the 7.5 ton York packaged unit on the roof. Savings result from using outside air instead of mechanical cooling when outside air conditions permit.

4.1.4 Plug Load Equipment Control - Vending Machines

Our recommendations for plug load equipment control measures are summarized in Figure 18 below.

Figure 18 - Summary of HVAC System Improvement ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Plug Load Equipment Control - Vending Machine	1,612	0.0	0.0	0.0	0.0	0.0	\$198.09	\$230.00	\$0.00	\$230.00	1.2	1,623
ECM 5 Vending Machine Control	1,612	0.0	0.0	0.0	0.0	0.0	\$198.09	\$230.00	\$0.00	\$230.00	1.2	1,623

ECM 5: Vending Machine Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,612	0.0	0.0	\$198.09	\$230.00	\$0.00	\$230.00	1.2	1,623

Measure Description

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor controls to reduce the energy use. These controls power down vending machines when the vending machine area has been vacant for some time, then power up at regular intervals, as needed, to turn machine lights on or keep the product cool. Energy savings are a dependent on vending machine and activity level in the area surrounding the machines.

4.2 ECMs Evaluated But Not Recommended

The measures below have been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in each measure description narrative.

Figure 19 – Summary of Measures Evaluated, But Not Recommended

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures	265	0.1	0.0	\$32.60	\$1,000.00	\$0.00	\$1,000.00	30.7	267
Install High/Low Lighting Controls	265	0.1	0.0	\$32.60	\$1,000.00	\$0.00	\$1,000.00	30.7	267
Electric Unitary HVAC Measures	5,338	3.2	0.0	\$656.06	\$42,123.61	\$985.50	\$41,138.11	62.7	5,376
Install High Efficiency Electric AC	5,338	3.2	0.0	\$656.06	\$42,123.61	\$985.50	\$41,138.11	62.7	5,376
TOTALS	5,604	3.2	0.0	\$688.67	\$43,123.61	\$985.50	\$42,138.11	61.2	5,643

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Install High/Low Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
265	0.1	0.0	\$32.60	\$1,000.00	\$0.00	\$1,000.00	30.7	267

Measure Description

We evaluated installing occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons. Typical areas for such lighting control are stairwells, interior corridors, parking lots, and parking garages.

Lighting fixtures with these controls operate at default low levels when the area is not occupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. The lighting systems are switched to full lighting levels whenever an occupant is detected. Fixtures are automatically switched back to low level after an area has been vacant for a preset period of time. Energy savings results from only providing full lighting levels when it is required.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage needs to be provided to ensure that lights turn on in each area as an occupant approaches.

Reasons for not Recommending

This measure is not recommended as the payback period is much higher than the cost savings due to the measure.

Install High Efficiency Air Conditioning Units

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
5,338	3.2	0.0	\$656.06	\$42,123.61	\$985.50	\$41,138.11	62.7	5,376

Measure Description

We evaluated replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Reasons for not Recommending

This measure evaluates replacing the (1-ton) window AC units, (6-ton) split AC unit and (7.5-ton) packaged AC unit. Although the units are old enough to be replaced, the payback period on replacing these units are more than the useful life of the equipment. When the AC units are due for replacement, we suggest that these be replaced with high efficiency units.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Use Window Treatments/Coverings

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gpf and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a High potential for installing a PV array.

The amount of free area, ease of installation (location), and the lack of shading elements contribute to the high potential for PV at the site. A PV array located on the roof of the main building/ground next to the building/over the main parking lot may be feasible. If Board of Education Administrative Offices is interested in pursuing the installation of PV, we recommended a full feasibility study be conducted.

Figure 20 - Photovoltaic Screening



Potential	High	
System Potential	69	kW DC STC
Electric Generation	82,204	kWh/yr
Displaced Cost	\$7,150	/yr
Installed Cost	\$179,400	

Solar projects must register their projects in the SREC (Solar Renewable Energy Certificate) Registration Program (SRP) prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey’s solar marketplace provides market participants with information about developed new solar projects and insight into future SREC pricing.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.

CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility’s ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a Low potential for installing a cost-effective CHP system. Lack of gas service is the most significant factor contributing to the low potential of the CHP at the site.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/.

7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion, this building is not a good candidate for demand response program.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 21 for a list of the eligible programs identified for each recommended ECM.

Figure 21 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	Direct Install
ECM 1	Install LED Fixtures	x	x
ECM 2	Retrofit Fixtures with LED Lamps	x	x
ECM 3	Install Occupancy Sensor Lighting Controls	x	x
ECM 4	Install Dual Enthalpy Outside Economizer Control	x	x
ECM 5	Vending Machine Control	x	x

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for any recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

How to Participate

To participate in the Direct Install program you will need to contact the participating contractor who the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the DI website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since Direct Install offers a free assessment of eligible measures, Direct Install is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 SREC Registration Program

The SREC (Solar Renewable Energy Certificate) Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SRP prior to the start of construction in order to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number which enables it to generate New Jersey SRECs. SREC's are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SREC's to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar RPS. One way they can meet the RPS requirements is by purchasing SRECs. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period can and will fluctuate depending on supply and demand.

Information about the SRP can be found at: www.njcleanenergy.com/srec.

8.4 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Back Corridor	7	Linear Fluorescent - T8: 2 T8 (17W) - 2L	Wall Switch	33	2,470	Relamp	Yes	7	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	1,729	0.12	427	0.0	\$52.46	\$537.40	\$70.00	8.91
Faculty Restroom - Women	1	Linear Fluorescent - T8: 2 T8 (17W) - 1L	Wall Switch	22	2,470	Relamp	Yes	1	LED - Linear Tubes: (1) 2' Lamp	Occupancy Sensor	9	1,729	0.01	46	0.0	\$5.70	\$147.90	\$5.00	25.07
Faculty Restroom - Men	1	Linear Fluorescent - T8: 2 T8 (17W) - 1L	Wall Switch	22	2,470	Relamp	Yes	1	LED - Linear Tubes: (1) 2' Lamp	Occupancy Sensor	9	1,729	0.01	46	0.0	\$5.70	\$147.90	\$5.00	25.07
Closet	1	Incandescent: 1 Lamp	Wall Switch	40	2,470	Relamp	No	1	LED Screw-In Lamps: 1 Lamp	Wall Switch	6	2,470	0.03	98	0.0	\$12.08	\$53.75	\$5.00	4.04
Kitchenette	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	114	1,729	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,210	0.12	297	0.0	\$36.50	\$306.27	\$60.00	6.75
Kitchenette	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	1,729	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,729	0.03	67	0.0	\$8.20	\$58.50	\$10.00	5.91
Kitchenette	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	1,729	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,729	0.03	67	0.0	\$8.20	\$58.50	\$10.00	5.91
Supply Closet	1	Incandescent: 1 Lamp	Wall Switch	60	2,470	Relamp	No	1	LED Screw-In Lamps: 1 Lamp	Wall Switch	9	2,470	0.04	147	0.0	\$18.11	\$53.75	\$5.00	2.69
Assistant Business Administrator	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.18	636	0.0	\$78.21	\$401.40	\$80.00	4.11
Assistant Business Administrator	2	Linear Fluorescent - T8: 2 T8 (17W) - 2L	Wall Switch	33	2,470	Relamp	Yes	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,729	0.03	122	0.0	\$14.99	\$212.40	\$40.00	11.50
Superintendent	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.35	1,273	0.0	\$156.41	\$686.80	\$140.00	3.50
Superintendent Secretary	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.18	636	0.0	\$78.21	\$401.40	\$80.00	4.11
Purchasing department	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.35	1,273	0.0	\$156.41	\$686.80	\$140.00	3.50
Office suite	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.47	1,697	0.0	\$208.55	\$877.07	\$180.00	3.34
Board secretary	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.35	1,273	0.0	\$156.41	\$686.80	\$140.00	3.50
Secretary BA/BS	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.23	848	0.0	\$104.27	\$496.53	\$100.00	3.80
Accounting department	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.35	1,273	0.0	\$156.41	\$686.80	\$140.00	3.50
Assistant Superintendent secretary	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.23	848	0.0	\$104.27	\$496.53	\$100.00	3.80
Assistant Superintendent secretary	3	Linear Fluorescent - T8: 2 T8 (17W) - 2L	Wall Switch	33	2,470	Relamp	Yes	3	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,729	0.05	183	0.0	\$22.48	\$260.60	\$50.00	9.37
Assistant superintendent	7	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	7	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.41	1,485	0.0	\$182.48	\$781.93	\$160.00	3.41
HR Manager	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,470	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,729	0.15	542	0.0	\$66.64	\$495.60	\$35.00	6.91
Front entrance and hallways	11	Linear Fluorescent - T8: 2 T8 (17W) - 2L	Wall Switch	33	2,470	Relamp	Yes	11	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	1,729	0.18	671	0.0	\$82.43	\$1,330.20	\$110.00	14.80
Front entrance and hallways	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,470	0.09	324	0.0	\$39.78	\$190.27	\$40.00	3.78
Front entrance and hallways	3	Halogen Incandescent: 1 Lamp	Wall Switch	90	2,470	Relamp	No	3	LED Screw-In Lamps: 1 Lamp	Wall Switch	14	2,470	0.18	663	0.0	\$81.51	\$293.56	\$15.00	3.42
Vending machine	2	Linear Fluorescent - T8: 2 T8 (17W) - 2L	Wall Switch	33	2,470	Relamp	No	2	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,470	0.03	92	0.0	\$11.36	\$96.40	\$20.00	6.72

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Communication specialist	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.23	848	0.0	\$104.27	\$496.53	\$100.00	3.80
Registration	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.23	848	0.0	\$104.27	\$496.53	\$100.00	3.80
Women's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,470	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,729	0.03	121	0.0	\$14.81	\$174.50	\$10.00	11.11
Men's restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,470	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,729	0.03	121	0.0	\$14.81	\$174.50	\$10.00	11.11
Assistant superintendent	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.23	848	0.0	\$104.27	\$496.53	\$100.00	3.80
Assistant superintendent	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.18	636	0.0	\$78.21	\$285.40	\$80.00	2.63
Assistant superintendent	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.18	636	0.0	\$78.21	\$285.40	\$80.00	2.63
Conference room	22	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,470	Relamp	Yes	22	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,729	0.37	1,341	0.0	\$164.86	\$1,870.40	\$325.00	9.37
9 closets in conference room	9	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,470	Relamp	No	9	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,470	0.11	416	0.0	\$51.14	\$433.80	\$90.00	6.72
Storage	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,470	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,729	0.20	723	0.0	\$88.86	\$467.00	\$60.00	4.58
Storage	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,729	0.18	636	0.0	\$78.21	\$401.40	\$60.00	4.37
Between entrance doors	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,470	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,470	0.04	162	0.0	\$19.89	\$95.13	\$20.00	3.78
Janitor closet	1	Incandescent 1 Lamp	Wall Switch	40	2,470	Relamp	No	1	LED Screw-In Lamps: 1 Lamp	Wall Switch	6	2,470	0.03	98	0.0	\$12.08	\$53.75	\$5.00	4.04
Trailer BOE Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,470	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,729	0.20	723	0.0	\$88.86	\$891.00	\$130.00	8.56
Payroll Trailer	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,470	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,729	0.30	1,085	0.0	\$133.29	\$1,066.50	\$160.00	6.80
Restroom trailer	1	Incandescent 1 Lamp	Wall Switch	40	2,470	Relamp	No	1	LED Screw-In Lamps: 1 Lamp	Wall Switch	6	2,470	0.03	98	0.0	\$12.08	\$53.75	\$5.00	4.04
Wall packs	5	High-Pressure Sodium: (1) 150W Lamp	Wall Switch	188	4,380	Fixture Replacement	No	5	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	45	4,380	0.57	3,664	0.0	\$450.30	\$1,953.39	\$500.00	3.23
Pole with 1 fixture	1	High-Pressure Sodium: (1) 400W Lamp	Wall Switch	465	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Wall Switch	120	4,380	0.27	1,768	0.0	\$217.28	\$1,952.99	\$100.00	8.53
All building	8	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	8	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Office Suite	1	Supply Fan	2.0	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Conference room	1	Supply Fan	2.0	86.5%	No	2,745	No	86.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions									Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchenette	Kitchenette	1	Window AC	1.00		Yes	1	Window AC	2.00		12.00		No	-0.45	-754	0.0	-\$92.66	\$2,177.52	\$0.00	-23.50
Assistant BA	Assistant BA	1	Window AC	1.00		Yes	1	Window AC	2.00		12.00		No	-0.45	-754	0.0	-\$92.66	\$2,177.52	\$0.00	-23.50
Superintendent office	Superintendent office	2	Window AC	1.00		Yes	2	Window AC	2.00		12.00		No	-0.89	-1,508	0.0	-\$185.33	\$4,355.04	\$0.00	-23.50
Purchasing department	Purchasing Department	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.22	377	0.0	\$46.33	\$1,088.76	\$0.00	23.50
Board Secretary	Board Secretary	2	Window AC	1.00		Yes	2	Window AC	1.00		12.00		No	0.45	754	0.0	\$92.66	\$2,177.52	\$0.00	23.50
Assistant BA/BS	Assistant BA/BS	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.22	377	0.0	\$46.33	\$1,088.76	\$0.00	23.50
Accounting Department	Accounting Department	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.22	377	0.0	\$46.33	\$1,088.76	\$0.00	23.50
Assistant Superintendent	Assistant Superintendent	2	Window AC	1.00		Yes	2	Window AC	1.00		12.00		No	0.45	754	0.0	\$92.66	\$2,177.52	\$0.00	23.50
HR Resources	HR Resources	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.22	377	0.0	\$46.33	\$1,088.76	\$0.00	23.50
Communication Specialist	Communication Specialist	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.22	377	0.0	\$46.33	\$1,088.76	\$0.00	23.50
Assistant Superintendent	Assistant Superintendent	3	Window AC	1.00		Yes	3	Window AC	1.00		12.00		No	0.67	1,131	0.0	\$138.99	\$3,266.28	\$0.00	23.50
Roof	Conference room/storage	1	Split-System AC	6.00		Yes	1	Split-System AC	6.00		11.50		No	1.17	1,967	0.0	\$241.73	\$6,982.62	\$438.00	27.07
Roof	Office Suite	1	Packaged AC	7.50		Yes	1	Packaged AC	7.50		11.50		Yes	1.59	4,027	0.0	\$494.94	\$14,115.79	\$797.50	26.91
Roof	Conference room/storage	1	Electric Resistance Heat		51.82	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Office Suite	1	Electric Resistance Heat		92.13	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Trailer	Payroll trailer	1	Packaged AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Trailer	BOE Office trailer	1	Packaged AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Trailer	Payroll trailer	1	Electric Resistance Heat		17.06	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Trailer	BOE Office trailer	1	Electric Resistance Heat		17.06	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Perimeter offices	Perimeter offices	24	Electric Resistance Heat		10.24	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mech room	All building	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$168.35	\$0.00	\$0.00	0.00


Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
BOE office	29	Computer	150.0	Yes
BOE office	15	Printer - Small	20.0	Yes
BOE office	7	Printer - Medium	60.0	Yes
BOE office	6	Printer - Large	200.0	Yes
BOE office	4	Paper shredder	150.0	Yes
BOE office	1	Projector	200.0	Yes
BOE office	5	Microwave	1,000.0	No
BOE office	4	Refrigerator - Small	20.0	No
BOE office	2	Refrigerator - Medium	60.0	No
BOE office	1	Refrigerator - Large	218.0	Yes
BOE office	4	Coffee Machine	400.0	Yes
BOE office	1	Toaster Oven	1,200.0	Yes
BOE office	2	Television - LED	100.0	Yes
BOE office	3	Hot and Cold water dispenser	500.0	Yes
BOE office	1	Electric stove	1,500.0	No

Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchenette	1	Refrigerated	Yes	0.00	1,612	0.0	\$198.09	\$230.00	\$0.00	1.16

Appendix B: ENERGY STAR® Statement of Energy Performance



ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

20

ENERGY STAR®
Score¹

Jackson Township BOE Administration Office

Primary Property Type: Office
Gross Floor Area (ft²): 10,200
Built: 1979

For Year Ending: December 31, 2016
Date Generated: March 28, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Jackson Township BOE Administration Office 151 Don Connor Boulevard Jackson, New Jersey 08527	Property Owner Jackson Township BOE 151 Don Connor Boulevard Jackson, NJ 08527 (732) 833-4600	Primary Contact Michelle Richardson 151 Don Connor Boulevard Jackson, NJ 08527 (732) 833-4600 sstewart@trcsolutions.com
Property ID: 3078783		

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI	Annual Energy by Fuel	National Median Comparison	
73.8 kBtu/ft ²	Electric - Grid (kBtu) 752,438 (100%)	National Median Site EUI (kBtu/ft ²)	53.6
		National Median Source EUI (kBtu/ft ²)	168.4
		% Diff from National Median Source EUI	38%
Source EUI		Annual Emissions	
231.6 kBtu/ft ²		Greenhouse Gas Emissions (Metric Tons CO ₂ e/year)	84

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

() - _____



Professional Engineer Stamp
(if applicable)