



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Life Hall and Speech Building

1 Normal Ave

Montclair, New Jersey 07043

Montclair State University

July 26, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	6
2.1	Project Contacts	6
2.2	General Site Information.....	6
2.3	Building Occupancy	7
2.4	Building Envelope	7
2.5	On-Site Generation.....	7
2.6	Energy-Using Systems	8
	Lighting System	8
	Chilled Water System	9
	Steam to Hot Water Heating System	9
	Air Distribution System	10
	Direct Expansion Air Conditioning System (DX)	10
	Building Energy Management System (BEMS).....	11
	Domestic Hot Water Heating System.....	11
	Building Plug Load	11
3	Site Energy Use and Costs.....	12
3.1	Total Cost of Energy	12
3.2	Electricity Usage	13
3.3	Steam Usage.....	14
3.4	Chilled Water Usage	15
3.5	Benchmarking.....	16
3.6	Energy End-Use Breakdown	17
4	Energy Conservation Measures	18
4.1	High Priority ECMs.....	18
4.1.1	Lighting Upgrades.....	19
	ECM 1: Install LED Fixtures	19
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers	20
	ECM 3: Retrofit Fixtures with LED Lamps	20
4.1.2	Lighting Control Measures	21
	ECM 4: Install Occupancy Sensor Lighting Controls	21
	ECM 5: Install High/Low Lighting Controls	22
4.1.3	Variable Frequency Drive Measures	23
	ECM 6: Install VFDs on Chilled Water Pumps.....	23

ECM 7: Install VFDs on Hot Water Pumps.....	24
4.1.4 HVAC System Upgrades.....	25
ECM 8: Implement Demand Control Ventilation (DCV)	25
ECM 9: Install Pipe Insulation.....	26
4.1.5 Plug Load Equipment Control - Vending Machines.....	27
ECM 10: Vending Machine Control	27
5 Energy Efficient Practices	28
Reduce Air Leakage	28
Close Doors and Windows	28
Perform Proper Lighting Maintenance.....	28
Develop a Lighting Maintenance Schedule	28
Ensure Lighting Controls Are Operating Properly	28
Turn Off Unneeded Motors.....	29
Reduce Motor Short Cycling.....	29
Perform Routine Motor Maintenance	29
Ensure Economizers are Functioning Properly.....	29
Clean Evaporator/Condenser Coils on AC Systems.....	29
Clean and/or Replace HVAC Filters	29
Check for and Seal Duct Leakage	30
Repair/Replace Steam Traps	30
Perform Maintenance on Compressed Air Systems	30
Plug Load Controls.....	30
Water Conservation	30
6 On-Site Generation Measures	31
6.1 Photovoltaic.....	31
6.2 Combined Heat and Power	32
7 Demand Response	33
8 Project Funding / Incentives	34
8.1 SmartStart	35
8.2 Pay for Performance - Existing Buildings.....	36
8.3 Energy Savings Improvement Program	37
9 Energy Purchasing and Procurement Strategies	38
9.1 Retail Electric Supply Options.....	38
9.2 Retail Natural Gas Supply Options	38

Appendix A: Equipment Inventory & Recommendations

Appendix B: Energy Star® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs.....	2
Figure 2 – Potential Post-Implementation Costs	2
Figure 3 – Summary of Energy Reduction Opportunities	2
Figure 4 – Project Contacts	6
Figure 5 - Building Schedule.....	7
Figure 6 – Building Façade	7
Figure 7 - Building Lighting Systems	8
Figure 8 – Chilled Water Pumps.....	9
Figure 9 – Hot Water Pumps.....	9
Figure 10 – Air Handling Units	10
Figure 11 – DX Air Conditioning Systems.....	10
Figure 12 – Building Energy Management System Controller	11
Figure 13 - Utility Summary	12
Figure 14 - Energy Cost Breakdown	12
Figure 15 - Electric Usage & Demand.....	13
Figure 16 - Electric Usage & Demand.....	13
Figure 17 - Steam Usage	14
Figure 18 – Steam Usage.....	14
Figure 19 – Chilled Water Usage.....	15
Figure 20 – Chilled Water Usage.....	15
Figure 21 - Energy Use Intensity Comparison – Existing Conditions.....	16
Figure 22 - Energy Use Intensity Comparison – Following Installation of Recommended Measures	16
Figure 23 - Energy Balance (% and kBtu/SF)	17
Figure 24 – Summary of High Priority ECMs	18
Figure 25 – Summary of Lighting Upgrade ECMs.....	19
Figure 26 – Summary of Lighting Control ECMs	21
Figure 27 – Summary of Variable Frequency Drive ECMs	23
Figure 28 - Summary of HVAC System Improvement ECMs	25
Figure 29 - Summary of Plug Load Equipment Control ECMs.....	27
Figure 30 - ECM Incentive Program Eligibility.....	34

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPUB) has sponsored this Local Government Energy Audit (LGEA) Report for Life Hall and Speech Building.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey higher education facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Life Hall and Speech Building is a building complex consisting of Life Hall, Memorial Auditorium, and Speech Building. The complex occupies an area of 88,691 square feet and was constructed in the year 1967. The complex is an educational/auditorium facility containing several types of spaces including offices, classrooms, auditorium, a theater area, lobbies, bathrooms, common areas, hallways, mechanical, and electrical rooms.

Lighting at Life Hall and Speech building primarily consists of a combination of 32-Watt T8 fluorescent fixtures, 40-Watt T12 fluorescent fixtures, and LED linear tubes. In addition to the linear fluorescent and LED lamps, the facility also has compact fluorescent (CFL), metal halide (MH), incandescent (INC), and LED exit sign fixtures. Exterior lighting is provided by MH fixtures. Lighting control is provided by switches and occupancy sensors at interior spaces and by a direct digital control system (DDC) for the exterior fixtures.

Cooling is provided by chilled water (CHW) provided by the District Energy Plant to Life Hall's mechanical room, where it is distributed by pumps to the building's air handling equipment. Steam is provided from the District Energy Plant to Life Hall's mechanical room, where it is converted to heating and domestic hot water by steam to water heat exchangers. Heating hot water is distributed to the building's AHUs.

Electricity, steam, and chilled water are supplied to the building by the campus central cogeneration plant. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated and recommends 10 measures that together represent an opportunity for Life Hall and Speech Building to reduce annual energy costs by \$44,779 and annual greenhouse gas emissions by 262,978 lbs CO₂e. We estimate that if all high priority measures are implemented as recommended, the project will pay for itself in 2.5 years. TRC has defined high priority measures as the evaluated measures that have a simple payback less than the typical equipment life of the proposed equipment. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Life Hall and Speech Building's annual energy use by 5%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Life Hall and Speech Building’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the evaluated energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	High Priority?	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Steam Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		170,773	0	21.3	0.0	0.0	\$28,689.87	\$66,592.13	\$3,810.00	\$62,782.13	2.2	171,967
ECM 1	Install LED Fixtures	11,501	0	1.8	0.0	0.0	\$1,932.08	\$11,245.50	\$75.00	\$11,170.50	5.8	11,581
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	88,284	0	10.8	0.0	0.0	\$14,831.76	\$29,990.00	\$2,830.00	\$27,160.00	1.8	88,902
ECM 3	Retrofit Fixtures with LED Lamps	70,988	0	8.7	0.0	0.0	\$11,926.03	\$25,356.63	\$905.00	\$24,451.63	2.1	71,485
Lighting Control Measures		30,579	0	3.7	0.0	0.0	\$5,137.31	\$13,080.00	\$1,330.00	\$11,750.00	2.3	30,793
ECM 4	Install Occupancy Sensor Lighting Controls	27,031	0	3.3	0.0	0.0	\$4,541.20	\$10,530.00	\$1,330.00	\$9,200.00	2.0	27,220
ECM 5	Install High/Low Lighting Controls	3,548	0	0.4	0.0	0.0	\$596.11	\$2,550.00	\$0.00	\$2,550.00	4.3	3,573
Variable Frequency Drive (VFD) Measures		43,973	0	4.4	0.0	0.0	\$7,387.39	\$20,317.00	\$0.00	\$20,317.00	2.8	44,280
ECM 6	Install VFDs on Chilled Water Pumps	28,092	0	3.1	0.0	0.0	\$4,719.38	\$13,765.30	\$0.00	\$13,765.30	2.9	28,288
ECM 7	Install VFDs on Hot Water Pumps	15,881	0	1.3	0.0	0.0	\$2,668.02	\$6,551.70	\$0.00	\$6,551.70	2.5	15,992
HVAC System Improvements		0	5,440	0.0	95.4	95.4	\$3,236.19	\$17,846.46	\$0.00	\$17,846.46	5.5	13,970
ECM 8	Implement Demand Control Ventilation	0	5,440	0.0	78.6	78.6	\$2,978.89	\$17,672.46	\$0.00	\$17,672.46	5.9	11,503
ECM 9	Install Pipe Insulation	0	0	0.0	16.9	16.9	\$257.29	\$174.00	\$0.00	\$174.00	0.7	2,467
Plug Load Equipment Control - Vending Machine		1,954	0	0.0	0.0	0.0	\$328.33	\$460.00	\$0.00	\$460.00	1.4	1,968
ECM 10	Vending Machine Control	1,954	0	0.0	0.0	0.0	\$328.33	\$460.00	\$0.00	\$460.00	1.4	1,968
TOTALS FOR HIGH PRIORITY MEASURES		247,279	5,440	29.4	95.4	95.4	\$44,779.10	\$118,295.59	\$5,140.00	\$113,155.59	2.5	262,978
TOTALS FOR ALL EVALUATED MEASURES		247,279	5,440	29.4	95.4	95.4	\$44,779.10	\$118,295.59	\$5,140.00	\$113,155.59	2.5	262,978

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Variable Frequency Drives (VFD) are motor control devices. These measures control the speed of a motor so that the motor spins at peak efficiency during partial load conditions. Sensors adapt the speed to flow,

temperature, or pressure settings which is much more efficient than using a valve or damper to control flow rates or running the motor at full speed when only partial power is needed. These measures save energy by controlling motor usage more efficiently.

HVAC System Improvements generally involve the installation of automated controls to reduce heating and cooling demand during periods of reduced demand. These measures could encompass changing temperature setpoints, using outside air for free cooling, or limiting excessive outside air during extreme outdoor air temperature conditions. These measures save energy by reducing the demand on HVAC systems and the amount of time systems operate.

Plug Load Equipment control measures generally involve installing automated devices that limit the power usage or operation of equipment that is plugged into an electric outlet when not in use.

Energy Efficient Practices

TRC also identified 16 low cost or no cost energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Life Hall and Speech Building include:

- Reduce Air Leakage
- Close Doors and Windows
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Turn Off Unneeded Motors
- Reduce Motor Short Cycling
- Perform Routine Motor Maintenance
- Ensure Economizers are Functioning Properly
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Check for and Seal Duct Leakage
- Repair/Replace Steam Traps
- Perform Maintenance on Compressed Air Systems
- Install Plug Load Controls
- Water Conservation

For details on these Energy Efficient Practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Life Hall and Speech Building. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered, and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Pay for Performance - Existing Building (P4P)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

Larger facilities with an interest in a more comprehensive whole building approach to energy conservation should consider participating in the Pay for Performance (P4P) program. Projects eligible for this project program must meet minimum savings requirements. Final incentives are calculated based on actual measured performance achieved at the end of the project. The application process is more involved, and it requires working with a qualified P4P contractor, but the process may result in greater energy savings overall and more lucrative incentives, up to 50% of project's total cost.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Ana Pinto	Director of Energy Management	pintoa@mail.montclair.edu	973-655-3244
TRC Energy Services			
Moussa Traore	Auditor	MTraore@trcsolutions.com	732-855-0033

2.2 General Site Information

On July 13, 2017, TRC performed an energy audit at Life Hall and Speech Building located in Montclair, New Jersey. TRC team met with Ana Pinto to review the facility operations and help focus our investigation on specific energy-using systems.

Life Hall and Speech Building is a building complex consisting of Life Hall, Memorial Auditorium, and Speech Building. The complex occupies an area of 88,691 square feet and was constructed in 1967. The complex is an educational/auditorium facility containing several types of spaces including offices, classrooms, an auditorium, a theater area, lobbies, bathrooms, common areas, hallways, mechanical rooms, and electrical rooms.

Lighting at the Life Hall and Speech complex primarily consists of a combination of 32-Watt T8 fluorescent fixtures, 40-Watt T12 fluorescent fixtures, and LED linear tubes. In addition to the linear fluorescent and LED lamps, the facility also has CFL, MH, INC, and LED exit sign fixtures. Exterior lighting is provided by MH fixtures. Lighting control is provided by switches and occupancy sensors at interior spaces and by a direct DDC for the exterior fixtures.

Cooling is provided by CHW provided by the District Energy Plant to Life Hall’s mechanical room, where it is distributed by pumps to the building’s air handling equipment. Steam is provided from the District Energy Plant to Life Hall’s mechanical room, where it is converted to heating and domestic hot water by steam-to-water heat exchangers. Heating hot water is distributed to the building’s AHUs. Electricity, steam, and chilled water are supplied to the building by the campus central cogeneration plant.

2.3 Building Occupancy

The school building is open seven (7) days a week. The typical schedule is presented in the table below. The entire facility is used year-round by the community and camps are run throughout the summer.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Life Hall and Speech Building	Weekday	8:00 AM - 8:00 PM
Life Hall and Speech Building	Weekend	8:00 AM - 8:00 PM

2.4 Building Envelope

The Life Hall and Speech Building complex is formed with continuity as a single structure. The construction is of brick material with brick exterior finish and double-pane, tinted windows with operable frames. The flat roof is constructed of built-up roofing material.

Figure 6 – Building Façade



2.5 On-Site Generation

Life Hall and Speech Building does not have any on-site electric generation capacity.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Lighting at Life Hall and Speech Building primarily consists of a combination of 32-Watt T8 fluorescent fixtures, 40-Watt T12 fluorescent fixtures, and LED linear tubes. T8 fluorescent fixtures generally have 1-lamp, 2-lamp, and 4-lamp configurations, whereas T12 fixtures have 2-lamp, 3-lamp, 4-lamp and 6-lamp configurations. T8 fixtures are 4-foot and T12 fixtures are 2-foot, 4-foot, and 8-foot in size. In general, 2-foot and 4-foot LED linear tubes have been installed in classrooms and corridors in 1-lamp and 2-lamp configurations. In addition to linear fluorescent fixtures, the building also has several 23-Watt and 42-Watt CFLs providing lighting to spaces including restrooms, stairwells, and corridors. Interior lighting also consists of 100-Watt and 300-Watt incandescent fixtures in lobby areas and various other locations. All the exit signs are LED based fixtures.

Lighting control in all interior spaces is provided by manual switches or occupancy sensors with exit signs operating 24 hours a day for security reasons.

The building's exterior lighting consists of 100-Watt and 250-Watt metal halide perimeter and wall pack fixtures. Based on the audit, all the exterior fixtures are controlled by the campus DDC system.

Figure 7 - Building Lighting Systems

Typical Surface Mounted Fluorescent Fixture



Exterior Wallpacks



Chilled Water System

CHW is provided from the District Energy Plant to Life Hall and Speech Building's mechanical rooms, where it is distributed by two (2) 7.5 hp and two (2) 5 hp chilled water pumps to the building's air handling equipment. None of the chilled water pumps have VFDs for demand-based speed variation; therefore, all the pumps operate at a constant speed regardless of the chilled water demand at the air side systems.

Figure 8 – Chilled Water Pumps



The facility also has a reciprocating chiller that is non-operational and from the original construction.

Steam to Hot Water Heating System

The heating hot water (HHW) system consists of a steam-to-water heat exchanger in the mechanical room that receives steam from the District Energy Plant. From there, the HHW is distributed to the various buildings in the complex by hot water pumps—the majority operating at constant speed. The distribution pumps for the Memorial Theater loop operate at variable speed.

Figure 9 – Hot Water Pumps



Air Distribution System

There are two (2) air handling units that serve the entire facility. AHU-1 is a variable air volume (VAV) system that serves the Life Hall portion of the complex. The AHU has one (1) 15 hp supply fan and one (1) 7.5 hp return fan. Both the fans are controlled by VFDs, and the system flow is controlled by changing speed of the supply and return fans.

Figure 10 – Air Handling Units

Air Handling Unit Fan Section



Typical Fan VFD



The second air handling unit is also a variable air volume (VAV) system. The AHU has one (1) 5 hp supply fan and one (1) 3 hp return fan. Both the fans are controlled by VFDs, and the system air flow is controlled by changing speed of the supply and return fans.

Direct Expansion Air Conditioning System (DX)

The facility also has several direct expansion air conditioning systems that include split systems and window air conditioning units. The sizes of split systems range between 0.67 tons and 5 tons, while the capacity of window AC units range from 0.42 tons to 2 tons.

Figure 11 – DX Air Conditioning Systems

Split Systems



Window AC Units



Building Energy Management System (BEMS)

Building systems are controlled through an Automated Logic Corporation's (ALC) energy management system (EMS). The BEMS is capable of providing control and programming in terms of scheduling, temperature resets, trending, and other advanced sequences.

Figure 12 – Building Energy Management System Controller



Domestic Hot Water Heating System

Steam from the District Energy Plant produces domestic hot water through a dedicated steam to water heat exchanger located in the mechanical room. The circulation pump motors operate at a constant speed.

Building Plug Load

There are about 63 computer work stations throughout the facility. All the computers are desktop units with LCD monitors. There is no centralized PC power management software installed.

There are other plug load systems such as printers, copiers, microwaves, television, etc. at the facility. In addition to the typical plug load equipment, the facility also has one (1) refrigerated and one (1) non-refrigerated vending machine.

3 SITE ENERGY USE AND COSTS

This building receives electricity through master meters. It also receives electricity, steam and chilled water from the campus central cogeneration plant. These utilities were prorated for individual buildings based on building size and function.

Prorated and direct purchase utility data were evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.5 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 13 - Utility Summary

Utility Summary for Life Hall and Speech Building		
Fuel	Usage	Cost
Electricity	2,567,012 kWh	\$216,276
Steam	8,043 kLbs	\$146,604
Total		\$362,880

The current annual energy cost for this facility is \$362,880 as shown in the chart below.

Figure 14 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G and the campus cogeneration plant. The average electric for electricity purchased from PSE&G was \$0.168/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption is shown in the chart below.

Figure 15 - Electric Usage & Demand




Figure 16 - Electric Usage & Demand

Electric Billing Data for Life Hall and Speech Building				
Period Ending	Days in Period	Electric Usage (kWh)	Total Electric Cost	TRC Estimated Usage?
11/30/15	30	119,076	\$8,486	Yes
12/31/15	31	101,199	\$8,074	Yes
1/31/16	31	103,443	\$7,034	Yes
2/28/16	28	102,473	\$13,988	Yes
3/31/16	31	115,155	\$7,850	Yes
4/30/16	30	144,134	\$10,563	Yes
5/31/16	31	211,309	\$17,196	Yes
6/30/16	30	309,775	\$26,807	Yes
7/31/16	31	411,982	\$35,849	Yes
8/31/16	31	413,918	\$36,174	Yes
9/30/16	30	337,676	\$28,616	Yes
10/31/16	31	196,872	\$15,638	Yes
Totals	365	2,567,012	\$216,276	12
Annual	365	2,567,012	\$216,276	

3.3 Steam Usage

Steam is provided by campus CHP. The average steam cost for the past 12 months is \$18.227/kLb, which is the blended rate used throughout the analyses in this report. The steam consumption is shown in the table below.

Figure 17 - Steam Usage




Figure 18 – Steam Usage

Steam Billing Data for Life Hall and Speech Building				
Period Ending	Days in Period	Steam Usage (kLbs)	Fuel Cost	TRC Estimated Usage?
11/30/15	30	532	\$8,109	Yes
12/31/15	31	713	\$10,959	Yes
1/31/16	31	1,014	\$15,829	Yes
2/28/16	28	914	\$37,918	Yes
3/31/16	31	764	\$11,610	Yes
4/30/16	30	625	\$9,397	Yes
5/31/16	31	475	\$7,410	Yes
6/30/16	30	463	\$7,033	Yes
7/31/16	31	597	\$8,985	Yes
8/31/16	31	623	\$9,390	Yes
9/30/16	30	612	\$9,187	Yes
10/31/16	31	710	\$10,778	Yes
Totals	365	8,043	\$146,604	12
Annual	365	8,043	\$146,604	

3.4 Chilled Water Usage

Chilled water is provided by the campus cogeneration plant. The average chilled water cost is \$0.327/ton-hr, which is the blended rate used throughout the analyses in this report. The chilled water consumption is shown in the table below. Chilled water is produced by steam engine chillers at the cogeneration plant, however, for ease of analysis and reporting chilled water use and cost has been combined with electricity use and cost in this report in the summary graphics.

Figure 19 – Chilled Water Usage




Figure 20 – Chilled Water Usage

Chilled Water Billing Data for Life Hall and Speech Building				
Period Ending	Days in Period	Chilled Water Usage (ton-hr)	Total Electric Cost	TRC Estimated Usage?
11/30/15	30	12,208	\$4,489	Yes
12/31/15	31	7,259	\$5,685	Yes
1/31/16	31	7,074	\$4,679	Yes
2/28/16	28	7,644	\$10,857	Yes
3/31/16	31	10,722	\$4,349	Yes
4/30/16	30	19,195	\$4,340	Yes
5/31/16	31	38,925	\$4,248	Yes
6/30/16	30	68,102	\$4,572	Yes
7/31/16	31	95,516	\$4,835	Yes
8/31/16	31	95,516	\$5,129	Yes
9/30/16	30	72,921	\$5,004	Yes
10/31/16	31	33,473	\$4,712	Yes
Totals	365	468,555	\$62,898	12
Annual	365	468,555	\$62,898	

3.5 Benchmarking

This facility was benchmarked using *Portfolio Manager*, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 21 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Life Hall and Speech Building	National Median Building Type: Higher Education - Public
Source Energy Use Intensity (kBtu/ft ²)	440.0	262.6
Site Energy Use Intensity (kBtu/ft ²)	207.0	130.7

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 22 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Life Hall and Speech Building	National Median Building Type: Higher Education - Public
Source Energy Use Intensity (kBtu/ft ²)	408.9	262.6
Site Energy Use Intensity (kBtu/ft ²)	196.4	130.7

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification.

As the electric accounts were shared between various buildings, it was not possible to benchmark these buildings and provide a score individually. A campus wide Portfolio Manager Statement of Energy Performance (SEP) was generated.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.6 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 23 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Life Hall and Speech Building regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 High Priority ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 24 – Summary of High Priority ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		170,773	0	21.3	0.0	\$28,689.87	\$66,592.13	\$3,810.00	\$62,782.13	2.2	171,967
ECM 1	Install LED Fixtures	11,501	0	1.8	0.0	\$1,932.08	\$11,245.50	\$75.00	\$11,170.50	5.8	11,581
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	88,284	0	10.8	0.0	\$14,831.76	\$29,990.00	\$2,830.00	\$27,160.00	1.8	88,902
ECM 3	Retrofit Fixtures with LED Lamps	70,988	0	8.7	0.0	\$11,926.03	\$25,356.63	\$905.00	\$24,451.63	2.1	71,485
Lighting Control Measures		30,579	0	3.7	0.0	\$5,137.31	\$13,080.00	\$1,330.00	\$11,750.00	2.3	30,793
ECM 4	Install Occupancy Sensor Lighting Controls	27,031	0	3.3	0.0	\$4,541.20	\$10,530.00	\$1,330.00	\$9,200.00	2.0	27,220
ECM 5	Install High/Low Lighting Controls	3,548	0	0.4	0.0	\$596.11	\$2,550.00	\$0.00	\$2,550.00	4.3	3,573
Variable Frequency Drive (VFD) Measures		43,973	0	4.4	0.0	\$7,387.39	\$20,317.00	\$0.00	\$20,317.00	2.8	44,280
ECM 6	Install VFDs on Chilled Water Pumps	28,092	0	3.1	0.0	\$4,719.38	\$13,765.30	\$0.00	\$13,765.30	2.9	28,288
ECM 7	Install VFDs on Hot Water Pumps	15,881	0	1.3	0.0	\$2,668.02	\$6,551.70	\$0.00	\$6,551.70	2.5	15,992
HVAC System Improvements		0	5,440	0.0	95.4	\$3,236.19	\$17,846.46	\$0.00	\$17,846.46	5.5	13,970
ECM 8	Implement Demand Control Ventilation	0	5,440	0.0	78.6	\$2,978.89	\$17,672.46	\$0.00	\$17,672.46	5.9	11,503
ECM 9	Install Pipe Insulation	0	0	0.0	16.9	\$257.29	\$174.00	\$0.00	\$174.00	0.7	2,467
Plug Load Equipment Control - Vending Machine		1,954	0	0.0	0.0	\$328.33	\$460.00	\$0.00	\$460.00	1.4	1,968
ECM 10	Vending Machine Control	1,954	0	0.0	0.0	\$328.33	\$460.00	\$0.00	\$460.00	1.4	1,968
TOTALS		247,279	5,440	29.4	95.4	\$44,779.10	\$118,295.59	\$5,140.00	\$113,155.59	2.5	262,978

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 25 below.

Figure 25 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		170,773	0	21.3	0.0	\$28,689.87	\$66,592.13	\$3,810.00	\$62,782.13	2.2	171,967
ECM 1	Install LED Fixtures	11,501	0	1.8	0.0	\$1,932.08	\$11,245.50	\$75.00	\$11,170.50	5.8	11,581
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	88,284	0	10.8	0.0	\$14,831.76	\$29,990.00	\$2,830.00	\$27,160.00	1.8	88,902
ECM 3	Retrofit Fixtures with LED Lamps	70,988	0	8.7	0.0	\$11,926.03	\$25,356.63	\$905.00	\$24,451.63	2.1	71,485

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM I: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	11,501	0	1.8	0.0	\$1,932.08	\$11,245.50	\$75.00	\$11,170.50	5.8	11,581

Measure Description

We recommend replacing existing fixtures containing HID lamps with new high-performance LED light fixtures. This measure saves energy by installing LEDs, which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than that of a HID lamp.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	88,284	0	10.8	0.0	\$14,831.76	\$29,990.00	\$2,830.00	\$27,160.00	1.8	88,902
Exterior	0	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs, which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of fluorescent tubes and more than 10 times longer than many incandescent lamps.

ECM 3: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	70,988	0	8.7	0.0	\$11,926.03	\$25,356.63	\$905.00	\$24,451.63	2.1	71,485
Exterior	0	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing incandescent, fluorescent, and compact fluorescent lighting technologies with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs, which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes, which are more than twice that of fluorescent tubes and more than 10 times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 26 below.

Figure 26 – Summary of Lighting Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures	30,579	0	3.7	0.0	\$5,137.31	\$13,080.00	\$1,330.00	\$11,750.00	2.3	30,793
ECM 4 Install Occupancy Sensor Lighting Controls	27,031	0	3.3	0.0	\$4,541.20	\$10,530.00	\$1,330.00	\$9,200.00	2.0	27,220
ECM 5 Install High/Low Lighting Controls	3,548	0	0.4	0.0	\$596.11	\$2,550.00	\$0.00	\$2,550.00	4.3	3,573

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 4: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
27,031	0	3.3	0.0	\$4,541.20	\$10,530.00	\$1,330.00	\$9,200.00	2.0	27,220

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in all restrooms, storage rooms, classrooms, corridors, etc. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 5: Install High/Low Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,548	0	0.4	0.0	\$596.11	\$2,550.00	\$0.00	\$2,550.00	4.3	3,573

Measure Description

We recommend installing occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons. Typical areas for such lighting control are interior corridors.

Lighting fixtures with these controls operate at default low levels when the area is not occupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. The lighting systems are switched to full lighting levels whenever an occupant is detected. Fixtures are automatically switched back to low level after an area has been vacant for a preset period of time. Energy savings results from only providing full lighting levels when it is required.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage needs to be provided to ensure that lights turn on in each area as an occupant approaches.

Additional savings from reduced lighting maintenance may also result from this measure, due to reduced lamp operation.

4.1.3 Variable Frequency Drive Measures

Our recommendations for VFD measures are summarized in Figure 27 below.

Figure 27 – Summary of Variable Frequency Drive ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		43,973	0	4.4	0.0	\$7,387.39	\$20,317.00	\$0.00	\$20,317.00	2.8	44,280
ECM 6	Install VFDs on Chilled Water Pumps	28,092	0	3.1	0.0	\$4,719.38	\$13,765.30	\$0.00	\$13,765.30	2.9	28,288
ECM 7	Install VFDs on Hot Water Pumps	15,881	0	1.3	0.0	\$2,668.02	\$6,551.70	\$0.00	\$6,551.70	2.5	15,992

ECM 6: Install VFDs on Chilled Water Pumps

Summary of Measure Economics

Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
28,092	0	3.1	0.0	\$4,719.38	\$13,765.30	\$0.00	\$13,765.30	2.9	28,288

Measure Description

We recommend installing VFD to control chilled water pumps. This measure requires that chilled water coils be served by 2-way valves and that a differential pressure sensor be installed in the chilled water loop. As the chilled water valves close, the differential pressure increases. The VFD modulates pump speed to maintain a differential pressure setpoint. Energy savings results from reducing pump motor speed (and power) as chilled water valves close. The magnitude of energy savings is based on the estimated amount of time that the system operates at reduced loads.

For systems with variable chilled water flow through the chiller, the minimum flow to prevent the chiller from tripping off will have to be determined during the final project design. The control system should be programmed to maintain the minimum flow through the chiller and to prevent pump cavitation.

ECM 7: Install VFDs on Hot Water Pumps

Summary of Measure Economics

Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
15,881	0	1.3	0.0	\$2,668.02	\$6,551.70	\$0.00	\$6,551.70	2.5	15,992

Measure Description

We recommend installing VFDs to control hot water pumps. This measure requires that a majority of the hot water coils be served by 2-way valves and that a differential pressure sensor is installed in the hot water loop. As the hot water valves close, the differential pressure increases. The VFD modulates pump speed to maintain a differential pressure setpoint. Energy savings results from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

4.1.4 HVAC System Upgrades

Our recommendation for HVAC system improvement are summarized in Figure 28 below.

Figure 28 - Summary of HVAC System Improvement ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
HVAC System Improvements		0	5,440	0.0	95.4	\$3,236.19	\$17,846.46	\$0.00	\$17,846.46	5.5	13,970
ECM 8	Implement Demand Control Ventilation	0	5,440	0.0	78.6	\$2,978.89	\$17,672.46	\$0.00	\$17,672.46	5.9	11,503
ECM 9	Install Pipe Insulation	0	0	0.0	16.9	\$257.29	\$174.00	\$0.00	\$174.00	0.7	2,467

ECM 8: Implement Demand Control Ventilation (DCV)

Summary of Measure Economics

Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
0	5,440	0.0	78.6	\$2,978.89	\$17,672.46	\$0.00	\$17,672.46	5.9	11,503

Measure Description

Demand control ventilation (DCV) monitors indoor air CO₂ content to measure room occupancy. This data is used to regulate the amount of outdoor provided to the space for ventilation. In order to ensure adequate air quality, standard ventilation systems often provide outside air based on a space's estimated maximum occupancy. However, during low occupancy periods, the space may be over ventilated. This wastes energy through excessive fan more usage and additional cost to heat and cool the excessive air flow. DCV reduces unnecessary outdoor air intake by regulating ventilation based on actual occupancy levels, saving significant amounts of energy. DCV is most suited for facilities where occupancy levels vary significantly hour to hour and day to day.

Energy savings associated with DCV are based on hours of operation, space occupancy, system air flow, outside air reduction, and other factors. Energy savings results from eliminating unnecessary ventilation and space conditioning.

ECM 9: Install Pipe Insulation

Summary of Measure Economics

Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
0	0	0.0	16.9	\$257.29	\$174.00	\$0.00	\$174.00	0.7	2,467

Measure Description

We recommend installing insulation on heating system piping. Distribution system losses are dependent on heating water system temperature, the size of the distribution system, and the level of insulation of the piping. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is exposed to water, when the insulation has been removed from some areas of the pipe, or when valves have not been properly insulated system efficiency can be significantly reduced.

This measure saves energy by reducing heat losses from the heating distribution system.

4.1.5 Plug Load Equipment Control - Vending Machines

Our recommendations for plug load equipment controls are summarized in Figure 29 below.

Figure 29 - Summary of Plug Load Equipment Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Plug Load Equipment Control - Vending Machine	1,954	0	0.0	0.0	\$328.33	\$460.00	\$0.00	\$460.00	1.4	1,968
ECM 10 Vending Machine Control	1,954	0	0.0	0.0	\$328.33	\$460.00	\$0.00	\$460.00	1.4	1,968

ECM 10: Vending Machine Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,954	0	0.0	0.0	\$328.33	\$460.00	\$0.00	\$460.00	1.4	1,968

Measure Description

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor controls to reduce the energy use. These controls power down vending machines when the vending machine area has been vacant for some time, then power up at regular intervals, as needed, to turn machine lights on or keep the product cool. Energy savings are a dependent on vending machine and activity level in the area surrounding the machines.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost-effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Turn Off Unneeded Motors

Electric motors often run unnecessarily, and this is an overlooked opportunity to save energy. These motors should be identified and turned off when appropriate. For example, exhaust fans often run unnecessarily when ventilation requirements are already met. Reducing run hours for these motors can result in significant energy savings. Whenever possible, use automatic devices such as twist timers or occupancy sensors to ensure that motors are turned off when not needed.

Reduce Motor Short Cycling

Frequent stopping and starting of motor subjects rotors and other parts to substantial stress. This can result in component wear, reducing efficiency, and increasing maintenance costs. Adjust the load on the motor to limit the amount of unnecessary stopping and starting to improve motor performance.

Perform Routine Motor Maintenance

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Ensure Economizers are Functioning Properly

Economizers, when properly configured, can be used to significantly reduce mechanical cooling. However, if the outdoor thermostat or enthalpy control is malfunctioning or the damper is stuck or improperly adjusted, benefits from the economizer may not be fully realized. As such, periodic inspection and maintenance is required to ensure proper operation. This maintenance should be scheduled with maintenance of the facility's air conditioning system and should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position. A malfunctioning economizer can significantly increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Check for and Seal Duct Leakage

Duct leakage in commercial buildings typically accounts for 5% to 25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building, significantly increasing cooling and heating costs. By sealing sources of leakage, cooling, heating, and ventilation energy use can be reduced significantly, depending on the severity of air leakage.

Repair/Replace Steam Traps

Properly functioning steam traps ensure that all latent heat in the steam is delivered to the end use by preventing pressurized steam from leaking. Steam traps should be inspected as part of the regular steam system maintenance. Traps that are blocked, venting, or allowing steam to leak through should be repaired or replaced. Repairing or replacing existing steam traps will reduce steam losses.

Perform Maintenance on Compressed Air Systems

Like all electro-mechanical equipment, compressed air systems require periodic maintenance to operate at peak efficiency. A maintenance plan should be developed for process related compressed air systems to include inspection, cleaning, and replacement of inlet filter cartridges, cleaning of drain traps, daily inspection of lubricant levels to reduce unwanted friction, inspection of belt condition and tension, checking for system leaks and adjustment of loose connections, and overall system cleaning. Contact a qualified technician for help with setting up periodic maintenance schedule.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gallons per minute (gpm) for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility's electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has a Low potential for installing a PV array.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.

The campus has a CHP plant that uses natural gas fired turbines to generate electricity. Waste heat from the turbines is used to produce steam which is either delivered to buildings on campus or used to produce chilled water which is delivered to buildings on campus. Since the campus has a CHP that serves a significant portion of the campus further evaluation of individual building CHP applications were not done.

7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary, and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically, an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion this building is not a good candidate for DR.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 30 for a list of the eligible programs identified for each recommended ECM.

Figure 30 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	X			X		
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X			X		
ECM 3	Retrofit Fixtures with LED Lamps	X			X		
ECM 4	Install Occupancy Sensor Lighting Controls	X			X		
ECM 5	Install High/Low Lighting Controls	X			X		
ECM 6	Install VFDs on Chilled Water Pumps	X			X		
ECM 7	Install VFDs on Hot Water Pumps	X			X		
ECM 8	Implement Demand Control Ventilation				X		
ECM 9	Install Pipe Insulation				X		
ECM 10	Vending Machine Control	X			X		

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. This facility does not meet all of the criteria for participating in the P4P program based on the measures identified in this study. However, since additional measures may be identified during the P4P evaluation and the facility is close to meeting the P4P program criteria it is worth considering the P4P program for this site. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Pay for Performance - Existing Buildings

Overview

The Pay for Performance – Existing Buildings (P4P EB) program is designed for larger customers with a peak demand over 200 kW in any of the preceding 12 months. Under this program the minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings. P4P is a generally a good option for medium to large sized facilities looking to implement as many measures as possible under a single project in order to achieve deep energy savings. This program has an added benefit of evaluating a broad spectrum of measures that may not otherwise qualify under other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also utilize the P4P program.

Incentives

Incentives are calculated based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50% total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

How to Participate

To participate in the P4B EB program you will need to contact one of the pre-approved consultants and contractors (“Partners”). Under direct contract to you, the Partner will help further evaluate the measures identified in this report through development of the Energy Reduction Plan (ERP), assist you in implementing selected measures, and verify actual savings one year after the installation. At each of these three milestones your Partner will also facilitate securing program incentives.

Approval of the final scope of work is required by the program prior to installation completion. Although installation can be accomplished by a contractor of your choice (some P4P Partners are also contractors) or by internal personnel, the Partner must remain involved to ensure compliance with the program guidelines and requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: www.njcleanenergy.com/P4P.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility is purchasing electricity from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third-party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions					Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Corridor	11	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	11	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	3,669	0.48	3,903	0.0	\$655.77	\$1,587.00	\$110.00	2.25
Corridor	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Lobby	22	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	None	No	22	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Lobby	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1300	4	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.20	1,632	0.0	\$274.23	\$738.00	\$75.00	2.42
1300	3	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	3	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.03	253	0.0	\$42.53	\$150.00	\$0.00	3.53
1300	1	Incandescent: Screw-in 100 Watts	Wall Switch	100	5,242	Relamp	No	1	LED Screw-In Lamps: LED Screw-in 19-Watt	Wall Switch	19	5,242	0.06	488	0.0	\$82.03	\$53.75	\$5.00	0.59
Corridor	22	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	Yes	22	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	3,669	0.08	676	0.0	\$113.62	\$600.00	\$0.00	5.28
Corridor	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor	4	U-Bend Fluorescent - T12: U T12 (34W) - 2L	Wall Switch	72	5,242	Relamp & Reballast	Yes	4	LED - Linear Tubes: (2) U-Lamp	High/Low Control	33	3,669	0.14	1,179	0.0	\$198.08	\$618.00	\$0.00	3.12
1251	25	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	Yes	25	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	0.09	769	0.0	\$129.12	\$540.00	\$70.00	3.64
1254	4	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	4	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1252	4	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	4	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1301	1	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	1	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.01	84	0.0	\$14.18	\$50.00	\$0.00	3.53
Corridor - Basement	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	3,669	None	No	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - Basement	2	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	None	No	2	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - Basement	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - Basement	10	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	10	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	3,669	0.50	4,081	0.0	\$685.58	\$1,470.00	\$100.00	2.00
Corridor - Basement	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	3,669	0.20	1,632	0.0	\$274.23	\$473.67	\$40.00	1.58
Corridor - Basement	5	Linear Fluorescent - T12: 2' T12 (20W) - 4L	Wall Switch	100	5,242	Relamp & Reballast	Yes	5	LED - Linear Tubes: (4) 2' Lamps	High/Low Control	34	3,669	0.28	2,297	0.0	\$385.83	\$869.17	\$100.00	1.99
Corridor - Basement	6	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	5,242	None	No	6	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - Basement	23	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	None	Yes	23	LED - Linear Tubes: (1) 4' Lamp	High/Low Control	15	3,669	0.07	603	0.0	\$101.32	\$600.00	\$0.00	5.92
Corridor - Basement	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor - Basement	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
104	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
102	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
Mens Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	5,242	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	0.01	105	0.0	\$17.72	\$35.90	\$5.00	1.74
Mens Restroom	1	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	1	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.01	84	0.0	\$14.18	\$50.00	\$0.00	3.53
Womens Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	5,242	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	0.01	105	0.0	\$17.72	\$35.90	\$5.00	1.74
Womens Restroom	1	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	1	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.01	84	0.0	\$14.18	\$50.00	\$0.00	3.53
31	2	Linear Fluorescent - T12: 2' T12 (20W) - 4L	Wall Switch	100	5,242	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 2' Lamps	Occupancy Sensor	34	3,669	0.11	919	0.0	\$154.33	\$557.67	\$75.00	3.13
31	4	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.17	1,423	0.0	\$238.99	\$468.00	\$40.00	1.79
101	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
50	7	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.35	2,857	0.0	\$479.91	\$1,089.00	\$105.00	2.05
50	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.09	711	0.0	\$119.50	\$161.83	\$20.00	1.19
51	8	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.40	3,265	0.0	\$548.47	\$1,206.00	\$115.00	1.99
Storage	3	Incandescent: Screw-in 300 Watts	Wall Switch	300	5,242	Relamp	Yes	3	LED Screw-In Lamps: LED Screw-in 145-Watt	Occupancy Sensor	145	3,669	0.44	3,590	0.0	\$603.05	\$1,170.00	\$15.00	1.92
63	7	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.35	2,857	0.0	\$479.91	\$1,089.00	\$105.00	2.05
63	18	Compact Fluorescent: CFL - 3L - 39W	Wall Switch	39	5,242	Relamp	Yes	18	LED Screw-In Lamps: LED 11-Watt 4-Pin	Occupancy Sensor	11	3,669	0.41	3,396	0.0	\$570.54	\$1,170.00	\$35.00	1.99
52	12	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.60	4,897	0.0	\$822.70	\$1,674.00	\$155.00	1.85
53	6	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,669	0.60	4,897	0.0	\$822.70	\$1,241.00	\$155.00	1.32
Mens Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,242	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.02	199	0.0	\$33.42	\$58.50	\$10.00	1.45
31	1	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	1	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.01	84	0.0	\$14.18	\$50.00	\$0.00	3.53
309	2	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	2	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.02	169	0.0	\$28.35	\$100.00	\$0.00	3.53
Womens Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,242	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.02	199	0.0	\$33.42	\$58.50	\$10.00	1.45
Womens Restroom	1	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	1	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.01	84	0.0	\$14.18	\$50.00	\$0.00	3.53
54A	1	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	1	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.01	84	0.0	\$14.18	\$50.00	\$0.00	3.53
54B	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	5,242	Relamp	No	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	0.03	211	0.0	\$36.44	\$71.80	\$10.00	1.74
56	3	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	3	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.03	253	0.0	\$42.53	\$150.00	\$0.00	3.53
Mechanical Room	4	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	1,095	None	No	4	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	1,095	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
333	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.09	711	0.0	\$119.50	\$161.83	\$20.00	1.19
Mechanical Room	5	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	1,095	None	No	5	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	1,095	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor	4	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	None	No	4	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mens Restroom	5	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	None	No	5	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
230	1	Compact Fluorescent CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	1	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.01	84	0.0	\$14.18	\$50.00	\$0.00	3.53
Womens Restroom	3	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	None	No	3	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
200	21	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,242	Relamp	Yes	21	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.64	5,279	0.0	\$886.80	\$1,498.50	\$245.00	1.41
200	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Back Corridor	9	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	9	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Back Corridor	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Electrical Room	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	1,095	None	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	1,095	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Tunnel	12	Compact Fluorescent CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	Yes	12	LED Screw-In Lamps: LED 9-Watt 2-Pin	Occupancy Sensor	9	3,669	0.15	1,208	0.0	\$202.94	\$870.00	\$35.00	4.11
Mechanical Room	10	Compact Fluorescent CFL - 1L - 23W	Wall Switch	23	1,095	Relamp	No	10	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	1,095	0.10	176	0.0	\$29.62	\$500.00	\$0.00	16.88
Mechanical Room	15	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	1,095	None	No	15	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	1,095	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	2	Exit Signs: LED - 2 W Lamp	None	6	1,095	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	1,095	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	2	Exit Signs: LED - 2 W Lamp	None	6	1,095	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	1,095	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1309	1	Incandescent - Screw-in 100 Watts	Wall Switch	100	5,242	Relamp	No	1	LED Screw-In Lamps: LED Screw-in 19-Watt	Wall Switch	19	5,242	0.06	488	0.0	\$82.03	\$53.75	\$5.00	0.59
1309A	1	Incandescent - Screw-in 100 Watts	Wall Switch	100	5,242	Relamp	No	1	LED Screw-In Lamps: LED Screw-in 19-Watt	Wall Switch	19	5,242	0.06	488	0.0	\$82.03	\$53.75	\$5.00	0.59
1305	12	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	None	No	12	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1310	45	Incandescent - Screw-in 300 Watts	Wall Switch	300	5,242	Relamp	Yes	45	LED Screw-In Lamps: LED Screw-in 145-Watt	Occupancy Sensor	145	3,669	6.57	53,844	0.0	\$9,045.74	\$14,040.00	\$295.00	1.52
1310	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1303	5	Compact Fluorescent CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	5	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.05	422	0.0	\$70.89	\$250.00	\$0.00	3.53
1244	4	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,669	0.40	3,265	0.0	\$548.47	\$917.33	\$115.00	1.46
1250	9	Compact Fluorescent CFL - 4L - 42W	Wall Switch	42	5,242	Relamp	Yes	9	LED Screw-In Lamps: LED 11-Watt 4-Pin	Occupancy Sensor	11	3,669	0.23	1,861	0.0	\$312.61	\$720.00	\$35.00	2.19
1250	18	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	None	Yes	18	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	0.08	618	0.0	\$103.90	\$270.00	\$35.00	2.26

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
1250	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1210	7	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	7	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1210	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1250	5	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	5	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1251	22	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	Yes	22	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	0.08	676	0.0	\$113.62	\$270.00	\$35.00	2.07
1251	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Stairwell F	4	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	None	No	4	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Stairwell F	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
Corridor 2nd Floor	9	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	5,242	Relamp	Yes	9	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	3,669	0.49	3,982	0.0	\$668.97	\$1,156.20	\$180.00	1.46
Corridor 2nd Floor	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Corridor 2nd Floor	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
2231	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
2231D	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	5,242	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,669	0.11	885	0.0	\$148.66	\$460.27	\$75.00	2.59
2231C	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
2231E	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
2231A	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
2231B	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
2221	15	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.75	6,121	0.0	\$1,028.37	\$2,025.00	\$185.00	1.79
2221A	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
2224	10	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.50	4,081	0.0	\$685.58	\$1,440.00	\$135.00	1.90
2220	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
2224A	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	5,242	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,669	0.11	885	0.0	\$148.66	\$460.27	\$75.00	2.59
2220	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
2220B	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
2220C	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
2217A	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
2217	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
2217B	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
2212	8	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	Yes	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,669	0.80	6,529	0.0	\$1,096.93	\$1,564.67	\$195.00	1.25
2210	3	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	5,242	Relamp & Reballast	Yes	3	LED - Linear Tubes: (2) 8' Lamps	Occupancy Sensor	72	3,669	0.24	1,946	0.0	\$326.89	\$876.00	\$35.00	2.57
435	4	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	None	No	4	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mezzanine	6	Compact Fluorescent: CFL - 1L - 23W	Wall Switch	23	5,242	Relamp	No	6	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.06	506	0.0	\$85.06	\$300.00	\$0.00	3.53
Attic	10	Incandescent: Screw-in 300 Watts	Wall Switch	300	5,242	Relamp	Yes	10	LED Screw-In Lamps: LED Screw-in 145-Watt	Occupancy Sensor	145	3,669	1.46	11,965	0.0	\$2,010.16	\$3,270.00	\$85.00	1.58
Attic	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1246	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
1246A	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
1246B	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
1240	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.09	711	0.0	\$119.50	\$161.83	\$20.00	1.19
1241	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.09	711	0.0	\$119.50	\$161.83	\$20.00	1.19
1242	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.09	711	0.0	\$119.50	\$161.83	\$20.00	1.19
1243	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.09	711	0.0	\$119.50	\$161.83	\$20.00	1.19
Exterior Perimeter	5	Metal Halide: (1) 100W Lamp	DDC	128	4,100	Fixture Replacement	No	5	LED - Fixtures: Outdoor Porch Wall Mount	DDC	37	4,100	0.33	2,145	0.0	\$360.41	\$3,748.50	\$25.00	10.33
Wallpack	10	Metal Halide: (1) 250W Lamp	DDC	295	4,100	Fixture Replacement	No	10	LED - Fixtures: Porch (Wall Mounted)	DDC	60	4,100	1.73	11,080	0.0	\$1,861.48	\$7,497.00	\$50.00	4.00
Entrance	6	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	None	No	6	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Lobby	12	Incandescent: Screw-in 100 Watts	Wall Switch	100	5,242	Relamp	No	12	LED Screw-In Lamps: LED Screw-in 19-Watt	Wall Switch	19	5,242	0.72	5,859	0.0	\$984.32	\$645.04	\$60.00	0.59
Lobby	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1401	12	Linear Fluorescent - T12: 4' T12 (40W) - 3L	Wall Switch	127	5,242	Relamp & Reballast	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,669	0.85	6,984	0.0	\$1,173.29	\$1,848.00	\$215.00	1.39
1402	12	Linear Fluorescent - T12: 4' T12 (40W) - 3L	Wall Switch	127	5,242	Relamp & Reballast	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,669	0.85	6,984	0.0	\$1,173.29	\$1,848.00	\$215.00	1.39
1403	1	Incandescent: Screw-in 100 Watts	Wall Switch	100	5,242	Relamp	No	1	LED Screw-In Lamps: LED Screw-in 19-Watt	Wall Switch	19	5,242	0.06	488	0.0	\$82.03	\$53.75	\$5.00	0.59
1405	1	Incandescent: Screw-in 100 Watts	Wall Switch	100	5,242	Relamp	No	1	LED Screw-In Lamps: LED Screw-in 19-Watt	Wall Switch	19	5,242	0.06	488	0.0	\$82.03	\$53.75	\$5.00	0.59

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Corridor	5	Compact Fluorescent CFL - 2L - 26W	Wall Switch	26	5,242	Relamp	No	5	LED Screw-In Lamps: LED 9-Watt 2-Pin	Wall Switch	9	5,242	0.06	512	0.0	\$86.08	\$250.00	\$0.00	2.90
436	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
436	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,242	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.02	199	0.0	\$33.42	\$58.50	\$10.00	1.45
407	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	None	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.06	472	0.0	\$79.29	\$270.00	\$35.00	2.96
428	11	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	Yes	11	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	0.04	338	0.0	\$56.81	\$270.00	\$35.00	4.14
428	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	None	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
428	21	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	None	Yes	21	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	0.09	722	0.0	\$121.22	\$270.00	\$35.00	1.94
428A	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	None	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
427	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	None	No	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
425	12	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	Yes	12	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	0.05	369	0.0	\$61.98	\$270.00	\$35.00	3.79
425	17	LED - Fixtures: 19 Watt 2-Pin	Wall Switch	19	5,242	None	Yes	17	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	0.07	584	0.0	\$98.13	\$270.00	\$35.00	2.39
424	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	None	No	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
424	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	None	No	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
424	1	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	None	No	1	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
422	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
420	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	None	No	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
406	9	LED - Linear Tubes: (1) 2' Lamp	Occupancy Sensor	9	3,669	None	No	9	LED - Linear Tubes: (1) 2' Lamp	Occupancy Sensor	9	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
406	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
406A	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	None	No	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
406A	1	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	None	No	1	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
406B	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mens Restroom	2	Linear Fluorescent - T12: 2 T12 (20W) - 4L	Wall Switch	100	5,242	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 2' Lamps	Occupancy Sensor	34	3,669	0.11	919	0.0	\$154.33	\$557.67	\$75.00	3.13
Mens Restroom	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
Womens Restroom	2	Linear Fluorescent - T12: 2 T12 (20W) - 4L	Wall Switch	100	5,242	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 2' Lamps	Occupancy Sensor	34	3,669	0.11	919	0.0	\$154.33	\$557.67	\$75.00	3.13
Womens Restroom	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
404	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	None	No	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
404	2	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	None	No	2	LED - Fixtures: 19 Watt 2-Pin	Occupancy Sensor	19	3,669	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
402	1	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	None	No	1	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Stairwell	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	None	No	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Fox Theater	5	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	5	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.43	3,556	0.0	\$597.48	\$809.17	\$100.00	1.19
Fox Theater	6	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	6	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.52	4,268	0.0	\$716.98	\$971.00	\$120.00	1.19
Fox Theater	4	Compact Fluorescent CFL - 3L - 42W Screw-In	Wall Switch	42	5,242	Relamp	No	4	LED Screw-In Lamps: LED 11-Watt 4-Pin	Wall Switch	11	5,242	0.09	747	0.0	\$125.57	\$200.00	\$0.00	1.59
Fox Theater	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1404	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
414	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
414	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
Shop Area	4	Linear Fluorescent - T12: 4' T12 (40W) - 6L	Wall Switch	254	5,242	Relamp & Reballast	No	4	LED - Linear Tubes: (6) 4' Lamps	Wall Switch	87	5,242	0.49	4,027	0.0	\$676.47	\$879.33	\$120.00	1.12
Shop Area	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Shop Area	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	176	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	5,242	0.17	1,423	0.0	\$238.99	\$323.67	\$40.00	1.19
Shop Area	6	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	5,242	Relamp & Reballast	No	6	LED - Linear Tubes: (2) 8' Lamps	Wall Switch	72	5,242	0.38	3,110	0.0	\$522.54	\$1,212.00	\$0.00	2.32
Shop Area	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,242	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.02	199	0.0	\$33.42	\$58.50	\$10.00	1.45
Shop Area	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.09	711	0.0	\$119.50	\$234.00	\$20.00	1.79
1401	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
1401	43	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	None	Yes	43	LED Screw-In Lamps: LED Screw-in 9 Watts	Occupancy Sensor	9	3,669	0.09	700	0.0	\$117.57	\$540.00	\$70.00	4.00
1401	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1440	2	Linear Fluorescent - T12: 2' T12 (20W) - 2L	Wall Switch	50	5,242	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,242	0.05	398	0.0	\$66.84	\$214.00	\$20.00	2.90
1439	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	5,242	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,242	0.04	356	0.0	\$59.75	\$117.00	\$10.00	1.79
1439	33	LED Screw-In Lamps: LED Screw-in 9 Watts	Wall Switch	9	5,242	None	Yes	33	LED Screw-In Lamps: LED Screw-in 9 Watts	Occupancy Sensor	9	3,669	0.07	537	0.0	\$90.23	\$540.00	\$70.00	5.21

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical Room	Heating Hot Water System	2	Heating Hot Water Pump	5.0	89.5%	No	4,380	No	89.5%	Yes	2	1.26	15,881	0.0	\$2,668.02	\$6,551.70	\$0.00	2.46
Mechanical Room	Chilled Water System	2	Chilled Water Pump	7.5	91.0%	No	3,391	No	91.0%	Yes	2	1.85	18,139	0.0	\$3,047.30	\$7,213.60	\$0.00	2.37
Rm 435	Chilled Water System	2	Chilled Water Pump	5.0	89.5%	No	2,745	No	89.5%	Yes	2	1.26	9,953	0.0	\$1,672.08	\$6,551.70	\$0.00	3.92
Rm 435	Condensate System	2	Condenser Water Pump	1.0	85.5%	No	4,380	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 435	Chilled and Hot Water System (2-pipe system)	2	Other	2.0	84.0%	No	2,745	No	84.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 435	Chilled and Hot Water System (2-pipe system)	1	Other	0.1	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 435	Chilled and Hot Water System (2-pipe system)	1	Other	1.0	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 435	Drain System	2	Other	1.5	86.5%	No	2,745	No	86.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Restroom	1	Exhaust Fan	0.8	85.5%	No	8,760	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Life Hall AHU	1	Supply Fan	15.0	92.4%	Yes	8,760	No	92.4%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Life Hall AHU	1	Return Fan	7.5	91.7%	Yes	8,760	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Exhaust System	2	Exhaust Fan	3.0	89.5%	Yes	8,760	No	89.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Exhaust System	1	Exhaust Fan	15.0	92.4%	Yes	8,760	No	92.4%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Exhaust System	3	Exhaust Fan	0.5	82.5%	No	8,760	No	82.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Compressed Air	1	Air Compressor	5.0	89.5%	No	2,190	No	89.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Heating Hot Water System	3	Heating Hot Water Pump	2.0	86.5%	No	2,920	No	86.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Heating Hot Water System	2	Heating Hot Water Pump	3.0	87.5%	Yes	4,380	No	87.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Condensate System	1	Condenser Water Pump	0.3	77.0%	No	2,745	No	77.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Heating Hot Water System	2	Heating Hot Water Pump	1.5	86.5%	No	4,380	No	86.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	AHU	1	Supply Fan	5.0	89.5%	Yes	8,760	No	89.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical Room	AHU	1	Return Fan	3.0	89.5%	Yes	8,760	No	89.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
414	Elevator	1	Other	30.0	91.7%	No	1,460	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Sump Room	Air Compressor	2	Air Compressor	1.0	85.5%	No	2,190	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions									Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
50	50	2	Window AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
51	51	1	Window AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
53	53	2	Window AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
31	31	1	Window AC	0.42		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
309	309	1	Window AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
200	200	2	Split-System AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2221	2221	2	Split-System AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2224	2224	1	Split-System AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2220B	2220B	1	Split-System AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2220C	2220C	1	Split-System AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2217A	2217A	1	Split-System AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2217B	2217B	1	Split-System AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2212	2212	1	Split-System AC	1.18		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2210	2210	2	Split-System AC	0.67		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Ground Floor	Rm 404	1	Split-System AC	5.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
430	Data Room	1	Split-System AC	1.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1441	1441	1	Window AC	0.43		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
1440	1440	1	Window AC	0.43		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric Chiller Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions							Energy Impact & Financial Analysis							
		Chiller Quantity	System Type	Cooling Capacity per Unit (Tons)	Install High Efficiency Chillers?	Chiller Quantity	System Type	Constant/Variable Speed	Cooling Capacity (Tons)	Full Load Efficiency (kW/Ton)	IPLV Efficiency (kW/Ton)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Central Plant	Life Hall and Speech Building	1	Water-Cooled Centrifugal Chiller	344.53	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis							
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
CHP	Life Hall and Speech Building	1	Forced Draft Steam Boiler	6,800.00	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Demand Control Ventilation Recommendations

Location	Area(s)/System(s) Affected	Recommendation Inputs				Energy Impact & Financial Analysis					
		Number of Zones	Cooling Capacity of Controlled System (Tons)	Electric Heating Capacity of Controlled System (kBtu/hr)	Output Heating Capacity of Controlled System (MBh)	Total Annual Ton-Hr Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Building	Throughout Building	13	80.00		1,200.00	5,440	78.6	\$2,978.89	\$17,672.46	\$0.00	5.93

Pipe Insulation Recommendations

Location	Area(s)/System(s) Affected	Recommendation Inputs		Energy Impact & Financial Analysis						
		Length of Uninsulated Pipe (ft)	Pipe Diameter (in)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mech Spaces	Distribution piping	40	3.00	0.00	0	16.9	\$257.29	\$174.00	\$0.00	0.68

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Life Hall	Life Hall	1	Indirect System	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Life Hall	63	Desktop Computer and LCD Monitor	191.0	No
Life Hall	5	Copier	515.0	No
Life Hall	7	Microwave	1,000.0	No
Life Hall	26	Printer	20.0	No
Life Hall	5	Small Freezer	600.0	No
Life Hall	3	Water Cooler	500.0	No
Life Hall	1	Dryer	1,600.0	No
Life Hall	1	Washer	900.0	No
Life Hall	2	Washer	900.0	No
Life Hall	9	Television	120.0	No

Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Corridor	1	Refrigerated	Yes	0.00	1,612	0.0	\$270.79	\$230.00	\$0.00	0.85
Corridor	1	Non-Refrigerated	Yes	0.00	343	0.0	\$57.54	\$230.00	\$0.00	4.00

APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE



ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

N/A **Montclair State University Campus (Buildings 1-41)**

Primary Property Type: College/University
 Gross Floor Area (ft²): 2,925,896
 Built: 1908

For Year Ending: October 31, 2016
 Date Generated: October 10, 2017

ENERGY STAR® Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Montclair State University Campus (Buildings 1-41) 1 Normal Avenue Montclair, New Jersey 07043	Property Owner Montclair Statet University 1 Normal Avenue Montclair, NJ 07043 973-655-3244	Primary Contact Ana Pinto 1 Normal Avenue Montclair, NJ 07043 973-655-3244 pintoa@montclair.edu
Property ID: 6069294		

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI 172.3 kBtu/ft²	Annual Energy by Fuel	National Median Comparison	
	District Chilled Water - 81,507,530 (16%)	National Median Site EUI (kBtu/ft²)	147.6
	Other (kBtu)	National Median Source EUI (kBtu/ft²)	262.6
	District Steam (kBtu) 223,798,259 (44%)	% Diff from National Median Source EUI	17%
	Electric - Grid (kBtu) 161,334,839 (32%)		
	Natural Gas (kBtu) 37,406,141 (7%)		
Source EUI 306.4 kBtu/ft²		Annual Emissions	
		Greenhouse Gas Emissions (Metric Tons CO2e/year)	N/A

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional



Professional Engineer Stamp (if applicable)