



# Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

**DPW**

**Secaucus, Town of**

370 Secaucus Road

Secaucus, New Jersey 07094

November 26, 2018

Final Report by:

**TRC Energy Services**

## Disclaimer

---

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

# Table of Contents

---

<b>1</b>	<b>Executive Summary .....</b>	<b>1</b>
1.1	Facility Summary .....	1
1.2	Your Cost Reduction Opportunities.....	2
	Energy Conservation Measures.....	2
	Energy Efficient Practices .....	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
<b>2</b>	<b>Facility Information and Existing Conditions .....</b>	<b>5</b>
2.1	Project Contacts .....	5
2.2	General Site Information.....	5
2.3	Building Occupancy .....	6
2.4	Building Envelope .....	6
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems .....	7
	Lighting System .....	7
	Hot Water Heating System.....	7
	Air Side Direct Expansion (DX) Cooling and Heating .....	8
	Domestic Hot Water Heating System.....	9
	Building Plug Load .....	9
2.7	Water-Using Systems .....	9
<b>3</b>	<b>Site Energy Use and Costs .....</b>	<b>10</b>
3.1	Total Cost of Energy .....	10
3.2	Electricity Usage .....	11
3.3	Natural Gas Usage .....	12
3.4	Benchmarking.....	13
3.5	Energy End-Use Breakdown .....	14
<b>4</b>	<b>Energy Conservation Measures .....</b>	<b>15</b>
4.1	Recommended ECMs .....	15
4.2	Lighting Upgrades.....	16
	ECM 1: Install LED Fixtures.....	16
	ECM 2: Retrofit Fixtures with LED Lamps.....	17
	ECM 3: Install LED Exit Signs.....	17
4.3	Lighting Control Measures .....	18
	ECM 4: Install Occupancy Sensor Lighting Controls .....	18
4.4	Gas-Fired Heating System Replacements.....	19
	ECM 5: Install High Efficiency Furnaces.....	19
4.5	Domestic Hot Water Heating System Upgrades .....	20
	ECM 6: Install Low-Flow DHW Devices.....	20

4.6	ECM Evaluated but Not Recommended .....	21
	Install High Efficiency Hot Water Boiler .....	21
<b>5</b>	<b>Energy Efficient Practices .....</b>	<b>22</b>
	Ensure Lighting Controls Are Operating Properly .....	22
	Perform Routine Motor Maintenance .....	22
	Practice Proper Use of Thermostat Schedules and Temperature Resets .....	22
	Clean Evaporator/Condenser Coils on AC Systems .....	22
	Clean and/or Replace HVAC Filters .....	22
	Perform Proper Furnace Maintenance .....	23
	Perform Proper Water Heater Maintenance .....	23
	Perform Maintenance on Compressed Air Systems .....	23
	Plug Load Controls.....	23
	Water Conservation .....	24
<b>6</b>	<b>On-Site Generation Measures .....</b>	<b>25</b>
6.1	Photovoltaic.....	26
6.2	Combined Heat and Power .....	27
<b>7</b>	<b>Demand Response .....</b>	<b>28</b>
<b>8</b>	<b>Project Funding / Incentives .....</b>	<b>29</b>
8.1	SmartStart .....	30
8.2	Direct Install .....	31
8.3	Energy Savings Improvement Program .....	32
<b>9</b>	<b>Energy Purchasing and Procurement Strategies .....</b>	<b>33</b>
9.1	Retail Electric Supply Options.....	33
9.2	Retail Natural Gas Supply Options .....	33

**Appendix A: Equipment Inventory & Recommendations**

**Appendix B: ENERGY STAR® Statement of Energy Performance**

# Table of Figures

---

Figure 1 – Previous 12 Month Utility Costs.....	2
Figure 2 – Potential Post-Implementation Costs .....	2
Figure 3 – Summary of Energy Reduction Opportunities .....	2
Figure 4 – Project Contacts .....	5
Figure 5 - Building Schedule.....	6
Figure 6: DPW Administration Building .....	6
Figure 7: Hot Water Boiler .....	7
Figure 8 - Utility Summary .....	10
Figure 9 - Energy Cost Breakdown .....	10
Figure 10 - Electric Usage & Demand.....	11
Figure 11 - Electric Usage & Demand.....	11
Figure 12 - Natural Gas Usage.....	12
Figure 13 - Natural Gas Usage.....	12
Figure 14 - Energy Use Intensity Comparison – Existing Conditions.....	13
Figure 15 - Energy Use Intensity Comparison – Following Installation of Recommended Measures .....	13
Figure 16 - Energy Balance (% and kBtu/SF) .....	14
Figure 17 – Summary of Recommended ECMs.....	15
Figure 18 – Summary of Lighting Upgrade ECMs.....	16
Figure 19 – Summary of Lighting Control ECMs .....	18
Figure 20 - Summary of Gas-Fired Heating Replacement ECMs.....	19
Figure 21 - Summary of Domestic Water Heating ECMs .....	20
Figure 22 – Summary of Measures Evaluated, But Not Recommended .....	21
Figure 23 - Photovoltaic Screening .....	26
Figure 24 - Combined Heat and Power Screening .....	27
Figure 25 - ECM Incentive Program Eligibility .....	29

# I EXECUTIVE SUMMARY

---

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for the Public Works Garage (DPW).

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

## I.1 Facility Summary

Public Works Garage (DPW) at the Town of Secaucus is an approximately 21,160 square foot facility originally built in 1965. The facility is comprised of various space types located in two buildings, the Administration and the Garage buildings. Interior lighting is provided predominantly by linear T8 fixtures and lamps with electronic ballasts which are mostly controlled with manual wall switches. Cooling is provided in the Administration Building by window unit air conditioners (AC) while the office spaces and locker rooms in the garage are cooled with one split AC and one packaged AC. The heating system consists of one small hot water boiler for the Administration Building, and gas fired furnaces and warm air unit heaters for the garage building.

A thorough description of the facility and our observations are located in Section 2.

## 1.2 Your Cost Reduction Opportunities

### Energy Conservation Measures

TRC evaluated seven measures. Six measures were recommended for implementation, which together represent an opportunity for DPW to reduce annual energy costs by roughly \$7,876 and annual greenhouse gas emissions by 76,940 lbs CO<sub>2</sub>e. We estimate that if all measures were implemented as recommended, the project would pay for itself in roughly 2.3 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce DPW's annual energy use by 25%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of DPW's existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)	
<b>Lighting Upgrades</b>												
ECM 1	Install LED Fixtures	Yes	18,466	3.0	0.0	0.0	\$2,689.26	\$6,378.80	\$1,400.00	\$4,978.80	1.9	18,595
ECM 2	Retrofit Fixtures with LED Lamps	Yes	13,300	3.5	0.0	0.0	\$1,936.90	\$6,866.07	\$1,265.00	\$5,601.07	2.9	13,393
ECM 3	Install LED Exit Signs	Yes	653	0.1	0.0	0.0	\$95.14	\$1,183.11	\$0.00	\$1,183.11	12.4	658
<b>Lighting Control Measures</b>												
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	1,664	0.5	0.0	0.0	\$242.34	\$928.00	\$140.00	\$788.00	3.3	1,676
<b>Gas Heating (HVAC/Process) Replacement</b>												
	Install High Efficiency Hot Water Boilers	No	0	0.0	16.7	16.7	\$134.00	\$3,757.44	\$1,000.00	\$2,757.44	20.6	1,961
ECM 5	Install High Efficiency Furnaces	Yes	0	0.0	360.5	360.5	\$2,884.36	\$6,185.45	\$400.00	\$5,785.45	2.0	42,207
<b>Domestic Water Heating Upgrade</b>												
ECM 6	Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	3.5	3.5	\$28.07	\$14.34	\$0.00	\$14.34	0.5	411
<b>TOTALS FOR ALL RECOMMENDED MEASURES</b>			<b>34,084</b>	<b>7</b>	<b>364</b>	<b>364</b>	<b>\$7,876.07</b>	<b>\$21,555.77</b>	<b>\$3,205.00</b>	<b>\$18,350.77</b>	<b>2.3</b>	<b>\$76,939.84</b>
<b>TOTALS FOR ALL MEASURES</b>			<b>34,084</b>	<b>7.1</b>	<b>380.7</b>	<b>380.7</b>	<b>\$8,010.08</b>	<b>\$25,313.21</b>	<b>\$4,205.00</b>	<b>\$21,108.21</b>	<b>2.6</b>	<b>78,901</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

**Lighting Upgrades** generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

**Lighting Controls** measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

**Gas Heating** (HVAC/Process) measures generally involve replacing older inefficient hydronic heating systems with modern energy efficient systems. Gas heating systems can provide equivalent heating compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel demands for heating, due to improved combustion and heat transfer efficiency.

**Domestic Hot Water** upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

### **Energy Efficient Practices**

TRC also identified 10 low cost or no cost energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at DPW include:

- Ensure Lighting Controls Are Operating Properly
- Perform Routine Motor Maintenance
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Perform Proper Furnace Maintenance
- Perform Proper Water Heater Maintenance
- Perform Maintenance on Compressed Air Systems
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

### **On-Site Generation Measures**

TRC evaluated the potential for installing on-site generation for DPW. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.



### I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 2 FACILITY INFORMATION AND EXISTING CONDITIONS

### 2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
<b>Customer</b>			
Amanda Nesheiwat	Environmental Director	<a href="mailto:anesheiwat@secaucus.net">anesheiwat@secaucus.net</a>	201-864-7336
<b>Designated Representative</b>			
Phil Taglieri	Maintenance Personnel	<a href="mailto:ptaglieri@secaucus.net">ptaglieri@secaucus.net</a>	201-864-7336
<b>TRC Energy Services</b>			
Moussa Traore	Auditor	<a href="mailto:mtraore@trcsolutions.com">mtraore@trcsolutions.com</a>	(732) 855-0033

### 2.2 General Site Information

On January 11, 2018, TRC performed an energy audit at DPW located in Secaucus, New Jersey. TRC met with Phil Taglieri to review the facility operations and help focus our investigation on specific energy-using systems.

Public Works Garage (DPW) at the Town of Secaucus is an approximately 21,160 square foot facility originally built in 1965. The facility is comprised of various space types located in two buildings. The Administration Building is constructed of brick masonry and primarily houses offices. The Garage Building is a metal structure that houses public works equipment related to sanitation, recycling, mechanics, parks, and public building services.

Interior lighting in both buildings is provided predominantly by linear T8 fixtures and lamps with electronic ballasts, mostly controlled with manual wall switches. Cooling is provided in the Administration Building by window AC units, while the office spaces and the locker rooms in the garage are cooled with one split system and one packaged AC. The heating system consists of hot one small hot water boiler for the Administration Building while gas fired furnaces and warm air unit heaters serve the Garage.



Image 1: Interior View - Garage Building

## 2.3 Building Occupancy

The entire facility is used year-round. During a typical day, the facility is occupied by approximately 70 people. The typical schedule is presented in the table below.

*Figure 5 - Building Schedule*

Building Name	Weekday/Weekend	Operating Schedule
DPW	Weekday	7:30 AM - 5:30 PM
DPW	Weekend	7:30 AM - 5:30 PM

## 2.4 Building Envelope



*Figure 6: DPW Administration Building*

The Administration Building has cast-in-place concrete perimeter wall footings with concrete foundation walls. It has a pitched roof covered with asphalt shingles. Exterior walls are finished with brick masonry. The windows are glass double paned with aluminum frames. They are in good condition. The Garage is a metal structure with a gable roof and a heavy grade steel frame for the exterior walls. Solar photovoltaic arrays are installed on the roof. The exterior doors are of the motorized movable type.



*Image 2: DPW Garage Building*

## 2.5 On-Site Generation

The DPW garage building has photovoltaic (PV) arrays installed on the roof. The PV arrays provide about 33% of the electricity required by the facility.

## 2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

### Lighting System

Interior lighting in both facilities is provided predominantly by linear T8 fixtures with electronic ballasts, as well as some incandescent, compact fluorescent lamps, and LEDs. Most of the Administration Building fixtures are 2-lamp or 3-lamp, 4-foot long troffers with diffusers. The Garage is illuminated with a combination of 2-lamp, 2-foot long LED tubes and 6-lamp, 4-foot long 32-Watt linear fluorescent lamps. The lunch room and the mechanic office lighting has been retrofitted to use 2-lamp, 2-foot long LED tubes. A small number of incandescent and compact fluorescent are found in spaces such as restrooms and some offices. Remaining spaces are lit with linear fluorescent lamps. Interior lighting control is provided by manual wall switches. Exit signs throughout both buildings use fluorescents sources. The exterior lighting system consists of wall mounted 250-Watt and 400-Watt metal halide lamps and one 400-Watt pole mounted lamps located near the Administration Building. They are controlled with photocells and timers.

### Hot Water Heating System



*Figure 7: Hot Water Boiler*

The hot water system consists of one small 96 MBh output non-condensing boiler serving the Administration Building. The boiler is 46 years old with an estimated combustion efficiency of 75%. It has passed its useful service life. Two small fractional motors (0.1 hp) each are used to distribute hot water to the hydronic baseboards. The boiler is in poor condition and should be evaluated for replacement with a more efficient condensing boiler.

## **Air Side Direct Expansion (DX) Cooling and Heating**

The DX system consists of five window ACs, one 1.5-ton split AC serving the Garage office, and one 7.5 ton packaged AC serving the Garage's lunch and locker rooms. The window ACs serve the Administration Building. They are rated at 0.83 ton and appear to be in good condition. The split and the Carrier packaged ACs are seven years old and are in good working condition. The units utilize a scroll compressor and a direct-expansion (DX) coil. The Carrier packaged AC also includes a gas fired furnace section that has 148 MBh output heating capacity.

Two Reznor gas fired furnaces each with 273 MBh output capacity each provide heating to the Garage locker rooms. They have a combustion efficiency of 78%. The units are 21 years old and have passed their respective useful life service. Heating is provided to the garage main areas by eight new 50 MBh gas fired suspended unit heaters. The split and packaged ACs are controlled with programmable thermostats.



*Image 3: Carrier Packaged AC*



*Image 4: Reznor Gas Fired Furnace*



## Domestic Hot Water Heating System



*Image 5: Gas Fired Water Heater*



*Image 6: Electric Water Heater*

The domestic hot water heating system consists of one gas fire non-condensing hot water heater with an input rating of 36 MBh serving r the Administration Building and one electric unit with an input rating of 4.5 kW for the Garage. The water heaters have a 40-gallon storage tank each. They are respectively 13 and 6 years old.

### Building Plug Load

There are approximately seven computer work stations throughout the facility and they are mostly desktop units with LCD monitors. There is no centralized PC power management software installed. There is no vending machine. Other plug loads equipment includes two copy machines, three refrigerators, water coolers and microwaves

## 2.7 Water-Using Systems

There are several restrooms at public works. A sampling of restrooms found that some of the faucets are rated for 2.2 gallons per minute (gpm) or higher, the toilets are rated at 2.5 gallons per flush (gpf) and the urinals are rated at 2 gpf.

### 3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

#### 3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

*Figure 8 - Utility Summary*

Utility Summary for DPW		
Fuel	Usage	Cost
Electricity	102,766 kWh	\$14,966
Natural Gas	16,048 Therms	\$12,841
<b>Total</b>		<b>\$27,807</b>

The current annual energy cost for this facility is \$27,807 as shown in the chart below.

*Figure 9 - Energy Cost Breakdown*



### 3.2 Electricity Usage

Electricity is mainly provided by PSE&G but supplemented by rooftop solar units. The average electric cost over the past 12 months was \$0.146/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 10 - Electric Usage & Demand




Figure 11 - Electric Usage & Demand

Electric Billing Data for DPW				
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Total Electric Cost
10/23/15	30	6,768	21	\$1,068
11/23/15	31	6,439	17	\$1,012
12/24/15	31	6,755	21	\$965
1/26/16	31	8,648	19	\$1,194
2/25/16	28	9,273	26	\$1,266
3/28/16	31	7,483	20	\$995
4/26/16	30	6,734	18	\$896
5/25/16	31	6,510	16	\$861
6/24/16	30	9,352	23	\$1,437
7/26/16	31	12,387	27	\$1,926
8/24/16	31	12,068	31	\$1,802
9/23/16	30	10,349	25	\$1,542
<b>Totals</b>	<b>365</b>	<b>102,766</b>	<b>31</b>	<b>\$14,966</b>
<b>Annual</b>	<b>365</b>	<b>102,766</b>	<b>31</b>	<b>\$14,966</b>



### 3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.800/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 12 - Natural Gas Usage




Figure 13 - Natural Gas Usage

Gas Billing Data for DPW			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
10/23/15	30	287	\$287
11/23/15	31	1,255	\$1,482
12/24/15	31	2,035	\$1,924
1/26/16	31	3,755	\$2,887
2/25/16	28	3,981	\$2,769
3/28/16	31	2,246	\$1,696
4/26/16	30	1,485	\$755
5/25/16	31	740	\$441
6/24/16	30	49	\$141
7/26/16	31	153	\$195
8/24/16	31	33	\$133
9/23/16	30	30	\$132
<b>Totals</b>	<b>365</b>	<b>16,048</b>	<b>\$12,841</b>
<b>Annual</b>	<b>365</b>	<b>16,048</b>	<b>\$12,841</b>

### 3.4 Benchmarking

This facility was benchmarked using Portfolio Manager®, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager® analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

**Figure 14 - Energy Use Intensity Comparison – Existing Conditions**

Energy Use Intensity Comparison - Existing Conditions		
	DPW	National Median Building Type: Garage
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	131.6	100.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	92.4	70.5

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

**Figure 15 - Energy Use Intensity Comparison – Following Installation of Recommended Measures**

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	DPW	National Median Building Type: Garage
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	96.3	100.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	69.7	70.5

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. This building is not eligible to receive a score because the property type falls under repair services type, which is currently not being rated by ENERGY STAR® score.

A Portfolio Manager® Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager® account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager® regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

### 3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

*Figure 16 - Energy Balance (% and kBtu/SF)*



## 4 ENERGY CONSERVATION MEASURES

### Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the DPW regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

### 4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

*Figure 17 – Summary of Recommended ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>32,420</b>	<b>6.6</b>	<b>0.0</b>	<b>\$4,721.30</b>	<b>\$14,427.98</b>	<b>\$2,665.00</b>	<b>\$11,762.98</b>	<b>2.5</b>	<b>32,646</b>
ECM 1	Install LED Fixtures	18,466	3.0	0.0	\$2,689.26	\$6,378.80	\$1,400.00	\$4,978.80	1.9	18,595
ECM 2	Retrofit Fixtures with LED Lamps	13,300	3.5	0.0	\$1,936.90	\$6,866.07	\$1,265.00	\$5,601.07	2.9	13,393
ECM 3	Install LED Exit Signs	653	0.1	0.0	\$95.14	\$1,183.11	\$0.00	\$1,183.11	12.4	658
<b>Lighting Control Measures</b>		<b>1,664</b>	<b>0.5</b>	<b>0.0</b>	<b>\$242.34</b>	<b>\$928.00</b>	<b>\$140.00</b>	<b>\$788.00</b>	<b>3.3</b>	<b>1,676</b>
ECM 4	Install Occupancy Sensor Lighting Controls	1,664	0.5	0.0	\$242.34	\$928.00	\$140.00	\$788.00	3.3	1,676
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>360.5</b>	<b>\$2,884.36</b>	<b>\$6,185.45</b>	<b>\$400.00</b>	<b>\$5,785.45</b>	<b>2.0</b>	<b>42,207</b>
ECM 5	Install High Efficiency Furnaces	0	0.0	360.5	\$2,884.36	\$6,185.45	\$400.00	\$5,785.45	2.0	42,207
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>3.5</b>	<b>\$28.07</b>	<b>\$14.34</b>	<b>\$0.00</b>	<b>\$14.34</b>	<b>0.5</b>	<b>411</b>
ECM 6	Install Low-Flow Domestic Hot Water Devices	0	0.0	3.5	\$28.07	\$14.34	\$0.00	\$14.34	0.5	411
<b>TOTALS</b>		<b>34,084</b>	<b>7.1</b>	<b>364.0</b>	<b>\$7,876.07</b>	<b>\$21,555.77</b>	<b>\$3,205.00</b>	<b>\$18,350.77</b>	<b>2.3</b>	<b>76,940</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

## 4.2 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 18 below.

*Figure 18 – Summary of Lighting Upgrade ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>32,420</b>	<b>6.6</b>	<b>0.0</b>	<b>\$4,721.30</b>	<b>\$14,427.98</b>	<b>\$2,665.00</b>	<b>\$11,762.98</b>	<b>2.5</b>	<b>32,646</b>
ECM 1	Install LED Fixtures	18,466	3.0	0.0	\$2,689.26	\$6,378.80	\$1,400.00	\$4,978.80	1.9	18,595
ECM 2	Retrofit Fixtures with LED Lamps	13,300	3.5	0.0	\$1,936.90	\$6,866.07	\$1,265.00	\$5,601.07	2.9	13,393
ECM 3	Install LED Exit Signs	653	0.1	0.0	\$95.14	\$1,183.11	\$0.00	\$1,183.11	12.4	658

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

### ECM 1: Install LED Fixtures

#### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	18,466	3.0	0.0	\$2,689.26	\$6,378.80	\$1,400.00	\$4,978.80	1.9	18,595

#### *Measure Description*

We recommend replacing existing fixtures containing 250-Watt and 400-Watt metal halide lamps with new high-performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of metal halide and other high intensity discharge (HID) lamps.

## ECM 2: Retrofit Fixtures with LED Lamps

### Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	13,300	3.5	0.0	\$1,936.90	\$6,866.07	\$1,265.00	\$5,601.07	2.9	13,393
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

### Measure Description

We recommend retrofitting existing linear fluorescent, incandescent and compact fluorescent with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tube and more than 10 times longer than many incandescent lamps.

## ECM 3: Install LED Exit Signs

### Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	653	0.1	0.0	\$95.14	\$1,183.11	\$0.00	\$1,183.11	12.4	658
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

### Measure Description

We recommend replacing all compact fluorescent EXIT signs with LED EXIT signs. LED EXIT signs require virtually no maintenance and have a life expectancy of at least 20 years. This measure saves energy by installing LED fixtures, which use less power than other technologies with an equivalent lighting output.

### 4.3 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 19 below.

*Figure 19 – Summary of Lighting Control ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>		1,664	0.5	0.0	\$242.34	\$928.00	\$140.00	\$788.00	3.3	1,676
ECM 4	Install Occupancy Sensor Lighting Controls	1,664	0.5	0.0	\$242.34	\$928.00	\$140.00	\$788.00	3.3	1,676

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

#### **ECM 4: Install Occupancy Sensor Lighting Controls**

##### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
1,664	0.5	0.0	\$242.34	\$928.00	\$140.00	\$788.00	3.3	1,676

##### *Measure Description*

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in restrooms, locker rooms, and offices. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

## 4.4 Gas-Fired Heating System Replacements

Our recommendations for gas-fired heating system replacements are summarized in Figure 20 below.

**Figure 20 - Summary of Gas-Fired Heating Replacement ECMs**

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>360.5</b>	<b>\$2,884.36</b>	<b>\$6,185.45</b>	<b>\$400.00</b>	<b>\$5,785.45</b>	<b>2.0</b>	<b>42,207</b>
ECM 5	Install High Efficiency Furnaces	0	0.0	360.5	\$2,884.36	\$6,185.45	\$400.00	\$5,785.45	2.0	42,207

### ECM 5: Install High Efficiency Furnaces

#### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
0	0.0	360.5	\$2,884.36	\$6,185.45	\$400.00	\$5,785.45	2.0	42,207

#### *Measure Description*

We recommend replacing two existing standard efficiency Reznor furnaces with condensing furnaces. Improved combustion technology and heat exchanger design optimize heat recovery from the combustion gases which can significantly improve furnace efficiency. Savings result from improved system efficiency.



## 4.5 Domestic Hot Water Heating System Upgrades

Our recommendations for domestic water heating system improvements are summarized in Figure 21 below.

*Figure 21 - Summary of Domestic Water Heating ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>3.5</b>	<b>\$28.07</b>	<b>\$14.34</b>	<b>\$0.00</b>	<b>\$14.34</b>	<b>0.5</b>	<b>411</b>
ECM 6	Install Low-Flow Domestic Hot Water Devices	0	0.0	3.5	\$28.07	\$14.34	\$0.00	\$14.34	0.5	411

### **ECM 6: Install Low-Flow DHW Devices**

#### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
0	0.0	3.5	\$28.07	\$14.34	\$0.00	\$14.34	0.5	411

#### *Measure Description*

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators can reduce hot water usage, relative to standard aerators, which saves energy. Low-flow devices reduce the overall water flow from the fixture, while still adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

## 4.6 ECM Evaluated but Not Recommended

The measure below has been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in the measure description section.

**Figure 22 – Summary of Measures Evaluated, But Not Recommended**

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Gas Heating (HVAC/Process) Replacement</b>	<b>0</b>	<b>0.0</b>	<b>16.7</b>	<b>\$134.00</b>	<b>\$3,757.44</b>	<b>\$1,000.00</b>	<b>\$2,757.44</b>	<b>20.6</b>	<b>1,961</b>
Install High Efficiency Hot Water Boilers	0	0.0	16.7	\$134.00	\$3,757.44	\$1,000.00	\$2,757.44	20.6	1,961
<b>TOTALS</b>	<b>0</b>	<b>0.0</b>	<b>16.7</b>	<b>\$134.00</b>	<b>\$3,757.44</b>	<b>\$1,000.00</b>	<b>\$2,757.44</b>	<b>20.6</b>	<b>1,961</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

### Install High Efficiency Hot Water Boiler

#### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
0	0.0	16.7	\$134.00	\$3,757.44	\$1,000.00	\$2,757.44	20.6	1,961

#### *Measure Description*

We evaluated replacing the older inefficient hot water boiler with a high efficiency hot water boiler. Significant improvements have been made in combustion technology resulting in increased overall boiler efficiency. Energy savings results from improved combustion efficiency and reduced standby losses at low loads.

The most notable efficiency improvement is condensing hydronic boilers that can achieve over 90% efficiency under the proper conditions. Condensing hydronic boilers typically operate at efficiencies between 85% and 87% (comparable to other high efficiency boilers) when the return water temperature is above 130°F. The boiler efficiency increases as the return water temperature drops below 130°F. Therefore, condensing hydronic boilers are typically recommended when the system return water temperature can be set to be less than 130°F during most of the operating hours.

#### *Reasons for not Recommending*

The simple payback of this measure exceeds the expected useful life of the equipment and is therefore not recommended on the basis of energy savings alone. However, as the unit has passed its useful service life service and appears to be in poor condition, it is likely in the best interest of the town to replace the boiler prior to a catastrophic failure.

Replacement of the boiler may also necessitate replacement of ancillary equipment, including pumping, piping, and controls. Such additional work may increase the overall cost significantly beyond the estimate provided. It is recommended to engage the services of a local heating system engineer to establish a basis of design for your optimal heating system.

## 5 ENERGY EFFICIENT PRACTICES

---

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

### **Ensure Lighting Controls Are Operating Properly**

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

### **Perform Routine Motor Maintenance**

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

### **Practice Proper Use of Thermostat Schedules and Temperature Resets**

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

### **Clean Evaporator/Condenser Coils on AC Systems**

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

### **Clean and/or Replace HVAC Filters**

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

## **Perform Proper Furnace Maintenance**

Preventative furnace maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should include tasks such as checking for gas / carbon monoxide leaks; changing the air and fuel filters; checking components for cracks, corrosion, dirt, or debris build-up; ensuring the ignition system is working properly; testing and adjusting operation and safety controls; inspecting the electrical connections; and ensuring proper lubrication for motors and bearings.

## **Perform Proper Water Heater Maintenance**

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

## **Perform Maintenance on Compressed Air Systems**

Like all electro-mechanical equipment, compressed air systems require periodic maintenance to operate at peak efficiency. A maintenance plan should be developed for process related compressed air systems to include inspection, cleaning, and replacement of inlet filter cartridges, cleaning of drain traps, daily inspection of lubricant levels to reduce unwanted friction, inspection of belt condition and tension, checking for system leaks and adjustment of loose connections, and overall system cleaning. Contact a qualified technician for help with setting up periodic maintenance schedule.

## **Plug Load Controls**

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

## **Water Conservation**

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gpf and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.5 for any low-flow ECM recommendations.

## 6 ON-SITE GENERATION MEASURES

---

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


## 6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a **Low** potential for installing an additional PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

**Figure 23 - Photovoltaic Screening**



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1)

## 6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility's ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a **Low** potential for installing a cost-effective CHP system.

Low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/).

**Figure 24 - Combined Heat and Power Screening**





## 7 DEMAND RESPONSE

---

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

**In TRC's opinion, this facility is not a good candidate for DR curtailment.**

## 8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 25 for a list of the eligible programs identified for each recommended ECM.

*Figure 25 - ECM Incentive Program Eligibility*

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	X		X			
ECM 2	Retrofit Fixtures with LED Lamps	X		X			
ECM 3	Install LED Exit Signs			X			
ECM 4	Install Occupancy Sensor Lighting Controls	X		X			
ECM 5	Install High Efficiency Furnaces	X		X			
ECM 6	Install Low-Flow Domestic Hot Water Devices			X			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 8.1 SmartStart

### Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

### **Equipment with Prescriptive Incentives Currently Available:**

*Electric Chillers*

*Electric Unitary HVAC*

*Gas Cooling*

*Gas Heating*

*Gas Water Heating*

*Ground Source Heat Pumps*

*Lighting*

*Lighting Controls*

*Refrigeration Doors*

*Refrigeration Controls*

*Refrigerator/Freezer Motors*

*Food Service Equipment*

*Variable Frequency Drives*

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

### Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

### How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB).

## 8.2 Direct Install

### Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for any recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

### Incentives

The program pays up to **70%** of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

### How to Participate

To participate in the Direct Install program you will need to contact the participating contractor who the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since Direct Install offers a free assessment of eligible measures, Direct Install is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: [www.njcleanenergy.com/DI](http://www.njcleanenergy.com/DI).

### 8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: [www.njcleanenergy.com/ESIP](http://www.njcleanenergy.com/ESIP).

*Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.*

## 9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third-party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

### 9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility is purchasing natural gas from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

# APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

## Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Exterior Pole Lighting	1	Metal Halide: (1) 400W Lamp	Daylight Dimming	458	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Daylight Dimming	145	4,380	0.25	1,549	0.0	\$225.61	\$1,300.00	\$100.00	5.32
DPW Office - Front Entrance	1	Compact Fluorescent: Screw in CFL	Wall Switch	23	2,600	Relamp	No	1	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	15	2,600	0.01	24	0.0	\$3.42	\$53.75	\$0.00	15.70
DPW Office	19	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	19	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.97	3,492	0.0	\$508.50	\$1,660.80	\$325.00	2.63
DPW Office	2	Compact Fluorescent: 4 PIN	Wall Switch	16	2,600	Relamp	No	2	LED Screw-In Lamps: LED 4 pin base	Wall Switch	11	2,600	0.01	29	0.0	\$4.28	\$88.10	\$0.00	20.59
Women's Restroom	2	Compact Fluorescent: 4 PIN	Wall Switch	16	2,600	Relamp	No	2	LED Screw-In Lamps: LED 4 pin base	Wall Switch	11	2,600	0.01	29	0.0	\$4.28	\$88.10	\$0.00	20.59
Basement	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	9	2,600	None	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	9	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Basement	7	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	None	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.05	179	0.0	\$26.06	\$116.00	\$20.00	3.68
Basement	2	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	119	0.0	\$17.30	\$215.11	\$0.00	12.43
Restroom	2	Compact Fluorescent: 4 PIN	Wall Switch	16	2,600	Relamp	No	2	LED Screw-In Lamps: LED 4 pin base	Wall Switch	11	2,600	0.01	29	0.0	\$4.28	\$88.10	\$0.00	20.59
Exterior Wall Pack Garage	6	Metal Halide: (1) 400W Lamp	Daylight Dimming	458	4,380	Fixture Replacement	No	6	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	145	4,380	1.53	9,295	0.0	\$1,353.64	\$2,344.06	\$600.00	1.29
Exterior Wall Pack Garage	7	Metal Halide: (1) 250W Lamp	Daylight Dimming	295	4,380	Fixture Replacement	No	7	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	75	4,380	1.25	7,622	0.0	\$1,110.01	\$2,734.74	\$700.00	1.83
Corridor Garage	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	4	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.09	341	0.0	\$49.63	\$252.80	\$0.00	5.09
Corridor Garage	1	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.00	59	0.0	\$8.65	\$107.56	\$0.00	12.43
Men's Restroom	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.25	919	0.0	\$133.81	\$492.00	\$95.00	2.97
Men's Locker Room	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.31	1,103	0.0	\$160.58	\$567.20	\$110.00	2.85
Women's Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.15	551	0.0	\$80.29	\$341.60	\$65.00	3.45
Lunch Room	5	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	None	No	5	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Electrical Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.04	145	0.0	\$21.18	\$75.20	\$15.00	2.84
Fire Sprinkler Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.04	145	0.0	\$21.18	\$75.20	\$15.00	2.84
Janitorial	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.04	145	0.0	\$21.18	\$75.20	\$15.00	2.84
Men's Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.15	551	0.0	\$80.29	\$341.60	\$65.00	3.45
Garage	22	Linear Fluorescent - T8: 4' T8 (32W) - 6L	Wall Switch	176	2,860	Relamp	No	22	LED - Linear Tubes: (6) 4' Lamps	Wall Switch	87	2,860	1.59	6,328	0.0	\$921.53	\$2,952.91	\$660.00	2.49
Garage	27	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,860	None	No	27	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,860	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	2	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	2,860	Relamp	No	2	LED - Linear Tubes: (2) 8' Lamps	Wall Switch	72	2,860	0.14	556	0.0	\$80.95	\$220.00	\$0.00	2.72
Garage	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	2,860	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	2,860	0.01	57	0.0	\$8.24	\$35.90	\$5.00	3.75

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Garage	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,860	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,860	0.03	107	0.0	\$15.53	\$58.50	\$10.00	3.12
Garage	3	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	178	0.0	\$25.95	\$322.67	\$0.00	12.43
Mechanic Office	1	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.00	59	0.0	\$8.65	\$107.56	\$0.00	12.43
Mechanic Office	7	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	None	Yes	7	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,820	0.03	105	0.0	\$15.27	\$116.00	\$0.00	7.59
Garage	1	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	22	2,860	Relamp	No	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	2,860	0.01	44	0.0	\$6.35	\$31.90	\$5.00	4.23
Restroom Garage	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.02	85	0.0	\$12.41	\$63.20	\$0.00	5.09
Garage	4	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	4	LED Exit Signs: 2 W Lamp	None	6	8,760	0.02	238	0.0	\$34.60	\$430.22	\$0.00	12.43

### Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement	Heating Hot Water	2	Heating Hot Water Pump	0.1	78.0%	No	910	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Basement	Sump Pump	2	Other	0.8	78.0%	No	728	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Rollup Doors	19	Other	0.5	78.0%	No	1,248	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Air Compressor	1	Air Compressor	3.0	82.0%	No	1,248	No	82.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Air Compressor	2	Air Compressor	7.5	86.0%	No	1,248	No	86.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Machine Tool	1	Other	0.8	78.0%	No	1,248	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Machine Tool	1	Other	2.3	82.0%	No	1,248	No	82.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Air Compressor	1	Air Compressor	5.0	81.5%	No	1,248	No	81.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00



### Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions									Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
DPW Office Reception Area	DPW Office Reception Area	1	Window AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Superintendent Office	Superintendent Office	1	Window AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Assistant Superintendent Office	Assistant Superintendent Office	1	Window AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Basement	Basement	2	Window AC	0.83		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rear Garage Building	Office Garage	1	Ductless Mini-Split HP	1.50	18.00	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rear Garage Building	DPW Garage	1	Packaged AC	7.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom	Restroom	1	Electric Resistance Heat		5.00	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions							Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
DPW Office	DPW Office	1	Non-Condensing Hot Water Boiler	96.00	Yes	1	Condensing Hot Water Boiler	96.00	93.00%	AFUE	0.00	0	16.7	\$134.00	\$3,757.44	\$1,000.00	20.58
Rear Garage Building	DPW Garage	1	Furnace	148.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rear Garage Building	DPW Garage	2	Furnace	273.00	Yes	1	Furnace	273.00	95.00%	AFUE	0.00	0	360.5	\$2,884.36	\$6,185.45	\$400.00	2.01
Garage	Garage	8	Warm Air Unit Heater	50.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis							
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Basement	DPW Office	1	Storage Tank Water Heater (≤ 50 Gal)	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
DPW Garage	DPW Garage	1	Storage Tank Water Heater (≤ 50 Gal)	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00


### Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis						
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
DPW Garage	2	Faucet Aerator (Lavatory)	2.20	1.00	0.00	0	3.5	\$28.07	\$14.34	\$0.00	0.51

### Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Offices	7	Desktop with LCD Monitors	191.0	Yes
Offices	2	Copy machine	800.0	Yes
Offices	4	Printer	56.0	Yes
Offices	2	Water Cooler	272.0	Yes
Offices	2	Microwave	1,000.0	No
Offices	1	Toaster	850.0	No
Offices	1	Coffee Machine	850.0	No
Offices	3	Refrigerator	175.0	Yes
Offices	2	TV	224.0	Yes

# APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE



LEARN MORE AT [energystar.gov](http://energystar.gov)

## ENERGY STAR® Statement of Energy Performance

# N/A

### Town of Secaucus - DPW Garage

Primary Property Type: Repair Services (Vehicle, Shoe, Locksmith, etc.)  
 Gross Floor Area (ft<sup>2</sup>): 21,160  
 Built: 1965

ENERGY STAR®  
Score<sup>1</sup>

For Year Ending: August 31, 2016  
 Date Generated: February 23, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

#### Property & Contact Information

Property Address	Property Owner	Primary Contact
Town of Secaucus - DPW Garage 370 Secaucus Road Secaucus, New Jersey 07094	Town of Secaucus 1203 Paterson Plank Rd Secaucus, NJ 07094 201-864-7336	Amanda Nesheiwat 1203 Paterson Plank Rd Secaucus, NJ 07094 201-864-7336 anesheiwat@secaucus.net

Property ID: 6207315

#### Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
92.4 kBtu/ft <sup>2</sup>	Natural Gas (kBtu) 1,605,637 (82%)	National Median Site EUI (kBtu/ft <sup>2</sup> ) 70.5
	Electric - Solar (kBtu) 113,001 (6%)	National Median Source EUI (kBtu/ft <sup>2</sup> ) 100.4
	Electric - Grid (kBtu) 238,818 (12%)	% Diff from National Median Source EUI 31%
Source EUI	Annual Emissions	
131.6 kBtu/ft <sup>2</sup>	Greenhouse Gas Emissions (Metric Tons CO <sub>2</sub> e/year) 124	

#### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Licensed Professional

\_\_\_\_\_  
 ( ) \_\_\_\_\_



Professional Engineer Stamp  
(if applicable)