



Local Government Energy Audit: Energy Audit Report



Copyright ©2017 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Warner Student Life Center

Brookdale Community College

765 Newman Springs Road

Lincroft, NJ 07738

March 27, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	6
2.1	Project Contacts	6
2.2	General Site Information.....	6
2.3	Building Occupancy	6
2.4	Building Envelope	6
2.5	On-Site Generation.....	7
2.6	Energy-Using Systems	7
	Lighting System	7
	Chilled Water or Condenser Water System	7
	Hot Water Heating System.....	8
	Domestic Hot Water Heating System.....	8
	Food Service & Refrigeration	8
	Building Plug Load	9
2.7	Water-Using Systems	9
3	Site Energy Use and Costs.....	10
3.1	Total Cost of Energy	10
3.2	Electricity Usage	11
3.3	Natural Gas Usage	12
3.4	Benchmarking.....	13
3.5	Energy End-Use Breakdown	14
4	Energy Conservation Measures	15
4.1	Recommended ECMs	15
4.1.1	Lighting Upgrades.....	16
	ECM 1: Retrofit Fixtures with LED Lamps.....	16
	ECM 2: Install LED Exit Signs.....	17
4.1.2	Lighting Control Measures	17
	ECM 3: Install Occupancy Sensor Lighting Controls	17
4.1.3	Variable Frequency Drive Measures	18
	ECM 4: Install VFDs on Hot Water Pumps.....	18
4.1.4	Domestic Hot Water Heating System Upgrades	19
	ECM 5: Install Low-Flow DHW Devices.....	19

4.1.5	Plug Load Equipment Control - Vending Machines.....	20
	ECM 6: Vending Machine Control	20
5	Energy Efficient Practices	21
	Reduce Air Leakage	21
	Close Doors and Windows	21
	Use Window Treatments/Coverings	21
	Perform Proper Lighting Maintenance.....	21
	Develop a Lighting Maintenance Schedule	21
	Practice Proper Use of Thermostat Schedules and Temperature Resets	22
	Perform Proper Water Heater Maintenance	22
	Water Conservation	22
6	On-Site Generation Measures	23
6.1	Photovoltaic.....	23
6.2	Combined Heat and Power	24
7	Demand Response	26
8	Project Funding / Incentives	27
8.1	SmartStart	28
8.2	Pay for Performance - Existing Buildings.....	29
8.3	SREC Registration Program.....	29
8.4	Energy Savings Improvement Program	30
9	Energy Purchasing and Procurement Strategies	31
9.1	Retail Electric Supply Options.....	31
9.2	Retail Natural Gas Supply Options	31

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs.....	2
Figure 2 – Potential Post-Implementation Costs	2
Figure 3 – Summary of Energy Reduction Opportunities	2
Figure 4 – Project Contacts	6
Figure 5 - Building Schedule.....	6
Figure 6 - Utility Summary	10
Figure 7 - Energy Cost Breakdown	10
Figure 8 - Electric Usage & Demand.....	11
Figure 9 - Electric Usage & Demand.....	11
Figure 10 - Natural Gas Usage.....	12
Figure 11 - Natural Gas Usage.....	12
Figure 12 - Energy Use Intensity Comparison – Existing Conditions.....	13
Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures	13
Figure 14 - Energy Balance (kBtu/SF, %)	14
Figure 15 – Summary of Recommended ECMs.....	15
Figure 16 – Summary of Lighting Upgrade ECMs.....	16
Figure 17 – Summary of Lighting Control ECMs	17
Figure 18 – Summary of Variable Frequency Drive ECMs	18
Figure 19 - Summary of Domestic Water Heating ECMs	19
Figure 20 - Photovoltaic Screening	23
Figure 21 - ECM Incentive Program Eligibility	27

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Warner Student Life Center.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey higher education in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Warner Student Life Center is a two story, 71,244 square foot facility comprised of various space types within a single building. The building includes hallways, offices, locker rooms, classrooms, storage rooms, cafeteria, book stores, lounge, restrooms and a mechanical space.

Lighting at Warner Student Life Center consists of aging and inefficient fluorescent fixtures. The building is conditioned by numerous air handling units (AHU) with variable frequency drives on the supply fans. The AHU receives chilled water and hot water from the campus central utility plant. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated six measures which together represent an opportunity for Warner Student Life Center to reduce annual energy costs by \$14,684 and annual greenhouse gas emissions by 131,680 lbs CO₂e. We estimate that if all measures are implemented as recommended, the project will pay for itself in 5.1 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce the Warner Student Life Center's annual energy use by 8%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Warner Student Life Center’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			107,049	23.8	0.0	\$12,024.27	\$62,962.01	\$3,950.00	\$59,012.01	4.9	107,797
ECM 1	Retrofit Fixtures with LED Lamps	Yes	92,905	22.8	0.0	\$10,435.56	\$59,090.03	\$3,950.00	\$55,140.03	5.3	93,554
ECM 2	Install LED Exit Signs	Yes	14,144	1.0	0.0	\$1,588.72	\$3,871.98	\$0.00	\$3,871.98	2.4	14,243
Lighting Control Measures			7,334	2.0	0.0	\$823.75	\$3,864.00	\$580.00	\$3,284.00	4.0	7,385
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	7,334	2.0	0.0	\$823.75	\$3,864.00	\$580.00	\$3,284.00	4.0	7,385
Variable Frequency Drive (VFD) Measures			14,465	1.8	0.0	\$1,624.83	\$12,009.41	\$0.00	\$12,009.41	7.4	14,567
ECM 4	Install VFDs on Hot Water Pumps	Yes	14,465	1.8	0.0	\$1,624.83	\$12,009.41	\$0.00	\$12,009.41	7.4	14,567
Domestic Water Heating Upgrade			0	0.0	2.6	\$30.22	\$43.02	\$0.00	\$43.02	1.4	308
ECM 5	Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	2.6	\$30.22	\$43.02	\$0.00	\$43.02	1.4	308
Plug Load Equipment Control - Vending Machine			1,612	0.0	0.0	\$181.05	\$230.00	\$0.00	\$230.00	1.3	1,623
ECM 6	Vending Machine Control	Yes	1,612	0.0	0.0	\$181.05	\$230.00	\$0.00	\$230.00	1.3	1,623
TOTALS			130,460	27.7	2.6	\$14,684.13	\$79,108.44	\$4,530.00	\$74,578.44	5.1	131,680

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measure save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Variable Frequency Drives (VFDs) are motor control devices. These measures control the speed of a motor so that the motor spins at peak efficiency during partial load conditions. Sensors adapt the speed to flow, temperature, or pressure settings which is much more efficient than using a valve or damper to control flow rates, or running the motor at full speed when only partial power is needed. These measures save energy by controlling motor usage more efficiently.

Domestic Hot Water upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

Plug Load Equipment control measures generally involve installing automated devices that limit the power usage or operation of equipment that is plugged into an electric outlets when not in use.

Energy Efficient Practices

TRC also identified eight low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Warner Student Life Center include:

- Reduce Air Leakage
- Close Doors and Windows
- Use Window Treatments/Coverings
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Perform Proper Water Heater Maintenance
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-Site generation for Warner Student Life Center. Based on the configuration of the site and its loads there is a high potential for installing a photovoltaic (PV) array. For details on our evaluation and on-site generation potential, please refer to Section 6.

I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Pay for Performance - Existing Building (P4P)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SS incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

Larger facilities with an interest in a more comprehensive whole building approach to energy conservation should consider participating in the Pay for Performance (P4P) program. Projects eligible for this project program must meet minimum savings requirements. Final incentives are calculated based on actual measured performance achieved at the end of the project. The application process is more involved, and it requires working with a qualified P4P contractor, but the process may result in greater energy savings overall and more lucrative incentives, up to 50% of project's total cost.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.4 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8 or:
www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Timothy Drury	Director of Facilities Management and Construction	tdrury@brookdalecc.edu	(732) 224-2217
TRC Energy Services			
Smruti Srinivasan	Auditor	ssrinivasan@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On December 8, 2016, TRC performed an energy audit at Warner Student Life Center located in Lincroft, New Jersey. TRC’s team met with Anne to review the facility operations and help focus our investigation on specific energy-using systems.

Warner Student Life Center is a two (2) story, 71,244 square foot facility comprised of various space types within a single building. The building includes hallways, offices, locker rooms, classrooms, storage rooms, cafeteria, book stores, lounge, restrooms and a mechanical space. The building was constructed in 1974.

2.3 Building Occupancy

The typical schedule is presented in the table below. The building is open Monday through Saturday and remains closed on Sunday. On a typical day the building is occupied by approximately 275 including full time staff and a varying amount of students.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Student Life Center	Weekday	7:30 AM - 10:00 PM
Student Life Center	Weekend	Saturday: 7:30 AM - 5:00 PM Sunday: No operation

2.4 Building Envelope

The building has a poured concrete and concrete block construction with brick, stone and stucco (over Styrofoam) facades. The building interior (dividing walls) are made of sheet rock over metal studs. The building has flat and pitched roofs. The flat roof section has EPDM membrane and the pitched portion has seam metal paneling. The windows in the building are double pane with fiber glass insulation and aluminum frames. The exterior doors are constructed of aluminum and in good condition.



2.5 On-Site Generation

Warner Student Life Center does not have any on-site electric generation systems currently installed.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Interior lighting is provided mostly by with linear fluorescent fixtures 32-Watt, 4-foot T8 lamps. The fixtures typically have two or three lamps. There are also fluorescent fixtures with T8 U lamps and electronic ballasts as well as some compact fluorescent lamps (CFL).

Lighting control in most spaces is provided by manual switches. The CFL fixtures at the entrance are controlled by occupancy sensors. The building's exterior lighting consists primarily of wall mount compact fluorescent fixtures with 2-bulbs each (42-Watt each). These are controlled using timers.



Chilled Water or Condenser Water System

The building is served by the campus's central chilled water plant. The central chilled water plant is comprised of three 740 ton water cooled centrifugal chillers. The chillers are included in this report to facilitate the development of an energy balance for the Warner Student Life Center. See the Central Utility Plant report for a full description of the chilled water system.

The six air handling units (AHU) on the roof and in the mechanical space of the building have chilled water coils. All of the AHU supply fans have variable frequency drives (VFD) to control the fan speed.

Hot Water Heating System

The building is served by the campus's central hot water plant. The central hot water plant is comprised of eight 2,850 MBh condensing hot water boilers. The boilers are included in this report to facilitate the development of an energy balance for the Warner Student Life Center. See the Central Utility Plant report for a full description of the hot water system.

The six AHUs have hot water coils. The heated water from the central plant boilers is supplied to these AHUs using two 5 hp and two 2 hp pumps. These are constant speed motors. There is one variable speed, 15 hp pump that distributes heating water to the baseboard radiators.

Domestic Hot Water Heating System

The domestic water heating system for the facility consists of two Lochinvar gas fired water heaters with an input capacity of 399 MBh. There is also a 125 gallon storage tank. This system is about three years old and has an efficiency of 95%. This equipment is in very good condition and well maintained.



Food Service & Refrigeration

The student center has gas fired kitchen equipment. The kitchen has five (5) gas burners/stove sets (six burners each), three gas griddles and two gas convection ovens from Vulcan. There is one single tank conveyor commercial dishwasher with a gas fired booster. This equipment appeared to be in good condition.

The refrigeration system consists of two walk in refrigerators and four reach-in glass door refrigerators. There are two self-contained ice machines.

Building Plug Load

There are 62 computer work stations throughout the facility. Other plug loads in the facility include printers, copy machines, televisions (LCD &LED) projectors, kitchenette equipment consisting of refrigerators, microwaves, and coffee machines. There is no centralized PC power management software installed.

2.7 Water-Using Systems

A sampling of restrooms found that the faucets are rated for 2.2 gallons per minute (gpm) or higher, the toilets are rated at 2.5 gallons per flush (gpf) and the urinals are rated at 2 (gpf).

3 SITE ENERGY USE AND COSTS

Nearly the entire campus receives electricity through a master electric meter. A large portion of the campus receives natural gas through a master gas meter. The main meters were prorated for individual buildings based on building size and function. It should be noted that the energy used by the central utility plant is included in the proration to this building.

Prorated utility data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. . These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Warner Student Life Center		
Fuel	Usage	Cost
Electricity	800,171 kWh	\$89,879
Natural Gas	31,661 Therms	\$36,359
Total		\$126,238

The current annual energy cost for this facility is \$126,238 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by JCP&L. The average electric cost over the past 12 months was \$0.112/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The prorated monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Warner Student Life Center						
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost	TRC Estimated Usage?
4/13/15	30	52,364			\$5,882	Yes
5/12/15	29	61,479			\$6,906	Yes
6/11/15	30	65,551			\$7,363	Yes
7/13/15	32	76,150			\$8,554	Yes
8/12/15	30	78,228			\$8,787	Yes
9/11/15	30	74,671			\$8,387	Yes
10/13/15	32	65,297			\$7,334	Yes
11/12/15	30	66,983			\$7,524	Yes
12/14/15	32	66,123			\$7,427	Yes
1/13/16	30	56,382			\$6,333	Yes
2/11/16	29	66,087			\$7,423	Yes
3/11/16	29	66,471			\$7,466	Yes
Totals	363	795,787	0	\$0	\$89,387	12
Annual	365	800,171	0	\$0	\$89,879	

3.3 Natural Gas Usage

Natural Gas is provided by New Jersey Natural Gas. The average gas cost for the past 12 months is \$1.148/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for Warner Student Life Center				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
4/1/15	30	3,994	\$4,586	Yes
5/1/15	30	2,913	\$3,345	Yes
6/1/15	31	1,963	\$2,254	Yes
7/1/15	30	1,436	\$1,650	Yes
8/1/15	31	1,468	\$1,686	Yes
9/1/15	31	1,590	\$1,826	Yes
10/1/15	30	2,403	\$2,759	Yes
11/1/15	31	2,628	\$3,018	Yes
12/1/15	30	2,707	\$3,108	Yes
1/1/16	31	2,551	\$2,930	Yes
2/1/16	31	3,895	\$4,473	Yes
3/1/16	29	4,114	\$4,724	Yes
Totals	365	31,661	\$36,359	12
Annual	365	31,661	\$36,359	

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR Score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Warner Student Life Center	National Median Building Type: Center/Meeting Hall
Source Energy Use Intensity (kBtu/ft ²)	167.0	69.8
Site Energy Use Intensity (kBtu/ft ²)	82.8	45.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Warner Student Life Center	National Median Building Type: Center/Meeting Hall
Source Energy Use Intensity (kBtu/ft ²)	147.3	69.8
Site Energy Use Intensity (kBtu/ft ²)	76.5	45.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. As the electric and gas accounts were shared between various buildings, it was not possible to benchmark these buildings and provide a score individually. We have generated a campus wide Portfolio Manager Statement of Energy Performance (SEP) which is attached in Appendix B: ENERGY STAR® Statement of Energy Performance.

For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>


A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. The central utility plant chillers and boilers are included in the analysis but the operating hours were scaled to be consistent with the prorated historical energy use.

This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (kBtu/SF, %)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Warner Student Life Center regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		107,049	23.8	0.0	\$12,024.27	\$62,962.01	\$3,950.00	\$59,012.01	4.9	107,797
ECM 1	Retrofit Fixtures with LED Lamps	92,905	22.8	0.0	\$10,435.56	\$59,090.03	\$3,950.00	\$55,140.03	5.3	93,554
ECM 2	Install LED Exit Signs	14,144	1.0	0.0	\$1,588.72	\$3,871.98	\$0.00	\$3,871.98	2.4	14,243
Lighting Control Measures		7,334	2.0	0.0	\$823.75	\$3,864.00	\$580.00	\$3,284.00	4.0	7,385
ECM 3	Install Occupancy Sensor Lighting Controls	7,334	2.0	0.0	\$823.75	\$3,864.00	\$580.00	\$3,284.00	4.0	7,385
Variable Frequency Drive (VFD) Measures		14,465	1.8	0.0	\$1,624.83	\$12,009.41	\$0.00	\$12,009.41	7.4	14,567
ECM 4	Install VFDs on Hot Water Pumps	14,465	1.8	0.0	\$1,624.83	\$12,009.41	\$0.00	\$12,009.41	7.4	14,567
Domestic Water Heating Upgrade		0	0.0	2.6	\$30.22	\$43.02	\$0.00	\$43.02	1.4	308
ECM 5	Install Low-Flow Domestic Hot Water Devices	0	0.0	2.6	\$30.22	\$43.02	\$0.00	\$43.02	1.4	308
Plug Load Equipment Control - Vending Machine		1,612	0.0	0.0	\$181.05	\$230.00	\$0.00	\$230.00	1.3	1,623
ECM 6	Vending Machine Control	1,612	0.0	0.0	\$181.05	\$230.00	\$0.00	\$230.00	1.3	1,623
TOTALS		130,460	27.7	2.6	\$14,684.13	\$79,108.44	\$4,530.00	\$74,578.44	5.1	131,680

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Recommended upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		107,049	23.8	0.0	\$12,024.27	\$62,962.01	\$3,950.00	\$59,012.01	4.9	107,797
ECM 1	Retrofit Fixtures with LED Lamps	92,905	22.8	0.0	\$10,435.56	\$59,090.03	\$3,950.00	\$55,140.03	5.3	93,554
ECM 2	Install LED Exit Signs	14,144	1.0	0.0	\$1,588.72	\$3,871.98	\$0.00	\$3,871.98	2.4	14,243

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	89,580	22.3	0.0	\$10,062.14	\$58,552.50	\$3,950.00	\$54,602.50	5.4	90,207
Exterior	3,324	0.5	0.0	\$373.42	\$537.53	\$0.00	\$537.53	1.4	3,348

Measure Description

We recommend retrofitting existing 4-foot linear T8, U-bent T8 fixtures, and CFL fixtures with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tube and more than 10 times longer than many incandescent lamps.

ECM 2: Install LED Exit Signs

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	14,144	1.0	0.0	\$1,588.72	\$3,871.98	\$0.00	\$3,871.98	2.4	14,243
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend replacing all incandescent exit signs with LED exit signs. LED exit signs require virtually no maintenance and have a life expectancy of at least 20 years. This measure saves energy by installing LED fixtures, which use less power than other technologies with an equivalent lighting output.

4.1.2 Lighting Control Measures

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		7,334	2.0	0.0	\$823.75	\$3,864.00	\$580.00	\$3,284.00	4.0	7,385
ECM 3	Install Occupancy Sensor Lighting Controls	7,334	2.0	0.0	\$823.75	\$3,864.00	\$580.00	\$3,284.00	4.0	7,385

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 3: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
7,334	2.0	0.0	\$823.75	\$3,864.00	\$580.00	\$3,284.00	4.0	7,385

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in all restrooms, storage rooms, classrooms and offices areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern

occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.1.3 Variable Frequency Drive Measures

Our recommendations for variable frequency drive (VFD) measures are summarized in Figure 18 below.

Figure 18 – Summary of Variable Frequency Drive ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		14,465	1.8	0.0	\$1,624.83	\$12,009.41	\$0.00	\$12,009.41	7.4	14,567
ECM 4	Install VFDs on Hot Water Pumps	14,465	1.8	0.0	\$1,624.83	\$12,009.41	\$0.00	\$12,009.41	7.4	14,567

ECM 4: Install VFDs on Hot Water Pumps

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
14,465	1.8	0.0	\$1,624.83	\$12,009.41	\$0.00	\$12,009.41	7.4	14,567

Measure Description

We recommend installing variable frequency drives (VFD) to control the 2 hp and 4 hp hot water pumps. This measure requires that a majority of the hot water coils be served by 2-way valves and that a differential pressure sensor is installed in the hot water loop. As the hot water valves close, the differential pressure increases. The VFD modulates pump speed to maintain a differential pressure setpoint. Energy savings results from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

4.1.4 Domestic Hot Water Heating System Upgrades

Our recommendations for domestic water heating system improvements are summarized in Figure 19 below.

Figure 19 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		0	0.0	2.6	\$30.22	\$43.02	\$0.00	\$43.02	1.4	308
ECM 5	Install Low-Flow Domestic Hot Water Devices	0	0.0	2.6	\$30.22	\$43.02	\$0.00	\$43.02	1.4	308

ECM 5: Install Low-Flow DHW Devices

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
0	0.0	2.6	\$30.22	\$43.02	\$0.00	\$43.02	1.4	308

Measure Description

We recommend installing low-flow domestic hot water devices on the kitchen faucets to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators can reduce hot water usage, relative to standard aerators, which saves energy. Pre-rinse spray valves (PRSVs)—often used in commercial and institutional kitchens—are designed to remove food waste from dishes prior to dishwashing. Replacing standard pre-rinse spray valves with low flow PRSVs will reduce hot water usage and save energy.

Low-flow devices reduce the overall water flow from the fixture, while still adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

4.1.5 Plug Load Equipment Control - Vending Machines

ECM 6: Vending Machine Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,612	0.0	0.0	\$181.05	\$230.00	\$0.00	\$230.00	1.3	1,623

Measure Description

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor controls to the vending machine placed in the kitchen to reduce the energy use. These controls power down vending machines when the vending machine area has been vacant for some time, then power up at regular intervals, as needed, to turn machine lights on or keep the product cool. Energy savings are a dependent on vending machine and activity level in the area surrounding the machines.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Use Window Treatments/Coverings

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.4 for any low-flow ECM recommendations.

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.


Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a High potential for installing a PV array. The amount of free area, ease of installation (location), and the lack of shading elements contribute to the high potential for PV at the site. A PV array located on the roof of the main building/ground next to the building/over the main parking lot may be feasible. If Warner Student Life Center is interested in pursuing the installation of PV, we recommended a full feasibility study be conducted.

Figure 20 - Photovoltaic Screening





Potential	High	
System Potential	129	kW DC STC
Electric Generation	153,687	kWh/yr
Displaced Cost	\$13,370	/yr
Installed Cost	\$335,400	

Solar projects must register their projects in the SREC Registration Program prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey’s solar marketplace provides market participants with information about developed new solar projects and insight into future SREC pricing. Refer to Section 8.3 for additional information.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.

CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility’s ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a Low potential for installing a cost-effective CHP system.

Lack of gas service, low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion this building is not a good candidate for DR.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 21 for a list of the eligible programs identified for each recommended ECM.

Figure 21 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Retrofit Fixtures with LED Lamps	x			x		
ECM 2	Install LED Exit Signs				x		
ECM 3	Install Occupancy Sensor Lighting Controls	x			x		
ECM 4	Install VFDs on Hot Water Pumps		x		x		
ECM 5	Install Low-Flow Domestic Hot Water Devices				x		
ECM 6	Vending Machine Control				x		

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Pay for Performance - Existing Buildings

Overview

The Pay for Performance – Existing Buildings (P4P EB) program is designed for larger customers with a peak demand over 200 kW in any of the preceding 12 months. Under this program the minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings. P4P is a generally a good option for medium to large sized facilities looking to implement as many measures as possible under a single project in order to achieve deep energy savings. This program has an added benefit of evaluating a broad spectrum of measures that may not otherwise qualify under other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also utilize the P4P program.

Incentives

Incentives are calculated based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50% total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

How to Participate

To participate in the P4B EB program you will need to contact one of the pre-approved consultants and contractors (“Partners”). Under direct contract to you, the Partner will help further evaluate the measures identified in this report through development of the Energy Reduction Plan (ERP), assist you in implementing selected measures, and verify actual savings one year after the installation. At each of these three milestones your Partner will also facilitate securing program incentives.

Approval of the final scope of work is required by the program prior to installation completion. Although installation can be accomplished by a contractor of your choice (some P4P Partners are also contractors) or by internal personnel, the Partner must remain involved to ensure compliance with the program guidelines and requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: www.njcleanenergy.com/P4P.

8.3 SREC Registration Program

The SREC Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SRP prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey’s solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number which enables it to generate New Jersey SRECs. SREC’s are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SREC’s to be placed in the customer’s electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project’s life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar RPS. One way they can meet the RPS requirements is by purchasing SRECs. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period can and will fluctuate depending on supply and demand.

Information about the SRP can be found at: www.njcleanenergy.com/srec.

8.4 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Entrance	5	Compact Fluorescent: Recessed fixture - 2 bulbs	Occupancy Sensor	72	4,380	Relamp	No	5	LED Screw-In Lamps: Recessed fixture	Occupancy Sensor	22	4,380	0.18	1,259	0.0	\$141.45	\$488.53	\$0.00	3.45
Admin Office C112	13	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	Yes	13	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	2,985	0.37	2,480	0.0	\$278.54	\$937.60	\$20.00	3.29
SLC 113	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,985	0.03	204	0.0	\$22.97	\$174.50	\$10.00	7.16
SLC 114 - Massage Therapy	1	Compact Fluorescent: Recessed fixture - 2 bulbs	Wall Switch	72	1,248	Relamp	No	1	LED Screw-In Lamps: Recessed fixture	Wall Switch	22	1,248	0.04	72	0.0	\$8.06	\$97.71	\$0.00	12.12
SLC 114 - Massage Therapy	14	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,248	Relamp	No	14	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,248	0.51	995	0.0	\$111.72	\$1,052.80	\$210.00	7.54
SLC 114 - Massage Therapy	7	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	7	LED Exit Signs: 2 W Lamp	None	6	8,760	0.20	2,750	0.0	\$308.92	\$752.89	\$0.00	2.44
SLC 114A Storage	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	208	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	208	0.02	8	0.0	\$0.89	\$58.50	\$10.00	54.70
Hallway	10	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	10	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	4,264	0.21	1,422	0.0	\$159.73	\$632.00	\$0.00	3.96
Women Restroom	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	728	Relamp	Yes	4	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	510	0.11	130	0.0	\$14.63	\$522.80	\$35.00	33.34
Men Restroom	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	728	Relamp	Yes	4	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	510	0.11	130	0.0	\$14.63	\$522.80	\$35.00	33.34
Hallway	15	Compact Fluorescent: Ceiling Mount - 1 bulb	Wall Switch	42	4,264	Relamp	No	15	LED Screw-In Lamps: Ceiling Mount fixture	Wall Switch	9	4,264	0.36	2,427	0.0	\$272.65	\$806.30	\$0.00	2.96
Elevator Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	104	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	104	0.02	4	0.0	\$0.44	\$58.50	\$10.00	109.40
Hallway	14	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	14	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	4,264	0.30	1,991	0.0	\$223.62	\$884.80	\$0.00	3.96
Custodial closet	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	52	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	52	0.10	8	0.0	\$0.89	\$234.00	\$40.00	218.80
Custodial Hallway	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,264	0.05	324	0.0	\$36.35	\$117.00	\$20.00	2.67
SLC 120	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	4	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.09	347	0.0	\$38.96	\$252.80	\$0.00	6.49
SLC 120	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.02	99	0.0	\$11.08	\$58.50	\$10.00	4.38
Fire door	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	52	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	52	0.02	2	0.0	\$0.22	\$58.50	\$10.00	218.80
Loading Dock	1	Compact Fluorescent: Wall mount fixture - 1 bulb	Wall Switch	42	4,264	Relamp	No	1	LED Screw-In Lamps: Wall mount fixture	Wall Switch	9	4,264	0.02	162	0.0	\$18.18	\$53.75	\$0.00	2.96
SLC 123	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	208	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	146	0.09	30	0.0	\$3.36	\$291.50	\$50.00	71.85
Stock Room	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	520	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	520	0.07	59	0.0	\$6.65	\$175.50	\$30.00	21.88
SLC 118	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.43	1,739	0.0	\$195.33	\$584.00	\$100.00	2.48
Hallway	7	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	7	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	4,264	0.15	995	0.0	\$111.81	\$442.40	\$0.00	3.96
SLC 124	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.15	623	0.0	\$70.03	\$408.50	\$70.00	4.83
Server room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	104	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	104	0.05	8	0.0	\$0.89	\$117.00	\$20.00	109.40

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Pump room	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	104	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	104	0.24	39	0.0	\$4.43	\$585.00	\$100.00	109.40
Women Locker Room	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	500	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	350	0.09	72	0.0	\$8.08	\$291.50	\$50.00	29.89
Men Locker Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	500	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	350	0.06	48	0.0	\$5.39	\$233.00	\$20.00	39.54
Hallway	8	Compact Fluorescent: Wall mount fixture - 2 bulb	Wall Switch	42	4,264	Relamp	No	8	LED Screw-In Lamps: Wall mount fixture	Wall Switch	18	4,264	0.14	941	0.0	\$105.75	\$860.05	\$0.00	8.13
Hallway	1	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.03	393	0.0	\$44.13	\$107.56	\$0.00	2.44
SLC 102	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.28	1,122	0.0	\$126.05	\$567.20	\$110.00	3.63
SLC 104	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	8	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.37	1,496	0.0	\$168.06	\$717.60	\$140.00	3.44
SLC 105	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	8	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.37	1,496	0.0	\$168.06	\$717.60	\$140.00	3.44
Hallway	24	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	24	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,264	0.58	3,884	0.0	\$436.23	\$1,404.00	\$240.00	2.67
SLC 106	8	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.25	997	0.0	\$112.04	\$584.00	\$100.00	4.32
SLC 107	8	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.25	997	0.0	\$112.04	\$584.00	\$100.00	4.32
Hallway	1	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.03	393	0.0	\$44.13	\$107.56	\$0.00	2.44
Clubs Room 109	31	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,300	Relamp	Yes	31	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	910	1.43	2,899	0.0	\$325.62	\$2,795.20	\$545.00	6.91
Hallway	7	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	7	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	4,264	0.15	995	0.0	\$111.81	\$442.40	\$0.00	3.96
Hallway	1	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.03	393	0.0	\$44.13	\$107.56	\$0.00	2.44
Hallway	4	Compact Fluorescent: Wall mount fixture - 2 bulbs	Wall Switch	84	4,264	Relamp	No	4	LED Screw-In Lamps: Wall mount fixture	Wall Switch	18	4,264	0.19	1,295	0.0	\$145.41	\$430.02	\$0.00	2.96
Stairwell	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,264	0.05	324	0.0	\$36.35	\$117.00	\$20.00	2.67
Stairwell	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	4,264	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	4,264	0.07	485	0.0	\$54.53	\$150.40	\$30.00	2.21
SLC 216,217,219	111	Compact Fluorescent: Recessed fixture - 1 bulb	Wall Switch	42	624	Relamp	No	111	LED Screw-In Lamps: Recessed fixture	Wall Switch	16	624	2.12	2,071	0.0	\$232.62	\$5,422.68	\$0.00	23.31
SLC 209 - Conference	7	Compact Fluorescent: Recessed fixture - 2 bulbs	Wall Switch	36	624	Relamp	No	7	LED Screw-In Lamps: Recessed fixture	Wall Switch	4	624	0.16	161	0.0	\$18.06	\$683.94	\$0.00	37.88
SLC 209 - Conference	8	Compact Fluorescent: Recessed fixture - 1 bulb	Wall Switch	18	624	Relamp	No	8	LED Screw-In Lamps: Recessed fixture	Wall Switch	16	624	0.01	11	0.0	\$1.29	\$390.82	\$0.00	303.04
SLC 208	15	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	15	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,820	0.43	1,745	0.0	\$195.97	\$1,064.00	\$20.00	5.33
SLC 207 - Storage	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	104	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	104	0.02	4	0.0	\$0.44	\$58.50	\$10.00	109.40
SLC 210 - Storage	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	104	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	104	0.01	1	0.0	\$0.11	\$117.00	\$20.00	902.55
SLC 212 - Storage	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	104	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	104	0.07	12	0.0	\$1.33	\$150.40	\$30.00	90.53

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Hallway	25	Compact Fluorescent: Wall mount fixture - 1 bulb	Wall Switch	42	4,264	Relamp	No	25	LED Screw-In Lamps: Wall mount fixture	Wall Switch	9	4,264	0.61	4,045	0.0	\$454.41	\$1,343.83	\$0.00	2.96
SLC 216,217,219	4	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	4	LED Exit Signs: 2 W Lamp	None	6	8,760	0.11	1,572	0.0	\$176.52	\$430.22	\$0.00	2.44
SLC 212 - Storage	2	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.06	786	0.0	\$88.26	\$215.11	\$0.00	2.44
Kitchen Hallway	2	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	624	Relamp	No	2	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	624	0.04	42	0.0	\$4.68	\$126.40	\$0.00	27.04
SLC 213	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.02	99	0.0	\$11.08	\$58.50	\$10.00	4.38
Kitchen Hallway	1	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.03	393	0.0	\$44.13	\$107.56	\$0.00	2.44
SLC 214	38	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	38	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	2.05	8,340	0.0	\$936.76	\$3,847.07	\$800.00	3.25
SLC 214A	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.04	167	0.0	\$18.81	\$95.13	\$20.00	3.99
SLC 214A	3	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.09	1,179	0.0	\$132.39	\$322.67	\$0.00	2.44
SLC 214B	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,600	0.04	167	0.0	\$18.81	\$95.13	\$20.00	3.99
SLC 214D	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.07	296	0.0	\$33.25	\$175.50	\$30.00	4.38
Cafeteria	24	Compact Fluorescent: Recessed fixture - 2 bulbs	Wall Switch	36	2,600	Relamp	No	24	LED Screw-In Lamps: Recessed fixture	Wall Switch	8	2,600	0.49	2,009	0.0	\$225.69	\$2,580.14	\$0.00	11.43
Cafeteria	4	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	4	LED Exit Signs: 2 W Lamp	None	6	8,760	0.11	1,572	0.0	\$176.52	\$430.22	\$0.00	2.44
Cafeteria	76	Compact Fluorescent: Ceiling Mount - 1 bulb	Wall Switch	32	2,600	Relamp	No	76	LED Screw-In Lamps: Ceiling Mount fixture	Wall Switch	9	2,600	1.29	5,227	0.0	\$587.07	\$4,085.23	\$0.00	6.96
SLC 103	11	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	11	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.51	2,057	0.0	\$231.08	\$943.20	\$185.00	3.28
SLC 101	13	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	13	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.60	2,431	0.0	\$273.10	\$1,093.60	\$215.00	3.22
SLC 101A	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	4	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.15	592	0.0	\$66.50	\$300.80	\$60.00	3.62
SLC 106	20	Compact Fluorescent: Recessed fixture - 1 bulb	Wall Switch	18	2,600	Relamp	Yes	20	LED Screw-In Lamps: Recessed fixture	Occupancy Sensor	4	1,820	0.22	909	0.0	\$102.10	\$1,191.06	\$20.00	11.47
SLC 107	6	Compact Fluorescent: Chandelier - 3 bulbs	Wall Switch	54	2,600	Relamp	No	6	LED Screw-In Lamps: Chandelier	Wall Switch	12	2,600	0.19	753	0.0	\$84.63	\$967.55	\$90.00	10.37
SLC 108	2	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.04	173	0.0	\$19.48	\$126.40	\$0.00	6.49
SLC 108	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.07	296	0.0	\$33.25	\$150.40	\$30.00	3.62
Hallway	7	Compact Fluorescent: Wall mount fixture - 2 bulbs	Wall Switch	84	4,264	Relamp	No	7	LED Screw-In Lamps: Wall mount fixture	Wall Switch	18	4,264	0.34	2,265	0.0	\$254.47	\$752.54	\$0.00	2.96
Hallway	2	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.06	786	0.0	\$88.26	\$215.11	\$0.00	2.44
SLC 110 - Student life board	16	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	16	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.74	2,992	0.0	\$336.12	\$1,473.20	\$275.00	3.56
2nd Floor - Hallway near book store	4	Compact Fluorescent: Wall mount fixture - 1 bulb	Wall Switch	42	2,600	Relamp	No	4	LED Screw-In Lamps: Wall mount fixture	Wall Switch	9	2,600	0.10	395	0.0	\$44.33	\$215.01	\$0.00	4.85

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
2nd Floor - Hallway near book store	41	Compact Fluorescent: Wall hanging fixture - 1 bulb	Wall Switch	32	2,600	Relamp	No	41	LED Screw-In Lamps: Wall hanging fixture	Wall Switch	9	2,600	0.69	2,820	0.0	\$316.71	\$2,203.87	\$0.00	6.96
2nd Floor - Hallway near book store	15	Compact Fluorescent: Wall mount fixture - 2 bulb	Wall Switch	84	2,600	Relamp	No	15	LED Screw-In Lamps: Wall mount fixture	Wall Switch	18	2,600	0.73	2,960	0.0	\$332.49	\$806.30	\$0.00	2.42
2nd Floor - Hallway near book store	4	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	4	LED Exit Signs: 2 W Lamp	None	6	8,760	0.11	1,572	0.0	\$176.52	\$430.22	\$0.00	2.44
Convenient Store	18	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	4,264	Relamp	No	18	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	4,264	0.38	2,560	0.0	\$287.52	\$1,137.60	\$0.00	3.96
Bookstore	14	Compact Fluorescent: Wall hanging fixture - 2 bulb	Wall Switch	36	2,600	Relamp	No	14	LED Screw-In Lamps: Wall hanging fixture	Wall Switch	8	2,600	0.29	1,172	0.0	\$131.65	\$752.54	\$0.00	5.72
Bookstore	48	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	48	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	1.02	4,162	0.0	\$467.51	\$3,033.60	\$0.00	6.49
Bookstore	44	LED Screw-In Lamps: Wall hanging fixture - 1 bulb	Wall Switch	14	2,600	None	No	44	LED Screw-In Lamps: Wall hanging fixture - 1 bulb	Wall Switch	14	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Bookstore	6	Incandescent: Spot fixture - 1 bulb	Wall Switch	40	2,600	Relamp	No	6	LED Screw-In Lamps: Spot fixture	Wall Switch	9	2,600	0.14	556	0.0	\$62.47	\$322.52	\$30.00	4.68
Bookstore	2	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.06	786	0.0	\$88.26	\$215.11	\$0.00	2.44
Bookstore Storage	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	208	Relamp	No	14	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	208	0.19	62	0.0	\$6.96	\$1,052.80	\$210.00	121.11
Bookstore Storage	2	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.06	786	0.0	\$88.26	\$215.11	\$0.00	2.44
Bookstore Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	4	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.15	592	0.0	\$66.50	\$300.80	\$60.00	3.62
Bookstore Office	2	Exit Signs: Incandescent	None	45	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.06	786	0.0	\$88.26	\$215.11	\$0.00	2.44
SLC 204 A	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.09	374	0.0	\$42.02	\$266.40	\$50.00	5.15
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	780	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	780	0.04	44	0.0	\$4.99	\$75.20	\$15.00	12.07
Paramount lounge	8	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	8	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,600	0.17	694	0.0	\$77.92	\$505.60	\$0.00	6.49
Paramount lounge	13	Compact Fluorescent: Recessed fixture - 2 bulbs	Wall Switch	36	2,600	Relamp	No	13	LED Screw-In Lamps: Recessed fixture	Wall Switch	8	2,600	0.27	1,088	0.0	\$122.25	\$698.79	\$0.00	5.72
Hallway	28	Compact Fluorescent: Wall mount fixture - 1 bulb	Wall Switch	42	4,264	Relamp	No	28	LED Screw-In Lamps: Wall mount fixture	Wall Switch	9	4,264	0.68	4,531	0.0	\$508.94	\$1,505.08	\$0.00	2.96
Hallway	24	Compact Fluorescent: Recessed fixture - 2 bulbs	Wall Switch	36	4,264	Relamp	No	24	LED Screw-In Lamps: Recessed fixture	Wall Switch	8	4,264	0.49	3,295	0.0	\$370.14	\$1,290.07	\$0.00	3.49
Entrance	8	Compact Fluorescent: Wall mount fixture - 1 bulb	Wall Switch	42	4,264	Relamp	No	8	LED Screw-In Lamps: Wall mount fixture	Wall Switch	9	4,264	0.19	1,295	0.0	\$145.41	\$430.02	\$0.00	2.96
Women's Restroom	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	780	Relamp	Yes	4	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	546	0.11	140	0.0	\$15.68	\$522.80	\$35.00	31.11
Office SLC 202	6	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,820	0.17	698	0.0	\$78.39	\$495.20	\$20.00	6.06
Exterior	10	Compact Fluorescent: Wall mount fixture - 2 bulbs	Wall Switch	84	4,380	Relamp	No	10	LED Screw-In Lamps: Wall mount fixture	Wall Switch	18	4,380	0.49	3,324	0.0	\$373.42	\$537.53	\$0.00	1.44

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Elevator Room	SLC	1	Other	40.0	92.4%	No	1,500	No	92.4%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
DHW room	SLC	2	Heating Hot Water Pump	5.0	86.5%	No	2,745	No	86.5%	Yes	2	1.30	10,298	0.0	\$1,156.73	\$6,551.70	\$0.00	5.66
DHW room	SLC	2	Heating Hot Water Pump	2.0	85.5%	No	2,745	No	85.5%	Yes	2	0.53	4,167	0.0	\$468.10	\$5,457.71	\$0.00	11.66
Elevator Room	SLC	2	Other	30.0	91.7%	No	1,500	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Electrical room	SLC	1	Heating Hot Water Pump	15.0	91.7%	Yes	3,391	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Electrical room	SLC	1	Chilled Water Pump	25.0	91.7%	Yes	4,067	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Electrical room	SLC	1	Water Supply Pump	7.5	91.7%	Yes	3,391	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
AHU units	SLC	6	Supply Fan	5.0	91.7%	Yes	2,745	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric Chiller Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis						
		Chiller Quantity	System Type	Cooling Capacity per Unit (Tons)	Install High Efficiency Chillers?	Chiller Quantity	System Type	Constant/ Variable Speed	Cooling Capacity (Tons)	Full Load Efficiency (kW/Ton)	IPLV Efficiency (kW/Ton)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Rm	Campus	3	Water-Cooled Centrifugal Chiller	740.00	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Rm	Central Campus	8	Condensing Hot Water Boiler	2,850.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis					
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical Room	Student Life center building	2	Indirect System	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis							
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Kitchen	6	Faucet Aerator (Kitchen)	2.50	2.20	0.00	0	2.6	\$30.22	\$43.02	\$0.00	1.42	

Walk-In Cooler/Freezer Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions			Energy Impact & Financial Analysis						
	Cooler/Freezer Quantity	Case Type/Temperature	Install EC Evaporator Fan Motors?	Install Electric Defrost Control?	Install Evaporator Fan Control?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	2	Medium Temp Freezer (0F to 30F)	No	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis						
	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	4	Stand-Up Refrigerator, Glass Door (31 - 50 cu. ft.)	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Commercial Ice Maker Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis						
	Quantity	Ice Maker Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	2	Self-Contained Unit (≥175 lbs/day), Batch	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Cooking Equipment Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Equipment Type	High Efficiency Equipement?	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	5	Gas Combination Oven/Steam Cooker (<15 Pans)	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	3	Gas Griddle (4 Feet Width)	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	2	Gas Convection Oven (Full Size)	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Dishwasher Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Dishwasher Type	Water Heater Fuel Type	Booster Heater Fuel Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Payback w/ Incentives in Years
Kitchen	1	Single Tank Conveyor (High Temp)	Natural Gas	N/A	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
SLC	62	Computer	75.0	Yes
SLC	3	Printer small	18.0	Yes
SLC	7	Printer medium	20.0	No
SLC	1	Printer large	27.0	Yes
SLC	10	Projector	200.0	Yes
SLC	2	Microwave	900.0	No
SLC	3	Refrigerator medium	50.0	No
SLC	7	Refrigerator large	200.0	No
SLC	1	Refrigerator double door	300.0	No
SLC	4	Coffee machine	400.0	No
SLC	7	Television - LCD	120.0	No
SLC	4	Television - LED	100.0	No
SLC	1	Standing fan	60.0	No
SLC	3	Space heater	900.0	No

Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Refrigerated	Yes	0.00	1,612	0.0	\$181.05	\$230.00	\$0.00	1.27

Appendix B: ENERGY STAR® Statement of Energy Performance

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

N/A

Brookdale Community College - Lincroft Campus

Primary Property Type: College/University
Gross Floor Area (ft²): 900,381
Built: 1967

For Year Ending: February 29, 2016
Date Generated: June 28, 2017

ENERGY STAR® Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Brookdale Community College - Lincroft Campus 765 Newman Springs Road Lincroft, New Jersey 07738	Property Owner Brookdale Community College 765 Newman Springs Road Lincroft, NJ 07738 (732) 224-2217	Primary Contact Timothy Drury 765 Newman Springs Road Lincroft, NJ 07738 (732) 224-2217 tdrury@brookdalecc.edu
Property ID: 5733170		

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI 95.4 kBtu/ft²	Annual Energy by Fuel		National Median Comparison
	Electric - Grid (kBtu)	48,132,581 (56%)	National Median Site EUI (kBtu/ft²) 118.2
	Natural Gas (kBtu)	37,799,044 (44%)	National Median Source EUI (kBtu/ft²) 262.8
			% Diff from National Median Source EUI -19%
Source EUI 211.9 kBtu/ft²			Annual Emissions
			Greenhouse Gas Emissions (Metric Tons CO2e/year) 7,528

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

,
() _____



Professional Engineer Stamp (if applicable)