



# Local Government Energy Audit: Energy Audit Report



Copyright ©2017 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

**Wilbur Ray Police Station**

**Brookdale Community College**

765 Newman Springs Road

Lincroft, NJ 07738

March 27, 2018

Final Report by:

**TRC Energy Services**

## Disclaimer

---

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

# Table of Contents

---

<b>1</b>	<b>Executive Summary.....</b>	<b>1</b>
1.1	Facility Summary .....	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices .....	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
<b>2</b>	<b>Facility Information and Existing Conditions .....</b>	<b>5</b>
2.1	Project Contacts .....	5
2.2	General Site Information.....	5
2.3	Building Occupancy .....	5
2.4	Building Envelope .....	5
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems .....	6
	Lighting System .....	6
	Heating, Ventilation, and Air Conditioning (HVAC) .....	7
	Domestic Hot Water Heating System.....	8
	Building Plug Load .....	8
2.7	Water-Using Systems .....	8
<b>3</b>	<b>Site Energy Use and Costs.....</b>	<b>9</b>
3.1	Total Cost of Energy .....	9
3.2	Electricity Usage .....	10
3.3	Natural Gas Usage .....	11
3.4	Benchmarking.....	12
3.5	Energy End-Use Breakdown .....	14
<b>4</b>	<b>Energy Conservation Measures .....</b>	<b>15</b>
4.1	High Priority ECMs.....	15
4.1.1	Lighting Upgrades.....	16
	ECM 1: Install LED Fixtures .....	16
	ECM 2: Retrofit Fixtures with LED Lamps.....	17
	ECM 3: Install LED Exit Signs.....	17
4.1.2	Lighting Control Measures .....	18
	ECM 4: Install Occupancy Sensor Lighting Controls .....	18
4.1.3	Electric Unitary HVAC Measures .....	19
	ECM 5: Install High Efficiency Air Conditioning Units.....	19
4.1.4	Gas-Fired Heating System Replacements.....	20
	ECM 6: Install High Efficiency Furnaces.....	20
4.1.5	HVAC System Upgrades.....	20

ECM 7: Install Programmable Thermostats.....	21
ECM 8: Install Dual-Enthalpy Economizers.....	21
4.1.6 Domestic Hot Water Heating System Upgrades .....	22
ECM 9: Install Low-Flow DHW Devices.....	22
<b>5 Energy Efficient Practices .....</b>	<b>23</b>
Close Doors and Windows .....	23
Ensure Lighting Controls Are Operating Properly .....	23
Use Fans to Reduce Cooling Load .....	23
Practice Proper Use of Thermostat Schedules and Temperature Resets .....	23
Perform Proper Furnace Maintenance .....	23
Perform Proper Water Heater Maintenance .....	24
Plug Load Controls.....	24
Water Conservation .....	24
<b>6 On-Site Generation Measures .....</b>	<b>25</b>
6.1 Photovoltaic.....	25
<b>7 Demand Response .....</b>	<b>27</b>
<b>8 Project Funding / Incentives .....</b>	<b>28</b>
8.1 SmartStart .....	29
8.2 Energy Savings Improvement Program .....	30
<b>9 Energy Purchasing and Procurement Strategies .....</b>	<b>31</b>
9.1 Retail Electric Supply Options.....	31
9.2 Retail Natural Gas Supply Options .....	31

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

# Table of Figures

---

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs ..... 2

Figure 3 – Summary of Energy Reduction Opportunities ..... 2

Figure 4 – Project Contacts ..... 5

Figure 5 - Building Schedule..... 5

Figure 6 - Utility Summary ..... 9

Figure 7 - Energy Cost Breakdown ..... 9

Figure 8 - Electric Usage & Demand..... 10

Figure 9 - Electric Usage & Demand..... 10

Figure 10 - Natural Gas Usage..... 11

Figure 11 - Natural Gas Usage..... 11

Figure 12 - Energy Use Intensity Comparison – Existing Conditions..... 12

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures ..... 12

Figure 14 - Energy Balance (% and kBtu/SF) ..... 14

Figure 15 – Summary of High Priority ECMs ..... 15

Figure 16 – Summary of Lighting Upgrade ECMs..... 16

Figure 17 – Summary of Lighting Control ECMs ..... 18

Figure 18 - Summary of Unitary HVAC ECMs..... 19

Figure 19 - Summary of Gas-Fired Heating Replacement ECMs..... 20

Figure 20 - Summary of HVAC System Improvement ECMs ..... 20

Figure 21 - Summary of Domestic Water Heating ECMs ..... 22

Figure 22 - Photovoltaic Screening ..... 25

Figure 23 - ECM Incentive Program Eligibility..... 28

# I EXECUTIVE SUMMARY

---

The New Jersey Board of Public Utilities (NJBPUB) has sponsored this Local Government Energy Audit (LGEA) Report for Wilbur Ray Police Station.

The goal of an LGEA report is to provide public facilities and local governments with valuable information on their facilities' energy usage. The LGEA program identifies energy conservation measures (ECMs) and energy management options that may benefit public facilities and to provides information on financial incentives from New Jersey's Clean Energy Programs (NJCEP) and other sources assistance which may be available to help with ECM implementation.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey community colleges in controlling their energy costs and help to protect our environment by promoting more efficient use of energy resources statewide.

## I.1 Facility Summary

Wilbur Ray Police Station is a single story 2,967 square foot facility constructed in 1997 with 17 rooms. It includes a central squad room, offices, a dispatch center, restrooms, locker rooms, and mechanical spaces. The facility is occupied 24 hours a day, 7 days a week. During a typical day shift, the facility is occupied by 20 people.

Interior lighting at Wilbur Ray Police Station consists primarily of 2-lamp T8 linear fluorescent fixtures which are considered inefficient by modern lighting standards. Lighting is controlled by manual switches. The exterior lighting is a mix of metal halide fixtures and recently upgraded LED fixtures. Exterior lights are controlled by photocells.

The building is conditioned by two inefficient split AC systems and a small gas furnace. The AC units appeared to be aging and in need of replacement.

The building is supplied electricity via the campus main account. The building has no submeter, so we estimated its electric usage as a pro-rated share of the main account, based on the building type, size, and occupancy hours.


A thorough description of the facility and our observations are located in Section 2.

## I.2 Your Cost Reduction Opportunities


### Energy Conservation Measures

TRC evaluated nine energy conservation measures. Together these nine ECMs represent an opportunity for Wilbur Ray Police Station to reduce annual energy costs by about \$3,672 and annual greenhouse gas emissions by 32,962 lbs CO<sub>2</sub>e. We estimate that if all measures are implemented as recommended, then the project would pay for itself in 7.9 years. The breakdown of existing utility costs and projected annual savings following implementation of all measures are shown in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Wilbur Ray Police Station's annual energy use by about 31% overall.

**Figure 1 – Previous 12 Month Utility Costs**



**Figure 2 – Potential Post-Implementation Costs**



A detailed description of Wilbur Ray Police Station’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the evaluated energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

**Figure 3 – Summary of Energy Reduction Opportunities**

Energy Conservation Measure		Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>			<b>14,130</b>	<b>2.3</b>	<b>0.0</b>	<b>\$1,587.12</b>	<b>\$5,749.16</b>	<b>\$1,140.00</b>	<b>\$4,609.16</b>	<b>2.9</b>	<b>14,229</b>
ECM 1	Install LED Fixtures	Yes	6,494	1.1	0.0	\$729.40	\$2,571.38	\$700.00	\$1,871.38	2.6	6,539
ECM 2	Retrofit Fixtures with LED Lamps	Yes	7,359	1.2	0.0	\$826.59	\$2,747.56	\$440.00	\$2,307.56	2.8	7,410
ECM 3	Install LED Exit Signs	Yes	277	0.0	0.0	\$31.13	\$430.22	\$0.00	\$430.22	13.8	279
<b>Lighting Control Measures</b>			<b>1,016</b>	<b>0.2</b>	<b>0.0</b>	<b>\$114.07</b>	<b>\$1,776.00</b>	<b>\$135.00</b>	<b>\$1,641.00</b>	<b>14.4</b>	<b>1,023</b>
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	1,016	0.2	0.0	\$114.07	\$1,776.00	\$135.00	\$1,641.00	14.4	1,023
<b>Electric Unitary HVAC Measures</b>			<b>10,807</b>	<b>3.2</b>	<b>0.0</b>	<b>\$1,213.91</b>	<b>\$21,979.21</b>	<b>\$1,447.50</b>	<b>\$20,531.71</b>	<b>16.9</b>	<b>10,883</b>
ECM 5	Install High Efficiency Electric AC	Yes	10,807	3.2	0.0	\$1,213.91	\$21,979.21	\$1,447.50	\$20,531.71	16.9	10,883
<b>Gas Heating (HVAC/Process) Replacement</b>			<b>0</b>	<b>0.0</b>	<b>12.7</b>	<b>\$163.15</b>	<b>\$1,608.67</b>	<b>\$400.00</b>	<b>\$1,208.67</b>	<b>7.4</b>	<b>1,483</b>
ECM 6	Install High Efficiency Furnaces	Yes	0	0.0	12.7	\$163.15	\$1,608.67	\$400.00	\$1,208.67	7.4	1,483
<b>HVAC System Improvements</b>			<b>3,790</b>	<b>0.8</b>	<b>5.4</b>	<b>\$495.06</b>	<b>\$1,229.87</b>	<b>\$250.00</b>	<b>\$979.87</b>	<b>2.0</b>	<b>4,447</b>
ECM 7	Install Programmable Thermostats	Yes	418	0.0	5.4	\$116.30	\$329.87	\$0.00	\$329.87	2.8	1,051
ECM 8	Install Dual Enthalpy Outside Economizer Control	Yes	3,372	0.8	0.0	\$378.76	\$900.00	\$250.00	\$650.00	1.7	3,396
<b>Domestic Water Heating Upgrade</b>			<b>0</b>	<b>0.0</b>	<b>7.7</b>	<b>\$98.88</b>	<b>\$21.51</b>	<b>\$0.00</b>	<b>\$21.51</b>	<b>0.2</b>	<b>899</b>
ECM 9	Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	7.7	\$98.88	\$21.51	\$0.00	\$21.51	0.2	899
<b>TOTALS</b>			<b>29,742</b>	<b>6.4</b>	<b>25.7</b>	<b>\$3,672.19</b>	<b>\$32,364.42</b>	<b>\$3,372.50</b>	<b>\$28,991.92</b>	<b>7.9</b>	<b>32,962</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

**Lighting Upgrades** generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measure save energy by reducing the power used by the lighting components due to improved electrical efficiency.

**Lighting Controls** measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

**Electric Unitary HVAC** measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air condition systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

**Gas Heating** (HVAC/Process) measures generally involve replacing older inefficient hydronic heating systems with modern energy efficient systems. Gas heating systems can provide equivalent heating compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel demands for heating, due to improved combustion and heat transfer efficiency.

**HVAC System Improvements** generally involve the installation of automated controls to reduce heating and cooling demand during periods of reduced demand. These measures could encompass changing temperature setpoints, using outside air for free cooling, or limiting excessive outside air during extreme outdoor air temperature conditions. These measures save energy by reducing the demand on HVAC systems and the amount of time systems operate.

**Domestic Hot Water** upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

### **Energy Efficient Practices**

TRC also identified eight low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Wilbur Ray Police Station include:

- Close Doors and Windows
- Ensure Lighting Controls Are Operating Properly
- Use Fans to Reduce Cooling Load
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Perform Proper Furnace Maintenance
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

### **On-Site Generation Measures**

TRC evaluated the potential for installing on-site generation for Wilbur Ray Police Station. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.



### I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.2 for additional information on the ESIP Program.

Additional information on relevant incentive programs is located in Section 8 or: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 2 FACILITY INFORMATION AND EXISTING CONDITIONS

### 2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
<b>Customer</b>			
Tim Drury	Director of Facilities Management & Construction	<a href="mailto:tdrury@brookdalecc.edu">tdrury@brookdalecc.edu</a>	732-224-2217
<b>TRC Energy Services</b>			
Tom Page	Auditor	<a href="mailto:tpage@TRCsolutions.com">tpage@TRCsolutions.com</a>	(732) 855-0033

### 2.2 General Site Information

On December 7, 2017, TRC performed an energy audit at Wilbur Ray Police Station located in Lincroft, New Jersey. TRC’s team met with Tim Drury, Director of Facilities Management & Construction to review the facility operations and help focus our investigation on specific energy-using systems.

Wilbur Ray Police Station is a single story 2,967 square foot facility, consisting of just 17 rooms in a single building. The police station was constructed in 1997. It includes a central squad room, offices, a dispatch center, restrooms, locker rooms, and mechanical spaces.

### 2.3 Building Occupancy

The police station is open 24 hours a day, 7 days a week. The facility is used year round. During a typical day shift, the facility is occupied by approximately 20 officers and staff.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Wilbur Ray Police Station (POL)	Weekday	24 hrs / day
Wilbur Ray Police Station (POL)	Weekend	24 hrs / day

### 2.4 Building Envelope

The building is constructed of concrete with a stucco façade in some locations with few windows. The windows are double paned and in good condition. The building has a pitched shed roof covered with composite shingles. The exterior doors are constructed of glass within an aluminum frame and are in good condition. The building shows no sign of excessive air infiltration.

*Image 1: Police Station – Front Exterior*



## 2.5 On-Site Generation

There is a single 35-kW Kohler back-up generator behind the building, which is used only in the event of emergency power outage.

## 2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

### Lighting System

Lighting is provided mostly by 32-Watt linear fluorescent T8 lamps with electronic ballasts. Most of the fixtures are 2-lamp, 4-foot long troffers with diffusers. There are U-bend and 2-foot linear fluorescent fixtures in the restrooms. Lighting control in all spaces is provided by manual wall switches.

The building's exterior lighting is minimal and consists metal halide lamps in the parking area, plus recently installed new high-efficiency LED area lights. Exterior lights are controlled by photocells.

*Image 2: Building Interior & Exterior Lighting*






**Heating, Ventilation, and Air Conditioning (HVAC)**

A 12.5-ton Trane/ American Standard split system AC unit that uses 100% return air is used to condition most of the police station. A separate forced-air Carrier Weathermaster 8000 furnace provides heat for the space. A 5-ton Carrier split system heat pump conditions the dispatch office. The units are controlled by manual thermostats. Both units provide a constant volume of air. All units were estimated to be over 15 years old. The compressor and condensing units are located on the ground adjacent to the building. The HVAC units are manually controlled by thermostats located in each zone.

*Image 3: Split System Condenser and HVAC Controls*



## **Domestic Hot Water Heating System**

The police station has a single 48-gallon gas-fired Bradford White domestic water heater with an input rating of 40 kBtu/hr and a nominal efficiency of 85%. Hot water is used in the restrooms and break room.

## **Building Plug Load**

Plug load equipment at the facility is fairly minimal. There are 16 computer work stations throughout the facility. All of the computers are desktop units with LCD monitors. There is no centralized PC power management software installed.

In addition to the computer work stations, the police station has three printers, a copy machine, two refrigerators, and a microwave.

## **2.7 Water-Using Systems**

There are 3 restrooms at this facility. A sampling of restrooms found that the faucets are all rated at 2.5 gallons per minute (gpm) or higher, which is above the current standard for low-flow water conservation standards. The building's toilets and urinals appeared to meet current low-flow standards for water conservation in public facilities.



### 3 SITE ENERGY USE AND COSTS

Nearly the entire campus receives electricity through a master electric meter. A large portion of the campus receives natural gas through master gas meter. All campus meters were combined and usage prorated for individual buildings based on building size and function.

Prorated utility data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

#### 3.1 Total Cost of Energy


The following energy consumption and cost data is prorated from the last 12-month period of master meter utility billing data. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

*Figure 6 - Utility Summary*

Utility Summary for Wilbur Ray Police Station		
Fuel	Usage	Cost
Electricity	83,186 kWh	\$9,344
Natural Gas	1,212 Therms	\$1,562
<b>Total</b>		<b>\$10,906</b>

The current annual energy cost for this facility is \$10,906 as shown in the chart below.

*Figure 7 - Energy Cost Breakdown*



### 3.2 Electricity Usage

Electricity is provided by JCP&L. The average electric rate over a recent 12 month period was found to be \$0.112/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The facility is supplied by the campus main electric account. Power is distributed from the Central Utility Plant. Because the building has no submeter, we had to estimate its portion of the total campus electric usage. Electric usage for campus building on the main account were assign a pro-rata share of the total billed usage based on building type, size, and relative occupancy levels. The estimated pro-rated monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Wilbur Ray Police Station					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Total Electric Cost	TRC Estimated Usage?
4/13/15	32	5,474	15.4	\$615	Yes
5/12/15	29	6,427	9.6	\$722	Yes
6/11/15	30	6,852	19.9	\$770	Yes
7/13/15	32	7,960	19.4	\$894	Yes
8/12/15	30	8,177	21.6	\$919	Yes
9/11/15	30	7,806	17.9	\$877	Yes
10/13/15	32	6,826	20.4	\$767	Yes
11/12/15	30	7,002	18.9	\$786	Yes
12/14/15	32	6,912	16.4	\$776	Yes
1/13/16	30	5,894	13.9	\$662	Yes
2/11/16	29	6,908	13.3	\$776	Yes
3/11/16	29	6,948	15.4	\$780	Yes
<b>Totals</b>	<b>365</b>	<b>83,186</b>	<b>21.6</b>	<b>\$9,344</b>	<b>12</b>
<b>Annual</b>	<b>365</b>	<b>83,186</b>	<b>21.6</b>	<b>\$9,344</b>	

### 3.3 Natural Gas Usage

Natural gas is provided by New Jersey Natural Gas. The average rate for natural gas service over a recent 12-month period was found to be \$1.288/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for Wilbur Ray Police Station			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
4/15/15	29	160	\$196
5/14/15	29	39	\$66
6/11/15	28	9	\$34
7/16/15	35	10	\$40
8/12/15	27	6	\$32
9/10/15	29	6	\$32
10/8/15	28	10	\$35
11/9/15	32	52	\$78
12/11/15	32	148	\$177
1/12/16	32	227	\$258
2/11/16	30	305	\$338
3/17/16	35	244	\$280
<b>Totals</b>	<b>366</b>	<b>1,215</b>	<b>\$1,566</b>
<b>Annual</b>	<b>365</b>	<b>1,212</b>	<b>\$1,562</b>



### 3.4 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

**Figure 12 - Energy Use Intensity Comparison – Existing Conditions**

Energy Use Intensity Comparison - Existing Conditions		
	Wilbur Ray Police Station	National Median Building Type: Fire/Police Station
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	343.3	154.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	136.5	88.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

**Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures**

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Wilbur Ray Police Station	National Median Building Type: Fire/Police Station
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	226.8	154.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	93.6	88.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification.

This building is not eligible to receive an ENERGY STAR® score, because it shares electric and gas end usage with the other central campus buildings – which are all served by the Central Utility Plant’s main electric and gas accounts. Without individual submeters to measure each building’s actual electric usage, we cannot be certain that the assumptions underlying our estimates of building performance are accurate for this building and other central campus buildings. Because of this limitation, a Portfolio Manager Statement of Energy Performance (SEP) was generated for all of the central campus buildings combined, based on the utility data provided for the master electric and gas accounts (including other

small gas accounts that supply some buildings, such as this one), see Appendix B: ENERGY STAR® Statement of Energy Performance.

For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.


A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

### 3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage.

This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



## 4 ENERGY CONSERVATION MEASURES

### Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Wilbur Ray Police Station regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

### 4.1 High Priority ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of High Priority ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>14,130</b>	<b>2.3</b>	<b>0.0</b>	<b>\$1,587.12</b>	<b>\$5,749.16</b>	<b>\$1,140.00</b>	<b>\$4,609.16</b>	<b>2.9</b>	<b>14,229</b>
ECM 1	Install LED Fixtures	6,494	1.1	0.0	\$729.40	\$2,571.38	\$700.00	\$1,871.38	2.6	6,539
ECM 2	Retrofit Fixtures with LED Lamps	7,359	1.2	0.0	\$826.59	\$2,747.56	\$440.00	\$2,307.56	2.8	7,410
ECM 3	Install LED Exit Signs	277	0.0	0.0	\$31.13	\$430.22	\$0.00	\$430.22	13.8	279
<b>Lighting Control Measures</b>		<b>1,016</b>	<b>0.2</b>	<b>0.0</b>	<b>\$114.07</b>	<b>\$1,776.00</b>	<b>\$135.00</b>	<b>\$1,641.00</b>	<b>14.4</b>	<b>1,023</b>
ECM 4	Install Occupancy Sensor Lighting Controls	1,016	0.2	0.0	\$114.07	\$1,776.00	\$135.00	\$1,641.00	14.4	1,023
<b>Electric Unitary HVAC Measures</b>		<b>10,807</b>	<b>3.2</b>	<b>0.0</b>	<b>\$1,213.91</b>	<b>\$21,979.21</b>	<b>\$1,447.50</b>	<b>\$20,531.71</b>	<b>16.9</b>	<b>10,883</b>
ECM 5	Install High Efficiency Electric AC	10,807	3.2	0.0	\$1,213.91	\$21,979.21	\$1,447.50	\$20,531.71	16.9	10,883
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>12.7</b>	<b>\$163.15</b>	<b>\$1,608.67</b>	<b>\$400.00</b>	<b>\$1,208.67</b>	<b>7.4</b>	<b>1,483</b>
ECM 6	Install High Efficiency Furnaces	0	0.0	12.7	\$163.15	\$1,608.67	\$400.00	\$1,208.67	7.4	1,483
<b>HVAC System Improvements</b>		<b>3,790</b>	<b>0.8</b>	<b>5.4</b>	<b>\$495.06</b>	<b>\$1,229.87</b>	<b>\$250.00</b>	<b>\$979.87</b>	<b>2.0</b>	<b>4,447</b>
ECM 7	Install Programmable Thermostats	418	0.0	5.4	\$116.30	\$329.87	\$0.00	\$329.87	2.8	1,051
ECM 8	Install Dual Enthalpy Outside Economizer Control	3,372	0.8	0.0	\$378.76	\$900.00	\$250.00	\$650.00	1.7	3,396
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>7.7</b>	<b>\$98.88</b>	<b>\$21.51</b>	<b>\$0.00</b>	<b>\$21.51</b>	<b>0.2</b>	<b>899</b>
ECM 9	Install Low-Flow Domestic Hot Water Devices	0	0.0	7.7	\$98.88	\$21.51	\$0.00	\$21.51	0.2	899
<b>TOTALS</b>		<b>29,742</b>	<b>6.4</b>	<b>25.7</b>	<b>\$3,672.19</b>	<b>\$32,364.42</b>	<b>\$3,372.50</b>	<b>\$28,991.92</b>	<b>7.9</b>	<b>32,962</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

### 4.1.1 Lighting Upgrades

Recommended upgrades to existing lighting fixtures are summarized in Figure 16 below.

*Figure 16 – Summary of Lighting Upgrade ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>14,130</b>	<b>2.3</b>	<b>0.0</b>	<b>\$1,587.12</b>	<b>\$5,749.16</b>	<b>\$1,140.00</b>	<b>\$4,609.16</b>	<b>2.9</b>	<b>14,229</b>
ECM 1	Install LED Fixtures	6,494	1.1	0.0	\$729.40	\$2,571.38	\$700.00	\$1,871.38	2.6	6,539
ECM 2	Retrofit Fixtures with LED Lamps	7,359	1.2	0.0	\$826.59	\$2,747.56	\$440.00	\$2,307.56	2.8	7,410
ECM 3	Install LED Exit Signs	277	0.0	0.0	\$31.13	\$430.22	\$0.00	\$430.22	13.8	279

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

#### **ECM 1: Install LED Fixtures**

##### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	6,494	1.1	0.0	\$729.40	\$2,571.38	\$700.00	\$1,871.38	2.6	6,539

##### *Measure Description*

We recommend replacing existing fixtures containing HID lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

## **ECM 2: Retrofit Fixtures with LED Lamps**

### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	7,359	1.2	0.0	\$826.59	\$2,747.56	\$440.00	\$2,307.56	2.8	7,410
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

### *Measure Description*

We recommend retrofitting existing T8 fluorescent technologies with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than 10 times longer than many incandescent lamps.

## **ECM 3: Install LED Exit Signs**

### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	277	0.0	0.0	\$31.13	\$430.22	\$0.00	\$430.22	13.8	279
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

### *Measure Description*

We recommend replacing all incandescent or compact fluorescent exit signs with LED exit signs. LED exit signs require virtually no maintenance and have a life expectancy of at least 20 years. This measure saves energy by installing LED fixtures, which use less power than other technologies with an equivalent lighting output.

## 4.1.2 Lighting Control Measures

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>	<b>1,016</b>	<b>0.2</b>	<b>0.0</b>	<b>\$114.07</b>	<b>\$1,776.00</b>	<b>\$135.00</b>	<b>\$1,641.00</b>	<b>14.4</b>	<b>1,023</b>
ECM 4 Install Occupancy Sensor Lighting Controls	1,016	0.2	0.0	\$114.07	\$1,776.00	\$135.00	\$1,641.00	14.4	1,023

### ECM 4: Install Occupancy Sensor Lighting Controls

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
1,016	0.2	0.0	\$114.07	\$1,776.00	\$135.00	\$1,641.00	14.4	1,023

#### Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in all restrooms, storage rooms, and offices areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

### 4.1.3 Electric Unitary HVAC Measures

Our recommendations for unitary HVAC measures are summarized in Figure 18 below.

*Figure 18 - Summary of Unitary HVAC ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Electric Unitary HVAC Measures</b>		<b>10,807</b>	<b>3.2</b>	<b>0.0</b>	<b>\$1,213.91</b>	<b>\$21,979.21</b>	<b>\$1,447.50</b>	<b>\$20,531.71</b>	<b>16.9</b>	<b>10,883</b>
ECM 5	Install High Efficiency Electric AC	10,807	3.2	0.0	\$1,213.91	\$21,979.21	\$1,447.50	\$20,531.71	16.9	10,883

#### ECM 5: Install High Efficiency Air Conditioning Units

*Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
10,807	3.2	0.0	\$1,213.91	\$21,979.21	\$1,447.50	\$20,531.71	16.9	10,883

*Measure Description*

We recommend replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.



#### 4.1.4 Gas-Fired Heating System Replacements

Our recommendations for gas-fired heating system replacements are summarized in Figure 19 below.

*Figure 19 - Summary of Gas-Fired Heating Replacement ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>12.7</b>	<b>\$163.15</b>	<b>\$1,608.67</b>	<b>\$400.00</b>	<b>\$1,208.67</b>	<b>7.4</b>	<b>1,483</b>
ECM 6	Install High Efficiency Furnaces	0	0.0	12.7	\$163.15	\$1,608.67	\$400.00	\$1,208.67	7.4	1,483

#### **ECM 6: Install High Efficiency Furnaces**

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
0	0.0	12.7	\$163.15	\$1,608.67	\$400.00	\$1,208.67	7.4	1,483

#### *Measure Description*

We recommend replacing existing standard efficiency furnaces with condensing furnaces. Improved combustion technology and heat exchanger design optimize heat recovery from the combustion gases which can significantly improve furnace efficiency. Savings result from improved system efficiency.

#### 4.1.5 HVAC System Upgrades

Our recommendation for HVAC system improvement are summarized in Figure 20 below.

*Figure 20 - Summary of HVAC System Improvement ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>HVAC System Improvements</b>		<b>3,790</b>	<b>0.8</b>	<b>5.4</b>	<b>\$495.06</b>	<b>\$1,229.87</b>	<b>\$250.00</b>	<b>\$979.87</b>	<b>2.0</b>	<b>4,447</b>
ECM 7	Install Programmable Thermostats	418	0.0	5.4	\$116.30	\$329.87	\$0.00	\$329.87	2.8	1,051
ECM 8	Install Dual Enthalpy Outside Economizer Control	3,372	0.8	0.0	\$378.76	\$900.00	\$250.00	\$650.00	1.7	3,396

## **ECM 7: Install Programmable Thermostats**

### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
418	0.0	5.4	\$116.30	\$329.87	\$0.00	\$329.87	2.8	1,051

### *Measure Description*

We recommend replacing manual thermostats with programmable thermostats. Manual thermostats are generally adjusted to a single heating and cooling setpoint and left at that setting regardless of occupancy in the area served by the HVAC equipment. As a result, the same level of heating and cooling is provided regardless of the occupancy in the space. Programmable thermostats can be set to maintain different temperature settings for different times of day and for different days of the week. By reducing heating temperature setpoints and raising cooling temperature setpoints when space are unoccupied, the operation of the HVAC equipment is reduced while still maintaining reasonable space temperatures for building usage at all times.

Programmable thermostats provide energy savings by reducing heating and cooling energy usage when a room is unoccupied.

## **ECM 8: Install Dual-Enthalpy Economizers**

### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
3,372	0.8	0.0	\$378.76	\$900.00	\$250.00	\$650.00	1.7	3,396

### *Measure Description*

When replacing the AC units in the building it is recommended they include outside air economizers. Dual enthalpy economizers are used to control a ventilation system's outside air intake in order to reduce a facility's total cooling load. A dual-enthalpy economizer monitors the air temperature and humidity of both the outside and return air. The control supplies the lowest energy (temperature and humidity) air to the air handling system. When outside air conditions allow, outside air can be used for cooling instead of running the air handling system's compressor. This reduces the demand on the cooling system, lowering its usage hours and saving energy.

Savings result from using outside air instead of mechanical cooling when outside air conditions permit.

## 4.1.6 Domestic Hot Water Heating System Upgrades

Our recommendations for domestic water heating system improvements are summarized in Figure 21 below.

*Figure 21 - Summary of Domestic Water Heating ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>7.7</b>	<b>\$98.88</b>	<b>\$21.51</b>	<b>\$0.00</b>	<b>\$21.51</b>	<b>0.2</b>	<b>899</b>
ECM 9	Install Low-Flow Domestic Hot Water Devices	0	0.0	7.7	\$98.88	\$21.51	\$0.00	\$21.51	0.2	899

### **ECM 9: Install Low-Flow DHW Devices**

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
0	0.0	7.7	\$98.88	\$21.51	\$0.00	\$21.51	0.2	899

#### *Measure Description*

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Low flow faucet aerators can reduce hot water usage, relative to standard aerators, which saves energy. Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

## 5 ENERGY EFFICIENT PRACTICES

---

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

### **Close Doors and Windows**

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

### **Ensure Lighting Controls Are Operating Properly**

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

### **Use Fans to Reduce Cooling Load**

Utilizing ceiling fans to supplement cooling is a low cost strategy to reduce cooling load considerably. Thermostat settings can be increased by 4°F with no change in overall occupant comfort when the wind chill effect of moving air is employed for cooling.

### **Practice Proper Use of Thermostat Schedules and Temperature Resets**

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

### **Perform Proper Furnace Maintenance**

Preventative furnace maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should include tasks such as checking for gas / carbon monoxide leaks; changing the air and fuel filters; checking components for cracks, corrosion, dirt, or debris build-up; ensuring the ignition system is working properly; testing and adjusting operation and safety controls; inspecting the electrical connections; and ensuring proper lubrication for motors and bearings.

## **Perform Proper Water Heater Maintenance**

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

## **Plug Load Controls**

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

## **Water Conservation**

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products> ) labeled devices are 1.5 gallons per minute (gpm) for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.6 for any low-flow ECM recommendations.

## 6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


### 6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a Low potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation. The orientation and pitch of the roof would make solar PV installation difficult there. The expected higher cost for the building’s small roof would likely make solar development of this site uneconomic.

Figure 22 - Photovoltaic Screening



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1)

## 7 DEMAND RESPONSE

---

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.



## 8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 23 for a list of the eligible programs identified for each recommended ECM.

*Figure 23 - ECM Incentive Program Eligibility*

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings
ECM 1	Install LED Fixtures	X			
ECM 2	Retrofit Fixtures with LED Lamps	X			
ECM 3	Install LED Exit Signs				
ECM 4	Install Occupancy Sensor Lighting Controls	X			
ECM 5	Install High Efficiency Electric AC	X			
ECM 6	Install High Efficiency Furnaces	X			
ECM 7	Install Programmable Thermostats	X			
ECM 8	Install Dual Enthalpy Outside Economizer Control	X			
ECM 9	Install Low-Flow Domestic Hot Water Devices				

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. This facility does not meet all of the criteria for participating in the P4P program based on the measures identified in this study.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 8.1 SmartStart

### Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

### **Equipment with Prescriptive Incentives Currently Available:**

*Electric Chillers*

*Electric Unitary HVAC*

*Gas Cooling*

*Gas Heating*

*Gas Water Heating*

*Ground Source Heat Pumps*

*Lighting*

*Lighting Controls*

*Refrigeration Doors*

*Refrigeration Controls*

*Refrigerator/Freezer Motors*

*Food Service Equipment*

*Variable Frequency Drives*

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

### Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

### How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB).

## 8.2 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: [www.njcleanenergy.com/ESIP](http://www.njcleanenergy.com/ESIP).

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

## 9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

### 9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

# Appendix A: Equipment Inventory & Recommendations

## Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,920	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,044	0.07	275	0.0	\$30.91	\$233.00	\$40.00	6.24
Restroom	1	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	2	8,760	0.01	69	0.0	\$7.78	\$107.56	\$0.00	13.82
Squad Room	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	8,736	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	8,736	0.27	3,258	0.0	\$365.91	\$585.00	\$100.00	1.33
Squad Room	2	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	2	8,760	0.01	139	0.0	\$15.57	\$215.11	\$0.00	13.82
Dispatch Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	8,736	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	6,115	0.14	1,647	0.0	\$184.95	\$350.00	\$60.00	1.57
Lieutenant's Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,380	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,066	0.07	413	0.0	\$46.37	\$233.00	\$40.00	4.16
Admin Sergeant's Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,380	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,066	0.07	413	0.0	\$46.37	\$233.00	\$40.00	4.16
Office	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,920	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,044	0.03	138	0.0	\$15.46	\$174.50	\$10.00	10.64
Captain's Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,920	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,044	0.14	550	0.0	\$61.82	\$350.00	\$60.00	4.69
Kitchen	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,920	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,044	0.14	550	0.0	\$61.82	\$504.00	\$75.00	6.94
Processing Rm 1	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,460	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,460	0.03	54	0.0	\$6.12	\$58.50	\$10.00	7.93
Processing Rm 1	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,460	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,460	0.04	82	0.0	\$9.17	\$75.20	\$15.00	6.56
Processing Rm 2	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,460	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,460	0.03	54	0.0	\$6.12	\$58.50	\$10.00	7.93
Processing Rm 2	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,460	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	1,460	0.04	82	0.0	\$9.17	\$75.20	\$15.00	6.56
Equipment Storage	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,460	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,460	0.03	54	0.0	\$6.12	\$58.50	\$10.00	7.93
Evidence Storage	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	730	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	730	0.03	27	0.0	\$3.06	\$58.50	\$10.00	15.86
Mop Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	730	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	730	0.03	27	0.0	\$3.06	\$58.50	\$10.00	15.86
Back Hall	1	U-Bend Fluorescent - T8: U T8 (32W) - 1L	Wall Switch	39	8,736	Relamp	Yes	1	LED - Linear Tubes: (1) U-Lamp	Occupancy Sensor	17	6,115	0.02	271	0.0	\$30.44	\$309.73	\$0.00	10.18
Back Hall	1	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	2	8,760	0.01	69	0.0	\$7.78	\$107.56	\$0.00	13.82
Mech Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	730	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	730	0.08	82	0.0	\$9.17	\$175.50	\$30.00	15.86
Men's Rm	2	U-Bend Fluorescent - T8: U T8 (32W) - 1L	Wall Switch	39	2,190	Relamp	Yes	2	LED - Linear Tubes: (1) U-Lamp	Occupancy Sensor	17	1,533	0.04	136	0.0	\$15.26	\$349.46	\$0.00	22.90
Men's Rm	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,190	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,533	0.02	63	0.0	\$7.06	\$117.00	\$20.00	13.74
Women's Rm	2	U-Bend Fluorescent - T8: U T8 (32W) - 1L	Wall Switch	39	2,190	Relamp	Yes	2	LED - Linear Tubes: (1) U-Lamp	Occupancy Sensor	17	1,533	0.04	136	0.0	\$15.26	\$349.46	\$0.00	22.90
Women's Rm	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,190	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,533	0.02	63	0.0	\$7.06	\$117.00	\$20.00	13.74
Exterior Wall	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	40	4,380	None	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	40	4,380	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Location	Existing Conditions					Proposed Conditions					Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Flag Pole	1	LED - Fixtures: Architectural Flood/Spot Luminaire	Wall Switch	70	4,380	None	No	1	LED - Fixtures: Architectural Flood/Spot Luminaire	Wall Switch	70	4,380	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Parking Lot	6	Metal Halide: (1) 250W Lamp	Wall Switch	295	4,380	Fixture Replacement	No	6	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Wall Switch	100	4,380	0.95	5,791	0.0	\$650.45	\$2,279.04	\$600.00	2.58
Parking Lot	1	Metal Halide: (1) 150W Lamp	Wall Switch	190	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Wall Switch	48	4,380	0.12	703	0.0	\$78.94	\$292.34	\$100.00	2.44

### Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restroom	Restroom	1	Exhaust Fan	0.2	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Above Ceiling	Aggregated Building	1	Supply Fan	3.0	80.0%	No	2,745	No	80.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Behind Building	Police Station	1	Split-System AC	12.50		Yes	1	Split-System AC	12.50		12.30		Yes	2.84	10,409	0.0	\$1,169.20	\$15,398.11	\$1,237.50	12.11
Behind Building	Dispatch Office	1	Split-System AC	5.00		Yes	1	Split-System AC	5.00		18.00		No	1.12	3,770	0.0	\$423.47	\$7,481.10	\$460.00	16.58

### Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mech Rm	Police Station	1	Furnace	71.00	Yes	1	Furnace	71.00	96.00%	AFUE	0.00	0	12.7	\$163.15	\$1,608.67	\$400.00	7.41

### Programmable Thermostat Recommendations

Location	Area(s)/System(s) Affected	Recommendation Inputs				Energy Impact & Financial Analysis						
		Thermostat Quantity	Cooling Capacity of Controlled System (Tons)	Electric Heating Capacity of Controlled System (kBtu/hr)	Output Heating Capacity of Controlled System (MBh)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Main Area	Whole Building	1	12.50	0.00	71.00	0.00	418	5.4	\$116.30	\$329.87	\$0.00	2.84

### DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mech Rm	Whole Building	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis						
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restroom	1	Faucet Aerator (Lavatory)	2.50	1.00	0.00	0	2.6	\$32.96	\$7.17	\$0.00	0.22
Men's Rm	1	Faucet Aerator (Lavatory)	2.50	1.00	0.00	0	2.6	\$32.96	\$7.17	\$0.00	0.22
Women's Rm	1	Faucet Aerator (Lavatory)	2.50	1.00	0.00	0	2.6	\$32.96	\$7.17	\$0.00	0.22

**Commercial Refrigerator/Freezer Inventory & Recommendations**


Existing Conditions		Proposed Condi	Energy Impact & Financial Analysis								
Location	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Stand-Up Refrigerator, Solid Door (16 - 30 cu. ft.)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Equipment Storage	1	Stand-Up Refrigerator, Solid Door (≤15 cu. ft.)	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

**Plug Load Inventory**

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Whole Building	16	Computer + Monitor	150.0	Yes
Whole Building	3	Printers	80.0	Yes
Whole Building	1	Copy Machine	240.0	Yes
Whole Building	1	TV (small)	450.0	No
Whole Building	1	Microwaves	800.0	No



## Appendix B: ENERGY STAR® Statement of Energy Performance



**ENERGY STAR® Statement of Energy Performance**

LEARN MORE AT [energystar.gov](http://energystar.gov)

N/A

### Brookdale Community College - Lincroft Campus

**Primary Property Type:** College/University  
**Gross Floor Area (ft²):** 900,381  
**Built:** 1967

**For Year Ending:** February 29, 2016  
**Date Generated:** June 28, 2017

**ENERGY STAR®**  
Score<sup>1</sup>

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

### Property & Contact Information

Property Address	Property Owner	Primary Contact
Brookdale Community College - Lincroft Campus 765 Newman Springs Road Lincroft, New Jersey 07738	Brookdale Community College 765 Newman Springs Road Lincroft, NJ 07738 (732) 224-2217	Timothy Drury 765 Newman Springs Road Lincroft, NJ 07738 (732) 224-2217 tdrury@brookdalecc.edu

Property ID: 5733170

### Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
95.4 kBtu/ft²	Electric - Grid (kBtu) 48,132,581 (56%) Natural Gas (kBtu) 37,799,044 (44%)	National Median Site EUI (kBtu/ft²) 118.2 National Median Source EUI (kBtu/ft²) 262.6 % Diff from National Median Source EUI -19%
Source EUI		Annual Emissions
211.9 kBtu/ft²		Greenhouse Gas Emissions (Metric Tons CO2e/year) 7,528

### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Licensed Professional

\_\_\_\_\_  
,  
( ) \_\_\_\_\_  
\_\_\_\_\_



Professional Engineer Stamp  
(if applicable)