



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Town Hall

Maplewood, Township of

574 Valley Street
Maplewood, NJ 07040

November 16, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	5
2.1	Project Contacts	5
2.2	General Site Information.....	5
2.3	Building Occupancy	6
2.4	Building Envelope	6
2.5	On-Site Generation.....	7
2.6	Energy-Using Systems	7
	Lighting System	7
	Steam Heating System	7
	Direct Expansion Air Conditioning System (DX)	8
	Ventilation System	9
	Domestic Hot Water Heating System.....	9
	Building Plug Load	9
2.7	Water-Using Systems	9
3	Site Energy Use and Costs.....	10
3.1	Total Cost of Energy	10
3.2	Electricity Usage	11
3.3	Natural Gas Usage	12
3.4	Benchmarking.....	13
3.5	Energy End-Use Breakdown	14
4	Energy Conservation Measures	15
4.1	Recommended ECMs	15
4.1.1	Lighting Upgrades.....	16
	ECM 1: Install LED Fixtures	16
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	16
	ECM 3: Retrofit Fixtures with LED Lamps	17
4.1.2	Lighting Control Measures	18
	ECM 4: Install Occupancy Sensor Lighting Controls	18
	ECM 5: Install High/Low Lighting Controls	19
4.1.3	Domestic Hot Water Heating System Upgrades	20
	ECM 6: Install Low-Flow DHW Devices.....	20
4.1.4	Plug Load Equipment Control - Vending Machines.....	21

ECM 7: Vending Machine Control	21
4.2 ECMs Evaluated but Not Recommended	22
Premium Efficiency Motors	22
Install High Efficiency Air Conditioning Units	23
5 Energy Efficient Practices	24
Reduce Air Leakage	24
Perform Proper Lighting Maintenance.....	24
Develop a Lighting Maintenance Schedule	24
Ensure Lighting Controls Are Operating Properly	24
Use Fans to Reduce Cooling Load	24
Practice Proper Use of Thermostat Schedules and Temperature Resets	25
Clean Evaporator/Condenser Coils on AC Systems	25
Clean and/or Replace HVAC Filters	25
Repair/Replace Steam Traps	25
Perform Proper Boiler Maintenance	25
Perform Proper Furnace Maintenance	25
Perform Proper Water Heater Maintenance	26
Water Conservation	26
6 On-Site Generation Measures	27
6.1 Photovoltaic.....	27
6.2 Combined Heat and Power	28
7 Demand Response	29
8 Project Funding / Incentives	30
8.1 SmartStart	31
8.2 Direct Install	32
8.3 Energy Savings Improvement Program	32
9 Energy Purchasing and Procurement Strategies	34
9.1 Retail Electric Supply Options.....	34
9.2 Retail Natural Gas Supply Options	34

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs.....	2
Figure 2 – Potential Post-Implementation Costs	2
Figure 3 – Summary of Energy Reduction Opportunities	2
Figure 4 – Project Contacts	5
Figure 5 - Building Schedule.....	6
Figure 6 - Utility Summary	10
Figure 7 - Energy Cost Breakdown	10
Figure 8 - Electric Usage & Demand.....	11
Figure 9 - Electric Usage & Demand.....	11
Figure 10 - Natural Gas Usage.....	12
Figure 11 - Natural Gas Usage.....	12
Figure 12 - Energy Use Intensity Comparison – Existing Conditions.....	13
Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures	13
Figure 14 - Energy Balance (%and kBtu/SF)	14
Figure 15 – Summary of Recommended ECMs.....	15
Figure 16 – Summary of Lighting Upgrade ECMs.....	16
Figure 17 – Summary of Lighting Control ECMs	18
Figure 18 - Summary of Domestic Water Heating ECMs	20
Figure 19 - Summary of Plug Load Equipment Control ECMs.....	21
Figure 19 – Summary of Measures Evaluated, But Not Recommended	22
Figure 20 - Photovoltaic Screening	27
Figure 21 - Combined Heat and Power Screening	28
Figure 22 - ECM Incentive Program Eligibility.....	30

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Maplewood Town Hall.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Maplewood Town Hall building is a 22,100 square foot facility constructed in 1931. Including the basement, the Town Hall is a two-story building and is comprised of various spaces including Town administrative offices, building and engineering departments, finance department, Township Clerk, tax accessor and collector offices, mechanical and storage spaces. The building is occupied year-round.

The building has pitched roof sections with slate shingles and a small center flat membrane roof. The exterior walls are finished with brick masonry. The windows throughout the building are clear glass, single paned with wood frames. They are original to the building and appear to be in appropriate aging condition. The exterior doors are constructed of wood.

The building's interior lighting consists of a combination of linear fluorescent fixtures and compact fluorescent lamps. Lighting is controlled largely by manual switches with occupancy sensors used mainly in restrooms. The exterior lighting system consists of high intensity discharge (HID) lamps and compact fluorescent lamps. They are controlled with timers and photocells.

Heating is provided in the Town Hall building by a steam boiler while the cooling system consists of split systems system and packaged air conditioners. Most of the cooling equipment is in need of replacement.

A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated nine measures and recommends seven measures which together represent an opportunity for Town Hall to reduce annual energy costs by \$5,651 and annual greenhouse gas emissions by 30,795 lbs CO₂e. We estimate that if all measures were implemented as recommended, the project would pay for itself in 4.3 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce the Town Hall's annual energy use by 7%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of the Town Hall’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)	
Lighting Upgrades											
ECM 1	Install LED Fixtures	Yes	12,369	1.9	0.0	\$2,288.62	\$8,345.32	\$1,515.00	\$6,830.32	3.0	12,456
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	1,069	0.4	0.0	\$197.72	\$1,244.00	\$20.00	\$1,224.00	6.2	1,076
ECM 3	Retrofit Fixtures with LED Lamps	Yes	12,764	4.5	0.0	\$2,361.71	\$13,702.71	\$1,410.00	\$12,292.71	5.2	12,853
Lighting Control Measures											
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	2,061	0.7	0.0	\$381.33	\$3,244.00	\$390.00	\$2,854.00	7.5	2,075
ECM 5	Install High/Low Lighting Controls	Yes	294	0.1	0.0	\$54.34	\$600.00	\$0.00	\$600.00	11.0	296
Motor Upgrades											
	Premium Efficiency Motors	No	109	0.1	0.0	\$20.23	\$532.17	\$0.00	\$532.17	26.3	110
Electric Unitary HVAC Measures											
	Install High Efficiency Electric AC	No	7,026	6.3	0.0	\$1,299.97	\$45,885.71	\$2,875.50	\$43,010.21	33.1	7,075
Domestic Water Heating Upgrade											
ECM 6	Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	0.6	\$5.56	\$35.85	\$0.00	\$35.85	6.5	71
Plug Load Equipment Control - Vending Machine											
ECM 7	Vending Machine Control	Yes	1,954	0.0	0.0	\$361.61	\$460.00	\$0.00	\$460.00	1.3	1,968
TOTALS FOR HIGH PRIORITY MEASURES			30,511	7.6	0.6	\$5,650.88	\$27,631.88	\$3,335.00	\$24,296.88	4.3	30,795
TOTALS FOR ALL EVALUATED MEASURES			37,646	14.0	0.6	\$6,971.08	\$74,049.75	\$6,210.50	\$67,839.25	9.7	37,981

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Motor Upgrades generally involve replacing older standard efficiency motors with high efficiency standard (NEMA Premium). Motors replacements generally assume the same size motors, just higher efficiency. Although occasionally additional savings can be achieved by downsizing motors to better meet current load requirements. This measure saves energy by reducing the power used by the motors, due to improved electrical efficiency.

Electric Unitary HVAC measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air condition systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

Domestic Hot Water upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

Plug Load Equipment control measures generally involve installing automated devices that limit the power usage or operation of equipment that is plugged into an electric outlets when not in use.

Energy Efficient Practices

TRC also identified 13 low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at the Town Hall include:

- Reduce Air Leakage
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Use Fans to Reduce Cooling Load
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Repair/Replace Steam Traps
- Perform Proper Boiler Maintenance
- Perform Proper Furnace Maintenance
- Perform Proper Water Heater Maintenance
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for the Town Hall. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary, and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Joseph Manning	Business Administrator	<a href="mailto:Joseph.F.Manning<twpadmin@twp.maplewood.nj.us">Joseph.F.Manning<twpadmin@twp.maplewood.nj.us	973-762-8120 ex. 2000
Designated Representative			
Joe Pukatch	Maintenance Personnel		973-762-8120 ex. 2000
TRC Energy Services			
Moussa Traore	Auditor	mtraore@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On April 25, 2018, TRC performed an energy audit at the Town Hall located in Maplewood, New Jersey. TRC’s auditor met with Joe Pukatch, Maintenance Personnel to review the facility operations and help focus our investigation on specific energy-using systems.

Maplewood Town Hall building is a 22,100 square foot facility constructed in 1931. Including the basement, the Town Hall is a two-story building and is comprised of various spaces including Town administrative offices, building and engineering departments, finance department, Township Clerk, tax accessor and collector offices, mechanical and storage spaces. The building is occupied year-round.



Image 1: Old Court Room

2.3 Building Occupancy

The Town Hall building is open Monday through Friday. The typical schedule is presented in the table below. The entire building facilities are used year round.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Town Hall	Weekday	9:00 AM - 4:30 PM
Town Hall	Weekend	Closed

2.4 Building Envelope

The building has a concrete foundation. Exterior walls are brick masonry faced with concrete brick construction. The windows throughout the facility are in appropriate aging condition. They are typically single paned, with clear glass and wood frames. The roofing system consists of pitched roof sections with slate roofing tiles and a small center flat membrane roof housing the rooftop HVAC units. The roofs appear to be in good condition. The exterior doors are constructed of wood. The door seals throughout the building were observed to be in fair condition. Overall, the Town Hall building is in appropriate aging condition with outside air infiltration through windows and doors.



Image 2: Town Hall Building Envelope

2.5 On-Site Generation

The Town Hall does not have any on-site electric generation capacity.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

The interior lighting in the Maplewood Town Hall consists mostly of 32-Watt linear fluorescent T8 fixtures with electronic ballasts and compact fluorescent fixtures. The server room and the basement storage room are illuminated with 40-Watt T12 lamps. The main lobby, court room and the front entrance are primarily lit with compact fluorescent lamps. The main lobby and the court house also have some candelabra lamps. The remaining Town Hall spaces are illuminated with 32-Watt linear fluorescent lamps. The exit signs throughout the Town Hall building are LED. Lighting is controlled throughout the building by manual wall switches except for the restrooms which have occupancy sensors. Exterior building and site illumination is provided by HID lamps of approximately 50-Watt, 150-Watt and 175-Watt. The flat roof housing the HVAC equipment is illuminated with three halogen incandescent flood lamps of approximately 500-Watt. Exterior fixtures are controlled with timers and photocells.



Image 3: Interior Lighting

Steam Heating System

The steam system consists of one Best Boiler 2,678 MBh output steam boiler. The boiler is 11 years old and has a combustion efficiency of 83%. It has a 1.5 hp forced draft fan with discharge dampers to control the volume of combustion air. There is one constant speed 0.8 hp feed water pump and two 0.8 hp condensate pumps. The water level in the boiler is controlled by a valve. Steam is supplied to the radiators for heating at 15 psig. Space temperatures are controlled by local thermostats. The boiler is well maintained.



Image 4: Steam Boiler

Direct Expansion Air Conditioning System (DX)

The DX system consists of six split air conditioners of various size and two Lennox packaged AC units. The split system ACs have passed their useful service life and appear in poor condition. The two Lennox packaged ACs are equipped with gas fired furnace sections that provide heating as needed. Refer to the table below for the observed condition of the units. They are controlled with programmable thermostats.

System Type	Qty	Cooling Capacity (Ton)	Heating Capacity (MBh)	Areas Served	Manufacturer	Age (Years)	Condition
Split System AC	1	7.5	N/A	Offices	Lennox	20	Poor
Packaged AC	2	3	84	Offices/Conf Room	Lennox	6	Good
Split System AC	2	7.5	N/A	First Floor	Carrier	20	Poor
Split System AC	1	1.5	N/A	Main Server Room	Liebert	15	Poor
Split System AC	1	7.5	N/A	Clerk Offices	Worthington	20	Poor
Split System AC	1	7.5	N/A	Finance Offices	Luxaire	20	Poor



Image 5: Split System AC



Image 6: Lennox Packaged AC

Ventilation System

Two air handlers located in the attic provide ventilation for the conference room and restrooms. Each is equipped with a constant speed supply fan motor, approximately 2 hp and 1.5 hp respectively.

Domestic Hot Water Heating System

Domestic hot water for the Town Hall is provided by one Bradford White gas fired non-condensing hot water heater with an input rating of 40 MBh and a nominal efficiency of 80%. The water heater has a 40 gallon storage tank. It is in good condition.

Building Plug Load

There are approximately 38 computer work stations throughout the facility and they are mostly desktop units with LCD monitors. There is no centralized PC power management software installed.

There is one main server room with cooling provided by one 1.5 ton dedicated Liebert split air conditioner. We also counted approximately 5 copy machines, 15 printers, 6 microwaves and 2 water coolers. There are two vending machines located in the basement kitchen.

2.7 Water-Using Systems

There are several restrooms at the Town Hall. A sampling of restrooms found that some of the faucets are rated for 2.5 gallons per minute (gpm) or higher, the toilets are rated at 2.5 gallons per flush (gpf) and the urinals are rated at 2 gpf.

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Town Hall		
Fuel	Usage	Cost
Electricity	102,630 kWh	\$18,989
Natural Gas	12,233 Therms	\$11,160
Total		\$30,150

The current annual energy cost for this facility is \$30,150 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.185/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Town Hall					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
2/19/16	28	8,340	29	\$126	\$1,177
3/18/16	31	7,770	25	\$108	\$1,083
4/18/16	30	6,840	26	\$115	\$982
5/18/16	31	9,000	30	\$131	\$1,269
6/17/16	30	8,370	49	\$217	\$1,734
7/20/16	31	13,890	49	\$217	\$2,477
8/18/16	31	10,680	46	\$202	\$2,970
9/16/16	30	9,660	44	\$196	\$1,860
10/17/16	31	8,550	44	\$198	\$1,478
11/19/16	30	6,660	50	\$174	\$1,165
12/16/16	31	6,780	23	\$79	\$1,094
1/18/17	31	6,090	25	\$113	\$1,702
Totals	365	102,630	49.5	\$1,874	\$18,989
Annual	365	102,630	49.5	\$1,874	\$18,989

3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.912/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for Town Hall			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
2/19/16	28	2,802	\$2,173
3/18/16	31	1,358	\$1,220
4/18/16	30	1,125	\$664
5/18/16	31	967	\$601
6/17/16	30	628	\$429
7/20/16	31	383	\$526
8/18/16	31	0	\$107
9/16/16	30	0	\$107
10/17/16	31	120	\$182
11/19/16	30	603	\$904
12/16/16	31	1,713	\$1,734
1/18/17	31	2,534	\$2,512
Totals	365	12,233	\$11,160
Annual	365	12,233	\$11,160

3.4 Benchmarking

This facility was benchmarked using *Portfolio Manager*[®], an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR[®] program. *Portfolio Manager*[®] analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR[®] score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Town Hall	National Median Building Type: Municipal
Source Energy Use Intensity (kBtu/ft ²)	107.9	148.1
Site Energy Use Intensity (kBtu/ft ²)	71.2	67.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Town Hall	National Median Building Type: Municipal
Source Energy Use Intensity (kBtu/ft ²)	93.1	148.1
Site Energy Use Intensity (kBtu/ft ²)	66.5	67.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR[®] score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75% of all similar buildings nationwide and may be eligible for ENERGY STAR[®] certification. This facility has a current score of 89.

A *Portfolio Manager*[®] Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR[®] Statement of Energy Performance.


For more information on ENERGY STAR[®] certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A *Portfolio Manager*[®] account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in *Portfolio Manager*[®] regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR[®] *Portfolio Manager*[®] to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Town Hall regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		26,202	6.8	0.0	\$4,848.05	\$23,292.03	\$2,945.00	\$20,347.03	4.2	26,385
ECM 1	Install LED Fixtures	12,369	1.9	0.0	\$2,288.62	\$8,345.32	\$1,515.00	\$6,830.32	3.0	12,456
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	1,069	0.4	0.0	\$197.72	\$1,244.00	\$20.00	\$1,224.00	6.2	1,076
ECM 3	Retrofit Fixtures with LED Lamps	12,764	4.5	0.0	\$2,361.71	\$13,702.71	\$1,410.00	\$12,292.71	5.2	12,853
Lighting Control Measures		2,355	0.8	0.0	\$435.67	\$3,844.00	\$390.00	\$3,454.00	7.9	2,371
ECM 4	Install Occupancy Sensor Lighting Controls	2,061	0.7	0.0	\$381.33	\$3,244.00	\$390.00	\$2,854.00	7.5	2,075
ECM 5	Install High/Low Lighting Controls	294	0.1	0.0	\$54.34	\$600.00	\$0.00	\$600.00	11.0	296
Domestic Water Heating Upgrade		0	0.0	0.6	\$5.56	\$35.85	\$0.00	\$35.85	6.5	71
ECM 6	Install Low-Flow Domestic Hot Water Devices	0	0.0	0.6	\$5.56	\$35.85	\$0.00	\$35.85	6.5	71
Plug Load Equipment Control - Vending Machine		1,954	0.0	0.0	\$361.61	\$460.00	\$0.00	\$460.00	1.3	1,968
ECM 7	Vending Machine Control	1,954	0.0	0.0	\$361.61	\$460.00	\$0.00	\$460.00	1.3	1,968
TOTALS		30,511	7.6	0.6	\$5,650.88	\$27,631.88	\$3,335.00	\$24,296.88	4.3	30,795

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		26,202	6.8	0.0	\$4,848.05	\$23,292.03	\$2,945.00	\$20,347.03	4.2	26,385
ECM 1	Install LED Fixtures	12,369	1.9	0.0	\$2,288.62	\$8,345.32	\$1,515.00	\$6,830.32	3.0	12,456
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	1,069	0.4	0.0	\$197.72	\$1,244.00	\$20.00	\$1,224.00	6.2	1,076
ECM 3	Retrofit Fixtures with LED Lamps	12,764	4.5	0.0	\$2,361.71	\$13,702.71	\$1,410.00	\$12,292.71	5.2	12,853

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	12,369	1.9	0.0	\$2,288.62	\$8,345.32	\$1,515.00	\$6,830.32	3.0	12,456

Measure Description

We recommend replacing fixtures which contain HID, and halogen incandescent flood lamps with new high performance LED light fixtures, mainly for the building exterior and parking. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of HID sources and more than ten times longer than many incandescent lamps.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	1,069	0.4	0.0	\$197.72	\$1,244.00	\$20.00	\$1,224.00	6.2	1,076
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing T12 fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten times longer than many incandescent lamps.

ECM 3: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	12,606	4.5	0.0	\$2,332.53	\$13,570.56	\$1,410.00	\$12,160.56	5.2	12,695
Exterior	158	0.0	0.0	\$29.18	\$132.15	\$0.00	\$132.15	4.5	159

Measure Description

We recommend retrofitting existing T8 fluorescent, incandescent and compact fluorescent lamps with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for upgrades to existing lighting controls are summarized in Figure 17 below.

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		2,355	0.8	0.0	\$435.67	\$3,844.00	\$390.00	\$3,454.00	7.9	2,371
ECM 4	Install Occupancy Sensor Lighting Controls	2,061	0.7	0.0	\$381.33	\$3,244.00	\$390.00	\$2,854.00	7.5	2,075
ECM 5	Install High/Low Lighting Controls	294	0.1	0.0	\$54.34	\$600.00	\$0.00	\$600.00	11.0	296

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 4: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
2,061	0.7	0.0	\$381.33	\$3,244.00	\$390.00	\$2,854.00	7.5	2,075

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in many offices, conference room and other selected areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 5: Install High/Low Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
294	0.1	0.0	\$54.34	\$600.00	\$0.00	\$600.00	11.0	296

Measure Description

We recommend installing occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons. Typical areas for such lighting control are stairwells, interior corridors.

Lighting fixtures with these controls operate at default low levels when the area is not occupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. The lighting systems are switched to full lighting levels whenever an occupant is detected. Fixtures are automatically switched back to low level after an area has been vacant for a preset period of time. Energy savings results from only providing full lighting levels when it is required.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage needs to be provided to ensure that lights turn on in each area as an occupant approaches.

Additional savings from reduced lighting maintenance may also result from this measure, due to reduced lamp operation.

4.1.3 Domestic Hot Water Heating System Upgrades

Our recommendation for domestic water heating system improvements is summarized in Figure 18 below.

Figure 18 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade	0	0.0	0.6	\$5.56	\$35.85	\$0.00	\$35.85	6.5	71
ECM 6 Install Low-Flow Domestic Hot Water Devices	0	0.0	0.6	\$5.56	\$35.85	\$0.00	\$35.85	6.5	71

ECM 6: Install Low-Flow DHW Devices

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
0	0.0	0.6	\$5.56	\$35.85	\$0.00	\$35.85	6.5	71

Measure Description

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators can reduce hot water usage, relative to standard aerators, which saves energy.

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

4.1.4 Plug Load Equipment Control - Vending Machines

Our recommendation for upgrades to plug load equipment control – vending machines is summarized in Figure 19 below.

Figure 19 - Summary of Plug Load Equipment Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Plug Load Equipment Control - Vending Machine		1,954	0.0	0.0	\$361.61	\$460.00	\$0.00	\$460.00	1.3	1,968
ECM 7	Vending Machine Control	1,954	0.0	0.0	\$361.61	\$460.00	\$0.00	\$460.00	1.3	1,968

ECM 7: Vending Machine Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,954	0.0	0.0	\$361.61	\$460.00	\$0.00	\$460.00	1.3	1,968

Measure Description

Vending machines operate continuously, even during non-business hours. We recommend installing occupancy sensor controls to reduce the energy use. These controls power down vending machines when the vending machine area has been vacant for some time, then power up at regular intervals, as needed, to turn machine lights on or keep the product cool. Energy savings are a dependent on vending machine and activity level in the area surrounding the machines.

4.2 ECMs Evaluated but Not Recommended

The measures below have been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in each measure description section.

Figure 20 – Summary of Measures Evaluated, But Not Recommended

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Motor Upgrades	109	0.1	0.0	\$20.23	\$532.17	\$0.00	\$532.17	26.3	110
Premium Efficiency Motors	109	0.1	0.0	\$20.23	\$532.17	\$0.00	\$532.17	26.3	110
Electric Unitary HVAC Measures	7,026	6.3	0.0	\$1,299.97	\$45,885.71	\$2,875.50	\$43,010.21	33.1	7,075
Install High Efficiency Electric AC	7,026	6.3	0.0	\$1,299.97	\$45,885.71	\$2,875.50	\$43,010.21	33.1	7,075
TOTALS	7,135	6.4	0.0	\$1,320.19	\$46,417.88	\$2,875.50	\$43,542.38	33.0	7,185

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Premium Efficiency Motors

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
109	0.1	0.0	\$20.23	\$532.17	\$0.00	\$532.17	26.3	110

Measure Description

We evaluated replacing the 2 hp standard efficiency Conference room supply fan motor with *NEMA Premium™* efficiency motors. Our evaluation assumes that existing motor will be replaced with motor of equivalent size and type. Although occasionally additional savings can be achieved by downsizing motor to better meet the motor's current load requirements. The base case motor efficiencies are estimated from nameplate information and our best estimates of motor run hours. Efficiencies of proposed motor upgrades are obtained from the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings (2016)*. Savings are based on the difference between baseline and proposed efficiencies and the assumed annual operating hours.

Reasons for not Recommending

We evaluated this motor as it is one of the older motors, at the end of its expected useful life. However, the simple payback of this measure exceeds the expected useful life of the proposed equipment and is therefore not recommended on the basis of energy savings alone.

Install High Efficiency Air Conditioning Units

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
7,026	6.3	0.0	\$1,299.97	\$45,885.71	\$2,875.50	\$43,010.21	33.1	7,075

Measure Description

We evaluated replacing the older standard efficiency split air conditioning units with high efficiency split air conditioning units. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Reasons for not Recommending

The simple payback of this measure exceeds the expected useful life of the proposed equipment and is therefore not recommended on the basis of energy savings alone. However, as the units have passed their useful service life and appear to be in poor condition, it is likely in the best interest of the township to replace the split system air conditioners prior to catastrophic failure.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20%-60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6–12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Use Fans to Reduce Cooling Load

Utilizing ceiling fans to supplement cooling is a low cost strategy to reduce cooling load considerably. Thermostat settings can be increased by 4°F with no change in overall occupant comfort when the wind chill effect of moving air is employed for cooling.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5°F-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Repair/Replace Steam Traps

Properly functioning steam traps ensure that all latent heat in the steam is delivered to the end use by preventing pressurized steam from leaking. Steam traps should be inspected as part of the regular steam system maintenance. Traps that are blocked, venting, or allowing steam to leak through should be repaired or replaced. Repairing or replacing existing steam traps will reduce steam losses.

Perform Proper Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up in order to sustain efficiency and equipment life.

Perform Proper Furnace Maintenance

Preventative furnace maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should include tasks such as checking for gas/carbon monoxide leaks; changing the air and fuel filters; checking components for cracks, corrosion, dirt, or debris build-up; ensuring the ignition system is working properly; testing and adjusting operation and safety controls; inspecting the electrical connections; and ensuring proper lubrication for motors and bearings.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gpf and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.3 for any low-flow ECM recommendations.

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a Low potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

Figure 21 - Photovoltaic Screening



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility’s ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a Low potential for installing a cost-effective CHP system.

Low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/.

Figure 22 - Combined Heat and Power Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion, the Town Hall has no potential for DR curtailment.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund, your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 23 for a list of the eligible programs identified for each recommended ECM.

Figure 23 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	X		X			
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X		X			
ECM 3	Retrofit Fixtures with LED Lamps	X		X			
ECM 4	Install Occupancy Sensor Lighting Controls	X		X			
ECM 5	Install High/Low Lighting Controls			X			
ECM 6	Install Low-Flow Domestic Hot Water Devices			X			
ECM 7	Vending Machine Control			X			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program description and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e., non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Server Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	1,950	Relamp & Reballast	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.09	264	0.0	\$48.85	\$350.00	\$40.00	6.35
Basement - Kitchen	7	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	No	7	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	1,950	0.16	463	0.0	\$85.69	\$442.40	\$0.00	5.16
Basement - Storage	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,950	0.03	75	0.0	\$13.93	\$58.50	\$10.00	3.48
Basement - Storage	1	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	1,950	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 8' Lamps	Wall Switch	72	1,950	0.07	196	0.0	\$36.30	\$202.00	\$0.00	5.56
Basement	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.30	856	0.0	\$158.43	\$796.50	\$125.00	4.24
Basement	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Basement	3	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	3	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.03	82	0.0	\$15.20	\$132.15	\$0.00	8.70
Storage Room	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.17	476	0.0	\$88.02	\$408.50	\$50.00	4.07
Storage Room	4	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	1,950	Relamp & Reballast	Yes	4	LED - Linear Tubes: (2) 8' Lamps	Occupancy Sensor	72	1,365	0.34	982	0.0	\$181.69	\$924.00	\$0.00	5.09
Mechanical Room	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	No	5	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,950	0.13	376	0.0	\$69.65	\$292.50	\$50.00	3.48
Mechanical Room	2	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	2	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.02	55	0.0	\$10.13	\$88.10	\$0.00	8.70
Storage Room	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.10	285	0.0	\$52.81	\$291.50	\$30.00	4.95
Storage Room	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Women Restroom	2	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	2	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.02	55	0.0	\$10.13	\$88.10	\$0.00	8.70
Main Lobby	17	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	Yes	17	LED Screw-In Lamps: LED Screw-In Lamps	High/Low Control	11	1,365	0.21	593	0.0	\$109.80	\$948.87	\$0.00	8.64
Main Lobby	12	Compact Fluorescent: Screw in	Wall Switch	34	1,950	Relamp	Yes	12	LED Screw-In Lamps: LED Screw-In Lamps	High/Low Control	19	1,365	0.20	567	0.0	\$104.86	\$728.61	\$0.00	6.95
Main Lobby	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Lobby	4	Incandescent: Candelabra	Wall Switch	40	1,950	Relamp	No	4	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	7	1,950	0.11	301	0.0	\$55.72	\$175.81	\$20.00	2.80
Clerk Department	7	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,950	Relamp	Yes	7	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,365	0.41	1,172	0.0	\$216.90	\$935.93	\$175.00	3.51
Storage Room	1	Compact Fluorescent: Screw in	Wall Switch	34	1,950	Relamp	No	1	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	19	1,950	0.01	34	0.0	\$6.33	\$44.05	\$0.00	6.96
Clerk Department	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 102	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,950	Relamp	Yes	1	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,365	0.06	167	0.0	\$30.99	\$211.13	\$20.00	6.17
Room 101	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,950	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,365	0.12	335	0.0	\$61.97	\$306.27	\$60.00	3.97
Office	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	4	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,365	0.12	355	0.0	\$65.68	\$368.80	\$20.00	5.31
Room 104	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,950	Relamp	Yes	1	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,365	0.06	167	0.0	\$30.99	\$211.13	\$20.00	6.17

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Occupancy Sensor	62	1,456	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,456	0.02	49	0.0	\$9.14	\$63.20	\$0.00	6.91
Room 105	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	114	1,456	Relamp	No	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,456	0.09	191	0.0	\$35.30	\$190.27	\$40.00	4.26
Conference Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,950	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,365	0.23	670	0.0	\$123.94	\$496.53	\$100.00	3.20
Court Room	48	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	48	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.46	1,314	0.0	\$243.15	\$2,114.45	\$0.00	8.70
Court Room	24	Incandescent: Candelabra	Wall Switch	40	1,950	Relamp	No	24	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	7	1,950	0.63	1,807	0.0	\$334.33	\$1,054.87	\$120.00	2.80
Court Room	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 106	5	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,950	Relamp	Yes	5	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,365	0.29	837	0.0	\$154.93	\$591.67	\$120.00	3.04
Room 108	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	114	1,456	Relamp	No	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,456	0.18	382	0.0	\$70.60	\$380.53	\$80.00	4.26
Room 108	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Finance Department	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.46	1,332	0.0	\$246.44	\$1,359.00	\$210.00	4.66
Main Server Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,950	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,365	0.10	285	0.0	\$52.81	\$266.40	\$50.00	4.10
Storage Room	1	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	1	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.01	27	0.0	\$5.07	\$44.05	\$0.00	8.70
Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.13	381	0.0	\$70.41	\$350.00	\$60.00	4.12
Corridor	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	1,365	0.10	285	0.0	\$52.81	\$375.50	\$30.00	6.54
Corridor	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Stairwell	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,950	0.03	75	0.0	\$13.93	\$58.50	\$10.00	3.48
Stairwell	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Occupancy Sensor	62	1,456	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,456	0.02	49	0.0	\$9.14	\$63.20	\$0.00	6.91
Women Restroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Occupancy Sensor	62	1,456	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,456	0.02	49	0.0	\$9.14	\$63.20	\$0.00	6.91
Corridor	3	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	3	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.03	82	0.0	\$15.20	\$132.15	\$0.00	8.70
Room 201	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.60	1,712	0.0	\$316.86	\$1,593.00	\$250.00	4.24
Room 201	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room 201	1	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	1	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.01	27	0.0	\$5.07	\$44.05	\$0.00	8.70
Room 201 - Kitchen	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,950	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,365	0.10	285	0.0	\$52.81	\$291.50	\$50.00	4.57
Room 201	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,950	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,365	0.20	571	0.0	\$105.62	\$416.80	\$80.00	3.19

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Attic Floor	11	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	11	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.11	301	0.0	\$55.72	\$484.56	\$0.00	8.70
Front Entrance Recessed Lights	5	Compact Fluorescent: Screw in	Wall Switch	23	1,950	Relamp	No	5	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	11	1,950	0.05	137	0.0	\$25.33	\$220.26	\$0.00	8.70
Exterior Front Entrance Lights	3	Compact Fluorescent: Screw in	Daylight Dimming	23	4,380	Relamp	No	3	LED Screw-In Lamps: LED Screw-In Lamps	Daylight Dimming	11	4,380	0.03	184	0.0	\$34.13	\$132.15	\$0.00	3.87
Exterior Wall Pack	8	Metal Halide: (1) 50W Lamp	Daylight Dimming	72	4,380	Fixture Replacement	No	8	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	11	4,380	0.39	2,501	0.0	\$462.72	\$3,125.42	\$800.00	5.03
Roof	3	Halogen Incandescent: Flood Lights	Daylight Dimming	500	4,380	Fixture Replacement	No	3	LED - Fixtures: Outdoor Post-Mount	Daylight Dimming	55	4,380	1.06	6,841	0.0	\$1,265.83	\$1,719.90	\$15.00	1.35
Parking Lot	7	High-Pressure Sodium: (1) 150W Lamp	Daylight Dimming	188	4,380	Fixture Replacement	No	7	LED - Fixtures: Parking Garage Fixture	Daylight Dimming	45	4,380	0.80	5,130	0.0	\$949.14	\$3,500.00	\$700.00	2.95

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement	Elevator	1	Process Pump	5.0	82.0%	No	780	No	82.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Boiler	1	Boiler Feed Water Pump	0.8	78.0%	No	910	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Condensate	2	Other	0.8	78.0%	No	910	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Basement - Kitchen	Kitchen	2	Exhaust Fan	0.3	78.0%	No	1,690	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Mechanical Room	1	Exhaust Fan	0.1	78.0%	No	1,690	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Air Compressor	1	Air Compressor	0.3	78.0%	No	1,690	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Boiler	1	Combustion Air Fan	1.5	84.0%	No	910	No	84.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Attic Floor	Conference Room	1	Supply Fan	2.0	80.0%	No	1,300	Yes	86.5%	No		0.06	109	0.0	\$20.23	\$532.17	\$0.00	26.31
Attic Floor	Restrooms	1	Supply Fan	1.5	84.0%	No	1,690	No	84.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Mechanical Room	1	Other	1.0	82.0%	No	520	No	82.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions									Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Rooftop	Administration Offices	1	Split-System AC	7.50		Yes	1	Split-System AC	7.50		12.00		No	1.19	1,494	0.0	\$276.40	\$8,728.28	\$547.50	29.60
Rooftop	Administration Offices/Conference Room	2	Packaged AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Attic Floor	First Floor	2	Split-System AC	7.50		Yes	2	Split-System AC	7.50		12.00		No	2.38	2,561	0.0	\$473.82	\$17,456.55	\$1,095.00	34.53
Ground Floor	Main Server Room	1	Split-System AC	1.50		Yes	1	Split-System AC	1.50		14.00		No	0.38	410	0.0	\$75.93	\$2,244.33	\$138.00	27.74
Ground Floor	Clerk Offices	1	Split-System AC	7.50		Yes	1	Split-System AC	7.50		12.00		No	1.19	1,280	0.0	\$236.91	\$8,728.28	\$547.50	34.53
Ground Floor	Finance Offices	1	Split-System AC	7.50		Yes	1	Split-System AC	7.50		12.00		No	1.19	1,280	0.0	\$236.91	\$8,728.28	\$547.50	34.53

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions							Energy Impact & Financial Analysis								
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years		
Rooftop	Administration Offices/Conference Room	2	Furnace	84.00	No								0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Town Hall	1	Forced Draft Steam Boiler	2,678.00	No								0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis									
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years			
Mechanical Room	Town Hall	1	Storage Tank Water Heater (≤ 50 Gal)	No									0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis						
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Town Hall Restrooms	5	Faucet Aerator (Lavatory)	2.50	1.00	0.00	0	0.6	\$5.56	\$35.85	\$0.00	6.45

Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Town Hall	6	Microwave	800.0	No
Town Hall	2	Refrigerator	185.0	Yes
Town Hall	2	Toaster	700.0	No
Town Hall	15	Printer	85.0	Yes
Town Hall	38	Computer with LCD Monitor	191.0	Yes
Town Hall	5	Copy Machine	500.0	Yes
Town Hall	2	Water Cooler	272.0	Yes
Town Hall	4	Coffee Machine	600.0	No
Town Hall	1	Small Freezer	45.0	Yes
Town Hall	1	TV	124.0	Yes

Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement - Kitchen	1	Refrigerated	Yes	0.00	1,612	0.0	\$298.23	\$230.00	\$0.00	0.77
Basement - Kitchen	1	Non-Refrigerated	Yes	0.00	343	0.0	\$63.37	\$230.00	\$0.00	3.63

Appendix B: ENERGY STAR® Statement of Energy Performance



LEARN MORE AT energystar.gov

ENERGY STAR® Statement of Energy Performance

89

ENERGY STAR®
Score¹

Maplewood Town Hall (Main Building)

Primary Property Type: Office
Gross Floor Area (ft²): 22,100
Built: 1931

For Year Ending: December 31, 2016
Date Generated: May 27, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Maplewood Town Hall (Main Building) 574 Valley Street Maplewood, New Jersey 07040	Property Owner Township of Maplewood 574 Valley Street Maplewood, NJ 07040 (973) 762-8120	Primary Contact Joseph Manning 574 Valley Street Maplewood, NJ 07040 (973) 762-8120 Ext. 2000 twpadmin@twp.maplewood.nj.us
Property ID: 6359501		

Energy Consumption and Energy Use Intensity (EUI)				
Site EUI 71.8 kBtu/ft ²	Annual Energy by Fuel		National Median Comparison	
	Natural Gas (kBtu)	1,229,880 (78%)		National Median Site EUI (kBtu/ft ²)
	Electric - Grid (kBtu)	356,855 (22%)	National Median Source EUI (kBtu/ft ²)	191.8
			% Diff from National Median Source EUI	-43%
Source EUI 109.1 kBtu/ft ²			Annual Emissions	
			Greenhouse Gas Emissions (Metric Tons CO2e/year)	105

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

() _____



Professional Engineer Stamp
(if applicable)