



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

The Construction and Zoning Building (new)

119 Wells Mills Rd
Waretown, NJ 08758

Ocean Township

November 6, 2018

Final Report by:
TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	5
2.1	Project Contacts	5
2.2	General Site Information.....	5
2.3	Building Occupancy	5
2.4	Building Envelope	6
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems	6
	Lighting System	6
	Motors 6	6
	Hot Water Heating System.....	7
	Cooling System	7
	Domestic Hot Water Heating System.....	7
	HVAC Controls	8
	Building Plug Load	8
2.7	Water-Using Systems	8
3	Site Energy Use and Costs.....	9
3.1	Total Cost of Energy	9
3.2	Electricity Usage	10
3.3	Natural Gas Usage	11
3.4	Benchmarking.....	12
3.5	Energy End-Use Breakdown	13
4	Energy Conservation Measures	14
4.1	Recommended ECMs	14
4.1.1	Lighting Upgrades.....	15
	ECM 1: Install LED Fixtures	15
	ECM 2: Retrofit Fixtures with LED Lamps.....	16
4.1.2	Lighting Control Measures	17
	ECM 3: Install Occupancy Sensor Lighting Controls	17
	ECM 4: Install Photocell Control.....	18
4.1.3	Electric Unitary HVAC Measures	19
	ECM 5: Install High Efficiency Air Conditioning Units.....	19
4.1.4	HVAC System Upgrades.....	20

ECM 6: Install Programmable Thermostats.....	20
4.1.5 Domestic Hot Water Heating System Upgrades	21
ECM 7: Install Low-Flow DHW Devices.....	21
4.2 ECMs Evaluated But Not Recommended	22
Retrofit Fluorescent Fixtures with LED Lamps and Drivers	22
5 Energy Efficient Practices	23
Reduce Air Leakage	23
Close Doors and Windows	23
Perform Proper Lighting Maintenance.....	23
Develop a Lighting Maintenance Schedule	23
Ensure Lighting Controls Are Operating Properly	23
Perform Routine Motor Maintenance	24
Use Fans to Reduce Cooling Load	24
Install Destratification Fans.....	24
Practice Proper Use of Thermostat Schedules and Temperature Resets	24
Clean Evaporator/Condenser Coils on AC Systems	24
Clean and/or Replace HVAC Filters	24
Check for and Seal Duct Leakage	25
Perform Proper Boiler Maintenance.....	25
Perform Proper Water Heater Maintenance	25
Water Conservation	25
6 On-Site Generation Measures	26
6.1 Photovoltaic.....	26
7 Demand Response	27
8 Project Funding / Incentives	28
8.1 SmartStart	29
8.2 Direct Install	30
8.3 Energy Savings Improvement Program	30
8.4 Demand Response Energy Aggregator.....	31
9 Energy Purchasing and Procurement Strategies	32
9.1 Retail Electric Supply Options.....	32
9.2 Retail Natural Gas Supply Options	32

Appendix A: Equipment Inventory & Recommendations

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs 2

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Project Contacts 5

Figure 5 - Building Schedule..... 5

Figure 6 - Utility Summary 9

Figure 7 - Energy Cost Breakdown 9

Figure 8 - Electric Usage & Demand..... 10

Figure 9 - Electric Usage & Demand..... 10

Figure 10 - Natural Gas Usage..... 11

Figure 11 - Natural Gas Usage..... 11

Figure 12 - Energy Use Intensity Comparison – Existing Conditions..... 12

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 12

Figure 14 - Energy Balance (% and kBtu/SF) 13

Figure 15 – Summary of Recommended ECMs..... 14

Figure 16 – Summary of Lighting Upgrade ECMs..... 15

Figure 17 – Summary of Lighting Control ECMs 17

Figure 18 - Summary of Unitary HVAC ECMs..... 19

Figure 19 - Summary of HVAC System Improvement ECMs 20

Figure 20 - Summary of Domestic Water Heating ECMs 21

Figure 21 – Summary of Measures Evaluated, But Not Recommended 22

Figure 22 - Photovoltaic Screening 26

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for the Construction and Zoning Building.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist the Ocean Township in New Jersey with controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

The Construction and Zoning Building is approximately 3,650 square foot and is comprised of office space. This building will be the new space for the Construction and Zoning Building offices and was previously occupied by others. For the purposes of this report, estimated energy usage and savings are provided to encourage energy efficient upgrades and behaviors as the Ocean Township begins to operate the building.

The building will have open office space, private offices, a large storage/file room, and a kitchenette. The structure also has a basement which will be used for mechanical equipment and storage. The building's previous use and occupancy patterns will remain approximately the same when the Ocean Township operates the building. The building will be open Monday through Friday between 8:00 AM and 4:30 PM and will not be used on the weekends. The facility will be used year round. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated seven measures which together represent an opportunity for the Construction and Zoning Building (new) to reduce annual energy costs by \$1,468 and annual greenhouse gas emissions by 8,846 lbs CO₂e. We estimate that if all recommended measures are implemented, the project would pay for itself in energy savings in 10.3 years. A breakdown of current utility costs is shown in Figure 1. The estimated reduction in utility costs for the proposed measures is shown in Figure 2. Together these measures represent an opportunity to reduce The Construction and Zoning Building's annual energy use by 17%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of the Construction and Zoning Building’s (new) existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			4,199	2.3	0.0	\$739.18	\$9,853.81	\$740.00	\$9,113.81	12.3	4,228
ECM 1	Install LED Fixtures	Yes	1,040	0.2	0.0	\$183.14	\$1,475.15	\$120.00	\$1,355.15	7.4	1,048
	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	No	489	1.3	0.0	\$86.08	\$4,508.00	\$40.00	\$4,468.00	51.9	492
ECM 2	Retrofit Fixtures with LED Lamps	Yes	2,670	0.8	0.0	\$469.96	\$3,870.66	\$580.00	\$3,290.66	7.0	2,688
Lighting Control Measures			763	0.2	0.0	\$134.24	\$1,430.00	\$125.00	\$1,305.00	9.7	768
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	705	0.2	0.0	\$124.18	\$1,390.00	\$125.00	\$1,265.00	10.2	710
ECM 4	Install Photocell Controls	Yes	57	0.0	0.0	\$10.06	\$40.00	\$0.00	\$40.00	4.0	58
Electric Unitary HVAC Measures			1,370	2.2	0.0	\$241.20	\$4,787.90	\$736.00	\$4,051.90	16.8	1,380
ECM 5	Install High Efficiency Electric AC	Yes	1,370	2.2	0.0	\$241.20	\$4,787.90	\$736.00	\$4,051.90	16.8	1,380
HVAC System Improvements			381	0.0	7.5	\$141.91	\$659.74	\$0.00	\$659.74	4.6	1,259
ECM 6	Install Programmable Thermostats	Yes	381	0.0	7.5	\$141.91	\$659.74	\$0.00	\$659.74	4.6	1,259
Domestic Water Heating Upgrade			1,202	0.0	0.0	\$211.66	\$28.68	\$0.00	\$28.68	0.1	1,211
ECM 7	Install Low-Flow Domestic Hot Water Devices	Yes	1,202	0.0	0.0	\$211.66	\$28.68	\$0.00	\$28.68	0.1	1,211
TOTALS			7,916	4.7	7.5	\$1,468.19	\$16,760.13	\$1,601.00	\$15,159.13	10.3	8,846

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Electric Unitary HVAC measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air conditioning systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

HVAC System Improvements generally involve the installation of automated controls to reduce heating and cooling demand during periods of reduced demand. These measures could encompass changing temperature setpoints, using outside air for free cooling, or limiting excessive outside air during extreme outdoor air temperature conditions. These measures save energy by reducing the demand on HVAC systems and the amount of time systems operate.

Domestic Hot Water upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

Energy Efficient Practices

TRC also identified 15 low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and operation and maintenance costs. Potential opportunities identified at the Construction and Zoning Building include:

- Reduce Air Leakage
- Close Doors and Windows
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Perform Routine Motor Maintenance
- Use Fans to Reduce Cooling Load
- Install Destratification Fans
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Check for and Seal Duct Leakage
- Perform Proper Boiler Maintenance
- Perform Proper Water Heater Maintenance
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for the Construction and Zoning Building. Based on the configuration of the site and its loads there is a low potential for installing any PV or combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Diane Ambrosio	Business Administrator	clerk@twpoceannj.gov	609-693-3302
Dan Kehoe	Foreman - Public Works		609-839-7701
Matt Ambrosio	Superintendent - Public Works		609-618-0892
TRC Energy Services			
Aimee Lalonde	Auditor	alalonde@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On June 27, 2017, TRC performed an energy audit at the Construction and Zoning Building located in Waretown, New Jersey. TRC’s team met with Diane Ambrosio, Business Administrator; Dan Kehoe, Foreman – Public Works; and Matt Ambrosio, Superintendent – Public Works to review the facility operations and help focus our investigation on specific energy-using systems.

The Construction and Zoning Building is approximately 3,650 square foot in size comprised of office space. This building will be the new space for Construction and Zoning Building offices and was previously occupied by others. For the purposes of this report, estimated energy usage and savings are provided to encourage energy efficient upgrades and behaviors as the Ocean Township begins to operate the building.

The building will have open office space, private offices, a large storage/file room, and a kitchenette. The structure also has a basement which will be used for mechanical equipment and storage. The building’s previous use and occupancy patterns will remain approximately the same when the Ocean Township operates the building.

2.3 Building Occupancy

The building is open Monday through Friday between 8:00 AM and 4:30 PM and is not used on the weekends. The typical schedule is presented in the table below. The entire facility will be used year round.

Figure 5 - Building Schedule

Building Occupancy Schedule		
Building Name	Weekday/Weekend	Operating Schedule
Construction & Zoning Building	Weekday	8:00 AM - 4:30 PM
Construction & Zoning Building	Weekend	No Use

2.4 Building Envelope

The building envelope is in good condition with exterior cladding. The building has a pitched roof which appears to be in good condition. The building has double-pane, operable windows with vinyl and the exterior doors are wooden with wooden frames and are both in good condition. It is good maintenance practice to ensure window and door frames are properly sealed with caulk materials and that exterior doors are properly weather-stripped. ASHRAE recommends that this be done every couple of years to reduce the amount of air infiltration.

2.5 On-Site Generation


The Construction and Zoning Building does not have any on-site electric generation capacity. There is no potential for installing a PV system.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

The building is primarily lit by linear fluorescent fixtures which contain T8 lamps. The majority of these fixtures are recessed troffer fixtures. The large file/storage room is lit by recessed can fixtures with compact fluorescent lamps. The basement is lit by linear fluorescent strip fixtures with T12 lamps. The exterior of the building overhang has recessed can fixtures with what are assumed to be mercury vapor lamps. There is also a wall pack fixture near an exterior door which has a compact fluorescent lamp and was noted to be on during the day. The fixtures are generally in good condition which provides a great opportunity for energy savings by retrofitting to LED technology.



The lighting fixtures in the building are controlled manually by wall switches.



Motors

The HVAC systems that serve the building include fan and pump motors which are generally in good condition and of standard to high efficiency. These include hot water pumps and supply fan motors. There is an opportunity for energy savings by installing variable frequency drives (VFDs) to control the supply fan motors in the air-handling units which serve the building, however this would be cost prohibitive.

Hot Water Heating System

The building is heated by a non-condensing, as-fired hot water boilers which are in good condition. The boilers provides hot water to baseboard radiators and heating coils in the air-handling units via heating hot water pumps. Outdoor air reset controls are used to help modulate boiler operations.



Cooling System

Two air-handling units equipped with heating and cooling coils supply conditioned air to the building. The condenser portion of the split-system air-conditioning equipment is in fair to poor condition and only standard efficiency. The refrigerant piping insulation is in poor condition or missing. We recommended insulating these as part of ongoing maintenance.



Domestic Hot Water Heating System

The building restroom sinks are supplied domestic hot water by an electric storage tank water heater that is located in the basement and is in fair condition. If this is scheduled for replacement as part of the renovations, we recommend considering the installation of a high efficiency gas-fired condensing tankless water heater. The sink aerators throughout the building are fit with higher flow devices (2.0 gallons per minute [gpm]). There is an opportunity for energy savings by replacing these aerators with low-flow devices. This is a cost effective approach to reducing energy used to provide hot water throughout the building.



HVAC Controls

The building's HVAC equipment is controlled by manual dial thermostats located in the space. There is an opportunity for energy savings by replacing these with programmable thermostats. These may be set to appropriate temperatures and match the building occupancy schedules. Temperatures should be set back at night and on weekends. We recommend installing pipe insulation around the refrigerant piping for the cooling side of the system.



Building Plug Load

There are plans to convert one of the spaces into a kitchenette. Also, there will be general office equipment in the building. We recommend installing ENERGY STAR® equipment where possible. We also recommend practicing energy conscious behavior by turning off equipment when not in use, and to consider the use of computer power management software.

2.7 Water-Using Systems

There are restrooms in the facility. A sampling of these spaces found that the faucets are rated for 2.0 gpm. There is an opportunity for energy savings by installing low flow devices throughout the building.

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Construction & Zoning Building (new)		
Fuel	Usage	Cost
Electricity	27,875 kWh	\$4,907
Natural Gas	1,099 Therms	\$1,099
Total		\$6,007

The current annual energy cost for this facility is \$6,007 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by JCP&L. The average electric cost over the past 12 months was \$0.176/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The electric demand and charges were not included as part of our analysis. The estimated monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Construction & Zoning Building (new)						
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost	TRC Estimated Usage?
8/26/15	28	3,148			\$554	Yes
9/28/15	33	2,031			\$358	Yes
10/29/15	31	2,031			\$358	Yes
11/27/15	29	2,031			\$358	Yes
12/29/15	32	2,031			\$358	Yes
1/30/16	32	2,031			\$358	Yes
2/26/16	27	2,031			\$358	Yes
3/28/16	31	2,031			\$358	Yes
4/26/16	29	2,031			\$358	Yes
5/26/16	30	2,031			\$358	Yes
6/23/16	28	3,148			\$554	Yes
7/26/16	33	3,148			\$554	Yes
Totals	363	27,723	0	\$0	\$4,880	12
Annual	365	27,875	0	\$0	\$4,907	

3.3 Natural Gas Usage

Natural gas is provided by NJ Natural Gas. The average gas cost for the past 12 months is \$1.000/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for NEW Construction & Zoning Building				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
8/26/15	28	0	\$0	Yes
9/28/15	33	0	\$0	Yes
10/29/15	31	0	\$0	Yes
11/27/15	29	22	\$22	Yes
12/29/15	32	120	\$120	Yes
1/30/16	32	142	\$142	Yes
2/26/16	27	317	\$317	Yes
3/28/16	31	284	\$284	Yes
4/26/16	29	98	\$98	Yes
5/26/16	30	98	\$98	Yes
6/23/16	28	11	\$11	Yes
7/26/16	33	0	\$0	Yes
Totals	363	1,093	\$1,093	12
Annual	365	1,099	\$1,099	

3.4 Benchmarking

This facility was benchmarked using *Portfolio Manager*[®], an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR[®] program. *Portfolio Manager*[®] analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR[®] score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Construction & Zoning Building (new)	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	113.5	148.1
Site Energy Use Intensity (kBtu/ft ²)	56.2	67.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures


Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Construction & Zoning Building (new)	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	89.5	148.1
Site Energy Use Intensity (kBtu/ft ²)	47.2	67.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR[®] score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75% of all similar buildings nationwide and may be eligible for ENERGY STAR[®] certification. Your building is not is one of the building categories that are eligible to receive a score.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Construction and Zoning Building regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		3,710	1.0	0.0	\$653.10	\$5,345.81	\$700.00	\$4,645.81	7.1	3,736
ECM 1	Install LED Fixtures	1,040	0.2	0.0	\$183.14	\$1,475.15	\$120.00	\$1,355.15	7.4	1,048
ECM 2	Retrofit Fixtures with LED Lamps	2,670	0.8	0.0	\$469.96	\$3,870.66	\$580.00	\$3,290.66	7.0	2,688
Lighting Control Measures		763	0.2	0.0	\$134.24	\$1,430.00	\$125.00	\$1,305.00	9.7	768
ECM 3	Install Occupancy Sensor Lighting Controls	705	0.2	0.0	\$124.18	\$1,390.00	\$125.00	\$1,265.00	10.2	710
ECM 4	Install Daylight Dimming Controls	57	0.0	0.0	\$10.06	\$40.00	\$0.00	\$40.00	4.0	58
Electric Unitary HVAC Measures		1,370	2.2	0.0	\$241.20	\$4,787.90	\$736.00	\$4,051.90	16.8	1,380
ECM 5	Install High Efficiency Electric AC	1,370	2.2	0.0	\$241.20	\$4,787.90	\$736.00	\$4,051.90	16.8	1,380
HVAC System Improvements		381	0.0	7.5	\$141.91	\$659.74	\$0.00	\$659.74	4.6	1,259
ECM 6	Install Programmable Thermostats	381	0.0	7.5	\$141.91	\$659.74	\$0.00	\$659.74	4.6	1,259
Domestic Water Heating Upgrade		1,202	0.0	0.0	\$211.66	\$28.68	\$0.00	\$28.68	0.1	1,211
ECM 7	Install Low-Flow Domestic Hot Water Devices	1,202	0.0	0.0	\$211.66	\$28.68	\$0.00	\$28.68	0.1	1,211
TOTALS		7,427	3.4	7.5	\$1,382.11	\$12,252.13	\$1,561.00	\$10,691.13	7.7	8,354

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		3,710	1.0	0.0	\$653.10	\$5,345.81	\$700.00	\$4,645.81	7.1	3,736
ECM 1	Install LED Fixtures	1,040	0.2	0.0	\$183.14	\$1,475.15	\$120.00	\$1,355.15	7.4	1,048
ECM 2	Retrofit Fixtures with LED Lamps	2,670	0.8	0.0	\$469.96	\$3,870.66	\$580.00	\$3,290.66	7.0	2,688

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	1,040	0.2	0.0	\$183.14	\$1,475.15	\$120.00	\$1,355.15	7.4	1,048

Measure Description

We recommend replacing existing fixtures containing fluorescent, or HID lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent lamps and more than ten times longer than many incandescent lamps.

ECM 2: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	2,670	0.8	0.0	\$469.96	\$3,870.66	\$580.00	\$3,290.66	7.0	2,688
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend re-lamping existing linear fluorescent fixtures by removing fluorescent tubes and replacing them with LEDs (assuming the existing ballasts are compatible with the proposed LED lamps). This measure uses the existing fixture housing but replaces the lamps with more efficient lighting technology. We also recommend replacing all compact fluorescent and incandescent lamps with LED lamps. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for upgrades to existing lighting controls are summarized in Figure 17 below.

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		763	0.2	0.0	\$134.24	\$1,430.00	\$125.00	\$1,305.00	9.7	768
ECM 3	Install Occupancy Sensor Lighting Controls	705	0.2	0.0	\$124.18	\$1,390.00	\$125.00	\$1,265.00	10.2	710
ECM 4	Install Daylight Dimming Controls	57	0.0	0.0	\$10.06	\$40.00	\$0.00	\$40.00	4.0	58

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 3: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
705	0.2	0.0	\$124.18	\$1,390.00	\$125.00	\$1,265.00	10.2	710

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in restrooms, storage rooms, hallways and offices areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 4: Install Photocell Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
57	0.0	0.0	\$10.06	\$40.00	\$0.00	\$40.00	4.0	58

Measure Description

We recommend installing photocell controls that use photosensors to limit the operation of exterior light fixtures to dusk to dawn hours only. This measure reduces energy use by ensuring exterior lighting only operates during night time.

4.1.3 Electric Unitary HVAC Measures

Our recommendation for unitary HVAC measures is summarized in Figure 18 below.

Figure 18 - Summary of Unitary HVAC ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Electric Unitary HVAC Measures		1,370	2.2	0.0	\$241.20	\$4,787.90	\$736.00	\$4,051.90	16.8	1,380
ECM 5	Install High Efficiency Electric AC	1,370	2.2	0.0	\$241.20	\$4,787.90	\$736.00	\$4,051.90	16.8	1,380

ECM 5: Install High Efficiency Air Conditioning Units

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,370	2.2	0.0	\$241.20	\$4,787.90	\$736.00	\$4,051.90	16.8	1,380

Measure Description

We recommend replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Since we believe the equipment is at or near the end of useful life, investment in new equipment is likely warranted in order to preserve ongoing functionality. The long payback projected for the replacement of this equipment indicates that this is primarily an infrastructure recapitalization measure rather than one dominated by energy savings.

4.1.4 HVAC System Upgrades

Our recommendation for HVAC system improvement are summarized in Figure 19 below.

Figure 19 - Summary of HVAC System Improvement ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
HVAC System Improvements		381	0.0	7.5	\$141.91	\$659.74	\$0.00	\$659.74	4.6	1,259
ECM 6	Install Programmable Thermostats	381	0.0	7.5	\$141.91	\$659.74	\$0.00	\$659.74	4.6	1,259

ECM 6: Install Programmable Thermostats

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
381	0.0	7.5	\$141.91	\$659.74	\$0.00	\$659.74	4.6	1,259

Measure Description

We recommend replacing manual thermostats with programmable thermostats. Manual thermostats are generally adjusted to a single heating and cooling setpoint and left at that setting regardless of occupancy in the area served by the HVAC equipment. As a result, the same level of heating and cooling is provided regardless of the occupancy in the space. Programmable thermostats can be set to maintain different temperature settings for different times of day and for different days of the week. By reducing heating temperature setpoints and raising cooling temperature setpoints when space are unoccupied, the operation of the HVAC equipment is reduced while still maintaining reasonable space temperatures for building usage at all times.

Programmable thermostats provide energy savings by reducing heating and cooling energy usage when a room is unoccupied.

4.1.5 Domestic Hot Water Heating System Upgrades

Our recommendation for domestic water heating system improvements is summarized in Figure 20 below.

Figure 20 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade	1,202	0.0	0.0	\$211.66	\$28.68	\$0.00	\$28.68	0.1	1,211
ECM 7 Install Low-Flow Domestic Hot Water Devices	1,202	0.0	0.0	\$211.66	\$28.68	\$0.00	\$28.68	0.1	1,211

ECM 7: Install Low-Flow DHW Devices

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,202	0.0	0.0	\$211.66	\$28.68	\$0.00	\$28.68	0.1	1,211

Measure Description

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators can reduce hot water usage, relative to standard aerators, which saves energy.

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

4.2 ECMs Evaluated But Not Recommended

The measures below have been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in each measure description section.

Figure 21 – Summary of Measures Evaluated, But Not Recommended

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades	489	1.3	0.0	\$86.08	\$4,508.00	\$40.00	\$4,468.00	51.9	492
Retrofit Fluorescent Fixtures with LED Lamps and Drivers	489	1.3	0.0	\$86.08	\$4,508.00	\$40.00	\$4,468.00	51.9	492
TOTALS	489	1.3	0.0	\$86.08	\$4,508.00	\$40.00	\$4,468.00	51.9	492

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	489	1.3	0.0	\$86.08	\$4,508.00	\$40.00	\$4,468.00	51.9	492
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing T12 fluorescent fixtures in the basement by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten times longer than many incandescent lamps.

Reasons for not Recommending

This measure is not cost effective. The light fixtures in the basement do not have enough run hours to financially justify this measure. We recommend considering this for consistency and general maintenance benefits.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20%-60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6–12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Perform Routine Motor Maintenance

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Use Fans to Reduce Cooling Load

Utilizing ceiling fans to supplement cooling is a low cost strategy to reduce cooling load considerably. Thermostat settings can be increased by 4°F with no change in overall occupant comfort when the wind chill effect of moving air is employed for cooling.

Install Destratification Fans

Allowing air to thermally stratify in spaces with high ceilings results in additional energy consumption by requiring the heating system to heat a volume of space much larger than the actual occupied space. Additional inefficiencies also occur because there are higher temperatures at the ceiling level than at the floor level. Higher temperatures at the ceiling accelerate heat loss through the roof, requiring additional energy consumption by the heating equipment in order to compensate for the accelerated heat transfer.

Destratification fans are specially designed to deliver a columnar, laminar flow of air balancing the air temperature from floor to ceiling. In addition to fuel savings, the use of destratification fans will reduce the recovery time necessary to warm the space after nightly temperature setbacks and will increase the comfort level of the occupants.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5°F-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Check for and Seal Duct Leakage

Duct leakage in commercial buildings typically accounts for 5% to 25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building, significantly increasing cooling and heating costs. By sealing sources of leakage, cooling, heating, and ventilation energy use can be reduced significantly, depending on the severity of air leakage.

Perform Proper Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up in order to sustain efficiency and equipment life.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.5 for any low-flow ECM recommendations.

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a Low potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

Figure 22 - Photovoltaic Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 24 for a list of the eligible programs identified for each recommended ECM.

Figure 24 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	x		x			
ECM 2	Retrofit Fixtures with LED Lamps	x		x			
ECM 3	Install Occupancy Sensor Lighting Controls	x		x			
ECM 4	Install Photocell Controls	x		x			
ECM 5	Install High Efficiency Electric AC						
ECM 6	Install Programmable Thermostats			x			
ECM 7	Install Low-Flow Domestic Hot Water Devices			x			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program description and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

8.4 Demand Response Energy Aggregator

The first step toward participation in a Demand Response (DR) program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (www.pjm.com/markets-and-operations/demand-response/csps.aspx). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (www.pjm.com/training/trainingmaterial.aspx), along with a variety of other program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding the program rules and requirements for metering and controls, a facility's ability to temporarily reduce electric load, as well as the payments involved in participating in the program. Also, these providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment to help ensure compliance of all terms and conditions of a DR contract.

See Section 7 for additional information.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e., non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Hallways	6	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	Yes	6	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,547	0.09	280	0.0	\$49.25	\$559.20	\$95.00	9.42
Restroom	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	No	2	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,210	0.03	83	0.0	\$14.57	\$96.40	\$20.00	5.25
Restroom	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	No	2	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,210	0.03	83	0.0	\$14.57	\$96.40	\$20.00	5.25
File Room	20	Compact Fluorescent Recessed Can Fixtures	Wall Switch	23	2,210	Relamp	Yes	20	LED Screw-In Lamps: Recessed Can Fixtures	Occupancy Sensor	9	1,547	0.27	864	0.0	\$152.03	\$1,345.06	\$35.00	8.62
Restroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,210	0.01	41	0.0	\$7.28	\$48.20	\$10.00	5.25
Restroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,210	0.01	41	0.0	\$7.28	\$48.20	\$10.00	5.25
Hallways	4	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,547	0.07	218	0.0	\$38.42	\$308.80	\$40.00	7.00
Open Office Area	24	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	Yes	24	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,547	0.40	1,309	0.0	\$230.50	\$1,426.80	\$275.00	5.00
Kitchenette	4	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,547	0.07	218	0.0	\$38.42	\$308.80	\$40.00	7.00
Conference Room	6	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	Yes	6	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,547	0.10	327	0.0	\$57.63	\$405.20	\$80.00	5.64
Office	4	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,547	0.07	218	0.0	\$38.42	\$308.80	\$40.00	7.00
Office	4	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,210	Relamp	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,547	0.07	218	0.0	\$38.42	\$308.80	\$40.00	7.00
Basement	20	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	250	Relamp & Reballast	No	20	LED - Linear Tubes: (2) 8' Lamps	Wall Switch	72	250	1.37	503	0.0	\$88.56	\$4,040.00	\$0.00	45.62
Basement	4	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	250	Relamp & Reballast	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	250	0.19	69	0.0	\$12.15	\$468.00	\$40.00	35.22
Exterior	1	Compact Fluorescent Wall Pack Fixture	None	23	8,760	Fixture Replacement	Yes	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	12	4,000	0.01	180	0.0	\$31.61	\$430.68	\$100.00	10.46
Exterior	4	Mercury Vapor: (1) 50W Lamp	None	74	4,000	Fixture Replacement	No	4	LED - Fixtures: Downlight Recessed	None	15	4,000	0.19	1,104	0.0	\$194.43	\$1,084.47	\$20.00	5.47

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement	Hot Water Pumps	2	Heating Hot Water Pump	0.2	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Basement	BARD Units	2	Supply Fan	0.5	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis								
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Indoor / Outdoor	BARD Forced Air Units	1	Split-System AC	4.00		Yes	1	Split-System AC	4.00		14.00		No	1.28	797	0.0	\$140.24	\$2,393.95	\$0.00	14.45
Indoor / Outdoor	BARD Forced Air Units	1	Split-System AC	4.00		Yes	1	Split-System AC	4.00		14.00		No	0.92	574	0.0	\$100.97	\$2,393.95	\$0.00	20.07

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis							
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Basement	Boilers	2	Non-Condensing Hot Water Boiler	137.00	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Programmable Thermostat Recommendations

Location	Area(s)/System(s) Affected	Recommendation Inputs				Energy Impact & Financial Analysis						
		Thermostat Quantity	Cooling Capacity of Controlled System (Tons)	Electric Heating Capacity of Controlled System (kBtu/hr)	Output Heating Capacity of Controlled System (MBh)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
File Room	BARD Unit	1	4.00		137.00	0.00	201	3.7	\$72.72	\$329.87	\$0.00	4.54
Open Office Area	BARD Unit	1	4.00		137.00	0.00	181	3.7	\$69.19	\$329.87	\$0.00	4.77

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement	Restrooms	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis							
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Restrooms	4	Faucet Aerator (Lavatory)	2.00	1.00	0.00	1,202	0.0	\$211.66	\$28.68	\$0.00	0.14	

Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Various	1	Office & Café Equipment	5,475.0	