



FINAL

Energy Audit Report Molitor Water Pollution Control Facility

December 2010



listen. think. deliver.

CDM[®]

Contents

Executive Summary

Section 1 Introduction

| | | |
|-----|-------------------------|-----|
| 1.1 | General..... | 1-1 |
| 1.2 | Background | 1-2 |
| 1.3 | Purpose and Scope | 1-3 |

Section 2 Facility Description

| | | |
|--------|--|------|
| 2.1 | Water Pollution Control Plant | 2-1 |
| 2.1.1 | Inlet Facilities | 2-2 |
| 2.1.2 | Primary Clarifiers | 2-2 |
| 2.1.3 | Primary Effluent Pump Station | 2-2 |
| 2.1.4 | Aeration Basins | 2-2 |
| 2.1.5 | Final Clarifiers 1 & 2 | 2-3 |
| 2.1.6 | Oxidation Ditches A & B | 2-3 |
| 2.1.7 | Final Clarifiers 3 & 4 | 2-3 |
| 2.1.8 | Stabilization Pond | 2-4 |
| 2.1.9 | Chlorine Contact Tanks | 2-4 |
| 2.1.10 | Anaerobic Digestion..... | 2-4 |
| 2.2 | Administration Building..... | 2-6 |
| 2.2.1 | Description of Building Envelope..... | 2-6 |
| 2.2.2 | Description of Building HVAC | 2-7 |
| 2.2.3 | Description of Building Lighting | 2-7 |
| 2.3 | Grit Building..... | 2-8 |
| 2.3.1 | Description of Building Envelope..... | 2-8 |
| 2.3.2 | Description of Building HVAC | 2-8 |
| 2.3.3 | Description of Building Lighting | 2-8 |
| 2.4 | Digester No. 1 Building | 2-8 |
| 2.4.1 | Description of Building Envelope..... | 2-8 |
| 2.4.2 | Description of Building HVAC | 2-8 |
| 2.4.3 | Description of Building Lighting | 2-9 |
| 2.5 | Digester No. 2 Building | 2-9 |
| 2.5.1 | Description of Building Envelope..... | 2-9 |
| 2.5.2 | Description of Building HVAC | 2-10 |
| 2.5.3 | Description of Building Lighting | 2-10 |
| 2.6 | Waste Oil Building | 2-10 |
| 2.6.1 | Description of Building Envelope..... | 2-10 |
| 2.6.2 | Description of Building HVAC | 2-10 |
| 2.6.3 | Description of Building Lighting | 2-11 |
| 2.7 | Blower Building..... | 2-11 |
| 2.7.1 | Description of Building Envelope..... | 2-11 |

- 2.7.2 Description of Building HVAC2-11
- 2.7.3 Description of Building Lighting2-11
- 2.8 Sludge Handling Building.....2-11
 - 2.8.1 Description of Building Envelope2-11
 - 2.8.2 Description of Building HVAC2-12
 - 2.8.3 Description of Building Lighting2-12
- 2.9 Final Clarifiers Building No 1 & 2.....2-12
 - 2.9.1 Description of Building Envelope2-12
 - 2.9.2 Description of Building HVAC2-12
 - 2.9.3 Description of Building Lighting2-12
- 2.10 Final Clarifiers Building No 3 & 4.....2-12
 - 2.10.1 Description of Building Envelope2-12
 - 2.10.2 Description of Building HVAC2-13
 - 2.10.3 Description of Building Lighting2-13

Section 3 Baseline Energy Use

- 3.1 Historical Data Analysis3-1
 - 3.1.1 Water Pollution Control Facility3-2
- 3.2 Aggregate Costs.....3-4
- 3.3 Portfolio Manager.....3-5
 - 3.3.1 Portfolio Manager Overview3-5
 - 3.3.2 Energy Performance Rating3-5
 - 3.3.3 Portfolio Manager Account Information.....3-5

Section 4 Energy Conservation and Retrofit Measures (ECRM)

- 4.1 Water Pollution Control Plant4-1
 - 4.1.1 Aeration Basins4-1
 - 4.1.2 Aeration System Improvement Alternatives.....4-7
 - 4.1.3 Economic Analysis4-9
 - 4.1.4 Oxidation Ditches.....4-11
 - 4.1.5 Stabilization Pond4-12
 - 4.1.6 Anaerobic Digestion System.....4-14
 - 4.1.6.1 Current Mode of Operation4-15
 - 4.1.6.2 Determination of the Maximum VS Loading to the
Primary Digesters.....4-18
 - 4.1.6.3 Addition of Fats, Oils and Grease (FOG)4-20
 - 4.1.6.4 Addition of Peat Humic Substance (PHS)4-23
 - 4.1.6.5 Economic Analysis4-25
- 4.2 Building HVAC Systems4-29
 - 4.2.1 Administration Building4-30
 - 4.2.2 Grit Building4-32
 - 4.2.3 Digester No. 1 Building4-33
 - 4.2.4 Digester No. 2 Building4-34

- 4.2.5 Waste Oil Building4-35
- 4.2.6 Blower Building.....4-36
- 4.2.7 Sludge Handling Building4-41
- 4.2.8 Final Clarifiers Building No. 1 & 2.....4-45
- 4.2.9 Final Clarifiers Building No. 3 & 4.....4-46

- 4.3 Building Lighting Systems4-47
 - 4.3.1 Administration Building4-48
 - 4.3.2 Grit Building4-49
 - 4.3.3 Digester No. 1 Building4-49
 - 4.3.4 Digester No. 2 Building4-50
 - 4.3.5 Waste Oil Building4-50
 - 4.3.6 Blower Building.....4-51
 - 4.3.7 Sludge Handling Building4-53
 - 4.3.8 Final Clarifier #1 & #2 Building4-54
 - 4.3.9 Final Clarifier #3 & #4 Building4-56
 - 4.3.10 Roadway and Process Lighting.....4-57
- 4.4 Motor Upgrades and VFD Additions4-60
 - 4.4.1 Administration Building4-59
 - 4.4.2 Blower Building.....4-61
 - 4.4.3 Sludge Handling Building4-63
 - 4.4.4 Final Clarifier #1 & #2 Building4-64
 - 4.4.5 Final Clarifier #3 & #4 Building4-65
 - 4.4.6 Outdoor Process Pumps4-66
 - 4.4.7 All Combined Motors4-68
- 4.5 Alternative Energy Sources.....4-69
 - 4.5.1 Photovoltaic Solar Energy System Overview.....4-69
 - 4.5.1.1 Molitor Water Pollution Control Facility4-70
 - 4.5.1.2 Basis for Design and Calculations.....4-71
 - 4.5.2 Ground Source Heat Pump Systems4-73
 - 4.5.3 Wind Power Generation.....4-74
 - 4.5.4 Combined Heat and Power Cogeneration Technology4-77

Section 5 Evaluation of Energy Purchasing and Procurement Strategies

- 5.1 Energy Deregulation5-1
- 5.2 Demand Response Program.....5-2

Section 6 Ranking of Energy Conservation and Retrofit Measures (ECRMs)

- 6.1 ECRMs.....6-1
 - 6.1.1 Water Pollution Control Plant6-1
 - 6.1.2 Building HVAC Components.....6-3
 - 6.1.3 Building Lighting Systems6-3
 - 6.1.4 Motors6-4
 - 6.1.5 Solar Energy6-4

6.1.6 Wind Power Generation.....6-5

Section 7 Grants, Incentives and Funding Sources

7.1 Renewable Energy7-1
7.1.1 Renewable Energy Certificates (NJ BPU).....7-1
7.1.2 Clean Energy Solutions Capital Investment Loan/Grant (NJ EDA) .7-1
7.1.3 Renewable Energy Incentive Program (NJ BPU).....7-1
7.1.4 Grid Connected Renewables Program (NJ BPU).....7-1
7.1.5 Utility Financing Programs.....7-2
7.1.6 Renewable Energy Manufacturing Incentive (NJ BPU).....7-2
7.1.7 Environmental Infrastructure Financing Program (NJ DEP).....7-2
7.1.8 Clean Renewable Energy Bonds (IRS).....7-2
7.1.9 Qualified Energy Conservation Bonds (IRS).....7-3
7.1.10 Global Climate Change Mitigation Incentive Fund (US EDA).....7-3
7.1.11 Private Tax-Exempt Financing7-3
7.1.12 Performance Based Contracts (ESCOs)7-3
7.1.13 Power Purchase Agreements (SPCs)7-4
7.2 Energy Efficiency7-4
7.2.1 Introduction.....7-4
7.2.2 New Jersey Smart Start Buildings Program (NJ BPU)7-5
7.2.3 Pay for Performance Program (NJ BPU)7-5
7.2.4 Direct Install (NJ BPU).....7-6

Appendices

Appendix A Historical Data Analysis
Appendix B Statement of Energy Performance
Appendix C Digester System Data
Appendix D Digester Gas Production and Use Analysis
Appendix E Analysis of Various Sludge Processing Alternatives
Appendix F eQuest Model Results
Appendix G Engineer’s Opinion of Probable Construction Costs
Appendix H NJ SmartStart Incentives Information and Worksheets
Appendix I Lighting Upgrades Spreadsheet
Appendix J Motor and VFD Upgrades Analysis
Appendix K Solar PV System Financial Analysis
Appendix L Wind Turbine Energy System Wind CAD Analysis
Appendix M Wind Turbine Energy System Financial Analysis
Appendix N ECRM Financial Analysis
Appendix O Facility Data Forms

Executive Summary

As part of an initiative to reduce energy cost and consumption, the Madison-Chatham Joint Meeting (MCJM) has secured the services of Camp Dresser and McKee (CDM) to perform an energy audit for the Molitor Water Pollution Control Facility (WPCF) in an effort to develop comprehensive Energy Conservation and Retrofit Measures (ECRMs).

CDM's energy audit team visited the WPCF on May 27th, 2010. As a result of the site visit and evaluation of the historical energy usage of the facilities, CDM was successful in identifying various treatment processes and building system components that present feasible opportunities for energy savings measures.

CDM has also evaluated the potential for renewable energy technologies to be implemented at the Water Pollution Control Facility to offset the facility's electrical energy usage. Specifically, the use of solar electric photovoltaic panels, wind turbines, and methods to increase digester gas production to fuel the existing engine driven blowers and boiler were investigated.

Not all ECRMs identified as a result of the energy audit are recommended. ECRMs must be economically feasible to be recommended to the MCJM for implementation. The feasibility of each ECRM was measured through a simple payback analysis. The simple payback period was determined after establishing Engineer's Opinion of Probable Construction Cost estimates, O&M estimates, projected annual energy savings estimates, and the potential value of New Jersey Clean Energy rebates, or Renewable Energy Credits, if applicable. ECRMs with a payback period of 20 years or less are recommended.

The payback periods presented herein do not account for additional cost savings associated with participation in the Clean Energy Programs, Pay for Performance Program or the Direct Install Program. The eligibility requirements for participation in these programs and the associated cost savings from these Programs are discussed in Section 7.2.

Historical Energy Usage

Table ES-1 summarizes the historical energy usage at the WPCF as presented in Section 3. These values can serve as a bench-marking tool, along with the building profiles that have been established through the EPA's Portfolio Manager Program, to quantify the reduction in electrical energy and natural gas usage following the implementation of the recommended ECRMs.

| Table ES-1 | | | | | | |
|--|------------------------------------|--------------------------------|--------------------------------|--|----------------------------------|----------------------|
| Summary of Annual Energy Usage & Cost (April 2009 – March 2010) | | | | | | |
| | Electrical Energy Use (kWh) | Peak Summer Demand (kW) | Peak Winter Demand (kW) | Fuel Use for Entire Building (therms) | Cost for Electric Service | Cost for Fuel |
| WPCF | 2,213,387 | 386 | 462 | 77,163 | \$334,742 | \$69,350 |

Recommended ECRMs

The following table, Table ES-2, presents the ranking of recommended ECRMs identified for treatment processes and equipment and various building system components at the WPCF. Additional ECRMs were identified and evaluated, as discussed in Section 4; however, were not recommended due to longer payback periods. Table ES-2 includes the Engineer's Opinion of Probable Construction Cost, projected annual energy cost savings, projected annual energy usage savings, and total simple payback period for each recommended ECRM. The ECRMs are ranked based on their simple payback period.

| Table ES-2 | | | | | |
|--|---|---------------------------------|--|--|--------------------------------------|
| Ranking of Recommended ECRM's | | | | | |
| Overall Ranking (Based on Simple Payback) | ECRM | Total Cost⁽¹⁾ | Project Annual Energy Savings (kWh or Therms) | Projected Annual Fiscal Savings⁽²⁾ | Simple Payback Period (years) |
| Water Pollution Control Facility Process Improvements/Additions | | | | | |
| 1 | Aerations Basins, New Motors and VFDs for Mechanical Aerators | \$85,076 | 134,036 kWh | \$15,293 | 5.6 |
| 2 | Oxidation Ditches, New Motors and VFDs for Existing Aerators | \$383,460 | 398,943 kWh | \$56,400 | 6.8 |

| | | | | | |
|------------------------------------|---|-----------|---------------|----------|------|
| 3 | Digesters | \$409,656 | 34,039 Therms | \$47,030 | 8.7 |
| 4 | New Solar Powered Aerators and DO Control System | \$354,954 | 190,885 kWh | \$28,900 | 13.5 |
| HVAC Improvements | | | | | |
| 1 | Steam Pipe Insulation | \$955 | 1,379 Therms | \$1,475 | 0.6 |
| Lighting Systems | | | | | |
| 1 | Waste Oil Building - Total Lighting | \$78 | 1,034 kWh | \$204 | 0.4 |
| 2 | Administration Building - Total Lighting | \$14,732 | 11,213 kWh | \$1,956 | 7.5 |
| 3 | Blower Building - Interior Lighting | \$1,539 | 891 kWh | \$158 | 9.7 |
| 4 | Roadway and Process - Exterior Lighting | \$15,853 | 10,534 kWh | \$1,610 | 9.8 |
| 5 | Sludge Handling Building - Total Lighting | \$12,351 | 7,249 kWh | \$1,240 | 10.0 |
| 6 | Clarifier #3 & #4 Building - Interior Lighting | \$4,463 | 1,509 kWh | \$269 | 16.6 |
| Electric Motor Replacements | | | | | |
| 1 | Final Clarifier Building #1 & #2 - Motor & VFD Upgrades | \$8,586 | 19,001 kWh | \$2,877 | 3.0 |
| 2 | Outdoor Process - Motor & VFD Upgrades | \$12,867 | 23,214 kWh | \$3,515 | 3.7 |
| 3 | Final Clarifier Building #3 & #4 - Motor & VFD Upgrades | \$17,772 | 26,096 kWh | \$3,951 | 4.5 |

1. 'Total Cost' takes into account any applicable rebates.

2. 'Annual Fiscal Savings' takes into account operation and maintenance cost savings, if any.

Table ES-3 summarizes the Total Engineer's Opinion of Construction Cost, annual energy savings, projected annual energy cost savings, and average simple payback based on the implementation of all the recommended ECRMs at the facility.

| Table ES-3 Recommended ECRM's - WPCF⁽¹⁾ | | | |
|---|--|---|--|
| Total Cost | Project Annual Energy Savings (kWh or Therms) | Projected Annual Fiscal Savings | Average Simple Payback Period (years) |
| \$1,322,342 | 824,605 kWh 35,418 Therms | \$116,373 electricity \$48,505 natural gas | 8.0 |

Note 1: Does not include energy savings associated with solar or wind energy system, with the exception of the solar powered aerators for the Stabilization Pond, which are included.

Renewable Energy Technologies

- **Solar Energy**

Section 4.5.1 of the report provides for an economic evaluation of a PV solar system that was evaluated to be installed at WPCF. The evaluation covered the economic feasibility of WPCF installing a solar energy system under a typical construction contract and to assume full responsibility of the operation of such a system.

Based on a simple payback model, summarized in Table ES-4, it would benefit Madison-Chatham Joint Meeting to further investigate the installation of a solar energy system at the WPCF. This is primarily based on the initial upfront capital investment required for a solar energy system installation and the combined 16.6 year payback period. This payback period may justify installing the solar energy system. Other options such as Power Purchase Agreements are potentially available as well to help finance the project. Solar technology is constantly changing and will most likely continue to lower in price.

Two major factors influencing the project financial evaluation is the variance of the prevailing energy market conditions and Solar Renewable Energy Credit (SREC) rates, with the largest impact to the payback model being the SREC credit pricing. For the payback model, conservative estimates of the SREC's market value over a 15 year period were assumed, as discussed in Section 4.5.1.

Table ES-4 includes a simple payback analysis for the installation of a solar energy system at WPCF. Refer to Appendix K for a more detailed solar financing spreadsheet.

| Table ES-4 Simple Payback Analysis for Solar Energy System | |
|---|-------------------|
| Parameter | Solar |
| Engineer's Opinion of Probable Cost | \$15,248,668 |
| 1 st Year Production | 1,601,345 kWh |
| Annual Electric Savings | \$242,443.6 |
| Annual Estimated SREC Revenue | \$677,369 |
| Project Simple Payback | 16.6 Years |

- **Wind Power Generation**

Section 4.5.3 of the report provides for an economic evaluation of a wind turbine energy system recommended to be installed at WPCF. The evaluation covered the economic feasibility of MCJM furnishing and installing a wind turbine energy system under a typical construction contract and to assume full responsibility of the operation of such a system.

CDM completed a preliminary desktop wind power production analysis and has concluded that an additional on-site feasibility study is warranted and recommended. Such a feasibility study would include the installation of a wind test rig to measure actual wind conditions as observed on-site.

Wind power as a renewable energy source also qualifies for Renewable Energy Certificates (REC's). The prevailing energy market, REIP and REC's comprise the major factors influencing a wind turbine energy system installation. Other options, such as government bonds or a Power Purchase Agreement are potentially available and can assist with the financing of this project.

Table ES-5 includes a simple payback analysis for the installation of a wind turbine energy system at the WPCF. Refer to Appendix M for a more detailed wind energy financing spreadsheet.

Table ES-5: Ranking of Energy Savings Measures Summary - Wind Turbine Energy System

| Table ES-5 Ranking of Energy Savings Measures Summary - Wind Turbine Energy System | | | |
|---|--|---|---|
| Parameter | Wind Turbine (Minimum Site Wind Speed - 8.52 mph) | Wind Turbine (Average Site Wind Speed - 10.56 mph) | Wind Turbine (Maximum Site Wind Speed - 12.35 mph) |
| Engineer's Opinion of Probable Cost | \$68,489.69 | \$68,489.69 | \$68,489.69 |
| Renewable Energy Incentive Program** | -\$18,198.00 | -\$33,978 | -\$51,661.00 |
| Total Cost | \$50,291.69 | \$34,511.69 | \$16,282.69 |
| 1 st Year Production | 5,687 kWh | 10,618 kWh | 16,144 kWh |
| Annual Estimated Electric Savings | \$861.0 | \$1,607.6 | \$2,444.2 |
| Annual Estimated REC Revenue | \$142.00 | \$265.00 | \$407.00 |
| Project Simple Payback | 50.1 Years | 18.4 Years | 5.9 Years |

Section 1

Introduction

1.1 General

As part of an initiative to reduce energy cost and consumption, the Madison-Chatham Joint Meeting (MCJM) has secured the services of Camp Dresser and McKee (CDM) to perform an energy audit for their wastewater treatment plant in an effort to develop comprehensive energy conservation initiatives.

The performance of an Energy Audit requires a coordinated phased approach to identify, evaluate and recommend energy conservation and retrofit measures (ECRM). The various phases conducted under this Energy Audit included the following:

- Gather preliminary data on all facilities;
- Facility inspection;
- Identify and evaluate potential ECRMs and evaluate renewable/distributed energy measures;
- Develop the energy audit report.

Figure 1.1-1 is a schematic representation of the phases utilized by CDM to prepare the Energy Audit Report.




Figure 1.1-1: Energy Audit Phases

1.2 Background

The Madison-Chatham Joint Meeting (MCJM) is a Joint Meeting providing wastewater treatment service to the Borough of Madison and the Borough of Chatham.

The MCJM maintains and operates the Molitor Water Pollution Control Facility (WPCF). The WPCF is an activated sludge wastewater treatment plant providing advanced secondary treatment and is located in the Borough of Chatham, Morris County, New Jersey. The plant operates under NJPDES Permit No. NJ0024937 and discharges directly to the Passaic River. The MCJM also maintains and operates the main 42-inch interceptor that collects and conveys the wastewater from the Boroughs to the WPCF. The individual Boroughs are responsible for maintaining and operating the branch sanitary sewer collection systems and associated pump stations.

The wastewater treatment processes at the WPCF provide primary and secondary treatment for the removal of BOD₅, ammonia, and suspended solids in the wastewater flow. Wastewater entering the WPCF is first conveyed by gravity to the grit chamber and manual bar rack at the Inlet Facilities. The wastewater is then conveyed by gravity to three Primary Clarifiers. The Primary Effluent Pump Station then pumps the primary clarifier effluent to Distribution Box No. 1, where 43% of the wastewater flow is diverted to the Aeration Basins and 57% of the wastewater flow is conveyed to Distribution Box No. 2 for flow distribution to two Oxidation Ditches (Oxidation Ditch A and Oxidation Ditch B).

The Aeration Basins consist of a total of 11 bays. Two of the bays, however, have been removed from service, leaving the remaining nine bays in service for treatment. The wastewater is first conveyed to three bays that are aerated via mechanical aerators. The wastewater is then conveyed to the remaining six bays that have a coarse bubble diffused air system. The mixed liquor from the Aeration Basins is then conveyed by gravity to Control Chamber No. 1, where the wastewater is conveyed to two final clarifiers (Final Clarifier No. 1 and Final Clarifier No. 2). The final clarifier effluent is then routed to the Stabilization Pond Influent Chamber and then conveyed to the Stabilization Pond in order to raise the dissolved oxygen level.

The mixed liquor that is conveyed from the Oxidation Ditches is then routed back to Distribution Box No. 2, for discharge to Final Clarifier No. 3 and Final Clarifier No. 4. The final clarifier effluent is then conveyed to Control Chamber No. 2 and then to the Stabilization Pond Influent Chamber, where the wastewater is then routed to the Stabilization Pond.

Following passage through the Stabilization Pond, the wastewater is conveyed to the Chlorine Contact Tanks for disinfection utilizing sodium hypochlorite. The treated effluent is then dechlorinated utilizing sodium bisulfite prior to ultimate discharge to the Passaic River.

Raw primary sludge from the Primary Clarifiers is conveyed to two Primary Anaerobic Digesters. The primary digested sludge is then sent to the Secondary Digester. The supernatant is conveyed to the Inlet Facilities and the digested sludge is dewatered prior to being hauled for ultimate disposal.

The waste activated sludge from Final Clarifier No. 1 and Final Clarifier No. 2 (following the Aeration Basins) is conveyed to the Inlet Facilities of the plant and is recycled into the wastewater process stream. The waste activated sludge from Final Clarifier No. 3 and Final Clarifier No. 4 (following the Oxidation Ditches) is thickened via gravity belt thickeners prior to being blended with the Primary Sludge at the Primary Digesters.

1.3 Purpose and Scope

The objective of the energy audit is to identify energy conservation and retrofit measures to reduce energy usage and to develop an economic basis to financially validate the planning and implementation of identified energy conservation and retrofit measures.

Significant energy savings may be available with retrofits to the buildings' envelopes, heating and cooling systems, and lighting systems. It should be noted that the magnitude of energy savings available is not only dependent on the type of treatment process and delivery systems in use, but also on the age and condition of the equipment and the capital available to implement major changes. Therefore, with the growing demands for electricity and the increased cost for this electricity, feasible alternatives for reducing energy consumption and operating costs must be evaluated on a case-by-case basis.

The purpose of this energy audit is to identify the various critical processes and pumping systems within the wastewater treatment plant facility that are major consumers of electrical energy and are clear candidates for energy savings measures. In addition, potential energy producing systems such as the existing combined heat and power co-generation and new solar electric, ground source heat pumps, and wind energy systems to be located at the wastewater treatment plant were also evaluated. A discussion on these technologies is included in Section 4 - Energy Conservation and Retrofit Measures (ECRM).

The existing process systems that have been identified for possible energy savings retrofits include the following:

Water Pollution Control Plant

- Primary Effluent Pump Station;
- Aeration System and Controls;

- Oxidation Ditches and Controls;
- Stabilization Pond and Controls;
- Anaerobic Digestion System;
- Building HVAC Systems; and
- Building Lighting Systems.

A feasibility analysis of the existing internal combustion engines and a new solar energy and wind power generation system at the wastewater treatment plant was conducted. A discussion on these technologies is included in Section 4 Energy Conservation and Retrofit Measures (ECRM).

In addition to identifying ECRMs and the potential for on-site energy generation, alternate third party suppliers were not contacted, because MCJM is currently utilizing an alternate third party supplier. This is discussed further in Section 5.

Section 2

Facility Description

2.1 Water Pollution Control Plant

The Madison-Chatham Joint Meeting owns and operates the Molitor Water Pollution Control Plant (WPCP) located on North Passaic Avenue in the Borough of Chatham, Morris County, New Jersey. The WPCP is an activated sludge wastewater treatment plant providing advanced secondary treatment and is located in the Borough of Chatham, Morris County, New Jersey. The WPCP treats wastewater from the Borough of Madison and the Borough of Chatham. The plant operates under NJPDES Permit No. NJ0024937, is rated at an annual average flow of 3.5 MGD, and discharges directly to the Passaic River. The individual Boroughs are responsible for maintaining and operating the sanitary sewer collection systems and associated pump stations.

The existing treatment plant utilizes the Activated Sludge Process. Wastewater enters the Inlet Facilities of the WPCP via the main 42-inch interceptor that collects and conveys the wastewater from the Boroughs to the WPCP. The Inlet Facilities consist of a bar rack, an 18-inch Parshall Flume, and a grit chamber. The wastewater is conveyed by gravity from the Inlet Facilities to the Primary Clarifiers. Following the three Primary Clarifiers, the wastewater flow is split with 43% of the flow being conveyed to the Aeration Basins and 57% of the flow being routed to two parallel Oxidation Ditches. The Aeration Basins and Oxidation Ditches serve as treatment units for the reduction of BOD₅ and ammonia from the raw wastewater. Dual Final Clarifiers follow both the Aeration Basins and the Oxidation Ditches (for a total of four Final Clarifiers) and operate in parallel for settling of mixed liquor suspended solids created in the aeration tanks. Chemical addition is currently not used to remove phosphorus from the wastewater. However, provisions exist to enable the plant to begin utilizing chemical addition, if needed. The final clarifier effluent is then conveyed to the Stabilization Pond for raising of the dissolved oxygen concentration of the wastewater prior to the wastewater being conveyed to the Chlorine Contact Tanks. At the Chlorine Contact Tanks, sodium hypochlorite is added for disinfection. The treated effluent is then dechlorinated utilizing sodium bisulfite prior to ultimate discharge to the Passaic River.

Raw primary sludge from the Primary Clarifiers is conveyed to two Primary Anaerobic Digesters. The primary digested sludge is then sent to the Secondary Digester. The supernatant is conveyed to the Inlet Facilities and the digested sludge is dewatered prior to being hauled for ultimate disposal.

The waste activated sludge from Final Clarifier No. 1 and Final Clarifier No. 2 (following the Aeration Basins) is conveyed to the Inlet Facilities of the plant where it is recycled into the wastewater process stream. The waste activated sludge from Final Clarifier No. 3 and Final Clarifier No. 4 (following the Oxidation Ditches) is thickened via gravity belt thickeners prior to being blended with the Primary Sludge at the Primary Digesters.

2.1.1 Inlet Facilities

The inlet facilities consist of a manually cleaned bar rack, and a parshall flume that is rated for a peak flow of 15.8 MGD, and a mechanically cleaned grit chamber that is 16-feet in diameter with 1.7 feet of sidewater depth.

2.1.2 Primary Clarifiers

The three primary clarifiers are each 35 feet in diameter with 9.0 feet of sidewater depth and operate in parallel. The primary clarifiers are equipped with mechanical sludge removal and scum removal mechanisms. Primary clarifier effluent is transferred by gravity to the Primary Clarifier Effluent Pump Station. Primary sludge is conveyed to two Primary Anaerobic Digesters. The primary digested sludge is then sent to the Secondary Digester. The supernatant is conveyed to the Inlet Facilities and the digested sludge is dewatered prior to being hauled for ultimate disposal.

2.1.3 Primary Effluent Pump Station

Primary clarifier effluent flows by gravity to the Primary Effluent Pump Station, which consists of three-30 Hp, variable speed, dry pit submersible pumps. The Primary Effluent Pumps convey the wastewater to Distribution Box No. 1. At Distribution Box No. 1, 43% of the wastewater flow is diverted to the Aeration Basins and 57% of the wastewater flow is diverted to Distribution Box No. 2. Distribution Box No. 2 then splits the wastewater flow to Oxidation Ditch A and Oxidation Ditch B, which operate in parallel.

2.1.4 Aeration Basins

The Aeration Basins consist of a total of 11 bays. There are three bays that are mechanically aerated; one bay is 30 feet wide by 30 feet long by 14 feet sidewater depth and two bays are 30 feet wide by 30 feet long by 10 feet sidewater depth. There are also six bays that are each 10 feet wide by 105 feet long by 9½ feet sidewater depth and contain a coarse bubble diffuser aeration system. There are also two additional bays that are each 32 feet wide by 25½ feet long by 11.2 feet sidewater depth that have been removed from service. The Aeration Basins operate in series and are a conventional activated sludge system with single stage nitrification for the reduction of BOD₅ and ammonia for 43% of the WPCP's total flow. The remaining 57% of the WPCP's flow is diverted to the Oxidation Ditches, as further discussed herein.



Mechanical Aerator

The three mechanically aerated bays each have one mechanical aerator rated at 15 Hp each. The course bubble diffuser aeration system that is installed in the six bays following the mechanically aerated bays includes seven drop legs per bay. Each drop leg includes ten course bubble diffusers for a total of 70 diffusers per bay and a total of 420 diffusers in all six bays.

There are a total of four blowers that can supply air to the course bubble diffused aeration system. Two of the blowers are engine driven Roots rotary positive displacement blowers, rated at a volume of 4,445 SCFM and a discharge pressure of 6.0 psig each. There are also two 75 Hp electric rotary blowers, as manufactured by Kaeser Compressors, rated at a volume of 1,926 SCFM and a discharge pressure of 6.0 psig. The speed of the electric blowers can be manually adjusted by Variable Frequency Drives. The plant typically runs the three mechanical aerators continuously and either one of the engine driven blowers or both electric blowers at 90% capacity.

2.1.5 Final Clarifier Nos. 1 & 2

The mixed liquor from the Aeration Basins is conveyed to Final Clarifier No. 1 and Final Clarifier No. 2, which operate in parallel and are each 65 feet in diameter with 10.0 feet of sidewater depth.

Waste activated sludge settled in the clarifiers is discharged to the Inlet Facilities at the head of the WPCP. The sludge is then co-settled with solids from the raw sewage in the primary clarifiers.

Return activated sludge from the clarifiers is conveyed back to the Aeration Basins.

2.1.6 Oxidation Ditches A & B

The two Oxidation Ditches are designed for two passes per tank, with each pass being 26 feet wide by 163 feet long by 13.67 feet sidewater depth, for the reduction of BOD₅ and ammonia. The Oxidation Ditches operate in parallel and treat 57% of the WPCP's flow that is diverted from Distribution Box No. 1. Each Oxidation Ditch includes one constant speed 75 Hp mechanical aerator.

2.1.7 Final Clarifier Nos. 3 & 4

The mixed liquor from the Oxidation Ditches is conveyed to Final Clarifier No. 3 and Final Clarifier No. 4, which operate in parallel and are each 65 feet in diameter with 12.0 feet of sidewater depth.

Waste activated sludge settled in the clarifiers is thickened via gravity belt thickeners prior to being blended with the Primary Sludge at the Primary Digesters.

Return activated sludge from the clarifiers is conveyed back to the Oxidation Ditches.

2.1.8 Stabilization Pond

The final clarifier effluent from Final Clarifier Nos. 1 and 2 is conveyed directly to the Stabilization Pond Influent Chamber. The effluent from Final Clarifiers Nos. 3 & 4 is conveyed through Control Chamber No. 2 and then combines with the effluent from Final Clarifier Nos. 1 and 2 in the Stabilization Pond Influent Chamber. The combined secondary effluent is then conveyed to the Stabilization Pond for raising of the dissolved oxygen concentration. The Stabilization Pond has a surface area of 106,900 square feet and a volume of 8.0 million gallons.

The Stabilization Pond is equipped with four 10 Hp AIRE-O₂ mechanical aerators, which are mounted on individual floatation assemblies. Three of the four mechanical aerators are operated on a full-time basis.

2.1.9 Chlorine Contact Tanks

The wastewater from the Stabilization Pond is then conveyed to two Chlorine Contact Tanks operating in parallel. Each Chlorine Contact Tank is 17.25 feet wide by 55 feet long by 5 feet sidewater depth. At the Chlorine Contact Tanks, sodium hypochlorite is added for disinfection. The treated effluent is then dechlorinated utilizing sodium bisulfite prior to ultimate discharge to the Passaic River.

2.1.10 Anaerobic Digestion

The anaerobic digester system consists of two primary digesters and one secondary digester configured in a two-stage digestion system. In this configuration, the primary digesters (high-rate digesters) are coupled in series with a secondary digestion tank. The contents of the primary digesters are heated and mixed to facilitate volatile solid destruction, gas production and to avoid grit and sludge accumulation in order to maintain usable digester volume. The secondary digester is used for the storage and concentration of digested sludge and for the formation of a relatively clear supernatant.

The three (3) digesters have varying usage volumes. Primary Digester No. 1 is 50 feet in diameter with a 21 foot side water depth resulting in a usable volume of 41,233 cubic feet. Primary Digester No. 2 is 60 feet in diameter with a 23 foot side water depth resulting in a usable volume of 65,031 cubic feet. The corresponding secondary digester is 50 feet in diameter with an 18 foot side water depth resulting in a usable volume of 35,343 cubic feet. Blended primary and waste activated sludge from Final Clarifier Nos. 3 and 4 is conveyed to the primary digesters with 40% of this sludge flow being sent to Primary Digester No. 1 and 60% of the sludge volume being sent to Primary Digester No. 2.

The Primary Digesters currently are equipped with Pearth gas mixing systems in order to facilitate volatile solid destruction, gas production, and to minimize grit and sludge accumulation in order to maintain usable digester volume. However, the existing Pearth gas mixing system in Primary Digester No. 1 is currently being

replaced with mechanical draft tube mixers; the Pearth gas mixing system in Primary Digester No. 2 will remain in service and is not being replaced at this time. The secondary digester is used for the storage and concentration of digested sludge and for the formation of a relatively clear supernatant. The supernatant is then conveyed to the Inlet Facilities of the WPCP and the digested sludge is sent to either Sludge Drying Beds or the Digested Sludge Wet Well for dewatering in the belt filter presses.

Waste activated sludge from the Final Clarifiers is either conveyed back to the Inlet Facilities or to the Waste Activated Sludge Wet Well for thickening. The thickened sludge is then pumped back to the Primary Digesters or into tanker trucks for off-site disposal.

The design of the digestion system was based upon the following parameters:

| Digestion System Design Parameters¹ | |
|---|--------------------------------|
| Total Solids Loading: | 8,964 lbs/day |
| Total Volume of Sludge: | 23,885 gpd |
| Volatile Solids Loading to Primary Digesters: | 0.054 lbs/ft ³ /day |
| Detention Time: | 49 days |

1. Design Parameters from a 1990 report developed by Killam Associates.

Based upon the design volatile solids loading to the primary digester of 0.054 lbs/ft³/day, it can be computed that the volatile solid portion of the incoming sludge is 5,738 lb/d or a volatile suspended solids (VSS) to total suspended solids (TSS) ratio of 0.64 lb VSS/lb TSS.

Although not provided for in the aforementioned basis of design report, based upon a detention time of 49 days and a feed sludge volatile solid of approximately 0.64 lb VSS/lb TSS, the estimated reduction in volatile solids is 49 percent (see Figure 2-1). Based upon the estimated reduction in volatile solids destruction and using an average gas production rate of 15 ft³/lb of volatile solids destroyed, the calculated design gas production from the primary digesters based upon average month condition is as follows:

$$8,964 \text{ lb/d} \times 0.64 \text{ lb VSS/lb TSS} \times 0.49 \times 15 \text{ ft}^3 / \text{lb of VSS destroyed} = 42,167 \text{ ft}^3 / \text{day}.$$

The design sludge heating requirements based upon mesophilic digestion operation at the design solid loading condition is computed to be as follows:

$$\text{Heating Load} = 8,964 \text{ gpd} \times (1 \text{ BTU/LB-}^\circ\text{F}) \times 8.34 \text{ lb/gal} \times (95^\circ\text{F} - 50^\circ\text{F}) = 3,364,189 \text{ Btu/day or } 140,174 \text{ Btu/hr}.$$

For estimating purposes and based on an assumed sludge temperature loss of 1°F /day, the estimated heat loss from both primary digesters is computed to be as follows:

$$\text{Heat Loss} = (41,233 + 65,031) \text{ ft}^3 \times 62.4 \text{ lb/ft}^3 \times (1 \text{ BTU/LB-}^\circ\text{F}) \times 1^\circ\text{F/day} = 6,630,873 \text{ Btu/day or } 276,286 \text{ Btu/hr.}$$

Therefore, the total design heat load is computed to be 140,174 Btu/hr + 276,286 Btu/hr = 416,460 Btu/hr.




Figure 2-1: Effect of Detention Time and Initial Volatile Solids Content on Digester Efficiency

2.2 Administration Building

2.2.1 Description of Building Envelope

The energy audit included an evaluation of the building's envelope (exterior shell) to determine the components' effective R-values to be utilized in the building model and to locate and fix any thermal weaknesses that may be present. The components of a building envelope include the exterior walls, foundation and roof. The construction and material, age and general condition of these components, including exterior windows and doors, impact the building's energy use.

The Administration Building's walls consist of brick and mortar façade with concrete masonry (CMU) back up blocks. The existing roofing system on the North-West side of the building consists of EPDM membrane with 1 ½" rigid insulation over flat roof decks. The older section consists of ballasted built-up roofing over flat roof decks.

The windows throughout the building are insulating double pane windows with weatherstripping. The exterior doors are FRP doors. FRP doors are recommended on an energy efficiency level, as the doors are made out of a high strength, light weight material with energy saving insulation and good sealing ability, as the doors will not expand or contract with changing climate. The windows and exterior doors are sealed well with no signs of infiltration.

Our inspection has revealed that the building envelope is in good condition and is currently providing a high level of insulation. As such, any modifications to the insulation system would not prove to be cost effective, from an energy savings standpoint.

2.2.2 Description of Building HVAC

The Administration Building office area is heated and cooled by a Trane rooftop unit. This gas fired unit has a heating output capacity of 200 MBH with an efficiency of 80 percent, and a cooling capacity of 10 tons. Conditioned air is distributed throughout the office by use of ductwork. Ceiling mounted diffusers release or remove air from the spaces. There is an Emerson digital thermostat located next to the conference room which provides control for the office spaces. The basement and electrical room are heated by Airtherm gas fired unit heaters. It was undetermined at the time of the audit if the gas fired unit heaters are currently operated. The sulfur dioxide storage, chlorine room, and bisulfite room are all heated by electric unit heaters. Roof mounted exhaust fans exhaust air from respective spaces through means of ductwork. Wall mounted exhaust fans exhaust air from both the chlorine room and laboratory.

2.2.3 Description of Building Lighting

The Administration Building's existing lighting system consists of 1X4 (2 lamp), 1X8 (2 lamp), 2x4 (4 lamp) T12 standard efficiency linear fluorescent fixtures with magnetic ballasts, regular and explosion-proof incandescent, and mercury vapor fixtures. Existing exterior lighting consists of mercury vapor, and compact fluorescent fixtures. Refer to Section 4 for a more detailed description.

The roadway and process existing lighting system consists of pole mounted fixtures, which are assumed to have high pressure sodium lamps. Refer to Section 4 for a more detailed description.

2.3 Grit Building

2.3.1 Description of Building Envelope

The Grit Building is a prefabricated fiberglass building. The windows used for the prefabricated building are single pane.

Our inspection has revealed that the building envelope is in good condition. Due to the size of the building any modifications to the insulation system would not prove to be cost effective, from an energy savings stand-point.

2.3.2 Description of Building HVAC

The Grit Building is heated by a Sentinel explosion proof electric unit heater. There is a roof mounted exhaust fan that exhausts air from the space.

2.3.3 Description of Building Lighting

The Grit Building's existing lighting system consists of explosion-proof incandescent fixtures. No existing exterior lighting is present. Refer to Section 4 for a more detailed description.

2.4 Digester No. 1 Building

2.4.1 Description of Building Envelope

The Digester No. 1 Building walls consist of poured concrete with concrete masonry (CMU) back up blocks. The existing roofing system of the building consists of EPDM roofing over flat roof decks. The roof was in immaculate condition and there were no signs of interior leakage from the roof.

The windows throughout the building are insulating double pane windows with weatherstripping. The exterior doors are FRP doors and as indicated in Section 2.2.1, are recommended on an energy efficiency level. The windows and exterior doors were sealed well with no signs of infiltration.

Our inspection has revealed that the building envelope is in good condition and is currently providing a high level of insulation.

2.4.2 Description of Building HVAC

The Digester No. 1 Building is heated by the Buderus cast-iron boiler with a 711 MBH heating capacity. This boiler has an input of 944 MBH giving it a combustion efficiency of 75 percent. It is also used for heating the sludge in the digester. The two gas trains allow the boiler to be run by natural or digester gas. Hot water is sent to fin tube radiators and a unit heater that is located in the boiler room. There is an exhaust fan located on the roof which exhausts air from all floors of the building.

2.4.3 Description of Building Lighting

The Digester No. 1 Building's existing lighting system consists of explosion-proof incandescent fixtures. Existing exterior lighting consists of an explosion-proof incandescent fixture. Refer to Section 4 for a more detailed description.

2.5 Digester No. 2 Building

2.5.1 Description of Building Envelope

The Digester No. 2 Building walls consist of poured concrete with portions of the exterior walls constructed of brick and mortar facade. The existing roofing system of the building consists of EPDM roofing over flat roof decks. The equipment room had many stained acoustic tiles, which is an indication of leakage.

It should be determined if the stained acoustic tiles is due to roof leakage. If the staining is due to roof leakage, it is recommended to completely tear-off the remainder of the original roofing system of the C-Wing including membranes, flashings, insulation, etc., down to the base substrate. An



Interior Leakage in Equipment Room

isocyanurate insulation

system is recommended to promote positive drainage to existing roof drains. Installation of 1/2-in thick, high-density wood fiber recovery board insulation is also recommended. It is recommended to install a new modified asphalt 3-ply built-up system with polyester felts and white or cool colored granulated cap sheet or a modified bitumen hot or cold applied system, including a 20 year warranty. Built-up or modified bitumen systems permit maximum movement of the membrane and flashing, without failure, due to its elasticity. In addition, the roofing system would then be consistent throughout the building.

It is recommended that a qualified roofing contractor evaluate the system, including the structural capacity of the building frame. Due to the cost of a roof replacement, it is anticipated that the payback will be in excess of 20 years; as such this recommendation has not been evaluated further.

The type of windows along the SouthEast wall were not able to be confirmed because their high placement. The exterior doors are FRP doors and as indicated in Section 2.2.1, are recommended on an energy efficiency level. The exterior doors were sealed well with no signs of infiltration.

2.5.2 Description of Building HVAC

The Digester No. 2 Building is heated by a Buderus cast-iron high efficiency boiler with a 1,110 MBH input and a combustion efficiency of 93 percent. It is also used for heating the sludge in the digester. The two gas trains allow the boiler to be run by natural or digester gas. Hot water is sent to fin tube radiators in the storage and equipment room. There are three gravity ventilators on the roof exhausting air from the engine, boiler, equipment, and storage room.

2.5.3 Description of Building Lighting

The Digester No. 2 Building's existing lighting system consists of explosion-proof mercury vapor and incandescent fixtures. Existing exterior lighting consists of a compact fluorescent fixture. Refer to Section 4 for a more detailed description.

2.6 Waste Oil Building

2.6.1 Description of Building Envelope

The Waste Oil Building walls consist of Brick and Mortar. The roof consists of asphalt shingles over pitched roof decks.

The front door at the Waste Oil Building is an aging wooden door. FRP doors are made out of a high strength, light weight material with energy saving insulation and good sealing ability, as the doors will not expand or contract with changing climate. It is recommended that any wooden exterior doors are replaced with FRP doors.

The windows at the Waste Oil Building consist of insulating double pane windows.

2.6.2 Description of Building HVAC

The Waste Oil Building is heated by a Qmark electric unit heater.



Waste Oil Building Front Door

2.6.3 Description of Building Lighting

The Waste Oil Building's existing lighting system consists of an incandescent fixture. The existing exterior lighting consists of an incandescent fixture. Refer to Section 4 for a more detailed description.

2.7 Blower Building

2.7.1 Description of Building Envelope

The Blower Building's walls consist of brick or poured concrete. The roofing system consists of clay roof tile over pitched roof decks. There were no signs of interior leakage from the roof.

The windows throughout the building are insulating double pane windows. The exterior doors are FRP doors and as indicated in Section 2.2.1, are recommended on an energy efficiency level. The windows and exterior doors were sealed well with no signs of infiltration.

Our inspection has revealed that the building envelope is in good condition and is currently providing a high level of insulation.

2.7.2 Description of Building HVAC

The Blower Building is heated by a steam Utica boiler with an output heating capacity of 243 MBH. The gas fired Utica boiler has an input rating of 300 MBH giving it a combustion efficiency of 80 percent. A one pipe steam system distributes the steam to the American Radiator radiators. A steam unit heater provides heating to the basement space. There is a belt driven ventilation fan located in the blower room on the first floor.

2.7.3 Description of Building Lighting

The Blower Building's existing lighting system consists of 1X4 (1 lamp) T8 standard efficiency linear fluorescent fixture, 1X8 (2 lamp) T12 linear fluorescent fixtures with magnetic ballasts, compact fluorescent, and incandescent fixtures. No existing exterior lighting is present. Refer to Section 4 for a more detailed description.

2.8 Sludge Handling Building

2.8.1 Description of Building Envelope

The Sludge Handling Building walls are composite walls consisting of brick and mortar façade or poured concrete, and CMU back up blocks. The existing roofing system consists of ballasted EPDM roofing with rigid insulation over flat metal roof decks.

The windows are insulating double pane windows. The exterior doors are FRP doors and as indicated in Section 2.2.1, are recommended on an energy efficiency level. The windows and exterior doors were sealed well with no signs of infiltration.

Our inspection has revealed that the building envelope is in good condition and is currently providing a high level of insulation.

2.8.2 Description of Building HVAC

The Sludge Handling Building hot water unit heaters are served by a 1,087 MBH Raypak modulating gas fired boiler. The boiler has an input rating of 1,250 MBH giving it a combustion efficiency of 87 percent. This gas fired boiler serves the hot water unit heaters that are located in the mechanical room, electrical room, pump room, filter room, and the mezzanine level. Trane heating and ventilating units serve the pump room, janitor's closet, restroom, and locker room. A Trane roof mounted heating and ventilating unit serves the filter room, and the sludge handling area. Unit ventilators provide heating to the stairwells. Cooling is provided to the break, and control room by two Trane condensing units located on the roof. These condensing units have efficiencies of 10 and 13.25 SEER. Roof mounted exhaust fans, ventilators, and motor operated wall louvers provide ventilation for the building.

2.8.3 Description of Building Lighting

The Sludge Handling Building's existing lighting system consists of 1X3 (1 lamp), 1X4 (1 and 2 lamp), 2X2 (2 lamp), 2X4 (2 and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, and explosion-proof mercury vapor fixtures. Existing exterior fixtures consist of building mounted wallpacks, the lamps are assumed to be high pressure sodium. Refer to Section 4 for a more detailed description.

2.9 Final Clarifiers Building No. 1 & 2

2.9.1 Description of Building Envelope

The Final Clarifiers Building was an underground structure consisting of poured concrete.

2.9.2 Description of Building HVAC

The Final Clarifiers Building No. 1 & 2 is heated by a Dayton electric unit heater. The building is exhausted by a gravity ventilator located outside on a concrete slab.

2.9.3 Description of Building Lighting

The Final Clarifiers Building No. 1 & 2 existing lighting system consists of 1X8 (2 lamp) T12 linear fluorescent fixtures with magnetic ballasts. No existing exterior lighting is present. Refer to Section 4 for a more detailed description.

2.10 Final Clarifiers Building No. 3 & 4

2.10.1 Description of Building Envelope

The walls of the Final Clarifiers Building No. 3 & 4 consist of brick and mortar façade with CMU back up blocks. Signs of interior leakage were observed at the time of the

audit. CDM did not have access to the roof at the time of the audit so the roof condition could not be observed.

It should be determined if the stained acoustic tiles is due to roof leakage. If the staining is due to roof leakage, it is recommended to completely tear-off the remainder of the original roofing system of the C-Wing including membranes, flashings, insulation, etc., down to the base substrate. An isocyanurate insulation system is recommended to promote positive drainage to existing roof drains. Installation of 1/2-in thick, high-density wood fiber recovery board insulation is also recommended. It is recommended to install a new modified asphalt 3-ply built-up system with polyester felts and white or cool colored granulated cap sheet or a modified bitumen hot or cold applied system, including a 20 year warranty. Built-up or modified bitumen systems permit maximum movement of the membrane and flashing, without failure, due to its elasticity. In addition, the roofing system would then be consistent throughout the building.

It is recommended that a qualified roofing contractor evaluate the system, including the structural capacity of the building frame. Due to the cost of a roof replacement, it is anticipated that the payback will be in excess of 20 years; as such this recommendation has not been evaluated further.

The exterior doors are of FRP construction and as indicated in Section 2.2.1, are recommended on an energy efficiency level.

2.10.2 Description of Building HVAC

Hot water from the Sludge Handling Building provides heat to this building. Various hot water fin tube radiators provide heat to the building. A Trane heating and ventilating unit with hot water coils located in the electrical room provides heat to the basement. A hot water unit heater in the basement provides additional heat to the basement. A gravity roof ventilator supplies air through the H&V unit. Another gravity roof ventilator provides supply air to the electrical room. Two roof mounted exhaust fans exhaust air from the building.

2.10.3 Description of Building Lighting

The Final Clarifiers No. 3 & 4 Building's existing lighting system consists of 1x4 (2 lamp), 2X2 (2 lamp), 2X4 (2 lamp) T12 linear fluorescent fixtures with magnetic ballasts. Existing exterior lighting consists of one wallpack, it is assumed to be a high pressure sodium fixture. Refer to Section 4 for a more detailed description.

Section 3

Baseline Energy Use

3.1 Historical Data Analysis

The first step in the energy audit process is the compilation and quantification of the facility's current and historical energy usage and associated utility costs. It is important to establish the existing patterns of electric and gas usage in order to be able to identify areas in which energy consumption can be reduced.

For this study, the monthly gas and electric bills for the wastewater treatment plant were analyzed and unit costs of energy were obtained. The unit cost of energy, as determined from the information provided by the Joint Meeting, was utilized in determining the feasibility of switching from one energy source to another or reducing the demand on that particular source of energy to create annual cost savings for MCJM.

It is important to understand how the utility companies charge for the service. The majority of the energy consumed is electric, as a result of both indoor and outdoor lighting systems, pumping systems, and wastewater treatment processes and equipment. Electricity is charged by three basic components: electrical consumption (kWh), electrical demand (kW) and power factor (kVAR) (reactive power). The cost for electrical consumption is similar to the cost for fuel oil, the monthly consumption appears on the utility bill as kWh consumed per month with a cost figure associated with it. The service connections are either billed on a flat rate or time of day rates per kWh.

Electrical demand can be as much as 50 percent or more of the electric bill. The maximum demand (kW value) during the billing period is multiplied by the demand cost factor and the result is added to the electric bill. It is often possible to decrease the electric bill by 15 – 25 percent by reducing the demand, while still using the same amount of energy.

The power factor (reactive power) is the power required to energize electric and magnetic fields that result in the production of real power. Power factor is important because transmission and distribution systems must be designed and built to manage the need for real power as well as the reactive power component (the total power). If the power factor is low, then the total power required can be greater than 50 percent or more than the real power alone. The power factor charge is a penalty for having a low power factor.

The other parts of the electric bill are the supply charges, delivery charges, system benefits, transmission revenue adjustments, state and municipality tariff surcharges and sales taxes, which cannot be avoided.

JCP&L is the distributor of electric energy for MCJM and FirstEnergy Solutions Corps. is the third party supplier.


PSE&G is the current distributor and Gateway Energy Services Corporation is the current supplier of gas for the MCJM WPCP. MCJM is charged for the cost of the natural gas, a delivery charge and a customer charge, which covers gas administration charges.

3.1.1 Water Pollution Control Facility

Electric power for the Water Pollution Control Facility is fed from one General Secondary Service three phase line from JCP&L. Figure 3.1-1 illustrates the average monthly total energy consumption from December 2007 through April 2010. For example, for the month of November, the bar graph represents average energy consumption for November 2008 & 2009. This same graphical representation approach has been carried through for all months and is typical for all graphs presented in this Section. Electrical usage has been averaged by month for the above referenced time period to portray a more encompassing monthly usage trend.

From this graph, it can be determined that the average annual baseline electrical consumption for the wastewater treatment plant is approximately 151,000 kWh / month.

Figure 3.1-1: WPCP's Electrical Usage




The most recent tariff rates available at the time of this audit for the WPCP's electrical service can be found on the electrical bills provided by JCP&L and are as follows:

| Acct #: 10005606627 | |
|---------------------------------|----------------|
| Customer Charge: | \$11.65/month |
| Basic Generation Service: | \$0.1058/kWh |
| Non-Utility Generation Service: | \$0.016960/kWh |
| Delivery Service Charges: | \$0.004958/kWh |

| | |
|--------------------------------|----------------|
| | \$6.47/kW |
| Societal Benefits Charge: | \$0.006322/kWh |
| System Control Charge: | \$0.000079/kWh |
| RGGI Recovery Charge: | \$0.000100/kWh |
| Transitional Assessment Charge | \$0.002928/kWh |

Figure 3.1-2 illustrates the average monthly demand load for the wastewater treatment plant facility from December 2007 through April 2010.


Figure 3.1-2: WPCP's Maximum Monthly Demand



Refer to Table 3.2-1, in Section 3.2 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.

The gas usage for the Water Pollution Control Plant is metered at two locations. The monthly total gas consumption from December 2007 through April 2010 at the plant is illustrated in Figure 3.2-3.

Figure 3.2-3: WPCP's Total Gas Usage



For more on the wastewater treatment plant facility's gas usage, refer to Section 4.

3.2 Aggregate Costs

For the purposes of computing energy savings for all identified energy conservation and retrofit measures, aggregate unit costs for electrical energy and fuel, in terms of cost/kWh and cost/therm, were determined for each service location and utilized in the simple payback analyses discussed in subsequent sections. The aggregate unit cost accounts for all distribution and supply charges for each location. Table 3.2-1 and Table 3.2-2 summarize the aggregate costs for electrical energy consumption and therms utilized, respectively.

Table 3.2-1: Electrical Aggregate Unit Costs

| Service Location | Aggregate \$ / kW-hr |
|-------------------------------|----------------------|
| Water Pollution Control Plant | \$0.1514 |

Table 3.2-2: Natural Gas Aggregate Unit Costs

| Service Location | Aggregate \$ / therm |
|-------------------------------|----------------------|
| Water Pollution Control Plant | \$1.07 |

3.3 Portfolio Manager

3.3.1 Portfolio Manager Overview

Portfolio Manager is an interactive energy management tool that allows Madison-Chatham Joint Meeting to track and assess the energy consumption of the WPCP. Portfolio Manager can help MCJM set investment priorities, verify efficiency improvements, and receive EPA recognition for superior energy performance.

3.3.2 Energy Performance Rating

For many facilities, you can rate their energy performance on a scale of 1-100 relative to similar facilities nationwide. Your facility is *not* compared to the other facilities entered into Portfolio Manager to determine your ENERGY STAR rating. Instead, statistically representative models are used to compare your facility against similar facilities from a national survey conducted by the Department of Energy's Energy Information Administration. This national survey, known as the Commercial Building Energy Consumption Survey (CBECS), is conducted every four years, and gathers data on building characteristics and energy use from thousands of facilities across the United States. Your facility's peer group of comparison is those facilities in the CBECS survey that have similar facility and operating characteristics. A rating of 50 indicates that the facility, from an energy consumption standpoint, performs better than 50% of all similar facilities nationwide, while a rating of 75 indicates that the facility performs better than 75% of all similar facilities nationwide.

The wastewater treatment plant is eligible to receive a rating, yet is not eligible for an Energy Star label.

3.3.3 Portfolio Manager Account Information

A Portfolio Manager account has been established for MCJM, which includes a profile for the wastewater treatment plant facility. Information entered into this Portfolio Manager Facility profile, including electrical energy consumption and natural gas consumption, has been used to establish a performance baseline.

It is recommended that the information be updated to track the buildings' energy usage. At the time of the audit the wastewater treatment plant facility received a rating of 33.

Appendix B contains the Statement of Energy Performance and a Portfolio Manager Reference sheet.

The following website link, username and password shall be used to access the Portfolio Manager account and building profiles that has been established for MCJM:

<https://www.energystar.gov/istar/pmpam/>

[REDACTED]

[REDACTED]

Section 4

Energy Conservation and Retrofit Measures (ECRM)

4.1 Water Pollution Control Plant

4.1.1 Aeration Basins

Aeration systems are used in the activated sludge process to provide oxygen for the biological oxidation of carbonaceous and nitrogenous matter and to maintain the biological solids mixed within the wastewater. Aeration devices for wastewater treatment can be classified into two basic types:

- (1) Agitating wastewater mechanically to dissolve oxygen from atmospheric air into the wastewater (mechanical aeration); or
- (2) Introducing air or pure oxygen into the wastewater with submerged diffusers (diffused air).

The aeration system at MCJM consists of eleven total bays, two of which have been removed from service. Of the nine active bays, the first three are mechanically aerated and the following six bays utilize a coarse bubble diffuser system with positive displacement blowers supplying the air. The mechanical aerators are constant speed and are operated continuously. Table 4.1-1 summarizes the existing aeration system and equipment.

| Table 4.1-1 Existing Aeration System | | | |
|---|------------------|-----------------------------|-------------------------|
| | 2 Bays | 3 Bays | 6 Bays |
| Total Volume (gallons) | 155,584 | 228,888 | 435,874 |
| Aerator Equipment | (not in service) | Mechanical Surface Aerators | Coarse Bubble Diffusers |
| - Quantity | - | 3 (one per Bay) | 420 total |
| - Motor Horsepower | - | 15 each; 45 total | - |
| - Run Time | - | 24/7 | - |
| - SOTE (lbs O ₂ /hp-hr) | - | 3 | 2 |

1. Standard Oxygen Transfer Efficiency (SOTE)

There are four blowers that can be utilized to supply the air to the coarse bubble diffuser system; two electric Kaeser compressors with variable frequency drives (VFDs) and two Roots blowers that are direct driven from MCJM's digester gas driven engines. The aeration basins do not currently have a DO control system and, as such,

the VFDs for the electric blowers are adjusted manually. Discussion with plant staff and analysis of the motor run time data provided indicates that the plant is typically running the three mechanical aerators continuously and either one of the engine driven blowers or both electric blowers at 90% capacity. The engine driven blowers are the primary source of aeration air. Table 4.1-2 summarizes the existing blower design information.

| Table 4.1-2 Existing Blower Information | | |
|--|----------------------------------|---------------------------------------|
| | Existing Electric Blowers | Existing Engine Driven Blowers |
| Number of Units | 2 | 2 |
| Capacity (scfm) | 1,926 | 4,445 |
| Discharge Pressure (psig) | 6 | 6 |
| Motor Horsepower | 75 hp | 138 bhp |

1. Based on the run-time data of the existing blowers and mechanical aerators, with the engine driven blower being utilized 75% of the time in 2009, it was estimated that the current annual aeration system energy cost is \$82,986((15 hp/89.5% eff. * 3 mixers * 0.746 kW/hp * 24hr/day * 365 days/yr + (2X75 hp/90% eff.) * 0.746 kW/hp * 2,180 hrs/2009) * \$0.1514/kWh).

In most wastewater treatment plants, a minimum dissolved oxygen (DO) level of 2.0 mg/l is commonly maintained in the aeration basins. The facility currently has eight DO sample locations, but does not have an aeration control system to utilize the DO readings to adjust blower speed and valve positions to optimize the operation of the system by controlling the amount of air that is delivered to the aeration tanks. Based on a review of plant operating data, the dissolved oxygen concentration in the aeration tanks typically varies from 1.2 to 3.1 mg/l at the first four sampling locations, which is an acceptable range for this type of process. However, the DO concentrations at the remaining four sample locations typically vary between 3.5 to 11.2 mg/l. This is the result of an equal volume being delivered across the aeration basin volume, whereas the biological oxygen demand (BOD) will decrease over the length of the aeration tank as the mixed liquor is aerated.

Table 4.1-3 summarizes the operating conditions utilized to estimate the annual cost of operation.

| Table 4.1-3 Existing Annual Energy Consumption and Cost | |
|--|--|
| Mechanical Aerators: | 24 hour, 7 day operation |
| Mechanical Aerators (annual kWh): | 328,574 |
| Engine Driven Blowers: | 6,580 hours of operation |
| Engine Drive Blowers (annual kWh): | 677,398 (free energy source) |
| 2 Electric Blowers: | 2,180 hours of operation (@ 90% speed) |
| Electric Blowers (annual kWh): | 219,548 |
| Total Annual Energy Consumption (kWh): | 1,225,520 |
| Associated Annual Cost¹: | \$82,986 |

1. Annual energy cost: 328,574 kWh + 219,548 kWh X \$0.1514/kWh

MCJM is saving \$100,328 annually (677,398 kWh) as the energy to run the primary aeration blower is supplied from the facility's digester gas.

Although there is currently only an adequate supply of digester gas to operate one engine and, as such, one engine driven blower, one engine driven blower is more than adequate to satisfy the DO demand of the aeration basins. CDM analyzed the design conditions as well as the existing conditions to determine if energy savings can be realized with aeration equipment modifications or replacements. In addition to potential equipment modifications or replacements, one of the more critical elements to any energy conservation project for aeration systems is a dissolved oxygen control system.

Oxygen requirements change continuously based on daily fluctuations in plant flow and loadings. Providing the correct monitoring and control systems for the aeration process is critical, since energy demand increases as the DO demand increases. The installation of a DO control system would automatically control blower output and optimize energy usage.

A typical automated DO control system is known as a DO loop. A DO loop control system consists of DO probes in each aeration bay to continuously monitor the DO levels, which are then fed back to the main control panel (MCP). The DO readings from the DO transmitters would be wired to a new PLC which could be connected to a SCADA system for monitoring and DO set point input. A software program in the PLC interprets the readings and sends a signal to the blower VFDs to maintain, increase, or decrease speed, depending on the DO reading when compared to a set DO point or range. The individual DO readings from each bay and measured air flow rates into each diffuser grid will be used to control the inlet air valves of each diffuser

grid to maintain the desired DO concentration in each pass automatically. Each diffuser grid drop leg will be provided with one modulating control valve, one thermal dispersion flow meter and one isolation valve.

Since a coarse or fine bubble diffused air system distributes air at the bottom of the tank and the probe is at the water surface, the mixed liquor dissolved oxygen is fairly constant throughout the tank. Therefore, this type of control system works well for a coarse or fine bubble diffused aeration system providing instantaneous change in blower output under varying flows and loads to the plant. The control system would also allow for sequencing between the available four blowers, depending upon the air demand. If a DO control loop was applied in mechanically aerated bays, the recommended DO probes for this type of application are capable of being fully submerged to a depth in excess of 20 feet.

Common methods of reducing energy consumption of mechanical aerators include installing DO probes and reducing aerator-operating time during low load periods or installing VFDs to turn down the speed of the mechanical aerators. Since older surface mechanical aerators are less energy efficient and have limited means of control, they have frequently been replaced with more efficient fine bubble diffuser systems. However, recent advances in mechanical aeration equipment have made them cost competitive with diffused air systems, depending on the size of the plant.

Design Conditions

Table 4.1-4 presents a summary of the relevant design parameters used to calculate the amount of air required based on the design conditions. The design conditions were provided in a report completed by Killam Associates. The maximum month and day flows were estimated from current flow peaking factors. Diffuser efficiency was based on a typical transfer efficiency of coarse bubble diffusers.

This aeration analysis to determine the oxygen demand in lbs/day was completed on the 9 active aeration bays, a volume of 664,762 gallons. The conversion to air flow (scfm) was based on the oxygen transfer efficiency (OTE) of coarse bubble diffusers.

| Table 4.1-4 Aeration System Calculation Summary – Design Conditions | | | | |
|--|--------|----------------|----------------------|----------------|
| | | Average | Max Month | Max Day |
| Flow | mgd | 1.5 | 1.9 | 3.6 |
| Wastewater Temperature | deg C | 17 | 17 | 17 |
| Beta | | 0.95 | 0.95 | 0.95 |
| Alpha | | 0.65 | 0.65 | 0.65 |
| Oxygen Saturation (Cd, based on WW temp) | mg/L | 9.58 | 9.58 | 9.58 |
| Dissolved Oxygen Concentration | mg/L | 2 | 2 | 2 |
| Oxygen Saturation (Cs, based on Standard Conditions) | mg/L | 9.09 | 9.09 | 9.09 |
| Oxygen Demand/BOD removed | lb/lb | 1.2 | 1.2 | 1.2 |
| Oxygen Demand/TKN removed | lb/lb | 4.25 | 4.25 | 4.25 |
| Influent BOD Concentration | mg/L | 196 | 223 | 150 |
| Influent BOD Load | lb/day | 2,463 | 3,441 | 4,454 |
| Influent Nitrogen Concentration | mg/L | 49 | 51 | 32 |
| Influent Nitrogen Load | lb/day | 617 | 787 | 950 |
| Oxygen Demand | lb/day | 3,143 | 4,216 | 4,796 |
| Density of Air | | 0.075 | 0.075 | 0.075 |
| Diffuser Efficiency | % | 12 | 12 | 12 |
| Oxygen in Air | % | 23.20% | 23.20% | 23.20% |
| Standard Oxygen Rate (SOR) | lb/day | 6,963 | 9,729 | 12,645 |
| Oxygen Transfer Efficiency (OTE), field | % | 3.8% | 3.8% | 3.8% |
| Air Flow | scfm | 3,103 | 4,163 | 4,736 |
| Air Flow (summer) | acfm | 3,552 | 4,764 | 5,420 |
| Associated Blower hp | hp | 143 | 192 | 218 |

Actual Current Conditions

The facility influent data was analyzed to determine the actual required blower demands. Table 4.1-5 presents a summary of the relevant design parameters used to calculate the amount of air needed based on the actual current conditions.

This aeration analysis to determine the oxygen demand in lbs/ day was completed on the nine (9) active aeration bays, a volume of 664,762 gallons. The conversion to air flow (scfm) was based on the OTE of coarse bubble diffusers.

| Table 4.1-5 Aeration System Calculation Summary – Actual Conditions | | | | |
|--|--------|----------------|----------------------|----------------|
| | | Average | Max Month | Max Day |
| Aeration Tank Influent Flow | mgd | 1.1 | 1.3 | 2.6 |
| Wastewater Temperature | deg C | 17.4 | 17.4 | 17.4 |
| Beta | | 0.95 | 0.95 | 0.95 |
| Alpha | | 0.65 | 0.65 | 0.65 |
| Oxygen Saturation (Cd, based on WW temp) | mg/L | 9.58 | 9.58 | 9.58 |
| Dissolved Oxygen Concentration | mg/L | 2 | 2 | 2 |
| Oxygen Saturation (Cs, based on Standard Conditions) | mg/L | 9.09 | 9.09 | 9.09 |
| Oxygen Demand/BOD removed | lb/lb | 1.2 | 1.2 | 1.2 |
| Oxygen Demand/TKN removed | lb/lb | 4.25 | 4.25 | 4.25 |
| Influent BOD Concentration | mg/L | 183 | 214 | 126 |
| Influent BOD Load | lb/day | 1,664 | 2,392 | 5,016 |
| Influent Nitrogen Concentration | mg/L | 49 | 51 | 32 |
| Influent Nitrogen Load | lb/day | 445 | 570 | 689 |
| Oxygen Demand | lb/day | 2,173 | 2,907 | 3,306 |
| Density of Air | | 0.075 | 0.075 | 0.075 |
| Diffuser Efficiency | % | 12 | 12 | 12 |
| Oxygen in Air | % | 23.20% | 23.20% | 23.20% |
| Standard Oxygen Rate (SOR) | lb/day | 4,691 | 6,750 | 7,698 |
| Oxygen Transfer Efficiency (OTE), field | % | 3.8% | 3.8% | 3.8% |
| Air Flow | scfm | 2,146 | 2,871 | 3,264 |
| Air Flow (summer) | acfm | 2,456 | 3,285 | 3,736 |
| Associated Blower hp | hp | 99 | 132 | 150 |

The results of the aeration air analysis show that there is enough blower capacity to meet the air flow requirements for the current and design average, max month and max day conditions.

Under the current average flow and load conditions, the operation of both electric blowers at approximately 67% capacity or one engine driven blower at approximately 72% capacity is required to satisfy the oxygen demand and maintain a dissolved oxygen concentration of 2.0 mg/L through these nine (9) aeration bays.

The air demand under current average flow and load equates to an annual energy consumption of approximately 647,000 kWh, which is approximately 72% of the blower energy that is currently utilized for six (6) of the nine (9) aeration bays and

53% of the blower and mixer energy that is currently utilized for the nine (9) aeration bays.

The following Table 4.1-6 summarizes the oxygen demand under the current average, max month and max day flow and load conditions and the percent of which is supplied through the operation of the mechanical aerators, assuming 3 lbs O₂ delivered/hp-hr.

| Table 4.1-6 Current Oxygen Demand | | | |
|---|----------------------------|------------------------------|----------------------------|
| | Current Average | Current Max Month | Current Max Day |
| Oxygen Demand (lb/day): | 2,173 | 2,907 | 3,306 |
| Oxygen Delivered by Mechanical Aerators (lbs/day): | 1,080 | 1,080 | 1,080 |
| % of Oxygen Demand: | 50% | 37% | 33% |

4.1.2 Aeration System Improvement Alternatives

The actual facility influent data as well as the design conditions were used to estimate the amount of air required for the aeration system. The range as shown in Tables 4.1-4 and 4.1-5 is from 2,146 to 4,736 scfm; with the lower end of this range corresponding to the current average and the higher end corresponding to the design maximum day.

To achieve energy savings for the aeration system, two (2) alternatives were evaluated: installing premium efficiency motors and VFDs on the mechanical mixers to run at a lower speed and installing fine bubble diffusers through the nine aerated bays. The installation of a fine bubble diffuser system includes the implementation of a dissolved oxygen control system.

A dissolved oxygen sensor and controller would be provided for each tank. Although the installation of the dissolved oxygen sensor and controller will not be utilized to turn-down the engine driven blowers and ultimately will not result in an energy savings, the dissolved oxygen controller along with the air flow as measured through the existing air flow meters would throttle a new motorized butterfly valve controlling the air flow to each respective aeration bay. Additionally, assuming that the recommendations outlined in Section 4.1.6 regarding the Anaerobic Digestion System are implemented, it is anticipated that the operation of the existing electrical blowers will be minimal. This is based on the assumption that there will be an

adequate supply of biogas to fuel the engines. However, since the existing electrical blowers are currently operated with VFDs (which are manually controlled) and the electric blowers should remain in the event that the engine driven blowers are out of service for maintenance, the DO control system can further be utilized to automate the VFD operation of these electric blowers.

Alternative 1: Premium Efficiency Motors & VFDs on Mechanical Aerators

Review of the design and current operation of the aeration system has led to the determination that there is adequate aeration air available through the operation of the existing blowers to maintain the process with a minimum DO set point of 2 mg/L throughout the aeration system volume. However, because there are no air diffusers installed in the first three bays, the ability currently does not exist to deliver aeration air to the first three bays with the operation of the blowers.

As such, since it is recommended from an energy standpoint to supply as much aeration air as possible through the operation of the engine driven blowers, the first alternative is to retrofit the existing mechanical aerators with new premium efficiency motors and variable frequency drives (VFDs). This will allow for the mechanical aerators to operate at a minimum speed, with the intent to maintain a certain level of agitation of the mixed liquor suspended solids, as this volume in the aeration system has been determined to be required.

The current operation of the three (3) mechanical aerators (15 hp, continuous operation) results in an annual energy consumption of 328,574 kWh, or \$49,746. The installation of premium efficiency motors (90.7%) and VFDs will allow for the aerators to be run at 60% speed. The annual electrical energy savings from the installation of premium efficiency motors is estimated to be 134,038 kWh (\$20,293).

Alternative 2: Installing Fine Bubble Diffuser System

Oxygen transfer efficiency (OTE) is a measure of the amount of oxygen transferred to the liquid by the aeration equipment. This efficiency affects both the initial and operating costs of the installation; the more efficient the system, the lower the total power required to operate it.

A fine bubble diffuser system has an OTE of approximately 2 times that of a coarse bubble diffuser system. The following table summarizes the air flow to maintain the process at a dissolved oxygen concentration of 2 mg/L with a fine bubble system.

| Table 4.1-7 Summary of Fine Bubble Diffuser System Air Flow & Associated Blower hp | | | |
|---|----------------------------|------------------------------|----------------------------|
| | Current Average | Current Max Month | Current Max Day |
| Air Flow (scfm): | 1,895 | 2,722 | 3,231 |
| Associated Blower bhp: | 53 | 76 | 93 |

The installation of a fine bubble diffuser system and DO control system as previously discussed throughout the nine (9) active aeration bays will result in an annual average energy consumption of 346,353 kWh, which can be met through the use of the digester gas fueled engine driven blowers, with the installation of mechanical sheaves to reduce the speed of the blowers. The installation of this system throughout the nine (9) aeration bays will eliminate the current annual energy consumption associated with the three (3) mechanical aerators of 294,073 kWh, or an electrical energy cost savings of \$44,522. Additionally, the installation of the fine bubble aeration system will eliminate the use of the electric blowers, an annual electrical energy cost savings of \$33,240, assuming an adequate supply of biogas to fuel the engines.

4.1.3 Economic Analysis

Table 4.1-8 summarizes the simple payback associated with the ECRMs evaluated for the aeration basins. Included in this simplified payback analysis summary table is the 'Annual Return on Investment' (AROI) values. This value is a performance measure used to evaluate the efficiency of an investment and is calculated using the following equation:

$$AROI = \frac{AECS + OCS}{NET\ ECM\ Cost} - \frac{1}{Lifetime}$$

Where OCS = Operating Cost Savings, and AECS = Annual Energy Cost Savings.

Also included in the table are net present values (NPVs) for each option. The NPV calculates the present value of an investment's future cash flows based on the time value of money, which is accounted for by a discount rate (DR) (assume bond rate of 3%). NPV is calculated using the following equation:

$$NPV = \sum_{n=0}^N \frac{C_n}{(1 + DR)^n}$$

Where C_n=Annual cash flow, and N = number of years.

The internal rate of return (IRR) expresses an annual rate that results in a break-even point for the investment. If MCJM is currently experiencing a lower return on their capital than the IRR, the project is financially advantageous. This measure also allows MCJM to compare ECM's against each other to determine the most appealing choices.

$$IRR \rightarrow 0 = \sum_{n=0}^N \frac{C_n}{(1 + IRR)^n}$$

Where C_n=Annual cash flow, and N = number of years.

The lifetime energy savings represents the cumulative energy savings over the assumed life of the ECM.

| Table 4.1-8 Aeration Basin ECRMs | | |
|--|--|---|
| | Alt. 1 – Premium Eff. Motors and VFDs on Mech. Aerators | Alt. 2 – Fine Bubble Diffuser System & DO Control System |
| Engineers Opinion of Probable Construction Cost ¹ | \$85,388 | \$1,357,200 |
| New Jersey SmartStart Rebate | \$312 | \$0 |
| Total Cost | \$85,076 | \$1,357,200 |
| Annual Electrical Energy Cost Savings | \$20,293 | \$77,763 |
| Annual Maintenance Cost Savings (AMCS) | (\$5,000) | \$4,000 |

| Simple Payback (years) | 5.6 | 16.6 |
|--------------------------------------|------------|-------------|
| Annual Return on Investment (AROI) | 12.98% | 1.03% |
| Lifetime Energy Savings ² | \$545,280 | \$2,089,520 |
| Internal Rate of Return (IRR) | 21.0% | 1.25% |
| Net Present Value (NPV) | \$234,575 | \$212,471 |

1. The Engineer's Option of Construction Cost is based solely upon a conceptual engineering level of effort. A more detailed construction cost estimate should be prepared as design documents are progressed.
2. 3% yearly inflation on electricity costs. Assumption on equipment life is based on manufacturer information.

Both of the above alternatives have a reasonable simple payback period. However, it is recommended that Alternative No. 1 is considered since this alternative has a significantly lower initial capital cost with a smaller simple payback period when compared to Alternative No. 2. Additionally, the existing blowers have adequate capacity without the installation of a fine bubble diffuser system.

4.1.4 Oxidation Ditches

The existing facility has two oxidation ditches that typically receive approximately 57 percent of the flow from the primary settling tanks. The oxidation ditches are aerated by two single-speed aerators (one in each ditch).

Alternative 1 consists of providing new motors (inverter duty) and variable frequency drives (VFDs) for the existing aerators as well as a DO instrumentation system consisting of a probe and transmitter in each oxidation ditch. The DO system will monitor the DO concentration in the oxidation ditch and vary the speed of the aerators to meet the desired DO concentration set-point. Implementation of Alternative 1 would result in an annual energy savings of approximately 398,943 kW-hrs.

Alternative 2 consists of providing new aerators with VFDs as well as a DO probe and transmitter in the lagoon. Alternative 2 would result in an annual energy savings of approximately 501,321 kW-hrs.

Alternative 3 consists of providing new two-speed aerators as well as a DO probe and transmitter in the lagoon. Construction of the improvements required for Alternative 3 would result in an annual energy savings of approximately 330,911 kW-hrs.

Table 4.1-9 presents a summary of the simple payback analyses for the three different options. Refer to Appendix G for the Engineer’s Opinion of Probable Cost.

| Table 4.1-9 Oxidation Ditch System Improvements | | | |
|--|--|--|--|
| | Alt. 1 – New Motors & VFDs on Existing Aerators | Alt. 2 – New Aerators with VFDs | Alt. 3 - New Two-Speed Aerators |
| Installation Cost | \$384,000 | \$631,000 | \$445,000 |
| New Jersey SmartStart Rebate | \$540 | \$0 | \$0 |
| Total Cost | \$383,460 | \$631,000 | \$445,000 |
| Annual Energy Savings | \$60,400 | \$75,900 | \$50,100 |
| Annual Maintenance Cost Savings | (\$4,000) | (\$4,000) | (\$4,000) |
| Simple Payback Period, years | 6.8 | 8.8 | 9.7 |
| Lifetime, years | 20 | 20 | 20 |
| Internal Rate of Return (IRR) | 14.7% | 10.4% | 9.4% |
| Net Present Value (NPV) | \$515,000 | \$498,000 | \$300,000 |

Based on the above analysis, it is recommended that MCJM consider Alternative 1 as long as the existing aerators are in good working condition and not near the end of their useful life.

4.1.5 Stabilization Pond

The existing facility has a lagoon/post aeration system to ensure that the effluent leaving the facility meets the effluent dissolved oxygen (DO) weekly minimum permit limit concentration of 6.0 mg/L.

The lagoon currently is equipped with four AIRE-02 Aerators installed on floatation assemblies as manufactured by Aeration Industries International, Inc. The aerators are each operated with 10 hp constant speed motors. Typically, three of the aerators are operated 24 hours per day, 7 days per week with the fourth aerator being utilized as a standby unit.

Various alternatives were considered in order to reduce energy costs and consumption associated with the post aeration system.

The following alternative analysis assumed that the post aeration system operates 24 hours per day. Since DO concentration data for the post aeration influent wastewater was not available, it was conservatively assumed that the starting DO concentration was 0 mg/L.

Alternative 1 consists of providing new motors and variable frequency drives (VFDs) for the existing post aeration mixers as well as a DO instrumentation system consisting of a probe and transmitter in the lagoon. The DO system will monitor the DO concentration in the lagoon and vary the speed of the aerators to meet the desired DO concentration set-point. Implementation of the improvements required for Alternative 1 would result in an annual energy savings of approximately 38,309 kW-hrs.

Alternative 2 consists of providing new constant speed aerators to replace the four existing aerators. Since the same size aerators as the existing are recommended for the lagoon size, the potential energy savings is minimal for this alternative. Alternative 2 would result in an annual energy savings of approximately 23,778 kW-hrs.

Alternative 3 consists of providing new aerators with VFDs, as well as a DO instrumentation system in the lagoon. Construction of the improvements required for Alternative 2 would result in an annual energy savings of approximately 66,710 kW-hrs.

Alternative 4 consists of providing two new solar-powered aerators in the lagoon. Aerators manufactured by SolarBee can be provided to circulate 7 million gallons of lagoon water per day. Each machine runs day and night on a brushless low-voltage motor that is entirely powered by solar energy. The aerators circulate water by bringing water from below and sending it out across the top in a thin layer causing a mixing effect. Solar panels provide power to the onboard battery which energized the drive system's controls and motor - excess energy is stored during the day allowing the units to operate night and day. The existing aerators would remain in the lagoons and would require new motors (inverter duty) and VFDs. A new DO instrumentation system in the lagoon would also be installed. The existing aerators would be required to run at a low power when the lagoon is iced over and/or if the battery backup system on the solar units was empty. Implementation of Alternative No. 2 would result in an annual energy savings of approximately 190,885 kW-hrs.

Table 4.1-10 presents a summary of the simple payback analyses for the two different options. Refer to Appendix G for the Engineer's Opinion of Probable Cost.

| Table 4.1-10 Post Aeration System Improvements | | | | |
|---|--|----------------------------------|--|--|
| | Alt. 1 – New Motors, VFDs & DO Control System | Alt. 2 – New Aerators | Alt. 3 – New Aerators, VFDs & DO Control System | Alt. 4 – New Solar Aerators & DO Control System |
| Installation Cost | \$161,000 | \$113,000 | \$301,000 | \$355,134 |
| New Jersey SmartStart Rebate | \$360 | \$0 | \$0 | \$180 |
| Total Cost | \$160,640 | \$113,000 | \$301,000 | \$354,954 |
| Annual Energy Savings | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| Annual Maintenance Cost Savings | (\$1,000) | \$0 | (\$1,000) | (\$2,650) |
| Simple Payback Period, years | 33.5 | 31.4 | 33.1 | 13.5 |
| Lifetime, years | 20 | 20 | 20 | 20 |
| Internal Rate of Return (IRR) | -2.9% | -4.0% | -3.5% | 5.2% |
| Net Present Value (NPV) | -\$74,000 | -\$59,000 | -\$151,000 | \$75,000 |

Alternative 4 results in the greatest annual energy savings with the least simple payback period.

4.1.6 Anaerobic Digestion System

As discussed in Section 2.1.10, a blend of primary sludge and thickened waste activated sludge from the Oxidation Ditches is currently conveyed to the primary digesters. Waste Activated Sludge (WAS) from the Aeration Basins is conveyed back to the Inlet Facilities. Although, not part of the current operational practice, there is the ability with existing piping to convey the WAS from the Aeration Basins to the gravity belt thickeners for thickening, prior to being added to the primary digesters.

Currently, approximately 40% of the total raw sludge flow to the digestion complex is conveyed to Primary Digester #1 and the remaining 60% of the total raw sludge flow is sent to Primary Digester #2. The raw sludge flow to the digesters is typically 2.5 to 3% solids.

Initially, both primary digesters were equipped with Perth gas mixing systems. The mixing system in Primary Digester #1 is being replaced with a mechanical draft tube mixer system. The contents of the secondary digester are not mixed.

Both primary digesters are heated. Heat from engine #1 is utilized to heat Primary Digester #1 and the heat from engine #2 is utilized to heat Primary Digester #2. The digester gas that is produced as a result of the anaerobic digestion process is utilized in the internal combustion engines that drive the Roots positive displacement blowers for the aeration system. Under normal operating conditions, there is not enough digester gas to run both engines. As such, the Primary Digester that is not being heated by the respective engine will be heated via a natural gas fueled boiler. It should be further noted that this boiler has a dual gas fuel train to enable digester gas to be utilized, as well.

CDM has evaluated the current operation of the anaerobic digestion process and has identified potential ECRMs to enhance the current sludge digestion process with the ultimate goal of improving digester gas production to further optimize the use as fuel in the existing internal combustion engines.

4.1.6.1 Current Mode of Operation

A summary of the total raw sludge flow to the primary digesters for the operational period spanning from January 2007 to December 2009 was tabulated and is presented in Appendix C. This data indicates that the maximum month average total raw sludge flow to the primary digesters was 20,124 gallons per day which occurred during February 2007. At the average percent solids concentration of 2.5 percent and a current percent volatile solid concentration of 0.81 lb-VSS/lb-TSS, the corresponding total solids loading and volatile solids loading are 4,196 pounds per day and 3,399 pounds per day, respectively.

Figure 4.1-1 illustrates the total sludge flow and resulting hydraulic detention time in each of the primary digesters. Sludge flow to the two (2) primary digesters is split such that 40% of the flow is sent to Primary Digester #1 and 60% of the flow to Primary Digester #2. From this, it can be determined that the sludge flow to Primary Digester #1 ranges from a minimum of 5,330 to a maximum of 8,030 gpd, with an average sludge flow of 6,826 gpd. The sludge flow to Primary Digester #2 ranges from a minimum of 7,994 to a maximum of 12,074, with an average sludge flow of 10,239 gpd. This corresponds to average hydraulic detention times of 45 and 48 days respectively.




Figure 4.1-1: Sludge Flow & Detention Time in the Primary Digesters

The volatile solids loading to the primary digesters, as illustrated in Figure 4.1-2, ranges from 862 to 1,577 lbs VS/day to Primary Digester #1 and 1,293 to 2,365 lbs VS/day to Primary Digester #2. Based upon the digester volumes of 308,464 gallons (41,233 ft³) and 486,497 gallons (65,031 ft³), this loading corresponds to a volatile solids loading range of 0.02 to 0.04 lbs VS/ft³-day. Typical design peak sustained volatile solids loading ranges from 0.1 to 0.2 lbs VS/ft³-day and detention times between 10 and 20 days for high-rate anaerobic digesters.




Figure 4.1-2: Volatile Solids (VS) Loading to Primary Digesters

A review of the facility's 2007-2009 digester gas production data, also presented in Appendix D, as measured from existing gas meters, indicates an average gas production rate of 22,410 ft³/day. As shown in Figure 4.1-3, MCJM is currently utilizing 80-85% of the digester gas produced to fuel the existing internal combustion engines, which in turn powers one of the aeration blowers. On average, a digester gas fueled engine is run 16 hours a day, at 40% load. When the digester gas isn't being utilized in the engine, MJCM has the ability to use the digester gas to supplement the natural gas use in the boiler.




Figure 4.1-3: Digester Gas Production and Use

Table 4.1-11 summarizes the current operational parameters of the digestion system under minimum, average and maximum month conditions.

| Table 4.1-11 Current Mode of Operation | | | | | | |
|---|---|--|---|--|---|---|
| | Sludge Flow to Dig#1 (gpd) | VS Loading of Dig #1 (lbs VS/ft³- day) | Sludge Flow to Dig#2 (gpd) | VS Loading of Dig #2 (lbs VS/ft³- day) | Biogas Production (ft³/day) | Biogas Utilized (ft³/day) |
| Min | 5,330 | 0.02 | 7,994 | 0.02 | 11,086 | 6,186 |
| Average | 6,826 | 0.03 | 10,239 | 0.03 | 22,410 | 17,510 |
| Max | 8,050 | 0.04 | 12,074 | 0.04 | 30,351 | 25,451 |

At the average monthly volatile solids loading to both primary digesters of 2,842 lbs VS/day, using an average biogas production rate of 15 ft³/lb-VS destroyed, and an average monthly digester gas production of 22,410 ft³/day, the volatile solids destruction within the primary digester complex is calculated to be generally above 50%. This is well within the expected VS destruction of 40 - 60% for a high-rate digestion process.

The objective of CDM's analysis is to identify cost effective means to enhance the digester gas production and consequent use in the existing internal combustion engine system, through the optimization of volatile solids (VS) loading to the Primary Digesters.

4.1.6.2 Determination of the Maximum VS Loading to the Primary Digesters

To determine the maximum volatile solid loading to the primary digesters, an allowable volatile solids loading rate of 0.14 lbs/ft³-day will be used.

Under the current maximum average month conditions, the volatile solids loading to Primary Digester #1 is 1,577 lbs/day and 2,365 lbs/day to Primary Digester #2, which equates to a volatile solids loading to both primary digesters of 0.04 lbs/ft³-day. The corresponding digester detention times are computed to be 44 and 47 days. Detention times greater than 15 days are required to meet Class B pathogen reduction.

Based upon an allowable volatile solids loading rate of 0.14 lbs/ft³-day, the maximum volatile solid loading that can be conveyed to Primary Digester #1 and #2 is 5,722 lbs/day and 9,104 lbs/day, respectively. With the current maximum total volatile solids loading of 3,942 pounds per day, the primary digesters can accept an additional

volatile solid loading of 10,884 pounds per day. Additional volatile solids loading can be obtained by adding the thickened waste activated sludge (WAS) from the Aeration Basins or through the addition of fats, oils and grease (FOG).

By increasing the volatile solid loading to the primary digesters by 10,884 pounds per day, at a volatile solid destruction of 50 percent and at an average gas production rate of 15 ft³/lb of volatile solid destroyed, the additional gas production is calculated to be 81,630 ft³/day. This gas production value coupled with the average actual measured gas production of 22,410 ft³/day yields an expected total gas production of 104,040 ft³/day. This would increase the engine and associated blower run times.

Current Mode of Operation plus Thickened WAS from Aeration Basins

Upon review of the facility's process data, the WAS flow from the aeration basins was determined to range from 30,000 to 47,000 gallons per day. As discussed previously, although not part of the current operation, the ability does exist in the piping configuration to convey the WAS flow from the Aeration Basins to the Gravity Belt Thickeners prior to being added to the Primary Digesters.

There are two Gravity Belt Thickeners designed to process 4,852 lbs/day, on a 7 day per week schedule. At a 0.5% solids content, the WAS flow from the Aeration Basins ranges from 1,200 to 1,960 lbs/day. Based upon the current flows and loads, the total WAS production from both the Oxidation Ditches and the Aeration Basins is within the GBTs' design capacity.

Based on the average WAS production of 1,731 lbs/day from the Aeration Basins, at a capture rate of 95% across the GBTs and an average volatile solids content of 81%, adding thickened WAS from the Aeration Basins results in an additional 1,330 lbs/day of volatile solids (6,380 gpd at 2.5% solids) that can be added to the Primary Digesters. This flow, in addition to the 17,065 gpd of primary sludge and WAS from the Oxidation Ditches, results in a detention time of 34 days. Since a new mixing system is currently being installed in Primary Digester #1, coupled with the cleaning of both Primary Digesters and the Secondary Digester that is also currently being performed, it is anticipated that the volatile solids destruction within the digesters will become more consistent with the expected performance. Therefore, it is assumed that a volatile destruction of approximately 55% will be achieved. At 55% destruction within the digesters and at an average digester gas production rate of 15 ft³/lb VS destroyed, an additional 10,973 ft³/day of digester gas production will be produced.

This potential option will be considered further, as the infrastructure already exists within the plant for thickening of this WAS flow and conveying this sludge flow to the primary digesters. It would be recommended that the existing piping be inspected and potentially lined or rehabilitated as required, prior to operating in this matter.

4.1.6.3 Addition of Fats, Oils and Grease (FOG)


At a time when energy costs are rising, energy recovery is especially beneficial. One of the desirable characteristics of biodegradable fats, oil, and grease (FOG) is its high energy content. When digested under anaerobic conditions, FOG increases the digester methane yield and total quantity of gas produced.

Typically, FOG digestion is more difficult than digestion of primary and waste activated sludge for digesters whose diameter is approximately more than twice its depth. FOG tends to float, so the challenge is to break up the FOG by ensuring adequate digester mixing intensity. Heating of the FOG to more than 160 °F prior to injection into the digester will liquefy the FOG, promoting better FOG digestion from enhanced mixing, as well as even distribution of FOG throughout the digester volume.

Since FOG is a high-energy material, slug loading the digester with FOG is not desirable, because it can lead to digester upsets or poor digestion of FOG. Therefore, a FOG holding tank large enough to enable FOG to be fed continuously to the digesters at a low rate is recommended.

A typical grease digestion system consists of a fiberglass-reinforced plastic or steel grease holding tank, tank mixing pump, grease feed pump, and tank heating system. Grease haulers can pump grease from their trucks into the grease holding tank. A typical FOG load is between 2,000 and 5,000 gallons and consists of 15 to 20 percent grease, with the balance being water. The grease holding tank mixing pump runs continuously, emulsifying the grease to the consistency of cottage cheese. Over time, grease is pumped into the primary digester. See Figure 4.1-4 for a typical grease digestion system.

Figure 4.1-4: Schematic of a Typical Grease Digestion System



Typically, the grease tank mixing pump is a chopper pump and the grease feed pump is a progressive-cavity pump. Care must be taken with regard to the selection of the material for the progressive-cavity pump's stator as significant wear can be expected as a result of conveying grit. The grease holding tank typically has a conical bottom to facilitate grit accumulation.

One issue with grease digestion is the timing of the grease deliveries and subsequent pumping into the digester. During periods of high deliveries, the grease feed rate to the digester must be increased to make room in the grease holding tank.

The most important design consideration is the increase in solids loading on the primary digester from the grease. Achieving a significant increase in digester gas production requires a significant increase in volatile solids loading. For example, for the City of Watsonville, California wastewater treatment plant, the average grease delivery was 6,100 gallons per day, which increased their volatile solids loading by 0.03 lb/day- ft³ or approximately 20 percent.

Other important design considerations include adequate digester mixing, grease holding tank volume, mixing rate, and grease feed pump flow. Because gas production will increase, the digester gas handling system should be checked for adequate capacity, including the gas pipe sizing and equipment capacities, such as pressure relief valves, flame arrestors, condensate tanks, and waste gas flares.

Adding grease to anaerobic digesters is relatively inexpensive and a potential source of income; however, an evaluation should be performed before beginning design of the digestion system. The evaluation should consider the following elements:

- Estimate potential grease volume;
- Evaluate digester grease-digestion capacity;
- Evaluate additional heating requirements for heating the grease within the grease holding tank;
- Estimate increased digester gas production with the assumption that grease is 100 percent volatile solids and digests 100 percent;
- Review existing gas handling capacity;
- Review existing gas utilization capacity;
- Determine size and location of grease receiving station;

- Estimate construction cost;
- Estimate increased gas production value;
- Estimate revenue from accepting grease;
- Perform an economic evaluation.

For the purposes of this analysis, it has been assumed that FOG loading will occur in addition to conveying thickened WAS from the Aeration Basins to the Primary Digesters. Therefore, based upon a target additional total volatile solids loading of 10,884 pounds per day as previously discussed and following the addition of 1,330 lbs VS/day of thickened WAS, there is the potential to add 9,554 lbs/day of volatile solids from FOG. At a solid content of FOG of 15 percent as indicated in design literature, approximately 7,635 gallons per day of FOG can be added to the primary digesters.

Based on previous experience and the variability of FOG characteristics, foaming and initial spikes in digester gas production will likely occur. In recent work, FOG addition has successfully attributed to 40-50% of the total VS loading. However, it is recommended that FOG addition be piloted or 'stress-tested' to determine the optimal loading, by adding small amounts of FOG and measuring the performance. Digesters may become unstable if FOG comprises more than 30% of the VS loading.

For the purposes of this analysis, a 30% VS loading from FOG has been assumed. This results in a total VS loading of 0.07 lbs VS/ft³-day or 7,531 lbs VS/day, which includes 2,259 lbs VS/day from FOG. At a solid content of FOG of 15 percent, this is an additional 1,805 gpd that can be added to the primary digesters. The detention time of the primary digesters when adding primary sludge & WAS under the current mode of operation at 17,065 gallons per day, thickened WAS from the aeration basins at 6,380 gpd and FOG at 1,805 gallons per day is calculated to be approximately 31 days. At a 60% VS destruction rate and a digester gas production rate of 15 ft³/lb VS destroyed, this additional volatile solids load would result in a total average digester gas production of 67,779 ft³/day.

Since the FOG will be heated to 160 °F, there will be no additional sludge heating load to convey the 1,805 gallons per day of FOG to the digesters.

For estimating purposes, assume a temperature loss from the primary digesters of approximately 1°F per day, the estimated heat loss can be computed as follows:

$$Q = (41,233 + 65,031) \text{ ft}^3 \times 62.4 \text{ lb/ft}^3 \times 1^\circ\text{F/day} = 6,620,873 \text{ Btu/day} = 276,286 \text{ Btu/hr.}$$

The total heat load requirement is calculated as follows:

$Q_T = 366,621 \text{ Btu/hr} + 276,286 \text{ Btu/hr} = 642,907 \text{ Btu/hr}$ which is less than the rated capacity of the existing boiler of 944,000 Btu/hr.

A conceptual design of the FOG system will consist of one (1) nominal capacity steel grease holding tank of 10,000 gallons with external jacketed heating coils, one (1) 350 gpm recirculation chopper pump, one (1) progressive cavity pump rated for 35 – 1600 gph with a variable frequency drive and inline grinder to be installed on the suction side of the progressive cavity pump. The FOG system will consist of PVC interconnecting piping. To achieve a 1,805 gallon per day FOG loading to the primary digesters and assuming a 5,000 gallon storage volume of FOG (typical volume capacity of a septage receiving truck), the frequency of FOG deliveries is estimated to be 2 times per week. The expected revenue from accepting FOG is \$0.06/gallon. If MCJM accepts two (2) deliveries of 4,200 gallons per week this would result in an annual revenue of \$26,208.

The governing heating requirement for the design of a FOG system must include the heating requirement for heating sludge to the primary digester and the heating requirement for raising the temperature of FOG within the FOG storage tank from 50 degrees F to 160 degrees F. Both of these heating requirements occur simultaneously until the FOG reaches the 160 degrees F. temperature. Therefore, based upon a 5,000 gallon storage volume of FOG and using a 10 degree temperature difference of FOG in the storage tank, the heating requirement to heat the grease within the storage tank is approximately 420,000 Btu/hr. Adding this heat transfer requirement to the sludge heat transfer requirement of 366,621 Btu/hr, the total heat transfer requirement is computed to be 786,621 Btu/hr.

The detailed analyses presented in Appendix E provides information on the available heat produced by the operation of the engines, based upon the projected gas production rates from different operating scenarios.

4.1.6.4 Addition of Peat Humic Substance (PHS)

The various sludge processing options and the addition of FOG discussed thus far, result in an increase in VS loading to the digestion complex and resulting increase in digester gas production. Another alternative available is the addition of peat humic substance (PHS).

PHS does not increase the solids loading of the digester, but rather stimulates the activity of the micro-organisms that are destroying the volatile solids and releasing digester gas. Prodex, which is a division of JSH International, is a company in NJ that provides PHS. Prodex's PHS product is called BAE™ (Biological Activity Enhancer). BAE is an organic liquid bio-stimulant that is derived from highly humified peat sources that is blended through a stabilization and extraction process.

gallon, which at an average dosing rate of 1.25 gallons per day, relates to an annual material cost of \$20,532.

Table 4.1-12 summarizes the above analyses for the digester loading operational scenarios.

| Table 4.1-12 Various Sludge Processing and Digester Loading Operational Scenarios | | | | | | |
|--|---------------------|--|--------------------------|------------------------------|--|-------------------------------------|
| Sludge Processing | VS (lbs/day) | Digester Loading (lbs/day-ft³) | Sludge Flow (gpd) | Detention Time (Days) | Gas Production (ft³/day) | Heating Requirement (Btu/hr) |
| Current Operation (PSL & TWAS) | 3,942 | 0.04 | 17,065 | 47 | 22,410 | 416,460 |
| Current Operation + TWAS from Aeration Basins | 5,272 | 0.05 | 23,445 | 34 | 33,383 | 416,460 |
| Current Operation + TWAS from Aeration Basins + FOG | 7,531 | 0.07 | 25,250 | 31 | 67,779 | 786,621 |
| Current Operation + PHS | 3,942 | 0.04 | 17,065 | 47 | 26,892 ¹ | 416,460 |

PSL = Primary Sludge
 TWAS = Thickened Waste Activated Sludge
 FOG = Fats, Oils, and Grease
 PHS = Peat, Humic Substance

1. It is recommended that the addition of PHS be piloted and the increase in digester gas production confirmed, as Prodex does not have experience with BAE addition to digesters with greater than 30 day detention times.

4.1.6.5 Economic Analysis

Appendix E includes detailed analyses for three (3) of the different operational schemes discussed herein: the addition of thickened WAS from the aeration basins, the addition of thickened WAS and FOG and the addition of PHS. These operational schemes have been evaluated in an effort to maximum the digester loading and the resulting digester gas production and use.

Table 4.1-13 summarizes the pertinent energy savings and energy production associated with the addition of thickened WAS from the Aeration Basins to the primary digesters.

Table 4.1-13: TWAS Addition Performance Summary

| Table 4.1-13 TWAS Addition Performance Summary | | | | | | | |
|---|--------------------------------------|---|--|---|---|---|--|
| Annual Biogas Production (ft ³ /day) | Annual Digester Heat Demand (Btu/hr) | Annual Biogas Utilized to run Blower (ft ³ /day) | Annual Reclaimed Heat from Engine Operation (Btu/hr) | Avg. Annual Biogas Utilized in Boilers (ft ³ /day) | Annual Heat Production from Boiler Operation on Biogas (Btu/hr) | Annual Available Heat for Building Heat Demand (Btu/hr) | Annual Thermal Energy Cost Savings at \$1.07/therm |
| 465,320 | 5,223,723 | 281,600 | 3,353,333 | 183,720 | 3,368,200 | 1,497,811 | \$14,805 |

This operational scheme results in an increase in digester gas production, which can then be utilized to off-set the natural gas consumption to heat the building and the primary digesters and result in an annual thermal energy cost savings of \$14,805.

Table 4.1-14 summarizes the pertinent energy savings and energy production associated with the addition of thickened WAS from the Aeration Basins and fats, oils and grease to the primary digesters.

| Table 4.1-14 TWAS & FOG Addition Performance Summary | | | | | | | | |
|---|--------------------------------------|---|--|---|---|--|---|--|
| Annual Biogas Production (ft ³ /day) | Annual Digester Heat Demand (Btu/hr) | Annual Biogas Utilized to Run Blower (ft ³ /day) | Annual Reclaimed Heat from Engine Operation (Btu/hr) | Avg. Annual Biogas Utilized in Boilers (ft ³ /day) | Annual Heat Production from Boiler Operation on Biogas (Btu/hr) | Annual FOG System Heat Demand (Btu/hr) | Annual Available Heat for Building Heat Demand (Btu/hr) | Annual Thermal Energy Cost Savings at \$1.07/therm |
| 878,072 | 5,223,723 | 281,600 | 3,353,333 | 596,472 | 10,935,320 | 4,399,452 | 4,665,479 | \$36,422 |

This operational scheme results in an increase in digester gas production, which can then be utilized to off-set the natural gas consumption to heat the building and the primary digesters and result in an annual thermal energy cost savings of \$36,422. The thermal energy cost savings is less as a result of the FOG system heat demand. Additionally, if MCJM accepts two (2) deliveries of 4,200 gallons per week of FOG this would result in annual revenue of \$26,208.

Table 4.1-15 summarizes the pertinent energy savings and energy production associated with the addition of peat, humic substance to the primary digesters.

Table 4.1-15: PHS Addition Performance Summary

| Table 4.1-15 PHS Addition Performance Summary | | | | | | | |
|--|---|--|---|--|--|--|---|
| Annual Biogas Production (ft³/day) | Annual Digester Heat Demand (Btu/hr) | Annual Biogas Utilized to Run Blower (ft³/day) | Annual Reclaimed Heat from Engine Operation (Btu/hr) | Avg. Annual Biogas Utilized in Boilers (ft³/day) | Annual Heat Production from Boiler Operation on Biogas (Btu/hr) | Annual Available Heat for Building Heat Demand (Btu/hr) | Annual Thermal Energy Cost Savings at \$1.07/therm |
| 400,373 | 5,223,723 | 257,195 | 3,062,711 | 143,330 | 2,627,717 | 1,263,612 | \$9,865 |

This operational scheme results in an increase in digester gas production, which can then be utilized to off-set the natural gas consumption to heat the building and the primary digesters and result in an annual thermal energy cost savings of \$9,865. Additionally, if MCJM doses 1.25 gallons per day of PHS, this relates to an annual material cost of \$20,532.

As a result, the addition of PHS during the current operational practices is not recommended. The addition of PHS in addition to the addition of thickened WAS from the aeration basins would allow for the potential thermal cost savings to off-set the additional operational costs associated with accepting PHS and maintaining the system. This evaluation is presented in Table 4.1-16.

Table 4.1-16 summarizes the simple payback associated with the various digestion system optimization options.

| Table 4.1-16 Digestion Optimization Alternatives | | | |
|--|---|---|---|
| | Alt. 1 – Add TWAS from Aeration Basins | Alt. 2 – TWAS and FOG Addition | Alt. 3 – TWAS and PHS Addition |
| Engineers Opinion of Probable Construction Cost ¹ | \$15,600 | \$409,656 | \$15,600 ⁴ |
| New Jersey SmartStart Rebate | \$0 | \$0 | \$0 |
| Total Cost | \$15,600 | \$409,656 | \$15,600 |
| Annual Thermal Energy Cost Savings | \$14,805 | \$36,422 | \$24,670 |
| Annual Maintenance Cost Savings (AMCS) | NA | (\$15,600) | (\$2,000) |
| Annual Revenue ² | NA | \$26,208 | (\$20,532) |
| Simple Payback (years) | 1.1 | 8.7 | 7.3 |
| Annual Return on Investment (AROI) | 90% | 6.5% | 8.7% |
| Lifetime Energy Savings ³ | \$397,816 | \$978,673 | \$662,892 |
| Internal Rate of Return (IRR) | 98% | 12% | 30.2% |
| Net Present Value (NPV) | \$271,876 | \$548,552 | \$128,210 |

1. The Engineer's Option of Construction Cost is based solely upon a conceptual engineering level of effort. A more detailed construction cost estimate should be prepared as design documents are progressed.
2. Annual revenue is calculated on the assumption that 2 FOG deliveries of 4,200 gallons per week would be accepted every week at a cost of \$0.06/gallon.
3. 3% yearly inflation on natural gas costs. Assumption on equipment life is based on manufacturer information.
4. It would be recommended that the digesters be cleaned prior to testing the addition of PHS, however, this is included under the current digester gas mixing system contract.

Although the capital cost is significantly greater for Alternative 2 than 1, the addition of thickened WAS from the aeration basins plus FOG, the annual revenue and thermal energy cost savings makes this the most attractive alternative from a financial point of view and as such it is recommended that MCJM further investigate this option. As discussed previously a number of considerations, potential piloting and design work would be required to confirm a consistent supply of FOG.

In the mean time, modifying the current operation of the digestion system with the addition of thickened WAS from the aeration basins will improve digester gas production and create thermal energy savings with a minimal capital investment.

4.2 Building HVAC Systems

The goal of this section is to present any heating and cooling energy reduction and cost saving measures that may also be cost beneficial. Where possible, measures will be presented with a life-cycle cost analysis. This analysis displays a payback period based on weighing the capital cost of the measure against predicted annual fiscal savings.

Some buildings, with more complex HVAC systems, were modeled to more accurately predict energy usage savings from certain recommendations. Buildings modeled were done so using software called eQuest, a Department of Energy-sponsored energy modeling program, to establish a baseline space heating and cooling energy usage. Climate data from Belvidere, NJ was used for analyses. From this, the model may be calibrated, using historical utility bills, to predict the impact of theoretical energy savings measures. However, because the entire Wastewater Plant is on one electric bill, CDM was not able to accurately track electric heating requirements for each individual building at the facility. The electric usage for heating is extremely small when compared to the electric use that is process related. For this reason, modeling all of the buildings and calibrating to the entire plant's electric bill would not be beneficial for estimated electrical heating or energy savings.

There are two gas meters at the plant. One meter is for the 1990 upgrade, which includes the Sludge Handling Building and the Final Clarifier No. 3 & 4 building. The other meter services the remaining four buildings that have gas fired equipment. The four buildings that are on meter 2808461 are the two Digester Buildings, the Blower Building, and the Administration Building. The digester building boilers provide process hot water for digesters heating, and can operate on either natural, or digester gas. Due to the boilers being used for purposes other than heating the buildings, the four buildings were not able to be calibrated to actual gas usage. The Blower Building was the only one of the four buildings that was modeled. The proportion of the total gas used through meter 2808461 that belongs to the blower building is unknown, so the model could not be calibrated. The two buildings that were a part of the 1990 upgrade were modeled because they could be more accurately calibrated to the actual gas usage of the plant.

Once annual energy savings from a particular measure has been predicted and the initial capital cost has been estimated, payback periods may be approximated. Equipment cost estimate calculations are provided in Appendix G. Building eQuest model run summaries for ECRMs may be found in Appendix F.

4.2.1 Administration Building

The Administration Building office area is heated and cooled by a gas fired Trane rooftop unit. The rooftop unit was manufactured in 2006 and is not in need of replacement. The basement and electrical room are heated by gas fired unit heaters. The sulfur dioxide storage, chlorine room, and bi-sulfate room are all heated by electric unit heaters. There is an Emerson digital thermostat located next to the conference room. Staff mentioned that they currently have night setback incorporated. For a more detailed description of the heating ventilation and air conditioning see Section 2.2.2.

The HVAC equipment at the Administration Building appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a window air conditioning unit has a median service life of 10 years. Therefore, if a window unit has been in service for more than 10 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment associated with the Administration Building noted during CDM's on site audit is listed in Table 4.2.1-1, along with ASHRAE-expected service lives. It should be noted that equipment that was not seen while on site and was observed on the provided drawings are included. Where equipment ages were not found on the equipment tags, they have been estimated based on the unit appearance, approximate renovation dates, or last manufacture date of the particular model. Additionally, in cases where a unit's manufacturer and/or model could not be determined due to an unreadable, faded, destroyed, or lost tag, manufacturer and model number information has been represented as "unknown".

| Table 4.2.1-1 Administration Building HVAC Equipment Service Lives | | | | | | | |
|---|------------------------|-------------------------|---------------------|--------------------------------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Forced Air Furnace with Cooling Rooftop Unit | Roof | Administration Building | Trane | YSC120A4EHA2R0 00000000000D | 80% | 4 | 15 |
| Electric Unit Heater | Sulfur Dioxide Storage | Sulfur Dioxide Storage | Dayton | Unknown | 100% | Unknown (good) | 13 |
| Electric Unit Heater | Chlorine Room | Chlorine Room | Trane | Unknown | 100% | Unknown (good) | 13 |
| Electric Unit Heater | Bi-Sulfite Room | Bi-Sulfite Room | Dayton | Unknown | 100% | Unknown (good) | 13 |
| Gas Fired Unit Heater | Electrical Room | Electrical Room | Airtherm | Unknown | 80% | Unknown (old) | 13 |
| Gas Fired Unit Heater | Basement | Basement | Airtherm | Unknown | 80% | Unknown (old) | 13 |
| Small Exhaust Fans (x3) | Roof | Offices | Penn Ventilator Co. | Unknown | Unknown | Unknown (old) | 20 |
| Large Exhaust Fan | Roof | Offices | Penn Ventilator Co. | 33 Watt | Unknown | Unknown (old) | 20 |
| Exhaust Fan | Roof | Sulfur Dioxide Storage | Penn Ventilator Co. | FMX-18B | Unknown | Unknown (good) | 20 |
| Ventilator | Roof | Garage | Delhi Industries | B1-10CW UPN EIS | Unknown | 11 | 20 |

| Table 4.2.1-1 Administration Building HVAC Equipment Service Lives | | | | | | | |
|---|----------------|---------------|---------|---------|---------|----------------|----|
| Wall Exhaust Fan | Chlorine Room | Chlorine Room | Unknown | Unknown | Unknown | Unknown (good) | 20 |
| Wall Ventilation Fan | Southwest Wall | Laboratory | ILG | CWF-22 | Unknown | Unknown (old) | 20 |

CDM also created an inventory of observed domestic water heaters. This will identify any water heaters that are in need of replacement. Domestic water heaters observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2.1-2 below.

| Table 4.2.1-2 Administration Building Domestic Water Heaters | | | | | |
|---|-------|----------------------------|----------|------------------|-----------------------|
| Location | Make | Storage Capacity (Gallons) | Type | Heating Capacity | Estimated Age (Years) |
| Garage | Rheem | 50 | Electric | 4500 Watts | Unknown (Good) |

4.2.2 Grit Building

The Grit Building HVAC equipment consists of an explosion proof electric unit heater, and a roof mounted exhaust fan. The HVAC equipment at the Grit Building appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

All major equipment noted during CDM's on site audit is listed in Table 4.2.2-1 below, along with estimated current ages and ASHRAE-expected service lives.

| Table 4.2.2-1 Grit Building HVAC Equipment Service Lives | | | | | | | |
|---|---------------|------------------|--------------|-------------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Explosion Proof Electric Unit Heater | Grit Building | Grit Building | Sentinel | XUHA05A73SP | 100% | Unknown (old) | 13 |
| Exhaust Fan | Roof | Grit Building | Unknown | Unknown | Unknown | Unknown | 20 |

4.2.3 Digester No. 1 Building

The Digester No. 1 Building’s heating is provided by a Buderus cast-iron boiler. The boiler is 16 years old and has not exceeded half of its ASHRAE expected life. A replacement may be warranted when it approaches 35 years old. The boiler has two gas trains that are located on the side of the boiler. One of the gas trains is for natural gas, the other for digester gas. This boiler sends hot water to the sludge heat exchanger which allows for the heating of the digester. The hot water is also sent through a hot water unit heater in the boiler room, and hot water fin tube radiators. An exhaust fan exhausts air from the three floors of the building.

During the audit, CDM noted that there was a combustion air louver with dimensions of approximately 2’ x 3’ located in the boiler room. Outdoor combustion air should be provided to the boiler room according to Section 304 of the New Jersey Fuel Gas Code. Having the appropriate proportion of fuel and combustion air can increase the efficiency of the boiler and generate savings for the Madison-Chatham Joint Meeting.

The HVAC equipment at the Digester No. 1 Building appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

All major equipment noted during CDM’s on site audit is listed in Table 4.2.3-1 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that equipment that was not seen while on site and was observed on the provided drawings are included.

| Table 4.2.3-1 Digester Building No. 1 HVAC Equipment Service Lives | | | | | | | |
|---|------------------------|--------------------|--------------|----------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Gas Fired Cast Iron Boiler | Boiler Room | Digesters | Buderus | G 405/10 | 75% | 16 | 35 |
| Hot water Unit Heater | Boiler Room | Boiler Room | Modine | Unknown | Unknown | Unknown (old) | 20 |
| Hot Water Baseboard Heater | Engine Room | Engine Room | Unknown | Unknown | Unknown | Unknown | 20 |
| Exhaust Fan | Roof Between Digesters | Three Floors Below | Unknown | Unknown | Unknown | Unknown (old) | 20 |

4.2.4 Digester No. 2 Building

The Digester No. 2 Building’s heating is provided by a high efficiency Buderus cast-iron boiler. The boiler is 10 years old and has a thermal efficiency of about 93%. The boiler has two gas trains that are located on the side of the boiler. One of the gas trains is for natural gas, the other for digester gas. This boiler sends hot water to the sludge heat exchanger which allows for the heating of the digester. The hot water is also sent through hot water fin tube radiators. Three exhaust fan exhaust air from the building. For a more detailed description of the heating ventilation and air conditioning see Section 2.5.2.

During the audit, CDM noted that there was a combustion air louver with dimensions of approximately 3’ x 3’ located in the boiler room. Outdoor combustion air should be

provided to the boiler room according to Section 304 of the New Jersey Fuel Gas Code. Having the appropriate proportion of fuel and combustion air can increase the efficiency of the boiler and generate savings for the Madison-Chatham Joint Meeting.

The HVAC equipment at the Digester No. 2 Building appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

All major equipment noted during CDM’s on site audit is listed in Table 4.2.4-1 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that equipment that was not seen while on site and was observed on the provided drawings are included.

| Table 4.2.4-1 Digester Building No. 2 HVAC Equipment Service Lives | | | | | | | |
|---|-------------------------|-----------------------------------|---------------------|--------------|-----------------------------|------------------------------|-------------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Gas Fired Cast Iron Boiler | Boiler Room | Digesters and Bar Screen Building | Buderus | GE515/7 | 93% | 10 | 35 |
| Hot Water Baseboard Heater | Pump Recirculation Room | Pump Recirculation Room | Unknown | Unknown | Unknown | Unknown | 20 |
| Exhaust Fan (x3) | Roof | Bar Screen Building | Unknown | Unknown | Unknown | Unknown | 20 |

4.2.5 Waste Oil Building

The Waste Oil Building HVAC equipment consists of a Qmark electric unit heater. The HVAC equipment at the Grit Building appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

All major equipment noted during CDM’s on site audit is listed in Table 4.2.5-1 below, along with estimated current ages and ASHRAE-expected service lives.


| Table 4.2.5-1 Waste Oil Building HVAC Equipment Service Lives | | | | | | | |
|--|---------------|------------------|--------------|---------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Electric Unit Heater | First Floor | First Floor | Qmark | Unknown | 100% | Unknown (good) | 13 |

4.2.6 Blower Building

The Blower Building’s heating is provided by a natural gas fired Utica steam boiler. The boiler is 11 years old and has not exceeded half of its ASHRAE expected life. The steam fills the American Radiator Co. radiators throughout the building. A Modine steam unit heater heats the basement. For a more detailed description of the heating ventilation and air conditioning see Section 2.7.2.

Figure 4.2.6-1 below displays the anticipated gas use at the Blower Building. As stated in Section 4.2.6, the anticipated gas use is based on building models, and could not be calibrated to actual gas use. Due to eQuest limitations, the building was modeled with a hydronic heating system. CDM is using the building model to estimate the savings that are discussed in this section.

Figure 4.2.6-1: Blower Building Natural Gas Usage




The current cast iron Utica boiler has an input rating of 300 MBH. A hot water gross I=B=R rating of 243 MBH gives this boiler a combustion efficiency of 81%.

CDM recommends replacing this boiler with a higher-efficiency steam boiler. Current steam boilers can provide combustion efficiencies of up to 86%.

CDM anticipates that one (1) 243 MBH output high-efficiency steam boiler is more than enough heating capacity to heat the Blower Building.

Figure 4.2.6-2 predicted gas usage with predicted gas usage resulting from a switch to a high-efficiency steam boiler. The replacement boiler is modeled with a full-load efficiency of 85% in mild weather.

Figure 4.2.6-2: Blower Building – Boiler Upgrade - Natural Gas Usage



Fiscal savings from such an upgrade are then identified in Table 4.2.6-1 below. Lifetime savings calculations for all ECRM's may be found in Appendix N. It's important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

| Table 4.2.6-1 Blower Building Boiler Upgrade Payback | |
|---|----------|
| Predicted Annual Savings (Therms) | 161 |
| Total Annual Savings | \$172 |
| Initial Capital Cost of Upgrade | \$15,071 |
| Incentives** | \$300 |

| Table 4.2.6-1 Blower Building Boiler Upgrade Payback | |
|---|-------------|
| Cost of Upgrade | \$15,071 |
| Simple Payback | 87.6 |
| Lifetime Energy Savings (25 years)* | \$5,509 |
| Annual Maintenance Cost Savings (AMCS) | \$0 |
| Annual Return on Investment (AROI) | (2.86%) |
| Internal Rate of Return (IRR) | (5.38%) |
| Net Present Value (NPV) | (\$10,896) |

*Assumes 2% yearly inflation on natural gas costs


**Incentives, per New Jersey Clean Energy Program, are \$300 per unit

Due to the long payback, CDM does not recommend this replacement. The current Utica boiler is only 11 years old, and boiler should be evaluated for replacement when it nears its expected life.

The steam piping that was seen in the Blower Building was bare with no insulation. Significant savings can be realized from insulating the steam piping. 3E Plus is an insulation thickness computer program and was used to estimate the savings. The steam is assumed to be maintained at 220 degrees F, and the ambient temperature surrounding the piping is assumed to be a conservative 80 degrees F. The existing pipe diameter of 1.5" was used for the calculation. The 5,000 operating hours per year was taken from the eQuest generated model. Mineral Fiber insulation with an all service jacket was the material input.

A series of insulation thicknesses between 1" to 3" were evaluated to find the shortest payback. Figure 4.2.6-3 shows the savings and cost associated with each insulation thickness.

Figure 4.2.6-3: Blower Building – Pipe Insulation Savings



Fiscal savings from the 1" insulation addition to the steam piping are then identified in Table 4.2.6-2 below. Lifetime savings calculations for all ECRM's may be found in Appendix N. It's important to note that these are estimates based on building models and simulation software. Further investigation of insulation material, thickness and savings is warranted before pursuing installation.

| Table 4.2.6-2 Blower Building Pipe Insulation Payback | |
|--|------------|
| Predicted Annual Savings (Therms) | 1,379 |
| Total Annual Savings | \$1,475 |
| Initial Capital Cost of Upgrade | \$955 |
| Incentives** | \$0 |
| Cost of Upgrade | \$955 |
| Simple Payback | 0.6 |
| Lifetime Energy Savings (24 years)* | \$44,872 |
| Annual Maintenance Cost Savings (AMCS) | \$0 |
| Annual Return on Investment (AROI) | 150.28% |

| Table 4.2.6-2 Blower Building Pipe Insulation Payback | |
|--|----------|
| Internal Rate of Return (IRR) | 157.45% |
| Net Present Value (NPV) | \$33,414 |

*Assumes 2% yearly inflation on natural gas costs

During the audit, CDM noted that there wasn't proper combustion air supplied to the boiler room. Outdoor combustion air should be provided to the boiler room according to Section 304 of the New Jersey Fuel Gas Code. Having the appropriate proportion of fuel and combustion air can increase the efficiency of the boiler and generate savings for the Madison-Chatham Joint Meeting.

All major equipment noted during CDM's on site audit is listed in Table 4.2.6-3 below, along with estimated current ages and ASHRAE-expected service lives.

| Table 4.2.6-3 Blower Building HVAC Equipment Service Lives | | | | | | | |
|---|-------------------------|-------------------------|--------------|------------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Gas Fired Unit Heater | Basement | Basement | Modine | H 345 | 80% | Unknown (old) | 13 |
| Gas Fired Cast Iron Steam Boiler | Boiler Room Basement | Blower Building | Utica | PEG300CIDE | 81% | 11 | 30 |
| Belt Driven Ventilation Fan | Blower Room First Floor | Blower Room First Floor | Unknown | Unknown | Unknown | Unknown | 15 |


CDM also created an inventory of observed domestic water heaters. This will identify any water heaters that are in need of replacement. Domestic water heaters observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2.6-4 below.

| Table 4.2.6-4 Blower Building Domestic Water Heaters | | | | | |
|---|----------|----------------------------|----------|------------------|-----------------------|
| Location | Make | Storage Capacity (Gallons) | Type | Heating Capacity | Estimated Age (Years) |
| Boiler Room Basement | Vanguard | 30 | Electric | 4500 Watts | Unknown (Good) |

4.2.7 Sludge Handling Building

As stated above, the entire Wastewater Treatment Facility is on one electric bill. Modeling all of the buildings and calibrating to the entire plant’s electric bill would not be beneficial for estimated electrical usage or energy savings. However, there are two buildings on gas meter number 2414133 that can be calibrated. The Sludge Handling Building and the Final Clarifiers No. 3 & 4 Building were modeled and calibrated to match the actual gas usage for the plant. To calibrate the models, CDM used natural gas bills from December, 2007 through April, 2010. Figure 4.2.7-1 below compares actual monthly gas usages, with those predicted by the eQuest models for the two buildings. While some natural gas is used for domestic water heating, the boilers account for the majority of the natural gas usage at the school. The models combined are modeled within 7% of the actual usage.

Figure 4.2.7-1: Sludge Handling and Final Clarifiers No. 3&4 Buildings - Natural Gas Usage



The Sludge Handling Building is heated by hot water supplied by a Raypak modulating boiler. The boiler has an input rating of 1,250 MBH and a gross I=B=R output rating of 1,087 MBH. This boiler has a thermal efficiency of 87%. Unit heaters and heating and ventilating units are served by this boiler. This boiler also serves the H&V unit and unit heaters at the Final Clarifiers Building No. 3 & 4. Air cooled condensing units are located on the roof of the building. They provide cooling by means of ceiling mounted air handling units to the break and control room. For a more detailed description of the heating ventilation and air conditioning see Section 2.8.2.

There is a decommissioned heat recovery system that was used to serve the filter room. The superintendent has investigated the possibility of operating the system again. It was determined that the heat recovery system would be too costly to repair.

During the audit, CDM noted that there are four combustion air louvers with dimensions of approximately 2' x 2' at both high and low locations in the mechanical room. Outdoor combustion air should be provided to the boiler room according to Section 304 of the New Jersey Fuel Gas Code. Having the appropriate proportion of fuel and combustion air can increase the efficiency of the boiler and generate savings for the Madison-Chatham Joint Meeting.

The HVAC equipment at the Sludge Handling Building appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

All major equipment noted during CDM's on site audit is listed in Table 4.2.7-1 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that equipment that was not seen while on site and was observed on the provided drawings are included.

| Table 4.2.7-1 Sludge Handling Building HVAC Equipment Service Lives | | | | | | | |
|--|---------------|--|--------------|---------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Gas Fired Modulating Boiler | Boiler Room | Sludge Handling & Pump Station Buildings | Raypak | H7-1253 | 87% | 6 | 35 |

| Table 4.2.7-1 Sludge Handling Building HVAC Equipment Service Lives | | | | | | | |
|--|-----------------|--|---------|------------------|---------|---------------|----|
| Hot Water Unit Heater | Boiler Room | Boiler Room | Trane | UHSA-020W-2C-AAA | Unknown | Unknown | 20 |
| Hot Water Unit Heater | Electrical Room | Electrical Room | Trane | Unknown | Unknown | Unknown | 20 |
| Hot Water Unit Heater (x4) | Pump Room | Pump Room | Trane | Unknown | Unknown | Unknown | 20 |
| Belt Drive Ventilation Fans (x2) | Pump Room | Pump Room | Unknown | Unknown | Unknown | Unknown | 15 |
| Hot Water Unit Heater (x4) | Thickener Room | Thickener Room | Trane | Unknown | Unknown | Unknown | 20 |
| Hot Water Unit Heater (x2) | Mezzanine Level | Mezzanine Level | Trane | UHSA-020W-2C-AAA | Unknown | Unknown | 20 |
| Heating & Ventilation Unit (HV-2) | Mezzanine Level | Pump Room | Trane | TVDB06AG0FBARR02 | Unknown | Unknown (old) | 20 |
| Heating & Ventilation Unit (HV-3) | Mezzanine Level | Janitors Closet, Restroom, Locker Room | Trane | TV0B03AG0FSALL02 | Unknown | Unknown (old) | 20 |
| Air Handling Unit (AC-1) | Mezzanine Level | Control Room | Trane | TWEO18C14OBO | Unknown | 6 | 15 |
| Air Handling Unit (AC-2) | Ceiling | Break Room | Unknown | Unknown | Unknown | Unknown | 15 |
| Condensing Unit (ACC-1) | Roof | AC-1 | Trane | TTB012C100A2 | 10 SEER | 7 | 15 |

| Table 4.2.7-1 Sludge Handling Building HVAC Equipment Service Lives | | | | | | | |
|--|------|--|-----------------|-----------------|------------|---------|----|
| Condensing Unit (ACC-2) | Roof | AC-2 | Trane | 2TTB3018A1000AA | 13.25 SEER | 4 | 15 |
| Heating and Ventilation Rooftop Unit (HV-1) | Roof | Filter Room, Sludge Handling Area | Trane | PCC-37EA | Unknown | Unknown | 20 |
| Roof Ventilator | Roof | Filter Room | Unknown | Unknown | Unknown | Unknown | 20 |
| Roof Ventilator | Roof | HV-3 | Unknown | Unknown | Unknown | Unknown | 20 |
| Roof Ventilator | Roof | AC-1 & AC-2 | Unknown | Unknown | Unknown | Unknown | 20 |
| Roof Ventilator | Roof | HV-2 | Unknown | Unknown | Unknown | Unknown | 20 |
| Roof Ventilator | Roof | Electrical Room | Unknown | Unknown | Unknown | Unknown | 20 |
| Exhaust Fan | Roof | Locker Room, Restroom, Janitors Closet | Unknown | Unknown | Unknown | Unknown | 20 |
| Exhaust Fan | Roof | Locker Room, Restroom, Janitors Closet | Penn Ventilator | FMX-12B | Unknown | Unknown | 20 |
| Exhaust Fan | Roof | Electrical Room | Penn Ventilator | FMX-24B | Unknown | Unknown | 20 |

CDM also created an inventory of observed domestic water heaters. This will identify any water heaters that are in need of replacement. Domestic water heaters observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2.7-2 below.

| Table 4.2.7-2 Sludge Handling Building Domestic Water Heaters | | | | | |
|--|------------|----------------------------|------|------------------|-----------------------|
| Location | Make | Storage Capacity (Gallons) | Type | Heating Capacity | Estimated Age (Years) |
| Boiler Room | A.O. Smith | 100 | Gas | 199 MBH | Unknown (good) |

4.2.8 Final Clarifiers Building No. 1 & 2

The Final Clarifiers Building No. 1 & 2 HVAC equipment consists of a Dayton electric unit heater and a gravity ventilator. The HVAC equipment at the Final Clarifiers Building No. 1 & 2 appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

All major equipment noted during CDM's on site audit is listed in Table 4.2.8-1 below, along with estimated current ages and ASHRAE-expected service lives.

| Table 4.2.8-1 Final Clarifiers Building No. 1 & 2 HVAC Equipment Service Lives | | | | | | | |
|---|---------------|------------------|--------------|---------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Electric Unit Heater | Basement | Basement | Dayton | 2YU56 | 100% | Unknown (good) | 13 |
| Exhaust Fan | Concrete Slab | Basement | Unknown | Unknown | Unknown | Unknown | 20 |

4.2.9 Final Clarifiers Building No. 3 & 4

Final Clarifiers Building No. 3 & 4 is heated by the hot water boiler from the Sludge Handling Building. The hot water runs through a heating and ventilating unit that serves the basement. A Trane hot water unit heater provides additional heating to the basement. Hot water fin tube radiators also provide heating to the building. For a more detailed description of the heating ventilation and air conditioning see Section 2.10.2.

The HVAC equipment at the Final Clarifiers Building No. 3 & 4 appeared to be operating efficiently and based upon our site inspection appears to be in good operating order. Due to the equipment condition, CDM did not identify any HVAC-related energy savings recommendations for this building.

All major equipment noted during CDM's on site audit is listed in Table 4.2.9-1 below, along with estimated current ages and ASHRAE-expected service lives.

| Table 4.2.9-1 Final Clarifier Building No. 3 & 4 HVAC Equipment Service Lives | | | | | | | |
|--|--------------------------------|--------------------------------|--------------|------------------|----------------------|-----------------------|------------------------------|
| Description | Unit Location | Service Location | Manufacturer | Model | Estimated Efficiency | Estimated Age (Years) | ASHRAE Expected Life (Years) |
| Heating & Ventilating Unit | Mechanical/ Electrical Room | Basement | Trane | TVDB03AGOFNSRRO2 | Unknown | 20 | 20 |
| Hot Water Unit Heater | Basement | Basement | Trane | 42-S | Unknown | 20 | 20 |
| Exhaust Fan | Roof | Mechanical/ Electrical Room | Unknown | 1,200 CFM | Unknown | 20 | 20 |
| Exhaust Fan | Roof | Basement | Unknown | 1,000-2,000 CFM | Unknown | 20 | 20 |

| Table 4.2.9-1 Final Clarifier Building No. 3 & 4 HVAC Equipment Service Lives | | | | | | | |
|--|------|-----------------------------------|---------|---------|---------|----|----|
| Gravity Roof Vent | Roof | Mechanical/ Electrical Room | Unknown | Unknown | Unknown | 20 | 20 |
| Gravity Roof Vent | Roof | HV Unit | Unknown | Unknown | Unknown | 20 | 20 |

4.3 Building Lighting Systems

The goal of this section is to present any lighting energy conservation measures that may also be cost beneficial. It should be noted that replacing current bulbs with more energy-efficient equivalents will have a small effect on the building heating and cooling loads. The building cooling load will see a small decrease from an upgrade to more efficient bulbs and the heating load will see a small increase, as the more energy efficient bulbs give off less heat.

Two options are offered for most buildings. The first option will be for upgrading existing interior lighting, if applicable. The second option will be for upgrading existing exterior lighting, if applicable. A total cost for upgrading both options at the same time will be presented. Retrofitting of existing fluorescent fixtures includes upgrading both ballasts and lamps for the fixture. Refer to Appendix I for more information.

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles.

For the Molitor Water Pollution Control Facility (MWPCF), it was noted that there were no interior occupancy sensors installed. Installing occupancy sensors will typically increase energy savings; however, if the space is not occupied often in the first place, there will be little savings by installing occupancy sensors. However, certain areas of the MWPCF plant could benefit from installation of occupancy sensors. Therefore, occupancy sensor installation has been recommended in this report. Refer to Appendix I for occupancy sensor locations and quantities.

Please note that the Engineer’s Estimate of Probable Construction Costs presented herein are estimates based on historic data compiled from similar installations and engineering opinions. Additional engineering will be required for each measure

identified in this report and final scope of work and budget cost estimates will need to be confirmed prior to the coordination of project financing or the issuance of a Request for Proposal.

4.3.1 Administration Building

It is recommended that the existing lighting system at the Administration Building be upgraded to high efficiency standards to reduce power consumption. In general, the recommended lighting upgrade, as presented in Appendix I, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Options for improving the interior and exterior lighting for the Administration Building are listed in Table 4.3-1.

| Table 4.3-1 Administration Building Lighting System Improvements | |
|---|---|
| Interior Lighting | High Performance T8 Retrofit of T12 Fixtures and HID Fixture, Incandescent to CFL |
| Exterior Lighting | HID to CFL |

The annual energy savings for these options are as follows:

Interior Lighting: 4.0kW, 9,045.0 kWh and \$1,369.4
Exterior Lighting: 0.5kW, 2,168.1 kWh and \$328.3

The following table, Table 4.3-2, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Administration Building.

| Table 4.3-2 Administration Building Lighting System Improvements*** | | | |
|--|--------------------------|--------------------------|--------------|
| | Interior Lighting | Exterior Lighting | Total |
| Engineer's Opinion of Probable Cost | \$15,690.3 | \$116.4 | \$15,806.7 |
| New Jersey SmartStart Rebate | -\$1,075* | -\$0**** | -\$1,075* |
| Total Cost | \$14,615.3 | \$116.4 | \$14,731.8 |

| Table 4.3-2 Administration Building Lighting System Improvements*** | | | |
|--|--------------------------|--------------------------|------------------|
| | Interior Lighting | Exterior Lighting | Total |
| Annual Energy Savings | \$1,369.4 | \$328.3 | \$1,697.7 |
| Annual Maintenance Cost Savings (AMCS) | \$260.5 | -\$1.6 | \$258.9 |
| Simple Payback | 9.0 years | 0.4 years | 7.5 years |
| Annual Return on Investment (AROI) | 4.49% | 274.01% | 6.61% |
| Lifetime Energy Savings (15 years)** | \$25,469.4 | \$6,106.0 | \$31,575.4 |
| Internal Rate of Return (IRR) | 9.98% | 283.68% | 12.95% |
| Net Present Value (NPV) | \$9,121.3 | \$4,641.5 | \$13,762.7 |

* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.
 **3% yearly inflation on electricity costs. Total lifetime savings does not equal sum of combined savings.
 ***See Appendix G & N for ECRM Financial Analyses
 ****No incentives are available for the type of retrofit being recommended.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours Without Sensors” in Appendix I.

4.3.2 Grit Building

It is not recommended to upgrade the existing interior lighting at the Grit Building. Payback calculations yield an excessive simple payback to replace the four explosion proof interior lights. Additionally, these fixtures are turned off during non-work hours, and the building is limitedly occupied. No exterior fixtures exist.

Therefore, based upon the above, no recommendations to improve energy reduction are being made at this time.

Refer to Appendix Q for complete ECRM financial calculations.

4.3.3 Digester #1 Building

It is not recommended to upgrade either the existing interior or exterior lighting at the Digester #1 Building. Payback calculations yield an excessive simple payback to

replace the nineteen explosion proof interior lights, and two explosion proof exterior lights.

Therefore, based upon the above, no recommendations to improve energy reduction are being made at this time.

Refer to Appendix Q for complete ECRM financial calculations.

4.3.4 Digester #2 Building

It is not recommended to upgrade either the existing interior or exterior lighting at the Digester #1 Building. The interior lighting simple payback calculation yields an excessive simple payback to replace the fourteen explosion proof lights, and energy efficient lights already exist on the exterior of the building.

Therefore, based upon the above, no recommendations to improve energy reduction are being made at this time.

Refer to Appendix Q for complete ECRM financial calculations.

4.3.5 Waste Oil Building

It is recommended that the existing lighting system at the Waste Oil Building be upgraded to high efficiency standards to reduce power consumption. In general, the recommended lighting upgrade, as presented in Appendix I, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Options for improving the interior and exterior lighting for the Waste Oil Building are listed in Table 4.3-3.

| Table 4.3-3 Waste Oil Building Lighting System Improvements | |
|--|--------------------------------------|
| Interior Lighting | CFL Retrofit of Incandescent Fixture |
| Exterior Lighting | CFL Retrofit of Incandescent Fixture |

The annual energy savings for these options are as follows:

Interior Lighting: 0.2kW, 332.8 kWh and \$50.4
 Exterior Lighting: 0.2kW, 700.8 kWh and \$106.1

The following table, Table 4.3-4, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Waste Oil Building.

| Table 4.3-4 Waste Oil Building Lighting System Improvements*** | | | |
|---|------------------------------|------------------------------|------------------|
| | Interior Lighting | Exterior Lighting | Total |
| Engineer's Opinion of Probable Cost | \$38.8 | \$38.8 | \$77.6 |
| New Jersey SmartStart Rebate | -\$0*** | -\$0*** | -\$0*** |
| Total Cost | \$38.8 | \$38.8 | \$77.6 |
| Annual Energy Savings | \$50.4 | \$106.1 | \$156.5 |
| Annual Maintenance Cost Savings (AMCS) | \$23.9 | \$23.9 | \$47.8 |
| Simple Payback | 0.5 years | 0.3 years | 0.4 years |
| Annual Return on Investment (AROI) | 184.85% | 328.41% | 256.65% |
| Lifetime Energy Savings (15 years)* | \$937.4 | \$1,973.3 | \$2,910.7 |
| Internal Rate of Return (IRR) | 194.52% | 338.08% | 266.31% |
| Net Present Value (NPV) | \$1,043.4 | \$1,854.6 | \$2,898.1 |

*3% yearly inflation on electricity costs. Total lifetime savings does not equal sum of combined savings.

**See Appendix G & N for ECRM Financial Analyses

***No incentives are available for the type of retrofit being recommended.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Proposed Operational Hours Without Sensors" in Appendix I.

4.3.6 Blower Building

It is recommended that the existing interior lighting system at the Blower Building be upgraded to high efficiency standards to reduce power consumption. In general, the recommended lighting upgrade, as presented in Appendix I, involves replacing

existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. No exterior fixtures exist. Options for improving the interior and exterior lighting for the Blower Building are listed in Table 4.3-5.

| Table 4.3-5 Blower Building Lighting System Improvements | |
|---|---|
| Interior Lighting | High Performance T8 Retrofit of T12 Fixtures, Incandescent to CFL |

The annual energy savings for these options are as follows:

Interior Lighting: 0.3kW, 891.0 kWh and \$134.9

The following table, Table 4.3-6, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Blower Building.

| Table 4.3-6 Blower Building Lighting System Improvements*** | |
|--|--------------------------|
| | Interior Lighting |
| Engineer's Opinion of Probable Cost | \$1,639.0 |
| New Jersey SmartStart Rebate | -\$100* |
| Total Cost | \$1,539.0 |
| Annual Energy Savings | \$134.9 |
| Annual Maintenance Cost Savings (AMCS) | \$23.5 |
| Simple Payback | 9.7 years |
| Annual Return on Investment (AROI) | 3.63% |
| Lifetime Energy Savings (15 years)** | \$2,509.0 |
| Internal Rate of Return (IRR) | 8.71% |

| Table 4.3-6 Blower Building Lighting System Improvements*** | |
|--|--------------------------|
| | Interior Lighting |
| Net Present Value (NPV) | \$767.94 |

* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.
 **3% yearly inflation on electricity costs. Total lifetime savings does not equal sum of combined savings.
 ***See Appendix G & N for ECRM Financial Analyses
 ****No incentives are available for the type of retrofit being recommended.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours Without Sensors” in Appendix I.

4.3.7 Sludge Handling Building

It is recommended that the existing lighting system at the Sludge Handling Building be upgraded to high efficiency standards to reduce power consumption. In general, the recommended lighting upgrade, as presented in Appendix I, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Options for improving the interior and exterior lighting for the Sludge Handling Building are listed in Table 4.3-7.

| Table 4.3-7 Sludge Handling Building Lighting System Improvements | |
|--|---|
| Interior Lighting | High Performance T8 Retrofit of T12 Fixtures |
| Exterior Lighting | Induction Lighting Replacement of Exterior Fixtures |

The annual energy savings for these options are as follows:

Interior Lighting: 3.2kW, 6,442.6 kWh and \$975.4
 Exterior Lighting: 0.2kW, 805.9 kWh and \$122.0

The following table, Table 4.3-8, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Sludge Handling Building.

| Table 4.3-8 Sludge Handling Building Lighting System Improvements*** | | | |
|---|------------------------------|------------------------------|-------------------|
| | Interior Lighting | Exterior Lighting | Total |
| Engineer's Opinion of Probable Cost | \$10,138.0 | \$2,972.8 | \$13,110.8 |
| New Jersey SmartStart Rebate | -\$760* | -\$0**** | -\$760* |
| Total Cost | \$9,378.0 | \$2,972.8 | \$12,350.8 |
| Annual Energy Savings | \$975.4 | \$122.0 | \$1,097.4 |
| Annual Maintenance Cost Savings (AMCS) | \$140.8 | \$1.5 | \$142.3 |
| Simple Payback | 8.4 years | 24.1 years | 10.0 years |
| Annual Return on Investment (AROI) | 5.24% | -2.51% | 3.37% |
| Lifetime Energy Savings (15 years)** | \$18,141.4 | \$2,269.1 | \$20,410.5 |
| Internal Rate of Return (IRR) | 11.06% | -2.89% | 8.32% |
| Net Present Value (NPV) | \$6,877.6 | -\$1,174.8 | \$5,702.9 |

* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs. Total lifetime savings does not equal sum of combined savings.

***See Appendix G & N for ECRM Financial Analyses

****No incentives are available for the type of retrofit being recommended.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Proposed Operational Hours Without Sensors" in Appendix I.

4.3.8 Final Clarifier #1 & #2 Building

The Final Clarifier #1 & #2 Building lighting was analyzed for retrofit with high performance T8 fixtures, as shown in Table 4.3-9, but is not recommended due to a payback period of greater than twenty years. In general, the lighting upgrade, as presented in Appendix I, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. No exterior fixtures exist for this building.

| Table 4.3-9 Final Clarifier #1 & #2 Building Lighting System Improvements | |
|--|--|
| Interior Lighting | High Performance T8 Retrofit of T12 Fixtures |

The annual energy savings for these options are as follows:

Interior Lighting: 0.2kW, 107.0 kWh and \$16.2

The following table, Table 4.3-10, summarizes a simple payback analysis for the lighting system improvements that were analyzed at the Final Clarifier #1 & #2 Building.

| Table 4.3-10 Final Clarifier #1 & #2 Building Lighting System Improvements*** | |
|--|-------------------|
| | Interior Lighting |
| Engineer's Opinion of Probable Cost | \$756.4 |
| New Jersey SmartStart Rebate | -\$30* |
| Total Cost | \$726.4 |
| Annual Energy Savings | \$16.2 |
| Annual Maintenance Cost Savings (AMCS) | \$6.1 |
| Simple Payback | 32.5 years |
| Annual Return on Investment (AROI) | -3.59% |
| Lifetime Energy Savings (15 years)** | \$301.3 |
| Internal Rate of Return (IRR) | -5.96% |
| Net Present Value (NPV) | \$401.4 |

* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs. Total lifetime savings does not equal sum of combined savings.

***See Appendix G & N for ECRM Financial Analyses

****No incentives are available for the type of retrofit being recommended.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours Without Sensors” in Appendix I.

4.3.9 Final Clarifier #3 & #4 Building

It is recommended that the existing lighting system at the Final Clarifier #3 & #4 Building be upgraded to high efficiency standards to reduce power consumption. In general, the recommended lighting upgrade, as presented in Appendix I, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Options for improving the interior and exterior lighting for the Final Clarifier #3 & #4 Building are listed in Table 4.3-11.

| Table 4.3-11 Final Clarifier #3 & #4 Building Lighting System Improvements | |
|---|---|
| Interior Lighting | High Performance T8 Retrofit of T12 Fixtures |
| Exterior Lighting | Induction Lighting Replacement of Exterior Fixtures |

The annual energy savings for these options are as follows:

Interior Lighting: 0.5kW, 1,106.1 kWh and \$167.5
Exterior Lighting: 0.1kW, 403.0 kWh and \$61.0

The following table, Table 4.3-12, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Final Clarifier #3 & #4 Building.

| Table 4.3-12 Final Clarifier #3 & #4 Building Lighting System Improvements*** | | | |
|--|--------------------------|--------------------------|--------------|
| | Interior Lighting | Exterior Lighting | Total |
| Engineer’s Opinion of Probable Cost | \$3,201.3 | \$1,486.4 | \$4,687.7 |
| New Jersey SmartStart Rebate | -\$225* | -\$0**** | -\$225* |

| Table 4.3-12 Final Clarifier #3 & #4 Building Lighting System Improvements*** | | | |
|--|------------------------------|------------------------------|-------------------|
| | Interior Lighting | Exterior Lighting | Total |
| Total Cost | \$2,976.3 | \$1,486.4 | \$4,462.7 |
| Annual Energy Savings | \$167.5 | \$61.0 | \$228.5 |
| Annual Maintenance Cost Savings (AMCS) | \$39.8 | \$0.7 | \$40.53 |
| Simple Payback | 14.4 years | 24.1 years | 16.6 years |
| Annual Return on Investment (AROI) | 0.30% | -2.51% | -0.64% |
| Lifetime Energy Savings (15 years)** | \$3,115.3 | \$1,134.5 | \$4,249.9 |
| Internal Rate of Return (IRR) | 3.18% | -2.89% | 1.37% |
| Net Present Value (NPV) | \$42.6 | -\$587.4 | -\$544.8 |

* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs. Total lifetime savings does not equal sum of combined savings.

***See Appendix G & N for ECRM Financial Analyses

****No incentives are available for the type of retrofit being recommended.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours Without Sensors” in Appendix I.

4.3.10 Roadway and Process Lighting

It is recommended that the existing roadway and process lighting system at the Molitor Water Pollution Control Facility be upgraded to high efficiency standards to reduce power consumption. In general, the recommended lighting upgrade, as presented in Appendix I, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Options for improving the roadway and process lighting are listed in Table 4.3-13.

| Table 4.3-13 | |
|---|---|
| Roadway and Process Lighting System Improvements | |
| Exterior Lighting | Induction Lighting Replacement of Exterior Fixtures |

The annual energy savings for these options are as follows:

Exterior Lighting: 2.4KW, 10,533.9 kWh and \$1,594.8

The following table, Table 4.3-14, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the roadway and process lighting system at the Molitor Water Pollution Control Facility.

| Table 4.3-14 | |
|--|--------------------------|
| Roadway and Process Lighting System Improvements*** | |
| | Exterior Lighting |
| Engineer's Opinion of Probable Cost | \$16,762.7 |
| New Jersey SmartStart Rebate | -\$910**** |
| Total Cost | \$15,852.7 |
| Annual Energy Savings | \$1,594.8 |
| Annual Maintenance Cost Savings (AMCS) | \$15.2 |
| Simple Payback | 9.8 years |
| Annual Return on Investment (AROI) | 3.49% |
| Lifetime Energy Savings (15 years)** | \$29,661.6 |
| Internal Rate of Return (IRR) | 8.51% |
| Net Present Value (NPV) | \$7,593.6 |

* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs. Total lifetime savings does not equal sum of combined savings.

***See Appendix G & N for ECRM Financial Analyses

****No incentives are available for the type of retrofit being recommended.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours without Sensors” and “Proposed Operational Hours with Sensors” in Appendix I.

4.4 Motor Upgrades and VFD Additions

The goal of this section is to present any energy conservation measures related to upgrading motors to premium efficiency models, and adding variable frequency drives (VFD) that may also be cost beneficial.

To model the expected energy savings from upgrading motors to premium efficiency models, and the addition of VFDs, MotorMaster+ 4.0 software was utilized. Additional installation and labor costs were modeled using CostWorks software.

Additional benefits when adding VFDs include removal of traditional motor starters, lower stress levels on the motor bearings and windings, and a decrease in stress and wear on the motor/pump.

Application of a VFD to a pump results in a cubic power reduction with speed, where a 1% reduction in pump speed, will result in a 4% reduction in energy usage required to drive the pump. For the pumps which we added VFDs at the WPCP, we assumed a 25% decrease in energy usage, which results in a 6.25% reduction in pump horsepower.

Please note that the Engineer’s Estimate of Probable Construction Costs presented herein are estimates based on historic data compiled from similar installations and engineering opinions. Additional engineering will be required for each measure identified in this report and final scope of work and budget cost estimates will need to be confirmed prior to the coordination of project financing.

In addition, some of the motors surveyed had either unreadable or missing nameplate data. Therefore, CDM has assumed standard NEMA efficiencies for these motors for analysis. Refer to Appendix J for individual motor and VFD information.

Please note that not all of the motors present at the site have been analyzed in this report. Only motors that have been selected include the major process pumps. There are some buildings or areas not described within this section due to the fact the investigated pump(s) at the building do not present energy conservation measures related to upgrading.

4.4.1 Administration Building

It is not recommended to upgrade the existing motors at the Administration Building to high efficiency. This is primarily based on the 38.9 year payback period. It is recommended, however, to replace existing motors in the case of motor failure only. However, this option was included in the analysis for the purpose of illustrating pre-incentive costs. The NJBPU custom measure program could possibly provide additional incentives which would reduce the payback period. Refer to Appendix H for NJBPU custom measures incentives worksheets. Should the pre-incentive cost option be pursued, the following piece of equipment is included in the analysis:

- Primary Effluent Pump #1 Motor (Runs 2920 hours per year)
- Primary Effluent Pump #2 Motor (Runs 2920 hours per year)
- Primary Effluent Pump #3 Motor (Runs 2920 hours per year)
- Raw Sludge Pump #1 Motor (Runs 548 hours per year)
- Raw Sludge Pump #2 Motor (Runs 548 hours per year)

The combined annual energy savings for this option is as follows:

Motor Upgrades: 0.66kW, 1,473.27 kWh and \$223.05

The following Table, Table 4.4-1, summarizes a simple payback analysis assuming the implementation of all recommended motor upgrade for the Administration Building. For more information about the upgrade and a complete breakdown of simple payback and savings per motor, refer to Appendix J.

| Table 4.4-1 Administration Building Motor Upgrades*** | |
|--|-------------------|
| Engineer's Opinion of Probable Cost | \$8,675.31 |
| New Jersey SmartStart Rebate | -\$0* |
| Total Cost | \$8,675.31 |
| Annual Energy Savings | \$223.05 |
| Simple Payback | 38.9 years |
| Annual Return on Investment (AROI) | -4.10% |
| Lifetime Energy Savings (15 years)** | \$4,148.49 |
| Internal Rate of Return (IRR) | -7.65% |
| Net Present Value (NPV) | -\$5,427.01 |

* Incentives based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs

***See Appendices J for Upgrade Analyses, & G & N for ECRM Financial Analyses

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Yearly Runtime" in Appendix J.

4.4.2 Blower Building

It is not recommended to upgrade the existing motors at the Blower Building to high efficiency. This is primarily based on the 22.8 year payback period. It is recommended, however, to replace existing motors in the case of motor failure only. However, this option was included in the analysis for the purpose of illustrating pre-incentive costs. The NJBPU custom measure program could possibly provide additional incentives which would reduce the payback period. Refer to Appendix H for NJPBU custom measures incentives worksheets. Should the pre-incentive cost option be pursued, the following piece of equipment is included in the analysis:

-Raw Sludge Pump #3 Motor (Runs 1278 hours per year)

The combined annual energy savings for this option is as follows:

Motor Upgrades: 0.17kW, 216.76 kWh and \$32.82

The following Table, Table 4.4-2, summarizes a simple payback analysis assuming the implementation of all recommended motor upgrade for the Blower Building. For more information about the upgrade and a complete breakdown of simple payback and savings per motor, refer to Appendix J.

| Table 4.4-2 Blower Building Motor Upgrades*** | |
|--|-------------------|
| Engineer's Opinion of Probable Cost | \$747.50 |
| New Jersey SmartStart Rebate | -\$0* |
| Total Cost | \$747.50 |
| Annual Energy Savings | \$32.82 |
| Simple Payback | 22.8 years |
| Annual Return on Investment (AROI) | -2.28% |
| Lifetime Energy Savings (15 years)** | \$610.42 |
| Internal Rate of Return (IRR) | -2.29% |
| Net Present Value (NPV) | -\$269.54 |

* Incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs

***See Appendices J for Upgrade Analyses, & G & N for ECRM Financial Analyses

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Yearly Runtime" in Appendix J.

It should be noted that this analysis does not include all motors in the Pump Station No. 2 Building. The following existing motors are already highly efficient with no VFD's required:

- Blower #1 Motor
- Blower #2 Motor

Refer to Appendix J for more information regarding individual motor payback periods.

4.4.3 Sludge Handling Building

It is not recommended to upgrade the existing motors at the Sludge Handling Building to high efficiency. This is primarily based on the 83.9 year payback period. It is recommended, however, to replace existing motors in the case of motor failure only. However, this option was included in the analysis for the purpose of illustrating pre-incentive costs. The NJBPU custom measure program could possibly provide additional incentives which would reduce the payback period. Refer to Appendix H for NJBPU custom measures incentives worksheets. Should the pre-incentive cost option be pursued, the following piece of equipment is included in the analysis:

- Thick Sludge Pump #1 Motor (Runs 390 hours per year)
- Thick Sludge Pump #2 Motor (Runs 390 hours per year)
- Thick Feed Pump #1 Motor (Runs 390 hours per year)
- Thick Feed Pump #2 Motor (Runs 390 hours per year)
- BFP Pump #1 Motor (Runs 780 hours per year)
- BFP Pump #2 Motor (Runs 780 hours per year)
- Service Water Pump #1 Motor (Runs 910 hours per year)
- Service Water Pump #2 Motor (Runs 910 hours per year)
- Washwater Pump #1 Motor (Runs 390 hours per year)
- Washwater Pump #2 Motor (Runs 390 hours per year)
- Washwater Pump #3 Motor (Runs 780 hours per year)
- Washwater Pump #4 Motor (Runs 780 hours per year)
- Process Water Pump #1 Motor (Runs 260 hours per year)
- Process Water Pump #2 Motor (Runs 130 hours per year)

The combined annual energy savings for this option is as follows:

Motor Upgrades: 1.78kW, 1,078.14 kWh and \$163.23

The following Table, Table 4.4-3, summarizes a simple payback analysis assuming the implementation of all recommended motor upgrade for the Sludge Handling Building. For more information about the upgrade and a complete breakdown of simple payback and savings per motor, refer to Appendix J.

| Table 4.4-3 | |
|---|-------------|
| Sludge Handling Building Motor Upgrades*** | |
| Engineer's Opinion of Probable Cost | \$13,690.75 |
| New Jersey SmartStart Rebate | -\$0* |

| | |
|--------------------------------------|-------------------|
| Total Cost | \$13,690.75 |
| Annual Energy Savings | \$163.23 |
| Simple Payback | 83.9 years |
| Annual Return on Investment (AROI) | -5.47% |
| Lifetime Energy Savings (15 years)** | \$3,035.90 |
| Internal Rate of Return (IRR) | -14.16% |
| Net Present Value (NPV) | -\$11,313.61 |

* Incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs

***See Appendices J for Upgrade Analyses, & G & N for ECRM Financial Analyses

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Yearly Runtime” in Appendix J.

4.4.4 Final Clarifier #1 & #2 Building

It is recommended that the following existing motors at the Final Clarifier #1 & #2 Building be upgraded to high efficiency standards to create energy savings potential for the facility. The following pieces of equipment are included in the analysis:

- RAS Pump #1 Motor (Runs 4380 hours per year)(New VFD)
- RAS Pump #2 Motor (Runs 4380 hours per year)(New VFD)

The combined annual energy savings for this option is as follows:

Motor Upgrades: 4.34kW, 19,001.25 kWh and \$2,876.79

Refer to Appendix J for more information regarding motor annual energy savings.

The following Table, Table 4.4-4, summarizes a simple payback analysis assuming the implementation of all recommended motor upgrades and VFD additions for the Final Clarifier Building #1 & #2. For more information about the upgrades and a complete breakdown of simple payback and savings per motor, refer to Appendix J.

| Table 4.4-4 Final Clarifier Building #1 & #2 Motor Upgrades and VFD Additions*** | |
|---|------------------|
| Engineer's Opinion of Probable Cost | \$8,765.88 |
| New Jersey SmartStart Rebate | -\$180* |
| Total Cost | \$8,585.88 |
| Annual Energy Savings | \$2,876.79 |
| Simple Payback | 3.0 years |
| Annual Return on Investment (AROI) | 26.84% |
| Lifetime Energy Savings (15 years)** | \$53,505.17 |
| Internal Rate of Return (IRR) | 35.99% |
| Net Present Value (NPV) | \$33,309.12 |

* Incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs

***See Appendices J for Upgrade Analyses, & G & N for ECRM Financial Analyses

It should be noted that this analysis does not include all motors in the Final Clarifier Building #1 & #2. The following existing motors either are not in use or are already highly efficient with no VFD's required:

-WAS Pump

Refer to Appendix J for more information regarding individual motor payback periods.

4.4.5 Final Clarifier #3 & #4 Building

It is recommended that the following existing motors at the Final Clarifier #3 & #4 Building be upgraded to high efficiency standards to create energy savings potential for the facility. The following pieces of equipment are included in the analysis:

- RAS Pump #1 Motor (Runs 2920 hours per year)(New VFD)
- RAS Pump #2 Motor (Runs 2920 hours per year)(New VFD)
- RAS Pump #3 Motor (Runs 2920 hours per year)(New VFD)
- WAS Pump #1 Motor (Runs 4380 hours per year)(New VFD)
- WAS Pump #2 Motor (Runs 4380 hours per year)(New VFD)

The combined annual energy savings for this option is as follows:

Motor Upgrades: 7.70kW, 26,096.03 kWh and \$3,950.94

Refer to Appendix J for more information regarding motor annual energy savings.

The following Table, Table 4.4-5, summarizes a simple payback analysis assuming the implementation of all recommended motor upgrades and VFD additions for the Final Clarifier Building #3 & #4. For more information about the upgrades and a complete breakdown of simple payback and savings per motor, refer to Appendix J.

| Table 4.4-5 Final Clarifier Building #3 & #4 Motor Upgrades and VFD Additions*** | |
|---|------------------|
| Engineer's Opinion of Probable Cost | \$18,122.56 |
| New Jersey SmartStart Rebate | -\$351* |
| Total Cost | \$17,771.56 |
| Annual Energy Savings | \$3,950.94 |
| Simple Payback | 4.5 years |
| Annual Return on Investment (AROI) | 15.57% |
| Lifetime Energy Savings (15 years)** | \$73,483.19 |
| Internal Rate of Return (IRR) | 23.83% |
| Net Present Value (NPV) | \$39,766.40 |

* Incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs

***See Appendices J for Upgrade Analyses, & G & N for ECRM Financial Analyses

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Yearly Runtime" in Appendix J.

4.4.6 Outdoor Process Pumps

It is recommended that the following existing motors for Outdoor Process be upgraded to high efficiency standards to create energy savings potential for the facility. The following pieces of equipment are included in the analysis:

- Gas Mixer #1 Motor (Runs 2920 hours per year)
- Gas Mixer #2 Motor (Runs 2920 hours per year)
- Ejector Pump #1 Motor (Runs 4380 hours per year)
- Ejector Pump #2 Motor (Runs 4380 hours per year)
- Dewatering Pump #1 Motor (Runs 4380 hours per year)(New VFD)
- Dewatering Pump #2 Motor (Runs 4380 hours per year)(New VFD)
- Pond Boat Winch Pump (Runs 50 hours per year)

Pond Aerator Pump #4 has been included in the above list to be upgraded to high efficiency standards because it is a standby pump used for either maximum day demands or pump failure. Its inclusion has an almost negligible effect on the overall motor replacement payback.

The combined annual energy savings for this option is as follows:

Motor Upgrades: 5.64kW, 23,213 kWh and \$3,514.5

Refer to Appendix J for more information regarding motor annual energy savings.

The following Table, Table 4.4-6, summarizes a simple payback analysis assuming the implementation of all recommended motor upgrades and VFD additions for Outdoor Process. For more information about the upgrades and a complete breakdown of simple payback and savings per motor, refer to Appendix J.

| Table 4.4-6 Outdoor Process Motor Upgrades and VFD Additions*** | |
|--|------------------|
| Engineer's Opinion of Probable Cost | \$13,326 |
| New Jersey SmartStart Rebate | -\$459* |
| Total Cost | \$12,866.6 |
| Annual Energy Savings | \$3,514.5 |
| Simple Payback | 3.7 years |
| Annual Return on Investment (AROI) | 20.65% |
| Lifetime Energy Savings (15 years)** | \$65,365.9 |

| | |
|-------------------------------|------------|
| Internal Rate of Return (IRR) | 29.43% |
| Net Present Value (NPV) | \$38,315.4 |

* Incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs

***See Appendices J for Upgrade Analyses, & G & N for ECRM Financial Analyses

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Yearly Runtime” in Appendix J.

4.4.7 All Combined Motors

CDM has completed a full motor replacement analysis, in which replacing almost all motors described in this analysis is considered. Based on this analysis, it is recommended that most of the existing motors at the Molitor Water Pollution Control Facility could be upgraded to high efficiency standards to create energy savings potential for the Facility.

The annual energy savings for this option is as follows:

All Motor Upgrades: 20.29kW, 71,078.9 kWh and \$10,761.4

Refer to Appendix J for more information regarding motor annual energy savings.

The following Table, Table 4.4-7, summarizes a simple payback analysis assuming the implementation of all recommended motor upgrades and VFD additions for the Facility. For more information about the upgrades and VFD additions and a complete breakdown of simple payback per motor, refer to Appendix J.

| Table 4.4-7 All Combined Motor Upgrades and VFD Additions*** | |
|---|------------------|
| Engineer’s Opinion of Probable Cost | \$63,327.6 |
| New Jersey SmartStart Rebate | -\$1,395* |
| Total Cost | \$61,932.6 |
| Annual Energy Savings | \$10,761.4 |
| Simple Payback | 5.8 years |
| Annual Return on Investment (AROI) | 10.33% |

| | |
|--------------------------------------|-------------|
| Lifetime Energy Savings (15 years)** | \$200,150.4 |
| Internal Rate of Return (IRR) | 17.69% |
| Net Present Value (NPV) | \$93,392 |

* Incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix H.

**3% yearly inflation on electricity costs

***See Appendices J for Upgrade Analyses, & G & N for ECRM Financial Analyses

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Yearly Runtime” in Appendix J.

4.5 Alternative Energy Sources

4.5.1 Photovoltaic Solar Energy System Overview

Photovoltaic (PV) cells convert energy in sunlight directly into electrical energy through the use of silicon semi conductors, diodes and collection grids. Several PV cells are then linked together in a single frame of module to become a solar panel. PV cells are able to convert the energy from the sun into electricity. The angle of inclination of the PV cells, the amount of sunlight available, the orientation of the panels, the amount of physical space available and the efficiency of the individual panels are all factors that affect the amount of electricity that is generated.

Based on the estimated cumulative total available land area, calculations determine that the installation of one system, with a total rating of approximately 1,344 kW (dc) will be appropriate for the fields outside of the Molitor Water Pollution Control Facility.

As part of this energy audit, a preliminary engineering feasibility study of the Facility to support solar generation facilities was completed consisting of the following tasks:

- a. Site Visit by our engineers;
- b. Satellite Image Analysis and Conceptual design and layout of the photovoltaic system;
- c. Design and construction cost estimates;
- d. Determine a preliminary design for the size and energy production of the solar system.

The total unobstructed available area of land with southern exposure was evaluated. It is important to note the following:

1. The PV system sizing and kWh production was calculated assuming the installation of a crystalline module facing south direction (220 Degree Azimuth) and tilted approximately 20 degrees to allow better rain water shedding and snow melting. Please note that the kWh production as well as system size may differ significantly based on final panel tilt selected during the design phase.
2. Blended electric rates were used based on actual utility bills and were applied for the Facility.

The following is a preliminary study on the feasibility of installing a PV solar system at the WPCP to generate a portion of the facilities electricity requirements. The system is designed to offset the electric purchased from the local utility and not as a backup or emergency source of power.

In order to determine the best location for the installation of the PV solar system, a satellite image analysis and site walk through of the buildings was performed on May 27th, 2010. Also, as part of our assessment we investigated possible locations for electrical equipment that need to be installed such as combiner boxes, disconnect switches and DC to AC inverters. Consideration was also given to locations of interconnection between the solar system and the facilities electrical grid.

Roof mounted solar installation for various buildings within the wastewater treatment plant is not recommended. For solar installation on rooftops, considerable structural integrity is necessary. The best location for solar PV array would be the adjoining fields to the facilities; as the small area of the roofs would most likely need extra structural support, bringing the payback outside of 20 years. A study should be performed in order to determine if construction of a solar PV array on this land is feasible, based on land type, soil, etc.

4.5.1.1 Molitor Water Pollution Control Facility

Some land clearing and grubbing will be necessary to install a PV array system in the adjoining fields of the Facility. Shading, also, may have a very limited impact on the PV solar array depending on the design and layout of the system along the edges of the property. The quality of land was not confirmed, and prior to installation of a solar array, site analysis should determine if the land is feasible for a PV solar system.

The Project Team conducted both a facility walk through and a satellite image analysis and based on the estimated available area calculations predict that a system rated at approximately 1,344 kW (dc) is feasible.

Electrical Service

The electrical service size of the Facility is 1600 A, at 277/480V, 3-phase. The interconnection point for the PV system will require a modification or replacement of the existing service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. In the case of this Facility, the main circuit breaker is in an exterior enclosure. The inverter should be installed outside on a concrete pad in a weather proof enclosure. AC wiring would run from the inverters into the connection point(s) at the service entrance equipment. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

4.5.1.2 Basis for Design and Calculations

The most common solar PV system is referred to as a (“fixed tilt”) system typically mounted to a metal rack that can be fixed at a specific angle. There are also (“tracking systems”) or movable along one or two axes to follow the position of the sun during the day. For a roof-mounted PV system, tracking systems are very rarely installed and are usually used for ground-mounted systems only, as they require more complex racks and higher maintenance costs. For the “fixed” system, the tilt is determined based on the following factors: geographical location, total targeted kWh production, seasonal electricity requirements and weather conditions such as wind. Ideally, the module tilt for Central to Eastern New Jersey should be 25-35 degrees with an azimuth as close as possible to 180 (south); however, our experience has shown that PV systems are typically installed at a tilt of 20 degrees or lower in order to avoid any issues with wind and to maximize total system size.



Fixed Tilt System

The type of PV panels and equipment used to mount the system shall be determined based on the wind conditions determined during the design phase of the project. In general, penetration/tie-down systems, non-penetrating ballasted type systems, or a combination of the two should be considered.

Calculation of PV System Yield

An industry accepted software package, PV Watts, was used to calculate projected annual electrical production of the crystalline silicon PV system in its first year, as summarized in Table 4.5-1. The system was design to provide maximum kWh

production based on available land space. The assumptions we used in the calculations were as follows: average monthly electrical usage per month, average aggregate electrical rate, square feet of available land space, and a solar rating of 4.48 kWh/m² per day.

| Table 4.5-1 PV Solar System Summary** | | | | | | | | |
|--|-----------------|-----------|-----------------------|------------------|-------------------------------------|------------------------------------|-------------------------|-------------------------------|
| Site | Est. Area (ft2) | kWh | Annual Energy Savings | Est. Annual SREC | Lifetime Energy Savings (25 Years)* | Annual Return On Investment (AROI) | Net Present Value (NPV) | Internal Rate of Return (IRR) |
| Molitor Water Pollution Control Facility | 134,433 | 1,601,345 | \$242,443.6 | \$677,369 | \$8,839,315.3 | 2.0% | - \$1,674,030 | 1.8% |

*3% yearly inflation on electricity costs

**See Appendices P & Q for ECRM Financial Analyses

Total Costs

It should be noted that construction costs are only estimates based on historic data compiled from similar installations, and engineering opinion. Additional engineering and analysis is required to confirm the condition of the land, the system type, sizing, costs and savings. For illustration purposes, a draft financial analysis pro forma is attached outlining all project costs and revenues (refer to Appendix K).

| Table 4.5-2 Solar PV Array Engineer's Opinion of Probable Cost | |
|---|--------------|
| Engineer's Opinion of Probable Cost | \$15,248,668 |

As stated above, the engineer's opinion of probable costs are based on experience with the pricing of solar installations in New Jersey, and are intended to provide the Madison-Chatham Joint Meeting with a reasonable budget cost. A typical solar installation can vary in cost from \$7.00 - \$10.00 per watt depending on size, complexity of the system, labor rates, etc. Approximately 60-70% of that number is

material costs while the balance is labor, engineering, etc. Like any installation, certain conditions can affect a price upward or downward. We have included a budget of \$9/watt for the solar system installation with an additional estimated budget of \$100,000 for potential electric service work.

Based on a simple payback model, summarized in Table 4.5-3, it would benefit the Madison-Chatham Joint Meeting to further investigate the installation of a solar energy system at the Facility. This is primarily based on the initial upfront capital investment required for a solar energy system installation and the 16.6 year payback period. This payback period may justify installing the solar energy system. Other options such as Power Purchase Agreements are potentially available as well to help finance the project. Solar technology is constantly changing and will most likely continue to lower in price. Two major factors influencing the project financial evaluation is the variance of the prevailing energy market conditions and Solar Renewable Energy Credit (SREC) rates, with the largest impact to the payback model being the SREC credit pricing.

Table 4.5-3 includes the total simple payback analysis for the installation of a solar energy system at the Molitor Water Pollution Control Facility. Refer to Appendix K for a more detailed solar financing spreadsheet.

| Table 4.5-3 Simple Payback Analysis for Solar Energy System | | | | |
|--|--|-------------------------------|--------------------------------------|---------------------------------------|
| Building & Measure | Engineer's Opinion of Probable Cost | Annual SREC Credit | Annual Fiscal Savings | Simple Payback (Years) |
| Molitor Water Pollution Control Facility | \$15,248,668 | \$677,369 | \$242,443.6 | 16.6 |

Refer to Section 7 for discussion on Solar Renewable Energy Certificates and other financing options for solar projects. The financial model in Appendix K provides an annual forecast illustration of project revenues and costs for 25 years.

4.5.2 Ground Source Heat Pump Systems

Ground source heat pumps utilize the relatively constant temperature of underground water sources to reject or supply heat to the interior space. Water is pumped through a loop that runs from the underground source to heat pumps at the building level. Depending on the time of year and building demand, these heat pumps use the ground source loop as a heat source or a heat sink.

Typically, ground source heat pump systems are most efficient when used in spaces that have similar heating and cooling loads, as the same loop and heat pumps are used for both cooling and heating. For wastewater treatment plant facilities, the heating and cooling loads are essentially unequal with most of the cooling in plant process areas achieved by ventilation of outdoor air to meet code requirements. Furthermore, as a water conservation measure, the cooling medium for a proposed ground source geothermal system will likely consist of treated plant effluent, which, although treated, will tend to foul heat transfer components as a result of inherent microbiological organisms present in the cooling media. Potential fouling of heat transfer components will result in increased maintenance efforts and system outage.

Ground source heat pump systems are often very costly to install due to the high cost of test boring and drilling wells. Due to this, the largely unbalanced heating and cooling demands at wastewater treatment plants, and the potential fouling of heat transfer components, CDM anticipates that installation of a ground source heat pump system would not prove cost-beneficial.

4.5.3 Wind Power Generation

On-site wind power generation typically utilizes a form of turbine, which is rotated with the flow of wind across it, this rotational force powers a generator, producing DC electricity. The DC electricity is then converted into AC electricity, which can be used for commercial power, or can be fed back into the power grid, reducing the overall electric demand. The size of the turbine is proportional to the amount of wind and concurrently the amount of energy it can produce. An ideal location for a wind turbine is 20 feet above any surrounding object within a 250 foot radius. In general this relates to a property size of one acre or more.

CDM has determined that it is feasible for the Madison-Chatham Joint Meeting to install a wind turbine energy system on the grounds of the Molitor Water Pollution Control Facility. For the purpose of this feasibility analysis, CDM is recommending 1-10KW wind turbine. Depending on area available, and funding, the Madison-Chatham Joint Meeting may choose to install more than 1 wind turbine on the premises.

Utilizing NASA's online wind mapping tool, it was determined that the local average wind speeds at the plant ranged from 8.5 mph to 12.4 mph, or 3.8m/s to 5.5m/s. In general, around 9 mph of average wind speed, as determined over the course of a year, is necessary to "fuel" the turbine. These values fall within the range of feasibility for installation of a new wind turbine system.

For the purposes of this feasibility analysis, CDM chose a 10KW Bergey wind turbine. This turbine size is used most often for small commercial applications. Power Curve data was determined through the use of the product specification sheets on vendor

websites, and vendor provided tools. Actual turbine size, height, location, and manufacturer should be determined upon design of a wind turbine system.

The estimated wind speed data, associated wind probability distribution function (weibull value), turbulence losses, and other relevant data were then incorporated into Bergey's Wind Cad program to estimate the annual output for the wind turbine. Refer to Appendix L for Wind Cad Modeling.

In order to determine simple payback analysis of the proposed wind turbine, CDM used the vendor pricing information located on the Bergey Wind Turbine website (www.bergey.com) (for more information on wind turbine cost estimation refer to Appendix M). By installing the proposed wind turbine, the Facility will offset between \$861.00 and \$2,444.20 per year in utility costs based on the minimum and maximum average local wind speeds. In addition, Renewable Energy Credits (REC's) are obtainable for renewable power and incentives are available through the Renewable Energy Incentive Program (REIP); refer to Section 7 for a more in depth explanation.

This simple payback calculation takes into account the incentive provided for wind turbines through the REIP program. For the first 16,000 kWh of production, the incentive is \$3.20/kWh. For production between 16,000 kWh - 750,000 kWh the REIP program incentive is \$0.50/kWh. CDM used this incentive as an upfront deduction from the Engineer's Opinion of Probable Cost. In addition, in order to benefit from the REIP incentive, the Madison-Chatham Joint Meeting must purchase a wind turbine on the approved NJ Clean Energy list. CDM chose the Bergey wind turbine for this analysis as it is approved by the NJ Clean Energy program and is the appropriate size for plant or smaller commercial installations. Refer to the NJ Clean Energy website for more information.

Table 4.5 -4 includes a simple payback analysis for the installation of a wind turbine energy system on the Molitor Water Pollution Control grounds. Refer to Appendix M for a more detailed wind turbine financing spreadsheet, including utility cost avoidance and REC's.

| Table 4.5-4 Simple Payback Analysis for Wind Turbine Energy System*** | | | |
|--|---|--|--|
| Parameter | Wind Turbine (Minimum Site Wind Speed – 8.52 mph)* | Wind Turbine (Average Site Wind Speed – 10.56 mph)* | Wind Turbine (Maximum Site Wind Speed – 12.35 mph)* |
| Engineer's Opinion of Probable Cost | \$68,489.69 | \$68,489.69 | \$68,489.69 |
| Renewable Energy Incentive Program** | -\$18,198.00 | -\$33,978 | -\$51,661.00 |
| Total Cost | \$50,291.69 | \$34,511.69 | \$16,282.69 |
| 1 st Year Production | 5,687 kWh | 10,618 kWh | 16,144 kWh |
| Annual Estimated Electric Savings | \$861.0 | \$1,607.6 | \$2,444.2 |
| Annual Estimated REC Revenue | \$142.00 | \$265.00 | \$407.00 |
| Project Simple Payback | 50.1 Years | 18.4 Years | 5.9 Years |
| Annual Return On Investment (AROI) | -2.0% | 1.4% | 12.9% |
| Lifetime Energy Savings (25 years)** | \$31,391.43 | \$58,611.91 | \$89,113.73 |
| Internal Rate of Return (IRR) | -2.9% | 4.5% | 18.6% |
| Net Present Value (NPV) | -\$28,250 | \$6,642 | \$45,742 |

*Refer to Appendix L for Wind Cad Modeling

**REIP incentive is calculated for only the first year and is applied as a deduction.

***See Appendix G & N for ECRM Financial Analyses

Based on the simple payback model, summarized in Table 4.5-4, it would benefit the Madison-Chatham Joint Meeting to further investigate the installation of a wind energy system for the Facility. This is primarily based on the initial upfront capital investment required for a wind turbine energy system installation and the 18.4 year average wind speed payback period. Other options such as Power Purchase Agreements are potentially available as well to help finance the project. This technology is constantly changing and will most likely continue to lower in price.

It should be noted that CDM used only REC values, utility cost avoidance factors, and the REIP incentive in determining simple payback periods. As stated above, other incentives and financial programs such as Power Purchase Agreements are available to help finance this installation. For example, if a Power Purchase Agreement is

completed, the private company financing the project would benefit from the 30% tax credit. Other incentives such as CREB's and first year usage incentives could be available to the Facility in lowering the payback period. Refer to www.dsireusa.org for an extensive listing of possible incentives for the New Jersey area.

It should also be noted that the wind turbine represented above is for feasibility purposes only. If the Madison-Chatham Joint Meeting decides to install a wind turbine, different mounting heights, turbine sizes, and manufacturers should be considered. In addition, permits may be required for installation according to local zoning laws. The FAA must also be notified in order to give clearance for the tower, and for installation of aviation safety lights if necessary.

4.5.4 Combined Heat and Power Cogeneration Technology

The WPCP currently utilizes two (2) digester gas fueled internal combustion engines for heating of the Primary Digesters. Additionally, each engine also drives one (1) blower for the Aeration System. As such, the potential to increase the digester gas production for purposes of increasing the fuel source for the engines and boiler were previously discussed under Section 4.1.6 - Anaerobic Digestion System of this Report.

Section 5

Evaluation of Energy Purchasing and Procurement Strategies

5.1 Energy Deregulation

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law, the deregulation of the market, allowed all consumers to shop for their electric supplier. The intent was to create a competitive market for electrical energy supply. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party supplier. Energy deregulation in New Jersey increased the energy buyers' options by separating the function of electricity distribution from that of electricity supply.

Jersey Central Power and Lighting (JCP&L) is currently the supplier and First Energy Corp. is the supplier of energy for the Joint Meeting.

To sell electric generation service in New Jersey, electric power suppliers must be licensed by the New Jersey Board of Public Utilities (NJ BPU). They must also be registered with the local public utility (JCP&L) to sell electric service in that utility's service areas. The following suppliers are licensed with the NJ BPU and are registered to sell electric service in the JCP&L service territory:

- Amerada Hess Corp
- BOC Energy Services
- Con Edison Solutions, Inc.
- Constellation New Energy, Inc.
- Direct Energy, LLC.
- First Energy Solutions Corp.
- Glacial Energy
- Integrys Energy Service
- Liberty Power
- Pepco Energy Services, Inc.
- PP&L Energy Plus, LLC.

- Reliant Energy Solutions East, LLC.
- Sempra Energy Solutions
- South Jersey Energy
- Strategic Energy LLC
- Suez Energy Resources NA, Inc
- UGI Energy Services

5.2 Demand Response Program

Demand Response is a program through which a business can make money on reducing their electricity use when wholesale electricity prices are high or when heavy demand causes instability on the electric grid, which can result in voltage fluctuations or grid failure. Demand Response is an energy management program that compensates the participant for reducing their energy consumption at critical times. Demand Response is a highly efficient and cost effective means of reducing the potential for electrical grid failure and price volatility and is one of the best solutions to the Mid-Atlantic region's current energy challenges.

The program provides at least 2 hours advance notice before curtailment is required. There is typically 1 event a year that lasts about 3 hours in the summer months, when demand for electricity is at its highest.

Participation in Demand Response is generally done through companies known as Curtailment Service Providers, or CSPs, who are members of PJM Interconnection. There is no cost to enroll in the program and participation is voluntary, for instance, you can choose when you want to participate. In most cases, there is no penalty for declining to reduce your electricity use when you're asked to do so. The event is managed remotely by notifying your staff of the curtailment request and then enacting curtailment through your Building Management System. CSPs will share in a percentage of your savings, which may differ among various CSPs, since there may be costs associated with the hardware and/or software required for participation, so it is recommended that a number of CSPs be contacted to review their offers.

Section 6

Ranking of Energy Conservation and Retrofit Measures (ECRMs)

6.1 ECRMs

The main objective of this energy audit is to identify potential Energy Conservation and Retrofit Measures and to determine whether or not the identified ECRMs are economically feasible to warrant the cost for planning and implementation of each measure. Economic feasibility of each identified measure was evaluated through a simple payback analysis. The simple payback analysis consists of establishing the Engineer's Opinion of Probable Construction Cost estimates, O&M estimates, projected annual energy savings estimates, and the potential value of New Jersey Clean Energy rebates, or Renewable Energy Credits, if applicable. The simple payback period is then determined as the amount of time (years) until the energy savings associated with each measure amounts to the capital investment cost.

As discussed in Section 3, aggregate unit costs for electrical energy delivery and usage, which accounts for all demand and tariff charges, at each facility was determined and utilized in the simple payback analyses.

In general, ECRMs having a payback period of 20 years or less have been recommended and only those recommended ECRMs within Section 4 of the report have been ranked for possible implementation. The most attractive rankings are those with the lowest simple payback period.

Ranking of ECRMs has been broken down into the following categories:

- Water Pollution Control Plant;
- Building HVAC Components;
- Building Lighting Systems;
- Motors Upgrades & VFD Additions
- Solar
- Wind

6.1.1 Water Pollution Control Plant

At the WPCP, wastewater unit process such as the aeration basins, oxidation ditches, stabilization pond, and the anaerobic digestion system were evaluated as potential ECRMs.

Table 6.1-1 includes the recommended ECRM for the Aeration Basins, which includes the installation of a fine bubble diffuser system throughout the nine (9) active aeration bays. A detailed discussion of this alternative is included in Section 4.1.1.

| Table 6.1-1 Ranking of Energy Savings Measures – Aeration Basins | | | | |
|---|---------------------------------|---------------------------------------|--|-------------------------------|
| Recommendation | Total Cost⁽¹⁾ | Annual Energy Savings (KW-hrs) | Annual Fiscal Savings⁽²⁾ | Simple Payback (Years) |
| Installation of Premium Eff. Motors and VFDs on Aerators | \$85,076 | 134,036 | \$15,293 | 5.6 |

1. 'Total Cost' takes into account any applicable rebates.
2. 'Annual Fiscal Savings' takes into account operation and maintenance savings.

Table 6.1-2 includes the recommended ECRM for the Oxidation Ditches, which includes the installation of new motors and VFDs for the existing aerators as long as the existing aerators are in good working condition and not near the end of their useful life. A detailed discussion of this alternative is included in Section 4.1.4.

| Table 6.1-2 Ranking of Energy Savings Measures – Oxidation Ditches | | | | |
|---|---------------------------------|---------------------------------------|--|-------------------------------|
| Recommendation | Total Cost⁽¹⁾ | Annual Energy Savings (KW-hrs) | Annual Fiscal Savings⁽²⁾ | Simple Payback (Years) |
| Installation of Motors and VFDs | \$383,460 | 398,943 | \$56,400 | 6.8 |

1. 'Total Cost' takes into account any applicable rebates.
2. 'Annual Fiscal Savings' takes into account operation and maintenance savings.

Table 6.1-3 includes the recommended ECRM for the Stabilization Pond, which includes the installation of new solar-powered aerators with a DO control system. A detailed discussion of this alternative is included in Section 4.1.5.

| Table 6.1-3 Ranking of Energy Savings Measures – Stabilization Pond | | | | |
|--|---------------------------------|---------------------------------------|--|-------------------------------|
| Recommendation | Total Cost⁽¹⁾ | Annual Energy Savings (KW-hrs) | Annual Fiscal Savings⁽²⁾ | Simple Payback (Years) |
| Installation of Motors and VFDs | \$354,954 | 190,885 | \$28,900 | 13.5 |

1. 'Total Cost' takes into account any applicable rebates.
2. 'Annual Fiscal Savings' takes into account operation and maintenance savings.

Table 6.1-4 includes the recommended ECRM to provide energy cost savings associated with the Anaerobic Digestion System, which includes the addition of the Aeration Basins WAS load to the Primary Digesters, in addition to FOG. A detailed discussion on these alternatives is presented in Section 4.1.6.

| Table 6.1-4 Ranking of Energy Savings Measures – Anaerobic Digestion System | | | | |
|--|---------------------------------|---------------------------------------|--|-------------------------------|
| Recommendation | Total Cost⁽¹⁾ | Annual Energy Savings (Therms) | Annual Fiscal Savings⁽²⁾ | Simple Payback (Years) |
| Addition of Aeration Basin WAS and FOG | \$409,656 | 34,039 | \$47,030 | 8.7 |

1. 'Total Cost' takes into account any applicable rebates.
2. 'Annual Fiscal Savings' takes into account operation and maintenance savings.

6.1.2 Building HVAC Components

Table 6.1-5 includes the recommended ECRM to provide energy savings for building HVAC systems, which provide a simple payback of less than 20 years. A detailed discussion on building HVAC systems is presented in Section 4.2.

| Table 6.1-5 Ranking of Energy Savings Measures - HVAC | | | | |
|--|---------------------------------|--|--|-------------------------------|
| Recommendation | Total Cost⁽¹⁾ | Annual Natural Gas Savings (Therms) | Annual Fiscal Savings⁽²⁾ | Simple Payback (Years) |
| Blower Building – Steam Pipe Insulation | \$955 | 1,379 | \$1,475 | 0.6 |

1. 'Total Cost' takes into account any applicable rebates.
2. 'Annual Fiscal Savings' takes into account operation and maintenance savings.

6.1.3 Building Lighting Systems

Table 6.1-6 includes rankings of all recommended ECRMs to provide energy savings for all building lighting systems, which include the installation of energy-efficient luminaires and occupancy sensors. A detailed discussion on building lighting systems is presented in Section 4.3. Refer to Appendix I for a more detailed lighting financing spreadsheet.

| Table 6.1-6 Ranking of Energy Savings Measures - Electrical Lighting⁽¹⁾ | | | | |
|---|---------------------------------|---------------------------------------|--|-------------------------------|
| Recommendation | Total Cost⁽²⁾ | Annual Energy Savings (kW-hrs) | Annual Fiscal Savings⁽³⁾ | Simple Payback (Years) |
| Waste Oil Building – Total Lighting | \$77.6 | 1,033.6 | \$204.3 | 0.4 |
| Administration Building – Total Lighting | \$14,731.8 | 11,213.1 | \$1,956.6 | 7.5 |
| Blower Building – Interior Lighting | \$1,539.0 | 891.0 | \$158.4 | 9.7 |
| Roadway and Process – Exterior Lighting | \$15,852.7 | 10,533.9 | \$1,610.0 | 9.8 |
| Sludge Handling Building – Total Lighting | \$12,350.8 | 7,248.5 | \$1,239.7 | 10.0 |
| Clarifier #3 & #4 Building – Total Lighting | \$4,462.7 | 1,509.1 | \$269.03 | 16.6 |

1. Buildings recommended with total lighting upgrades represents payback for the combined interior and exterior lighting upgrade which may represent an interior or exterior payback that exceeds 20 years. The facility may reduce the simple payback further by only upgrading that portion of lighting that has a payback less than 20 years. See Section 4.4 for more detail.
2. ‘Total Cost’ takes into account any applicable rebates.
3. ‘Annual Fiscal Savings’ takes into account maintenance cost savings.

6.1.4 Motors

Table 6.1-7 includes the recommended ECRM to provide energy savings by upgrading motors to premium efficiency models, and adding VFDs. A detailed discussion on motor upgrades and VFD additions is presented in Section 4.4.

| Table 6.1-7 Ranking of Energy Savings Measures - Electrical Motors | | | | |
|---|---------------------------------|---------------------------------------|------------------------------|-------------------------------|
| Recommendation | Total Cost⁽¹⁾ | Annual Energy Savings (kW-hrs) | Annual Energy Savings | Simple Payback (Years) |
| Final Clarifier Building #1 & #2 – Motor & VFD Upgrades | \$8,585.88 | 19,001.25 | \$2,876.79 | 3.0 |
| Outdoor Process – Motor & VFD Upgrades ² | \$12,866.6 | 23,213.5 | \$3,514.5 | 3.7 |
| Final Clarifier Building #3 & #4 – Motor & VFD Upgrades | \$17,771.56 | 26,096.03 | \$3,950.94 | 4.5 |

1. ‘Total Cost’ takes into account any applicable rebates.
2. Does not include capital cost and energy savings associated with the motors for the Aeration Basins, Oxidation Ditches, and Stabilization Pond.

6.1.5 Solar Energy

Implementation of a new solar energy system has been evaluated to determine the economic feasibility for furnishing and installing such systems for Madison-Chatham Joint Meeting. Based on the simple payback modeling performed, it would benefit the

Joint Meeting to further investigate installing the solar energy system at the Molitor Water Pollution Control Facility. This is primarily based on the initial upfront capital investment required for a solar energy system installation and the 16.6 year payback period.

Two major factors influencing the project financial evaluation is the variance of the prevailing energy market conditions and Solar Renewable Energy Credit (SREC) rates, with the largest impact to the payback model being the SREC credit pricing. For the payback model, conservative estimates of the SREC's market value over a 15 year period were assumed, as discussed in Section 4.5.

Table 6.1-8 includes a simple payback analysis for the installation of solar energy systems at Molitor Water Pollution Control Facility. Refer to Appendix K for a more detailed solar financing spreadsheet.

| Table 6.1-8 Ranking of Energy Savings Measures Summary – Solar Energy Systems | |
|--|-------------------|
| Parameter | Solar |
| Engineer's Opinion of Probable Cost | \$15,248,668 |
| 1 st Year Production | 1,601,345 kWh |
| Annual Electric Savings | \$242,443.6 |
| Annual Estimated SREC Revenue | \$677,369 |
| Project Simple Payback | 16.6 Years |

6.1.6 Wind Power Generation

Implementation of a new on-site wind energy system has been evaluated to determine the economic feasibility for furnishing and installing such systems for the Madison-Chatham Joint Meeting. Based on the simple payback modeling performed, it would benefit the Joint Meeting to further investigate installing the on-site wind energy system at the Molitor Water Pollution Control Facility. This is primarily based on the initial upfront capital investment required for a wind energy system installation and an acceptable payback period.

Three major factors influencing the project financial evaluation is the variance of the prevailing energy market conditions, Renewable Energy Certificate (REC) rates and the Renewable Energy Incentive Program, with the largest impact to the simple payback model being the REIP incentive. Refer to Appendix M for a more detailed wind financing spreadsheet.

Table 6.1-9, includes a summary of the wind energy ECRM for the Molitor Water Pollution Control Facility.

| Table 6.1-9 Ranking of Energy Savings Measures Summary – Wind Turbine Energy System | | | |
|--|--|---|---|
| Parameter | Wind Turbine (Minimum Site Wind Speed – 8.52 mph) | Wind Turbine (Maximum Site Wind Speed – 12.35 mph) | Wind Turbine (Average Site Wind Speed – 10.56 mph) |
| Engineer’s Opinion of Probable Cost | \$68,489.69 | \$68,489.69 | \$68,489.69 |
| Renewable Energy Incentive Program** | -\$18,198.00 | -\$51,661.00 | -\$33,978 |
| Total Cost | \$50,291.69 | \$16,282.69 | \$34,511.69 |
| 1 st Year Production | 5,687 kWh | 16,144 kWh | 10,618 kWh |
| Annual Estimated Electric Savings | \$861.0 | \$2,444.2 | \$1,607.6 |
| Annual Estimated REC Revenue | \$142.00 | \$407.00 | \$265.00 |
| Project Simple Payback | 50.1 Years | 5.9 Years | 18.4 Years |

Section 7

Grants, Incentives and Funding Sources

7.1 Renewable Energy

7.1.1 Renewable Energy Certificates (NJ BPU)

As part of New Jersey's Renewable Portfolio Standards (RPS), electric suppliers are required to have an annually-increasing percentage of their retail sales generated by renewable energy. Electric suppliers fulfill this obligation by purchasing renewable energy certificates (RECs) from the owners of solar generating systems. One REC is created for every 1,000 kWh (1 MWh) of renewable electricity generated. Although solar systems generate electricity and SRECs in tandem, the two are independent commodities and sold separately. The RPS, and creation of RECs, is intended to provide additional revenue flow and financial support for renewable energy projects in New Jersey. Class I RECs, which include electricity generation from wind, wave, tidal, geothermal and sustainable biomass typically trade at around \$25/MWh. RECs generated from solar electricity, or SRECs, trade at \$550/MWh due to supplemental funding from NJ PBU. The supplemental funding will decrease over time to \$350/MWh.

7.1.2 Clean Energy Solutions Capital Investment Loan/Grant (NJ EDA)

NJ EDA in cooperation with NJ DEP is offering interest-free loans and grants for energy efficiency, combined heat and power (CHP) and renewable energy projects with total project capital equipment costs of at least \$1 million. The interest-free loans are available for up to \$5 million, a portion of which may be issued as a grant. The most recent round was closed as of October 2009, but new CESCO program updates will be posted at www.njeda.com. For additional information, contact CESCO@njeda.com or call 866-534-7789.

7.1.3 Renewable Energy Incentive Program (NJ BPU)

The Renewable Energy Incentive Program (REIP) provides rebates for installing solar, wind, and sustainable biomass systems in Smart Growth regions. Rebates of \$1.00 per watt are available for solar electricity projects up to 50 kW in capacity. Wind systems can receive rebates up to \$3.20 per expected kWh produced. Sustainable biomass rebates start at \$4.00 per watt installed with a maximum incentive amount of 30 percent of project costs. REIP will give out \$53.25 million in rebates from 2009 - 2012. Project owners must complete the Pay for Performance Program, Direct Install or Local Municipal audit, or the rebate will be reduced by \$0.10 per watt. For more information on REIP, please see www.njcleanenergy.com.

7.1.4 Grid Connected Renewables Program (NJ BPU)

The New Jersey Grid Connected Renewables Program offers competitive incentives for wind and sustainable biomass electricity generation projects larger than 1 Megawatt (MW). Applications for the most recent round of funding, which totaled \$6 million, were due January 8, 2010. Requests for Proposals (RFPs) for the next round

will be posted at www.njcleanenergy.com and www.state.nj.us/bpu. A total of roughly \$16 million is available for incentives under this program during 2010. Most of the incentives offered under this program will take the form of a payment for energy production (\$/MWh) once the project is operating. Incentives range up to \$58.49/MWh for publicly-owned wastewater biogas projects. Up to 10% of the incentive may be requested in the form of a lump grant to cover up-front costs such as financing fees, interconnection fees, project design, permitting, and construction costs.

7.1.5 Utility Financing Programs

All four Electric Distribution Companies (EDCs) in New Jersey have developed long term contracting or financing programs for the development of solar energy systems. In all of the programs, Solar Renewable Energy Credits (SRECs) generated by the solar energy systems will be sold at auction to energy suppliers who are required to purchase a certain quantity of SRECs to meet their Renewable Portfolio Standard requirements.

7.1.6 Renewable Energy Manufacturing Incentive (NJ BPU)

New Jersey's Renewable Energy Manufacturing Incentive (REMI) program provides rebates to purchase and install solar panels, inverters, and racking systems manufactured in New Jersey. Rebates for panels start at \$0.25 per watt and rebates for racking systems and inverters start at \$0.15 per watt for solar projects up to 500 kW in capacity. To be eligible for REMI, applicants must apply to either the Renewable Energy Incentive Program (REIP) or the SREC Registration Program (SRP).

7.1.7 Environmental Infrastructure Financing Program (NJ DEP)

The Environmental Infrastructure Financing Program (EIFP) provides low-interest loans for the planning, design and construction of a variety of water, wastewater and stormwater infrastructure projects. NJ DEP traditionally provides loans at 0% interest for approximately 20 years for up to one-half the allowable project costs. The remaining project costs are funded through 20-year loans at about the market rate or less. Approximately \$100 million-\$200 million is available per year. In 2009, 20 percent of the projects funded were required to be "green infrastructure" projects, including energy efficiency and renewable energy projects. Applicants must submit a commitment letter in the beginning of October and an application in March annually. For more information, contact Stanley V. Cach, Jr. Assistant Director NJDEP-Municipal Finance and Construction Element at 609-292-8961 or stanley.cach@dep.state.nj.us.

7.1.8 Clean Renewable Energy Bonds (IRS)

CREBs are 0% interest bonds typically issued for up to approximately \$3.0 million administered by the Internal Revenue Service (IRS). Last year, \$2.2 billion in CREBs was allocated to municipal entities to fund 610 renewable energy projects, including anaerobic digestion. IRS has been allocating funding for CREBs annually since 2005. Last year, IRS solicited applications starting in April, which were due in August. The

IRS is expected to receive additional funding for CREBs and release another round of solicitations in 2010.

7.1.9 Qualified Energy Conservation Bonds (IRS)

These IRS 0% interest bonds are very similar to CREBs except they are allocated based on state and county population. New Jersey was allocated \$90 million as part of the ARRA stimulus fund. QECBs are typically distributed through municipal bond banks or state economic development agencies.

7.1.10 Global Climate Change Mitigation Incentive Fund (US EDA)

The Economic Development Agency (part of the U.S. Department of Commerce) administers the GCCMIF to public works projects that reduce greenhouse gas emissions and creates new jobs. In FY 2009, \$15 million was allocated to the fund, and additional funding is expected to be allocated in FY 2010. Applications are due on a rolling basis. The program does not have a maximum grant amount but does limit the grant to 50 percent of the project cost.

7.1.11 Private Tax-Exempt Financing

Similar to traditional municipal bond financing, there are many private financial service companies that offer a myriad of options for tax-exempt financing of municipal projects. The providers of these services suggest that this capital can be offered at competitive rates in an expedited timeframe and with fewer complications when compared to traditional municipal financing methods. Though these factors would need to be compared on a case-by-case basis, the one distinct advantage to private financing on the current project would likely be the flexibility to structure payments to meet budget needs with consideration given to the terms and conditions of existing loan and/or bond agreements. For example, this mechanism could be used to limit the digestion project dept payments in the initial years when the current bond debt is the greatest and the operations savings of the project has yet to be fully realized. It should also be noted that, in many cases, the construction and long term financing can be rolled into a single private financing agreement. Also, in some instances, equipment manufacturers have the ability to offer competitive financing terms (e.g. Siemens Financial Services Corporation), though financing from these sources is generally contingent upon a substantial portion of the project cost (~20% to 30%) being for their respective equipment.

7.1.12 Performance Based Contracts (ESCOs)

A second financing alternative for a project of this nature would be to enter into a Performance Based Contract with an Energy Services Company (ESCO). The premise of this type of contract is that it requires no initial municipal capital contributions in order to implement the project - instead relying on future operations cost savings and/or energy production, to fund the annual payments. Prior to entering into an agreement for the funding of the project, an ECSO would perform an energy audit

and/or conceptual studies to confirm future energy cost savings or energy production inherent with the projects implementation and operation. The contract would then be formulated based on some measurable parameter(s) (sludge reduction, energy production, etc) which would be verified by measurement throughout the contract duration. The savings in energy costs or energy production would then be used to pay back the capital investment of the project over the contract time period (typically on the order of 10-years or less). The ESCO would guarantee the agreed upon energy savings or energy production. If the project does not meet energy savings or production commitments, the ESCO pays the owner the equivalent difference.

With this funding alternative, the ownership and operation of the facility would be maintained by the original owner. A performance contract may also include ESCO operation and maintenance of the energy-related facilities if that were deemed appropriate. Significant ESCO's with experience in this area include Siemens Building Technologies, Chevron and Johnson Controls. CDM has functioned in several roles on performance based contracts including being the owner's representative and, on different contracts, providing design-build services (as a subcontractor to the ECSCO). We can provide additional experience-based information upon request.

7.1.13 Power Purchase Agreements (SPCs)

More commonly referred to as a Build-Own-Transfer (BOT) agreement in the Water/Wastewater industry, a Power Purchase Agreement (PPA) also delivers a project with no initial capital contribution by the original owner. In this model, a Special Purpose Company (SPC) created by a developer, would own the energy production facilities. Within the framework of a PPA, a SPC will typically lease property from the owners for construction and operation of the new facilities. The funding and construction of the new facilities would be performed by the SPC who would then own and operate the facilities for the duration of the contract (typically 20 to 30 years). Throughout that period of time, the original owner would purchase power from the SPC at a pre-negotiated rate which would take into account the initial capital cost, operation and maintenance of the constructed facility, ancillary benefits of the project and investor returns on investment. For renewable energy, financial incentives may enable this financing approach to compete favorably with utility power tariffs. Incentives include state and local tax credits, renewable energy credits, and Federal energy production tax credits or energy investment tax credits. It is expected that a number of experienced companies and developers may be interested in a PPA for New Jersey municipal renewable energy projects.

7.2 Energy Efficiency

7.2.1 Introduction

New Jersey's Clean Energy Program (NJ CEP) promotes increased energy efficiency and the use of clean, renewable sources of energy including solar, wind, geothermal, and sustainable biomass. The results for New Jersey are a stronger economy, less pollution, lower costs, and reduced demand for electricity. NJCEP offers financial

incentives, programs, and services for residential, commercial, and municipal customers.

NJCEP reduces the need to generate electricity and burn natural gas which eliminates the pollution that would have been caused by such electric generation or natural gas usage. The benefits of these programs continue for the life of the measures installed, which on average is about 15 years. Thus, the public receives substantial environmental and public health benefits from programs that also lower energy bills and benefit the economy.

7.2.2 New Jersey Smart Start Buildings Program (NJ BPU)

The New Jersey Smart Start Buildings Program offers rebate incentives for several qualifying equipment such as high efficient premium motors and lighting, and lighting controls.

Incentive information and incentive calculation worksheets are provided for the various new equipment installation identified in this report and are included in Appendix H.

7.2.3 Pay for Performance Program (NJ BPU)

Another program offered through the New Jersey Smart Start Program, is the Pay for Performance Program. Commercial, industrial and institutional buildings with an average annual peak demand over 200 kW are eligible for participation. In addition, local government agencies, which do not meet the 200 kW demand requirement and are not receiving Energy Efficiency and Conservation Block Grants are eligible.

Incentives are available for buildings that are able to present an Energy Reduction Plans that reduce the building's current energy consumption by 15% or more, in addition to incentives for installing the recommended measures and incentives for presenting the energy savings in a post-construction benchmarking report. No more than 50% of the total energy savings may be derived from lighting retrofits. In addition, the total energy savings of 15% may not come from the implementation of one energy savings measure.

The ERP presented herein for the MCJM WPCP results in an electrical and thermal energy savings of 15% or more. The following table summarizes the current annual energy use and the energy savings presented herein from the implementation of all ECRMs.

| Table 7.2-1 Pay for Performance ERP | | | |
|--|---|---|---|
| | Current Annual Electrical Energy Use (kWh) | Current Annual Fuel Use (therms) | Projected Annual Energy Savings from All ECRMs |
| WPCP | 2,213,387 | 77,163 | 1,695,828 kWh 35,418 Therms |

The following table summarizes the maximum potential incentives available through participation in the Pay for Performance Program.

| Table 7.2-2 Pay for Performance Incentive Summary | |
|--|---|
| | MCJM WPCP |
| Incentive #1: Energy Reduction Plan | \$2,549 (\$0.10 per square foot, Cap – 50% of annual energy expense) |
| Incentive #2: Installation of Recommended ECRMs | \$452,624 (Cap – 30% of total project cost) |
| Incentive #3: Post-Construction Benchmarking Report | \$301,749 (Cap – 20% of total project cost) |
| Total Incentives (Maximum) | \$756,922 |

7.2.4 Direct Install (NJ BPU)

Owners of existing small to mid-size commercial and industrial facilities with a peak electric demand that did not exceed 200 kW in any of the preceding 12 months are eligible to participate in Direct Install. Buildings must be located in New Jersey and served by one of the state’s public, regulated electric or natural gas utility companies.

This program will cover up to 80% of the retro-fitting costs associated with the use of new energy efficient equipment. Lighting, HVAC, refrigeration, motors, natural gas systems, and variable frequency drives are covered under the Direct Install program.



MCJM’s WPCP is not eligible for the Direct Install Program.

APPENDIX A

HISTORICAL DATA ANALYSIS

| Electric Bills for Plots - Molitor Water Pollution Control Facility | | | | | | | | | | |
|---|-----------|------|--|--|------------------------|-------------|--------------|-----------|-----------------|--------------|
| Comments | Month | Year | JCP&L Charges Ac # 10-00-05-6066-2-7 Meter # G15164052 | FirstEnergy Supply Charges Ac # 11013155 | Total Electric Charges | On Peak KWH | Off Peak KWH | Total KWH | Measured Demand | Cost Per KWh |
| | January | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | February | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | March | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | April | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | May | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | June | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | July | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | August | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | September | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | October | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | November | 2007 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | December | 2007 | \$ 25,683.36 | \$ - | \$ 25,683.36 | - | - | 173564 | 400.3 | \$ 0.15 |
| | January | 2008 | \$ 27,787.56 | \$ - | \$ 27,787.56 | - | - | 187909 | 384.5 | \$ 0.15 |
| | February | 2008 | \$ 27,912.94 | \$ - | \$ 27,912.94 | - | - | 191687 | 418.4 | \$ 0.15 |
| | March | 2008 | \$ 26,586.17 | \$ - | \$ 26,586.17 | - | - | 188032 | 417.6 | \$ 0.14 |
| | April | 2008 | \$ 23,749.23 | \$ - | \$ 23,749.23 | - | - | 168098 | 417.9 | \$ 0.14 |
| | May | 2008 | \$ 26,658.91 | \$ - | \$ 26,658.91 | - | - | 166603 | 373.3 | \$ 0.16 |
| | June | 2008 | \$ 27,771.83 | \$ - | \$ 27,771.83 | - | - | 160042 | 373.3 | \$ 0.17 |
| | July | 2008 | \$ 33,553.06 | \$ - | \$ 33,553.06 | - | - | 192966 | 371.8 | \$ 0.17 |
| | August | 2008 | \$ 35,271.93 | \$ - | \$ 35,271.93 | - | - | 204444 | 369.9 | \$ 0.17 |
| | September | 2008 | \$ 30,208.29 | \$ - | \$ 30,208.29 | - | - | 199473 | 369.9 | \$ 0.15 |
| | October | 2008 | \$ 30,287.20 | \$ - | \$ 30,287.20 | - | - | 204201 | 389.0 | \$ 0.15 |
| | November | 2008 | \$ 28,423.83 | \$ - | \$ 28,423.83 | - | - | 188023 | 405.8 | \$ 0.15 |
| | December | 2008 | \$ 31,754.98 | \$ - | \$ 31,754.98 | - | - | 203477 | 410.4 | \$ 0.16 |
| | January | 2009 | \$ 31,142.80 | \$ - | \$ 31,142.80 | - | - | 196980 | 384.5 | \$ 0.16 |
| | February | 2009 | \$ 11,641.90 | \$ 15,466.36 | \$ 27,108.26 | - | - | 177625 | 404.6 | \$ 0.15 |
| | March | 2009 | \$ 8,637.10 | \$ 19,844.25 | \$ 28,481.35 | - | - | 187564 | 383.0 | \$ 0.15 |
| | April | 2009 | \$ 7,749.64 | \$ 18,461.00 | \$ 26,210.63 | - | - | 172371 | 380.3 | \$ 0.15 |
| | May | 2009 | \$ 8,212.25 | \$ 19,229.95 | \$ 27,442.20 | - | - | 179031 | 378.4 | \$ 0.15 |
| | June | 2009 | \$ 7,600.67 | \$ 17,111.16 | \$ 24,711.83 | - | - | 165293 | 377.0 | \$ 0.15 |
| | July | 2009 | \$ 7,972.29 | \$ 17,835.45 | \$ 25,807.74 | - | - | 169860 | 375.8 | \$ 0.15 |
| | August | 2009 | \$ 8,052.59 | \$ 18,474.37 | \$ 26,526.96 | - | - | 174616 | 375.8 | \$ 0.15 |
| | September | 2009 | \$ 8,277.88 | \$ 19,301.86 | \$ 27,579.74 | - | - | 182437 | 385.9 | \$ 0.15 |
| | October | 2009 | \$ 8,702.39 | \$ 21,196.46 | \$ 29,898.85 | - | - | 200345 | 389.0 | \$ 0.15 |
| | November | 2009 | \$ 8,429.88 | \$ 19,134.80 | \$ 27,564.67 | - | - | 188858 | 461.9 | \$ 0.15 |
| | December | 2009 | \$ 9,024.40 | \$ 20,916.24 | \$ 29,940.63 | - | - | 197696 | 410.4 | \$ 0.15 |
| | January | 2010 | \$ 8,742.55 | \$ 20,903.02 | \$ 29,645.57 | - | - | 197571 | 384.5 | \$ 0.15 |
| | February | 2010 | \$ 8,617.47 | \$ 20,513.72 | \$ 29,131.19 | - | - | 193892 | 425.4 | \$ 0.15 |
| | March | 2010 | \$ 9,183.75 | \$ 21,098.36 | \$ 30,282.11 | - | - | 199417 | 438.2 | \$ 0.15 |
| | April | 2010 | \$ 8,456.78 | \$ 19,524.75 | \$ 27,981.53 | - | - | 184544 | 377.0 | \$ 0.15 |
| | May | 2010 | \$ 1,681.13 | \$ 3,910.37 | \$ 5,591.50 | - | - | 36960 | 0.0 | \$ 0.15 |
| | June | 2010 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | July | 2010 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | August | 2010 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | September | 2010 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | October | 2010 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | November | 2010 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |
| | December | 2010 | \$ - | \$ - | \$ - | - | - | 0 | 0.0 | #DIV/0! |

| Month | Combined (KWH) | Demand (KW) |
|--------------|----------------|-------------|
| January | 191153 | 385 |
| February | 187734 | 416 |
| March | 191671 | 413 |
| April | 175004 | 392 |
| May | 172817 | 376 |
| June | 162667 | 375 |
| July | 181263 | 374 |
| August | 189530 | 373 |
| September | 190955 | 378 |
| October | 202273 | 389 |
| November | 184441 | 434 |
| December | 191579 | 407 |
| Total | 2224089 | 4711 |





| Gas Bills for Plots - WWTP | | | | | | | | | | |
|----------------------------|-----------|------|--------------------------------|-----------------------|-------------------------------|-------------------|------------------------|------------------------|--------------|----------------|
| Comments | Month | Year | PSE & G Delivery Charges Ac. # | | Gateway Energy Supply Charges | Total Gas Charges | PSE & G Therms Meter # | PSE & G Therms Meter # | Total Therms | Cost Per Therm |
| | | | 65 669 384 00 Meter # | 65 669 384 00 Meter # | | | | | | |
| | January | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | February | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | March | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | April | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | May | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | June | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | July | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | August | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | September | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | October | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | November | 2007 | \$ - | \$ - | \$ - | \$ - | | | - | |
| | December | 2007 | \$ 970.86 | \$ 360.24 | \$ 4,108.97 | \$ - | 3,437 | 825 | 4,262 | \$ - |
| Econenergy Supply | January | 2008 | \$ 2,128.44 | \$ 757.17 | \$ 9,201.89 | \$ 12,087.50 | 7,408 | 1,920 | 9,327 | \$ 1.30 |
| Econenergy Supply | February | 2008 | \$ 1,884.12 | \$ 630.06 | \$ 8,659.21 | \$ 11,173.38 | 6,406 | 1,733 | 8,139 | \$ 1.37 |
| Econenergy Supply | March | 2008 | \$ 1,371.33 | \$ 471.55 | \$ 9,245.20 | \$ 11,088.08 | 6,289 | 1,648 | 7,937 | \$ 1.40 |
| Act. # 1243145013 and up | April | 2008 | \$ 592.78 | \$ 223.51 | \$ 8,926.55 | \$ 9,742.84 | 5,729 | 1,287 | 7,016 | \$ 1.39 |
| Act. # 12 431 450 13 | May | 2008 | \$ 389.60 | \$ 148.22 | \$ 5,176.19 | \$ 5,714.01 | 3,290 | 502 | 3,792 | \$ 1.51 |
| Act. # 12 431 450 13 | June | 2008 | \$ 163.99 | \$ 93.51 | \$ 1,134.10 | \$ 1,391.59 | 715 | 44 | 760 | \$ 1.83 |
| Act. # 12 431 450 13 | July | 2008 | \$ 151.01 | \$ 96.78 | \$ 794.47 | \$ 1,042.26 | 514 | 18 | 532 | \$ 1.96 |
| Act. # 12 431 450 13 | August | 2008 | \$ 152.28 | \$ 95.28 | \$ 743.83 | \$ 991.39 | 558 | 18 | 576 | \$ 1.72 |
| Act. # 12 431 450 13 | September | 2008 | \$ 613.00 | \$ 94.16 | \$ 6,440.97 | \$ 7,148.12 | 6,077 | 21 | 6,097 | \$ 1.17 |
| Act. # 12 431 450 13 | October | 2008 | \$ 1,253.21 | \$ 302.51 | \$ 7,252.02 | \$ 8,807.74 | 6,698 | 392 | 7,090 | \$ 1.24 |
| Act. # 12 431 450 13 | November | 2008 | \$ 1,736.16 | \$ 507.51 | \$ 5,032.25 | \$ 7,275.92 | 4,725 | 1,025 | 5,750 | \$ 1.27 |
| Act. # 12 431 450 13 | December | 2008 | \$ 2,343.45 | \$ 613.41 | \$ 8,912.49 | \$ 11,869.35 | 6,127 | 1,523 | 7,650 | \$ 1.55 |
| Act. # 12 431 450 13 | January | 2009 | \$ 2,107.42 | \$ 707.97 | \$ 7,628.95 | \$ 10,444.33 | 5,398 | 1,912 | 7,310 | \$ 1.43 |
| Act. # 12 431 450 13 | February | 2009 | \$ 1,811.34 | \$ 689.01 | \$ 4,822.94 | \$ 7,323.28 | 4,880 | 1,741 | 6,621 | \$ 1.11 |
| Act. # 12 431 450 13 | March | 2009 | \$ 820.41 | \$ 333.30 | \$ 3,878.19 | \$ 5,031.90 | 4,620 | 1,390 | 6,010 | \$ 0.84 |
| | April | 2009 | \$ 428.89 | \$ 198.42 | \$ 2,650.58 | \$ 3,277.88 | 3,467 | 1,002 | 4,469 | \$ 0.73 |
| | May | 2009 | \$ 383.19 | \$ 173.94 | \$ 2,068.38 | \$ 2,625.52 | 2,991 | 709 | 3,700 | \$ 0.71 |
| | June | 2009 | \$ 476.95 | \$ 110.91 | \$ 2,419.57 | \$ 3,007.42 | 3,938 | 216 | 4,154 | \$ 0.72 |
| | July | 2009 | \$ 674.77 | \$ 95.30 | \$ 3,378.02 | \$ 4,148.09 | 5,797 | 19 | 5,817 | \$ 0.71 |
| | August | 2009 | \$ 653.61 | \$ 96.75 | \$ 3,003.80 | \$ 3,754.16 | 5,504 | 17 | 5,521 | \$ 0.68 |
| | September | 2009 | \$ 550.03 | \$ 110.81 | \$ 2,390.25 | \$ 3,051.09 | 4,417 | 149 | 4,566 | \$ 0.67 |
| | October | 2009 | \$ 1,195.85 | \$ 341.41 | \$ 3,669.85 | \$ 5,207.11 | 5,561 | 587 | 6,147 | \$ 0.85 |
| | November | 2009 | \$ 1,832.58 | \$ 486.92 | \$ 5,345.33 | \$ 7,664.84 | 7,165 | 932 | 8,098 | \$ 0.95 |
| | December | 2009 | \$ 2,346.86 | \$ 628.46 | \$ 7,679.97 | \$ 10,655.28 | 8,937 | 1,600 | 10,537 | \$ 1.01 |
| | January | 2010 | \$ 2,392.53 | \$ 706.91 | \$ 8,061.75 | \$ 11,161.18 | 8,344 | 1,956 | 10,300 | \$ 1.08 |
| | February | 2010 | \$ 1,877.92 | \$ 610.89 | \$ 5,649.54 | \$ 8,138.36 | 5,614 | 1,536 | 7,150 | \$ 1.14 |
| | March | 2010 | \$ 1,346.58 | \$ 449.34 | \$ 4,863.39 | \$ 6,659.31 | 5,427 | 1,277 | 6,704 | \$ 0.99 |
| | April | 2010 | \$ 306.72 | \$ 107.56 | \$ 2,201.02 | \$ 2,614.30 | 2,678 | 542 | 3,199 | \$ - |
| | May | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |
| | June | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |
| | July | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |
| | August | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |
| | September | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |
| | October | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |
| | November | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |
| | December | 2010 | \$ - | \$ - | \$ - | \$ - | - | - | - | \$ - |

| Meter 2808461 All bldgs n/i 10 & 12 | |
|-------------------------------------|--------------|
| Month | (Therms) |
| January | 7050 |
| February | 5634 |
| March | 5445 |
| April | 4598 |
| May | 3140 |
| June | 2327 |
| July | 3156 |
| August | 3031 |
| September | 5247 |
| October | 6129 |
| November | 5945 |
| December | 7532 |
| Total | 59235 |

| Meter 2414133 Bldg 10 & 12 | |
|----------------------------|--------------|
| Month | (Therms) |
| January | 1929 |
| February | 1670 |
| March | 1438 |
| April | 1145 |
| May | 606 |
| June | 130 |
| July | 18 |
| August | 18 |
| September | 85 |
| October | 489 |
| November | 979 |
| December | 1561 |
| Total | 10068 |

| Total | |
|--------------|-------------------|
| Month | Combined (Therms) |
| January | 8979 |
| February | 7303 |
| March | 6884 |
| April | 5743 |
| May | 3746 |
| June | 2457 |
| July | 3174 |
| August | 3048 |
| September | 5332 |
| October | 6619 |
| November | 6924 |
| December | 9094 |
| Total | 69303 |



APPENDIX B

STATEMENT OF ENERGY PERFORMANCE
PORTFOLIO MANAGER REFERENCE SHEET



STATEMENT OF ENERGY PERFORMANCE

Molitor Water Pollution Control Facility

Building ID: 2385133
For 12-month Period Ending: May 31, 2010¹
Date SEP becomes ineligible: N/A

Date SEP Generated: July 21, 2010

| | | |
|--|--|---|
| Facility Molitor Water Pollution Control Facility 214 North Passaic Avenue Chatham Borough, NJ 07928 | Facility Owner Madison Chatham Joint Meeting 214 North Passaic Ave Chatham, NJ 07928 | Primary Contact for this Facility N/A |
|--|--|---|

Year Built: 1952
Energy Performance Rating² (1-100) 33

Site Energy Use Summary³

| | |
|-----------------------------------|------------|
| Electricity - Grid Purchase(kBtu) | 7,588,619 |
| Natural Gas (kBtu) ⁴ | 6,930,200 |
| Total Energy (kBtu) | 14,518,819 |

Energy Intensity⁵

| | |
|-------------------|----|
| Site (kBtu/gpd) | 6 |
| Source (kBtu/gpd) | 14 |

Emissions (based on site energy use)

| | |
|---|-------|
| Greenhouse Gas Emissions (MtCO ₂ e/year) | 1,524 |
|---|-------|

Electric Distribution Utility

FirstEnergy - Jersey Central Power & Lt Co

National Average Comparison

| | |
|---|------------|
| National Average Site EUI | 5 |
| National Average Source EUI | 11 |
| % Difference from National Average Source EUI | 19% |
| Building Type | Wastewater |

Meets Industry Standards⁶ for Indoor Environmental Conditions:

| | |
|---|-----|
| Ventilation for Acceptable Indoor Air Quality | N/A |
| Acceptable Thermal Environmental Conditions | N/A |
| Adequate Illumination | N/A |

Stamp of Certifying Professional

Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

Certifying Professional
N/A

Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) or a Registered Architect (RA) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE or RA in double-checking the information that the building owner or operator has entered into Portfolio Manager.

Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.

NOTE: You must check each box to indicate that each value is correct, OR include a note.

| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | |
|---|---|--|-------|--------------------------|
| Building Name | Molitor Water Pollution Control Facility | Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings? | | <input type="checkbox"/> |
| Type | Wastewater | Is this an accurate description of the space in question? | | <input type="checkbox"/> |
| Location | 214 North Passaic Avenue, Chatham Borough, NJ 07928 | Is this address accurate and complete? Correct weather normalization requires an accurate zip code. | | <input type="checkbox"/> |
| Single Structure | Water Utility/Wastewater Plant | Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building | | <input type="checkbox"/> |
| Molitor Water Pollution Control Facility (Municipal Wastewater Treatment Plant) | | | | |
| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | |
| Average Influent Biological Demand (BOD5) Concentration | 163 mg/l (milligrams per liter) | Is this the average biological demand concentration of the wastewater flowing into the facility? This should be the average concentration estimated over a 12 month period. BOD5 should be reported in mg/l. BOD5 is not the same as CBOD5, the carbonaceous biological oxygen demand. BOD5 is required for the energy performance rating. | | <input type="checkbox"/> |
| Average Effluent Biological Demand (BOD5) Concentration | 3 mg/l (milligrams per liter) | Is this the average biological demand concentration of the wastewater after it is treated and is leaving the facility? This should be the average concentration estimated over a 12 month period. BOD5 should be reported in mg/l. BOD5 is not the same as CBOD5, the carbonaceous biological oxygen demand. BOD5 is required for the energy performance rating. | | <input type="checkbox"/> |
| Plant Design Flow Rate | 4 MGD (million gallons per day) | Is this the plant design flow rate, measured in million gallons per day (MGD)? This is the amount of flow the plant is designed to process. | | <input type="checkbox"/> |
| Fixed Film Trickle Filtration Process | No | Does this facility have an onsite fixed film trickle filtration process? Trickle filtration is a process used to reduce BOD, pathogens, and nitrogen levels. | | <input type="checkbox"/> |
| Nutrient Removal | Yes | Does this facility conduct nutrient removal as part of the treatment process? Nutrient removal is considered any process included for the purpose of removing nutrients (i.e., nitrogen, phosphorous). This may include biological nitrification, biological denitrification, phosphorus removal, or recirculating sand filters. | | <input type="checkbox"/> |

ENERGY STAR® Data Checklist for Commercial Buildings

Energy Consumption

Power Generation Plant or Distribution Utility: FirstEnergy - Jersey Central Power & Lt Co

| Fuel Type: Electricity | | |
|---|------------|--|
| Meter: Molitor Water Pollution Control Facility (kWh (thousand Watt-hours)) | | |
| Space(s): Entire Facility | | |
| Generation Method: Grid Purchase | | |
| Start Date | End Date | Energy Use (kWh (thousand Watt-hours)) |
| 05/01/2010 | 05/31/2010 | 172,817.00 |
| 04/01/2010 | 04/30/2010 | 175,004.00 |
| 03/01/2010 | 03/31/2010 | 191,671.00 |
| 02/01/2010 | 02/28/2010 | 187,734.00 |
| 01/01/2010 | 01/31/2010 | 194,153.00 |
| 12/01/2009 | 12/31/2009 | 191,579.00 |
| 11/01/2009 | 11/30/2009 | 184,441.00 |
| 10/01/2009 | 10/31/2009 | 202,273.00 |
| 09/01/2009 | 09/30/2009 | 190,955.00 |
| 08/01/2009 | 08/31/2009 | 189,530.00 |
| 07/01/2009 | 07/31/2009 | 181,263.00 |
| 06/01/2009 | 06/30/2009 | 162,677.00 |
| Molitor Water Pollution Control Facility Consumption (kWh (thousand Watt-hours)) | | 2,224,097.00 |
| Molitor Water Pollution Control Facility Consumption (kBtu (thousand Btu)) | | 7,588,618.96 |
| Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu)) | | 7,588,618.96 |
| Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters? | | <input type="checkbox"/> |
| Fuel Type: Natural Gas | | |
| Meter: Meter 2808461 (therms) | | |
| Space(s): Entire Facility | | |
| Start Date | End Date | Energy Use (therms) |
| 05/01/2010 | 05/31/2010 | 3,140.00 |
| 04/01/2010 | 04/30/2010 | 4,598.00 |
| 03/01/2010 | 03/31/2010 | 5,445.00 |
| 02/01/2010 | 02/28/2010 | 5,634.00 |
| 01/01/2010 | 01/31/2010 | 7,050.00 |
| 12/01/2009 | 12/31/2009 | 7,532.00 |
| 11/01/2009 | 11/30/2009 | 5,945.00 |
| 10/01/2009 | 10/31/2009 | 6,129.00 |
| 09/01/2009 | 09/30/2009 | 5,247.00 |
| 08/01/2009 | 08/31/2009 | 3,031.00 |

| | | |
|---|-----------------|----------------------------|
| 07/01/2009 | 07/31/2009 | 3,156.00 |
| 06/01/2009 | 06/30/2009 | 2,327.00 |
| Meter 2808461 Consumption (therms) | | 59,234.00 |
| Meter 2808461 Consumption (kBtu (thousand Btu)) | | 5,923,400.00 |
| Meter: Meter 24114133 (therms) Space(s): Entire Facility | | |
| Start Date | End Date | Energy Use (therms) |
| 05/01/2010 | 05/31/2010 | 606.00 |
| 04/01/2010 | 04/30/2010 | 1,145.00 |
| 03/01/2010 | 03/31/2010 | 1,438.00 |
| 02/01/2010 | 02/28/2010 | 1,670.00 |
| 01/01/2010 | 01/31/2010 | 1,929.00 |
| 12/01/2009 | 12/31/2009 | 1,561.00 |
| 11/01/2009 | 11/30/2009 | 979.00 |
| 10/01/2009 | 10/31/2009 | 489.00 |
| 09/01/2009 | 09/30/2009 | 85.00 |
| 08/01/2009 | 08/31/2009 | 18.00 |
| 07/01/2009 | 07/31/2009 | 18.00 |
| 06/01/2009 | 06/30/2009 | 130.00 |
| Meter 24114133 Consumption (therms) | | 10,068.00 |
| Meter 24114133 Consumption (kBtu (thousand Btu)) | | 1,006,800.00 |
| Total Natural Gas Consumption (kBtu (thousand Btu)) | | 6,930,200.00 |
| Is this the total Natural Gas consumption at this building including all Natural Gas meters? | | <input type="checkbox"/> |

| | |
|--|--------------------------|
| Additional Fuels | |
| Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility. | <input type="checkbox"/> |

| | |
|---|--------------------------|
| On-Site Solar and Wind Energy | |
| Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported. | <input type="checkbox"/> |

| IT Energy Type: Average Influent Flow Meter | | |
|---|------------|------------------|
| Meter Name: Average Influent Flow Meter | | |
| Start Date | End Date | Energy Use (kWh) |
| 05/01/2010 | 05/31/2010 | 2.41 |
| 04/01/2010 | 04/30/2010 | 2.50 |
| 03/01/2010 | 03/31/2010 | 2.10 |
| 02/01/2010 | 02/28/2010 | 2.38 |
| 01/01/2010 | 01/31/2010 | 2.69 |
| 12/01/2009 | 12/31/2009 | 2.95 |
| 11/01/2009 | 11/30/2009 | 2.17 |
| 10/01/2009 | 10/31/2009 | 2.36 |
| 09/01/2009 | 09/30/2009 | 2.17 |

| | | |
|--|------------|--------------|
| 08/01/2009 | 08/31/2009 | 2.39 |
| 07/01/2009 | 07/31/2009 | 2.15 |
| 06/01/2009 | 06/30/2009 | 2.69 |
| Average Influent Flow Meter (kWh) | | 28.96 |

Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same PE or RA that signed and stamped the SEP.)

Name: _____ Date: _____

Signature: _____

Signature is required when applying for the ENERGY STAR.

FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP) and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

General Information:

| | |
|---|--------------|
| Molitor Water Pollution Control Facility | |
| Year Built | 1952 |
| For 12-month Evaluation Period Ending Date: | May 31, 2010 |

Facility Space Use Summary

| Molitor Water Pollution Control Facility | |
|---|--------------------------------------|
| Space Type | Municipal Wastewater Treatment Plant |
| Average Influent Biological Demand (BOD5) Concentration | 163 |
| Average Effluent Biological Demand (BOD5) Concentration | 3 |
| Plant Design Flow Rate | 4 |
| Fixed Film Trickle Filtration Process | No |
| Nutrient Removal | Yes |

Energy Performance Comparison

| Performance Metrics | Evaluation Periods | | Comparisons | | |
|---|--------------------------------------|---------------------------------------|--------------|--------|------------------|
| | Current (Ending Date: 05/31/2010) | Baseline (Ending Date: 05/31/2010) | Rating of 75 | Target | National Average |
| Energy Performance Rating | 33 | 33 | 75 | N/A | 50 |
| Energy Intensity | | | | | |
| Site (kBtu/gpd) | 6 | 6 | N/A | N/A | 5 |
| Source (kBtu/gpd) | 14 | 14 | N/A | N/A | 11 |
| Energy Cost | | | | | |
| \$/year | N/A | N/A | N/A | N/A | N/A |
| \$/mgpd/year | N/A | N/A | N/A | N/A | N/A |
| Greenhouse Gas Emissions | | | | | |
| MtCO ₂ e/year | 1,524 | 1,524 | N/A | N/A | 1,278 |
| kgCO ₂ e/ft ² /year | N/A | N/A | N/A | N/A | N/A |

Statement of Energy Performance


2010

Molitor Water Pollution Control Facility
214 North Passaic Avenue
Chatham Borough, NJ 07928

Portfolio Manager Building ID: 2385133

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit energystar.gov/benchmark.

This building's score



This building uses N/A kBtu per square foot per year.*

*Based on source energy intensity for the 12 month period ending May 2010

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at energystar.gov

Date of certification



PORTFOLIO MANAGER QUICK REFERENCE GUIDE

Portfolio Manager is an interactive energy management tool that allows you to track and assess energy and water consumption across your entire portfolio of buildings in a secure online environment. Use this Quick Reference Guide to identify opportunities for energy efficiency improvements, track your progress over time, and verify results.

IDENTIFY ENERGY EFFICIENCY PROJECTS

Use Portfolio Manager to identify under-performing buildings to target for energy efficiency improvements and establish baselines for setting and measuring progress for energy efficiency improvement projects over time.

The screenshot shows the 'Facility Summary' page for 'Fire Station 2'. It includes general information like address and year built, facility performance metrics (Current Source Energy Intensity, Change from Baseline, etc.), and a table for 'Space Use' with columns for Space Name, Space Type, Floor Area, % Floor Area, and Alerts. A red circle highlights the 'Add Space' button in the 'Space Use' section.

| STEP | ACTIVITY | ACTION |
|------|---|--|
| 1 | Access Portfolio Manager. (step not shown) | Visit www.energystar.gov/benchmark . Scroll down to the Login section on the right-hand side in the middle of the page. |
| 2 | Access your account: (step not shown) • Create a new account. • Login to an existing account. | <ul style="list-style-type: none"> • Click REGISTER, and follow instructions. • Enter user name and password, and click LOGIN. |
| 3 | Review system updates and enter account. (step not shown) | Click ACCESS MY PORTFOLIO , located below Welcome to Portfolio Manager . |
| 4 | Add a new facility. (step not shown) | Click ADD a Property, located in the upper right portion of the screen. |
| 5 | Select property type and enter general facility information. (step not shown) | Select the option that most closely resembles your facility and click CONTINUE . Enter general data and click SAVE . For more information on facility space types, see: www.energystar.gov/index.cfm?c=eligibility.bus_portfolio_manager_space_types . |
| 6 | Enter space use data. | <p>From the Facility Summary page, shown above, go to the Space Use section, located half way down the page, and click ADD SPACE.</p> <ul style="list-style-type: none"> • Enter a facility name. In the Select a Space Type menu, select the appropriate space type(s) for your building. If your space is not listed, select Other. Click CONTINUE. • Enter building characteristics. Click SAVE. Information required for each space type is listed here: www.energystar.gov/index.cfm?c=eligibility.bus_portfolio_manager_space_types. • Repeat steps above to add all major spaces in your facility. <p>Use bulk import service to minimize manual data entry of large sets of facility data (10 or more facilities or campuses are required).</p> <ul style="list-style-type: none"> • Go back to My Portfolio by clicking on the link in the upper left portion of the page. • Click IMPORT Facility Data Using Templates, located below Add a Property. |
| 7 | Enter energy use data. | <p>From the Facility Summary page, go to the Energy Meters section, located below the Space Use section, and click ADD METER.</p> <ul style="list-style-type: none"> • Enter meter name, type, and units. Click SAVE. • Enter number of months and start date. Click CONTINUE. • Enter energy use and cost for each month. Click SAVE. • Repeat for all energy meters and fuel types. |

www.energystar.gov/benchmark

Energy STAR **PORTFOLIO MANAGER** ACCOUNT INFORMATION CONTACTS FAQ FREQUENTLY ASKED QUESTIONS CONTACT US HELP LOGOUT

Home > My Portfolio

Group Averages

| | |
|--|---|
| Baseline Rating: 72 Facilities Included: 1 | Current Rating: 80 Facilities Included: 1 |
| Change from Baseline: Group Adjusted Percent Energy Use (%): -14.8% Facilities Included: 2 | |

Averages are weighted by Total Floor Space.
[More about Baselines](#)
[More about Change from Baseline: Adjusted Energy Use](#)

[Add a Property](#)
[Import Facility Data Using Templates](#)

Work with Facilities
[Update Multiple Meters](#)
[Share Facilities](#)
[Request Energy Performance Report](#)

Apply for Recognition
[Apply for the ENERGY STAR ENERGY STAR Leaders](#)

Automated Benchmarking
[Get Started Now](#)

My Facilities | **My Campuses**

GROUP: Fire Stations 8 [Create Group](#) | [Edit Group](#) | [View All](#) **VIEW:** Summary View 9a [Create View](#) | [Edit View](#) | [View All](#)

[Download](#) in Excel Search Facility Name: [Search](#)

Results 1 - 2 of 2 All # A B C D E F G H I J K L M N O P Q R S T U V W X Y Z


| Facility Name | Current Source Energy Intensity (kBtu/Sq. Ft.) | Change from Baseline: Adjusted Energy Use (%) | Change from Baseline: Energy Use Intensity (kBtu/Sq. Ft.) | Change from Baseline: GHG Emissions (MtCO ₂ e) | Total Energy Cost per Sq. Ft. (US Dollars \$) |
|--------------------------------|--|---|---|---|---|
| Fire Station 1 | 160.1 | -12.3 | -6.1 | -275.86 | \$0.30 |
| Fire Station 2 | 172.6 | -17.2 | -10.7 | -488.62 | \$0.37 |

[Download](#) in Excel 9b Search Facility Name: [Search](#)

Results 1 - 2 of 2 All # A B C D E F G H I J K L M N O P Q R S T U V W X Y Z

The rating is calculated by using the last day of the latest full calendar month where all meters in the facility have meter entries; the Period Ending date reflects that particular date.

| STEP | ACTIVITY | ACTION |
|----------|-----------------------------|---|
| 8 | Create custom groups. | <p>Organize facilities into groups (e.g., Fire Stations, Northwest Region). Groups are completely customizable, and each facility may belong to multiple groups.</p> <ul style="list-style-type: none"> From the My Portfolio page, click CREATE GROUP, located directly to the right of the Group drop-down menu. Follow instructions to select buildings and name your group. Once they have been saved, custom groups will be available in the Group drop-down menu. |
| 9 | View and interpret results. | <p>Option 1: Go to My Portfolio and view all buildings to compare performance metrics.</p> <p>Option 2: Export data to Microsoft® Excel.</p> <ul style="list-style-type: none"> On the My Portfolio page, select the view, from the View drop-down menu that will display the data you wish to export. The My Portfolio page will update to display the selected view. (9a) Select the DOWNLOAD IN EXCEL link. A File Download dialog window will open. Follow the steps provided by Excel. (9b) Use Excel functionality to view building energy performance graphically. The example below shows a comparison of Energy Use Intensity for a portfolio of fire stations, identifying under-performing buildings to target for energy efficiency improvements. |




TRACK PROGRESS OVER TIME

Portfolio Manager comes pre-populated with nine standard summary views of facility data, which are displayed on the My Portfolio summary page. These standard views include:

- Summary: Energy Use
- Performance: Green House Gas Emissions
- Performance: Financial
- Performance: Water Use

Additionally, users can create and save custom downloadable views by choosing from more than 70 different metrics. The default view set by the user will display automatically after logging into Portfolio Manager, and data from all views can be exported to Microsoft® Excel.



CREATE A CUSTOM VIEW

STEP ACTION

- From the **My Portfolio** page or the **Facility Summary** page, select the **Create View** link, located directly to the right of the **View** drop-down menu.
- Enter a name for the view. To set as the default view, select the box labeled **Set this View as My Portfolio Default**, located directly to the right of **View Name**. You may include up to 7 (seven) columns in each view.
- Choose each metric to be included in the view by selecting an order number from the **Preferred Column Order** drop-down menu to the left of the **Facility Data** column.
- Click **SAVE** at the bottom of the page. You will be returned to the **My Portfolio** page, and your custom view will be available in the **View** drop-down menu. (step not shown)

VERIFY AND DOCUMENT RESULTS

Use Portfolio Manager to quickly and accurately document reductions in energy use, greenhouse gas emissions, water use, and energy costs for an individual building or an entire portfolio. This valuable information can be used to provide a level of transparency and accountability to help demonstrate strategic use of funding.

Generate a Statement of Energy Performance that includes valuable information about your building's performance, including:

- Normalized energy use intensity
- National average comparisons
- Greenhouse gas emissions
- Energy performance rating (if available)

In addition, you can also request an Energy Performance Report to see the change in performance over time for selected buildings or an entire portfolio. Available comparative metrics in this report include:

- Normalized energy use intensity
- Total electric use
- Total natural gas use
- Energy performance rating (if available)

OMB No. 2050-0347

STATEMENT OF ENERGY PERFORMANCE Fire Station 2

4

Building ID: 1642681
For 12-month Period Ending: December 31, 2008¹
Date SEP becomes ineligible: N/A

Date SEP Generated: March 05, 2009

| | | |
|---|--|--|
| Facility Fire Station 2 000 Blank Street Arlington, VA 22209 | Facility Owner N/A | Primary Contact for this Facility N/A |
| Year Built: 1990 Gross Floor Area (ft ²): 300,000 | Energy Intensity⁵ Site (kBtu/ft ² /yr) 52 Source (kBtu/ft ² /yr) 173 Emissions (based on site energy use) Greenhouse Gas Emissions (MTCO ₂ e/year) 2,352 | |
| Energy Performance Rating ² (1-100) | | |
| Site Energy Use Summary³ Electricity (kBtu) Natural Gas (kBtu) ⁴ Total Energy (kBtu) 15,600,000 | | |
| Energy Intensity⁵ Site (kBtu/ft ² /yr) 52 Source (kBtu/ft ² /yr) 173 | | |
| Emissions (based on site energy use) Greenhouse Gas Emissions (MTCO ₂ e/year) 2,352 | | |
| Electric Distribution Utility Virginia Electric & Power Co | | |
| National Average Comparison National Average Site EUI 78 National Average Source EUI 157 % Difference from National Average Source EUI 10% Building Type Fire Station/Police Station | | |
| Meets Industry Standards⁶ for Indoor Environmental Conditions: Ventilation for Acceptable Indoor Air Quality N/A Acceptable Thermal Environmental Conditions N/A Adequate Illumination N/A | Certifying Professional N/A | |

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

Notes:
1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to sites with adjustments made for elevation based on Facility zip code.
5. National Greenhouse Gas Emissions Intensity is based on a 12-month period.
6. Ventilation, Acceptable Thermal Environmental Conditions, and Illumination are based on ASHRAE 90.1-2001, ASHRAE 55-2004, and IESNA Lighting Handbook for lighting quality.

PORTFOLIO MANAGER

ENERGY STAR

Home > My Portfolio > Fire Station 2

Facility Summary: Fire Station 2

Building ID: 1642681

Level of Access: Building Data Administrator

Electric Distribution Utility: Virginia Electric & Power Co

Regional Power Grid: SERC Virginia/Carolina

Select my Power Generation Plant to calculate my electric emissions rate

Electric Emissions Rate (lbsCO₂/yr) 151.7 (what is this?)

1 Generate a Statement of Energy Performance for uses other than applying for the ENERGY STAR

| General Information | |
|--|---------------------|
| Address: 000 Blank Street, Arlington, VA 22209 | |
| Year Built: 1990 | |
| Property Type: Single Facility | |
| Baseline Rating: N/A | Current Rating: N/A |
| Eligibility for the ENERGY STAR | |
| N/A | |

GENERATE A STATEMENT OF ENERGY PERFORMANCE AND AN ENERGY PERFORMANCE REPORT

| STEP | ACTION |
|------|--|
| 1 | From your selected building's Facility Summary page, click GENERATE A STATEMENT OF ENERGY PERFORMANCE . |
| 2 | On the next page, select a period ending date. (step not shown) |
| 3 | Click GENERATE REPORT , located in the bottom right corner of the screen. (step not shown) |
| 4 | Save the Statement of Energy Performance, accompanying Data Checklist, and Facility Summary that include information on energy use intensity and greenhouse gas emissions. |
| 5 | From the My Portfolio page, click REQUEST ENERGY PERFORMANCE REPORT , located under Work with Facilities , which shows reductions in key performance indicators over a user-specified time period. Specify the type of report, the facilities to be included, and the requested report columns. The report will be e-mailed to a user-specified address within one business day. (step not shown) |




APPENDIX C
DIGESTER SYSTEM DATA

MCJM Digestion System Operation

Digester #1 Useable Volume: 308,464 gal 41,233 ft³
 Digester #2 Useable Volume: 486,497 gal 65,031 ft³
 Heat Loss (Oct - March): 1 °F
 Heat Loss (April - Sept): 0.2 °F
 Digester Gas Production: 15 ft³/lb VS destroyed
 Heat Content of Digas: 550 Btu/ft³
 Boiler Rating: 994,000 BTU/hr
 Boiler Efficiency: 80 %

| | Primary Digester #1 | | | | | | | | Primary Digester #2 | | | | Current VS Destruction (%) | Digester #1 Sludge Heat Load (btu/hr) | Digester #1 Heat Loss (btu/hr) | Total Digester #1 Heat Load (btu/hr) | Digester #2 Sludge Heat Load (btu/hr) | Digester #2 Heat Loss (btu/hr) | Total Digester #2 Heat Load (btu/hr) | Heat Output from Engine (btu/hr) | Supplemental Heat Required from Boiler to heat Digester #1 (btu/hr) | Supplemental Heat Required from Boiler to heat Digester #2 (btu/hr) | | | | |
|----------|---------------------|-----------------------------|---------------------------------|---------------------------------|------------------------|-------------------|-----------------------------------|--|---------------------------------|---------------------------------|--------------|-------------------|----------------------------|---------------------------------------|--------------------------------|--------------------------------------|---------------------------------------|--------------------------------|--------------------------------------|----------------------------------|---|---|-----------------------------------|--|--|--|
| | Raw Sludge (%TS) | Total Raw Sludge Flow (GPD) | Raw Sludge to Digester #1 (GPD) | Detention Time in Dig #1 (days) | TS to Dig #1 (lbs/day) | Raw Sludge (%VSS) | Raw Sludge VS to Dig #1 (lbs/day) | VS load to Dig #1 (lbs/day-ft ³) | Raw Sludge to Digester #2 (GPD) | Detention Time in Dig #2 (days) | TS (lbs/day) | Raw Sludge (%VSS) | | | | | | | | | | | Raw Sludge VS to Dig #2 (lbs/day) | VS load to Dig #2 (lbs/day-ft ³) | | |
| Jan-07 | 2.5 | 19,938 | 7,975 | 39 | 1,663 | 81 | 1,347 | 0.03 | 11,963 | 41 | 2,494 | 81 | 2,020 | 0.03 | 42% | 124,712 | 107,206 | 231,918 | 187,068 | 169,081 | 356,149 | 185,250 | 402,817 | 170,899 | | |
| Feb-07 | 2.5 | 20,124 | 8,050 | 38 | 1,678 | 81 | 1,359 | 0.03 | 12,074 | 40 | 2,518 | 81 | 2,039 | 0.03 | 37% | 125,876 | 107,206 | 233,081 | 188,813 | 169,081 | 357,894 | 156,094 | 76,988 | 201,800 | | |
| Mar-07 | 2.5 | 19,426 | 7,770 | 40 | 1,620 | 81 | 1,312 | 0.03 | 11,656 | 42 | 2,430 | 81 | 1,968 | 0.03 | 51% | 121,510 | 107,206 | 228,715 | 182,264 | 169,081 | 351,345 | 227,177 | 1,539 | 124,169 | | |
| Apr-07 | 2.5 | 16,309 | 6,524 | 47 | 1,360 | 81 | 1,102 | 0.03 | 9,785 | 50 | 2,040 | 81 | 1,653 | 0.03 | 59% | 102,013 | 21,441 | 123,454 | 153,019 | 33,816 | 186,835 | 216,474 | (93,020) | (29,638) | | |
| May-07 | 2.5 | 15,951 | 6,380 | 48 | 1,330 | 81 | 1,078 | 0.03 | 9,571 | 51 | 1,995 | 81 | 1,616 | 0.02 | 61% | 99,774 | 21,441 | 121,215 | 149,660 | 33,816 | 183,476 | 219,832 | (98,617) | (36,356) | | |
| Jun-07 | 2.5 | 15,539 | 6,216 | 50 | 1,296 | 81 | 1,050 | 0.03 | 9,323 | 52 | 1,944 | 81 | 1,575 | 0.02 | 76% | 97,196 | 21,441 | 118,638 | 145,795 | 33,816 | 179,611 | 281,347 | (162,709) | (101,736) | | |
| Jul-07 | 2.5 | 16,693 | 6,677 | 46 | 1,392 | 81 | 1,128 | 0.03 | 10,016 | 49 | 2,088 | 81 | 1,692 | 0.03 | 72% | 104,415 | 21,441 | 125,856 | 156,622 | 33,816 | 190,438 | 285,556 | (159,700) | (95,118) | | |
| Aug-07 | 2.5 | 16,368 | 6,547 | 47 | 1,365 | 81 | 1,106 | 0.03 | 9,821 | 50 | 2,048 | 81 | 1,659 | 0.03 | 57% | 102,382 | 21,441 | 123,823 | 153,573 | 33,816 | 187,389 | 210,731 | (86,908) | (23,342) | | |
| Sep-07 | 2.5 | 13,324 | 5,330 | 58 | 1,111 | 81 | 900 | 0.02 | 7,994 | 61 | 1,667 | 81 | 1,350 | 0.02 | 53% | 83,342 | 21,441 | 104,783 | 125,012 | 33,816 | 158,829 | 145,369 | (40,586) | (13,460) | | |
| Oct-07 | 2.5 | 15,404 | 6,162 | 50 | 1,285 | 81 | 1,041 | 0.03 | 9,242 | 53 | 1,927 | 81 | 1,561 | 0.02 | 54% | 96,352 | 107,206 | 203,558 | 144,528 | 169,081 | 313,609 | 182,645 | 20,913 | 130,964 | | |
| Nov-07 | 2.5 | 16,337 | 6,535 | 47 | 1,363 | 81 | 1,104 | 0.03 | 9,802 | 50 | 2,044 | 81 | 1,655 | 0.03 | 50% | 102,188 | 107,206 | 209,394 | 153,282 | 169,081 | 322,363 | 177,943 | 31,451 | 144,420 | | |
| Dec-07 | 2.5 | 16,336 | 6,534 | 47 | 1,362 | 81 | 1,104 | 0.03 | 9,802 | 50 | 2,044 | 81 | 1,655 | 0.03 | 47% | 102,182 | 107,206 | 209,387 | 153,273 | 169,081 | 322,353 | 165,014 | 44,373 | 157,339 | | |
| Jan-08 | 2.5 | 16,336 | 6,534 | 47 | 1,362 | 81 | 1,104 | 0.03 | 9,802 | 50 | 2,044 | 81 | 1,655 | 0.03 | 51% | 102,182 | 107,206 | 209,387 | 153,273 | 169,081 | 322,353 | 183,220 | 26,167 | 139,133 | | |
| Feb-08 | 3.0 | 16,785 | 6,714 | 46 | 1,680 | 81 | 1,361 | 0.03 | 10,071 | 48 | 2,520 | 81 | 2,041 | 0.03 | 44% | 104,990 | 107,206 | 212,196 | 157,485 | 169,081 | 326,566 | 197,064 | 15,132 | 129,502 | | |
| Mar-08 | 2.9 | 17,273 | 6,909 | 45 | 1,665 | 81 | 1,349 | 0.03 | 10,364 | 47 | 2,498 | 81 | 2,023 | 0.03 | 57% | 108,043 | 107,206 | 215,248 | 162,064 | 169,081 | 331,145 | 266,693 | (51,444) | 64,452 | | |
| Apr-08 | 2.7 | 18,304 | 7,322 | 42 | 1,630 | 81 | 1,321 | 0.03 | 10,982 | 44 | 2,446 | 81 | 1,981 | 0.03 | 59% | 114,492 | 21,441 | 135,933 | 171,737 | 33,816 | 205,553 | 270,306 | (134,373) | (64,752) | | |
| May-08 | 2.6 | 18,596 | 7,438 | 41 | 1,638 | 81 | 1,327 | 0.03 | 11,158 | 44 | 2,457 | 81 | 1,990 | 0.03 | 54% | 116,318 | 21,441 | 137,759 | 174,477 | 33,816 | 208,293 | 247,280 | (109,521) | (38,987) | | |
| Jun-08 | 2.1 | 18,771 | 7,508 | 41 | 1,284 | 81 | 1,035 | 0.03 | 11,263 | 43 | 1,926 | 81 | 1,552 | 0.02 | 67% | 117,413 | 21,441 | 138,854 | 176,119 | 33,816 | 209,935 | 235,658 | (96,804) | (25,723) | | |
| Jul-08 | 2.1 | 17,806 | 7,122 | 43 | 1,265 | 79 | 1,002 | 0.02 | 10,684 | 46 | 1,898 | 79 | 1,503 | 0.02 | 66% | 111,377 | 21,441 | 132,818 | 167,065 | 33,816 | 200,881 | 224,719 | (91,901) | (23,838) | | |
| Aug-08 | 2.2 | 17,042 | 6,817 | 45 | 1,273 | 80 | 1,023 | 0.02 | 10,225 | 48 | 1,910 | 80 | 1,535 | 0.02 | 50% | 106,598 | 21,441 | 128,039 | 159,897 | 33,816 | 193,713 | 161,456 | (33,418) | 32,256 | | |
| Sep-08 | 2.1 | 16,436 | 6,574 | 47 | 1,168 | 80 | 935 | 0.02 | 9,862 | 49 | 1,752 | 80 | 1,402 | 0.02 | 67% | 102,807 | 21,441 | 124,248 | 154,211 | 33,816 | 188,027 | 207,254 | (83,006) | (19,227) | | |
| Oct-08 | 2.7 | 16,303 | 6,521 | 47 | 1,468 | 83 | 1,223 | 0.03 | 9,782 | 50 | 2,203 | 83 | 1,834 | 0.03 | 50% | 101,975 | 107,206 | 209,181 | 152,963 | 169,081 | 322,043 | 203,434 | 5,747 | 118,609 | | |
| Nov-08 | 2.3 | 15,571 | 6,228 | 50 | 1,190 | 79 | 936 | 0.02 | 9,343 | 52 | 1,784 | 79 | 1,404 | 0.02 | 51% | 97,397 | 107,206 | 204,602 | 146,095 | 169,081 | 315,176 | 146,841 | 57,761 | 168,334 | | |
| Dec-08 | 2.4 | 16,511 | 6,604 | 47 | 1,322 | 78 | 1,033 | 0.03 | 9,907 | 49 | 1,983 | 78 | 1,549 | 0.02 | 46% | 103,276 | 107,206 | 210,482 | 154,914 | 169,081 | 323,995 | 145,502 | 64,980 | 178,493 | | |
| Jan-09 | 2.8 | 17,522 | 7,009 | 44 | 1,634 | 80 | 1,301 | 0.03 | 10,513 | 46 | 2,451 | 80 | 1,951 | 0.03 | 48% | 109,600 | 107,206 | 216,806 | 164,400 | 169,081 | 333,481 | 207,173 | 9,633 | 126,308 | | |
| Feb-09 | 3.2 | 17,391 | 6,956 | 44 | 1,857 | 85 | 1,577 | 0.04 | 10,435 | 47 | 2,785 | 85 | 2,365 | 0.04 | 38% | 108,781 | 107,206 | 215,987 | 163,171 | 169,081 | 332,252 | 196,249 | 19,738 | 136,003 | | |
| Mar-09 | 2.8 | 17,758 | 7,103 | 43 | 1,671 | 84 | 1,399 | 0.03 | 10,655 | 46 | 2,506 | 84 | 2,099 | 0.03 | 57% | 111,076 | 107,206 | 218,282 | 166,614 | 169,081 | 335,695 | 278,293 | (60,010) | 57,403 | | |
| Apr-09 | 2.6 | 17,805 | 7,122 | 43 | 1,550 | 84 | 1,299 | 0.03 | 10,683 | 46 | 2,325 | 84 | 1,948 | 0.03 | 62% | 111,370 | 21,441 | 132,811 | 167,055 | 33,816 | 200,872 | 282,943 | (150,131) | (82,071) | | |
| May-09 | 2.6 | 16,756 | 6,702 | 46 | 1,437 | 84 | 1,208 | 0.03 | 10,054 | 48 | 2,155 | 84 | 1,812 | 0.03 | 65% | 104,809 | 21,441 | 126,250 | 157,213 | 33,816 | 191,029 | 276,041 | (149,791) | (85,012) | | |
| Jun-09 | 2.4 | 14,973 | 5,989 | 52 | 1,214 | 80 | 973 | 0.02 | 8,984 | 54 | 1,821 | 80 | 1,459 | 0.02 | 60% | 93,656 | 21,441 | 115,097 | 140,484 | 33,816 | 174,300 | 192,484 | (77,387) | (18,184) | | |
| Jul-09 | 2.0 | 17,370 | 6,948 | 44 | 1,142 | 76 | 862 | 0.02 | 10,422 | 47 | 1,712 | 76 | 1,293 | 0.02 | 50% | 108,649 | 21,441 | 130,091 | 162,974 | 33,816 | 196,790 | 125,461 | 4,629 | 71,329 | | |
| Aug-09 | 1.9 | 18,177 | 7,271 | 42 | 1,122 | 81 | 909 | 0.02 | 10,906 | 45 | 1,683 | 81 | 1,363 | 0.02 | 44% | 113,697 | 21,441 | 135,138 | 170,546 | 33,816 | 204,362 | 113,393 | 21,746 | 90,969 | | |
| Sep-09 | 2.2 | 18,038 | 7,215 | 43 | 1,309 | 81 | 1,060 | 0.03 | 10,823 | 45 | 1,963 | 81 | 1,590 | 0.02 | 42% | 112,828 | 21,441 | 134,269 | 169,242 | 33,816 | 203,058 | 131,403 | 2,866 | 71,654 | | |
| Oct-09 | 2.2 | 17,306 | 6,922 | 45 | 1,251 | 81 | 1,013 | 0.02 | 10,384 | 47 | 1,877 | 81 | 1,520 | 0.02 | 41% | 108,249 | 107,206 | 215,455 | 162,374 | 169,081 | 331,454 | 120,442 | 95,013 | 211,012 | | |
| Nov-09 | 2.2 | 17,305 | 6,922 | 45 | 1,293 | 81 | 1,047 | 0.03 | 10,383 | 47 | 1,940 | 81 | 1,571 | 0.02 | 28% | 108,243 | 107,206 | 215,449 | 162,364 | 169,081 | 331,445 | 69,400 | 146,049 | 262,045 | | |
| Dec-09 | 2.2 | 16,439 | 6,576 | 47 | 1,223 | 81 | 991 | 0.02 | 9,863 | 49 | 1,834 | 81 | 1,486 | 0.02 | 46% | 102,826 | 107,206 | 210,032 | 154,239 | 169,081 | 323,320 | 136,238 | 73,794 | 187,082 | | |
| Min: | 1.9 | 13,324 | 5,330 | 38 | 1,111 | 76 | 862 | 0.02 | 7,994 | 40 | 1,667 | 76 | 1,293 | 0.02 | 28% | | | | | | | | | | | |
| Average: | 2.5 | 17,065 | 6,826 | 45 | 1,402 | 81 | 1,137 | 0.03 | 10,239 | 48 | 2,103 | 81 | 1,705 | 0.03 | 53% | | | | | | | | | | | |
| Max: | 3.2 | 20,124 | 8,050 | 58 | 1,857 | 85 | 1,577 | 0.04 | 12,074 | 61 | 2,785 | 85 | 2,365 | 0.04 | 76% | | | | | | | | | | | |

Calculated Values



APPENDIX D

DIGESTER GAS PRODUCTION AND USE ANALYSIS

MCJM DIGESTER GAS USAGE SUMMARY


Engine Performance Data (with 0.8 PF²):

| | | | |
|------------|--------|-------------------|---------------------------|
| 100% Load: | 135 kW | Fuel Consumption: | 1,760 ft ³ /hr |
| 75% Load: | 101 kW | Fuel Consumption: | 1,402 ft ³ /hr |
| 50% Load: | 68 kW | Fuel Consumption: | 1,012 ft ³ /hr |
| 25% Load: | 34 kW | Fuel Consumption: | 593 ft ³ /hr |

| | Waste Gas Flow (ft ³ /day) | Total Biogas Produced (ft ³) | Total Biogas Produced (ft ³ /day) | Total Biogas Utilized (ft ³ /day) | Fuel flow to One Engine (ft ³ /hr) | Percent Engine Load (%) | Engine Output (hp) | Associated Blower Output (as a check) (scfm) | Heat Output from Engine (btu/hr) ¹ |
|--------|---------------------------------------|--|--|--|---|-------------------------|--------------------|--|---|
| Jan-07 | 4,900 | 650,900 | 21,411 | 16,511 | 688 | 37% | 67 | 2,193 | 185,250 |
| Feb-07 | 4,900 | 571,900 | 18,813 | 13,913 | 580 | 31% | 56 | 1,848 | 156,094 |
| Mar-07 | 4,900 | 764,500 | 25,148 | 20,248 | 844 | 45% | 82 | 2,689 | 227,177 |
| Apr-07 | 4,900 | 735,500 | 24,194 | 19,294 | 804 | 43% | 78 | 2,562 | 216,474 |
| May-07 | 4,900 | 744,600 | 24,493 | 19,593 | 816 | 44% | 79 | 2,602 | 219,832 |
| Jun-07 | 4,900 | 911,275 | 29,976 | 25,076 | 1,045 | 56% | 101 | 3,330 | 281,347 |
| Jul-07 | 4,900 | 922,680 | 30,351 | 25,451 | 1,060 | 57% | 103 | 3,380 | 285,556 |
| Aug-07 | 4,900 | 719,940 | 23,682 | 18,782 | 783 | 42% | 76 | 2,494 | 210,731 |
| Sep-07 | 4,900 | 542,840 | 17,857 | 12,957 | 540 | 29% | 52 | 1,721 | 145,369 |
| Oct-07 | 4,900 | 643,840 | 21,179 | 16,279 | 678 | 36% | 66 | 2,162 | 182,645 |
| Nov-07 | 4,900 | 631,100 | 20,760 | 15,860 | 661 | 35% | 64 | 2,106 | 177,943 |
| Dec-07 | 4,900 | 596,070 | 19,608 | 14,708 | 613 | 33% | 59 | 1,953 | 165,014 |
| Jan-08 | 4,900 | 645,400 | 21,230 | 16,330 | 680 | 36% | 66 | 2,169 | 183,220 |
| Feb-08 | 4,900 | 682,910 | 22,464 | 17,564 | 732 | 39% | 71 | 2,333 | 197,064 |
| Mar-08 | 4,900 | 871,570 | 28,670 | 23,770 | 990 | 53% | 96 | 3,157 | 266,693 |
| Apr-08 | 4,900 | 881,360 | 28,992 | 24,092 | 1,004 | 54% | 97 | 3,200 | 270,306 |
| May-08 | 4,900 | 818,970 | 26,940 | 22,040 | 918 | 49% | 89 | 2,927 | 247,280 |
| Jun-08 | 4,900 | 787,480 | 25,904 | 21,004 | 875 | 47% | 85 | 2,790 | 235,658 |
| Jul-08 | 4,900 | 757,840 | 24,929 | 20,029 | 835 | 45% | 81 | 2,660 | 224,719 |
| Aug-08 | 4,900 | 586,430 | 19,290 | 14,390 | 600 | 32% | 58 | 1,911 | 161,456 |
| Sep-08 | 4,900 | 710,520 | 23,372 | 18,472 | 770 | 41% | 75 | 2,453 | 207,254 |
| Oct-08 | 4,900 | 700,170 | 23,032 | 18,132 | 755 | 40% | 73 | 2,408 | 203,434 |
| Nov-08 | 4,900 | 546,830 | 17,988 | 13,088 | 545 | 29% | 53 | 1,738 | 146,841 |
| Dec-08 | 4,900 | 543,200 | 17,868 | 12,968 | 540 | 29% | 52 | 1,722 | 145,502 |
| Jan-09 | 4,900 | 710,300 | 23,365 | 18,465 | 769 | 41% | 74 | 2,452 | 207,173 |
| Feb-09 | 4,900 | 680,700 | 22,391 | 17,491 | 729 | 39% | 71 | 2,323 | 196,249 |
| Mar-09 | 4,900 | 903,000 | 29,704 | 24,804 | 1,033 | 55% | 100 | 3,294 | 278,293 |
| Apr-09 | 4,900 | 915,600 | 30,118 | 25,218 | 1,051 | 56% | 102 | 3,349 | 282,943 |
| May-09 | 4,900 | 896,900 | 29,503 | 24,603 | 1,025 | 55% | 99 | 3,268 | 276,041 |
| Jun-09 | 4,900 | 670,500 | 22,056 | 17,156 | 715 | 38% | 69 | 2,278 | 192,484 |
| Jul-09 | 4,900 | 488,900 | 16,082 | 11,182 | 466 | 25% | 45 | 1,485 | 125,461 |
| Aug-09 | 4,900 | 456,200 | 15,007 | 10,107 | 421 | 23% | 41 | 1,342 | 113,393 |
| Sep-09 | 4,900 | 505,000 | 16,612 | 11,712 | 488 | 26% | 47 | 1,555 | 131,403 |
| Oct-09 | 4,900 | 475,300 | 15,635 | 10,735 | 447 | 24% | 43 | 1,426 | 120,442 |
| Nov-09 | 4,900 | 337,000 | 11,086 | 6,186 | 258 | 14% | 25 | 822 | 69,400 |
| Dec-09 | 4,900 | 518,100 | 17,043 | 12,143 | 506 | 27% | 49 | 1,613 | 136,238 |

| | | | |
|-------------|----------------|---------------|---------------|
| Min: | 337,000 | 11,086 | 6,186 |
| Avg: | 681,259 | 22,410 | 17,510 |
| Max: | 922,680 | 30,351 | 25,451 |

1. Assuming a 52% thermal efficiency.
2. Performance curves on page 12 of O&M manual.



APPENDIX E
ANALYSIS OF VARIOUS SLUDGE PROCESSING
ALTERNATIVES

M CJM - DIGESTION SYSTEM OPERATION WITH THE ADDITION OF THICKENED WAS FROM THE AERATION BASINS

Engine Size 135 kW
 Fuel Required 42,240 ft³/day/engine @ full load
 Thermal Output 503,000 Btu/hour/engine
 Elec. Energy Cost \$0.15 \$/kWh
 Thermal Energy Cost \$1.07 \$/therm
 Caloric Value of Biogas 550 Btu/ft³
 Rated Capacity of Digester Building Boiler 944,000 Btu/hr
 Efficiency of Boiler 80%
 Rated Capacity of Bar Screen Boiler 1,100,000 Btu/hr
 Efficiency of Boiler 80%

Prepared By: M.Messmann Date: 8/17/2010
 Checked By: MH Date: 9/16/2010

| Month/Year | Total Biogas Produced (ft ³ /day) | Projected Biogas Production with TWS (ft ³ /day) | Primary Digesters 1&2 Heat Load (Btu/hr) | Electrical & Thermal Energy Produced if all Biogas was utilized in the engines | | | | | | | Electrical & Thermal Energy Produced when Biogas runs blower and boiler | | | | | | | |
|----------------------|--|---|--|--|--------|--------------------------|--|----------------------------|--|-------------------------------|---|---|--------|--|---|---|---|-----------------------------|
| | | | | # of Engines in Operation | % Load | Elec. Energy Output (kW) | Parasitic Energy Consumption (kW) ¹ | Total Energy Produced (kW) | Total Energy Produced (kWh Month) ² | Total Available Heat (Btu/hr) | Blower Power Requirement (100 hp avg day) (kW) | Required Biogas Flow (ft ³ /day) | % Load | Available Reject Heat from Engine (Btu/hr) | Remaining Biogas to Boiler (ft ³ /day) | Available Heat from Boiler Operation (Btu/hr) | Available Heat for Building Demand (Btu/hr) | Thermal Energy Cost Savings |
| Jan-09 | 34,719 | 45,692 | 550,287 | 2 | 54% | 146 | 8 | 138 | 87,989 | 544,107 | 75 | 23,467 | 56% | 279,444 | 22,225 | 407,464 | 136,622 | \$1,067 |
| Feb-09 | 35,431 | 46,404 | 548,238 | 2 | 55% | 148 | 8 | 140 | 89,441 | 552,586 | 75 | 23,467 | 56% | 279,444 | 22,937 | 420,518 | 151,724 | \$1,184 |
| Mar-09 | 37,302 | 48,275 | 553,977 | 2 | 57% | 154 | 8 | 146 | 93,259 | 574,866 | 75 | 23,467 | 56% | 279,444 | 24,808 | 454,819 | 180,287 | \$1,407 |
| Apr-09 | 36,842 | 47,815 | 333,683 | 2 | 57% | 153 | 8 | 145 | 92,320 | 569,388 | 75 | 23,467 | 56% | 279,444 | 24,348 | 446,386 | 392,148 | \$3,061 |
| May-09 | 34,532 | 45,505 | 317,279 | 2 | 54% | 145 | 8 | 137 | 87,607 | 541,880 | 75 | 23,467 | 56% | 279,444 | 22,038 | 404,036 | 366,201 | \$2,859 |
| Jun-09 | 22,427 | 33,400 | 289,398 | 1 | 79% | 107 | 8 | 99 | 62,909 | 397,732 | 75 | 23,467 | 56% | 279,444 | 9,933 | 182,111 | 172,158 | \$1,344 |
| Jul-09 | 32,502 | 43,475 | 326,881 | 2 | 51% | 139 | 8 | 131 | 83,465 | 517,707 | 75 | 23,467 | 56% | 279,444 | 20,008 | 366,819 | 319,383 | \$2,493 |
| Aug-09 | 19,315 | 30,288 | 339,500 | 1 | 72% | 97 | 8 | 89 | 56,559 | 360,674 | 75 | 23,467 | 56% | 279,444 | 6,821 | 125,058 | 65,002 | \$507 |
| Sep-09 | 21,807 | 32,780 | 337,327 | 1 | 78% | 105 | 8 | 97 | 61,644 | 390,349 | 75 | 23,467 | 56% | 279,444 | 9,313 | 170,744 | 112,862 | \$881 |
| Oct-09 | 17,032 | 28,005 | 546,909 | 1 | 66% | 90 | 8 | 81 | 51,901 | 333,488 | 75 | 23,467 | 56% | 279,444 | 4,538 | 83,203 | (184,262) | \$0 |
| Nov-09 | 19,429 | 30,402 | 546,893 | 1 | 72% | 97 | 8 | 89 | 56,792 | 362,031 | 75 | 23,467 | 56% | 279,444 | 6,935 | 127,148 | (140,301) | \$0 |
| Dec-09 | 22,306 | 33,279 | 533,351 | 1 | 79% | 106 | 8 | 98 | 62,662 | 396,291 | 75 | 23,467 | 56% | 279,444 | 9,812 | 179,893 | (74,014) | \$0 |
| Annual Total: | 465,320 | 523,723 | | | | | | | | | | 281,600 | | 3,353,333 | 183,720 | 3,368,200 | 1,497,811 | \$14,805 |

1. Analysis includes the assumption of a 6 hp motors associated with the operation of theGBTs and 5 hp motor for WAS transfer to the GBTs.
 2. Analysis assumes an average engine run-time of 21 hours per day to account for downtime for maintenance and varying gas production.

MJCM - DIGESTION SYSTEM OPERATION WITH THE ADDITION OF THICKENED WAS FROM THE AERATION BASINS AND FOG

Engine Size 135 kW
 Fuel Required 42,240 ft³/day/engine @ full load
 Thermal Output 503,000 Btu/hour/engine
 Elec. Energy Cost \$0.15 \$/kWh
 Thermal Energy Cost \$1.07 \$/therm
 Caloric Value of Biogas 550 Btu/ft³
 Rated Capacity of Digester Building Boiler 944,000 Btu/hr
 Efficiency of Boiler 80%
 Rated Capacity of Bar Screen Boiler 1,100,000 Btu/hr
 Efficiency of Boiler 80%

Prepared By: M.Messmann Date: 8/17/2010
 Checked By: MH Date: 9/16/2010

| Month/Year | Electrical & Thermal Energy Produced if all Biogas was utilized in the engines | | | | | | | | | | | Electrical & Thermal Energy Produced when Biogas runs blower and dual fuel boilers | | | | | | | | | |
|----------------------|--|---|---|--|---------------------------|---------------|--------------------------|--|----------------------------|--|-------------------------------|--|--|---|---------------|--|---|---|---------------------------------|--|-----------------------------|
| | Total Biogas Produced (ft ³ /day) | Projected Biogas Production with TWS (ft ³ /day) | Project Biogas Production with TWS and FOG (ft ³ /day) | Primary Digesters 1&2 Heat Load (Btu/hr) | # of Engines in Operation | Engine % Load | Elec. Energy Output (kW) | Parasitic Energy Consumption (kW) ¹ | Total Energy Produced (kW) | Total Energy Produced (KWh Month) ² | Total Available Heat (Btu/hr) | Waste Gas Flow (ft ³ /day) | Blower Power Requirement (100 hp avg day) (kW) | Required Biogas Flow (ft ³ /day) | Engine % Load | Available Reject Heat from Engine (Btu/hr) | Remaining Biogas to Boiler (ft ³ /day) | Available Heat from Boiler Operation (Btu/hr) | FOG System Heat Demand (Btu/hr) | Available Heat for Building Heat Demand (Btu/hr) | Thermal Energy Cost Savings |
| Jan-09 | 34,719 | 45,692 | 80,088 | 550,287 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 56,621 | 1,038,058 | 366,621 | 400,595 | \$3,127 |
| Feb-09 | 35,431 | 46,404 | 80,800 | 548,238 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 57,333 | 1,051,111 | 366,621 | 415,696 | \$3,245 |
| Mar-09 | 37,302 | 48,275 | 82,671 | 553,977 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 59,204 | 1,085,413 | 366,621 | 444,259 | \$3,468 |
| Apr-09 | 36,842 | 47,815 | 82,211 | 333,683 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 58,744 | 1,076,979 | 366,621 | 656,120 | \$5,122 |
| May-09 | 34,532 | 45,505 | 79,901 | 317,279 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 56,434 | 1,034,629 | 366,621 | 630,174 | \$4,920 |
| Jun-09 | 22,427 | 33,400 | 67,796 | 289,398 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 44,329 | 812,704 | 366,621 | 436,130 | \$3,405 |
| Jul-09 | 32,502 | 43,475 | 77,871 | 326,881 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 54,404 | 997,413 | 366,621 | 583,356 | \$4,554 |
| Aug-09 | 19,315 | 30,288 | 64,684 | 339,500 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 41,217 | 755,651 | 366,621 | 328,974 | \$2,568 |
| Sep-09 | 21,807 | 32,780 | 67,176 | 337,327 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 43,709 | 801,338 | 366,621 | 376,835 | \$2,942 |
| Oct-09 | 17,032 | 28,005 | 62,401 | 546,909 | 2 | 74% | 199 | 8 | 191 | 122,081 | 743,080 | 0 | 75 | 23,467 | 56% | 279,444 | 38,934 | 713,796 | 366,621 | 79,711 | \$622 |
| Nov-09 | 19,429 | 30,402 | 64,798 | 546,893 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 41,331 | 757,741 | 366,621 | 123,671 | \$965 |
| Dec-09 | 22,306 | 33,279 | 67,675 | 533,351 | 2 | 100% | 270 | 8 | 262 | 167,129 | 1,006,000 | 0 | 75 | 23,467 | 56% | 279,444 | 44,208 | 810,486 | 366,621 | 189,958 | \$1,483 |
| Annual Total: | | | 878,072 | 5,223,723 | | | | | | | | | 281,600 | | | 3,353,333 | 596,472 | 10,935,320 | 4,399,452 | 4,665,479 | \$36,422 |

1. Analysis includes the assumption of a 6 hp motors associated with the operation of the GBTs and 5 hp motor for WAS transfer to the GBTs.
 2. Analysis assumes an average engine run-time of 21 hours per day to account for downtime for maintenance and varying gas production.

MCEM - DIGESTION SYSTEM OPERATION WITH THE ADDITION OF PHS

Engine Size 135 kW
 Fuel Required 42,240 ft³/day/engine @ full load
 Thermal Output 503,000 Btu/hour/engine
 Elec. Energy Cost \$0.15 \$/kWh
 Thermal Energy Cost \$1.07 \$/therm
 Caloric Value of Biogas 550 Btu/ft³
 Rated Capacity of Digester Building Boiler 944,000 Btu/hr
 Efficiency of Boiler 80%
 Rated Capacity of Bar Screen Boiler 1,100,000 Btu/hr
 Efficiency of Boiler 80%

Prepared By: M.Messmann Date: 8/17/2010
 Checked By: MH Date: 9/16/2010


| Month/Year | Total Biogas Produced (ft ³ /day) | Projected Biogas Production with PHS Addition (ft ³ /day) | Primary Digesters 1&2 Heat Load (Btu/hr) | # of Engines in Operation | Electrical & Thermal Energy Produced if all Biogas was utilized in the engines | | | | | | Electrical & Thermal Energy Produced when Biogas runs blower and boiler | | | | | | | |
|----------------------|--|--|--|---------------------------|--|--------------------------|--|----------------------------|--|-------------------------------|---|---|--------|--|---|---|---|-----------------------------|
| | | | | | % Load | Elec. Energy Output (kW) | Parasitic Energy Consumption (kW) ¹ | Total Energy Produced (kW) | Total Energy Produced (kWh Month) ² | Total Available Heat (Btu/hr) | Blower Power Requirement (83 hp avg day summer, 100 hp avg day winter) (kW) | Required Biogas Flow (ft ³ /day) | % Load | Available Reject Heat from Engine (Btu/hr) | Remaining Biogas to Boiler (ft ³ /day) | Available Heat from Boiler Operation (Btu/hr) | Available Heat for Building Demand (Btu/hr) | Thermal Energy Cost Savings |
| Jan-09 | 34,719 | 41,663 | 550,287 | 1 | 99% | 133 | 8 | 125 | 79,768 | 496,127 | 75 | 23,467 | 56% | 279,444 | 18,196 | 333,596 | 62,754 | \$490 |
| Feb-09 | 35,431 | 42,517 | 548,238 | 2 | 50% | 136 | 8 | 128 | 81,511 | 506,301 | 75 | 23,467 | 56% | 279,444 | 19,051 | 349,260 | 80,466 | \$628 |
| Mar-09 | 37,302 | 44,762 | 553,977 | 2 | 53% | 143 | 8 | 135 | 86,092 | 533,037 | 75 | 23,467 | 56% | 279,444 | 21,296 | 390,422 | 115,889 | \$905 |
| Apr-09 | 36,842 | 44,210 | 333,683 | 2 | 52% | 141 | 8 | 133 | 84,966 | 526,464 | 75 | 23,467 | 56% | 279,444 | 20,744 | 380,302 | 326,063 | \$2,545 |
| May-09 | 34,532 | 41,438 | 317,279 | 1 | 98% | 132 | 8 | 124 | 79,310 | 493,454 | 62 | 19,399 | 46% | 231,007 | 22,039 | 404,054 | 317,782 | \$2,481 |
| Jun-09 | 22,427 | 26,912 | 289,398 | 1 | 64% | 86 | 8 | 78 | 49,672 | 320,477 | 62 | 19,399 | 46% | 231,007 | 7,513 | 137,744 | 79,353 | \$619 |
| Jul-09 | 32,502 | 39,002 | 326,881 | 1 | 92% | 125 | 8 | 116 | 74,339 | 464,446 | 62 | 19,399 | 46% | 231,007 | 19,603 | 359,394 | 263,520 | \$2,057 |
| Aug-09 | 19,315 | 23,178 | 339,500 | 1 | 55% | 74 | 8 | 66 | 42,052 | 276,007 | 62 | 19,399 | 46% | 231,007 | 3,779 | 69,280 | 0 | \$0 |
| Sep-09 | 21,807 | 26,168 | 337,327 | 1 | 62% | 84 | 8 | 75 | 48,154 | 311,617 | 62 | 19,399 | 46% | 231,007 | 6,769 | 124,104 | 17,785 | \$139 |
| Oct-09 | 17,032 | 20,438 | 546,909 | 1 | 48% | 65 | 8 | 57 | 36,463 | 243,383 | 62 | 19,399 | 46% | 231,007 | 1,039 | 19,054 | 0 | \$0 |
| Nov-09 | 19,429 | 23,315 | 546,893 | 1 | 55% | 75 | 8 | 66 | 42,331 | 277,636 | 75 | 23,467 | 56% | 279,444 | 0 | 0 | 0 | \$0 |
| Dec-09 | 22,306 | 26,767 | 533,351 | 1 | 63% | 86 | 8 | 77 | 49,376 | 318,748 | 75 | 23,467 | 56% | 279,444 | 3,301 | 60,510 | 0 | \$0 |
| Annual Total: | 400,373 | 5,223,723 | | | | | | | | | | 257,195 | | 3,062,711 | 143,330 | 2,627,717 | 1,263,612 | \$9,865 |

1. Analysis includes the assumption of a 6 hp motors associated with the operation of theGBTs and 5 hp motor for WAS transfer to theGBTs.
2. Analysis assumes an average engine run-time of 21 hours per day to account for downtime for maintenance and varying gas production.


APPENDIX F

eQUEST MODEL RESULTS

Electric Consumption (kWh)



Gas Consumption (Btu)



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling

Electric Consumption (kWh x000)



| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
|---------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|---------------|
| Space Cool | - | - | - | 0.01 | 0.08 | 0.15 | 0.28 | 0.24 | 0.09 | 0.01 | 0.01 | - | 0.86 |
| Heat Reject. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Refrigeration | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Space Heat | - | - | - | - | - | - | - | - | - | - | - | - | - |
| HP Supp. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Hot Water | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Vent. Fans | 3.50 | 3.21 | 3.52 | 3.38 | 3.45 | 3.33 | 3.33 | 3.44 | 3.22 | 3.46 | 3.29 | 3.46 | 40.59 |
| Pumps & Aux. | 0.50 | 0.45 | 0.50 | 0.46 | 0.40 | 0.34 | 0.33 | 0.33 | 0.34 | 0.43 | 0.46 | 0.50 | 5.05 |
| Ext. Usage | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Misc. Equip. | 1.98 | 1.96 | 2.25 | 2.16 | 2.07 | 2.16 | 2.07 | 2.16 | 2.06 | 2.07 | 2.06 | 2.16 | 25.17 |
| Task Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Area Lights | 6.08 | 6.00 | 6.86 | 6.57 | 6.34 | 6.57 | 6.34 | 6.60 | 6.31 | 6.34 | 6.31 | 6.60 | 76.94 |
| Total | 12.05 | 11.62 | 13.13 | 12.58 | 12.35 | 12.55 | 12.35 | 12.78 | 12.03 | 12.31 | 12.13 | 12.72 | 148.61 |

Gas Consumption (Btu x000,000)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
|---------------|---------------|---------------|---------------|--------------|--------------|-------------|-------------|-------------|-------------|--------------|--------------|---------------|---------------|
| Space Cool | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Heat Reject. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Refrigeration | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Space Heat | 202.16 | 171.21 | 129.08 | 74.02 | 26.60 | 8.71 | - | - | 7.28 | 38.64 | 92.12 | 183.16 | 933.00 |
| HP Supp. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Hot Water | 1.12 | 1.11 | 1.26 | 1.18 | 1.05 | 1.00 | 0.90 | 0.91 | 0.89 | 0.96 | 1.02 | 1.14 | 12.55 |
| Vent. Fans | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Pumps & Aux. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Ext. Usage | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Misc. Equip. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Task Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Area Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Total | 203.28 | 172.32 | 130.35 | 75.21 | 27.66 | 9.71 | 0.90 | 0.91 | 8.18 | 39.61 | 93.15 | 184.30 | 945.55 |

Electric Consumption (kWh)

Gas Consumption (Btu)





- Area Lighting
- Task Lighting
- Misc. Equipment
- Exterior Usage
- Pumps & Aux.
- Ventilation Fans
- Water Heating
- Ht Pump Supp.
- Refrigeration
- Heat Rejection
- Space Heating
- Space Cooling

Electric Consumption (kWh x000)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
|---------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Space Cool | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Heat Reject. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Refrigeration | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Space Heat | - | - | - | - | - | - | - | - | - | - | - | - | - |
| HP Supp. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Hot Water | 0.05 | 0.05 | 0.06 | 0.05 | 0.05 | 0.04 | 0.04 | 0.04 | 0.04 | 0.04 | 0.05 | 0.05 | 0.56 |
| Vent. Fans | 1.01 | 0.91 | 1.01 | 0.98 | 1.01 | 0.98 | 1.01 | 1.01 | 0.98 | 1.01 | 0.98 | 1.01 | 11.90 |
| Pumps & Aux. | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.99 |
| Ext. Usage | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Misc. Equip. | 0.09 | 0.09 | 0.11 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 1.19 |
| Task Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Area Lights | 0.85 | 0.83 | 0.95 | 0.91 | 0.88 | 0.91 | 0.92 | 0.92 | 0.88 | 0.88 | 0.88 | 0.92 | 10.72 |
| Total | 2.09 | 1.96 | 2.21 | 2.12 | 2.12 | 2.12 | 2.15 | 2.15 | 2.07 | 2.12 | 2.08 | 2.17 | 25.36 |

Gas Consumption (Btu x000,000)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
|---------------|--------------|--------------|--------------|--------------|-------------|-------------|----------|----------|-------------|--------------|--------------|--------------|---------------|
| Space Cool | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Heat Reject. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Refrigeration | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Space Heat | 73.15 | 61.79 | 48.22 | 27.53 | 2.84 | 0.25 | - | - | 1.46 | 14.27 | 36.42 | 67.62 | 333.57 |
| HP Supp. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Hot Water | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Vent. Fans | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Pumps & Aux. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Ext. Usage | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Misc. Equip. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Task Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Area Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Total | 73.15 | 61.79 | 48.22 | 27.53 | 2.84 | 0.25 | - | - | 1.46 | 14.27 | 36.42 | 67.62 | 333.57 |



- Area Lighting
- Task Lighting
- Misc. Equipment
- Exterior Usage
- Pumps & Aux.
- Ventilation Fans
- Water Heating
- Ht Pump Supp.
- Space Heating
- Refrigeration
- Heat Rejection
- Space Cooling

Electric Consumption (kWh x000)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
|---------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| Space Cool | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Heat Reject. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Refrigeration | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Space Heat | - | - | - | - | - | - | - | - | - | - | - | - | - |
| HP Supp. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Hot Water | 0.05 | 0.05 | 0.06 | 0.05 | 0.05 | 0.04 | 0.04 | 0.04 | 0.04 | 0.04 | 0.05 | 0.05 | 0.56 |
| Vent. Fans | 1.01 | 0.91 | 1.01 | 0.98 | 1.01 | 0.98 | 1.01 | 1.01 | 0.98 | 1.01 | 0.98 | 1.01 | 11.90 |
| Pumps & Aux. | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.08 | 0.99 |
| Ext. Usage | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Misc. Equip. | 0.09 | 0.09 | 0.11 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 1.19 |
| Task Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Area Lights | 0.85 | 0.83 | 0.95 | 0.91 | 0.88 | 0.91 | 0.92 | 0.92 | 0.88 | 0.88 | 0.88 | 0.92 | 10.72 |
| Total | 2.09 | 1.96 | 2.21 | 2.12 | 2.12 | 2.12 | 2.15 | 2.15 | 2.07 | 2.12 | 2.08 | 2.17 | 25.36 |

Gas Consumption (Btu x000,000)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
|---------------|--------------|--------------|--------------|--------------|-------------|-------------|----------|----------|-------------|--------------|--------------|--------------|---------------|
| Space Cool | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Heat Reject. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Refrigeration | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Space Heat | 69.62 | 58.81 | 45.90 | 26.20 | 2.70 | 0.24 | - | - | 1.39 | 13.58 | 34.67 | 64.36 | 317.47 |
| HP Supp. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Hot Water | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Vent. Fans | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Pumps & Aux. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Ext. Usage | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Misc. Equip. | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Task Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Area Lights | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Total | 69.62 | 58.81 | 45.90 | 26.20 | 2.70 | 0.24 | - | - | 1.39 | 13.58 | 34.67 | 64.36 | 317.47 |

APPENDIX G

ENGINEER'S OPINION OF
PROBABLE CONSTRUCTION COST

The Engineer's Opinion of Probable Construction Cost Estimates presented in this Appendix is an Opinion of Probable Construction Cost only. CDM has no control over the cost of labor, materials, equipment, or services furnished, over schedules, over contractor's methods of determining prices, competitive bidding, market conditions or negotiating terms. CDM does not guarantee that this opinion will not vary from actual cost, or contractor's bids. There are not any costs provided for: Change Orders, Design Engineering, Construction Oversight, Client Costs, Finance or Funding Costs, Legal Fees, Land Acquisition or temporary/permanent Easements, Operations, or any other costs associated with this project that are not specifically part of the bidding contractor's proposed scope.

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

100 Crossways Park West, Suite 415
 Woodbury, NY 11797
 Phone (516) 496-8400
 Fax (516) 4968864

Location: MCJM

ITEM **Option 1: Installation of Premium Efficiency Motors & VFDs
 on Mechanical Aerators**

Estimate by: MM

Checked by: MH

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|--------------|
| 1 | Premium Efficiency Motors & VFDs | 3 | ea. | \$ 2,600.00 | \$ 7,800.00 | 3 | ea. | \$ 1,312.00 | \$ 3,936.00 | \$ 11,736.00 |
| 2 | Electrical Work | 3 | ea. | \$ 5,000.00 | \$ 15,000.00 | 3 | ea. | \$ 6,000.00 | \$ 18,000.00 | \$ 33,000.00 |
| 3 | Modification to Existing Aeration Blower | 1 | ls. | \$ 5,000.00 | \$ 5,000.00 | 1 | ls. | \$ 5,000.00 | \$ 5,000.00 | \$ 10,000.00 |
| | Subtotal | | | | 27,800.00 | | | | 26,936.00 | |

| | | |
|----------------------------------|-----------|------------------|
| SUBTOTAL = | \$ | 54,736.00 |
| OH&P 20 % = | \$ | 0.20 |
| MARKUP = | \$ | 10,947.20 |
| SUB-TOTAL w/ OH & P = | \$ | 65,683.20 |
| CONTINGENCY % = | | 0.30 |
| CONTINGENCY = | \$ | 19,704.96 |
| BUDGET COST ESTIMATE = | \$ | 85,388.16 |

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

100 Crossways Park West, Suite 415
 Woodbury, NY 11797
 Phone (516) 496-8400
 Fax (516) 4968864

Location: MCJM

ITEM **Option 2: Installation of Fine Bubble Aeration System**

Estimate by: MM

Checked by: MH

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|--------------------|-------------------|-----|------|---------------|----------------|---------------|
| 1 | Fine Bubble Aeration System ¹ | 1 | ea. | \$ 70,000.00 | \$ 70,000.00 | 1 | ea. | \$ 600,000.00 | \$ 600,000.00 | \$ 670,000.00 |
| 2 | Aeration System Controls | 1 | ea. | \$ 200,000.00 | \$ 200,000.00 | | | | | \$ 200,000.00 |
| | Subtotal | | | | 270,000.00 | | | | 600,000.00 | |

| | | |
|----------------------------------|-----------|---------------------|
| SUBTOTAL = | \$ | 870,000.00 |
| OH&P 20 % = | \$ | 0.20 |
| MARKUP = | \$ | 174,000.00 |
| SUB-TOTAL w/ OH & P = | \$ | 1,044,000.00 |
| CONTINGENCY % = | | 0.30 |
| CONTINGENCY = | \$ | 313,200.00 |
| BUDGET COST ESTIMATE = | \$ | 1,357,200.00 |

1. Material quote based on Sanitaire's standard PVC and 304SS components.
2. Labor cost is based on contractor's bids for similar installations. The labor cost is a lump sum for all work, including electrical, instrumentation, start up and testing of the system.

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Raritan Plaza 1, Raritan Center
 Edison, New Jersey 08818
 Phone (732) 225-7000
 Fax (732) 225-7851

Location: MCJM

ITEM Option 1: VFDs on Existing Aerators

Estimate by: Christie Arlotta

Checked by:

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|-------------------|-----|------|--------------------|-------------------|-----|------|------------|----------------|---------------|
| 1 | VFDs | 2 | ea. | \$ 81,500.00 | \$ 163,000.00 | 32 | hrs | \$ 70.00 | \$ 2,240.00 | \$ 165,240.00 |
| 2 | DO Control System | 1 | ea. | \$ 10,000.00 | \$ 10,000.00 | 40 | hrs | \$ 70.00 | \$ 2,800.00 | \$ 12,800.00 |
| 3 | Electrical Work | 2 | l.s. | \$ 10,000.00 | \$ 20,000.00 | 120 | hrs | \$ 70.00 | \$ 8,400.00 | \$ 28,400.00 |
| 4 | System Testing | 1 | l.s. | \$ 5,000.00 | \$ 5,000.00 | 32 | hrs | \$ 70.00 | \$ 2,240.00 | \$ 7,240.00 |
| 5 | Motors | 2 | ea. | \$ 15,000.00 | \$ 30,000.00 | 32 | hrs | \$ 70.00 | \$ 2,240.00 | \$ 32,240.00 |
| | | | | | \$ - | | | | \$ - | \$ - |
| | | | | | \$ - | | | | \$ - | \$ - |
| | Subtotal | | | | 228,000.00 | | | | 17,920.00 | |

SUBTOTAL = \$ 245,920.00

MARKUP % = \$ 0.20

MARKUP = \$ 49,184.00

SUB-TOTAL w/ OH & P = \$ 295,104.00

CONTINGENCY % = 0.30

CONTINGENCY = \$ 88,531.20

BUDGET COST ESTIMATE = \$ 383,635.20

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Raritan Plaza 1, Raritan Center
 Edison, New Jersey 08818
 Phone (732) 225-7000
 Fax (732) 225-7851

Location: MCJM
ITEM Option 2: New Aerators with VFDs
 Estimate by: Christie Arlotta
 Checked by:

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|-------------------|-----|------|--------------------|-------------------|-----|------|------------|----------------|---------------|
| 1 | Aerators | 2 | ea. | \$ 93,000.00 | \$ 186,000.00 | 32 | hrs | \$ 70.00 | \$ 2,240.00 | \$ 188,240.00 |
| 2 | VFDs | 2 | ea. | \$ 81,500.00 | \$ 163,000.00 | 40 | hrs | \$ 70.00 | \$ 2,800.00 | \$ 165,800.00 |
| 3 | DO Control System | 1 | ea. | \$ 10,000.00 | \$ 10,000.00 | 32 | hrs | \$ 70.00 | \$ 2,240.00 | \$ 12,240.00 |
| 4 | Electrical Work | 2 | l.s. | \$ 10,000.00 | \$ 20,000.00 | 160 | hrs | \$ 70.00 | \$ 11,200.00 | \$ 31,200.00 |
| 5 | System Testing | 1 | l.s. | \$ 5,000.00 | \$ 5,000.00 | 32 | hrs | \$ 70.00 | \$ 2,240.00 | \$ 7,240.00 |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | Subtotal | | | | 384,000.00 | | | | 20,720.00 | |

SUBTOTAL = \$ 404,720.00
 MARKUP % = \$ 0.20
 MARKUP = \$ 80,944.00
SUB-TOTAL w/ OH & P = \$ 485,664.00
 CONTINGENCY % = 0.30
 CONTINGENCY = \$ 145,699.20
BUDGET COST ESTIMATE = \$ 631,363.20

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Raritan Plaza 1, Raritan Center
 Edison, New Jersey 08818
 Phone (732) 225-7000
 Fax (732) 225-7851

Location: MCJM
ITEM Option 1: New Motors, VFDs & DO Controls
 Estimate by: Christie Arlotta
 Checked by:

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---------------------------|-----|------|--------------------|-------------------|-----|------|------------|----------------|--------------|
| 1 | VFDs | 4 | ea. | \$ 1,525.00 | \$ 6,100.00 | 45 | hrs | \$ 70.00 | \$ 3,150.00 | \$ 9,250.00 |
| 2 | Premium Efficiency Motors | 4 | ea. | \$ 620.00 | \$ 2,480.00 | 8 | hrs | \$ 70.00 | \$ 560.00 | \$ 3,040.00 |
| 3 | DO Control System | 1 | ea. | \$ 50,000.00 | \$ 50,000.00 | 120 | hrs | \$ 70.00 | \$ 8,400.00 | \$ 58,400.00 |
| 4 | Electrical Work | 4 | l.s. | \$ 5,000.00 | \$ 20,000.00 | 120 | hrs | \$ 70.00 | \$ 8,400.00 | \$ 28,400.00 |
| 5 | System Testing | 1 | l.s. | \$ 3,000.00 | \$ 3,000.00 | 16 | hrs | \$ 70.00 | \$ 1,120.00 | \$ 4,120.00 |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | Subtotal | | | | 81,580.00 | | | | 21,630.00 | |

SUBTOTAL = \$ 103,210.00
 MARKUP % = \$ 0.20
 MARKUP = \$ 20,642.00
 SUB-TOTAL w/ OH & P = \$ 123,852.00
 CONTINGENCY % = 0.30
 CONTINGENCY = \$ 37,155.60
 BUDGET COST ESTIMATE = \$ 161,007.60

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Raritan Plaza 1, Raritan Center
 Edison, New Jersey 08818
 Phone (732) 225-7000
 Fax (732) 225-7851

Location: MCJM
ITEM Option 2: New Aerators
 Estimate by: Christie Arlotta
 Checked by:

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|-------------------|-----|------|--------------------|-------------------|-----|------|------------|----------------|--------------|
| 1 | Aerators | 4 | ea. | \$ 10,000.00 | \$ 40,000.00 | 0 | hrs | \$ 70.00 | \$ - | \$ 40,000.00 |
| 2 | VFDs | 0 | ea. | \$ 1,525.00 | \$ - | 0 | hrs | \$ 70.00 | \$ - | \$ - |
| 3 | DO Control System | 0 | ea. | \$ 10,000.00 | \$ - | 0 | hrs | \$ 70.00 | \$ - | \$ - |
| 4 | Electrical Work | 4 | l.s. | \$ 5,000.00 | \$ 20,000.00 | 120 | hrs | \$ 70.00 | \$ 8,400.00 | \$ 28,400.00 |
| 5 | System Testing | 1 | l.s. | \$ 3,000.00 | \$ 3,000.00 | 16 | hrs | \$ 70.00 | \$ 1,120.00 | \$ 4,120.00 |
| | | | | \$ - | \$ - | | | | \$ - | \$ - |
| | | | | \$ - | \$ - | | | | \$ - | \$ - |
| | | | | \$ - | \$ - | | | | \$ - | \$ - |
| | Subtotal | | | | 63,000.00 | | | | 9,520.00 | |

SUBTOTAL = \$ 72,520.00
 MARKUP % = \$ 0.20
 MARKUP = \$ 14,504.00
SUB-TOTAL w/ OH & P = \$ 87,024.00
 CONTINGENCY % = 0.30
 CONTINGENCY = \$ 26,107.20
BUDGET COST ESTIMATE = \$ 113,131.20

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Raritan Plaza 1, Raritan Center
 Edison, New Jersey 08818
 Phone (732) 225-7000
 Fax (732) 225-7851

Location: MCJM
ITEM Option 3: New Aerators, VFDs & DO Control
 Estimate by: Christie Arlotta
 Checked by:

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|-------------------|-----|------|--------------------|-------------------|-----|------|------------|----------------|---------------|
| 1 | Aerators | 4 | ea. | \$ 10,000.00 | \$ 40,000.00 | 64 | hrs | \$ 70.00 | \$ 4,480.00 | \$ 44,480.00 |
| 2 | VFDs | 4 | ea. | \$ 1,525.00 | \$ 6,100.00 | 45 | hrs | \$ 70.00 | \$ 3,150.00 | \$ 9,250.00 |
| 3 | DO Control System | 1 | ea. | \$ 100,000.00 | \$ 100,000.00 | 16 | hrs | \$ 70.00 | \$ 1,120.00 | \$ 101,120.00 |
| 4 | Electrical Work | 4 | l.s. | \$ 5,000.00 | \$ 20,000.00 | 160 | hrs | \$ 70.00 | \$ 11,200.00 | \$ 31,200.00 |
| 5 | System Testing | 1 | l.s. | \$ 6,000.00 | \$ 6,000.00 | 16 | hrs | \$ 70.00 | \$ 1,120.00 | \$ 7,120.00 |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | Subtotal | | | | 172,100.00 | | | | 21,070.00 | |

SUBTOTAL = \$ 193,170.00
 MARKUP % = \$ 0.20
 MARKUP = \$ 38,634.00
SUB-TOTAL w/ OH & P = \$ 231,804.00
 CONTINGENCY % = 0.30
 CONTINGENCY = \$ 69,541.20
BUDGET COST ESTIMATE = \$ 301,345.20

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Raritan Plaza 1, Raritan Center
 Edison, New Jersey 08818
 Phone (732) 225-7000
 Fax (732) 225-7851

Location: MCJM

ITEM Option 4: New Solar Aerators & DO Control

Estimate by: Christie Arlotta

Checked by:

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|--------------------|-------------------|-----|------|------------|----------------|---------------|
| 1 | Solar Aerators | 2 | ea. | \$ 40,000.00 | \$ 80,000.00 | 32 | hrs | \$ 70.00 | \$ 2,240.00 | \$ 82,240.00 |
| 2 | New Motors & VFDs - only on 2 existing machines | 2 | ea. | \$ 2,145.00 | \$ 4,290.00 | 24 | hrs | \$ 70.00 | \$ 1,680.00 | \$ 5,970.00 |
| 3 | DO Control System | 1 | ea. | \$ 100,000.00 | \$ 100,000.00 | 16 | hrs | \$ 70.00 | \$ 1,120.00 | \$ 101,120.00 |
| 4 | Electrical Work | 4 | l.s. | \$ 5,000.00 | \$ 20,000.00 | 160 | hrs | \$ 70.00 | \$ 11,200.00 | \$ 31,200.00 |
| 5 | System Testing | 1 | l.s. | \$ 6,000.00 | \$ 6,000.00 | 16 | hrs | \$ 70.00 | \$ 1,120.00 | \$ 7,120.00 |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | | | | \$ - | \$ - | | | \$ - | \$ - | \$ - |
| | Subtotal | | | | 210,290.00 | | | | 17,360.00 | |

SUBTOTAL = \$ 227,650.00

MARKUP % = \$ 0.20

MARKUP = \$ 45,530.00

SUB-TOTAL w/ OH & P = \$ 273,180.00

CONTINGENCY % = 0.30

CONTINGENCY = \$ 81,954.00

BUDGET COST ESTIMATE = \$ 355,134.00

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

100 Crossways Park West, Suite 415
 Woodbury, NY 11797
 Phone (516) 496-8400
 Fax (516) 4968864

Location: MCJM

ITEM **Option 1: Current Operation of Digestion System plus TWAS Addition**

Estimate by: MM

Checked by: MH

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|--------------------|-------------------|-----|------|-------------|----------------|--------------|
| 1 | Inspection of Existing Digester Piping System | 1 | ls | \$ 5,000.00 | \$ 5,000.00 | 1 | ls | \$ 5,000.00 | \$ 5,000.00 | \$ 10,000.00 |
| | Subtotal | | | | 5,000.00 | | | | 5,000.00 | |

| | | |
|------------------------|----|-----------|
| SUBTOTAL = | \$ | 10,000.00 |
| OH&P 20 % = | \$ | 0.20 |
| MARKUP = | \$ | 2,000.00 |
| SUB-TOTAL w/ OH & P = | \$ | 12,000.00 |
| CONTINGENCY % = | | 0.30 |
| CONTINGENCY = | \$ | 3,600.00 |
| BUDGET COST ESTIMATE = | \$ | 15,600.00 |

CDM

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

100 Crossways Park West, Suite 415
 Woodbury, NY 11797
 Phone (516) 496-8400
 Fax (516) 4968864

Location: MCJM
ITEM Option 2: Current Operation of Digestion System, plus TWA& and FOG Addition
 Estimate by: MM
 Checked by: MH

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|--------------------|-------------------|-----|------|--------------|----------------|--------------|
| 1 | 10,000 gallon fiberglass aboveground storage tank | 1 | ea. | \$ 38,900.00 | \$ 38,900.00 | 1 | ea. | \$ 13,300.00 | \$ 13,300.00 | \$ 52,200.00 |
| 2 | Chopper Pump | 1 | ea. | \$ 10,000.00 | \$ 10,000.00 | 1 | ea. | \$ 1,000.00 | \$ 1,000.00 | \$ 11,000.00 |
| 3 | Hot Water Circulating Pump | 1 | ea. | \$1,000 | \$ 1,000.00 | 1 | ea. | \$500 | \$ 500.00 | \$ 1,500.00 |
| 4 | Progressive Cavity Pump | 1 | ea. | \$ 15,000.00 | \$ 15,000.00 | 1 | ea. | \$ 1,000.00 | \$ 1,000.00 | \$ 16,000.00 |
| 5 | Inline Grinder | 1 | ea. | \$ 20,000.00 | \$ 20,000.00 | 1 | ea. | \$ 2,500.00 | \$ 2,500.00 | \$ 22,500.00 |
| 6 | Heating coils for storage tank | 1 | ls. | \$ 10,000.00 | \$ 10,000.00 | 1 | ea. | \$ 4,000.00 | \$ 4,000.00 | \$ 14,000.00 |
| 7 | Electrical upgrade | 1 | ls. | \$ 50,000.00 | \$ 50,000.00 | - | - | - | - | - |
| 8 | Civil Site Work (pavement, curbing) | 1 | ls. | \$ 10,000.00 | \$ 10,000.00 | - | - | - | - | - |
| 9 | Structural - Concrete Pads | 1 | ls. | \$ 5,000.00 | \$ 5,000.00 | - | - | - | - | - |
| 10 | Plant Water Upgrades | 1 | ls. | \$ 15,000.00 | \$ 15,000.00 | - | - | - | - | - |
| 11 | Piping (Sch 40 PVC) | 300 | lf | \$ 55.00 | \$ 16,500.00 | 300 | lf | \$ 43.00 | \$ 12,900.00 | \$ 29,400.00 |
| 12 | Fittings | 1 | ls. | \$ 1,000.00 | \$ 1,000.00 | - | - | - | - | - |
| 13 | Heat trace and insulate | 300 | lf | \$ 4.50 | \$ 1,350.00 | 300 | lf | \$ 15.50 | \$ 4,650.00 | \$ 6,000.00 |
| 14 | Misc Eqpt (crane, etc) | 1 | ls. | \$ 10,000.00 | \$ 10,000.00 | - | - | - | - | - |
| 15 | FOG System Controls | 1 | ls | \$10,000 | \$ 10,000.00 | - | - | - | - | \$ 10,000.00 |
| 16 | Modification to Existing Digester Piping System | 1 | ls | \$60,000 | \$ 60,000.00 | 1 | ls | \$30,000 | \$30,000 | \$ 90,000.00 |
| 17 | Start up and testing | 1 | ls. | \$ 10,000.00 | \$ 10,000.00 | - | - | - | - | - |
| 18 | Inspection of Existing Digester Piping System | 1 | ls | \$ 5,000.00 | \$ 5,000.00 | 1 | ls | \$ 5,000.00 | \$ 5,000.00 | \$ 10,000.00 |
| | Subtotal | | | | 288,750.00 | | | | 69,850.00 | |

| | | |
|----------------------------------|-----------|-------------------|
| SUBTOTAL = | \$ | 262,600.00 |
| OH&P 20 % = | \$ | 0.20 |
| MARKUP = | \$ | 52,520.00 |
| SUB-TOTAL w/ OH & P = | \$ | 315,120.00 |
| CONTINGENCY % = | | 0.30 |
| CONTINGENCY = | \$ | 94,536.00 |
| BUDGET COST ESTIMATE = | \$ | 409,656.00 |

1. RS Means 2010 was utilized, for material and labor costs associated with FOG system.

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Location: Madison-Chatham
 Estimate by: MJR
 Checked by: MG

| ITEM | DESCRIPTION | QTY | UNIT | *MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | *LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|------------------------|----------------------|-----|------|----------------|-------------------|--------------|
| 1 | Blower Building Boiler, Gas-Fired, Steam, 243 MBH output | 1 | ea. | \$ 8,293.00 | \$ 8,293.00 | 1 | ea. | \$ 2,191.00 | \$ 2,191.00 | \$ 10,484.00 |
| | Subtotal | | | | 8,293.00 | | | | 2,191.00 | |

*Pricing per RS Means 2010

| | | |
|------------------------|----|-----------|
| SUBTOTAL = | \$ | 10,484.00 |
| MARKUP % = | \$ | 0.15 |
| MARKUP = | \$ | 1,572.60 |
| SUB-TOTAL w/ OH & P = | \$ | 12,056.60 |
| CONTINGENCY % = | | 0.25 |
| CONTINGENCY = | \$ | 3,014.15 |
| BUDGET COST ESTIMATE = | \$ | 15,070.75 |

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Location: Madison-Chatham
 Estimate by: MJR
 Checked by: MG

| ITEM | DESCRIPTION | QTY | UNIT | *MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | **LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|------------------------|----------------------|-----|------|-----------------|-------------------|-----------|
| | Blower Building | | | | | | | | | |
| 1 | 1" Thick Pipe Insulation, 850F Mineral Fiber for 1.5" Pipe with All Service Jacket | 1 | ea. | \$ 196.50 | \$ 196.50 | 1 | ea. | \$ 468.00 | \$ 468.00 | \$ 664.50 |
| | Subtotal | | | | 196.50 | | | | 468.00 | |

*Pricing per RS Means 2010

| | | |
|------------------------|----|--------|
| SUBTOTAL = | \$ | 664.50 |
| MARKUP % = | \$ | 0.15 |
| MARKUP = | \$ | 99.68 |
| SUB-TOTAL w/ OH & P = | \$ | 764.18 |
| CONTINGENCY % = | | 0.25 |
| CONTINGENCY = | \$ | 191.04 |
| BUDGET COST ESTIMATE = | \$ | 955.22 |

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|--------------|
| 1 | Administration Building Lighting Upgrades - Interior | 1 | ls. | | \$ 6,774.00 | 1 | ls. | \$ 4,141.00 | \$ 4,141.00 | \$ 10,915.00 |
| | Subtotal | | | | 6,774.00 | | | | 4,141.00 | |

SUBTOTAL = \$ 10,915.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,637.25
 SUB-TOTAL w/ OH & P = \$ 12,552.25
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 3,138.06
 BUDGET COST ESTIMATE = \$ 15,690.31

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Grit Building Lighting Upgrades - Interior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Digester #1 Building Lighting Upgrades - Interior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Digester #2 Building Lighting Upgrades - Interior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|----------|
| 1 | Waste Oil Building Lighting Upgrades - Interior | 1 | ls. | | \$ 7.00 | 1 | ls. | \$ 20.00 | \$ 20.00 | \$ 27.00 |
| | Subtotal | | | | 7.00 | | | | 20.00 | |

SUBTOTAL = \$ 27.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 4.05
 SUB-TOTAL w/ OH & P = \$ 31.05
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 7.76
 BUDGET COST ESTIMATE = \$ 38.81

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Blower Building Lighting Upgrades - Interior | 1 | ls. | | \$ 655.20 | 1 | ls. | \$ 485.00 | \$ 485.00 | \$ 1,140.20 |
| | Subtotal | | | | 655.20 | | | | 485.00 | |

SUBTOTAL = \$ 1,140.20
 MARKUP % = \$ 0.15
 MARKUP = \$ 171.03
 SUB-TOTAL w/ OH & P = \$ 1,311.23
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 327.81
 BUDGET COST ESTIMATE = \$ 1,639.04

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Sludge Handling Building Lighting Upgrades - Interior | 1 | ls. | | \$ 3,967.50 | 1 | ls. | \$ 3,085.00 | \$ 3,085.00 | \$ 7,052.50 |
| | Subtotal | | | | 3,967.50 | | | | 3,085.00 | |

SUBTOTAL = \$ 7,052.50
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,057.88
 SUB-TOTAL w/ OH & P = \$ 8,110.38
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 2,027.59
 BUDGET COST ESTIMATE = \$ 10,137.97

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-----------|
| 1 | Clarifier #1 & #2 Building Lighting Upgrades - Interior | 1 | ls. | | \$ 340.20 | 1 | ls. | \$ 186.00 | \$ 186.00 | \$ 526.20 |
| | Subtotal | | | | 340.20 | | | | 186.00 | |

SUBTOTAL = \$ 526.20
 MARKUP % = \$ 0.15
 MARKUP = \$ 78.93
 SUB-TOTAL w/ OH & P = \$ 605.13
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 151.28
 BUDGET COST ESTIMATE = \$ 756.41

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Clarifier #3 & #4 Building Lighting Upgrades - Interior | 1 | ls. | | \$ 1,193.00 | 1 | ls. | \$ 1,034.00 | \$ 1,034.00 | \$ 2,227.00 |
| | Subtotal | | | | 1,193.00 | | | | 1,034.00 | |

SUBTOTAL = \$ 2,227.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 334.05
 SUB-TOTAL w/ OH & P = \$ 2,561.05
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 640.26
 BUDGET COST ESTIMATE = \$ 3,201.31

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|----------|
| 1 | Administration Building Lighting Upgrades - Exterior | 1 | ls. | | \$ 21.00 | 1 | ls. | \$ 60.00 | \$ 60.00 | \$ 81.00 |
| | Subtotal | | | | 21.00 | | | | 60.00 | |

SUBTOTAL = \$ 81.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 12.15
 SUB-TOTAL w/ OH & P = \$ 93.15
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 23.29
 BUDGET COST ESTIMATE = \$ 116.44

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Grit Building Lighting Upgrades - Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Digester #1 Building Lighting Upgrades - Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|--------------------|-------------------|-----|------|------------|----------------|-------|
| 1 | Digester #2 Building Lighting Upgrades - Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|--------------------|-------------------|-----|------|------------|----------------|----------|
| 1 | Waste Oil Building Lighting Upgrades - Exterior | 1 | ls. | | \$ 7.00 | 1 | ls. | \$ 20.00 | \$ 20.00 | \$ 27.00 |
| | Subtotal | | | | 7.00 | | | | 20.00 | |

SUBTOTAL = \$ 27.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 4.05
 SUB-TOTAL w/ OH & P = \$ 31.05
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 7.76
 BUDGET COST ESTIMATE = \$ 38.81

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|--------------------|-------------------|-----|------|------------|----------------|-------|
| 1 | Blower Building Lighting Upgrades - Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|--------------------|-------------------|-----|------|------------|----------------|-------------|
| 1 | Sludge Handling Building Lighting Upgrades - Exterior | 1 | ls. | | \$ 1,520.00 | 1 | ls. | \$ 548.00 | \$ 548.00 | \$ 2,068.00 |
| | Subtotal | | | | 1,520.00 | | | | 548.00 | |

SUBTOTAL = \$ 2,068.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 310.20
 SUB-TOTAL w/ OH & P = \$ 2,378.20
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 594.55
 BUDGET COST ESTIMATE = \$ 2,972.75

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|--------------------|-------------------|-----|------|------------|----------------|-------|
| 1 | Clarifier Building #1 & #2 Lighting Upgrades - Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|--------------------|-------------------|-----|------|------------|----------------|-------------|
| 1 | Clarifier Building #3 & #4 Lighting Upgrades - Exterior | 1 | ls. | | \$ 760.00 | 1 | ls. | \$ 274.00 | \$ 274.00 | \$ 1,034.00 |
| | Subtotal | | | | 760.00 | | | | 274.00 | |

SUBTOTAL = \$ 1,034.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 155.10
 SUB-TOTAL w/ OH & P = \$ 1,189.10
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 297.28
 BUDGET COST ESTIMATE = \$ 1,486.38

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|--------------|
| 1 | Roadway & Process Lighting Lighting Upgrades - Exterior | 1 | ls. | | \$ 9,880.00 | 1 | ls. | \$ 1,781.00 | \$ 1,781.00 | \$ 11,661.00 |
| | Subtotal | | | | 9,880.00 | | | | 1,781.00 | |

SUBTOTAL = \$ 11,661.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,749.15
 SUB-TOTAL w/ OH & P = \$ 13,410.15
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 3,352.54
 BUDGET COST ESTIMATE = \$ 16,762.69

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|--------------|
| 1 | Administration Building Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ 6,795.00 | 1 | ls. | \$ 4,201.00 | \$ 4,201.00 | \$ 10,996.00 |
| | Subtotal | | | | 6,795.00 | | | | 4,201.00 | |

SUBTOTAL = \$ 10,996.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,649.40
 SUB-TOTAL w/ OH & P = \$ 12,645.40
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 3,161.35
 BUDGET COST ESTIMATE = \$ 15,806.75

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Grit Building Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Digester #1 Building Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------|
| 1 | Digester #2 Building Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ - | 1 | ls. | \$ - | \$ - | \$ - |
| | Subtotal | | | | 0.00 | | | | 0.00 | |

SUBTOTAL = \$ -
 MARKUP % = \$ 0.15
 MARKUP = \$ -
 SUB-TOTAL w/ OH & P = \$ -
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ -
 BUDGET COST ESTIMATE = \$ -

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|----------|
| 1 | Waste Oil Building Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ 14.00 | 1 | ls. | \$ 40.00 | \$ 40.00 | \$ 54.00 |
| | Subtotal | | | | 14.00 | | | | 40.00 | |

SUBTOTAL = \$ 54.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 8.10
 SUB-TOTAL w/ OH & P = \$ 62.10
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 15.53
 BUDGET COST ESTIMATE = \$ 77.63

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|--|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Blower Building Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ 655.20 | 1 | ls. | \$ 485.00 | \$ 485.00 | \$ 1,140.20 |
| | Subtotal | | | | 655.20 | | | | 485.00 | |

SUBTOTAL = \$ 1,140.20
 MARKUP % = \$ 0.15
 MARKUP = \$ 171.03
 SUB-TOTAL w/ OH & P = \$ 1,311.23
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 327.81
 BUDGET COST ESTIMATE = \$ 1,639.04

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Sludge Handling Building Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ 5,487.50 | 1 | ls. | \$ 3,633.00 | \$ 3,633.00 | \$ 9,120.50 |
| | Subtotal | | | | 5,487.50 | | | | 3,633.00 | |

SUBTOTAL = \$ 9,120.50
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,368.08
 SUB-TOTAL w/ OH & P = \$ 10,488.58
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 2,622.14
 BUDGET COST ESTIMATE = \$ 13,110.72

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-----------|
| 1 | Clarifier Building #1 & #2 Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ 340.20 | 1 | ls. | \$ 186.00 | \$ 186.00 | \$ 526.20 |
| | Subtotal | | | | 340.20 | | | | 186.00 | |

SUBTOTAL = \$ 526.20
 MARKUP % = \$ 0.15
 MARKUP = \$ 78.93
 SUB-TOTAL w/ OH & P = \$ 605.13
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 151.28
 BUDGET COST ESTIMATE = \$ 756.41

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Clarifier Building #3 & #4 Lighting Upgrades - Interior & Exterior | 1 | ls. | | \$ 1,953.00 | 1 | ls. | \$ 1,308.00 | \$ 1,308.00 | \$ 3,261.00 |
| | Subtotal | | | | 1,953.00 | | | | 1,308.00 | |

SUBTOTAL = \$ 3,261.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 489.15
 SUB-TOTAL w/ OH & P = \$ 3,750.15
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 937.54
 BUDGET COST ESTIMATE = \$ 4,687.69

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: AJF
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Administration Building Motor Upgrades | 1 | ls. | | \$ 5,160.00 | 1 | ls. | \$ 875.00 | \$ 875.00 | \$ 6,035.00 |
| | Subtotal | | | | 5,160.00 | | | | 875.00 | |

SUBTOTAL = \$ 6,035.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 905.25
 SUB-TOTAL w/ OH & P = \$ 6,940.25
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 1,735.06
 BUDGET COST ESTIMATE = \$ 8,675.31

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|-----------------------------------|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-----------|
| 1 | Blower Building Motor Upgrades | 1 | ls. | | \$ 405.00 | 1 | ls. | \$ 115.00 | \$ 115.00 | \$ 520.00 |
| | Subtotal | | | | 405.00 | | | | 115.00 | |

SUBTOTAL = \$ 520.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 78.00
 SUB-TOTAL w/ OH & P = \$ 598.00
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 149.50
 BUDGET COST ESTIMATE = \$ 747.50

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: AJF
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---------------------------------|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Sludge Handling Building | | | | | | | | | |
| | Motor Upgrades | 1 | ls. | | \$ 7,720.00 | 1 | ls. | \$ 1,804.00 | \$ 1,804.00 | \$ 9,524.00 |
| | Subtotal | | | | 7,720.00 | | | | 1,804.00 | |

SUBTOTAL = \$ 9,524.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,428.60
 SUB-TOTAL w/ OH & P = \$ 10,952.60
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 2,738.15
 BUDGET COST ESTIMATE = \$ 13,690.75

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| 1 | Final Clarifier #1 & #2 Building | | | | | | | | | |
| | Motor Upgrades | 1 | ls. | | \$ 1,240.00 | 1 | ls. | \$ 258.00 | \$ 258.00 | \$ 1,498.00 |
| 2 | VFD Upgrades | 1 | ls. | | \$ 3,050.00 | 1 | ls. | \$ 1,550.00 | \$ 1,550.00 | \$ 4,600.00 |
| | Subtotal | | | | 4,290.00 | | | | 1,808.00 | |

SUBTOTAL = \$ 6,098.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 914.70
 SUB-TOTAL w/ OH & P = \$ 7,012.70
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 1,753.18
 BUDGET COST ESTIMATE = \$ 8,765.88

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: AJF
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| | Final Clarifier #3 & #4 Building | | | | | | | | | |
| 1 | Motor Upgrades | 1 | ls. | | \$ 2,340.00 | 1 | ls. | \$ 602.00 | \$ 602.00 | \$ 2,942.00 |
| 2 | VFD Upgrades | 1 | ls. | | \$ 6,050.00 | 1 | ls. | \$ 3,615.00 | \$ 3,615.00 | \$ 9,665.00 |
| | Subtotal | | | | 8,390.00 | | | | 4,217.00 | |

SUBTOTAL = \$ 12,607.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,891.05
 SUB-TOTAL w/ OH & P = \$ 14,498.05
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 3,624.51
 BUDGET COST ESTIMATE = \$ 18,122.56

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|------------------------|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|-------------|
| | Outdoor Process | | | | | | | | | |
| 1 | Motor Upgrades | 1 | ls. | | \$ 3,800.00 | 1 | ls. | \$ 870.00 | \$ 870.00 | \$ 4,670.00 |
| 2 | VFD Upgrades | 1 | ls. | | \$ 3,050.00 | 1 | ls. | \$ 1,550.00 | \$ 1,550.00 | \$ 4,600.00 |
| | Subtotal | | | | 6,850.00 | | | | 2,420.00 | |

SUBTOTAL = \$ 9,270.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 1,390.50
 SUB-TOTAL w/ OH & P = \$ 10,660.50
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 2,665.13
 BUDGET COST ESTIMATE = \$ 13,325.63

CDM

11 British American Blvd
 Latham, NY 12110
 Phone (518) 782-4500
 Fax (518) 786-3810

ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Molitor Water Pollution Control Facility
 Estimate by: PS
 Checked by: JTM

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|-----------------|-------------------|------------------|
| 1 | Molitor Water Pollution Control Facility Solar PV Array System | 1 | ls. | | \$ 8,539,254.00 | 1 | ls. | \$ 3,659,680.00 | \$ 3,659,680.00 | \$ 12,198,934.00 |
| | Subtotal | | | | 8,539,254.00 | | | | 3,659,680.00 | |

SUBTOTAL = \$ 12,198,934.00
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 3,049,733.50
 BUDGET COST ESTIMATE = \$ 15,248,667.50

| ITEM | DESCRIPTION | QTY | UNIT | MATERIAL UNIT COST | MATERIAL SUBTOTAL | QTY | UNIT | LABOR COST | LABOR SUBTOTAL | TOTAL |
|------|---|-----|------|-----------------------|----------------------|-----|------|---------------|-------------------|--------------|
| 1 | Molitor Water Pollution Control Facility 10KW Wind Turbine | 1 | ls. | | \$ 43,645.00 | 1 | ls. | \$ 4,000.00 | \$ 4,000.00 | \$ 47,645.00 |
| | Subtotal | | | | 43,645.00 | | | | 4,000.00 | |

SUBTOTAL = \$ 47,645.00
 MARKUP % = \$ 0.15
 MARKUP = \$ 7,146.75
 SUB-TOTAL w/ OH & P = \$ 54,791.75
 CONTINGENCY % = 0.25
 CONTINGENCY = \$ 13,697.94
 BUDGET COST ESTIMATE = \$ 68,489.69

APPENDIX H

NJ SMARTSTART INCENTIVES INFORMATION AND WORKSHEETS



2010 Prescriptive Lighting Application

Customer Information

| | | | | | | | |
|---|--|------------------------------------|--|--|--|-------------------|-----|
| Company | | Electric Utility Serving Applicant | | Electric Account No. | | Installation Date | |
| Facility Address | | | | City | | State | Zip |
| Type of Project <input type="checkbox"/> New Construction <input type="checkbox"/> Renovation <input type="checkbox"/> Equipment Replacement | | | | | | Size of Building | |
| Company Mailing Address | | | | City | | State | Zip |
| Contact Person (Name/Title) | | | | Telephone No. () | | Fax No. () | |
| Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Exempt | | | | Federal Tax ID# or SSN | | Email Address | |
| Incentive Payment to <input type="checkbox"/> Customer <input type="checkbox"/> Contractor <input type="checkbox"/> Other | | | | Please assign payment to contractor/vendor/other indicated below Customer Signature | | | |

Payee Information (must submit W-9 form with application)

| | | | | | | | | | | | |
|----------------|--|--|--|------|--|--------------|-----|---------------------------|--|------------------|--|
| Company | | | | | | Contact Name | | Incorporated? Yes No | | Email Address | |
| Street Address | | | | City | | State | Zip | Telephone No. () | | Fax No. () | |
| | | | | | | | | | | | |

Contractor/Vendor Information (if different from Payee)

| | | | | | | | | | | | |
|----------------|--|--|--|------|--|--------------|-----|---|--|------------------|--|
| Company | | | | | | Contact Name | | Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No | | Email Address | |
| Street Address | | | | City | | State | Zip | Telephone No. () | | Fax No. () | |
| | | | | | | | | | | | |

Building Type (circle one)

Education-Primary School; Education-Community College; Education-University; Grocery; Medical-Hospital; Medical-Clinic; Lodging Hotel(Guest Rooms); Lodging Motel; Manufacturing-Light Industrial; Office-Large; Office-Small; Restaurant-Sit Down; Restaurant-Fast Food; Retail-3 Story Large; Retail- Single Story Large; Retail-Small; Storage Conditioned; Storage Unconditioned; Warehouse; Other

Prescriptive Lighting Incentive

\$ _____ Total Incentive (per attached worksheet calculations)

Note: Prescriptive Lighting Worksheet must accompany this application.

Specific Program Requirements* (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. Incentives for T-5 and T-8 lamps with electronic ballasts are available only for fixtures with a Total Harmonic Distortion of $\leq 20\%$.
4. All eligible lighting devices must be UL listed.
5. Requirements for CFL fixtures (must meet all requirements):
 - Fixtures must be new and ENERGY STAR qualified
 - Fixtures must have replaceable electronic ballasts
 - Total Harmonic Distortion (THD) must not exceed 33%
 - Power factor of the ballast must be no less than 90%
 - The manufacturer must warrant all fixtures for a minimum of 3 years. Warranty does not pertain to lamps or photocells not physically part of the fixture.
 - The installer must warrant fixture installation – minimum of 1 yr.
- 5.1 Screw-in PAR 38 or 30 Compact Fluorescent Lamps (CFL) with Aluminum Reflectors replacing existing incandescent fixtures.
 - The lamp must be warranted by the manufacturer for 8,000 hours
 - Total Harmonic Distortion must not exceed 33%
 - Power factor of the ballast must be $\geq 90\%$
6. Pulse Start Metal Halide (including pole-mounted parking lot lighting) must have a 12% minimum wattage reduction.
7. T-5 or T-8 Fixtures replacing incandescent or T-12 fluorescent fixtures greater than 250 watt or High Intensity Discharge shall comply as follows:
 - 7.1 T-5 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.0; have reflectivity greater than or equal to 91%; have a minimum 2 lamps; and be designated as F54T5 HO.
 - 7.2 T-8 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.14; have reflectivity greater than or equal to 91%; have a minimum of 4 lamps; and be designated as F32T8, minimum 32 watts.
 - 7.3 Incentives for delamp T-8 lamps with new reflectors are available only for fixtures with a Total Harmonic Distortion of $\leq 20\%$. Electronic ballast replacement required for all eligible delamp fixtures. Eligible delamping can include reduction in linear lamp feet from existing conditions. For example, 1-8' linear fluorescent lamp can be considered as 2-4' linear lamps. U-bend lamps 4' in total length can be considered as 2-F17/T8 lamps.
 - 7.4 Electronic ballast replacement is necessary for all eligible delamp fixtures.
 - 7.5 Reduced wattage T8 (28W/25W 4') (1-4 lamps) retrofit requires lamp and ballast replacement.
8. LED Refrigerated/Freezer Case Lighting must meet NEEP Design Lights Consortium Standards or be on an ENERGY STAR or a SSL Qualified Product list. For new door installations on existing open cases, indicate the number of LED fixtures to be installed. Also indicate "New Door" in the Fixture Type column on the Prescriptive Lighting Worksheet (ie. New Door 5' LED).

Application Checklist (Before submitting your application, please make sure you have signed in the space below and completed the following items.)

- Payee Information is filled out and a W-9 form of the payee is included
- Manufacturer's specification sheets for proposed technology are included
- A copy (all pages) of a recent month's utility bill is included

ACKNOWLEDGEMENT

| | |
|--------------------------------------|---|
| _____ CUSTOMER'S SIGNATURE | By signing, I certify that I have read, understand and agree to the Specific Program Requirements/Terms and Conditions listed on this application form. I will also submit for approval a properly completed application package, which includes this signed application, worksheet (if applicable), manufacturer's specification sheets and complete utility bill (name and address on utility bill must match name and address on application). |
|--------------------------------------|---|

Prescriptive Lighting Measures and Incentives*

| Type of Fixture | Incentive | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|------------------------|-------------------------------|-------------------------------|-------------------------|-------------------|----------|-------|-------------------------|--------------|----------|-------|-------------------------|--------------|----------|------|----------|--------------|----------|------|----------|--------------|----------|------|----------|------------|----------|------|-----------|--------------|-----------------------|------|-----------|--------------|-----------------------|------|--|
| Recessed and Surface-Mounted Compact Fluorescents (New Fixtures Replacing Incandescent Fixtures Only): <small>Only available for hard-wired, electronically ballasted new fixtures with rare earth phosphor lamps and 4-pin based tubes (including: twin tube, quad tube, triple tube, 2D or circline lamps), THD$\leq 33\%$ and BF> 0.9</small> | \$25 per 1-lamp fixture \$30 per 2-lamp or more fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Screw-in PAR 38 or PAR 30 (CFL) as per 5.1 above | \$7 per lamp replaced | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| High-Efficiency Fluorescent Fixtures: For retrofit of T-12 fixtures to T-5 or T-8 with electronic ballasts | \$15 per fixture (1-4 lamps retrofits) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| For replacement of fixtures with new T-5 or T-8 fixtures | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 25%;">Type of Old Fixture</th> <th style="width: 25%;">Wattage of Old Fixture</th> <th style="width: 25%;">Type of New Fixture</th> <th style="width: 25%;">Incentive Per Fixture Removed</th> </tr> </thead> <tbody> <tr> <td>HID, T-12, Incandescent</td> <td>≥ 1000 Watts</td> <td>T-5, T-8</td> <td>\$284</td> </tr> <tr> <td>HID, T-12, Incandescent</td> <td>400-999 Watt</td> <td>T-5, T-8</td> <td>\$100</td> </tr> <tr> <td>HID, T-12, Incandescent</td> <td>250-399 Watt</td> <td>T-5, T-8</td> <td>\$50</td> </tr> <tr> <td>HID only</td> <td>175-249 Watt</td> <td>T-5, T-8</td> <td>\$45</td> </tr> <tr> <td>HID only</td> <td>100-174 Watt</td> <td>T-5, T-8</td> <td>\$30</td> </tr> <tr> <td>HID only</td> <td>75-99 Watt</td> <td>T-5, T-8</td> <td>\$16</td> </tr> <tr> <td>T-12 only</td> <td>< 250 Watt</td> <td>T-5, T-8 (1 & 2 lamp)</td> <td>\$25</td> </tr> <tr> <td>T-12 only</td> <td>< 250 Watt</td> <td>T-5, T-8 (3 & 4 lamp)</td> <td>\$30</td> </tr> </tbody> </table> | Type of Old Fixture | Wattage of Old Fixture | Type of New Fixture | Incentive Per Fixture Removed | HID, T-12, Incandescent | ≥ 1000 Watts | T-5, T-8 | \$284 | HID, T-12, Incandescent | 400-999 Watt | T-5, T-8 | \$100 | HID, T-12, Incandescent | 250-399 Watt | T-5, T-8 | \$50 | HID only | 175-249 Watt | T-5, T-8 | \$45 | HID only | 100-174 Watt | T-5, T-8 | \$30 | HID only | 75-99 Watt | T-5, T-8 | \$16 | T-12 only | < 250 Watt | T-5, T-8 (1 & 2 lamp) | \$25 | T-12 only | < 250 Watt | T-5, T-8 (3 & 4 lamp) | \$30 | |
| Type of Old Fixture | Wattage of Old Fixture | Type of New Fixture | Incentive Per Fixture Removed | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| HID, T-12, Incandescent | ≥ 1000 Watts | T-5, T-8 | \$284 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| HID, T-12, Incandescent | 400-999 Watt | T-5, T-8 | \$100 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| HID, T-12, Incandescent | 250-399 Watt | T-5, T-8 | \$50 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| HID only | 175-249 Watt | T-5, T-8 | \$45 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| HID only | 100-174 Watt | T-5, T-8 | \$30 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| HID only | 75-99 Watt | T-5, T-8 | \$16 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| T-12 only | < 250 Watt | T-5, T-8 (1 & 2 lamp) | \$25 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| T-12 only | < 250 Watt | T-5, T-8 (3 & 4 lamp) | \$30 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| For retrofit of T-8 fixtures by permanent delamping & new reflectors are available only for fixtures with a total Harmonic Distortion of $\leq 20\%$. Electronic ballast replacement required for all eligible delamp fixtures. | \$20 per fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| New Construction & Complete Renovation | Performance based only | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| LED Exit Signs (new fixtures only): | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| For existing facilities with connected load < 75 kW | \$20 per fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| For existing facilities with connected load ≥ 75 kW | \$10 per fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Pulse Start Metal Halide (for fixtures ≥ 150 watts) | \$25 per fixture (includes parking lot lighting) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Parking lot low bay - LED | \$45 per fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| T-12 to T-8 fixtures by permanent delamping & new reflectors. Electronic ballast replacement is necessary for all eligible delamp fixtures. | \$30 per fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Retrofit of existing 32 watt T-8 system to Reduced Wattage (28W/25W 4') | \$10 per fixture (1-4 lamps) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| LED Refrigerated/Freezer Case Lighting: Incentive for replacement of fluorescent lighting systems in medium or low temperature display cases | \$42 per 5' LED fixture \$65 per 6' LED fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Induction Lighting Fixtures | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Retrofit of HID | \$50 per HID ($\geq 100W$) fixture retrofitted with induction lamp, power coupler and generator. Replacement unit must use 30% less wattage per fixture than existing HID system | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Replacement of HID | \$70 per HID ($\geq 100W$) fixture with a new induction fixture | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.

New Jersey's Clean Energy Program
 c/o TRC Energy Services
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095
 Phone: 866-657-6278 • Fax: 732-855-0422

Visit our web site: NJCleanEnergy.com/ssb



Program Terms and Conditions

Definitions:

Design Incentives – Incentives that may be offered to design professionals by the Program.

Design Services – Services that may be offered to design professionals under the Program.

Energy-Efficient Measures – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

New Jersey Utilities – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Administrator – New Jersey Board of Public Utilities, Office of Clean Energy

Participating Customers – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

Product Installation or Equipment Installation – Installation of the Energy-Efficient Measures.

Market Manager – TRC Energy Services.

Program – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

Program Incentives – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

Program Offer – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

Application and Eligibility Process – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Exceptions for Approval – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

Post Installation Approval – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.

Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not eligible for incentives offered through this program.

Incentive Amount – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

Tax Liability – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

Endorsement – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

Warranties – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

Limitation of Liability – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

Assignment – The Participating Customer may assign Program Incentive payments to a specified vendor.

Participating Customer's Certification – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

Termination – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

Acknowledgement – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.

Specific Program Requirements* (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. Incentives for T-5 and T-8 lamps with electronic ballasts are available only for fixtures with a Total Harmonic Distortion of $\leq 20\%$.
4. All eligible lighting devices must be UL listed.
5. Requirements for CFL fixtures (must meet all requirements):
 - Fixtures must be new and Energy Star qualified
 - Fixtures must have replaceable electronic ballasts
 - Total Harmonic Distortion (THD) must not exceed 33%
 - Power factor of the ballast must be no less than 90%
 - The manufacturer must warrant all fixtures for a minimum of 3 years. Warranty does not pertain to lamps or photocells not physically part of the fixture.
 - The installer must warrant fixture installation – minimum of 1 yr.
- 5.1 Screw-in PAR 38 or 30 Compact Fluorescent Lamps (CFL) with Aluminum Reflectors replacing existing incandescent fixtures.
 - The lamp must be warranted by the manufacturer for 8,000 hours
 - Total Harmonic Distortion must not exceed 33%
 - Power factor of the ballast must be $\geq 90\%$
6. Pulse Start Metal Halide (including pole-mounted parking lot lighting) must have a 12% minimum wattage reduction.
7. T-5 or T-8 Fixtures replacing incandescent or T-12 fluorescent fixtures greater than 250 watt or High Intensity Discharge shall comply as follows:
 - 7.1 T-5 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.0; have reflectivity greater than or equal to 91%; have a minimum 2 lamps; and be designated as F54T5 HO.
 - 7.2 T-8 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.14; have reflectivity greater than or equal to 91%; have a minimum of 4 lamps; and be designated as F32T8, minimum 32 watts.
 - 7.3 Incentives for delamped T-8 lamps with new reflectors are available only for fixtures with a total Harmonic Distortion of $\leq 20\%$. Electronic ballast replacement required for all eligible delamped fixtures. Eligible delamping can include reduction in linear lamp feet from existing conditions. For example, 1-8' linear fluorescent lamp can be considered as 2-4' linear lamps. U-bend lamps 4' in total length can be considered as 2-F17/T8 lamps.
 - 7.4 Electronic ballast replacement is necessary for all eligible delamped fixtures.
 - 7.5 Reduced wattage T8 (28W/25W 4') (1-4 lamps) retrofit requires lamp and ballast replacement.
8. LED Refrigerated/Freezer Case Lighting must meet NEEP Design Lights Consortium Standards or be on an ENERGY STAR or a SSL Qualified Product list. For new door installations on existing open cases, indicate the number of LED fixtures to be installed. Also indicate "New Door" in the Fixture Type column on the Prescriptive Lighting Worksheet (ie. New Door 5' LED).

ACKNOWLEDGEMENT

| | |
|--------------------------------------|---|
| _____ CUSTOMER'S SIGNATURE | By signing, I certify that I have read, understand and agree to the Specific Program Requirements/Terms and Conditions listed on this application form, I will also submit for approval a properly completed application package, which includes this signed application, worksheet (if applicable), manufacturer's specification sheets and complete utility bill (name and address on utility bill must match name and address on application). |
|--------------------------------------|---|

Prescriptive Lighting Measures and Incentives*

| Type of Fixture | | Incentive | |
|--|------------------------|--|-------------------------------|
| Recessed and Surface-Mounted Compact Fluorescents (New Fixtures Replacing Incandescent Fixtures Only): <small>Only available for hard-wired, electronically ballasted new fixtures with rare earth phosphor lamps and 4-pin based tubes (including: twin tube, quad tube, triple tube, 2D or circline lamps), THD$\leq 33\%$ and BF> 0.9</small> | | \$25 per 1-lamp fixture \$30 per 2-lamp or more fixture | |
| Screw-in PAR 38 or PAR 30 (CFL) as per 5.1 above | | \$7 per lamp replaced | |
| High-Efficiency Fluorescent Fixtures: For retrofit of T-12 fixtures to T-5 or T-8 with electronic ballasts | | \$15 per fixture (1-4 lamps retrofits) | |
| For replacement of fixtures with new T-5 or T-8 fixtures | | | |
| Type of Old Fixture | Wattage of Old Fixture | Type of New Fixture | Incentive Per Fixture Removed |
| HID, T-12, Incandescent | ≥ 1000 Watts | T-5, T-8 | \$284 |
| HID, T-12, Incandescent | 400-999 Watt | T-5, T-8 | \$100 |
| HID, T-12, Incandescent | 250-399 Watt | T-5, T-8 | \$50 |
| HID only | 175-249 Watt | T-5, T-8 | \$43 |
| HID only | 100-174 Watt | T-5, T-8 | \$30 |
| HID only | 75-99 Watt | T-5, T-8 | \$16 |
| T-12 only | ≤ 250 Watt | T-5, T-8 (1 & 2 lamp) | \$25 |
| T-12 only | ≤ 250 Watt | T-5, T-8 (3 & 4 lamp) | \$30 |
| For retrofit of T-8 fixtures by permanent delamping & new reflectors are available only for fixtures with a total Harmonic Distortion of $\leq 20\%$. Electronic ballast replacement required for all eligible delamped fixtures. | | \$20 per fixture | |
| New Construction & Complete Renovation | | Performance based only | |
| LED Exit Signs (new fixtures only): For existing facilities with connected load < 75 kW | | \$20 per fixture | |
| For existing facilities with connected load ≥ 75 kW | | \$10 per fixture | |
| Pulse Start Metal Halide (for fixtures ≥ 150 watts) | | \$25 per fixture (includes parking lot lighting) | |
| Parking lot low bay - LED | | \$43 per fixture | |
| T-12 to T-8 fixtures by permanent delamping & new reflectors. Electronic ballast replacement is necessary for all eligible delamped fixtures. | | \$30 per fixture | |
| Retrofit of existing 32 watt T-8 system to Reduced Wattage (28W/25W 4') | | \$10 per fixture (1-4 lamps) | |
| LED Refrigerated/Freezer Case Lighting: Incentive for replacement of fluorescent lighting systems in medium or low temperature display cases | | \$42 per 5' LED Fixture \$65 per 6' LED Fixture | |
| Induction Lighting Fixtures Retrofit of HID | | \$50 per HID ($\geq 100W$) fixture retrofitted with induction lamp, power coupler and generator. Replacement unit must use 50% less wattage per fixture than existing HID system | |
| Replacement of HID | | \$70 per HID ($\geq 100W$) fixture with a new induction fixture | |

Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.

New Jersey's Clean Energy Program
 c/o TRC Energy Services
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095
 Phone: 866-657-6278 • Fax: 732-855-0422

Visit our web site: NJCleanEnergy.com/ssb



Program Terms and Conditions

Definitions:

Design Incentives – Incentives that may be offered to design professionals by the Program.

Design Services – Services that may be offered to design professionals under the Program.

Energy-Efficient Measures – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

New Jersey Utilities – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Administrator – New Jersey Board of Public Utilities, Office of Clean Energy

Participating Customers – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

Product Installation or Equipment Installation – Installation of the Energy-Efficient Measures.

Market Manager – TRC Energy Services.

Program – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

Program Incentives – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

Program Offer – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

Application and Eligibility Process – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Exceptions for Approval – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

Post Installation Approval – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.

Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not eligible for incentives offered through this program.

Incentive Amount – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

Tax Liability – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

Endorsement – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

Warranties – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

Limitation of Liability – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

Assignment – The Participating Customer may assign Program Incentive payments to a specified vendor.

Participating Customer's Certification – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

Termination – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

Acknowledgement – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.



2010 Lighting Controls Application

Customer Information

| | | | |
|---|--|----------------------|-------------------|
| Company | Electric Utility Serving Applicant | Electric Account No. | Installation Date |
| Facility Address | City | State | Zip |
| Type of Project <input type="checkbox"/> New Construction <input type="checkbox"/> Renovation <input type="checkbox"/> Equipment Replacement | Size of Building | | |
| Company Mailing Address | City | State | Zip |
| Contact Person (Name/Title) | Telephone No. () | Fax No. () | |
| Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Exempt | Federal Tax ID# or SSN | Email Address | |
| Incentive Payment to <input type="checkbox"/> Customer <input type="checkbox"/> Contractor <input type="checkbox"/> Other | Please assign payment to contractor/vendor/other indicated below Customer Signature | | |

Payee Information (must submit W-9 form with application)

| | | | | | | | | |
|----------------|--|------|-------|-----|------------------------|------------------|---------------------------|---------------|
| Company | | | | | | Contact Name | Incorporated? Yes No | Email Address |
| Street Address | | City | State | Zip | Telephone No. () | Fax No. () | Federal Tax ID# | |

Contractor/Vendor Information (if different from Payee)

| | | | | | | | | |
|----------------|--|------|-------|-----|------------------------|------------------|---|---------------|
| Company | | | | | | Contact Name | Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No | Email Address |
| Street Address | | City | State | Zip | Telephone No. () | Fax No. () | Federal Tax ID# | |

Building Type (circle one)

Education-Primary School; Education-Community College; Education-University; Grocery; Medical-Hospital; Medical-Clinic; Lodging Hotel(Guest Rooms); Lodging Motel; Manufacturing-Light Industrial; Office-Large; Office-Small; Restaurant-Sit Down; Restaurant-Fast Food; Retail-3 Story Large; Retail- Single Story Large; Retail-Small; Storage Conditioned; Storage Unconditioned; Warehouse; Other

Lighting Control Incentive

\$ _____ Total Incentive (per attached worksheet calculations)

Note: Lighting Controls Incentive Worksheet must accompany this application.

Specific Program Requirements* (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements, including special requirements for lighting controls.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. All lighting controls eligible for incentives must be UL listed.
4. Lighting control incentives are only available for control of eligible energy efficient lighting fixtures.
5. If more than one eligible lighting control device is associated with the same eligible fixture, the incentive paid will be for the lighting control device that yields the largest incentive only.
6. Occupancy Sensor Controls (existing facilities only):
 - There is no incentive available for occupancy sensors installed in a space where they are prohibited by state or local building or safety code. Additionally, no incentive is eligible for occupancy sensors in the following specific spaces in all cases: stairways, restrooms (remote mounted only allowed), elevators, corridors/hallways, lobbies, and closets/storage areas.
 - Incentives will only be paid for eligible occupancy sensors (OSW & OSR) controlling at least 2 eligible lighting fixtures and, for OSR installations, a minimum total connected load of 180 watts.
 - Incentives will only be paid for eligible OSRH occupancy sensors controlling eligible fixtures when the controlled wattage is greater than 180 watts.
 - Occupancy sensors with manual override to the "ON" position are ineligible for incentive.
7. High-Low Controls (OHLF and OHLH):
 - Incentives will not be paid for high-low controls on eligible fluorescent fixtures where daylight dimming controls can be effectively employed.
 - Incentives will not be paid for spaces smaller than 250 square feet.
 - Incentives available only when "low level" is no more than 60% of "high level."
 - Incentives are not available for the following spaces: stairways, elevators, corridors/hallways, or lobbies.
 - OHLF will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
 - OHLH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.
8. Daylight Dimming Controls for eligible fixtures:
 - Incentives will only be paid for eligible daylight dimming controls operating at least 4 eligible ballasts with a minimum total connected load of 240 watts.
 - Dimming shall be continuous or stepped at 4 or more levels.
 - Incentives will be paid only for eligible daylight dimming control systems designed in accordance with IESNA practice as delineated in "RP-5-99, IESNA Recommended Practice of Daylighting."
 - DLD will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
 - DDH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.

Application Checklist (Before submitting your application, please make sure you have signed in the space below and completed the following items.)

- Payee Information is filled out and a W-9 form of the payee is included
- Manufacturer's specification sheets for proposed technology are included
- A copy (all pages) of a recent month's utility bill is included

ACKNOWLEDGEMENT

CUSTOMER'S SIGNATURE

By signing, I certify that I have read, understand and agree to the Specific Program Requirements/Terms and Conditions listed on this application form, I will also submit for approval a properly completed application package, which includes this signed application, worksheet (if applicable), manufacturer's specification sheets and complete utility bill (name and address on utility bill must match name and address on application).

Lighting Control Prescriptive Incentives*

| Control Device Type | Incentive per Unit |
|--|-----------------------------|
| OSW – Occupancy Sensor Wall Mounted (Existing facilities only) | \$20 per control |
| OSR – Occupancy Sensor Remote Mounted (Existing facilities only) | \$35 per control |
| DLD – Fluorescent Daylight Dimming | \$25 per fixture controlled |
| DLD – Fluorescent Daylight Dimming (Office Applications) | \$50 per fixture controlled |
| OHLF – Occupancy Controlled High-Low with Step Ballast | \$25 per fixture controlled |
| OSRH – Occupancy Sensor Remote Mounted | \$35 per control |
| OHLH – Occupancy Controlled High-Low with Step Ballast | \$75 per fixture controlled |
| DDH – Daylight Dimming | \$75 per fixture controlled |

Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.

New Jersey's Clean Energy Program
 c/o TRC Energy Services
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095
 Phone: 866-657-6278 • Fax: 732-855-0422

Visit our web site: www.NJCleanEnergy.com



Program Terms and Conditions

Definitions:

Design Incentives – Incentives that may be offered to design professionals by the Program.

Design Services – Services that may be offered to design professionals under the Program.

Energy-Efficient Measures – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

New Jersey Utilities – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Administrator – New Jersey Board of Public Utilities, Office of Clean Energy

Participating Customers – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

Product Installation or Equipment Installation – Installation of the Energy-Efficient Measures.

Market Manager – TRC Energy Services.

Program – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

Program Incentives – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

Program Offer – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

Application and Eligibility Process – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Exceptions for Approval – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

Post Installation Approval – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.

Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not be eligible for incentives offered through this program.

Incentive Amount – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

Tax Liability – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

Endorsement – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

Warranties – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

Limitation of Liability – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

Assignment – The Participating Customer may assign Program Incentive payments to a specified vendor.

Participating Customer's Certification – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

Termination – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

Acknowledgement – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.

Specific Program Requirements* (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements, including special requirements for lighting controls.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. All lighting controls eligible for incentives must be UL listed.
4. Lighting control incentives are only available for control of eligible energy efficient lighting fixtures.
5. If more than one eligible lighting control device is associated with the same eligible fixture, the incentive paid will be for the lighting control device that yields the largest incentive only.
6. Occupancy Sensor Controls (existing facilities only):
 - There is no incentive available for occupancy sensors installed in a space where they are prohibited by state or local building or safety code. Additionally, no incentive is eligible for occupancy sensors in the following specific spaces in all cases: stairways, restrooms (remote mounted only allowed), elevators, corridors/hallways, lobbies, and closets/storage areas.
 - Incentives will only be paid for eligible occupancy sensors (OSW & OSR) controlling at least 2 eligible lighting fixtures and, for OSR installations, a minimum total connected load of 180 watts.
 - Incentives will only be paid for eligible OSRH occupancy sensors controlling eligible fixtures when the controlled wattage is greater than 180 watts.
 - Occupancy sensors with manual override to the "ON" position are ineligible for incentive.
7. High-Low Controls (OHLF and OHLH):
 - Incentives will not be paid for high-low controls on eligible fluorescent fixtures where daylight dimming controls can be effectively employed.
 - Incentives will not be paid for spaces smaller than 250 square feet.
 - Incentives available only when "low level" is no more than 60% of "high level."
 - Incentives are not available for the following spaces: stairways, elevators, corridors/hallways, or lobbies.
 - OHLF will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
 - OHLH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.
8. Daylight Dimming Controls for Eligible Fixtures:
 - Incentives will only be paid for eligible daylight dimming controls operating at least 4 eligible ballasts with a minimum total connected load of 240 watts.
 - Dimming shall be continuous or stepped at 4 or more levels.
 - Incentives will be paid only for eligible daylight dimming control systems designed in accordance with IESNA practice as delineated in "RP-5-99, IESNA Recommended Practice of Daylighting."
 - DLD will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
 - DDH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.

Lighting Control Prescriptive Incentives*

| Control Device Type | Incentive per Unit |
|--|-----------------------------|
| OSW – Occupancy Sensor Wall Mounted (Existing facilities only) | \$20 per control |
| OSR – Occupancy Sensor Remote Mounted (Existing facilities only) | \$35 per control |
| DLD – Fluorescent Daylight Dimming | \$25 per fixture controlled |
| DLD – Fluorescent Daylight Dimming (Office Applications) | \$50 per fixture controlled |
| OHLF – Occupancy Controlled High-Low with Step Ballast | \$25 per fixture controlled |
| OSRH – Occupancy Sensor Remote Mounted | \$35 per control |
| OHLH – Occupancy Controlled High-Low with Step Ballast | \$75 per fixture controlled |
| DDH – Daylight Dimming | \$75 per fixture controlled |

Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.

New Jersey's Clean Energy Program
 c/o TRC Energy Services
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095
 Phone: 866-657-6278 • Fax: 732-855-0422

Visit our web site: www.NJCleanEnergy.com



Program Terms and Conditions

Definitions:

Design Incentives – Incentives that may be offered to design professionals by the Program.

Design Services – Services that may be offered to design professionals under the Program.

Energy-Efficient Measures – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

New Jersey Utilities – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

Administrator – New Jersey Board of Public Utilities, Office of Clean Energy

Participating Customers – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

Product Installation or Equipment Installation – Installation of the Energy-Efficient Measures.

Market Manager – TRC Energy Services.

Program – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

Program Incentives – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

Program Offer – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

Application and Eligibility Process – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

Exceptions for Approval – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

Post Installation Approval – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.

Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not eligible for incentives offered through this program.

Incentive Amount – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

Tax Liability – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

Endorsement – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

Warranties – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

Limitation of Liability – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

Assignment – The Participating Customer may assign Program Incentive payments to a specified vendor.

Participating Customer's Certification – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

Termination – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

Acknowledgement – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.

New Jersey Clean Energy Program

Technical Worksheet – Solar Electric Equipment Information

Please carefully read all of the following information. With the help of your Installation Contractor, fully complete Sections A through D, as applicable, of the attached Technical Worksheet for Solar Electric Equipment, as well as the New Jersey Clean Energy Program Rebate Application Form.

GENERAL TERMS AND CONDITIONS

Rebates will be processed based on the date the New Jersey Clean Energy Program (NJCEP) approves the Final Application Form, not on the purchase date of the equipment. Program procedures and rebates are subject to change or cancellation without notice.

To qualify for a rebate, Applicant must comply with all Program Eligibility Requirements, Terms and Conditions, and Installation Requirements, and submit a completed Pre-Installation Application Form. For more information about the New Jersey Clean Energy Program, or for assistance in completing applications or forms, please see www.njcleanenergy.com or call 866-NJSMART

INSTALLATION REQUIREMENTS

Equipment installation must meet the following minimum requirements in order to qualify for payment under the provisions of the New Jersey Clean Energy Program; proposed changes to the requirements will be considered, but they must be documented by the Applicant or Installation Contractor and approved by the NJCEP. These requirements are not all-encompassing and are intended only to address certain minimum safety and efficiency standards.

A: Code Requirements

1. The installation must comply with the provisions of the National Electrical Code and all other applicable local, state and federal codes or practices.
2. All required permits must be properly obtained and posted.
3. The NJCEP Inspection must be performed before the local Building Code Enforcement Office. If not, this may delay the processing of the rebate
4. All required inspections must be performed (i.e., Electrical/NEC, Local Building Codes Enforcement Office, etc.). Note: In order to ensure compliance with provisions of the NEC, an inspection by a state-licensed electrical inspector is mandatory.

B: Solar Electric Module Array

1. Modules must be UL Listed and must be properly installed according to manufacturer's instructions.
2. The maximum amount of sunlight available year-round on a daily basis should not be obstructed. All applications must include documentation of the impact from any obstruction on the annual performance of the solar electric array. This analysis can be performed by using the New Jersey Clean Power Estimator on the program website www.njcep.com.
3. In order to qualify for program incentives, the solar electric system must adhere to a minimum design threshold, relative to the estimated system production using PVWATTS:
 - Solar electric array orientations require that the calculated system output must be at least 80% of the default output calculated by PVWatts. Additionally, all individual series strings of modules output must be at least 70% of the default output calculated by PVWatts.
 - For building integrated solar electric systems (i.e., part of the building envelope materials are comprised of solar electric components), the estimated system output must be 40% of the default output estimated by PVWATTS.
4. System wiring must be installed in accordance with the provisions of the NEC.
5. All modules installed in a series string must be installed in the same plane.

C: Inverter and Controls

1. The inverter and controls must be properly installed according to manufacturer's instructions.
2. The inverter must be certified as compliant with the requirements of IEEE 929 for small photovoltaic systems and with UL 1741.
3. The system should be equipped with the following visual indicators and/or controls:
 - On/off switch • Operating mode setting indicator • AC/DC over current protection • Operating status indicator
4. Warning labels must be posted on the control panels and junction boxes indicating that the circuits are energized by an alternate power source independent of utility-provided power.
5. Operating instructions must be posted on or near the system, or on file with facilities operation and maintenance documents.
6. Systems must have monitoring capability that is readily accessible to the owner. This monitor (meter or display) must at minimum display instantaneous and cumulative production. All projects greater than 10kW must have an output meter that meets ANSI C.12 standards

D: Control Panel to Solar Electric Array Wire Runs

1. Areas where wiring passes through ceilings, walls or other areas of the building must be properly restored, booted and sealed.
2. All interconnecting wires must be copper. (Some provisions may be made for aluminum wiring; approval must be received from utility engineering departments prior to acceptance.)
3. Thermal insulation in areas where wiring is installed must be replaced to "as found or better condition." Access doors to these areas must be properly sealed and gasketed.
4. Wiring connections must be properly made, insulated and weather-protected.
5. All wiring must be attached to the system components by the use of strain relief's or cable clamps, unless enclosed in conduit.
6. All outside wiring must be rated for wet conditions and/or encased in liquid-tight conduit.
7. Insulation on any wiring located in areas with potential high ambient temperature must be rated at 90° C or higher.
8. All wiring splices must be contained in UL-approved workboxes.

E: Batteries (If Applicable)

1. The batteries must be installed according to the manufacturer's instructions.
2. Battery terminals must be adequately protected from accidental contact.
3. DC-rated over current protection must be provided in accordance with the provisions of the NEC.

New Jersey Clean Energy Program

Technical Worksheet – Solar Electric Equipment Information

| | |
|--|--|
| Original Application Date: _____ | Revised Application Date: _____ |
| Customer Name: _____ (Corresponding to Rebate Application Form) | Application Number: _____ (Assigned by the NJBPU) |

A: EQUIPMENT INFORMATION

1. Solar Electric Module Manufacturer: _____ Module Model Number: _____

2. Power Rating per Module: _____ DC Watts (Refer to STC conditions) Number of Modules: _____

3. Total Array Output: _____ DC Watts (No. of Modules x Power Rating)

4. Inverter Manufacturer: _____ Inverter Model Number: _____

5. Inverter's Continuous AC Rating: _____ AC Watts Number of Inverters: _____

6. Total Inverter Output: _____ AC Watts (Inverter Continuous AC Rating x Number of Inverters)

7. Inverter's Peak Efficiency: _____ (Refer to manufacturer's peak efficiency rating)

B: PROPOSED INSTALLATION/INTERCONNECTION INFORMATION

1. Solar Electric Array Location: Rooftop Pole Mount or Ground Mount Location: _____

2. Solar Electric Module Orientation: _____ degrees (e.g., 180 degrees magnetic south)
Note: in Central New Jersey, magnetic south compass reading is 10 degrees east of true south.

3. Solar Electric Module Tilt: _____ degrees (e.g., flat mount = 0 degrees; vertical mount = 90 degrees)

4. Solar Electric Module Tracking: Fixed Single-axis Double-axis

5. Inverter Location: Indoor Outdoor Location: _____

6. Utility-Accessible AC Disconnect Switch Location: _____

7. System Type and Mode of Operation:
 Utility interactive (parallel/capable of back feeding the meter) (with battery backup)
 Dedicated circuit, utility power as backup (transfer switch) (with battery charging)
 Stand-alone (system confined to an independent circuit, no utility backup) (with battery charging)

C: INCENTIVE REQUEST CALCULATION

1. System rated output (Section A, line 3 above): _____ DC Watts

2. Incentive Calculation (Calculate appropriate incentive based on System Rated Output):

| | |
|--|--|
| Residential Applicants that perform Energy Efficiency Audit | Commercial, Farm, Public and Non-Profit |
| a. 0 to 10,000 Watts x \$1.75/Watt = \$ _____ + | 0 to 50,000 Watts x \$1.00/Watt = \$ _____ + |
| Residential Applicants that <u>do not</u> perform Energy Efficiency Audit | |
| b. 0 to 10,000 Watts x \$1.55/Watt = \$ _____ + | |
| | Large PV Project Applications |
| | > 50,000 Watts = \$ _____ Not eligible for rebates _____ |
| d. Total Rebate Calculation: \$ _____ | Total Rebate Calculation: \$ _____ |

3. School Applicants: Maximum Annual School Rebate: \$ _____
(For Public School applicants, enter the lesser value from no. 6 on the School Application form or \$50,000)

4. Total Installed System Cost: \$ _____
(Eligible installed system cost includes all equipment, installation, and applicable interconnection costs before the New Jersey Clean Energy Program incentive.)

5. Requested Incentive (Enter the appropriate value from C2. b or c): \$ _____

D: WARRANTY INFORMATION

1. Module: _____ Years at _____ Percent of Rated Power Output 2. Inverter: _____ Years 3. Installation: _____ Years

Revised January 2009



Incentive Structure for NJ Pay For Performance Program

Incentive #1: Energy Reduction Plan

Incentive Amount:.....\$0.10 per sq ft
 Minimum Incentive:.....\$5,000
 Maximum Incentive:.....\$50,000 or 50% of facility annual energy cost

This incentive will be developed to offset the cost of services associated with the development of the Energy Reduction Plan. Projects must identify efficiency improvements that meet the minimum performance level in order to become eligible for Incentive #1. Incentive amount will be based on the square footage of the building.

Incentive #2: Installation of Recommended Measures

Minimum Performance Target:.....15%

Electric Incentives

Base Incentive based on 15% savings:.....\$0.11 per projected kWh saved
 For each % over 15% add:.....\$0.005 per projected kWh saved
 Maximum Incentive:.....\$0.13 per projected kWh saved

Gas Incentives

Base Incentive base on 15% savings:.....\$1.10 per projected Therm saved
 For each % over 15% add:.....\$0.05 per projected Therm saved
 Maximum Incentive:.....\$1.45 per projected Therm saved

Incentive Cap:30% of total project cost

This incentive will be based on projected energy savings and designed to pay approximately 60% of the total performance-based incentive. Savings projections will be calculated using calibrated energy simulation and rounded to the nearest percent. Incentive #2 may not exceed 30% of the total project cost.

Incentive #3: Post-Construction Benchmarking Report

Minimum Performance Target:.....15%

Electric Incentives

Base Incentive based on 15% savings:.....\$0.07 per projected kWh saved
 For each % over 15% add:.....\$0.005 per projected kWh saved
 Maximum Incentive:.....\$0.09 per projected kWh saved

Gas Incentives

Base Incentive base on 15% savings:.....\$0.70 per projected Therm saved
 For each % over 15% add:.....\$0.05 per projected Therm saved
 Maximum Incentive:.....\$1.05 per projected Therm saved

Incentive Cap:20% of total project cost

This incentive will be released upon submittal of a Post-Construction Benchmarking Report that verifies that the level of savings actually achieved by the installed measures meets or exceeds the minimum performance threshold. To validate the savings and achievement of the Energy Target, the EPA Portfolio Manager shall be used. Savings should be rounded to the nearest percent. Total value of Incentive #2 and Incentive #3 may not exceed 50% of the total project cost. This incentive will "true up" proposed savings and the related payment for Incentive #2 so that the total incentive is based on actual savings. For buildings not covered by EPA, the process used by LEED EB shall be followed.

Advanced Measure Incentive: Combined Heat and Power

| Eligible Technology | Incentive (per Watt) Max: \$1 Million | Maximum % of Project Cost |
|---|--|------------------------------|
| Level 1: | | |
| Fuel cells not fueled by Class I renewable fuel | \$4.00..... | 60% |
| Level 2: | | |
| Microturbines | \$1.00..... | 30% ⁽¹⁾ |
| Internal Combustion Engines Combustion Turbines | | |
| Level 3: | | |
| Heat Recovery or other Mechanical Recovery from Existing Equipment | \$0.50..... | 30% |

(1) The maximum % of project cost will go to 40% where a cooling application is used or included with the CHP system.
 Note: Incentives for renewable fueled projects (Class 1) are currently being developed. This document will be updated when the incentive levels are finalized.

WHAT IS DIRECT INSTALL?

Designed for small to medium-sized facilities, Direct Install, by New Jersey's Clean Energy Program, cuts energy costs by replacing eligible lighting, HVAC, motors, natural gas, refrigeration and other equipment with higher efficiency alternatives. The program pays up to 80% of retrofit costs, dramatically lowering your upfront costs and improving your payback on the project. Services are provided by a network of Participating Contractors who perform Energy Assessments to identify eligible alternatives and then install the qualifying measures.

WHO'S ELIGIBLE?

Owners of existing small buildings to mid-size commercial and industrial facilities with a peak electric demand that did not exceed 200 kW in any of the preceding 12 months are eligible to participate in Direct Install. Buildings must be located in New Jersey and served by one of the state's public, regulated electric or natural gas utility companies.



WHAT TO EXPECT?

■ The program is completely turnkey!

Participating Contractors are approved to perform Energy Assessments and install the energy efficient equipment in your building.

■ Costs to you are minimal!

Your share of the project's cost will be approximately 20%, New Jersey's Clean Energy Program pays the remaining 80%. With incentives so dramatic, your payback can be less than 2 years.

■ Turnaround time is quick!

Direct Install is designed to fast-track project implementation so your business can begin saving on energy costs sooner rather than later. Participating Contractors will perform the Energy Assessments and implement the recommended efficiency measures quickly.



Contact us today at 866-NJSMART and get started on a path to savings.

APPENDIX I

LIGHTING UPGRADES SPREADSHEET

| Building | Floor | Location/Room # | Existing Fixture/Lamp & Ballast Description | Qty of Existing Fixtures | Existing Fixture Watts | Existing kW | Operating Hours | Existing kWh | Existing Annual Energy Cost | Proposed Replacement Solution | Qty of Proposed Fixtures | Proposed Fixture Watts | Proposed kW Base | Proposed Operational Hours Without Sensors | Proposed Operational Hours With Sensors | Proposed kWh Without Sensors | Proposed kWh With Sensors | Proposed Occupancy Type | Sensor | Occupancy Sensor Quantity | Total kW Saved | Total kWh Saved | Energy Cost Savings | Ballast/Fixture/Reflector Per Unit Price | Bulb (Per Unit Price) | Labor (Per Unit Price) | Occupancy Sensor (Per Unit Price) | Occupancy Sensor (Per Unit Price) | Labor Subtotal | Materials Subtotal | Labor & Materials Subtotal | Labor Total | Materials Total | Labor & Materials Total | |
|------------------------------------|-------|-----------------------|--|--------------------------|------------------------|-------------|-----------------|--------------|-----------------------------|--|--------------------------|------------------------|------------------|--|---|------------------------------|---------------------------|----------------------------------|--------|---------------------------|----------------|-----------------|---------------------|--|-----------------------|------------------------|-----------------------------------|-----------------------------------|----------------|--------------------|----------------------------|-------------|-----------------|-------------------------|---------|
| Administration Building - Interior | 001 | Hallway | 1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast | 4 | 342.4 | 0.3424 | 2080 | 712.192 | \$107.8 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 4 | 194.4 | 0.1944 | 2080 | 2080 | 404.352 | 404.352 | None Proposed | | 0 | 0.148 | 307.84 | 46.6 | \$70.0 | \$10.0 | \$65.0 | \$0.0 | \$0.0 | \$65.0 | \$80.0 | \$145.0 | \$260.0 | \$320.0 | \$580.0 | |
| Administration Building - Interior | 001 | File/Storage Area | 1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast | 4 | 342.4 | 0.3424 | 2080 | 712.192 | \$107.8 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 4 | 194.4 | 0.1944 | 2080 | 2080 | 404.352 | 404.352 | None Proposed | | 0 | 0.148 | 307.84 | 46.6 | \$70.0 | \$10.0 | \$65.0 | \$0.0 | \$0.0 | \$65.0 | \$80.0 | \$145.0 | \$260.0 | \$320.0 | \$580.0 | |
| Administration Building - Interior | 001 | Men's Bathroom | 1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast | 4 | 342.4 | 0.3424 | 2080 | 712.192 | \$107.8 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 4 | 194.4 | 0.1944 | 2080 | 1456 | 404.352 | 283.0464 | Ceiling Mounted Occupancy Sensor | | 1 | 0.148 | 429.1456 | 65.0 | \$70.0 | \$10.0 | \$65.0 | \$103.0 | \$73.5 | \$65.0 | \$80.0 | \$145.0 | \$333.5 | \$423.0 | \$756.5 | |
| Administration Building - Interior | 001 | Men's Shower | 65W Incandescent Fixture | 1 | 65 | 0.065 | 500 | 32.5 | \$4.9 | Replace 65W Incandescent Fixture with 13W CFL | 1 | 13 | 0.013 | 500 | 500 | 6.5 | 6.5 | None Proposed | | 0 | 0.052 | 26 | 3.9 | \$0.0 | \$5.0 | \$20.0 | \$0.0 | \$0.0 | \$20.0 | \$5.0 | \$25.0 | \$20.0 | \$5.0 | \$25.0 | |
| Administration Building - Interior | 001 | Women's Bathroom | 65W Incandescent Fixture | 1 | 65 | 0.065 | 2080 | 135.2 | \$20.5 | Replace 65W Incandescent Fixture with 13W CFL | 1 | 13 | 0.013 | 2080 | 1456 | 27.04 | 18.928 | Ceiling Mounted Occupancy Sensor | | 1 | 0.052 | 116.272 | 17.6 | \$0.0 | \$5.0 | \$20.0 | \$103.0 | \$73.5 | \$65.0 | \$20.0 | \$5.0 | \$25.0 | \$93.5 | \$108.0 | \$201.5 |
| Administration Building - Interior | 001 | Secretary's Office | 2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast | 4 | 684.8 | 0.6848 | 2080 | 1424.384 | \$215.7 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 4 | 389.2 | 0.3892 | 2080 | 1456 | 809.536 | 566.6752 | Ceiling Mounted Occupancy Sensor | | 1 | 0.2956 | 857.7088 | 129.9 | \$105.0 | \$20.0 | \$65.0 | \$103.0 | \$73.5 | \$65.0 | \$125.0 | \$190.0 | \$333.5 | \$603.0 | \$936.5 | |
| Administration Building - Interior | 001 | Lab | 2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast | 5 | 856 | 0.856 | 2080 | 1780.48 | \$269.6 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 5 | 486.5 | 0.4865 | 2080 | 1456 | 1011.92 | 708.344 | Ceiling Mounted Occupancy Sensor | | 1 | 0.3695 | 1072.136 | 162.3 | \$105.0 | \$20.0 | \$65.0 | \$103.0 | \$73.5 | \$65.0 | \$125.0 | \$190.0 | \$398.5 | \$728.0 | \$1,126.5 | |
| Administration Building - Interior | 001 | Superintendent Office | 2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast | 2 | 342.4 | 0.3424 | 2080 | 712.192 | \$107.8 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 2 | 194.6 | 0.1946 | 2080 | 1456 | 404.768 | 283.3376 | Ceiling Mounted Occupancy Sensor | | 1 | 0.1478 | 428.8544 | 64.9 | \$105.0 | \$20.0 | \$65.0 | \$103.0 | \$73.5 | \$65.0 | \$125.0 | \$190.0 | \$203.5 | \$353.0 | \$556.5 | |
| Administration Building - Interior | 001 | Conference Room | 2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast | 12 | 2054.4 | 2.0544 | 2080 | 4273.152 | \$647.0 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 12 | 1167.6 | 1.1676 | 2080 | 1456 | 2428.608 | 1700.0256 | Ceiling Mounted Occupancy Sensor | | 1 | 0.8868 | 2573.1264 | 389.6 | \$105.0 | \$20.0 | \$65.0 | \$103.0 | \$73.5 | \$65.0 | \$125.0 | \$190.0 | \$853.5 | \$1,603.0 | \$2,456.5 | |
| Administration Building - Interior | 001 | Garage | 8 T12 Fixture w/ 2-T12 Lamps | 3 | 1362 | 1.362 | 2080 | 2832.96 | \$428.9 | Replace 8 T12 Fixture with 1 Tandem Double-Length 4-T8 Lamp Fixture | 3 | 720 | 0.72 | 2080 | 2080 | 1497.6 | 1497.6 | None Proposed | | 0 | 0.642 | 1335.36 | 202.2 | \$65.1 | \$105.0 | \$93.0 | \$0.0 | \$0.0 | \$93.0 | \$170.1 | \$263.1 | \$279.0 | \$510.3 | \$789.3 | |
| Administration Building - Interior | 001 | Garage | 8 T12 Fixture w/ 2-T12 Lamps | 4 | 908 | 0.908 | 2080 | 1888.64 | \$285.9 | Replace 8 T12 Fixture with 1 Tandem Double-Length 2-T8 Lamp Fixture | 4 | 480 | 0.48 | 2080 | 2080 | 998.4 | 998.4 | None Proposed | | 0 | 0.428 | 890.24 | 134.8 | \$65.1 | \$105.0 | \$93.0 | \$0.0 | \$0.0 | \$93.0 | \$170.1 | \$263.1 | \$372.0 | \$680.4 | \$1,052.4 | |
| Administration Building - Interior | 001 | Electrical Room | 1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast | 6 | 513.6 | 0.5136 | 2080 | 1068.288 | \$161.7 | Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast | 6 | 291.6 | 0.2916 | 2080 | 2080 | 606.528 | 606.528 | None Proposed | | 0 | 0.222 | 461.76 | 69.9 | \$70.0 | \$10.0 | \$65.0 | \$0.0 | \$0.0 | \$65.0 | \$80.0 | \$145.0 | \$390.0 | \$480.0 | \$870.0 | |
| Administration Building - Interior | 001 | Hypochloride Room | 200W Incandescent Explosionproof Fixture | 4 | 800 | 0.8 | 500 | 400 | \$60.6 | None Proposed | 4 | 800 | 0.8 | 500 | 500 | 400 | 400 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Administration Building - Interior | 001 | Bsuffite Room | 200W Incandescent Explosionproof Fixture | 1 | 200 | 0.2 | 500 | 100 | \$15.1 | None Proposed | 1 | 200 | 0.2 | 500 | 500 | 100 | 100 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Administration Building - Interior | 001 | Analyzer Room | 75W Incandescent Explosionproof Fixture | 3 | 225 | 0.225 | 500 | 112.5 | \$17.0 | None Proposed | 3 | 225 | 0.225 | 500 | 500 | 112.5 | 112.5 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Administration Building - Interior | 000 | Basement | 8 T12 Fixture w/ 2-T12 Lamps | 3 | 681 | 0.681 | 500 | 340.5 | \$51.6 | Replace 8 T12 Fixture with 1 Tandem Double-Length 2-T8 Lamp Fixture | 3 | 360 | 0.36 | 500 | 500 | 180 | 180 | None Proposed | | 0 | 0.321 | 160.5 | 24.3 | \$65.1 | \$105.0 | \$93.0 | \$0.0 | \$0.0 | \$93.0 | \$170.1 | \$263.1 | \$279.0 | \$510.3 | \$789.3 | |
| Administration Building - Interior | 000 | Basement | 175W Self Ballasted Mercury Vapor Fixture | 1 | 205 | 0.205 | 500 | 102.5 | \$15.5 | Replace MV Fixture with Fluorescent Fixture with 2-High Perf. T8 Bulbs, and Ballast | 1 | 48.6 | 0.0486 | 500 | 500 | 24.3 | 24.3 | None Proposed | | 0 | 0.1564 | 78.2 | 11.8 | \$120.0 | \$10.0 | \$65.0 | \$0.0 | \$0.0 | \$65.0 | \$130.0 | \$195.0 | \$65.0 | \$130.0 | \$195.0 | |
| Administration Building - Exterior | - | Garage | 175W Self Ballasted Mercury Vapor Fixture (Assumed) | 3 | 615 | 0.615 | 4380 | 2693.7 | \$407.8 | Replace 175W Self Ballasted Mercury Vapor Fixture with 40W CFL | 3 | 120 | 0.12 | 4380 | 4380 | 525.6 | 525.6 | None Proposed | | 0 | 0.495 | 2168.1 | 328.3 | \$0.0 | \$7.0 | \$20.0 | \$0.0 | \$0.0 | \$20.0 | \$7.0 | \$27.0 | \$60.0 | \$21.0 | \$81.0 | |
| Administration Building - Exterior | - | Entrance | 26W CFL Fixture | 2 | 52 | 0.052 | 4380 | 227.76 | \$34.5 | None Proposed | 2 | 52 | 0.052 | 4380 | 4380 | 227.76 | 227.76 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Administration Building - Exterior | - | Canopy | 26W CFL Fixture | 2 | 52 | 0.052 | 4380 | 227.76 | \$34.5 | None Proposed | 2 | 52 | 0.052 | 4380 | 4380 | 227.76 | 227.76 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Grit Building - Interior | 000 | Grit Room | 200W Incandescent Explosionproof Fixture | 4 | 800 | 0.8 | 500 | 400 | \$60.6 | None Proposed | 4 | 800 | 0.8 | 500 | 500 | 400 | 400 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Digester #1 Building - Interior | 001 | Entrance | 100W Incandescent Explosionproof Fixture | 3 | 300 | 0.3 | 2080 | 624 | \$94.5 | None Proposed | 3 | 300 | 0.3 | 2080 | 2080 | 624 | 624 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Digester #1 Building - Interior | 001 | Boiler Room | 200W Incandescent Explosionproof Fixture | 2 | 400 | 0.4 | 2080 | 832 | \$126.0 | None Proposed | 2 | 400 | 0.4 | 2080 | 2080 | 832 | 832 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Digester #1 Building - Interior | 000 | Recirculator Room | 200W Incandescent Explosionproof Fixture | 6 | 1200 | 1.2 | 2080 | 2496 | \$377.9 | None Proposed | 6 | 1200 | 1.2 | 2080 | 2080 | 2496 | 2496 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Digester #1 Building - Interior | 000 | Cat. Room | 200W Incandescent Explosionproof Fixture | 5 | 1000 | 1 | 2080 | 2080 | \$314.9 | None Proposed | 5 | 1000 | 1 | 2080 | 2080 | 2080 | 2080 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Digester #1 Building - Interior | -001 | Digester Pump Room | 200W Incandescent Explosionproof Fixture | 6 | 1200 | 1.2 | 2080 | 2496 | \$377.9 | None Proposed | 6 | 1200 | 1.2 | 2080 | 2080 | 2496 | 2496 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Digester #1 Building - Exterior | - | Exterior | 100W Incandescent Explosionproof Fixture | 2 | 200 | 0.2 | 4380 | 876 | \$132.6 | None Proposed | 2 | 200 | 0.2 | 4380 | 4380 | 876 | 876 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Digester #2 Building - Interior | 001 | Boiler Room | 175W Mercury Vapor Explosionproof Fixture | 2 | 410 | 0.41 | 2080 | 852.8 | \$129.1 | None Proposed | 2 | 410 | 0.41 | 2080 | 2080 | 852.8 | 852.8 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | |
| Digester #2 Building - Interior | 001 | Cat. Room | 175W Mercury Vapor Explosionproof Fixture | 6 | 1230 | 1.23 | 2080 | 2556.4 | \$387.3 | None Proposed | 6 | 1230 | 1.23 | 2080 | 2080 | 2556.4 | 2556.4 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Digester #2 Building - Interior | 001 | Storage | 175W Mercury Vapor Explosionproof Fixture | 2 | 410 | 0.41 | 500 | 205 | \$31.0 | None Proposed | 2 | 410 | 0.41 | 500 | 500 | 205 | 205 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Digester #2 Building - Interior | 001 | Recirculator Room | 200W Incandescent Explosionproof Fixture | 4 | 800 | 0.8 | 2080 | 1664 | \$251.9 | None Proposed | 4 | 800 | 0.8 | 2080 | 2080 | 1664 | 1664 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Digester #2 Building - Exterior | - | Exterior | 26W CFL Fixture | 5 | 130 | 0.13 | 4380 | 569.4 | \$86.2 | None Proposed | 5 | 130 | 0.13 | 4380 | 4380 | 569.4 | 569.4 | None Proposed | | 0 | 0 | 0 | 0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Waste Oil Building - Interior | 001 | Inert Area | 200W Incandescent Fixture | 1 | 200 | 0.2 | 2080 | 416 | \$63.0 | Replace 200W Incandescent Fixture with 40W CFL | 1 | 40 | 0.04 | 2080 | 2080 | 83.2 | 83.2 | None Proposed | | 0 | 0.16 | 332.8 | 50.4 | \$0.0 | \$7.0 | \$20.0 | \$0.0 | \$0.0 | \$20.0 | \$7.0 | \$27.0 | \$20.0 | \$7.0 | \$27.0 | |
| Waste Oil Building - Exterior | - | Entrance | 200W Incandescent Fixture | 1 | 200 | 0.2 | 4380 | 876 | \$132.6 | Replace 200W Incandescent Fixture with 40W CFL | 1 | 40 | 0.04 | 4380 | 4380 | 175.2 | 175.2 | None Proposed | | 0 | 0.16 | 700.8 | 106.1 | | | | | | | | | | | | |

| Building | Floor | Location/Room # | Existing Fixture/Lamp & Ballast Description | Qty of Existing Fixtures | Existing Fixture Watts | Existing kW | Operating Hours | Existing kWh | Existing Annual Energy Cost | Proposed Replacement Solution | Qty of Proposed Fixtures | Proposed Fixture Watts | Proposed kW Base | Proposed Operational Hours Without Sensors | Proposed Operational Hours With Sensors | Proposed kWh Without Sensors | Proposed kWh With Sensors | Proposed Occupancy Sensor Type | Occupancy Sensor Quantity | Total kW Saved | Total kWh Saved | Energy Cost Savings | Ballast/Fixture/Reflector Per Unit Price | Bulb (Per Unit Price) | Labor (Per Unit Price) | Occupancy Sensor (Per Unit Price) | Occupancy Sensor (Per Unit Labor Price) | Labor Subtotal | Materials Subtotal | Labor & Materials Subtotal | Labor Total | Materials Total | Labor & Materials Total |
|---|-------|-------------------|---|--------------------------|------------------------|-------------|-----------------|--------------|-----------------------------|---|--------------------------|------------------------|------------------|--|---|------------------------------|---------------------------|--------------------------------|---------------------------|----------------|-----------------|---------------------|--|-----------------------|------------------------|-----------------------------------|---|----------------|--------------------|----------------------------|-------------|-----------------|-------------------------|
| Clarifier #3, #4 Building - Exterior | - | Exterior Walpacks | Exterior Wall Packs (Assume 70w) | 2 | 180 | 0.18 | 4380 | 788.4 | \$119.4 | Replace 70W Fixture with Induction Light Fixture | 2 | 88 | 0.088 | 4380 | 4380 | 385.44 | 385.44 | None Proposed | 0 | 0.092 | 402.96 | 61.0 | \$0.0 | \$380.0 | \$137.0 | \$0.0 | \$0.0 | \$137.0 | \$380.0 | \$517.0 | \$274.0 | \$760.0 | \$1,034.0 |
| Roadway and Process Lighting - Exterior | - | Site Lighting | Pole Mounted Luminaire - 1 Head (Assume 250W HPS) | 11 | 3245 | 3.245 | 4380 | 14213.1 | \$2,151.9 | Replace 250W Fixture with Induction Light Fixture | 11 | 1210 | 1.21 | 4380 | 4380 | 5299.8 | 5299.8 | None Proposed | 0 | 2.035 | 8913.3 | 1,349.5 | \$0.0 | \$760.0 | \$137.0 | \$0.0 | \$0.0 | \$137.0 | \$760.0 | \$897.0 | \$1,507.0 | \$8,360.0 | \$9,867.0 |
| Roadway and Process Lighting - Exterior | - | Oxidation Ditch | Pole Mounted Luminaire - 1 Head (Assume 250W HPS) | 2 | 590 | 0.59 | 4380 | 2584.2 | \$391.2 | Replace 250W Fixture with Induction Light Fixture | 2 | 220 | 0.22 | 4380 | 4380 | 963.6 | 963.6 | None Proposed | 0 | 0.37 | 1620.6 | 245.4 | \$0.0 | \$760.0 | \$137.0 | \$0.0 | \$0.0 | \$137.0 | \$760.0 | \$897.0 | \$274.0 | \$1,520.0 | \$1,794.0 |

APPENDIX J

MOTOR AND VFD UPGRADES ANALYSIS

Appendix J

| Description | Location | Horsepower | Efficiency | VFD | | | Premium Efficiency | | | | Total (VFD+PE Motor) | Markup ² | Inflated Total (VFD+PE Motor) | Cost Difference | Yearly Runtime | kW Usage Prior to Upgrades | kWh/Yr Prior to Upgrades | Energy Cost Prior to Upgrades | kW Usage with VFD & Motor Upgrades | kWh/Yr After Upgrades | Annual Energy Cost After Upgrades | Energy Savings | Incentive | Simple Payback (Years) | |
|--------------------------|----------------------------------|------------|------------|----------------|------------|------------|--------------------|------------|------------|------------|----------------------|---------------------|-------------------------------|-----------------|----------------|----------------------------|--------------------------|-------------------------------|------------------------------------|-----------------------|-----------------------------------|----------------|-----------|------------------------|-----|
| | | | | Equipment Cost | Labor Cost | Total Cost | Equipment Cost | Efficiency | Labor Cost | Total Cost | | | | | | | | | | | | | | | |
| Blower #1 | Blower Building | 75 | 95.4 | | | | | | 95.40 | | 0.00 | 0.00 | 0.00 | \$0 | \$0.0 | 1093 | 58.65 | 64102.0 | \$9,705.0 | 58.65 | 64102.04 | \$9,705.05 | \$0.00 | \$0.00 | N/A |
| Blower #2 | Blower Building | 75 | 95.4 | | | | | | 95.40 | | 0.00 | 0.00 | 0.00 | \$0 | \$0.0 | 1087 | 58.65 | 63750.2 | \$9,651.8 | 58.65 | 63750.16 | \$9,651.77 | \$0.00 | \$0.00 | N/A |
| Raw Sludge Pump #3 | Blower Building | 5 | 86 | | | | \$405.0 | 89.50 | 115.00 | 520.00 | 520.00 | 227.50 | \$748 | \$747.5 | 1278 | 4.34 | 5543.0 | \$839.2 | 4.17 | 5326.19 | \$806.39 | \$32.82 | \$0.00 | 22.78 | |
| Primary Effluent Pump #1 | Administration Building | 30 | 92.4 | | | | \$1,450.0 | 93.00 | 215.00 | 1665.00 | 1665.00 | 728.44 | \$2,393 | \$2,393.4 | 2920 | 24.22 | 70724.7 | \$10,707.7 | 24.06 | 70268.39 | \$10,638.63 | \$69.08 | \$135.00 | 32.69 | |
| Primary Effluent Pump #2 | Administration Building | 30 | 92.4 | | | | \$1,450.0 | 93.00 | 215.00 | 1665.00 | 1665.00 | 728.44 | \$2,393 | \$2,393.4 | 2920 | 24.22 | 70724.7 | \$10,707.7 | 24.06 | 70268.39 | \$10,638.63 | \$69.08 | \$135.00 | 32.69 | |
| Primary Effluent Pump #3 | Administration Building | 30 | 92.4 | | | | \$1,450.0 | 93.00 | 215.00 | 1665.00 | 1665.00 | 728.44 | \$2,393 | \$2,393.4 | 2920 | 24.22 | 70724.7 | \$10,707.7 | 24.06 | 70268.39 | \$10,638.63 | \$69.08 | \$135.00 | 32.69 | |
| Raw Sludge Pump #1 | Administration Building | 5 | 87.5 | | | | \$405.0 | 89.50 | 115.00 | 520.00 | 520.00 | 227.50 | \$748 | \$747.5 | 548 | 4.26 | 2336.0 | \$353.7 | 4.17 | 2283.84 | \$345.77 | \$7.90 | \$0.00 | 94.58 | |
| Raw Sludge Pump #2 | Administration Building | 5 | 87.5 | | | | \$405.0 | 89.50 | 115.00 | 520.00 | 520.00 | 227.50 | \$748 | \$747.5 | 548 | 4.26 | 2336.0 | \$353.7 | 4.17 | 2283.84 | \$345.77 | \$7.90 | \$0.00 | 94.58 | |
| Thick Sludge Pump #1 | Sludge Handling Building | 7.5 | 89.5 | | | | \$510.0 | 91.00 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 390 | 6.25 | 2438.0 | \$369.1 | 6.15 | 2397.86 | \$363.04 | \$6.08 | \$0.00 | 149.79 | |
| Thick Sludge Pump #2 | Sludge Handling Building | 7.5 | 89.5 | | | | \$510.0 | 91.00 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 390 | 6.25 | 2438.0 | \$369.1 | 6.15 | 2397.86 | \$363.04 | \$6.08 | \$0.00 | 149.79 | |
| Thick Feed Pump #1 | Sludge Handling Building | 15 | 90.2 | | | | \$795.0 | 91.70 | 162.00 | 957.00 | 957.00 | 418.69 | \$1,376 | \$1,375.7 | 390 | 12.41 | 4838.2 | \$732.5 | 12.20 | 4759.11 | \$720.53 | \$11.98 | \$0.00 | 114.81 | |
| Thick Feed Pump #2 | Sludge Handling Building | 15 | 90.2 | | | | \$795.0 | 91.70 | 162.00 | 957.00 | 957.00 | 418.69 | \$1,376 | \$1,375.7 | 390 | 12.41 | 4838.2 | \$732.5 | 12.20 | 4759.11 | \$720.53 | \$11.98 | \$0.00 | 114.81 | |
| BFP Pump #1 | Sludge Handling Building | 5 | 87.5 | | | | \$405.0 | 89.50 | 115.00 | 520.00 | 520.00 | 227.50 | \$748 | \$747.5 | 780 | 4.26 | 3325.0 | \$503.4 | 4.17 | 3250.73 | \$492.16 | \$11.25 | \$0.00 | 66.45 | |
| BFP Pump #2 | Sludge Handling Building | 5 | 87.5 | | | | \$405.0 | 89.50 | 115.00 | 520.00 | 520.00 | 227.50 | \$748 | \$747.5 | 780 | 4.26 | 3325.0 | \$503.4 | 4.17 | 3250.73 | \$492.16 | \$11.25 | \$0.00 | 66.45 | |
| Service Water Pump #1 | Sludge Handling Building | 7.5 | 85.5 | | | | \$510.0 | 88.50 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 910 | 6.54 | 5954.9 | \$901.6 | 6.32 | 5753.05 | \$871.01 | \$30.56 | \$0.00 | 29.82 | |
| Service Water Pump #2 | Sludge Handling Building | 7.5 | 85.5 | | | | \$510.0 | 88.50 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 910 | 6.54 | 5954.9 | \$901.6 | 6.32 | 5753.05 | \$871.01 | \$30.56 | \$0.00 | 29.82 | |
| Washwater Pump #1 | Sludge Handling Building | 7.5 | 88.1 | | | | \$510.0 | 88.50 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 390 | 6.35 | 2476.8 | \$375.0 | 6.32 | 2465.59 | \$373.29 | \$1.69 | \$0.00 | 537.73 | |
| Washwater Pump #2 | Sludge Handling Building | 7.5 | 88.1 | | | | \$510.0 | 88.50 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 390 | 6.35 | 2476.8 | \$375.0 | 6.32 | 2465.59 | \$373.29 | \$1.69 | \$0.00 | 537.73 | |
| Washwater Pump #3 | Sludge Handling Building | 7.5 | 86.5 | | | | \$510.0 | 88.50 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 780 | 6.47 | 5045.2 | \$763.8 | 6.32 | 4931.19 | \$746.58 | \$17.26 | \$0.00 | 52.80 | |
| Washwater Pump #4 | Sludge Handling Building | 7.5 | 86.5 | | | | \$510.0 | 88.50 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 780 | 6.47 | 5045.2 | \$763.8 | 6.32 | 4931.19 | \$746.58 | \$17.26 | \$0.00 | 52.80 | |
| Process Water Pump #1 | Sludge Handling Building | 10 | 88.5 | | | | \$620.0 | 89.50 | 129.00 | 749.00 | 749.00 | 327.69 | \$1,077 | \$1,076.7 | 260 | 8.43 | 2191.6 | \$331.8 | 8.34 | 2167.15 | \$328.11 | \$3.71 | \$0.00 | 290.41 | |
| Process Water Pump #2 | Sludge Handling Building | 10 | 88.5 | | | | \$620.0 | 89.50 | 129.00 | 749.00 | 749.00 | 327.69 | \$1,077 | \$1,076.7 | 130 | 8.43 | 1095.8 | \$165.9 | 8.34 | 1083.58 | \$164.05 | \$1.85 | \$0.00 | 580.83 | |
| RAS Pump #1 | Final Clarifier #1 & #2 Building | 10 | 90.2 | \$1,525 | \$775 | \$2,300 | \$620.0 | 91.70 | 129.00 | 749.00 | 3049.00 | 1333.94 | \$4,383 | \$4,382.9 | 4380 | 8.27 | 36224.8 | \$5,484.4 | 6.10 | 26724.21 | \$4,046.05 | \$1,438.39 | \$90.00 | 2.98 | |
| RAS Pump #2 | Final Clarifier #1 & #2 Building | 10 | 90.2 | \$1,525 | \$775 | \$2,300 | \$620.0 | 91.70 | 129.00 | 749.00 | 3049.00 | 1333.94 | \$4,383 | \$4,382.9 | 4380 | 8.27 | 36224.8 | \$5,484.4 | 6.10 | 26724.21 | \$4,046.05 | \$1,438.39 | \$90.00 | 2.98 | |
| WAS Pump | Final Clarifier #1 & #2 Building | 3 | 86.5 | | | | | 86.50 | | 0.00 | 0.00 | 0.00 | \$0 | \$0.0 | 1095 | 2.59 | 2833.1 | \$428.9 | 2.59 | 2833.08 | \$428.93 | \$0.00 | \$0.00 | N/A | |
| RAS Pump #1 | Final Clarifier #3 & #4 Building | 7.5 | 87.5 | \$1,300 | \$775 | \$2,075 | \$510.0 | 90.20 | 124.00 | 634.00 | 2709.00 | 1185.19 | \$3,894 | \$3,894.2 | 2920 | 6.39 | 18671.3 | \$2,826.8 | 4.65 | 13584.31 | \$2,056.66 | \$770.17 | \$81.00 | 4.95 | |
| RAS Pump #2 | Final Clarifier #3 & #4 Building | 7.5 | 87.5 | \$1,300 | \$775 | \$2,075 | \$510.0 | 90.20 | 124.00 | 634.00 | 2709.00 | 1185.19 | \$3,894 | \$3,894.2 | 2920 | 6.39 | 18671.3 | \$2,826.8 | 4.65 | 13584.31 | \$2,056.66 | \$770.17 | \$81.00 | 4.95 | |
| RAS Pump #3 | Final Clarifier #3 & #4 Building | 7.5 | 87.5 | \$1,300 | \$775 | \$2,075 | \$510.0 | 90.20 | 124.00 | 634.00 | 2709.00 | 1185.19 | \$3,894 | \$3,894.2 | 2920 | 6.39 | 18671.3 | \$2,826.8 | 4.65 | 13584.31 | \$2,056.66 | \$770.17 | \$81.00 | 4.95 | |
| WAS Pump #1 | Final Clarifier #3 & #4 Building | 5 | 85.5 | \$1,075 | \$645 | \$1,720 | \$405.0 | 89.50 | 115.00 | 520.00 | 2240.00 | 980.00 | \$3,220 | \$3,220.0 | 4380 | 4.36 | 19108.1 | \$2,893.0 | 3.13 | 13690.66 | \$2,072.75 | \$820.21 | \$54.00 | 3.86 | |
| WAS Pump #2 | Final Clarifier #3 & #4 Building | 5 | 85.5 | \$1,075 | \$645 | \$1,720 | \$405.0 | 89.50 | 115.00 | 520.00 | 2240.00 | 980.00 | \$3,220 | \$3,220.0 | 4380 | 4.36 | 19108.1 | \$2,893.0 | 3.13 | 13690.66 | \$2,072.75 | \$820.21 | \$54.00 | 3.86 | |
| Gas Mixer #1 | Outdoor Process | 10 | 83.5 | | | | \$620.0 | 89.50 | 129.00 | 749.00 | 749.00 | 327.69 | \$1,077 | \$1,076.7 | 2920 | 8.93 | 26087.7 | \$3,949.7 | 8.34 | 24338.77 | \$3,684.89 | \$264.78 | \$81.00 | 3.76 | |
| Gas Mixer #2 | Outdoor Process | 10 | 91 | | | | \$620.0 | 91.70 | 129.00 | 749.00 | 749.00 | 327.69 | \$1,077 | \$1,076.7 | 2920 | 8.20 | 23937.6 | \$3,624.1 | 8.14 | 23754.85 | \$3,596.48 | \$27.67 | \$90.00 | 35.67 | |
| Ejector Pump #1 | Outdoor Process | 5 | 85.5 | | | | \$405.0 | 89.50 | 115.00 | 520.00 | 520.00 | 227.50 | \$748 | \$747.5 | 4380 | 4.36 | 19108.1 | \$2,893.0 | 4.17 | 18254.08 | \$2,763.67 | \$129.29 | \$54.00 | 5.36 | |
| Ejector Pump #2 | Outdoor Process | 5 | 85.5 | | | | \$405.0 | 89.50 | 115.00 | 520.00 | 520.00 | 227.50 | \$748 | \$747.5 | 4380 | 4.36 | 19108.1 | \$2,893.0 | 4.17 | 18254.08 | \$2,763.67 | \$129.29 | \$54.00 | 5.36 | |
| Dewatering Pump #1 | Outdoor Process | 10 | 89.5 | \$1,525 | \$775 | \$2,300 | \$620.0 | 91.70 | 129.00 | 749.00 | 3049.00 | 1333.94 | \$4,383 | \$4,382.9 | 4380 | 8.34 | 36508.2 | \$5,527.3 | 6.10 | 26724.21 | \$4,046.05 | \$1,481.29 | \$90.00 | 2.90 | |
| Dewatering Pump #2 | Outdoor Process | 10 | 89.5 | \$1,525 | \$775 | \$2,300 | \$620.0 | 91.70 | 129.00 | 749.00 | 3049.00 | 1333.94 | \$4,383 | \$4,382.9 | 4380 | 8.34 | 36508.2 | \$5,527.3 | 6.10 | 26724.21 | \$4,046.05 | \$1,481.29 | \$90.00 | 2.90 | |
| Pond Boat Winch Pump | Outdoor Process | 7.5 | 88.5 | | | | \$510.0 | 90.20 | 124.00 | 634.00 | 634.00 | 277.38 | \$911 | \$911.4 | 50 | 6.32 | 316.1 | \$47.9 | 6.20 | 310.14 | \$46.96 | \$0.90 | \$0.00 | 1010.42 | |

- Note:**
1. VFD energy savings is attributed to a 6.25% reduction effective motor horsepower.
2. Markup amount includes 15% overhead & profit, and 25% contingency, see Appendix P for a complete breakdown.
3. Motor efficiencies marked in red were estimated with NEMA standard efficiency tables.

Madison-Chatham Plant Rate per kWh \$0.1514

For All Motors Represented:
Material & Labor \$63,327.63
Total Incentives \$1,395.00
Savings \$10,761.35
Payback 5.76
Energy Savings (KW) 20.29
Energy Savings (kWh) 71,078.91

| | Total Materials After Markup | Base Motor Cost | Base Motor Labor | Base VFD Cost | Base VFD Labor | Savings | Incentive | Payback | Materials - Incentive | Energy Savings (kWh) | Energy Savings (KW) |
|----------------------------------|------------------------------|--------------------|-------------------|--------------------|-------------------|--------------------|-------------------|------------|-----------------------|----------------------|---------------------|
| Blower Building | \$747.50 | \$405.00 | \$115.00 | \$0.00 | \$0.00 | \$32.82 | \$0.00 | 22.8 | \$747.50 | 216.76 | 0.17 |
| Administration Building | \$8,675.31 | \$5,160.00 | \$875.00 | \$0.00 | \$0.00 | \$223.05 | \$405.00 | 37.1 | \$8,270.31 | 1473.27 | 0.66 |
| Sludge Handling Building | \$13,690.75 | \$7,720.00 | \$1,804.00 | \$0.00 | \$0.00 | \$163.23 | \$0.00 | 83.9 | \$13,690.75 | 1078.14 | 1.78 |
| Final Clarifier #1 & #2 Building | \$8,765.88 | \$1,240.00 | \$258.00 | \$3,050.00 | \$1,550.00 | \$2,876.79 | \$180.00 | 3.0 | \$8,585.88 | 19001.25 | 4.34 |
| Final Clarifier #3 & #4 Building | \$18,122.56 | \$2,340.00 | \$602.00 | \$6,050.00 | \$3,615.00 | \$3,950.94 | \$351.00 | 4.5 | \$17,771.56 | 26096.03 | 7.70 |
| Outdoor Process | \$13,325.63 | \$3,800.00 | \$870.00 | \$3,050.00 | \$1,550.00 | \$3,514.52 | \$459.00 | 3.7 | \$12,866.63 | 23213.46 | 5.64 |
| Total | \$63,327.63 | \$20,665.00 | \$4,524.00 | \$12,150.00 | \$6,715.00 | \$10,761.35 | \$1,395.00 | 5.8 | \$61,932.63 | 71078.91 | 20.29 |

APPENDIX K

SOLAR PV SYSTEM FINANCIAL ANALYSIS

Molitor Water Pollution Control Facility

Design Goal: Provide
72% of average annual electricity

Existing Conditions

Average Annual Electrical Usage (kWh) 2,224,089
Current Utility Price (\$/kWh) \$0.1514

Calculations

Solar Rating (Zip Code: 07928) 4.48 kWh/sq-m/day
Solar Capacity Required (kW) 1344
Ground Space Needed (sq-ft) 134,433
Annual Solar kWh (PV Watts) 1,601,345
Net System installation Cost (\$9/kWh) \$12,098,934
Electrical Service Modification Cost \$100,000
Total System Installation Cost **\$12,198,934**
Materials \$8,539,254
Labor \$3,659,680
Engineer's Opinion of Probable Cost \$15,248,668

Assumptions

Annual System Degredation 0.50%
Annual Utility Inflation 3.00%
Annual Maintenance Costs 2%

| Year | Utility Price | Solar kWh | Utility Savings | SRECS | Maintenance Costs | Annual Cash Flow | Cummulative Cash Flow | SREC Factor (\$/kWh)* | REC Factor (\$/kWh) |
|---------|---------------|-------------|-----------------|-----------|-------------------|------------------|-----------------------|-----------------------|---------------------|
| Install | | | | | | | | | |
| 1 | 0.1514 | 1,601,345.0 | \$242,443.6 | \$677,369 | (\$32,027) | \$887,785.7 | \$887,785.7 | \$0.423 | |
| 2 | 0.1559 | 1,593,338.3 | \$248,468.4 | \$673,982 | (\$31,867) | \$890,583.7 | \$1,778,369.4 | \$0.423 | |
| 3 | 0.1606 | 1,585,371.6 | \$254,642.8 | \$670,612 | (\$31,707) | \$893,547.5 | \$2,671,916.9 | \$0.423 | |
| 4 | 0.1654 | 1,577,444.7 | \$260,970.7 | \$667,259 | (\$31,549) | \$896,680.9 | \$3,568,597.8 | \$0.423 | |
| 5 | 0.1704 | 1,569,557.5 | \$267,455.8 | \$663,923 | (\$31,391) | \$899,987.5 | \$4,468,585.3 | \$0.423 | |
| 6 | 0.1755 | 1,561,709.7 | \$274,102.1 | \$660,603 | (\$31,234) | \$903,471.1 | \$5,372,056.3 | \$0.423 | |
| 7 | 0.1808 | 1,553,901.2 | \$280,913.5 | \$657,300 | (\$31,078) | \$907,135.7 | \$6,279,192.0 | \$0.423 | |
| 8 | 0.1862 | 1,546,131.7 | \$287,894.2 | \$654,014 | (\$30,923) | \$910,985.3 | \$7,190,177.3 | \$0.423 | |
| 9 | 0.1918 | 1,538,401.0 | \$295,048.4 | \$650,744 | (\$30,768) | \$915,024.0 | \$8,105,201.2 | \$0.423 | |
| 10 | 0.1975 | 1,530,709.0 | \$302,380.3 | \$647,490 | (\$30,614) | \$919,256.1 | \$9,024,457.3 | \$0.423 | |
| 11 | 0.2035 | 1,523,055.5 | \$309,894.5 | \$644,252 | (\$30,461) | \$923,685.8 | \$9,948,143.1 | \$0.423 | |
| 12 | 0.2096 | 1,515,440.2 | \$317,595.4 | \$641,031 | (\$30,309) | \$928,317.7 | \$10,876,460.9 | \$0.423 | |
| 13 | 0.2159 | 1,507,863.0 | \$325,487.6 | \$637,826 | (\$30,157) | \$933,156.4 | \$11,809,617.3 | \$0.423 | |
| 14 | 0.2223 | 1,500,323.7 | \$333,576.0 | \$634,637 | (\$30,006) | \$938,206.4 | \$12,747,823.7 | \$0.423 | |
| 15 | 0.2290 | 1,492,822.0 | \$341,865.3 | \$631,464 | (\$29,856) | \$943,472.6 | \$13,691,296.3 | \$0.423 | |
| 16 | 0.2359 | 1,485,357.9 | \$350,360.7 | \$37,134 | (\$29,707) | \$357,787.5 | \$14,049,083.7 | | \$0.025 |
| 17 | 0.2430 | 1,477,931.1 | \$359,067.1 | \$36,948 | (\$29,559) | \$366,456.8 | \$14,415,540.5 | | \$0.025 |
| 18 | 0.2502 | 1,470,541.5 | \$367,990.0 | \$36,764 | (\$29,411) | \$375,342.7 | \$14,790,883.2 | | \$0.025 |
| 19 | 0.2577 | 1,463,188.8 | \$377,134.5 | \$36,580 | (\$29,264) | \$384,450.5 | \$15,175,333.7 | | \$0.025 |
| 20 | 0.2655 | 1,455,872.8 | \$386,506.3 | \$36,397 | (\$29,117) | \$393,785.7 | \$15,569,119.3 | | \$0.025 |
| 21 | 0.2734 | 1,448,593.5 | \$396,111.0 | \$36,215 | (\$28,972) | \$403,354.0 | \$15,972,473.3 | | \$0.025 |
| 22 | 0.2816 | 1,441,350.5 | \$405,954.3 | \$36,034 | (\$28,827) | \$413,161.1 | \$16,385,634.4 | | \$0.025 |
| 23 | 0.2901 | 1,434,143.7 | \$416,042.3 | \$35,854 | (\$28,683) | \$423,213.0 | \$16,808,847.4 | | \$0.025 |
| 24 | 0.2988 | 1,426,973.0 | \$426,381.0 | \$35,674 | (\$28,539) | \$433,515.8 | \$17,242,363.3 | | \$0.025 |
| 25 | 0.3078 | 1,419,838.2 | \$436,976.5 | \$35,496 | (\$28,397) | \$444,075.7 | \$17,686,439.0 | | \$0.025 |

* SREC factor is referenced from the NJBPU Solar Alternative Compliance Payment (SACP) schedule.

APPENDIX L

WIND TURBINE ENERGY SYSTEM
WIND CAD ANALYSIS

WindCad Turbine Performance Model

BWC EXCEL-S, Grid - Intertie

Tier/neo-SH3055-23-BWC

Prepared For: **Madison-Chatham Joint Meeting**
 Site Location: **214 North Passaic Avenue, Chatham, NJ**
 Data Source: **NASA**
 Date: **9/1/2010**

10 kW

| Inputs: | |
|----------------------------|-------|
| Ave. Wind (m/s) = | 4.72 |
| Weibull K = | 2 |
| Site Altitude (m) = | 106 |
| Wind Shear Exp. = | 0.180 |
| Anem. Height (m) = | 30 |
| Tower Height (m) = | 30 |
| Turbulence Factor = | 5.0% |

| Results: | |
|---------------------------------------|---------------|
| Hub Average Wind Speed (m/s) = | 4.72 |
| Air Density Factor = | -1% |
| Average Output Power (kW) = | 1.21 |
| Daily Energy Output (kWh) = | 29.1 |
| Annual Energy Output (kWh) = | 10,618 |
| Monthly Energy Output = | 885 |
| Percent Operating Time = | 64.7% |

Weibull Performance Calculations

| Wind Speed Bin (m/s) | Power (kW) | Wind Probability (f) | Net kW @ V |
|----------------------|----------------|----------------------|--------------|
| 1 | 0.00 | 6.86% | 0.000 |
| 2 | 0.00 | 12.34% | 0.000 |
| 3 | 0.13 | 15.49% | 0.020 |
| 4 | 0.40 | 16.10% | 0.065 |
| 5 | 0.83 | 14.62% | 0.121 |
| 6 | 1.42 | 11.86% | 0.169 |
| 7 | 2.21 | 8.72% | 0.193 |
| 8 | 3.23 | 5.84% | 0.189 |
| 9 | 4.52 | 3.59% | 0.162 |
| 10 | 6.04 | 2.03% | 0.123 |
| 11 | 7.72 | 1.06% | 0.082 |
| 12 | 9.43 | 0.51% | 0.048 |
| 13 | 10.70 | 0.23% | 0.024 |
| 14 | 11.06 | 0.09% | 0.010 |
| 15 | 11.35 | 0.04% | 0.004 |
| 16 | 11.42 | 0.01% | 0.001 |
| 17 | 11.43 | 0.00% | 0.000 |
| 18 | 11.38 | 0.00% | 0.000 |
| 19 | 11.21 | 0.00% | 0.000 |
| 20 | 10.76 | 0.00% | 0.000 |
| 2008, BWC | Totals: | 99.41% | 1.212 |

Weibull Calculations:
 Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2)) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous, 24 hour, basis.
 Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly average speeds is not recommended.

WindCad Turbine Performance Model

BWC EXCEL-S, Grid - Intertie

Tier/neo-SH3055-23-BWC

Prepared For: **Madison-Chatham Joint Meeting**
 Site Location: **214 North Passaic Avenue, Chatham, NJ**
 Data Source: **NASA**
 Date: **9/1/2010**

10 kW

| Inputs: | |
|---------------------|-------|
| Max. Wind (m/s) = | 5.52 |
| Weibull K = | 2 |
| Site Altitude (m) = | 106 |
| Wind Shear Exp. = | 0.180 |
| Anem. Height (m) = | 30 |
| Tower Height (m) = | 30 |
| Turbulence Factor = | 5.0% |

| Results: | |
|-------------------------------------|---------------|
| Hub Average Wind Speed (m/s) = | 5.52 |
| Air Density Factor = | -1% |
| Average Output Power (kW) = | 1.84 |
| Daily Energy Output (kWh) = | 44.2 |
| Annual Energy Output (kWh) = | 16,144 |
| Monthly Energy Output = | 1,345 |
| Percent Operating Time = | 72.8% |

Weibull Performance Calculations

| Wind Speed Bin (m/s) | Power (kW) | Wind Probability (f) | Net kW @ V |
|----------------------|------------|----------------------|------------|
| 1 | 0.00 | 5.07% | 0.000 |
| 2 | 0.00 | 9.37% | 0.000 |
| 3 | 0.13 | 12.34% | 0.016 |
| 4 | 0.40 | 13.72% | 0.056 |
| 5 | 0.83 | 13.57% | 0.112 |
| 6 | 1.42 | 12.24% | 0.174 |
| 7 | 2.21 | 10.18% | 0.225 |
| 8 | 3.23 | 7.88% | 0.254 |
| 9 | 4.52 | 5.70% | 0.257 |
| 10 | 6.04 | 3.86% | 0.233 |
| 11 | 7.72 | 2.46% | 0.190 |
| 12 | 9.43 | 1.48% | 0.139 |
| 13 | 10.70 | 0.84% | 0.089 |
| 14 | 11.06 | 0.45% | 0.049 |
| 15 | 11.35 | 0.22% | 0.026 |
| 16 | 11.42 | 0.11% | 0.012 |
| 17 | 11.43 | 0.05% | 0.006 |
| 18 | 11.38 | 0.02% | 0.002 |
| 19 | 11.21 | 0.01% | 0.001 |
| 20 | 10.76 | 0.00% | 0.000 |
| Totals: | | 99.56% | 1.843 |

Weibull Calculations:
 Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous, 24 hour, basis.
 Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly average speeds is not recommended.

WindCad Turbine Performance Model

BWC EXCEL-S, Grid - Intertie

Tier/neo-SH3055-23-BWC

Prepared For: **Madison-Chatham Joint Meeting**
 Site Location: **214 North Passaic Avenue, Chatham, NJ**
 Data Source: **NASA**
 Date: **9/1/2010**

10 kW

| Inputs: | |
|---------------------|-------|
| Min. Wind (m/s) = | 3.81 |
| Weibull K = | 2 |
| Site Altitude (m) = | 106 |
| Wind Shear Exp. = | 0.180 |
| Anem. Height (m) = | 30 |
| Tower Height (m) = | 30 |
| Turbulence Factor = | 5.0% |

| Results: | |
|-------------------------------------|--------------|
| Hub Average Wind Speed (m/s) = | 3.81 |
| Air Density Factor = | -1% |
| Average Output Power (kW) = | 0.65 |
| Daily Energy Output (kWh) = | 15.6 |
| Annual Energy Output (kWh) = | 5,687 |
| Monthly Energy Output = | 474 |
| Percent Operating Time = | 51.2% |

Weibull Performance Calculations

| Wind Speed Bin (m/s) | Power (kW) | Wind Probability (f) | Net kW @ V |
|----------------------|------------|----------------------|------------|
| 1 | 0.00 | 10.33% | 0.000 |
| 2 | 0.00 | 17.55% | 0.000 |
| 3 | 0.13 | 20.04% | 0.026 |
| 4 | 0.40 | 18.23% | 0.074 |
| 5 | 0.83 | 13.95% | 0.115 |
| 6 | 1.42 | 9.18% | 0.130 |
| 7 | 2.21 | 5.27% | 0.117 |
| 8 | 3.23 | 2.66% | 0.086 |
| 9 | 4.52 | 1.18% | 0.053 |
| 10 | 6.04 | 0.47% | 0.028 |
| 11 | 7.72 | 0.16% | 0.013 |
| 12 | 9.43 | 0.05% | 0.005 |
| 13 | 10.70 | 0.01% | 0.002 |
| 14 | 11.06 | 0.00% | 0.000 |
| 15 | 11.35 | 0.00% | 0.000 |
| 16 | 11.42 | 0.00% | 0.000 |
| 17 | 11.43 | 0.00% | 0.000 |
| 18 | 11.38 | 0.00% | 0.000 |
| 19 | 11.21 | 0.00% | 0.000 |
| 20 | 10.76 | 0.00% | 0.000 |
| Totals: | | 99.09% | 0.649 |

Weibull Calculations:
 Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous, 24 hour, basis.
 Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly average speeds is not recommended.

APPENDIX M

WIND TURBINE ENERGY SYSTEM
FINANCIAL ANALYSIS

Molitor Water Pollution Control Facility
(Average Site Wind Speed @30m - 10.56 mph)

Annual kWh 10,618
 Engineer's Opinion of Probable Cost \$68,489.69

Assumptions

Annual System Degredation 0.50%
 Annual Utility Inflation 3.00%
 Annual Maintenance Costs \$0.02/kWh Production
 REC Factor \$25/MWh Production
 REIP Incentive \$3.20/kWh First 16,000 kWh
 \$0.50/kWh 16,000 kWh - 750,000 kWh

| Year | Utility Price | Annual Wind kWh Production | Utility Savings | Renewable Energy Credits (RECs) | Renewable Energy Incentive Program (REIP) | Maintenance Costs | Annual Cash Flow | Cumulative Cash Flow |
|------|---------------|----------------------------|-----------------|---------------------------------|---|-------------------|------------------|----------------------|
| 1 | 0.1514 | 10,618.0 | \$1,607.6 | \$265 | \$33,978 | (\$212) | \$1,660.7 | \$1,660.7 |
| 2 | 0.1559 | 10,564.9 | \$1,647.5 | \$264 | \$0 | (\$211) | \$1,700.3 | \$3,361.0 |
| 3 | 0.1606 | 10,512.1 | \$1,688.5 | \$263 | \$0 | (\$210) | \$1,741.0 | \$5,102.0 |
| 4 | 0.1654 | 10,459.5 | \$1,730.4 | \$261 | \$0 | (\$209) | \$1,782.7 | \$6,884.7 |
| 5 | 0.1704 | 10,407.2 | \$1,773.4 | \$260 | \$0 | (\$208) | \$1,825.4 | \$8,710.2 |
| 6 | 0.1755 | 10,355.2 | \$1,817.5 | \$259 | \$0 | (\$207) | \$1,869.3 | \$10,579.4 |
| 7 | 0.1808 | 10,303.4 | \$1,862.6 | \$258 | \$0 | (\$206) | \$1,914.2 | \$12,493.6 |
| 8 | 0.1862 | 10,251.9 | \$1,908.9 | \$256 | \$0 | (\$205) | \$1,960.2 | \$14,453.8 |
| 9 | 0.1918 | 10,200.6 | \$1,956.4 | \$255 | \$0 | (\$204) | \$2,007.4 | \$16,461.2 |
| 10 | 0.1975 | 10,149.6 | \$2,005.0 | \$254 | \$0 | (\$203) | \$2,055.7 | \$18,516.9 |
| 11 | 0.2035 | 10,098.9 | \$2,054.8 | \$252 | \$0 | (\$202) | \$2,105.3 | \$20,622.2 |
| 12 | 0.2096 | 10,048.4 | \$2,105.9 | \$251 | \$0 | (\$201) | \$2,156.1 | \$22,778.3 |
| 13 | 0.2159 | 9,998.2 | \$2,158.2 | \$250 | \$0 | (\$200) | \$2,208.2 | \$24,986.5 |
| 14 | 0.2223 | 9,948.2 | \$2,211.8 | \$249 | \$0 | (\$199) | \$2,261.6 | \$27,248.1 |
| 15 | 0.2290 | 9,898.4 | \$2,266.8 | \$247 | \$0 | (\$198) | \$2,316.3 | \$29,564.4 |
| 16 | 0.2359 | 9,848.9 | \$2,323.1 | \$246 | \$0 | (\$197) | \$2,372.4 | \$31,936.7 |
| 17 | 0.2430 | 9,799.7 | \$2,380.9 | \$245 | \$0 | (\$196) | \$2,429.9 | \$34,366.6 |
| 18 | 0.2502 | 9,750.7 | \$2,440.0 | \$244 | \$0 | (\$195) | \$2,488.8 | \$36,855.4 |
| 19 | 0.2577 | 9,701.9 | \$2,500.7 | \$243 | \$0 | (\$194) | \$2,549.2 | \$39,404.5 |
| 20 | 0.2655 | 9,653.4 | \$2,562.8 | \$241 | \$0 | (\$193) | \$2,611.1 | \$42,015.6 |
| 21 | 0.2734 | 9,605.2 | \$2,626.5 | \$240 | \$0 | (\$192) | \$2,674.5 | \$44,690.1 |
| 22 | 0.2816 | 9,557.1 | \$2,691.8 | \$239 | \$0 | (\$191) | \$2,739.5 | \$47,429.6 |
| 23 | 0.2901 | 9,509.3 | \$2,758.6 | \$238 | \$0 | (\$190) | \$2,806.2 | \$50,235.8 |
| 24 | 0.2988 | 9,461.8 | \$2,827.2 | \$237 | \$0 | (\$189) | \$2,874.5 | \$53,110.3 |
| 25 | 0.3078 | 9,414.5 | \$2,897.4 | \$235 | \$0 | (\$188) | \$2,944.5 | \$56,054.9 |

Molitor Water Pollution Control Facility
(Maximum Average Site Wind Speed @30m - 12.35 mph)

Annual kWh 16,144
 Engineer's Opinion of Probable Cost \$68,489.69

Assumptions

Annual System Degredation 0.50%
 Annual Utility Inflation 3.00%
 Annual Maintenance Costs \$0.02/kWh Production
 REC Factor \$25/MWh Production
 REIP Incentive \$3.20/kWh First 16,000 kWh
 \$0.50/kWh 16,000 kWh - 750,000 kWh

| Year | Utility Price | Annual Wind kWh Production | Utility Savings | Renewable Energy Credits (RECs) | Renewable Energy Incentive Program (REIP) | Maintenance Costs | Annual Cash Flow | Cumulative Cash Flow |
|------|---------------|----------------------------|-----------------|---------------------------------|---|-------------------|------------------|----------------------|
| 1 | 0.1514 | 16,144.0 | \$2,444.2 | \$404 | \$51,661 | (\$323) | \$2,524.9 | \$2,524.9 |
| 2 | 0.1559 | 16,063.3 | \$2,504.9 | \$402 | \$0 | (\$321) | \$2,585.3 | \$5,110.2 |
| 3 | 0.1606 | 15,983.0 | \$2,567.2 | \$400 | \$0 | (\$320) | \$2,647.1 | \$7,757.3 |
| 4 | 0.1654 | 15,903.0 | \$2,631.0 | \$398 | \$0 | (\$318) | \$2,710.5 | \$10,467.8 |
| 5 | 0.1704 | 15,823.5 | \$2,696.4 | \$396 | \$0 | (\$316) | \$2,775.5 | \$13,243.3 |
| 6 | 0.1755 | 15,744.4 | \$2,763.4 | \$394 | \$0 | (\$315) | \$2,842.1 | \$16,085.3 |
| 7 | 0.1808 | 15,665.7 | \$2,832.0 | \$392 | \$0 | (\$313) | \$2,910.4 | \$18,995.7 |
| 8 | 0.1862 | 15,587.4 | \$2,902.4 | \$390 | \$0 | (\$312) | \$2,980.3 | \$21,976.1 |
| 9 | 0.1918 | 15,509.4 | \$2,974.5 | \$388 | \$0 | (\$310) | \$3,052.1 | \$25,028.1 |
| 10 | 0.1975 | 15,431.9 | \$3,048.5 | \$386 | \$0 | (\$309) | \$3,125.6 | \$28,153.8 |
| 11 | 0.2035 | 15,354.7 | \$3,124.2 | \$384 | \$0 | (\$307) | \$3,201.0 | \$31,354.7 |
| 12 | 0.2096 | 15,277.9 | \$3,201.8 | \$382 | \$0 | (\$306) | \$3,278.2 | \$34,633.0 |
| 13 | 0.2159 | 15,201.6 | \$3,281.4 | \$380 | \$0 | (\$304) | \$3,357.4 | \$37,990.4 |
| 14 | 0.2223 | 15,125.6 | \$3,363.0 | \$378 | \$0 | (\$303) | \$3,438.6 | \$41,429.0 |
| 15 | 0.2290 | 15,049.9 | \$3,446.5 | \$376 | \$0 | (\$301) | \$3,521.8 | \$44,950.8 |
| 16 | 0.2359 | 14,974.7 | \$3,532.2 | \$374 | \$0 | (\$299) | \$3,607.0 | \$48,557.8 |
| 17 | 0.2430 | 14,899.8 | \$3,619.9 | \$372 | \$0 | (\$298) | \$3,694.4 | \$52,252.2 |
| 18 | 0.2502 | 14,825.3 | \$3,709.9 | \$371 | \$0 | (\$297) | \$3,784.0 | \$56,036.3 |
| 19 | 0.2577 | 14,751.2 | \$3,802.1 | \$369 | \$0 | (\$295) | \$3,875.8 | \$59,912.1 |
| 20 | 0.2655 | 14,677.4 | \$3,896.6 | \$367 | \$0 | (\$294) | \$3,970.0 | \$63,882.1 |
| 21 | 0.2734 | 14,604.0 | \$3,993.4 | \$365 | \$0 | (\$292) | \$4,066.4 | \$67,948.5 |
| 22 | 0.2816 | 14,531.0 | \$4,092.6 | \$363 | \$0 | (\$291) | \$4,165.3 | \$72,113.8 |
| 23 | 0.2901 | 14,458.4 | \$4,194.3 | \$361 | \$0 | (\$289) | \$4,266.6 | \$76,380.4 |
| 24 | 0.2988 | 14,386.1 | \$4,298.6 | \$360 | \$0 | (\$288) | \$4,370.5 | \$80,750.9 |
| 25 | 0.3078 | 14,314.1 | \$4,405.4 | \$358 | \$0 | (\$286) | \$4,477.0 | \$85,227.9 |

Molitor Water Pollution Control Facility
(Minimum Average Site Wind Speed @30m – 8.52 mph)

Annual kWh 5,687
 Engineer's Opinion of Probable Cost \$68,489.69

Assumptions

Annual System Degredation 0.50%
 Annual Utility Inflation 3.00%
 Annual Maintenance Costs \$0.02/kWh Production
 REC Factor \$25/MWh Production
 REIP Incentive \$3.20/kWh First 16,000 kWh
 \$0.50/kWh 16,000 kWh - 750,000 kWh

| Year | Utility Price | Annual Wind kWh Production | Utility Savings | Renewable Energy Credits (RECs) | Renewable Energy Incentive Program (REIP) | Maintenance Costs | Annual Cash Flow | Cumulative Cash Flow |
|------|---------------|----------------------------|-----------------|---------------------------------|---|-------------------|------------------|----------------------|
| 1 | 0.1514 | 5,687.0 | \$861.0 | \$142 | \$18,198 | (\$114) | \$889.4 | \$889.4 |
| 2 | 0.1559 | 5,658.6 | \$882.4 | \$141 | \$0 | (\$113) | \$910.7 | \$1,800.1 |
| 3 | 0.1606 | 5,630.3 | \$904.3 | \$141 | \$0 | (\$113) | \$932.5 | \$2,732.6 |
| 4 | 0.1654 | 5,602.1 | \$926.8 | \$140 | \$0 | (\$112) | \$954.8 | \$3,687.5 |
| 5 | 0.1704 | 5,574.1 | \$949.8 | \$139 | \$0 | (\$111) | \$977.7 | \$4,665.2 |
| 6 | 0.1755 | 5,546.2 | \$973.4 | \$139 | \$0 | (\$111) | \$1,001.2 | \$5,666.3 |
| 7 | 0.1808 | 5,518.5 | \$997.6 | \$138 | \$0 | (\$110) | \$1,025.2 | \$6,691.6 |
| 8 | 0.1862 | 5,490.9 | \$1,022.4 | \$137 | \$0 | (\$110) | \$1,049.9 | \$7,741.4 |
| 9 | 0.1918 | 5,463.5 | \$1,047.8 | \$137 | \$0 | (\$109) | \$1,075.1 | \$8,816.6 |
| 10 | 0.1975 | 5,436.1 | \$1,073.9 | \$136 | \$0 | (\$109) | \$1,101.1 | \$9,917.6 |
| 11 | 0.2035 | 5,409.0 | \$1,100.6 | \$135 | \$0 | (\$108) | \$1,127.6 | \$11,045.2 |
| 12 | 0.2096 | 5,381.9 | \$1,127.9 | \$135 | \$0 | (\$108) | \$1,154.8 | \$12,200.1 |
| 13 | 0.2159 | 5,355.0 | \$1,155.9 | \$134 | \$0 | (\$107) | \$1,182.7 | \$13,382.8 |
| 14 | 0.2223 | 5,328.2 | \$1,184.7 | \$133 | \$0 | (\$107) | \$1,211.3 | \$14,594.1 |
| 15 | 0.2290 | 5,301.6 | \$1,214.1 | \$133 | \$0 | (\$106) | \$1,240.6 | \$15,834.7 |
| 16 | 0.2359 | 5,275.1 | \$1,244.3 | \$132 | \$0 | (\$106) | \$1,270.6 | \$17,105.3 |
| 17 | 0.2430 | 5,248.7 | \$1,275.2 | \$131 | \$0 | (\$105) | \$1,301.4 | \$18,406.7 |
| 18 | 0.2502 | 5,222.5 | \$1,306.9 | \$131 | \$0 | (\$104) | \$1,333.0 | \$19,739.7 |
| 19 | 0.2577 | 5,196.4 | \$1,339.4 | \$130 | \$0 | (\$104) | \$1,365.3 | \$21,105.1 |
| 20 | 0.2655 | 5,170.4 | \$1,372.6 | \$129 | \$0 | (\$103) | \$1,398.5 | \$22,503.6 |
| 21 | 0.2734 | 5,144.5 | \$1,406.7 | \$129 | \$0 | (\$103) | \$1,432.5 | \$23,936.0 |
| 22 | 0.2816 | 5,118.8 | \$1,441.7 | \$128 | \$0 | (\$102) | \$1,467.3 | \$25,403.3 |
| 23 | 0.2901 | 5,093.2 | \$1,477.5 | \$127 | \$0 | (\$102) | \$1,503.0 | \$26,906.3 |
| 24 | 0.2988 | 5,067.7 | \$1,514.2 | \$127 | \$0 | (\$101) | \$1,539.6 | \$28,445.9 |
| 25 | 0.3078 | 5,042.4 | \$1,551.9 | \$126 | \$0 | (\$101) | \$1,577.1 | \$30,023.0 |

APPENDIX N

ECRM FINANCIAL ANALYSES

Lifetime Saving Analysis for Aeration System Alternatives

| ECM | Option 1 - Premium Eff Motors and VFDs on Aerators | Option 2 - Fine Bubble System |
|--------------------------------------|--|----------------------------------|
| Assumed Inflation (Gas) | 2% | 2% |
| Initial Yearly Savings (Gas) | | |
| Assumed Inflation (Electricity) | 3% | 3% |
| Initial Yearly Savings (Electricity) | \$20,293.00 | \$77,763.00 |
| Assumed Average Useful Life (Years) | 20 | 20 |
| Lifetime Savings | \$545,280.51 | \$2,089,520.93 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$20,293.00 | \$77,763.00 |
| 2 | \$20,901.79 | \$80,095.89 |
| 3 | \$21,528.84 | \$82,498.77 |
| 4 | \$22,174.71 | \$84,973.73 |
| 5 | \$22,839.95 | \$87,522.94 |
| 6 | \$23,525.15 | \$90,148.63 |
| 7 | \$24,230.90 | \$92,853.09 |
| 8 | \$24,957.83 | \$95,638.68 |
| 9 | \$25,706.57 | \$98,507.84 |
| 10 | \$26,477.76 | \$101,463.08 |
| 11 | \$27,272.10 | \$104,506.97 |
| 12 | \$28,090.26 | \$107,642.18 |
| 13 | \$28,932.97 | \$110,871.44 |
| 14 | \$29,800.95 | \$114,197.59 |
| 15 | \$30,694.98 | \$117,623.51 |
| 16 | \$31,615.83 | \$121,152.22 |
| 17 | \$32,564.31 | \$124,786.79 |
| 18 | \$33,541.24 | \$128,530.39 |
| 19 | \$34,547.47 | \$132,386.30 |
| 20 | \$35,583.90 | \$136,357.89 |

IRR, NPV, AROI - Aeration System ECRMs

Financial Calculations

Based on inflation of: 3%

| Option 1 | | | Option 2 | | |
|---|----------------|------------|-----------------------------|----------------|---------------|
| Premium Efficiency Motors and VFDs on Mechanical Aerators | | | Fine Bubble Diffuser System | | |
| Year | Energy Savings | Cash Flow | Year | Energy Savings | Cash Flow |
| 0 | | (\$85,076) | 0 | | (\$1,357,000) |
| 1 | \$20,293 | \$15,293 | 1 | \$77,763 | \$81,763 |
| 2 | \$20,902 | \$15,902 | 2 | \$80,096 | \$84,096 |
| 3 | \$21,529 | \$16,529 | 3 | \$82,499 | \$86,499 |
| 4 | \$22,175 | \$17,175 | 4 | \$84,974 | \$88,974 |
| 5 | \$22,840 | \$17,840 | 5 | \$87,523 | \$91,523 |
| 6 | \$23,525 | \$18,525 | 6 | \$90,149 | \$94,149 |
| 7 | \$24,231 | \$19,231 | 7 | \$92,853 | \$96,853 |
| 8 | \$24,958 | \$19,958 | 8 | \$95,639 | \$99,639 |
| 9 | \$25,707 | \$20,707 | 9 | \$98,508 | \$102,508 |
| 10 | \$26,478 | \$21,478 | 10 | \$101,463 | \$105,463 |
| 11 | \$27,272 | \$22,272 | 11 | \$104,507 | \$108,507 |
| 12 | \$28,090 | \$23,090 | 12 | \$107,642 | \$111,642 |
| 13 | \$28,933 | \$23,933 | 13 | \$110,871 | \$114,871 |
| 14 | \$29,801 | \$24,801 | 14 | \$114,198 | \$118,198 |
| 15 | \$30,695 | \$25,695 | 15 | \$117,624 | \$121,624 |
| 16 | \$31,616 | \$26,616 | 16 | \$121,152 | \$125,152 |
| 17 | \$32,564 | \$27,564 | 17 | \$124,787 | \$128,787 |
| 18 | \$33,541 | \$28,541 | 18 | \$128,530 | \$132,530 |
| 19 | \$34,547 | \$29,547 | 19 | \$132,386 | \$136,386 |
| 20 | \$35,584 | \$30,584 | 20 | \$136,358 | \$140,358 |
| | IRR | 20.97% | | IRR | 1.25% |
| | NPV | \$234,575 | | NPV | \$212,471.06 |
| | AROI | 12.98% | | AROI | 1.03% |

**Table 4.1-9
Oxidation Ditch System Improvements**

| | Alt. 1 – VFDs on Existing Aerators | Alt. 2 – New Aerators with VFDs | Alt. 3 - New Two-Speed Aerators |
|-------------------------------|------------------------------------|---------------------------------|---------------------------------|
| Installation Cost | \$384,000 | \$631,000 | \$445,000 |
| New Jersey SmartStart Rebate | \$540 | \$0 | \$0 |
| Total Cost | \$383,460 | \$631,000 | \$445,000 |
| Annual Energy Savings | \$60,400 | \$75,900 | \$50,100 |
| Annual O&M Cost | \$4,000 | \$4,000 | \$4,000 |
| Simple Payback Period, years | 6.8 | 8.8 | 9.7 |
| Lifetime, years | 20 | 20 | 20 |
| Internal Rate of Return (IRR) | 14.7% | 10.4% | 9.4% |
| Net Present Value (NPV) | \$515,000 | \$498,000 | \$300,000 |

assume \$2000/yr per unit

\$0.1514 per kWh

Energy Savings Breakdown

| | | | | |
|-----------------------|-----------|-----------|-----------|--|
| current estimated use | \$168,600 | \$168,600 | \$168,600 | assumes avg hp now = 150 hp and 88% efficient motors |
| future average HP use | 105 | 90 | 115 | assumes avg flows/loads stay the same |
| future savings | \$108,200 | \$92,700 | \$118,500 | assumes 96% efficient motors (new) |
| savings | \$60,400 | \$75,900 | \$50,100 | |

Year

| | | | |
|------------|-------------|-------------|-------------|
| 0 | (\$383,460) | (\$631,000) | (\$445,000) |
| 1 | \$60,400 | \$75,900 | \$50,100 |
| 2 | \$60,400 | \$75,900 | \$50,100 |
| 3 | \$60,400 | \$75,900 | \$50,100 |
| 4 | \$60,400 | \$75,900 | \$50,100 |
| 5 | \$60,400 | \$75,900 | \$50,100 |
| 6 | \$60,400 | \$75,900 | \$50,100 |
| 7 | \$60,400 | \$75,900 | \$50,100 |
| 8 | \$60,400 | \$75,900 | \$50,100 |
| 9 | \$60,400 | \$75,900 | \$50,100 |
| 10 | \$60,400 | \$75,900 | \$50,100 |
| 11 | \$60,400 | \$75,900 | \$50,100 |
| 12 | \$60,400 | \$75,900 | \$50,100 |
| 13 | \$60,400 | \$75,900 | \$50,100 |
| 14 | \$60,400 | \$75,900 | \$50,100 |
| 15 | \$60,400 | \$75,900 | \$50,100 |
| 16 | \$60,400 | \$75,900 | \$50,100 |
| 17 | \$60,400 | \$75,900 | \$50,100 |
| 18 | \$60,400 | \$75,900 | \$50,100 |
| 19 | \$60,400 | \$75,900 | \$50,100 |
| 20 | \$60,400 | \$75,900 | \$50,100 |
| IRR | 15% | 10% | 9% |
| NPV | \$515,139 | \$498,200 | \$300,361 |

| Table 4.1-10 Post Aeration System Improvements | | | | |
|---|---|-----------------------|---|---|
| | Alt. 1 – New Motors, VFDs & DO Control System | Alt. 2 – New Aerators | Alt. 3 – New Aerators, VFDs & DO Control System | Alt. 4 – New Solar Aerators & DO Control System |
| Installation Cost | \$161,000 | \$113,000 | \$301,000 | \$355,134 |
| New Jersey SmartStart Rebate | \$360 | \$0 | \$0 | \$180 |
| Total Cost | \$160,640 | \$113,000 | \$301,000 | \$354,954 |
| Annual Energy Savings | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| Annual O&M Cost | \$1,000 | \$0 | \$1,000 | \$2,650 |
| Simple Payback Period, years | 33.5 | 31.4 | 33.1 | 13.5 |
| Lifetime, years | 20 | 20 | 20 | 20 |
| Internal Rate of Return (IRR) | -2.9% | -4.0% | -3.5% | 5.2% |
| Net Present Value (NPV) | -\$74,000 | -\$59,000 | -\$151,000 | \$75,000 |

assume \$500/yr for DO control system, \$500/yr for VFDs, \$750/yr for ea solar unit + \$150/yr

\$0.1514 per kWh

Energy Savings Breakdown

| | Alt. 1 | Alt. 2 | Alt. 3 | Alt. 4 | Notes |
|-----------------------|----------|----------|----------|----------|---|
| current estimated use | \$36,000 | \$36,000 | \$36,000 | \$36,000 | assumes avg hp now = 30 hp and 82.5% motor efficiency |
| future average HP use | 28 | 30 | 24 | 20 | assumes avg flows/loads stay the same |
| future | \$30,200 | \$32,400 | \$25,900 | \$7,100 | assumes 91.7% motor efficiency |
| savings | \$5,800 | \$3,600 | \$10,100 | \$28,900 | |

| Year | Alt. 1 | Alt. 2 | Alt. 3 | Alt. 4 |
|------------|-------------|-------------|-------------|-------------|
| 0 | (\$160,640) | (\$113,000) | (\$301,000) | (\$354,954) |
| 1 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 2 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 3 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 4 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 5 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 6 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 7 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 8 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 9 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 10 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 11 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 12 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 13 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 14 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 15 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 16 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 17 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 18 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 19 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| 20 | \$5,800 | \$3,600 | \$10,100 | \$28,900 |
| IRR | -2.92% | -3.96% | -3.53% | 5.17% |
| NPV | (\$74,351) | (\$59,441) | (\$150,738) | \$75,005 |

Lifetime Savings Analysis for Sludge Processing Alternatives

| ECM | Option 1 - TWAS Addition | Option 2 - TWAS & FOG Addition | Option 3 - TWAS & PHS Addition |
|--------------------------------------|---------------------------------|---|---|
| Assumed Inflation (Gas) | 3% | 3% | 3% |
| Initial Yearly Savings (Gas) | \$14,805.00 | \$36,422.00 | \$24,670.00 |
| Assumed Inflation (Electricity) | 3% | 3% | 3% |
| Initial Yearly Savings (Electricity) | | | |
| Assumed Average Useful Life (Years) | 20 | 20 | 20 |
| Lifetime Savings | \$397,815.89 | \$978,672.78 | \$662,892.14 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$14,805.00 | \$36,422.00 | \$24,670.00 |
| 2 | \$15,249.15 | \$37,514.66 | \$25,410.10 |
| 3 | \$15,706.62 | \$38,640.10 | \$26,172.40 |
| 4 | \$16,177.82 | \$39,799.30 | \$26,957.58 |
| 5 | \$16,663.16 | \$40,993.28 | \$27,766.30 |
| 6 | \$17,163.05 | \$42,223.08 | \$28,599.29 |
| 7 | \$17,677.94 | \$43,489.77 | \$29,457.27 |
| 8 | \$18,208.28 | \$44,794.47 | \$30,340.99 |
| 9 | \$18,754.53 | \$46,138.30 | \$31,251.22 |
| 10 | \$19,317.17 | \$47,522.45 | \$32,188.75 |
| 11 | \$19,896.68 | \$48,948.12 | \$33,154.42 |
| 12 | \$20,493.58 | \$50,416.57 | \$34,149.05 |
| 13 | \$21,108.39 | \$51,929.06 | \$35,173.52 |
| 14 | \$21,741.64 | \$53,486.93 | \$36,228.73 |
| 15 | \$22,393.89 | \$55,091.54 | \$37,315.59 |
| 16 | \$23,065.71 | \$56,744.29 | \$38,435.06 |
| 17 | \$23,757.68 | \$58,446.62 | \$39,588.11 |
| 18 | \$24,470.41 | \$60,200.02 | \$40,775.75 |
| 19 | \$25,204.52 | \$62,006.02 | \$41,999.02 |
| 20 | \$25,960.66 | \$63,866.20 | \$43,258.99 |

IRR, NPV, AROI - Digestion System ECRMs

Financial Calculations

Based on inflation of: 3%

| Option 1 | | | Option 2 | | | Option 3 | | |
|---------------|----------------|--------------|-----------------------|----------------|--------------|-----------------------|----------------|--------------|
| TWAS Addition | | | TWAS and FOG Addition | | | TWAS and PHS Addition | | |
| Year | Energy Savings | Cash Flow | Year | Energy Savings | Cash Flow | Year | Energy Savings | Cash Flow |
| 0 | | (\$15,600) | 0 | | (\$409,656) | 0 | | (\$15,600) |
| 1 | \$14,805 | \$14,805 | 1 | \$36,422 | \$47,030 | 1 | 24,670 | \$2,138 |
| 2 | \$15,249 | \$15,249 | 2 | \$37,515 | \$48,123 | 2 | 25,410 | \$2,878 |
| 3 | \$15,707 | \$15,707 | 3 | \$38,640 | \$49,248 | 3 | 26,172 | \$3,640 |
| 4 | \$16,178 | \$16,178 | 4 | \$39,799 | \$50,407 | 4 | 26,958 | \$4,426 |
| 5 | \$16,663 | \$16,663 | 5 | \$40,993 | \$51,601 | 5 | 27,766 | \$5,234 |
| 6 | \$17,163 | \$17,163 | 6 | \$42,223 | \$52,831 | 6 | 28,599 | \$6,067 |
| 7 | \$17,678 | \$17,678 | 7 | \$43,490 | \$54,098 | 7 | 29,457 | \$6,925 |
| 8 | \$18,208 | \$18,208 | 8 | \$44,794 | \$55,402 | 8 | 30,341 | \$7,809 |
| 9 | \$18,755 | \$18,755 | 9 | \$46,138 | \$56,746 | 9 | 31,251 | \$8,719 |
| 10 | \$19,317 | \$19,317 | 10 | \$47,522 | \$58,130 | 10 | 32,189 | \$9,657 |
| 11 | \$19,897 | \$19,897 | 11 | \$48,948 | \$59,556 | 11 | 33,154 | \$10,622 |
| 12 | \$20,494 | \$20,494 | 12 | \$50,417 | \$61,025 | 12 | 34,149 | \$11,617 |
| 13 | \$21,108 | \$21,108 | 13 | \$51,929 | \$62,537 | 13 | 35,174 | \$12,642 |
| 14 | \$21,742 | \$21,742 | 14 | \$53,487 | \$64,095 | 14 | 36,229 | \$13,697 |
| 15 | \$22,394 | \$22,394 | 15 | \$55,092 | \$65,700 | 15 | 37,316 | \$14,784 |
| 16 | \$23,066 | \$23,066 | 16 | \$56,744 | \$67,352 | 16 | 38,435 | \$15,903 |
| 17 | \$23,758 | \$23,758 | 17 | \$58,447 | \$69,055 | 17 | 39,588 | \$17,056 |
| 18 | \$24,470 | \$24,470 | 18 | \$60,200 | \$70,808 | 18 | 40,776 | \$18,244 |
| 19 | \$25,205 | \$25,205 | 19 | \$62,006 | \$72,614 | 19 | 41,999 | \$19,467 |
| 20 | \$25,961 | \$25,961 | 20 | \$63,866 | \$74,474 | 20 | 43,259 | \$20,727 |
| | IRR | 97.90% | | IRR | 11.95% | | IRR | 30.24% |
| | NPV | \$271,875.73 | | NPV | \$455,387.55 | | NPV | \$128,209.86 |
| | AROI | 89.90% | | AROI | 6.48% | | AROI | 8.71% |

| ECM | Blower Building - Boiler Upgrade | Blower Building - Pipe Insulation |
|--------------------------------------|----------------------------------|-----------------------------------|
| Assumed Inflation (Gas) | 2% | 2% |
| Initial Yearly Savings (Gas) | \$172.00 | \$1,475.00 |
| Assumed Inflation (Electricity) | 3% | 3% |
| Initial Yearly Savings (Electricity) | | |
| Assumed Average Useful Life (Years) | 25 | 24 |
| Lifetime Savings | \$5,509.21 | \$44,872.25 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$172.00 | \$1,475.00 |
| 2 | \$175.44 | \$1,504.50 |
| 3 | \$178.95 | \$1,534.59 |
| 4 | \$182.53 | \$1,565.28 |
| 5 | \$186.18 | \$1,596.59 |
| 6 | \$189.90 | \$1,628.52 |
| 7 | \$193.70 | \$1,661.09 |
| 8 | \$197.57 | \$1,694.31 |
| 9 | \$201.53 | \$1,728.20 |
| 10 | \$205.56 | \$1,762.76 |
| 11 | \$209.67 | \$1,798.02 |
| 12 | \$213.86 | \$1,833.98 |
| 13 | \$218.14 | \$1,870.66 |
| 14 | \$222.50 | \$1,908.07 |
| 15 | \$226.95 | \$1,946.23 |
| 16 | \$231.49 | \$1,985.16 |
| 17 | \$236.12 | \$2,024.86 |
| 18 | \$240.84 | \$2,065.36 |
| 19 | \$245.66 | \$2,106.66 |
| 20 | \$250.57 | \$2,148.80 |
| 21 | \$255.58 | \$2,191.77 |
| 22 | \$260.69 | \$2,235.61 |
| 23 | \$265.91 | \$2,280.32 |
| 24 | \$271.23 | \$2,325.93 |
| 25 | \$276.65 | |

IRR, NPV, AROI - HVAC ECRMS

| Boiler Upgrade Blower Building | | Pipe Insulation Blower Building | |
|-----------------------------------|---------------|------------------------------------|-------------|
| Year | Cash Flow | Year | Cash Flow |
| 0 | (\$15,071.00) | 0 | (\$955.00) |
| 1 | \$172.00 | 1 | \$1,475.00 |
| 2 | \$177.16 | 2 | \$1,519.25 |
| 3 | \$182.47 | 3 | \$1,564.83 |
| 4 | \$187.95 | 4 | \$1,611.77 |
| 5 | \$193.59 | 5 | \$1,660.13 |
| 6 | \$199.40 | 6 | \$1,709.93 |
| 7 | \$205.38 | 7 | \$1,761.23 |
| 8 | \$211.54 | 8 | \$1,814.06 |
| 9 | \$217.88 | 9 | \$1,868.49 |
| 10 | \$224.42 | 10 | \$1,924.54 |
| 11 | \$231.15 | 11 | \$1,982.28 |
| 12 | \$238.09 | 12 | \$2,041.74 |
| 13 | \$245.23 | 13 | \$2,103.00 |
| 14 | \$252.59 | 14 | \$2,166.09 |
| 15 | \$260.17 | 15 | \$2,231.07 |
| 16 | \$267.97 | 16 | \$2,298.00 |
| 17 | \$276.01 | 17 | \$2,366.94 |
| 18 | \$284.29 | 18 | \$2,437.95 |
| 19 | \$292.82 | 19 | \$2,511.09 |
| 20 | \$301.60 | 20 | \$2,586.42 |
| 21 | \$310.65 | 21 | \$2,664.01 |
| 22 | \$319.97 | 22 | \$2,743.93 |
| 23 | \$329.57 | 23 | \$2,826.25 |
| 24 | \$339.46 | 24 | \$2,911.04 |
| 25 | \$349.64 | | |
| IRR | -5.38% | IRR | 157.45% |
| NPV | (\$10,896.24) | NPV | \$33,413.93 |
| AROI | -2.86% | AROI | 150.28% |

IRR, NPV, AROI - PV Solar Energy System

Financial Calculations

Based on inflation of: 3%
O&M inflation: 3%

| Molitor Water Pollution Control Facility | | | |
|---|----------------|------------|----------------|
| Year | Energy Savings | SREC Sales | Cash Flow |
| 0 | | | (\$15,248,668) |
| 1 | \$242,443.6 | \$677,369 | \$919,813 |
| 2 | \$248,468.4 | \$673,982 | \$922,450 |
| 3 | \$254,642.8 | \$670,612 | \$925,255 |
| 4 | \$260,970.7 | \$667,259 | \$928,230 |
| 5 | \$267,455.8 | \$663,923 | \$931,379 |
| 6 | \$274,102.1 | \$660,603 | \$934,705 |
| 7 | \$280,913.5 | \$657,300 | \$938,214 |
| 8 | \$287,894.2 | \$654,014 | \$941,908 |
| 9 | \$295,048.4 | \$650,744 | \$945,792 |
| 10 | \$302,380.3 | \$647,490 | \$949,870 |
| 11 | \$309,894.5 | \$644,252 | \$954,147 |
| 12 | \$317,595.4 | \$641,031 | \$958,627 |
| 13 | \$325,487.6 | \$637,826 | \$963,314 |
| 14 | \$333,576.0 | \$634,637 | \$968,213 |
| 15 | \$341,865.3 | \$631,464 | \$973,329 |
| 16 | \$350,360.7 | \$37,134 | \$387,495 |
| 17 | \$359,067.1 | \$36,948 | \$396,015 |
| 18 | \$367,990.0 | \$36,764 | \$404,754 |
| 19 | \$377,134.5 | \$36,580 | \$413,714 |
| 20 | \$386,506.3 | \$36,397 | \$422,903 |
| 21 | \$396,111.0 | \$36,215 | \$432,326 |
| 22 | \$405,954.3 | \$36,034 | \$441,988 |
| 23 | \$416,042.3 | \$35,854 | \$451,896 |
| 24 | \$426,381.0 | \$35,674 | \$462,055 |
| 25 | \$436,976.5 | \$35,496 | \$472,472 |
| | IRR | | 1.8% |
| | NPV | | -\$1,674,030 |
| | AROI | | 2.0% |

IRR, NPV, AROI - Wind Energy System

Molitor Water Pollution Control Facility

Financial Calculations

Based on inflation of: 3%
O&M inflation: 3%

| Wind Turbine - Minimum Wind Speed | | | |
|--|----------------|-----------|---------------|
| REIP Incentive: \$18,198 | | | |
| Year | Energy Savings | REC Sales | Cash Flow |
| 0 | | | (\$50,291.69) |
| 1 | \$861 | \$142 | \$1,003 |
| 2 | \$882 | \$141 | \$1,024 |
| 3 | \$904 | \$141 | \$1,045 |
| 4 | \$927 | \$140 | \$1,067 |
| 5 | \$950 | \$139 | \$1,089 |
| 6 | \$973 | \$139 | \$1,112 |
| 7 | \$998 | \$138 | \$1,136 |
| 8 | \$1,022 | \$137 | \$1,160 |
| 9 | \$1,048 | \$137 | \$1,184 |
| 10 | \$1,074 | \$136 | \$1,210 |
| 11 | \$1,101 | \$135 | \$1,236 |
| 12 | \$1,128 | \$135 | \$1,262 |
| 13 | \$1,156 | \$134 | \$1,290 |
| 14 | \$1,185 | \$133 | \$1,318 |
| 15 | \$1,214 | \$133 | \$1,347 |
| 16 | \$1,244 | \$132 | \$1,376 |
| 17 | \$1,275 | \$131 | \$1,406 |
| 18 | \$1,307 | \$131 | \$1,437 |
| 19 | \$1,339 | \$130 | \$1,469 |
| 20 | \$1,373 | \$129 | \$1,502 |
| 21 | \$1,407 | \$129 | \$1,535 |
| 22 | \$1,442 | \$128 | \$1,570 |
| 23 | \$1,478 | \$127 | \$1,605 |
| 24 | \$1,514 | \$127 | \$1,641 |
| 25 | \$1,552 | \$126 | \$1,678 |
| | IRR | | -2.9% |
| | NPV | | -\$28,250 |
| | AROI | | -2.0% |

| Wind Turbine - Maximum Wind Speed | | | |
|--|----------------|-----------|---------------|
| REIP Incentive: \$51,661 | | | |
| Year | Energy Savings | REC Sales | Cash Flow |
| 0 | | | (\$16,828.69) |
| 1 | \$2,444 | \$404 | \$2,848 |
| 2 | \$2,505 | \$402 | \$2,907 |
| 3 | \$2,567 | \$400 | \$2,967 |
| 4 | \$2,631 | \$398 | \$3,029 |
| 5 | \$2,696 | \$396 | \$3,092 |
| 6 | \$2,763 | \$394 | \$3,157 |
| 7 | \$2,832 | \$392 | \$3,224 |
| 8 | \$2,902 | \$390 | \$3,292 |
| 9 | \$2,975 | \$388 | \$3,362 |
| 10 | \$3,048 | \$386 | \$3,434 |
| 11 | \$3,124 | \$384 | \$3,508 |
| 12 | \$3,202 | \$382 | \$3,584 |
| 13 | \$3,281 | \$380 | \$3,661 |
| 14 | \$3,363 | \$378 | \$3,741 |
| 15 | \$3,447 | \$376 | \$3,823 |
| 16 | \$3,532 | \$374 | \$3,907 |
| 17 | \$3,620 | \$372 | \$3,992 |
| 18 | \$3,710 | \$371 | \$4,081 |
| 19 | \$3,802 | \$369 | \$4,171 |
| 20 | \$3,897 | \$367 | \$4,264 |
| 21 | \$3,993 | \$365 | \$4,359 |
| 22 | \$4,093 | \$363 | \$4,456 |
| 23 | \$4,194 | \$361 | \$4,556 |
| 24 | \$4,299 | \$360 | \$4,658 |
| 25 | \$4,405 | \$358 | \$4,763 |
| | IRR | | 18.6% |
| | NPV | | \$45,742 |
| | AROI | | 12.9% |

| Wind Turbine - Average Wind Speed | | | |
|--|----------------|-----------|---------------|
| REIP Incentive: \$33,978 | | | |
| Year | Energy Savings | REC Sales | Cash Flow |
| 0 | | | (\$34,511.69) |
| 1 | \$1,608 | \$265 | \$1,873 |
| 2 | \$1,648 | \$264 | \$1,912 |
| 3 | \$1,688 | \$263 | \$1,951 |
| 4 | \$1,730 | \$261 | \$1,992 |
| 5 | \$1,773 | \$260 | \$2,034 |
| 6 | \$1,817 | \$259 | \$2,076 |
| 7 | \$1,863 | \$258 | \$2,120 |
| 8 | \$1,909 | \$256 | \$2,165 |
| 9 | \$1,956 | \$255 | \$2,211 |
| 10 | \$2,005 | \$254 | \$2,259 |
| 11 | \$2,055 | \$252 | \$2,307 |
| 12 | \$2,106 | \$251 | \$2,357 |
| 13 | \$2,158 | \$250 | \$2,408 |
| 14 | \$2,212 | \$249 | \$2,461 |
| 15 | \$2,267 | \$247 | \$2,514 |
| 16 | \$2,323 | \$246 | \$2,569 |
| 17 | \$2,381 | \$245 | \$2,626 |
| 18 | \$2,440 | \$244 | \$2,684 |
| 19 | \$2,501 | \$243 | \$2,743 |
| 20 | \$2,563 | \$241 | \$2,804 |
| 21 | \$2,626 | \$240 | \$2,867 |
| 22 | \$2,692 | \$239 | \$2,931 |
| 23 | \$2,759 | \$238 | \$2,996 |
| 24 | \$2,827 | \$237 | \$3,064 |
| 25 | \$2,897 | \$235 | \$3,133 |
| | IRR | | 4.5% |
| | NPV | | \$6,642 |
| | AROI | | 1.4% |

| ECM | Molitor Water Pollution Treatment Plant - Solar PV System |
|--------------------------------------|---|
| Assumed Inflation (Gas) | |
| Initial Yearly Savings (Gas) | |
| Assumed Inflation (Electricity) | 3% |
| Initial Yearly Savings (Electricity) | \$242,443.60 |
| Assumed Average Useful Life (Years) | 25 |
| Lifetime Savings | \$8,839,315.30 |
| <u>Year</u> | <u>Annual Savings</u> |
| 1 | \$242,443.60 |
| 2 | \$249,716.91 |
| 3 | \$257,208.42 |
| 4 | \$264,924.67 |
| 5 | \$272,872.41 |
| 6 | \$281,058.58 |
| 7 | \$289,490.34 |
| 8 | \$298,175.05 |
| 9 | \$307,120.30 |
| 10 | \$316,333.91 |
| 11 | \$325,823.93 |
| 12 | \$335,598.64 |
| 13 | \$345,666.60 |
| 14 | \$356,036.60 |
| 15 | \$366,717.70 |
| 16 | \$377,719.23 |
| 17 | \$389,050.81 |
| 18 | \$400,722.33 |
| 19 | \$412,744.00 |
| 20 | \$425,126.32 |
| 21 | \$437,880.11 |
| 22 | \$451,016.51 |
| 23 | \$464,547.01 |
| 24 | \$478,483.42 |
| 25 | \$492,837.92 |

| ECM | Wind Turbine - Min Wind Speed | Wind Turbine - Max Wind Speed | Wind Turbine - Avg wind Speed |
|--------------------------------------|-------------------------------|-------------------------------|-------------------------------|
| Assumed Inflation (Gas) | | | |
| Initial Yearly Savings (Gas) | | | |
| Assumed Inflation (Electricity) | 3% | 3% | 3% |
| Initial Yearly Savings (Electricity) | \$861.00 | \$2,444.20 | \$1,607.60 |
| Assumed Average Useful Life (Years) | 25 | 25 | 25 |
| Lifetime Savings | \$31,391.43 | \$89,113.73 | \$58,611.91 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$861.00 | \$2,444.20 | \$1,607.60 |
| 2 | \$886.83 | \$2,517.53 | \$1,655.83 |
| 3 | \$913.43 | \$2,593.05 | \$1,705.50 |
| 4 | \$940.84 | \$2,670.84 | \$1,756.67 |
| 5 | \$969.06 | \$2,750.97 | \$1,809.37 |
| 6 | \$998.13 | \$2,833.50 | \$1,863.65 |
| 7 | \$1,028.08 | \$2,918.50 | \$1,919.56 |
| 8 | \$1,058.92 | \$3,006.06 | \$1,977.15 |
| 9 | \$1,090.69 | \$3,096.24 | \$2,036.46 |
| 10 | \$1,123.41 | \$3,189.13 | \$2,097.55 |
| 11 | \$1,157.11 | \$3,284.80 | \$2,160.48 |
| 12 | \$1,191.83 | \$3,383.34 | \$2,225.29 |
| 13 | \$1,227.58 | \$3,484.84 | \$2,292.05 |
| 14 | \$1,264.41 | \$3,589.39 | \$2,360.81 |
| 15 | \$1,302.34 | \$3,697.07 | \$2,431.64 |
| 16 | \$1,341.41 | \$3,807.98 | \$2,504.59 |
| 17 | \$1,381.65 | \$3,922.22 | \$2,579.73 |
| 18 | \$1,423.10 | \$4,039.89 | \$2,657.12 |
| 19 | \$1,465.79 | \$4,161.09 | \$2,736.83 |
| 20 | \$1,509.77 | \$4,285.92 | \$2,818.94 |
| 21 | \$1,555.06 | \$4,414.50 | \$2,903.50 |
| 22 | \$1,601.71 | \$4,546.93 | \$2,990.61 |
| 23 | \$1,649.77 | \$4,683.34 | \$3,080.33 |
| 24 | \$1,699.26 | \$4,823.84 | \$3,172.74 |
| 25 | \$1,750.24 | \$4,968.56 | \$3,267.92 |

| ECM | Administration Building - Interior | Grit Building - Interior | Digester #1 Building - Interior | Digester #2 Building - Interior | Waste Oil Building - Interior | Blower Building - Interior | Sludge Handling Building - Interior | Final Clarifier #1 & #2 Building - Interior | Final Clarifier #3 & #4 Building - Interior |
|--------------------------------------|------------------------------------|--------------------------|---------------------------------|---------------------------------|-------------------------------|----------------------------|-------------------------------------|---|---|
| Assumed Inflation (Gas) | | | | | | | | | |
| Initial Yearly Savings (Gas) | | | | | | | | | |
| Assumed Inflation (Electricity) | 3% | 3% | 3% | 3% | 3% | 3% | 3% | 3% | 3% |
| Initial Yearly Savings (Electricity) | \$1,369.40 | \$0.00 | \$0.00 | \$0.00 | \$50.40 | \$134.90 | \$975.40 | \$16.20 | \$167.50 |
| Assumed Average Useful Life (Years) | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 |
| Lifetime Savings | \$25,469.35 | \$0.00 | \$0.00 | \$0.00 | \$937.39 | \$2,508.99 | \$18,141.38 | \$301.30 | \$3,115.32 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$1,369.40 | \$0.00 | \$0.00 | \$0.00 | \$50.40 | \$134.90 | \$975.40 | \$16.20 | \$167.50 |
| 2 | \$1,410.48 | \$0.00 | \$0.00 | \$0.00 | \$51.91 | \$138.95 | \$1,004.66 | \$16.69 | \$172.53 |
| 3 | \$1,452.80 | \$0.00 | \$0.00 | \$0.00 | \$53.47 | \$143.12 | \$1,034.80 | \$17.19 | \$177.70 |
| 4 | \$1,496.38 | \$0.00 | \$0.00 | \$0.00 | \$55.07 | \$147.41 | \$1,065.85 | \$17.70 | \$183.03 |
| 5 | \$1,541.27 | \$0.00 | \$0.00 | \$0.00 | \$56.73 | \$151.83 | \$1,097.82 | \$18.23 | \$188.52 |
| 6 | \$1,587.51 | \$0.00 | \$0.00 | \$0.00 | \$58.43 | \$156.39 | \$1,130.76 | \$18.78 | \$194.18 |
| 7 | \$1,635.14 | \$0.00 | \$0.00 | \$0.00 | \$60.18 | \$161.08 | \$1,164.68 | \$19.34 | \$200.00 |
| 8 | \$1,684.19 | \$0.00 | \$0.00 | \$0.00 | \$61.99 | \$165.91 | \$1,199.62 | \$19.92 | \$206.00 |
| 9 | \$1,734.71 | \$0.00 | \$0.00 | \$0.00 | \$63.85 | \$170.89 | \$1,235.61 | \$20.52 | \$212.18 |
| 10 | \$1,786.76 | \$0.00 | \$0.00 | \$0.00 | \$65.76 | \$176.01 | \$1,272.68 | \$21.14 | \$218.55 |
| 11 | \$1,840.36 | \$0.00 | \$0.00 | \$0.00 | \$67.73 | \$181.29 | \$1,310.86 | \$21.77 | \$225.11 |
| 12 | \$1,895.57 | \$0.00 | \$0.00 | \$0.00 | \$69.77 | \$186.73 | \$1,350.18 | \$22.42 | \$231.86 |
| 13 | \$1,952.44 | \$0.00 | \$0.00 | \$0.00 | \$71.86 | \$192.34 | \$1,390.69 | \$23.10 | \$238.81 |
| 14 | \$2,011.01 | \$0.00 | \$0.00 | \$0.00 | \$74.01 | \$198.11 | \$1,432.41 | \$23.79 | \$245.98 |
| 15 | \$2,071.34 | \$0.00 | \$0.00 | \$0.00 | \$76.23 | \$204.05 | \$1,475.38 | \$24.50 | \$253.36 |

| ECM | Administration Building - Exterior | Grit Building - Exterior | Digester #1 Building - Exterior | Digester #2 Building - Exterior | Waste Oil Building - Exterior | Blower Building - Exterior | Sludge Handling Building - Exterior | Final Clarifier #1 & #2 Building - Exterior | Final Clarifier #3 & #4 Building - Exterior | Roadway & Process Lighting - Exterior |
|--------------------------------------|------------------------------------|--------------------------|---------------------------------|---------------------------------|-------------------------------|----------------------------|-------------------------------------|---|---|---------------------------------------|
| Assumed Inflation (Gas) | | | | | | | | | | |
| Initial Yearly Savings (Gas) | | | | | | | | | | |
| Assumed Inflation (Electricity) | 3% | 3% | 3% | 3% | 3% | 3% | 3% | 3% | 3% | 3% |
| Initial Yearly Savings (Electricity) | \$328.30 | \$0.00 | \$0.00 | \$0.00 | \$106.10 | \$0.00 | \$122.00 | \$0.00 | \$61.00 | \$1,594.80 |
| Assumed Average Useful Life (Years) | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 |
| Lifetime Savings | \$6,106.02 | \$0.00 | \$0.00 | \$0.00 | \$1,973.34 | \$0.00 | \$2,269.07 | \$0.00 | \$1,134.53 | \$29,661.55 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$328.30 | \$0.00 | \$0.00 | \$0.00 | \$106.10 | \$0.00 | \$122.00 | \$0.00 | \$61.00 | \$1,594.80 |
| 2 | \$338.15 | \$0.00 | \$0.00 | \$0.00 | \$109.28 | \$0.00 | \$125.66 | \$0.00 | \$62.83 | \$1,642.64 |
| 3 | \$348.29 | \$0.00 | \$0.00 | \$0.00 | \$112.56 | \$0.00 | \$129.43 | \$0.00 | \$64.71 | \$1,691.92 |
| 4 | \$358.74 | \$0.00 | \$0.00 | \$0.00 | \$115.94 | \$0.00 | \$133.31 | \$0.00 | \$66.66 | \$1,742.68 |
| 5 | \$369.50 | \$0.00 | \$0.00 | \$0.00 | \$119.42 | \$0.00 | \$137.31 | \$0.00 | \$68.66 | \$1,794.96 |
| 6 | \$380.59 | \$0.00 | \$0.00 | \$0.00 | \$123.00 | \$0.00 | \$141.43 | \$0.00 | \$70.72 | \$1,848.81 |
| 7 | \$392.01 | \$0.00 | \$0.00 | \$0.00 | \$126.69 | \$0.00 | \$145.67 | \$0.00 | \$72.84 | \$1,904.27 |
| 8 | \$403.77 | \$0.00 | \$0.00 | \$0.00 | \$130.49 | \$0.00 | \$150.04 | \$0.00 | \$75.02 | \$1,961.40 |
| 9 | \$415.88 | \$0.00 | \$0.00 | \$0.00 | \$134.40 | \$0.00 | \$154.55 | \$0.00 | \$77.27 | \$2,020.24 |
| 10 | \$428.36 | \$0.00 | \$0.00 | \$0.00 | \$138.44 | \$0.00 | \$159.18 | \$0.00 | \$79.59 | \$2,080.85 |
| 11 | \$441.21 | \$0.00 | \$0.00 | \$0.00 | \$142.59 | \$0.00 | \$163.96 | \$0.00 | \$81.98 | \$2,143.28 |
| 12 | \$454.44 | \$0.00 | \$0.00 | \$0.00 | \$146.87 | \$0.00 | \$168.88 | \$0.00 | \$84.44 | \$2,207.58 |
| 13 | \$468.08 | \$0.00 | \$0.00 | \$0.00 | \$151.27 | \$0.00 | \$173.94 | \$0.00 | \$86.97 | \$2,273.80 |
| 14 | \$482.12 | \$0.00 | \$0.00 | \$0.00 | \$155.81 | \$0.00 | \$179.16 | \$0.00 | \$89.58 | \$2,342.02 |
| 15 | \$496.58 | \$0.00 | \$0.00 | \$0.00 | \$160.49 | \$0.00 | \$184.54 | \$0.00 | \$92.27 | \$2,412.28 |

| ECM | Administration Building - Interior & Exterior | Grit Building - Interior & Exterior | Digester #1 Building - Interior & Exterior | Digester #2 Building - Interior & Exterior | Waste Oil Building - Interior & Exterior | Blower Building - Interior & Exterior | Sludge Handling Building - Interior & Exterior | Final Clarifier #1 & #2 Building - Interior & Exterior | Final Clarifier #3 & #4 Building - Interior & Exterior |
|--------------------------------------|---|-------------------------------------|--|--|--|---------------------------------------|--|--|--|
| Assumed Inflation (Gas) | | | | | | | | | |
| Initial Yearly Savings (Gas) | | | | | | | | | |
| Assumed Inflation (Electricity) | 3% | 3% | 3% | 3% | 3% | 3% | 3% | 3% | 3% |
| Initial Yearly Savings (Electricity) | \$1,697.70 | \$0.00 | \$0.00 | \$0.00 | \$156.50 | \$134.90 | \$1,097.40 | \$16.20 | \$228.50 |
| Assumed Average Useful Life (Years) | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 | 15 |
| Lifetime Savings | \$31,575.38 | \$0.00 | \$0.00 | \$0.00 | \$2,910.73 | \$2,508.99 | \$20,410.45 | \$301.30 | \$4,249.85 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$1,697.70 | \$0.00 | \$0.00 | \$0.00 | \$156.50 | \$134.90 | \$1,097.40 | \$16.20 | \$228.50 |
| 2 | \$1,748.63 | \$0.00 | \$0.00 | \$0.00 | \$161.20 | \$138.95 | \$1,130.32 | \$16.69 | \$235.36 |
| 3 | \$1,801.09 | \$0.00 | \$0.00 | \$0.00 | \$166.03 | \$143.12 | \$1,164.23 | \$17.19 | \$242.42 |
| 4 | \$1,855.12 | \$0.00 | \$0.00 | \$0.00 | \$171.01 | \$147.41 | \$1,199.16 | \$17.70 | \$249.69 |
| 5 | \$1,910.78 | \$0.00 | \$0.00 | \$0.00 | \$176.14 | \$151.83 | \$1,235.13 | \$18.23 | \$257.18 |
| 6 | \$1,968.10 | \$0.00 | \$0.00 | \$0.00 | \$181.43 | \$156.39 | \$1,272.19 | \$18.78 | \$264.89 |
| 7 | \$2,027.14 | \$0.00 | \$0.00 | \$0.00 | \$186.87 | \$161.08 | \$1,310.35 | \$19.34 | \$272.84 |
| 8 | \$2,087.96 | \$0.00 | \$0.00 | \$0.00 | \$192.48 | \$165.91 | \$1,349.66 | \$19.92 | \$281.03 |
| 9 | \$2,150.60 | \$0.00 | \$0.00 | \$0.00 | \$198.25 | \$170.89 | \$1,390.15 | \$20.52 | \$289.46 |
| 10 | \$2,215.11 | \$0.00 | \$0.00 | \$0.00 | \$204.20 | \$176.01 | \$1,431.86 | \$21.14 | \$298.14 |
| 11 | \$2,281.57 | \$0.00 | \$0.00 | \$0.00 | \$210.32 | \$181.29 | \$1,474.81 | \$21.77 | \$307.08 |
| 12 | \$2,350.01 | \$0.00 | \$0.00 | \$0.00 | \$216.63 | \$186.73 | \$1,519.06 | \$22.42 | \$316.30 |
| 13 | \$2,420.51 | \$0.00 | \$0.00 | \$0.00 | \$223.13 | \$192.34 | \$1,564.63 | \$23.10 | \$325.79 |
| 14 | \$2,493.13 | \$0.00 | \$0.00 | \$0.00 | \$229.83 | \$198.11 | \$1,611.57 | \$23.79 | \$335.56 |
| 15 | \$2,567.92 | \$0.00 | \$0.00 | \$0.00 | \$236.72 | \$204.05 | \$1,659.92 | \$24.50 | \$345.63 |

| ECM | Motor Upgrades & VFD Additions - Administration Building | Motor Upgrades & VFD Additions - Blower Building | Motor Upgrades & VFD Additions - Sludge Handling Building | Motor Upgrades & VFD Additions - Final Clarifier #1 & #2 Building | Motor Upgrades & VFD Additions - Final Clarifier #3 & #4 Building | Motor Upgrades & VFD Additions - Outdoor Process | Motor Upgrades & VFD Additions - All Combined Motors |
|--------------------------------------|--|--|---|---|---|--|--|
| Assumed Inflation (Gas) | | | | | | | |
| Initial Yearly Savings (Gas) | | | | | | | |
| Assumed Inflation (Electricity) | 3% | 3% | 3% | 3% | 3% | 3% | 3% |
| Initial Yearly Savings (Electricity) | \$223.05 | \$32.82 | \$163.23 | \$2,876.79 | \$3,950.94 | \$3,514.50 | \$10,761.40 |
| Assumed Average Useful Life (Years) | 15 | 15 | 15 | 15 | 15 | 15 | 15 |
| Lifetime Savings | \$4,148.49 | \$610.42 | \$3,035.90 | \$53,505.17 | \$73,483.19 | \$65,365.88 | \$200,150.35 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$223.05 | \$32.82 | \$163.23 | \$2,876.79 | \$3,950.94 | \$3,514.50 | \$10,761.40 |
| 2 | \$229.74 | \$33.80 | \$168.13 | \$2,963.09 | \$4,069.47 | \$3,619.94 | \$11,084.24 |
| 3 | \$236.63 | \$34.82 | \$173.17 | \$3,051.99 | \$4,191.55 | \$3,728.53 | \$11,416.77 |
| 4 | \$243.73 | \$35.86 | \$178.37 | \$3,143.55 | \$4,317.30 | \$3,840.39 | \$11,759.27 |
| 5 | \$251.04 | \$36.94 | \$183.72 | \$3,237.85 | \$4,446.82 | \$3,955.60 | \$12,112.05 |
| 6 | \$258.58 | \$38.05 | \$189.23 | \$3,334.99 | \$4,580.22 | \$4,074.27 | \$12,475.41 |
| 7 | \$266.33 | \$39.19 | \$194.91 | \$3,435.04 | \$4,717.63 | \$4,196.50 | \$12,849.67 |
| 8 | \$274.32 | \$40.36 | \$200.75 | \$3,538.09 | \$4,859.16 | \$4,322.39 | \$13,235.16 |
| 9 | \$282.55 | \$41.58 | \$206.77 | \$3,644.23 | \$5,004.93 | \$4,452.06 | \$13,632.22 |
| 10 | \$291.03 | \$42.82 | \$212.98 | \$3,753.56 | \$5,155.08 | \$4,585.63 | \$14,041.19 |
| 11 | \$299.76 | \$44.11 | \$219.37 | \$3,866.17 | \$5,309.73 | \$4,723.19 | \$14,462.42 |
| 12 | \$308.75 | \$45.43 | \$225.95 | \$3,982.15 | \$5,469.02 | \$4,864.89 | \$14,896.29 |
| 13 | \$318.02 | \$46.79 | \$232.73 | \$4,101.61 | \$5,633.10 | \$5,010.84 | \$15,343.18 |
| 14 | \$327.56 | \$48.20 | \$239.71 | \$4,224.66 | \$5,802.09 | \$5,161.16 | \$15,803.48 |
| 15 | \$337.38 | \$49.64 | \$246.90 | \$4,351.40 | \$5,976.15 | \$5,316.00 | \$16,277.58 |

| ECM | Molitor Water Pollution Treatment Plant - Solar PV System |
|--------------------------------------|---|
| Assumed Inflation (Gas) | |
| Initial Yearly Savings (Gas) | |
| Assumed Inflation (Electricity) | 3% |
| Initial Yearly Savings (Electricity) | \$242,443.60 |
| Assumed Average Useful Life (Years) | 25 |
| Lifetime Savings | \$8,839,315.30 |
| <u>Year</u> | <u>Annual Savings</u> |
| 1 | \$242,443.60 |
| 2 | \$249,716.91 |
| 3 | \$257,208.42 |
| 4 | \$264,924.67 |
| 5 | \$272,872.41 |
| 6 | \$281,058.58 |
| 7 | \$289,490.34 |
| 8 | \$298,175.05 |
| 9 | \$307,120.30 |
| 10 | \$316,333.91 |
| 11 | \$325,823.93 |
| 12 | \$335,598.64 |
| 13 | \$345,666.60 |
| 14 | \$356,036.60 |
| 15 | \$366,717.70 |
| 16 | \$377,719.23 |
| 17 | \$389,050.81 |
| 18 | \$400,722.33 |
| 19 | \$412,744.00 |
| 20 | \$425,126.32 |
| 21 | \$437,880.11 |
| 22 | \$451,016.51 |
| 23 | \$464,547.01 |
| 24 | \$478,483.42 |
| 25 | \$492,837.92 |

| ECM | Wind Turbine - Min Wind Speed | Wind Turbine - Max Wind Speed | Wind Turbine - Avg wind Speed |
|--------------------------------------|-------------------------------|-------------------------------|-------------------------------|
| Assumed Inflation (Gas) | | | |
| Initial Yearly Savings (Gas) | | | |
| Assumed Inflation (Electricity) | 3% | 3% | 3% |
| Initial Yearly Savings (Electricity) | \$861.00 | \$2,444.20 | \$1,607.60 |
| Assumed Average Useful Life (Years) | 25 | 25 | 25 |
| Lifetime Savings | \$31,391.43 | \$89,113.73 | \$58,611.91 |
| <u>Year</u> | <u>Annual Savings</u> | <u>Annual Savings</u> | <u>Annual Savings</u> |
| 1 | \$861.00 | \$2,444.20 | \$1,607.60 |
| 2 | \$886.83 | \$2,517.53 | \$1,655.83 |
| 3 | \$913.43 | \$2,593.05 | \$1,705.50 |
| 4 | \$940.84 | \$2,670.84 | \$1,756.67 |
| 5 | \$969.06 | \$2,750.97 | \$1,809.37 |
| 6 | \$998.13 | \$2,833.50 | \$1,863.65 |
| 7 | \$1,028.08 | \$2,918.50 | \$1,919.56 |
| 8 | \$1,058.92 | \$3,006.06 | \$1,977.15 |
| 9 | \$1,090.69 | \$3,096.24 | \$2,036.46 |
| 10 | \$1,123.41 | \$3,189.13 | \$2,097.55 |
| 11 | \$1,157.11 | \$3,284.80 | \$2,160.48 |
| 12 | \$1,191.83 | \$3,383.34 | \$2,225.29 |
| 13 | \$1,227.58 | \$3,484.84 | \$2,292.05 |
| 14 | \$1,264.41 | \$3,589.39 | \$2,360.81 |
| 15 | \$1,302.34 | \$3,697.07 | \$2,431.64 |
| 16 | \$1,341.41 | \$3,807.98 | \$2,504.59 |
| 17 | \$1,381.65 | \$3,922.22 | \$2,579.73 |
| 18 | \$1,423.10 | \$4,039.89 | \$2,657.12 |
| 19 | \$1,465.79 | \$4,161.09 | \$2,736.83 |
| 20 | \$1,509.77 | \$4,285.92 | \$2,818.94 |
| 21 | \$1,555.06 | \$4,414.50 | \$2,903.50 |
| 22 | \$1,601.71 | \$4,546.93 | \$2,990.61 |
| 23 | \$1,649.77 | \$4,683.34 | \$3,080.33 |
| 24 | \$1,699.26 | \$4,823.84 | \$3,172.74 |
| 25 | \$1,750.24 | \$4,968.56 | \$3,267.92 |

Financial Calculations

Based on inflation of: 3%

| Lighting - Interior Administration Building | | Lighting - Interior Grit Building | | Lighting - Interior Digester #1 Building | | Lighting - Interior Digester #2 Building | | Lighting - Interior Waste Oil Building | | Lighting - Interior Blower Building | | Lighting - Interior Sludge Handling Building | | Lighting - Interior Final Clarifier #1 & #2 Building | | Lighting - Interior Final Clarifier #3 & #4 Building | |
|--|---------------|--------------------------------------|-----------|---|-----------|---|-----------|---|------------|--|--------------|---|--------------|---|------------|---|--------------|
| Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | |
| Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow |
| 0 | (\$14,615.30) | 0 | \$0.00 | 0 | \$0.00 | 0 | \$0.00 | 0 | (\$38.80) | 0 | (\$1,539.00) | 0 | (\$9,378.00) | 0 | (\$726.40) | 0 | (\$2,976.30) |
| 1 | \$1,629.91 | 1 | \$0.00 | 1 | \$0.00 | 1 | \$0.00 | 1 | \$74.31 | 1 | \$1,116.22 | 1 | \$1,116.22 | 1 | \$22.32 | 1 | \$207.30 |
| 2 | \$1,678.81 | 2 | \$0.00 | 2 | \$0.00 | 2 | \$0.00 | 2 | \$76.54 | 2 | \$163.16 | 2 | \$1,149.71 | 2 | \$22.99 | 2 | \$213.52 |
| 3 | \$1,729.17 | 3 | \$0.00 | 3 | \$0.00 | 3 | \$0.00 | 3 | \$78.84 | 3 | \$168.06 | 3 | \$1,184.20 | 3 | \$23.68 | 3 | \$219.92 |
| 4 | \$1,781.05 | 4 | \$0.00 | 4 | \$0.00 | 4 | \$0.00 | 4 | \$81.20 | 4 | \$173.10 | 4 | \$1,219.72 | 4 | \$24.39 | 4 | \$226.52 |
| 5 | \$1,834.48 | 5 | \$0.00 | 5 | \$0.00 | 5 | \$0.00 | 5 | \$83.64 | 5 | \$178.29 | 5 | \$1,256.32 | 5 | \$25.12 | 5 | \$233.32 |
| 6 | \$1,889.51 | 6 | \$0.00 | 6 | \$0.00 | 6 | \$0.00 | 6 | \$86.15 | 6 | \$183.64 | 6 | \$1,294.00 | 6 | \$25.87 | 6 | \$240.32 |
| 7 | \$1,946.20 | 7 | \$0.00 | 7 | \$0.00 | 7 | \$0.00 | 7 | \$88.73 | 7 | \$189.15 | 7 | \$1,332.83 | 7 | \$26.65 | 7 | \$247.53 |
| 8 | \$2,004.58 | 8 | \$0.00 | 8 | \$0.00 | 8 | \$0.00 | 8 | \$91.39 | 8 | \$194.82 | 8 | \$1,372.81 | 8 | \$27.45 | 8 | \$254.95 |
| 9 | \$2,064.72 | 9 | \$0.00 | 9 | \$0.00 | 9 | \$0.00 | 9 | \$94.13 | 9 | \$200.67 | 9 | \$1,413.99 | 9 | \$28.27 | 9 | \$262.60 |
| 10 | \$2,126.66 | 10 | \$0.00 | 10 | \$0.00 | 10 | \$0.00 | 10 | \$96.96 | 10 | \$206.69 | 10 | \$1,456.41 | 10 | \$29.12 | 10 | \$270.48 |
| 11 | \$2,190.46 | 11 | \$0.00 | 11 | \$0.00 | 11 | \$0.00 | 11 | \$99.87 | 11 | \$212.89 | 11 | \$1,500.11 | 11 | \$30.00 | 11 | \$278.59 |
| 12 | \$2,256.18 | 12 | \$0.00 | 12 | \$0.00 | 12 | \$0.00 | 12 | \$102.86 | 12 | \$219.28 | 12 | \$1,545.11 | 12 | \$30.90 | 12 | \$286.95 |
| 13 | \$2,323.86 | 13 | \$0.00 | 13 | \$0.00 | 13 | \$0.00 | 13 | \$105.95 | 13 | \$225.85 | 13 | \$1,591.46 | 13 | \$31.82 | 13 | \$295.56 |
| 14 | \$2,393.58 | 14 | \$0.00 | 14 | \$0.00 | 14 | \$0.00 | 14 | \$109.13 | 14 | \$232.63 | 14 | \$1,639.21 | 14 | \$32.78 | 14 | \$304.43 |
| 15 | \$2,465.39 | 15 | \$0.00 | 15 | \$0.00 | 15 | \$0.00 | 15 | \$112.40 | 15 | \$239.61 | 15 | \$1,688.38 | 15 | \$33.76 | 15 | \$313.56 |
| IRR | 9.98% | IRR | #NUM! | IRR | #NUM! | IRR | #NUM! | IRR | 194.52% | IRR | 8.71% | IRR | 11.06% | IRR | -5.96% | IRR | 3.18% |
| NPV | \$9,121.25 | NPV | \$0.00 | NPV | \$0.00 | NPV | \$0.00 | NPV | \$1,043.38 | NPV | \$767.94 | NPV | \$6,877.63 | NPV | (\$401.35) | NPV | \$42.63 |
| ARO | 4.49% | ARO | #DIV/0! | ARO | #DIV/0! | ARO | #DIV/0! | ARO | 184.85% | ARO | 3.63% | ARO | 5.24% | ARO | -3.59% | ARO | 0.30% |

| Lighting - Exterior Administration Building | | Lighting - Exterior Grit Building | | Lighting - Exterior Digester #1 Building | | Lighting - Exterior Digester #2 Building | | Lighting - Exterior Waste Oil Building | | Lighting - Exterior Blower Building | | Lighting - Exterior Sludge Handling Building | | Lighting - Exterior Final Clarifier #1 & #2 Building | | Lighting - Exterior Final Clarifier #3 & #4 Building | | Lighting - Exterior Roadway & Process Lighting | |
|--|------------|--------------------------------------|-----------|---|-----------|---|-----------|---|------------|--|-----------|---|--------------|---|-----------|---|--------------|---|---------------|
| Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | |
| Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow |
| 0 | (\$116.40) | 0 | \$0.00 | 0 | \$0.00 | 0 | \$0.00 | 0 | (\$38.80) | 0 | \$0.00 | 0 | (\$2,972.80) | 0 | \$0.00 | 0 | (\$1,486.40) | 0 | (\$15,852.70) |
| 1 | \$326.71 | 1 | \$0.00 | 1 | \$0.00 | 1 | \$0.00 | 1 | \$130.91 | 1 | \$0.00 | 1 | \$123.46 | 1 | \$0.00 | 1 | \$61.73 | 1 | \$1,609.98 |
| 2 | \$336.51 | 2 | \$0.00 | 2 | \$0.00 | 2 | \$0.00 | 2 | \$133.91 | 2 | \$0.00 | 2 | \$127.16 | 2 | \$0.00 | 2 | \$63.58 | 2 | \$1,658.28 |
| 3 | \$346.61 | 3 | \$0.00 | 3 | \$0.00 | 3 | \$0.00 | 3 | \$137.93 | 3 | \$0.00 | 3 | \$130.98 | 3 | \$0.00 | 3 | \$65.49 | 3 | \$1,708.03 |
| 4 | \$357.00 | 4 | \$0.00 | 4 | \$0.00 | 4 | \$0.00 | 4 | \$142.07 | 4 | \$0.00 | 4 | \$134.91 | 4 | \$0.00 | 4 | \$67.45 | 4 | \$1,759.27 |
| 5 | \$367.71 | 5 | \$0.00 | 5 | \$0.00 | 5 | \$0.00 | 5 | \$146.33 | 5 | \$0.00 | 5 | \$138.96 | 5 | \$0.00 | 5 | \$69.48 | 5 | \$1,812.05 |
| 6 | \$378.75 | 6 | \$0.00 | 6 | \$0.00 | 6 | \$0.00 | 6 | \$150.72 | 6 | \$0.00 | 6 | \$143.12 | 6 | \$0.00 | 6 | \$71.56 | 6 | \$1,866.41 |
| 7 | \$390.11 | 7 | \$0.00 | 7 | \$0.00 | 7 | \$0.00 | 7 | \$155.24 | 7 | \$0.00 | 7 | \$147.42 | 7 | \$0.00 | 7 | \$73.71 | 7 | \$1,922.40 |
| 8 | \$401.81 | 8 | \$0.00 | 8 | \$0.00 | 8 | \$0.00 | 8 | \$159.90 | 8 | \$0.00 | 8 | \$151.84 | 8 | \$0.00 | 8 | \$75.92 | 8 | \$1,980.07 |
| 9 | \$413.87 | 9 | \$0.00 | 9 | \$0.00 | 9 | \$0.00 | 9 | \$164.69 | 9 | \$0.00 | 9 | \$156.40 | 9 | \$0.00 | 9 | \$78.20 | 9 | \$2,039.47 |
| 10 | \$426.28 | 10 | \$0.00 | 10 | \$0.00 | 10 | \$0.00 | 10 | \$169.63 | 10 | \$0.00 | 10 | \$161.09 | 10 | \$0.00 | 10 | \$80.54 | 10 | \$2,100.66 |
| 11 | \$439.07 | 11 | \$0.00 | 11 | \$0.00 | 11 | \$0.00 | 11 | \$174.72 | 11 | \$0.00 | 11 | \$165.92 | 11 | \$0.00 | 11 | \$82.96 | 11 | \$2,163.68 |
| 12 | \$452.24 | 12 | \$0.00 | 12 | \$0.00 | 12 | \$0.00 | 12 | \$179.96 | 12 | \$0.00 | 12 | \$170.90 | 12 | \$0.00 | 12 | \$85.45 | 12 | \$2,228.59 |
| 13 | \$465.81 | 13 | \$0.00 | 13 | \$0.00 | 13 | \$0.00 | 13 | \$185.36 | 13 | \$0.00 | 13 | \$176.02 | 13 | \$0.00 | 13 | \$88.01 | 13 | \$2,296.45 |
| 14 | \$479.78 | 14 | \$0.00 | 14 | \$0.00 | 14 | \$0.00 | 14 | \$190.92 | 14 | \$0.00 | 14 | \$181.31 | 14 | \$0.00 | 14 | \$90.65 | 14 | \$2,364.31 |
| 15 | \$494.18 | 15 | \$0.00 | 15 | \$0.00 | 15 | \$0.00 | 15 | \$196.65 | 15 | \$0.00 | 15 | \$186.74 | 15 | \$0.00 | 15 | \$93.37 | 15 | \$2,435.24 |
| IRR | 283.68% | IRR | #NUM! | IRR | #NUM! | IRR | #NUM! | IRR | 338.08% | IRR | #NUM! | IRR | -2.89% | IRR | #NUM! | IRR | -2.89% | IRR | 8.51% |
| NPV | \$4,641.51 | NPV | \$0.00 | NPV | \$0.00 | NPV | \$0.00 | NPV | \$1,854.55 | NPV | \$0.00 | NPV | (\$1,174.84) | NPV | \$0.00 | NPV | (\$587.42) | NPV | \$7,593.61 |
| ARO | 274.01% | ARO | #DIV/0! | ARO | #DIV/0! | ARO | #DIV/0! | ARO | 328.41% | ARO | #DIV/0! | ARO | -2.51% | ARO | #DIV/0! | ARO | -2.51% | ARO | 3.49% |

| Lighting - Interior & Exterior Administration Building | | Lighting - Interior & Exterior Grit Building | | Lighting - Interior & Exterior Digester #1 Building | | Lighting - Interior & Exterior Digester #2 Building | | Lighting - Interior & Exterior Waste Oil Building | | Lighting - Interior & Exterior Blower Building | | Lighting - Interior & Exterior Sludge Handling Building | | Lighting - Interior & Exterior Final Clarifier #1 & #2 Building | | Lighting - Interior & Exterior Final Clarifier #3 & #4 Building | |
|---|---------------|---|-----------|--|-----------|--|-----------|--|------------|---|--------------|--|---------------|--|------------|--|--------------|
| Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | |
| Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow |
| 0 | (\$14,731.80) | 0 | \$0.00 | 0 | \$0.00 | 0 | \$0.00 | 0 | (\$77.60) | 0 | (\$1,539.00) | 0 | (\$12,350.70) | 0 | (\$726.40) | 0 | (\$4,462.70) |
| 1 | \$1,956.62 | 1 | \$0.00 | 1 | \$0.00 | 1 | \$0.00 | 1 | \$204.33 | 1 | \$158.41 | 1 | \$1,239.68 | 1 | \$22.32 | 1 | \$269.03 |
| 2 | \$2,015.32 | 2 | \$0.00 | 2 | \$0.00 | 2 | \$0.00 | 2 | \$210.46 | 2 | \$163.16 | 2 | \$1,276.87 | 2 | \$22.99 | 2 | \$277.10 |
| 3 | \$2,075.78 | 3 | \$0.00 | 3 | \$0.00 | 3 | \$0.00 | 3 | \$216.77 | 3 | \$168.06 | 3 | \$1,315.18 | 3 | \$23.68 | 3 | \$285.41 |
| 4 | \$2,138.05 | 4 | \$0.00 | 4 | \$0.00 | 4 | \$0.00 | 4 | \$223.28 | 4 | \$173.10 | 4 | \$1,354.63 | 4 | \$24.39 | 4 | \$293.98 |
| 5 | \$2,202.19 | 5 | \$0.00 | 5 | \$0.00 | 5 | \$0.00 | 5 | \$229.98 | 5 | \$178.29 | 5 | \$1,395.27 | 5 | \$25.12 | 5 | \$302.80 |
| 6 | \$2,268.26 | 6 | \$0.00 | 6 | \$0.00 | 6 | \$0.00 | 6 | \$236.87 | 6 | \$183.64 | 6 | \$1,437.13 | 6 | \$25.87 | 6 | \$311.88 |
| 7 | \$2,336.31 | 7 | \$0.00 | 7 | \$0.00 | 7 | \$0.00 | 7 | \$243.98 | 7 | \$189.15 | 7 | \$1,480.24 | 7 | \$26.65 | 7 | \$321.24 |
| 8 | \$2,406.40 | 8 | \$0.00 | 8 | \$0.00 | 8 | \$0.00 | 8 | \$251.30 | 8 | \$194.82 | 8 | \$1,524.65 | 8 | \$27.45 | 8 | \$330.87 |
| 9 | \$2,478.59 | 9 | \$0.00 | 9 | \$0.00 | 9 | \$0.00 | 9 | \$258.84 | 9 | \$200.67 | 9 | \$1,570.39 | 9 | \$28.27 | 9 | \$340.80 |
| 10 | \$2,552.95 | 10 | \$0.00 | 10 | \$0.00 | 10 | \$0.00 | 10 | \$266.60 | 10 | \$206.69 | 10 | \$1,617.50 | 10 | \$29.12 | 10 | \$351.02 |
| 11 | \$2,629.53 | 11 | \$0.00 | 11 | \$0.00 | 11 | \$0.00 | 11 | \$274.60 | 11 | \$212.89 | 11 | \$1,666.03 | 11 | \$30.00 | 11 | \$361.55 |
| 12 | \$2,708.42 | 12 | \$0.00 | 12 | \$0.00 | 12 | \$0.00 | 12 | \$282.84 | 12 | \$219.28 | 12 | \$1,716.01 | 12 | \$30.90 | 12 | \$372.40 |
| 13 | \$2,789.67 | 13 | \$0.00 | 13 | \$0.00 | 13 | \$0.00 | 13 | \$291.33 | 13 | \$225.85 | 13 | \$1,767.49 | 13 | \$31.82 | 13 | \$383.57 |
| 14 | \$2,873.36 | 14 | \$0.00 | 14 | \$0.00 | 14 | \$0.00 | 14 | \$300.07 | 14 | \$232.63 | 14 | \$1,820.51 | 14 | \$32.78 | 14 | \$395.08 |
| 15 | \$2,959.56 | 15 | \$0.00 | 15 | \$0.00 | 15 | \$0.00 | 15 | \$309.07 | 15 | \$239.61 | 15 | \$1,875.13 | 15 | \$33.76 | 15 | \$406.93 |
| IRR | 12.95% | IRR | #NUM! | IRR | #NUM! | IRR | #NUM! | IRR | 266.31% | IRR | 8.71% | IRR | 8.32% | IRR | -5.96% | IRR | 1.37% |
| NPV | \$13,762.67 | NPV | \$0.00 | NPV | \$0.00 | NPV | \$0.00 | NPV | \$2,898.08 | NPV | \$767.94 | NPV | \$5,702.89 | NPV | (\$401.35) | NPV | (\$544.79) |
| ARO | 6.61% | ARO | #DIV/0! | ARO | #DIV/0! | ARO | #DIV/0! | ARO | 256.65% | ARO | 3.63% | ARO | 3.37% | ARO | -3.59% | ARO | -0.64% |

| Motor Upgrades and VFD Additions Administration Building | | Motor Upgrades and VFD Additions Blower Building | | Motor Upgrades and VFD Additions Sludge Handling Building | | Motor Upgrades and VFD Additions Final Clarifier #1 & #2 Building | | Motor Upgrades and VFD Additions Final Clarifier #3 & #4 Building | | Motor Upgrades and VFD Additions Outdoor Process | | Motor Upgrades and VFD Additions All Combined Motors | |
|---|--------------|---|------------|--|---------------|--|--------------|--|---------------|---|---------------|---|---------------|
| Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | | Life of ECRM (Yrs): 15 | |
| Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow | Year | Cash Flow |
| 0 | (\$8,675.31) | 0 | (\$747.50) | 0 | (\$13,690.75) | 0 | (\$8,585.88) | 0 | (\$17,771.56) | 0 | (\$12,866.60) | 0 | (\$63,327.60) |
| 1 | \$223.05 | 1 | \$32.82 | 1 | \$163.23 | 1 | \$2,876.79 | 1 | \$3,950.94 | 1 | \$3,514.50 | 1 | \$10,761.40 |
| 2 | \$229.74 | 2 | \$33.80 | 2 | \$168.13 | 2 | \$2,963.09 | 2 | \$4,069.47 | 2 | \$3,619.94 | 2 | \$11,084.24 |
| 3 | \$236.63 | 3 | \$34.82 | 3 | \$173.17 | 3 | \$3,051.99 | 3 | \$4,191.55 | 3 | \$3,728.53 | 3 | \$11,416.77 |
| 4 | \$243.73 | 4 | \$35.86 | 4 | \$178.37 | 4 | \$3,143.55 | 4 | \$4,317.30 | 4 | \$3,840.39 | 4 | \$11,759.27 |
| 5 | \$251.04 | 5 | \$36.94 | 5 | \$183.72 | 5 | \$3,237.85 | 5 | \$4,446.82 | 5 | \$3,955.60 | 5 | \$12,112.05 |
| 6 | \$258.58 | 6 | \$38.05 | 6 | \$189.23 | 6 | \$3,334.99 | 6 | \$4,580.22 | 6 | \$4,074.27 | 6 | \$12,475.41 |
| 7 | \$266.33 | 7 | \$39.19 | 7 | \$194.91 | 7 | \$3,435.04 | 7 | \$4,717.63 | 7 | \$4,196.50 | 7 | \$12,849.67 |
| 8 | \$274.32 | 8 | \$40.36 | 8 | \$200.75 | 8 | \$3,538.09 | 8 | \$4,859.16 | 8 | \$4,322.39 | 8 | \$13,235.16 |
| 9 | \$282.55 | 9 | \$41.58 | 9 | \$206.77 | 9 | \$3,644.23 | 9 | \$5,004.93 | 9 | \$4,452.06 | 9 | \$13,632.22 |
| 10 | \$291.03 | 10 | \$42.82 | 10 | \$212.98 | 10 | \$3,753.56 | 10 | \$5,155.08 | 10 | \$4,585.63 | 10 | \$14,041.19 |
| 11 | \$299.76 | 11 | \$44.11 | 11 | \$219.37 | 11 | \$3,866.17 | 11 | \$5,309.73 | 11 | \$4,723.19 | 11 | \$14,462.42 |
| 12 | \$308.75 | 12 | \$45.43 | 12 | \$225.95 | 12 | \$3,982.15 | 12 | \$5,469.02 | 12 | \$4,864.89 | 12 | \$14,896.29 |
| 13 | \$318.02 | 13 | \$46.79 | 13 | \$232.73 | 13 | \$4,101.61 | 13 | \$5,633.10 | 13 | \$5,010.84 | 13 | \$15,343.18 |
| 14 | \$327.56 | 14 | \$48.20 | 14 | \$239.71 | 14 | \$4,224.66 | 14 | \$5,802.09 | 14 | \$5,161.16 | 14 | \$15,803.48 |
| 15 | \$337.38 | 15 | \$49.64 | 15 | \$246.90 | 15 | \$4,351.40 | 15 | \$5,976.15 | 15 | \$5,316.00 | 15 | \$16,277.58 |
| IRR | -7.65% | IRR | -2.29% | IRR | -14.16% | IRR | 35.99% | IRR | 23.83% | IRR | 29.43% | IRR | 17.69% |
| NPV | (\$5,427.01) | NPV | (\$269.54) | NPV | (\$11,313.61) | NPV | \$33,309.12 | NPV | \$39,766.40 | NPV | \$38,315.44 | NPV | \$93,391.82 |
| ARO | -4.10% | ARO | -2.28% | ARO | -5.47% | ARO | 26.84% | ARO | 15.57% | ARO | 20.65% | ARO | 10.33% |

APPENDIX O
FACILITY DATA FORMS



APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|--|--|--|---------------------|
| Facility Name Madison-Chatham Joint Meeting - Digesters (#1) | | | |
| Street Address 214 N. Passaic Ave | | County Morris | |
| City Chatham | | State NJ | Zip 07928 |
| Facility's Description Gas engines, gas boilers, pumps, motors, gas blowers, lights, heating | | | |
| Total Sq Ft 1800 | Year Built 1950/1970 | Hours/Week Occupied Intermittent | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: Wastewater Treatment | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

The Data Below is for the 12 Month Period: 12/09/08 to 12/09/09



ELECTRICITY

| | | |
|--|-------------------------|----------|
| Electric Utility Name & Account Number(s) | | Acct.# |
| JCP&L Acct.# 100005606627 AND First Energy Solutions | | 11013155 |
| Annual kWh Use | Annual Electricity Cost | |
| 2,211,680 | \$337,581.31 | |
| Max Summer kW | Max Winter kW | |
| 183,040 | 212,160 | |

NATURAL GAS

| | |
|--|-------------------------|
| Natural Gas Utility Name & Account Number(s) | |
| PSE&G Acct.# 6566938400 | |
| Annual Use in Therms | Annual Natural Gas Cost |
| 78,866.40 | \$62,644.46 |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| N/A | |
| Annual Use in Gallons | Annual Fuel Oil Cost |
| | |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| N/A | |
| Annual Use in Gallons | Annual Propane Cost |
| | |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| N/A | |
| Annual Energy Use (indicate units) | Annual Energy Cost |
| | |

STAFF USE ONLY





APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|--|--|--|---------------------|
| Facility Name Madison-Chatham Joint Meeting - Bar Screen (#2) | | | |
| Street Address 214 N. Passaic Ave | | County Morris | |
| City Chatham | State NJ | Zip 07928 | |
| Facility's Description Bar screen motor, lighting, electric heater | | | |
| Total Sq Ft 158 | Year Built 1992 | Hours/Week Occupied Intermittent | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input checked="" type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: Wastewater Treatment | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: 12/09/08 to 12/09/09 |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (indicate units) | Annual Energy Cost |

STAFF USE ONLY





APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|---|--|--|---------------------|
| Facility Name Madison-Chatham Joint Meeting - Clarifiers (#3) | | | |
| Street Address 214 N. Passaic Ave | | County Morris | |
| City Chatham | | State NJ | Zip 07928 |
| Facility's Description Motors, lighting, electric heaters | | | |
| Total Sq Ft 165 | Year Built 1950/1970/1992 | Hours/Week Occupied Intermittent | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input checked="" type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: Wastewater Treatment | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: <u>12/09/08</u> to <u>12/09/09</u> |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (indicate units) | Annual Energy Cost |

STAFF USE ONLY

| | |
|-----------------|--|
| [Redacted area] | |
|-----------------|--|



APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|--|--|--|--------------------------------------|
| Facility Name Madison-Chatham Joint Meeting - Administration (#4) | | | |
| Street Address 214 N. Passaic Ave. | | County Morris | |
| City Chatham | State NJ | Zip 07928 | |
| Facility's Description Lighting, gas heat, A/C, pumps, motors, VFDs, Computers Phone system, lab equipment, sander, drill press, electric heat | | | |
| Total Sq Ft 5,400 | Year Built 1950/1970 | Hours/Week Occupied Intermittent <small>Wep Funds -</small> | Number of Employees Varies |
| Building Type (Check only one of the following): M-F 8hrs/day | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: Wastewater Treatment | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: 12/09/08 to 12/09/09 |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digester sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digester sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (indicate units) | Annual Energy Cost |

STAFF USE ONLY





APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|---|--|--|---------------------|
| Facility Name Madison-Chatham Joint Meeting - Site Lighting (#5) | | | |
| Street Address 214 N. Passaic Ave | | County Morris | |
| City Chatham | State NJ | Zip 07936 | |
| Facility's Description HID & Mercury Vapor Lighting, lighting-bldg, electric heat | | | |
| Total Sq Ft 680 | Year Built 1910-1990 | Hours/Week Occupied Intermittent | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: Wastewater Treatment | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: 12/09/08 to 12/09/09 |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (indicate units) | Annual Energy Cost |

STAFF USE ONLY





APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|---|--|--|---------------------|
| Facility Name Madison-Chatham Joint Meeting - Blower Bldg (#6) | | | |
| Street Address 214 N. Passaic Ave | | County Morris | |
| City Chatham | | State NJ | Zip 07928 |
| Facility's Description Electric blowers, VFDS, lighting, gas heat, motors, pumps. | | | |
| Total Sq Ft 3,600 | Year Built 1910 | Hours/Week Occupied Intermittent | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: Wastewater Treatment | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: <u>12/09/08</u> to <u>12/09/09</u> |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (Indicate units) | Annual Energy Cost |

STAFF USE ONLY





APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|---|--|--|---------------------|
| Facility Name <i>Madison-Chatham Joint Meeting - Fin. Clarifiers #2 (#7)</i> | | | |
| Street Address <i>214 N. Passaic Ave</i> | | County <i>Morris</i> | |
| City <i>Chatham</i> | State <i>NJ</i> | Zip <i>07928</i> | |
| Facility's Description <i>Motors, pumps, lighting, electric heat</i> | | | |
| Total Sq Ft <i>390</i> | Year Built <i>1970</i> | Hours/Week Occupied <i>Intermittent</i> | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: <i>Wastewater Treatment</i> | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: <i>12/09/08</i> to <i>12/09/09</i> |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digestor Sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digestor Sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (indicate units) | Annual Energy Cost |

STAFF USE ONLY





APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|---|--|--|---------------------|
| Facility Name Madison-Chatham Joint Meeting - Fin. Clav. 344 (#8) | | | |
| Street Address 214 N. Passaic Ave | | County Morris | |
| City Chatham | State NJ | Zip 07928 | |
| Facility's Description Motors, pumps, heat, lighting | | | |
| Total Sq Ft 1,500 | Year Built 1990 | Hours/Week Occupied Intermittent | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> Emergency Services | <input type="checkbox"/> Garage | | |
| <input type="checkbox"/> Center/Meeting Hall/Library | <input type="checkbox"/> Offices | | |
| <input type="checkbox"/> Recreation/Entertainment/Parks | <input type="checkbox"/> Religious | | |
| <input type="checkbox"/> School | <input type="checkbox"/> School: College | | |
| <input type="checkbox"/> Water Treatment/Pumping | <input checked="" type="checkbox"/> Other: Wastewater Treatment | | |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: 12/09/08 to 12/09/09 |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (indicate units) | Annual Energy Cost |

STAFF USE ONLY





APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for each building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

| | | | |
|--|--------------------------------|--|------------------------------------|
| Facility Name <i>Madison-Chatham Joint Meeting - Sludge Bldg (#9)</i> | | | |
| Street Address <i>214 N. Passaic Ave</i> | | County <i>Morris</i> | |
| City <i>Chatham</i> | State <i>NJ</i> | Zip <i>07928</i> | |
| Facility's Description <i>pumps, motors, gas boilers, lighting (CFL & Hg Vapor) Belt Presses, microwave, refig, electric heat</i> | | | |
| Total Sq Ft <i>11,800</i> | Year Built <i>1990</i> | Hours/Week Occupied <i>Intermittent</i> | Number of Employees |
| Building Type (Check only one of the following): | | | |
| <input type="checkbox"/> | Emergency Services | <input type="checkbox"/> | Garage |
| <input type="checkbox"/> | Center/Meeting Hall/Library | <input type="checkbox"/> | Offices |
| <input type="checkbox"/> | Recreation/Entertainment/Parks | <input type="checkbox"/> | Religious |
| <input type="checkbox"/> | School | <input type="checkbox"/> | School: College |
| <input type="checkbox"/> | Water Treatment/Pumping | <input checked="" type="checkbox"/> | Other: <i>Wastewater Treatment</i> |

ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

| |
|---|
| The Data Below is for the 12 Month Period: <i>12/09/08</i> to <i>12/09/09</i> |
|---|



ELECTRICITY

| | |
|--|-------------------------|
| Electric Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual kWh Use | Annual Electricity Cost |
| Max Summer kW | Max Winter kW |

NATURAL GAS

| | |
|---|-------------------------|
| Natural Gas Utility Name & Account Number(s) <i>Included on Digester Sheet</i> | |
| Annual Use in Therms | Annual Natural Gas Cost |

FUEL OIL

| | |
|---|----------------------|
| Fuel Oil Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Fuel Oil Cost |

PROPANE

| | |
|--|---------------------|
| Propane Utility Name & Account Number(s) | |
| Annual Use in Gallons | Annual Propane Cost |

OTHER

In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.

| | |
|------------------------------------|--------------------|
| Other Fuel Type: | |
| Annual Energy Use (indicate units) | Annual Energy Cost |

STAFF USE ONLY

