



*Teaneck Board of Education  
May 28, 2010*

# *Final Energy Audit Report*



11 British American Boulevard  
Suite 200  
Latham, New York 12110  
tel: 518-782-4500  
fax: 518-786-3810

May 26, 2010

Mr. Anthony D'Angelo, AIA, CEFM  
Director of Facilities & Grounds  
Teaneck Public Schools  
1315 Taft Road  
Teaneck, NJ 07666

Subject: Final Energy Audit Report for Teaneck Public Schools

Dear Mr. D'Angelo:

Please find attached an electronic copy of our final report detailing the findings and recommendations of CDM's energy audit for Teaneck Public Schools. An electronic copy of this report has also been provided to TRC for their record.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Matthew T. Goss'.

Matthew T. Goss, P.E., C.E.M., C.E.A., LEED®AP  
Project Manager  
CDM

c: Ted Schlette (CDM)  
Colleen Kling (TRC)

Enclosure

# Contents

## Executive Summary

### Section 1 Introduction

- 1.1 General ..... 1-1
- 1.2 Background ..... 1-2
- 1.3 Purpose and Scope ..... 1-3

### Section 2 Facility Description

- 2.1 Benjamin Franklin Middle School ..... 2-1
  - 2.1.1 Description of Building Envelope ..... 2-1
  - 2.1.2 Description of Building HVAC ..... 2-1
  - 2.1.3 Description of Building Lighting ..... 2-2
- 2.2 Bryant Elementary School ..... 2-2
  - 2.2.1 Description of Building Envelope ..... 2-2
  - 2.2.2 Description of Building HVAC ..... 2-2
  - 2.2.3 Description of Building Lighting ..... 2-3
- 2.3 Eugene Field Administration Building ..... 2-3
  - 2.3.1 Description of Building Envelope ..... 2-3
  - 2.3.2 Description of Building HVAC ..... 2-3
  - 2.3.3 Description of Building Lighting ..... 2-3
- 2.4 Hawthorne Elementary School ..... 2-4
  - 2.4.1 Description of Building Envelope ..... 2-4
  - 2.4.2 Description of Building HVAC ..... 2-4
  - 2.4.3 Description of Building Lighting ..... 2-5
- 2.5 Lowell Elementary School ..... 2-5
  - 2.5.1 Description of Building Envelope ..... 2-5
  - 2.5.2 Description of Building HVAC ..... 2-5
  - 2.5.3 Description of Building Lighting ..... 2-6
- 2.6 Teaneck High School ..... 2-6
  - 2.6.1 Description of Building Envelope ..... 2-6
  - 2.6.2 Description of Building HVAC ..... 2-6
  - 2.6.3 Description of Building Lighting ..... 2-7
- 2.7 Thomas Jefferson Middle School ..... 2-7
  - 2.7.1 Description of Building Envelope ..... 2-7
  - 2.7.2 Description of Building HVAC ..... 2-7
  - 2.7.3 Description of Building Lighting ..... 2-8
- 2.8 Whittier Elementary School ..... 2-8
  - 2.8.1 Description of Building Envelope ..... 2-8
  - 2.8.2 Description of Building HVAC ..... 2-8
  - 2.8.3 Description of Building Lighting ..... 2-9
- 2.9 Teaneck High School Athletic Field Lighting, Scoreboard, and Well Pump ... 2-9

	2.9.1 Description of Press Box Building HVAC .....	2-9
	2.9.2 Description of Press Box Building Lighting .....	2-9
	2.9.3 Description of Athletic Field Lighting.....	2-9
	2.9.4 Description of Scoreboard.....	2-9
	2.9.5 Description of Well Pump.....	2-9
2.10	Miscellaneous Equipment .....	2-9

**Section 3 Baseline Energy Use**

3.1	Utility Data Analysis.....	3-1
	3.1.1 Electric Charges .....	3-1
	3.1.2 Natural Gas Charges.....	3-2
	3.1.3 Oil Changes .....	3-2
3.2	Facility Results .....	3-2
	3.2.1 Benjamin Franklin Middle School.....	3-2
	3.2.2 Bryant Elementary School.....	3-5
	3.2.3 Eugene Field Administration Building .....	3-8
	3.2.4 Hawthorne Elementary School.....	3-11
	3.2.5 Lowell Elementary School.....	3-13
	3.2.6 Teaneck High School.....	3-16
	3.2.7 Teaneck High School – Athletic Field Lighting.....	3-19
	3.2.8 Teaneck High School – Scoreboard.....	3-21
	3.2.9 Thomas Jefferson Middle School.....	3-22
	3.2.10 Whittier Elementary School .....	3-25
3.3	Aggregate Costs.....	3-28
3.4	Portfolio Manager.....	3-29
	3.4.1 Portfolio Manager Overview .....	3-29
	3.4.2 Energy Performance Rating.....	3-29
	3.4.3 Portfolio Manager Account Information.....	3-30

**Section 4 Energy Conservation and Retrofit Measures (ECRM)**

4.1	Building Lighting Systems .....	4-1
	4.1.1 Benjamin Franklin Middle School.....	4-1
	4.1.2 Bryant Elementary School.....	4-3
	4.1.3 Eugene Field Administration Building .....	4-4
	4.1.4 Hawthorne Elementary School.....	4-6
	4.1.5 Lowell Elementary School.....	4-7
	4.1.6 Teaneck High School.....	4-8
	4.1.7 Thomas Jefferson Middle School.....	4-10
	4.1.8 Whittier Elementary School.....	4-11
	4.1.9 Athletic Field Lighting & Scoreboard.....	4-13
	4.1.10 Teaneck High School – Press Box.....	4-13
4.2	HVAC Systems .....	4-14

4.2.1	Benjamin Franklin Middle School.....	4-15
4.2.2	Bryant Elementary School.....	4-21
4.2.3	Eugene Field Administration Building .....	4-27
4.2.4	Hawthorne Elementary School.....	4-34
4.2.5	Lowell Elementary School.....	4-40
4.2.6	Teaneck High School.....	4-47
4.2.7	Thomas Jefferson Middle School.....	4-54
4.2.8	Whittier Elementary School .....	4-60
4.3	Alternative Energy Sources.....	4-66
4.3.1	Photovoltaic Solar Energy System Overview .....	4-66
4.3.1.1	Benjamin Franklin Middle School.....	4-67
4.3.1.2	Bryant Elementary School .....	4-68
4.3.1.3	Eugene Field Administration Building .....	4-68
4.3.1.4	Hawthorne Elementary School.....	4-69
4.3.1.5	Lowell Elementary School.....	4-69
4.3.1.6	Teaneck High School.....	4-70
4.3.1.7	Thomas Jefferson Middle School.....	4-70
4.3.1.8	Whittier Elementary School .....	4-71
4.3.1.9	Basis for Design and Calculations.....	4-71
4.3.2	Wind Power Generation.....	4-73
4.3.3	Ground Source Heat Pumps.....	4-75
4.4	Additional Measures.....	4-76
<b>Section 5 Evaluation of Energy Purchasing and Procurement Strategies</b>		
5.1	Energy Deregulation .....	5-1
5.2	Demand Response Program.....	5-2
<b>Section 6 Ranking of Energy Conservation and Retrofit Measures (ECRM)</b>		
6.1	ECRMs.....	6-1
6.1.1	Lighting Systems .....	6-1
6.1.2	HVAC Systems .....	6-2
6.1.3	Solar Energy .....	6-3
6.1.4	Wind Power Generation.....	6-4
<b>Section 7 Available Grants, Incentives and Funding Sources</b>		
7.1	Renewable Energy .....	7-1
7.1.1	Renewable Energy Certificates (NJ BPU).....	7-1
7.1.2	Clean Energy Solutions Capital Investment Loan/Grant (NJ EDA).....	7-1
7.1.3	Renewable Energy Incentive Program (NJ BPU).....	7-1
7.1.4	Grid Connected Renewables Program (NJ BPU).....	7-1

7.1.5	Utility Financing Programs.....	7-2
7.1.6	Renewable Energy Manufacturing Incentive (NJ BPU).....	7-2
7.1.7	Clean Renewable Energy Bonds (IRS).....	7-2
7.1.8	Qualified Energy Conservation Bonds (IRS).....	7-2
7.1.9	Global Climate Change Mitigation Incentive Fund (US EDA).....	7-3
7.1.10	Private Tax-Exempt Financing .....	7-3
7.1.11	Performance Based Contracts (ESCOs) .....	7-3
7.1.12	Power Purchase Agreement (SPCs).....	7-4
7.2	Energy Efficiency .....	7-4
7.2.1	Introduction .....	7-4
7.2.2	New Jersey Smart Start Buildings Program (NJ BPU) .....	7-4
7.2.3	Pay for Performance Program (NJ BPU).....	7-5
7.2.4	Clean Energy Solutions Capital Investment Loan/Grant (NJ EDA) .	7-5
7.2.5	Private Tax-Exempt Financing .....	7-5
7.2.6	Performance Based Contracts (ESCOs) .....	7-6

## Appendices

*Appendix A* Utility Bill Information

*Appendix B* Statement of Energy Performance Portfolio Manager Reference Sheet

*Appendix C* eQUEST Model Run Summaries

*Appendix D* Lighting Upgrades Analysis Spreadsheet

*Appendix E* Solar PV System Financial Analysis

*Appendix F* Facility Data Forms

*Appendix G* NJ Smart Incentives Information and Worksheets NJ Pay for Performance Incentive Structure

*Appendix H* Engineer’s Opinion of Probable Construction Costs

*Appendix I* ECRM Financial Analysis

*Appendix J* Wind Turbine Energy System Wind CAD Analysis

*Appendix K* Wind Turbine Energy System Financial Analysis



# Executive Summary

As part of an initiative to reduce energy cost and consumption, the Teaneck Board of Education (BOE) has secured the services of Camp Dresser and McKee (CDM) to perform an energy audit at their school facilities in an effort to develop comprehensive Energy Conservation and Retrofit Measures (ECRMs).

CDM's energy audit team visited the facilities on February 9-12, 2010. As a result of the site visits and evaluation of the historical energy usage of the facilities, CDM was successful in identifying opportunities for energy savings measures.

CDM has also evaluated the potential for renewable energy technologies to be implemented at the school facilities to offset the electrical energy usage. Specifically, the use of solar electric photovoltaic panels and wind turbines were investigated.

In addition to identifying ECRMs and the potential for on-site energy generation, an alternate third party supplier was contacted in an effort to identify further energy cost savings available for Teaneck BOE. This is discussed further in Section 5. Additionally, there is potential for Teaneck BOE to make money by participation in a Demand Response Program, as discussed in Section 5.2.

Not all ECRMs identified as a result of the energy audit are recommended. ECRMs must be economically feasible to be recommended for implementation. The feasibility of each ECRM was measured through a simple payback analysis. The simple payback period was determined after establishing Engineer's Opinion of Probable Construction Cost estimates, O&M estimates, projected annual energy savings estimates, and the potential value of New Jersey Clean Energy rebates, or Renewable Energy Credits, if applicable. Generally, ECRMs with a payback period of 20 years or less are recommended, unless other various factors need to be factored into the decision process.

## Historical Energy Usage

The following table, Table ES-1, summarizes the historical energy usage at each of the Board's facilities as presented in Section 3. These values can serve as a bench-marking tool, along with the building profiles that have been established through the EPA's Portfolio Manager Program, to quantify the reduction in electrical energy, natural gas usage, and oil usage following the implementation of the recommended ECRMs.

Table ES-1: Summary of Annual Energy Usage & Cost								
	Electrical Energy Use (kWh)	Peak Summer Demand (kW)	Peak Winter Demand (kW)	Fuel Use for Entire Building (therms)	Fuel Use for Entire Building (gallons oil)	Cost for Electric Service (\$/kWh)	Cost for Fuel (\$/therm)	Cost for Fuel (\$/gallon)
Benjamin Franklin Middle School	887,410	259	275	6,062	29,621	\$0.1541	\$1.26	\$2.31
Bryant Elementary	293,440	102	90	135	36,107	\$0.1730	\$2.41	\$2.32
Eugene Fields Administration Building	177,150	65	41	622	8,759	\$0.1648	\$1.42	\$2.30
Hawthorne Elementary School	402,390	122	128	41,795	-	\$0.1649	\$1.25	-
Lowell Elementary School	298,450	106	92	453	27,018	\$0.1876	\$1.40	\$2.36
Teaneck High School	1,962,270	618	501	130,184	86,701	\$0.1589	\$1.08	\$3.33
Teaneck High School - Scoreboard	5,355	141	75	-	-	\$1.0689	-	-
Teaneck High School - Athletic Field Lighting	5,698	76	71	-	-	\$2.1980	-	-
Thomas Jefferson Middle School	762,720	239	246	7,626	41,516	\$0.1781	\$1.24	\$2.40
Whittier Elementary School	385,100	126	113	306	28,959	\$0.1667	\$1.60	\$2.37

## Building Lighting and HVAC System ECRMs

The following table, Table ES-2, presents the ranking of recommended ECRMs identified for the building lighting and HVAC systems based on the simple payback analysis.

Additional ECRMs associated were identified and evaluated, as discussed in Sections 2 and 4; however, were not recommended due to longer payback periods. This table includes the Engineer's Opinion of Probable Construction Cost, projected annual energy cost savings, projected annual energy usage savings, and total simple payback



period for each recommended ECRM. The ECRMs are ranked based on payback period.

<b>Table ES-2<sup>1</sup></b>					
<b>Ranking of Energy Savings Measures for Building Lighting and HVAC Systems</b>					
<b>Overall Ranking (Based on Simple Payback)</b>	<b>Site</b>	<b>Total Cost</b>	<b>Anticipated Annual Energy Savings</b>	<b>Annual Fiscal Savings<sup>3</sup></b>	<b>Simple Payback (Years)</b>
1	Teaneck High School (separate DHW Heater)	\$5,240	1,300 therms	\$9,977	0.5
2	Teaneck High School - Press Box Lighting	\$107.8	7.1 kWh	\$78.02	1.4
3	Benjamin Franklin Middle School (Boiler Replacement)	\$98,127	12,192.9 therms	\$33,637	2.9
4	Thomas Jefferson Middle School(Boiler Replacement)	\$147,190	14,203.4 therms	\$48,667	3.1
5	Bryant Elementary School (DDC BMS)	\$40,915	3,322 gal oil; 21,038 kWh	\$11,347	3.6
6	Whittier Elementary School (DDC BMS)	\$47,539	3,122 gal oil; 20,053 kWh	\$10,742	4.4
7	Teaneck High School (VFD)	\$76,123	-3,522 gal oil; 173,640 kWh	\$15,863	4.8
8	Bryant Elementary School Lighting	\$96,319	89,811.3 kWh	\$18,291.8	5.3
9	Hawthorne Elementary School (DDC BMS)	\$42,584	4,297 therms; 13,276 kWh	\$7,560	5.6
10	Eugene Field Administration Building (DDC BMS)	\$21,456	911 gal oil; 10,212 kWh	\$3,777	5.7
11	Lowell Elementary School (DDC BMS)	\$40,629	2,064 gal oil; 11,932 kWh	\$7,109	5.7
12	Whittier Elementary School Lighting	\$108,502.9	16,811 kWh	\$18,477.9	5.9
13	Eugene Fields Administration Building Lighting	\$56,146.5	7,891.9 kWh	\$8,665.7	6.5
14	Teaneck High School Lighting	\$142,903.3	20,173.5 kWh	\$21,750.8	6.6
15	Benjamin Franklin Middle School Lighting	\$390,818.7	45,923.7 kWh	\$52,545.9	7.4
16	Thomas Jefferson Middle School Lighting	\$213,303.3	25,679.3 kWh	\$27,889.1	7.6
17	Bryant Elementary School (Boiler Replacement)	\$175,165	6987.7 therms	\$20,871	8.4
18	Lowell Elementary School Lighting	\$74,288.8	7,834.3 kWh	\$8,355	8.9
19	Hawthorne Elementary School Lighting	\$103,835.2	10,015.5 kWh	\$11,216	9.3
20	Hawthorne Elementary School (Boiler Replacement)	\$175,165	12,991.1 therms	\$17,739	9.9
21	Lowell Elementary School (Boiler Replacement)	\$216,990	8,654.1 therms	\$21,871	9.9
22	Eugene Field Administration	\$98,127	1,884.5	\$7,017	14.0

<b>Overall Ranking (Based on Simple Payback)</b>	<b>Site</b>	<b>Total Cost</b>	<b>Anticipated Annual Energy Savings</b>	<b>Annual Fiscal Savings<sup>3</sup></b>	<b>Simple Payback (Years)</b>
	<b>Building (Boiler Replacement)</b>		therms		
<b>23</b>	<b>Whittier Elementary School (Boiler Replacement)</b>	\$216,990	3506.8 therms	\$11,170	<b>19.4</b>
<b>24</b>	<b>Hawthorne Elementary School (AHU Replacement)</b>	\$16,963	268 therms; 2,098 kWh	\$681	<b>24.9</b>
<b>25</b>	<b>Teaneck High School (AHU Replacement)</b>	\$126,848	1,336 therms; 12,696 kWh	\$3,460	<b>36.7</b>

1. 'Total Cost' takes into account any applicable rebates.
2. Savings assume all building heat provided by natural gas and/or oil, at current aggregate rate per unit of fuel
3. 'Annual Fiscal Savings' takes into account maintenance costs.

## Renewable Energy ECRMs

### Solar Energy

Section 4.3 of the report provides for an economic evaluation of a solar energy system recommended to be installed at eight (8) of the Board's facilities. The evaluation covered the economic feasibility of the Board installing a solar energy system under a typical construction contract and to assume full responsibility of the operation of such a system.

Based on a simple payback model, summarized in Table ES-3, it would benefit the Board to further investigate the installation of a solar energy system at eight (8) buildings. This is primarily based on the initial upfront capital investment required for a solar energy system installation and the 12.1 year payback period. This payback period may justify installing the solar energy system. Other options, such as Power Purchase Agreements, are potentially available as well to help finance the project. Solar technology is constantly changing and will most likely continue to lower in price.

Two major factors influencing the project financial evaluation is the variance of the prevailing energy market conditions and Solar Renewable Energy Credit (SREC) rates, with the largest impact to the payback model being the SREC credit pricing. For the payback model, conservative estimates of the SREC's market value over a 15 year period were assumed, as discussed in Section 4.3.

Table ES-3 includes a simple payback analysis for the installation of a solar energy system at the identified Board buildings.

**Table ES-3: Simple Payback Analysis for Solar Energy Systems**

Parameter	Solar
Estimated Budgetary Project Cost	\$16,571,045
1 <sup>st</sup> Year Production	2,035,334 kWh
Annual Electric Savings	\$291,903.8
Annual Estimated SREC Revenue	\$1,078,023
<b>Project Simple Payback</b>	<b>12.1 Years</b>

## Wind Power Generation

Section 4.3.3 of the report provides for an economic evaluation of a wind turbine energy system recommended to be installed at eight (8) of the Teaneck School District facilities. The evaluation covered the economic feasibility of furnishing and installing a wind turbine energy system under a typical construction contract and to assume full responsibility of the operation of such a system.

CDM completed a preliminary desktop wind power production analysis and has concluded that an additional on-site feasibility study is warranted and recommended. Such a feasibility study would include the installation of a wind test rig to measure actual wind conditions as observed on-site.

Wind power as a renewable energy source also qualifies for Renewable Energy Certificates (REC's). The prevailing energy market, REIP and REC's comprise the major factors influencing a wind turbine energy system installation. Other options, such as government bonds or a Power Purchase Agreement, are potentially available and can assist with the financing of this project.

Table ES-4 includes a typical simple payback analysis for the installation of a wind turbine energy system located at several of the Teaneck Board of Education facilities. Refer to Appendix K for a more detailed wind energy financing spreadsheet.

<b>Table ES-4: Ranking of Energy Savings Measures Summary – Wind Turbine Energy System</b>			
Parameter	Wind Turbine (Minimum Site Wind Speed – 9.01 mph)	Wind Turbine (Maximum Site Wind Speed – 13.02 mph)	Wind Turbine (Average Site Wind Speed – 11.2 mph)
Engineer's Opinion of Probable Cost	\$21,895	\$21,895	\$21,895
Renewable Energy Incentive Program**	-\$12,214	-\$21,895	-\$20,304

<b>Parameter</b>	<b>Wind Turbine (Minimum Site Wind Speed – 9.01 mph)</b>	<b>Wind Turbine (Maximum Site Wind Speed – 13.02 mph)</b>	<b>Wind Turbine (Average Site Wind Speed – 11.2 mph)</b>
Total Cost	\$9,681	\$0	\$1,591
1 <sup>st</sup> Year Production	3,817 kWh	8,316 kWh	6,345 kWh
Annual Estimated Electric Savings	\$643.2	\$1,401.2	\$1,069.1
Annual Estimated REC Revenue	\$95	\$208	\$159
<b>Project Simple Payback</b>	<b>13.1 Years</b>	<b>0 Years</b>	<b>1.3 Years</b>

\*\* REIP incentive is calculated for only the first year and is applied as a deduction.

## Recommended ECRMs

Table ES-5 summarizes the Total Engineer's Opinion of Probable Construction Cost, annual energy savings, projected annual energy and O&M cost savings and the payback period based on the implementation of all of the above recommended ECRMs.

<b>Total Engineer's Opinion of Probable Construction Cost</b>	<b>Projected Annual Energy Savings (kWh, therms, or gal oil)</b>	<b>Projected Annual Fiscal Savings</b>	<b>Simple Payback Period (years)</b>
\$2,732,277	332,793 kWh 67,621.5 therms 5,897 gal oil	\$398,758	8.7

1. Does not include energy savings associated with Solar Energy System or Wind Power Generation.

# Section 1

## Introduction

### 1.1 General

As part of an initiative to reduce energy cost and consumption, the Teaneck Board of Education has secured the services of Camp Dresser and McKee (CDM) to perform an energy audit at the District's eight (8) school buildings in an effort to develop comprehensive energy conservation initiatives.

The performance of an Energy Audit requires a coordinated phased approach to identify, evaluate and recommend energy conservation and retrofit measures (ECRM). The various phases conducted under this Energy Audit included the following:

- Gather preliminary data on all facilities;
- Facility inspection;
- Identify and evaluate potential ECRMs;
- Develop the energy audit report.

Figure 1-1 is a schematic representation of the phases utilized by CDM to prepare the Energy Audit Report.




Figure 1-1: Energy Audit Phases

## 1.2 Background

The eight (8) schools that were included in the energy audit for the Teaneck Board of Education were Benjamin Franklin Middle School, Bryant Elementary School, Eugene Field Administration Building, Hawthorne Elementary School, Lowell Elementary School, Teaneck High School, Thomas Jefferson Middle School, and Whittier Elementary School.

The Benjamin Franklin Middle School is a 100,202 ft<sup>2</sup> building that was originally built in 1957. The school is utilized for middle school classes, grades 5 through 8, occupied by 575 students and approximately 105 faculty and staff members. The school is occupied by students from 6 am to approximately 4 pm during the week, with custodial coverage until 12 am. The school is closed on the weekends except for special events and is open during the summer for school classes and camps.

The Bryant Elementary School is a 47,438 ft<sup>2</sup> building that was originally built in 1926. The school is utilized for grades Pre K and K, occupied by 386 students and approximately 76 faculty and staff members. The school is occupied from 6 am to approximately 4 pm during the week, but is closed on the weekends and during the summer except for summer school classes and camps.

The Eugene Field Administration Building is a 24,877 ft<sup>2</sup> building that was originally built in 1955. The building is utilized for administration office space and is occupied by approximately 47 employees. The building is occupied from 6 am to approximately 4 pm during the week, is closed on the weekends, and opens during the summer for summer school classes and camps.

The Hawthorne Elementary School is a 49,373 ft<sup>2</sup> building that was originally built in 1925. The school is utilized for elementary school classes, grades 1 through 4, occupied by 342 students and approximately 60 faculty and staff members. The school is occupied from 6 am to approximately 4 pm during the week, but is closed on the weekends and during the summer except for summer school classes and camps.

The Lowell Elementary School is a 47,106 ft<sup>2</sup> building that was originally built in 1934. The school is utilized for elementary school classes, grades 1 through 4, occupied by 305 students and approximately 61 faculty and staff members. The school is occupied from 6 am to approximately 4 pm during the week, is closed on the weekends and opens during the summer for summer school classes and camps.

The Teaneck High School is a 215,808 ft<sup>2</sup> building that was originally built in 1927. The school is utilized for high school classes, grades 9 through 12, occupied by 1,410 students and approximately 187 faculty and staff members. The school is occupied from 6 am to approximately 8 pm during the week, and is open on the weekends and the summer for special events, summer school classes, and administrative purposes.

The Thomas Jefferson Middle School is a 105,216 ft<sup>2</sup> building that was originally built in 1958. The school is utilized for middle school classes, grades 5 through 8, occupied by 627 students and approximately 55 faculty and staff members. The school is occupied from 6 am to approximately 4 pm during the week, but is closed on the weekends and during the summer except for summer school classes and camps.

The Whittier Elementary School is a 55,118 ft<sup>2</sup> building that was originally built in 1921. The school is utilized for elementary school classes, grades 1 through 4, occupied by 402 students and approximately 55 faculty and staff members. The school is occupied from 6 am to approximately 4 pm during the week, but is closed on the weekends and during the summer except for administrative personnel.

### 1.3 Purpose and Scope

The objective of the energy audit is to identify energy conservation and retrofit measures to reduce energy usage and to develop an economic basis to financially validate the planning and implementation of identified energy conservation and retrofit measures.

Due to the rising costs of power and the desire to minimize dependence on foreign oil supplies, energy consumption is taking a higher priority across the nation. Significant energy savings may be available with retrofits to the buildings' envelopes, heating, cooling, and lighting systems. It should be noted that the magnitude of energy savings available is not only dependent on the type of heating, lighting or insulation systems that are in use, but also on the age and condition of the equipment and the capital available to implement major changes.

The purpose of this energy audit is to identify the various critical building comfort systems within the buildings that are major consumers of electrical energy and are clear candidates for energy savings measures. In addition, the potential for alternative energy systems to be installed at each building was evaluated and presented herein.



## Section 2

### Facility Description

#### 2.1 Benjamin Franklin Middle School

##### 2.1.1 Description of Building Envelope

The walls of the Benjamin Franklin Middle School consist of brick and mortar facade, and finished interior. The newer portions of the roofing system consist of fully adhered EPDM membrane over flat roof deck; older roof sections consist of sprayed foam insulation with light gray gravel finish over a flat roof deck. There was evidence of leakage and in general deterioration of the older foam system.



**Deteriorating Foam Roof**

The windows throughout the building are double-paned. The majority of exterior doors are FRP doors.

FRP doors are highly recommended from an energy efficiency perspective. FRP doors are made out of a high strength, light weight material with energy saving insulation and good sealing ability, as the doors will not expand or contract with changing climate. Weather stripping on these doors appeared to be in poor condition and in need of replacement.

It was determined that the building envelope is in good condition and is currently providing a fair level of insulation. It is recommended that a qualified roofing contractor evaluate the system, including the structural capacity of the building frame, and repair or replace the existing roofing system with an EPDM membrane roofing system. A roof replacement will be costly; therefore, the system analysis, including the structural integrity of the building, may warrant the application of an elastomeric waterproof roof coating system to rectify any leaks and improve the level of insulation that the current roof is providing.

It is also recommended that a white thermal barrier coating be considered. This coating works to reduce the surface temperature of the roof by reflecting the UV rays, and provides insulation for the interior of the building reducing the heating and cooling loads.

##### 2.1.2 Description of Building HVAC

Two oil-fired cast iron steam boilers located in the boiler room provide heat for the entire building. The steam from the boilers is fed through a heat exchanger to produce hot water that is then circulated to fan coil unit ventilators in each classroom. DX air handling units located throughout the building, including the roof provide heating, cooling, or both to the zones they serve.

Ductless split system and through-the-wall air conditioning units provide cooling for the computer lab, server room, nurse's office, main office, administration area, principal's office, media center, operation and maintenance office, windowless

classrooms, guidance rooms, technology rooms, mail room, reading room, teacher's break room and a few other classrooms.

Domestic hot water for this building is produced by a gas fired water heater.

### **2.1.3 Description of Building Lighting**

The Benjamin Franklin Middle School existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## **2.2 Bryant Elementary School**

### **2.2.1 Description of Building Envelope**

The walls of the Bryant Elementary School consist of brick and mortar façade or Exterior Insulated Finish System (EIFS) with finished interior. The existing roofing system consists of fully adhered EPDM membrane over flat roof that is 13 years old, and slate shingles over pitched roof decks that are 70 years old.

The windows throughout the building are double-paned windows. The majority of exterior doors are FRP doors. FRP doors are highly recommended from an energy efficiency perspective. FRP doors are made out of a high strength, light weight material with energy saving insulation and good sealing ability, as the doors will not expand or contract with changing climate. Weather stripping on these doors appeared to be in poor condition and in need of replacement. There was also gapping noted between the door and door frame allowing for air to infiltrate into the building. Door replacement should be considered on main entrance doors.

### **2.2.2 Description of Building HVAC**

Two oil-fired cast iron steam boilers located in the boiler room provide heat for the entire building. The steam from the boilers is fed through a heat exchanger to produce hot water for space heating. This water is circulated through the unit ventilators in some of the classrooms. One DX air handling unit located on the roof and another located at grade provide cooled outdoor air throughout the building. An older portion of the building employs steam heating with either unit ventilators or two-pipe steam radiator units.

Ductless split system and through the wall air conditioning units provide cooling for the nurse's office, some interior classrooms, special services room, server room, speech therapy room, child therapy room, principal's office, main office, and teacher's lounge.

Domestic hot water for this building is produced from a 50 gallon and a 40 gallon electric water heater.

### **2.2.3 Description of Building Lighting**

The Bryant Elementary School existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## **2.3 Eugene Field Administration Building**

### **2.3.1 Description of Building Envelope**

The walls of the Eugene Field Administration Building are composite cavity walls consisting of brick and mortar facade, cavity and concrete masonry CMU back-up blocks and finished interiors in some location. The exterior walls appear to be in good condition. The existing roofing system consists of sprayed foam with gray aggregate that is approximately 16 years old. At the time of the audit, CDM was informed that the roof was scheduled for replacement this summer, but is on hold pending budget considerations.

The windows throughout the building are single and double-paned windows. The majority of exterior doors are FRP doors. FRP doors are highly recommended from an energy efficiency perspective. FRP doors are made out of a high strength, light weight material with energy saving insulation and good sealing ability, as the doors will not expand or contract with changing climate. Weather stripping on these doors appeared to be in poor condition and in need of replacement. There was also gapping noted between the door and door frame allowing for air to infiltrate into the building.

### **2.3.2 Description of Building HVAC**

Two oil-fired cast iron steam boilers located in the boiler room provide heat for the entire building. The steam from the boilers is fed through a heat exchanger to produce hot water for space heating. This water is then circulated through unit ventilators in each classroom.

Two air handling units located in the gym. Each is equipped with a DX cooling coil section and hot water coil section to provide heated and cooled air to the gym. These air handling units also provide outside air for ventilation.

Ductless split system and through the wall air conditioning units provide cooling for all rooms within the buildings.

Domestic hot water for this building is produced from a 50 gallon natural gas-fired water heater.

### **2.3.3 Description of Building Lighting**

The Eugene Field Administration Building existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures

with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## 2.4 Hawthorne Elementary School

### 2.4.1 Description of Building Envelope

The walls of the Hawthorn Elementary School consist of brick and mortar facade, and finished interior. The existing roofing system consists of fully adhered EPDM membrane over flat roof that is approximately 13 years old, asbestos composite shingles over pitched roof decks that are 70 years old, and sprayed foam with aggregate surfacing that is 16 years old. No pooling was observed, but existing shingled pitched roof appeared to be in poor condition.

The windows throughout the building are double-paned windows.

It was also noted that Hawthorn Elementary School has a number of window AC units. It is recommended that the air conditioning sleeves be checked for a tight seal and if the AC units are left in place through the winter, AC covers should be purchased and installed. It was noted during the audit that the AC units serving the office are covered during the winter. An outdoor AC cover covers the top and sides of the unit to stop drafts. Window and through-wall AC covers are UV resistant, water repellent PVC vinyl with elasticized corners and straps for a tight fit. Outdoor or indoor AC covers can also be customized to meet the District's needs. A standard outdoor AC cover can cost around \$15. The impact on the overall building heating load will be minimal; however, there will be a direct impact on the occupants comfort.



Example of an Outdoor AC Cover

### 2.4.2 Description of Building HVAC

Two natural gas-fired cast iron steam boilers located in the boiler room provide heat for the entire building. The steam from the boilers is fed through a heat exchanger to produce hot water for space heating. This water is then circulated through unit ventilators in some of the classrooms. Two DX air handling units located on the roof and one located in the cafeteria. These air handling units provide heated and cooled air throughout the building. These air handling units also provide the building with outside air for ventilation. An older portion of the building employs steam heating with either unit ventilators or two-pipe steam radiator units.

Ductless split system and through the wall air conditioning units provide cooling for the principal's office, server closet, teacher's lounge, child study room, nurse's office, and room 11.

Domestic hot water for this building is produced from an 80 gallon electric hot water heater.

### **2.4.3 Description of Building Lighting**

The Hawthorne Elementary School existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## **2.5 Lowell Elementary School**

### **2.5.1 Description of Building Envelope**

The walls of the Lowell Elementary School are composite cavity walls consisting of brick and mortar facade, cavity and concrete masonry CMU back-up blocks and finished interiors in some locations. The exterior walls appear to be in good condition. The roofing system consists of hot tar built up roof with white granular finish and asphalt shingles over pitched roof decks. At the time of the audit, CDM was informed that the flat roof was replaced within the past year, while the asphalt shingles are about 6 years old.

The windows throughout the building are double-paned. The majority of the exterior doors are FRP doors.

It was determined that the building envelope is in good condition and is currently providing a high level of insulation. As such, any modifications to the insulation system would not prove to be cost effective from an energy savings stand-point.

### **2.5.2 Description of Building HVAC**

Two oil-fired cast iron steam boilers located in the boiler room provide heat for the entire building. The steam from the boilers is fed through a heat exchanger to produce hot water for space heating. This water is then circulated through unit ventilators in some of the classrooms. One DX air handling unit located on the roof and two located in the building provide cooled outdoor air throughout the building. An older portion of the building employs steam heating with either unit ventilators or two-pipe steam radiator units.

Ductless split system and through the wall air conditioning units provide cooling for the principal's office, main office, special education rooms, library, server closet, computer room, and nurse's office.

Domestic hot water for this building is produced from a 40 gallon natural gas fired water heater.



### 2.5.3 Description of Building Lighting

The Lowell Elementary School existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## 2.6 Teaneck High School

### 2.6.1 Description of Building Envelope

The walls of the Teaneck High School are composite cavity walls consisting of brick and mortar facade, and finished interior. The existing roofing system is about 16 years old and consists of sprayed foam roofing with light gray gravel finish over a flat roof deck. There was evidence of leakage and in general deterioration of the existing system.

The windows throughout the building are double and single paned. The majority of exterior doors are FRP doors. FRP doors are highly recommended from an energy efficiency perspective. FRP doors are made out of a high strength, light weight material with energy saving insulation and good sealing ability, as the doors will not expand or contract with changing climate. Weather stripping on these doors appeared to be in poor condition and in need of replacement.

It was determined that the building envelope is in fair condition. It is recommended that a qualified roofing contractor evaluate the system, including the structural capacity of the building frame, and repair or replace the existing roofing system with an EPDM membrane roofing system. A roof replacement will be costly; therefore, the system analysis including the structural integrity of the building may warrant the application of an elastomeric waterproof roof coating system to rectify any leaks and improve the level of insulation that the current roof is providing.



High School Foam Roof Deterioration

### 2.6.2 Description of Building HVAC

Two oil-fired cast iron steam boilers located in the boiler room provide serve as a heat source for the building. The boilers are dual-fueled and thus have the ability to be fired with natural gas-fired or fuel oil. These boilers operate throughout the year. The steam from the boilers serves a number of purposes. A portion of the steam is fed through a hot water heat exchanger for space heating. This water is circulated through unit ventilators in each classroom. Another portion of the steam serves a separate double wall heat exchanger to generate domestic hot water.

The steam also energizes a single-stage absorption liquid chiller located in the boiler room, which generates chilled water for building cooling. The aforementioned unit

ventilators use this chilled water to cool the spaces they are located in. The chiller is typically in operation only during peak conditions in the summer months. A couple of separate screw chillers, located adjacent to the boiler room, are responsible for the majority of the summer cooling load. Air handling units equipped with a DX cooling and hot water coil heating sections are located throughout the building, including the roof. These air handling units provide heating, cooling, or both to the zones they serve.

Ductless split system and through the wall air conditioning units provide cooling for the server closet, main office, principal's office, nurse's office, technical closet, administrative office, and technician's room.

### **2.6.3 Description of Building Lighting**

The Teaneck High School existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## **2.7 Thomas Jefferson Middle School**

### **2.7.1 Description of Building Envelope**

The majority of the walls of the Thomas Jefferson Middle School are composite cavity walls consisting of brick and mortar facade, cavity and concrete masonry CMU back-up blocks with interior finishes. The majority of the roofing system consists of hot tar built up roof with white granular finish over a flat roof deck. This system was installed in two phases within the past two years.

The windows throughout the building are double-paned. The majority of the exterior doors are FRP doors.

It was determined that the building envelope is in good condition and is currently providing a high level of insulation. As such, any modifications to the insulation system would not prove to be cost effective from an energy savings stand-point.

### **2.7.2 Description of Building HVAC**

Two oil-fired cast iron steam boilers located in the boiler room provide heat for the entire building. The steam from the boilers is fed through a heat exchanger to produce hot water for space heating. This water is then circulated through unit ventilators in each classroom. Air handling units located throughout the building provide heating and cooling, to the zones they serve. These air handling units have DX cooling coils and hot-water heating coils.

Ductless split system and through the wall air conditioning units provide cooling for the child guidance room, main office, principal's office, server closet, nurse's office, teacher's lounge, and basement computer room.



Unit heaters provide heat for the corridor adjacent to the boiler room and the kitchen office.

Domestic hot water for this building is produced from a 199 MBH gas-fired water heater located in the boiler room.

### **2.7.3 Description of Building Lighting**

The Thomas Jefferson Middle School existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## **2.8 Whittier Elementary School**

### **2.8.1 Description of Building Envelope**

The majority of the walls of the Whittier Elementary School are composite cavity walls consisting of brick and mortar facade, cavity and concrete masonry CMU back-up blocks with interior finishes. The majority of the existing roofing system consists of hot tar built up roof with white granular finish and asphalt shingles over pitched roof decks. This system was installed within the past year. The existing (center) portion consists of fully adhered EPDM membrane over flat roof.

The windows throughout the building are double-paned windows. The majority of exterior doors are FRP doors. FRP doors are highly recommended from an energy efficiency perspective. FRP doors are made out of a high strength, light weight material with energy saving insulation and good sealing ability, as the doors will not expand or contract with changing climate. Weather stripping on these doors appeared to be in poor condition and in need of replacement.

It was determined that the building envelope is in good condition and is currently providing a high level of insulation. As such, any modifications to the insulation system would not prove to be cost effective from an energy savings stand-point.

### **2.8.2 Description of Building HVAC**

Two oil-fired cast iron steam boilers, located in the boiler room, provide heat for the entire building. Steam from the boilers is fed through a heat exchanger to produce hot water for space heating. This water is then circulated through unit ventilators in each classroom. An older portion of the building employs steam heating with either unit ventilators or two-pipe steam radiator units.

Ductless split system and through the wall air conditioning units provide cooling for the cafeteria, elevator, basement lunch room, main office, principal's office, computer room, child study room, and nurse's office.

Domestic hot water for this building is produced from a 50 gallon natural gas-fired water heater and an 80 gallon electric water heater.

### **2.8.3 Description of Building Lighting**

The Whittier Elementary School existing lighting system consists of 1X4 (1, and 2 lamp), 1X8 (2 lamp), 2X2 (2 lamp), and 2X4 (2, 3, and 4 lamp) T12 linear fluorescent fixtures with magnetic ballasts, 1X4 (2 lamp) T8 linear fluorescent fixtures with electronic ballasts, metal halide fixtures, incandescent fixtures, and CFL fixtures. See Section 4 for a more detailed description.

## **2.9 Teaneck High School Athletic Field Lighting, Scoreboard, and Well Pump**

### **2.9.1 Description of Press Box Building HVAC**

An electric unit heater provides heat for the press box when needed.

### **2.9.2 Description of Press Box Building Lighting**

The existing lighting system in the Press Box consists of incandescent fixtures and CFL fixtures. See Section 4 for a more detailed description.

### **2.9.3 Description of Athletic Field Lighting**

The Athletic Field lighting system consists of four lighting towers, each containing 21 1000 Watt Metal Halide fixtures. See Section 4 for a more detailed description.

### **2.9.4 Description of Scoreboard**

The scoreboard is manufactured by the Fairtron Corporation. Additional information pertaining to the scoreboard was unavailable because equipment tags were missing.

### **2.9.5 Description of Well Pump**

Information on the existing well pump was unavailable.

## **2.10 Miscellaneous Equipment**

The classrooms throughout Teaneck contain computers, printers, TVs and overhead projectors. In addition, the schools also have tech centers and libraries with 20 or more computers in each.

It is recommended that the Board consider implementing the standardized use of Smart Strips. Computer peripherals, such as monitors, printers or scanners, continue to use energy even after they are shut off, which adds up over time. The Smart Strip power strips offer surge protection and the ability to monitor the current on a single 'control' outlet. When the computer that is plugged into that single outlet is shut down the Smart Strip shuts off all of the other peripherals on the power strip. This is discussed further in Section 4.4.

The schools also have office areas and nurse's offices that contain copiers, microwaves, refrigerators, vending machines, soda machines and coffee makers.

The schools kitchens contain a number of appliances including convection ovens, refrigerators, electric warming tables and cabinets and walk-in refrigerators and freezers.

It is recommended that the District implement the standardized use of Energy Star appliances, as the need arises. All of the copiers that were noted during the audit were Energy Star copiers. Energy Star refrigerators and freezers, for example, use up to 40% less energy than models built in 2001. Energy Star appliances will not only reduce the District's utility bills, but will also outperform standard appliances, due to the improved design and advanced technologies.

# Section 3

## Baseline Energy Use

### 3.1 Utility Data Analysis

The first step in the energy audit process is the compilation and quantification of the facility's current and historical energy usage and associated utility costs. It is important to establish the existing patterns of electric, gas, and oil usage in order to be able to identify areas in which energy consumption can be reduced.

For this study, the monthly oil, gas, and electric bills per facility were analyzed and unit costs of energy were obtained. The unit cost of energy, as determined from the information provided by the Board of Education, was utilized in determining the feasibility of switching from one energy source to another or reducing the demand on that particular source of energy to create annual cost savings for the Board of Education.

#### 3.1.1 Electric Charges

It is important to understand how the utility companies charge for the service. The majority of the energy consumed is electric, as a result of both indoor and outdoor lighting, heating, ventilating and air-conditioning equipment. Electricity is charged by three basic components: electrical consumption (kWH), electrical demand (kW) and power factor (kVAR) (reactive power). The cost for electrical consumption is similar to the cost for fuel oil. The monthly consumption appears on the utility bill as kWH consumed per month with a cost figure associated with it. The service connections are either billed on a flat rate or time of day rates per kWH.

Electrical demand can be as much as 50 percent or more of the electric bill. The maximum demand (kW value) during the billing period is multiplied by the demand cost factor and the result is added to the electric bill. It is often possible to decrease the electric bill by 15 - 25 percent by reducing the demand, while still using the same amount of energy.

The power factor (reactive power) is the power required to energize electric and magnetic fields that result in the production of real power. Power factor is important because transmission and distribution systems must be designed and built to manage the need for real power as well as the reactive power component (the total power). If the power factor is low, then the total power required can be greater than 50 percent or more than the real power alone. The power factor charge is a penalty for having a low power factor. This penalty does not affect the Board.

The other parts of the electric bill are the supply charges, delivery charges, system benefits, transmission revenue adjustments, state and municipality tariff surcharges and sales taxes, which cannot be avoided.

PSE&G is the current supplier and distributor of electric energy for the Teaneck Board of Education.

### **3.1.2 Natural Gas Charges**

PSE&G is the current supplier and distributor of natural gas for the school facilities. The school facilities are charged for the cost of the natural gas, a delivery charge and a customer charge, which covers gas administration charges.

### **3.1.3 Oil Charges**

Allied Oil LLC and Rachles/Michele's Oil Company are the current suppliers and distributors of oil for the school facilities. The school facilities are charged for oil by the gallon.

## **3.2 Facility Results**

### **3.2.1 Benjamin Franklin Middle School**

Electric power for the Benjamin Franklin Middle School Building is fed from one General Secondary Service three phase line from PSE&G. The Benjamin Franklin Middle School also has generation supplied by South Jersey Energy. Figure 3.2-1 illustrates the average monthly total energy consumption from January 2008 through December 2009. For example, for the month of October, the bar graph represents average energy consumption for October 2008 and October 2009. This same graphical representation approach has been carried through for all months and is typical for all graphs presented in this Section. Electrical usage has been averaged by month for the above referenced time period to portray a more encompassing monthly usage trend.

From this graph, it can be determined that the average annual electrical consumption for the Benjamin Franklin Middle School is approximately 71,421 kWh / month. An unexpected peak in electrical consumption in October should be investigated further by the Board. Lowering the electrical consumption in October could result in significant energy cost savings.

Figure 3.2-1: Benjamin Franklin Middle School Electrical Usage





Figure 3.2-2 illustrates the average monthly demand load for the Benjamin Franklin Middle School from January 2008 through December 2009.

Figure 3.2-2: Benjamin Franklin Middle School Maximum Monthly Demand




The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 4200867818</b>
Customer Charge:	\$374.60
Delivery Service Charges:	\$0.005101024/kWh On-Peak \$0.00510089/kWh Off-Peak \$3.247/kW
Societal Benefits Charge:	\$0.007568060/kWh
Securitization Transition Charge:	\$0.010353944/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.

The gas usage for the Benjamin Franklin Middle School is metered at one location. The monthly average gas consumption from July 2007 through December 2009 at the school is illustrated in Figure 3.2-3.

**Figure 3.2-3: Benjamin Franklin Middle School Natural Gas Usage**




For more information on the Benjamin Franklin Middle School's gas usage, refer to Section 4.3.



The oil usage for the Benjamin Franklin Middle School is metered at one location. The monthly average oil consumption from November 2007 through December 2009 at the school is illustrated in Figure 3.2-4.

Figure 3.2-4: Benjamin Franklin Middle School Oil Usage



### 3.2.2 Bryant Elementary School

Electric power for the Bryant Elementary School is fed from one General Secondary Service three phase line from PSE&G. The Bryant Elementary School also has generation supplied by South Jersey Energy. Figure 3.2-5 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Bryant Elementary School is approximately 24,453 kWh / month. Unexpected peaks in electrical consumption in April and October, and electrical demand in May should be investigated further by the Board. Lowering the electrical consumption in April and October and the electrical demand in May could result in significant energy cost savings.

Figure 3.2-5: Bryant Elementary School Electrical Usage





Figure 3.2-6 illustrates the monthly demand load for the Bryant Elementary School from January 2008 through December 2009.

Figure 3.2-6: Bryant Elementary School Maximum Monthly Demand




The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 6582867106</b>
Customer Charge:	\$10.12
Delivery Service Charges:	\$0.008990181/kWh
	\$3.92/kW
Societal Benefits Charge:	\$0.00756976/kWh
Securitization Transition Charge:	\$0.010353852/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.


The Bryant Elementary School's monthly average natural gas consumption from July 2007 through December 2009 is illustrated in Figure 3.2-7.

**Figure 3.2-7: Bryant Elementary School Natural Gas Usage**



The oil usage for the Bryant Elementary School is metered at one location. The monthly average oil consumption from November 2007 through December 2009 at the school is illustrated in Figure 3.2-8.

Figure 3.2-8: Bryant Elementary School Oil Usage



### 3.2.3 Eugene Field Administration Building

Electric power for Eugene Field Administration Building is fed from one General Secondary Service three phase line from PSE&G. The Eugene Field Administration Building also has generation supplied by South Jersey Energy. Figure 3.2-9 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Eugene Field Administration Building is approximately 28,670 kWh / month. An unexpected peak in electrical demand in May should be investigated further by the Board. Lowering the demand in May could result in significant energy cost savings.

Figure 3.2-9: Eugene Field Administration Building Electrical Usage





Figure 3.2-10 illustrates the monthly demand load for the Eugene Field Administration Building from January 2008 through December 2009.

**Figure 3.2-10: Eugene Field Administration Building Maximum Monthly Demand**




The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 6642121902</b>
Customer Charge:	\$4.27
Delivery Service Charges:	\$0.008990092/kWh
	\$3.92/kW
Societal Benefits Charge:	\$0.007568294/kWh
Securitization Transition Charge:	\$0.010353857/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.


Eugene Field Administration Building's monthly average natural gas consumption from July 2007 through December 2009 is illustrated in Figure 3.2-11.

Figure 3.2-11: Eugene Field Administration Building Natural Gas Usage



The oil usage for the Eugene Field Administration Building is metered at one location. The monthly average oil consumption from November 2007 through December 2009 at the school is illustrated in Figure 3.2-12.

Figure 3.2-12: Eugene Field Administration Building Oil Usage



### 3.2.4 Hawthorne Elementary School

Electric power for the Hawthorne Elementary School is fed from one General Secondary Service line from PSE&G. The Hawthorne Elementary School also has generation supplied by South Jersey Energy. Figure 3.2-13 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Hawthorne Elementary School is approximately 32,470 kWh / month. An unexpected peak in electrical demand in May should be investigated further by the Board. Lowering the demand in May could result in significant energy cost savings.

Figure 3.2-13: Hawthorne Elementary School Electrical Usage





Figure 3.2-14 illustrates the monthly demand load for the Hawthorne Elementary School from January 2008 through December 2009.



Figure 3.2-14: Hawthorne Elementary School Maximum Monthly Demand




The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 6756264303</b>
Customer Charge:	\$4.27
Delivery Service Charges:	\$0.008990096/kWh
	\$3.92/kW
Societal Benefits Charge:	\$0.007567912/kWh
Securitization Transition Charge:	\$0.010353990/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.

Hawthorne Elementary School's monthly average natural gas consumption from July 2007 through December 2009 is illustrated in Figure 3.2-15.

Figure 3.2-15: Hawthorne Elementary School Natural Gas Usage



### 3.2.5 Lowell Elementary School

Electric power for the Lowell Elementary School is fed from one General Secondary Service three phase line from PSE&G. The Lowell Elementary School also has generation supplied by South Jersey Energy. Figure 3.2-16 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Lowell Elementary School is approximately 23,971 kWh / month. An unexpected peak in electrical consumption in electrical demand in May should be investigated further by the Board. Lowering the electrical demand in May could result in significant energy cost savings.

Figure 3.2-16: Lowell Elementary School Electrical Usage





Figure 3.2-17 illustrates the monthly demand load for the Lowell Elementary School from January 2008 through December 2009.

**Figure 3.2-17: Lowell Elementary School Maximum Monthly Demand**




The charges listed below can be found on the electrical bills provided by PSE&G.

<b>Acct #: 6590052301</b>	
Customer Charge:	\$4.27
Delivery Service Charges:	\$0.008946429/kWh (First 2240) \$0.008990017/kWh (After 2240) \$3.92/kW
Societal Benefits Charge:	\$0.007568038/kWh
Securitization Transition Charge:	\$0.010354035/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.


Lowell Elementary School's monthly average natural gas consumption from July 2007 through December 2009 is illustrated in Figure 3.2-18.

Figure 3.2-18: Lowell Elementary School Natural Gas Usage



The oil usage for the Lowell Elementary School is metered at one location. The monthly average oil consumption from November 2007 through December 2009 at the school is illustrated in Figure 3.2-19.

Figure 3.2-19: Lowell Elementary School Oil Usage



### 3.2.6 Teaneck High School - Main Building

Electric power for the Teaneck High School - Main Building is fed from one General Secondary Service three phase line from PSE&G. Figure 3.2-20 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Teaneck High School - Main Building is approximately 163,786 kWh / month. An unexpected peak in electrical demand in May should be investigated further by the Board. Lowering the electrical consumption and demand in May could result in significant energy cost savings.

Figure 3.2-20: Teaneck High School Electrical Usage





Figure 3.2-21 illustrates the monthly demand load for the Teaneck High School from January 2008 through December 2009.

Figure 3.2-21: Teaneck High School Maximum Monthly Demand




The charges listed below can be found on the electrical bills provided by PSE&G.

<b>Acct #: 4200312018</b>	
Customer Charge:	\$374.60
Basic Generation Service:	\$0.10389401/kWh (First 72519 kWh On Peak) \$0.10314687/kWh (First 32340 kWh On Peak) \$0.07437209/kWh (First 38995 kWh Off Peak) \$0.07362508/kWh (First 22725 kWh Off Peak) \$6.80/kW
Delivery Service Charges:	\$0.00505946/kWh (First 72519 kWh On Peak) \$0.00510084/kWh (First 32340 kWh On Peak) \$0.00505902/kWh (First 38995 kWh Off Peak) \$0.00510357/kWh (First 22725 kWh Off Peak) \$3.25/kW
Societal Benefits Charge:	\$0.007568001/kWh
Securitization Transition Charge:	\$0.10354006/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.


Teaneck High School's monthly average natural gas consumption from July 2007 through December 2009 is illustrated in Figure 3.2-22.

Figure 3.2-22: Teaneck High School Natural Gas Usage



The oil usage for the High School is metered at one location. The monthly oil consumption from January 2008 through December 2008 at the school is illustrated in Figure 3.2-23.

Figure 3.2-23: Teaneck High School Oil Usage





### 3.2.7 Teaneck High School - Athletic Field Lighting

Electric power for the Teaneck High School - Athletic Field Lighting is fed from one General Secondary Service three phase line from PSE&G. The Teaneck High School - Athletic Field Lighting also has generation supplied by South Jersey Energy. Figure 3.2-24 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Teaneck High School - Athletic Field Lighting is approximately 486 kWh / month. A peak in electrical usage and demand from September to December can be attributed to the fall sports program, along with shorter daylight hours. The unexpected spike in electrical demand in July should be investigated by the School District.

Figure 3.2-24: Teaneck High School - Athletic Field Lighting Electrical Usage





Figure 3.2-25 illustrates the monthly demand load for the Teaneck High School - Athletic Field Lighting from January 2008 through December 2009.

Figure 3.2-25: Teaneck High School - Athletic Field Lighting Maximum Monthly Demand



The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 6580617004</b>
Customer Charge:	\$4.27
Delivery Service Charges:	\$0.008990854/kWh
	\$3.92/kW
Societal Benefits Charge:	\$0.007567073/kWh
Securitization Transition Charge:	\$0.010353659/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.

### 3.2.8 Teaneck High School - Scoreboard

Electric power for the Teaneck High School - Scoreboard is fed from one General Secondary Service three phase line from PSE&G. Figure 3.2-26 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Teaneck High School is approximately 441 kWh / month. An unexpected peak in electrical demand in June and July should be investigated further by the Board. A peak in electrical usage and demand from September to November can be attributed to the fall sports program, along with shorter daylight hours. The unexpected spike in electrical demand in June and July should be investigated by the School District.

Figure 3.2-26: Teaneck High School - Scoreboard Electrical Usage





Figure 3.2-27 illustrates the monthly demand load for the Teaneck High School - Scoreboard from January 2008 through December 2009.

Figure 3.2-27: Teaneck High School - Scoreboard Maximum Monthly Demand



The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 6747639304</b>	
Customer Charge:	\$4.27	
Delivery Service Charges:	\$0.008971963/kWh	
	\$3.920560748/kW	
Supply Charges:	BGS Capacity	\$5.123639960/kW - Generation
		\$1.673790776/kW - Transmission
	BGS Energy	\$0.088695652/kWh - First 69 kWh
		\$0.089473684/kWh - Next
Societal Benefits Charge:	\$0.007570093/kWh	
Securitization Transition Charge:	\$0.010373832/kWh	

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.

### 3.2.9 Thomas Jefferson Middle School

Electric power for Thomas Jefferson Middle School is fed from one General Secondary Service three phase line from PSE&G. The Thomas Jefferson Middle School also has generation supplied by South Jersey Energy. Figure 3.2-28 illustrates the average

monthly total energy consumption from July 2007 through March 2009. From this graph, it can be determined that the average annual electrical consumption for the Thomas Jefferson Middle School is approximately 64,967 kWh / month.

Figure 3.2-28: Thomas Jefferson Middle School Electrical Usage





Figure 3.2-29 illustrates the monthly demand load for the Thomas Jefferson Middle School from January 2008 through December 2009.

Figure 3.2-29: Thomas Jefferson Middle School Maximum Monthly Demand




The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 4200398818</b>
Customer Charge:	\$449.52
Delivery Service Charges:	\$0.005100995/kWh (First 58320) \$0.005100962/kWh (After 31200) \$3.896/kW
Societal Benefits Charge:	\$0.007568029/kWh
Securitization Transition Charge:	\$0.010353999/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.


Thomas Jefferson Middle School's monthly average natural gas consumption from July 2007 through December 2009 is illustrated in Figure 3.2-30.

**Figure 3.2-30: Thomas Jefferson Middle School Natural Gas Usage**



The oil usage for the Thomas Jefferson Middle School is metered at one location. The monthly total gas consumption from November 2008 through December 2009 at the school is illustrated in Figure 3.2-31.

Figure 3.2-31: Thomas Jefferson Middle School Oil Usage



### 3.2.10 Whittier Elementary School

Electric power for the Whittier Elementary School is fed from one General Secondary Service three phase line from PSE&G. The Whittier Elementary School also has generation supplied by South Jersey Energy. Figure 3.2-32 illustrates the average monthly total energy consumption from January 2008 through December 2009. From this graph, it can be determined that the average annual electrical consumption for the Whittier Elementary School is approximately 31,406 kWh / month. Unexpected peaks in electrical consumption in electrical demand in May should be investigated further by the Board. Lowering the electrical demand in May could result in significant energy cost savings.



Figure 3.2-32: Whittier Elementary School Electrical Usage





Figure 3.2-33 illustrates the monthly demand load for the Whittier Elementary School from January 2008 through December 2009.

Figure 3.2-33: Whittier Elementary School Maximum Monthly Demand




The charges listed below can be found on the electrical bills provided by PSE&G.

	<b>Acct #: 6612801603</b>
Customer Charge:	\$4.27
Delivery Service Charges:	\$0.008990051/kWh
	\$3.92/kW
Societal Benefits Charge:	\$0.007568112/kWh
Securitization Transition Charge:	\$0.010354082/kWh

Refer to Table 3.3-1, in Section 3.3 for the average electrical aggregate cost. These tariffs are subject to change quite frequently. Refer to Appendix A for a complete Historical Data Analysis.


Whittier Elementary School's monthly average natural gas consumption from July 2007 through December 2009 is illustrated in Figure 3.2-34.

**Figure 3.2-34: Whittier Elementary School Natural Gas Usage**



The oil usage for the Whittier Elementary School is metered at one location. The monthly total gas consumption from July 2008 through October 2009 at the school is illustrated in Figure 3.2-35.

Figure 3.2-35: Whittier Elementary School Oil Usage



### 3.3 Aggregate Costs

For the purposes of computing energy savings for all identified energy conservation and retrofit measures, aggregate unit costs for electrical energy and fuel, in terms of cost/kWH and cost/therm, were determined for each service location and utilized in the simple payback analyses discussed in subsequent sections. The aggregate unit cost accounts for all distribution and supply charges for each location. Table 3.3-1 and Table 3.3-2 summarize the aggregate costs for electrical energy consumption and therms utilized, respectively.

Table 3.3-1: Electrical Aggregate Unit Costs

Service Location	Aggregate \$ / kW-hr
Benjamin Franklin Middle School	\$0.1541
Bryant Elementary School	\$0.1730
Eugene Field Administration Building	\$0.1648
Hawthorne Elementary School	\$0.1648
Lowell Elementary School	\$0.1876
Teaneck High School	\$0.1589
Teaneck High School - Scoreboard	\$1.0689
Teaneck High School - Athletic Field Lights	\$2.1980
Thomas Jefferson Middle School	\$0.1781
Whittier Elementary School	\$0.1667

**Table 3.3-2: Natural Gas Aggregate Unit Costs**

Service Location	Aggregate \$ / therm
Benjamin Franklin Middle School	\$1.26
Bryant Elementary School	\$2.41
Eugene Field Administration Building	\$1.42
Hawthorne Elementary School	\$1.25
Lowell Elementary School	\$1.40
Teaneck High School	\$1.08
Thomas Jefferson Middle School	\$1.24
Whittier Elementary School	\$1.60

**Table 3.3-3: Oil Aggregate Unit Costs**

Service Location	Aggregate \$ / gallon
Benjamin Franklin Middle School	\$2.31
Bryant Elementary School	\$2.32
Eugene Field Administration Building	\$2.30
Lowell Elementary School	\$2.36
Teaneck High School	\$3.33
Thomas Jefferson Middle School	\$2.40
Whittier Elementary School	\$2.37

## 3.4 Portfolio Manager

### 3.4.1 Portfolio Manager Overview

Portfolio Manager is an interactive energy management tool that allows Teaneck BOE to track and assess energy consumption at the school facilities in a secure online environment. Portfolio Manager can help Teaneck BOE set investment priorities, verify efficiency improvements, and receive EPA recognition for superior energy performance.

### 3.4.2 Energy Performance Rating

For many facilities, you can rate their energy performance on a scale of 1-100 relative to similar facilities nationwide. Your facility is *not* compared to the other facilities entered into Portfolio Manager to determine your ENERGY STAR rating. Instead, statistically representative models are used to compare your facility against similar facilities from a national survey conducted by the Department of Energy's Energy

Information Administration. This national survey, known as the Commercial Building Energy Consumption Survey (CBECS), is conducted every four years, and gathers data on building characteristics and energy use from thousands of facilities across the United States. Your facility's peer group of comparison is those facilities in the CBECS survey that have similar facility and operating characteristics. A rating of 50 indicates that the facility, from an energy consumption standpoint, performs better than 50% of all similar facilities nationwide, while a rating of 75 indicates that the facility performs better than 75% of all similar facilities nationwide.

### **3.4.3 Portfolio Manager Account Information**

A Portfolio Manager account has been established for Teaneck Board of Education, which includes a profile for the eight (8) buildings. Information entered into this Portfolio Manager Facility profile, including electrical energy consumption and natural gas consumption has been used to establish a performance baseline.

It is recommended that the information be updated each month to track the buildings' energy usage. Only Eugene Field Administration Building was eligible for an energy star label and rating. At the time of the audit the Administration Building received a rating of 82. This information would have to be confirmed in order to apply for an energy star label.

Appendix B contains the Statement of Energy Performance developed for the Administration Building and a Portfolio Manager Reference sheet.

The following website link, username and password shall be used to access the Portfolio Manager account and building profiles that has been established for the Board:

<https://www.energystar.gov/istar/pmpam/>

USERNAME: Teaneck1

PASSWORD: EnergyStar

# Section 4

## Energy Conservation and Retrofit Measures (ECRM)

### 4.1 Building Lighting Systems

#### 4.1.1 Benjamin Franklin Middle School

It is recommended that the existing lighting system at the Benjamin Franklin Middle School, as discussed in Section 2.1.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-1 below.

Table 4.1-1 Benjamin Franklin Middle School Lighting System Improvements	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 83.7 kW, 276,772 kWh and \$42,650

Exterior Lighting: 4.2 kW, 21,242 kWh and \$3,273

The following table, Table 4.1-2, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Benjamin Franklin Middle School. Included in this simplified payback analysis summary table is the 'Annual Return on Investment' (ARO) values. This value is a performance measure used to evaluate the efficiency of an investment and is calculated using the following equation:

$$ARO = \frac{AECS + OCS}{NET\ ECM\ Cost} - \frac{1}{Lifetime}$$

Where OCS = Operating Cost Savings, and AECS = Annual Energy Cost Savings.

Also included in the table are net present values for each option. The NPV calculates the present value of an investment's future cash flows based on the time value of money, which is accounted for by a discount rate (DR) (assume bond rate of 3%). NPV is calculated using the following equation:

$$NPV = \sum_{n=0}^N \frac{C_n}{(1 + DR)^n}$$

Where C<sub>n</sub>=Annual cash flow, and N = number of years.

The IRR expresses an annual rate that results in a break-even point for the investment. If the BOE is currently experiencing a lower return on their capital than the IRR, the project is financially advantageous. This measure also allows the BOE to compare ECM's against each other to determine the most appealing choices.

$$IRR \rightarrow 0 = \sum_{n=0}^N \frac{C_n}{(1 + IRR)^n}$$

Where C<sub>n</sub>=Annual cash flow, and N = number of years.

The lifetime energy savings represents the cumulative energy savings over the assumed life of the ECM.

<b>Table 4.1-2 Benjamin Franklin Middle School Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$329,261.5	\$82,692.2	\$411,953.7
New Jersey SmartStart Rebate	-\$21,135*	-\$0*	-\$21,135*
<b>Total Cost</b>	<b>\$308,126.5</b>	<b>\$82,692.2</b>	<b>\$390,818.7</b>
Annual Energy Savings	\$42,650.3	\$3,273.4	\$45,923.7
Annual Maintenance Cost Savings (AMCS)	\$6,576	\$46.49	\$6,622.1
<b>Simple Payback</b>	<b>6.3 years</b>	<b>24.9 years</b>	<b>7.4 years</b>
Annual Return on Investment (AROI)	9.31%	-2.65%	6.78%
Lifetime Energy Savings (15 years)**	\$793,249.3	\$60,881.7	\$854,131
Internal Rate of Return (IRR)	16.44%	-3.25%	13.17%
Net Present Value (NPV)	\$408,756.1	-\$34,344.3	\$374,411.8



\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours without Sensors” and “Proposed Operational Hours with Sensors” in Appendix D.

### 4.1.2 Bryant Elementary School

It is recommended that the existing lighting system at the Bryant Elementary School, as discussed in Section 2.2.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaries to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-3 below.

<b>Table 4.1-3 Bryant Elementary School Lighting System Improvements</b>	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 25.9 kW, 87,307.4 kWh and \$15,103.5

Exterior Lighting: 0.5 kW, 2,503.9 kWh and \$433.2

The following table, Table 4.1-4, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Bryant Elementary School.

<b>Table 4.1-4 Bryant Elementary School Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$99,705.7	\$19,843.3	\$119,549
New Jersey SmartStart Rebate	-\$23,230*	-\$0*	-\$23,230*
Total Cost	\$76,475.7	\$19,843.3	\$96,319
Annual Energy Savings	\$15,103.5	\$433.2	\$15,536.6
Annual Maintenance Cost Savings (AMCS)	\$2,713.1	\$42.05	\$2,755.2
<b>Simple Payback</b>	<b>4.3 years</b>	<b>41.8 years</b>	<b>5.3 years</b>
Annual Return on Investment (AROI)	16.63%	-4.27%	12.32%
Lifetime Energy Savings (15 years)**	\$280,908.7	\$8,057	\$288,964
Internal Rate of Return (IRR)	25.02%	-8.31%	20.09%
Net Present Value (NPV)	\$182,989.9	-\$12,922.2	\$170,066.3

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Proposed Operational Hours without Sensors" and "Proposed Operational Hours with Sensors" in Appendix D.

### 4.1.3 Eugene Field Administration Building

It is recommended that the existing lighting system at the Eugene Field Administration Building, as discussed in Section 2.3.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-5 below.

<b>Table 4.1-5 Eugene Field Administration Building Lighting System Improvements</b>	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 12.4 kW, 39,955.7 kWh and \$6,586.3

Exterior Lighting: 1.6 kW, 7,920.5 kWh and \$1,305.6

The following table, Table 4.1-6, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Eugene Field Administration Building.

<b>Table 4.1-6 Eugene Field Administration Building Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$45,476.8	\$14,794.8	\$60,271.5
New Jersey SmartStart Rebate	-\$4,125*	-\$0*	-\$4,125*
Total Cost	\$41,351.8	\$14,794.8	\$56,146.5
Annual Energy Savings	\$6,586.3	\$1,305.6	\$7,891.9
Annual Maintenance Cost Savings (AMCS)	\$748.29	\$25.51	\$773.8
<b>Simple Payback</b>	<b>5.6 years</b>	<b>11.1 years</b>	<b>6.5 years</b>
Annual Return on Investment (AROI)	11.07%	2.33%	8.77%
Lifetime Energy Savings (15 years)**	\$122,498	\$24,282	\$146,780.8
Internal Rate of Return (IRR)	18.60%	6.69%	15.76%
Net Present Value (NPV)	\$65,462.6	\$4,590.3	\$70,053

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Proposed Operational Hours without Sensors" and "Proposed Operational Hours with Sensors" in Appendix D.

### 4.1.4 Hawthorne Elementary School

It is recommended that the existing lighting system at the Hawthorne Elementary School, as discussed in Section 2.4.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-7 below.

<b>Table 4.1-7 Hawthorne Elementary School Lighting System Improvements</b>	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 16.8 kW, 56,096.5 kWh and \$9,248.8

Exterior Lighting: 0.9 kW, 4,650.1 kWh and \$766.7

The following table, Table 4.1-8, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Hawthorne Elementary School.

<b>Table 4.1-8 Hawthorne Elementary School Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$71,618.4	\$36,851.8	\$108,470.2
New Jersey SmartStart Rebate	-\$4,635*	-\$0*	-\$4,635*
Total Cost	\$66,983.4	\$36,851.8	\$103,835.2
Annual Energy Savings	\$9,248.8	\$766.7	\$10,015.5
Annual Maintenance Cost Savings (AMCS)	\$1,191	\$9.49	\$1,200.5

<b>Table 4.1-8 Hawthorne Elementary School Lighting System Improvements***</b>			
<b>Simple Payback</b>	<b>6.4 years</b>	<b>47.5 years</b>	<b>9.3 years</b>
Annual Return on Investment (AROI)	8.92%	-4.56%	4.14%
Lifetime Energy Savings (15 years)**	\$172,018	\$14,259.8	\$186,277.4
Internal Rate of Return (IRR)	15.95%	NA	9.47%
Net Present Value (NPV)	\$85,052.5	-\$25,548.1	\$59,504.5

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours without Sensors” and “Proposed Operational Hours with Sensors” in Appendix D.

### 4.1.5 Lowell Elementary School

It is recommended that the existing lighting system at Lowell Elementary School, as discussed in Section 2.5.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-9 below.

<b>Table 4.1-9 Lowell Elementary School Lighting System Improvements</b>	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 10.0 kW, 34,828.5 kWh and \$6,534.3

Exterior Lighting: 1.4 kW, 6,929.2 kWh and \$1,300

The following table, Table 4.1-10, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Lowell Elementary School.

<b>Table 4.1-10 Lowell Elementary School Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$44,335.4	\$33,663.4	\$77,998.8
New Jersey SmartStart Rebate	-\$3,710*	-\$0*	-\$3,710*
Total Cost	\$40,625.4	\$33,663.4	\$74,288.8
Annual Energy Savings	\$6,534.3	\$1,300	\$7,834.3
Annual Maintenance Cost Savings (AMCS)	\$505.5	\$15.2	\$520.7
<b>Simple Payback</b>	<b>5.8 years</b>	<b>25.6 years</b>	<b>8.9 years</b>
Annual Return on Investment (AROI)	10.66%	-2.76%	4.58%
Lifetime Energy Savings (15 years)**	\$121,530.9	\$24,179	\$145,709.5
Internal Rate of Return (IRR)	18.10%	-3.53%	10.12%
Net Present Value (NPV)	\$61,895.2	-\$14,509.7	\$47,385.7

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Proposed Operational Hours without Sensors" and "Proposed Operational Hours with Sensors" in Appendix D.

### 4.1.6 Teaneck High School

It is recommended that the existing lighting system at the Teaneck High School, as discussed in Section 2.6.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-11 below.

<b>Table 4.1-11 Teaneck High School Lighting System Improvements</b>	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 38.4kW, 120,609.7 kWh and \$19,168.1

Exterior Lighting: 1.2 kW, 6,326.2 kWh and \$1,005.4

The following table, Table 4.1-12, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Teaneck High School.

<b>Table 4.1-12 Teaneck High School Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$122,876.8	\$31,876.6	\$154,753.3
New Jersey SmartStart Rebate	-\$11,850*	-\$0*	-\$11,850*
<b>Total Cost</b>	<b>\$111,026.8</b>	<b>\$31,876.6</b>	<b>\$142,903.3</b>
Annual Energy Savings	\$19,168.1	\$1,005.4	\$20,173.5
Annual Maintenance Cost Savings (AMCS)	\$1,452.6	\$124.7	\$1,577.3
<b>Simple Payback</b>	<b>5.4 years</b>	<b>28.2 years</b>	<b>6.6 years</b>
Annual Return on Investment (AROI)	11.91%	-3.12%	8.55%
Lifetime Energy Savings (15 years)**	\$356,505.8	\$18,699.4	\$375,205.2
Internal Rate of Return (IRR)	19.60%	-4.54%	15.48%
Net Present Value (NPV)	\$189,274.8	-\$15,418.7	\$173,856.4

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours without Sensors” and “Proposed Operational Hours with Sensors” in Appendix D.

### 4.1.7 Thomas Jefferson Middle School

It is recommended that the existing lighting system at the Thomas Jefferson Middle School, as discussed in Section 2.7.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaires to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-13 below.

<b>Table 4.1-13 Thomas Jefferson Middle School Lighting System Improvements</b>	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 41.5 kW, 138,055.2 kWh and \$24,587.2

Exterior Lighting: 1.2 kW, 6,132 kWh and \$1,092.1

The following table, Table 4.1-14, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Thomas Jefferson Middle School.



<b>Table 4.1-14</b>			
<b>Thomas Jefferson Middle School Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$203,239.5	\$25,798.8	\$229,038.3
New Jersey SmartStart Rebate	-\$15,735*	-\$0*	-\$15,735*
Total Cost	\$187,504.5	\$25,798.8	\$213,303.3
Annual Energy Savings	\$24,587.2	\$1,092.1	\$25,679.3
Annual Maintenance Cost Savings (AMCS)	\$2,203.7	\$6.13	\$2,209.8
<b>Simple Payback</b>	<b>7.0 years</b>	<b>23.5 years</b>	<b>7.6 years</b>
Annual Return on Investment (AROI)	7.62%	-2.41%	6.41%
Lifetime Energy Savings (15 years)**	\$457,295.2	\$20,311.9	\$477,607.1
Internal Rate of Return (IRR)	14.28%	-2.62%	12.67%
Net Present Value (NPV)	\$202,653.7	-\$9,805.2	\$192,848.5

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Proposed Operational Hours without Sensors" and "Proposed Operational Hours with Sensors" in Appendix D.

### 4.1.8 Whittier Elementary School

It is recommended that the existing lighting system at the Whittier Elementary School, as discussed in Section 2.8.3, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaries to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-15 below.

<b>Table 4.1-15</b>	
<b>Whittier Elementary School Lighting System Improvements</b>	
Interior Lighting	High Performance T8 Retrofits, Incandescent to Compact Fluorescent Conversion, Occupancy Sensors
Exterior Lighting	LED Retrofit of Exterior Fixtures

The strategies included in this section focus on maximizing energy savings and maintaining or exceeding existing lighting levels, while also maintaining the existing look of each fixture; therefore, proposed lamp styles remain consistent with existing lamp styles. Please refer to Appendix D for a line-by-line proposed detailed lighting upgrades list.

The annual energy savings for the two options is as follows:

Interior Lighting: 28.3 kW, 99,436.8 kWh and \$16,572.5

Exterior Lighting: 0.3 kW, 1,430.8 kWh and \$238.5

The following table, Table 4.1-16, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Whittier Elementary School.

<b>Table 4.1-16 Whittier Elementary School Lighting System Improvements***</b>			
	Interior Lighting	Exterior Lighting	Total
Engineer's Opinion of Probable Cost	\$104,823.9	\$11,339	\$116,162.9
New Jersey SmartStart Rebate	-\$7,660*	-\$0*	-\$7,660*
<b>Total Cost</b>	<b>\$97,163.9</b>	<b>\$11,339</b>	<b>\$108,502.9</b>
Annual Energy Savings	\$16,572.5	\$238.5	\$16,811.0
Annual Maintenance Cost Savings (AMCS)	\$1,624.1	\$42.87	\$1,666.9
<b>Simple Payback</b>	<b>5.3 years</b>	<b>40.3 years</b>	<b>5.9 years</b>
Annual Return on Investment (AROI)	12.06%	-4.19%	10.36%
Lifetime Energy Savings (15 years)**	\$308,230.5	\$4,435.8	\$312,666.3
Internal Rate of Return (IRR)	19.78%	-7.98%	17.74%
Net Present Value (NPV)	\$167,834.6	-\$7,241.4	\$160,593

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled "Proposed Operational Hours without Sensors" and "Proposed Operational Hours with Sensors" in Appendix D.

### 4.1.9 Athletic Field Lighting & Scoreboard

CDM evaluated the athletic field lighting and has determined that minimal energy savings can be achieved, because the Teaneck BOE already limits the use of the lighting system to athletic events. The scoreboard lighting was also evaluated and the same conclusion has been reached. The minimal energy savings for both the athletic field lighting and the scoreboard would result in an extended payback period greater than 20 years, and therefore CDM does not recommend and ECRMs related to the athletic field lighting and the scoreboard.

### 4.1.10 Teaneck High School - Press Box

It is recommended that the existing lighting system at the Teaneck High School - Press Box, as discussed in Section 2.9.2, be upgraded to high efficiency standards to create lighting uniformity throughout the building. In general, the recommended lighting upgrade project, as presented in Appendix D, involves replacing existing inefficient bulbs, and installing new energy-efficient luminaries to the existing lighting systems. Two options have also been proposed in Appendix D for interior and exterior lighting, and are listed in Table 4.1-17 below.

Table 4.1-17 Teaneck High School - Press Box Lighting System Improvements	
Interior Lighting	Incandescent to Compact Fluorescent Conversion

The annual energy savings for the two options is as follows:

Interior Lighting: 0.1 kW, 7.1 kWh and \$7.5

The following table, Table 4.1-18, summarizes a simple payback analysis assuming the implementation of all recommended lighting system improvements at the Teaneck High School - Press Box.

Table 4.1-18 Teaneck High School - Press Box Lighting System Improvements***	
	Total
Engineer's Opinion of Probable Cost	\$107.8
New Jersey SmartStart Rebate	-\$0*
Total Cost	\$107.8
Annual Energy Savings	\$7.5
Annual Maintenance Cost Savings (AMCS)	\$70.52

<b>Table 4.1-18</b>	
<b>Teaneck High School - Press Box Lighting System Improvements***</b>	
<b>Simple Payback</b>	<b>1.4 years</b>
Annual Return on Investment (AROI)	65.71%
Lifetime Energy Savings (15 years)**	\$139.5
Internal Rate of Return (IRR)	75.35%
Net Present Value (NPV)	\$1,028.4

\* Additional incentives, based on eligibility, are available through the New Jersey SmartStart Program, see Appendix G.

\*\*3% yearly inflation on electricity costs.

\*\*\*See Appendix H & I for ECRM Financial Analyses.

It should be noted that the Annual Energy Savings assume the annual hours per year of operation as outlined under the columns entitled “Proposed Operational Hours without Sensors” and “Proposed Operational Hours with Sensors” in Appendix D.

## 4.2 HVAC Systems

The goal of this section is to present any heating and cooling energy reduction and cost saving measures that may also be cost beneficial. Where possible, measures will be presented with a life-cycle cost analysis. This analysis displays a payback period based on weighing the capital cost of the measure against predicted annual fiscal savings. To do this, the buildings have been modeled as accurately as possible to predict energy usage for space heating and cooling, as well as domestic hot water use.

Each building is modeled using software called eQuest, a Department of Energy-sponsored energy modeling program, to establish a baseline space heating and cooling energy usage. Climate data from Freehold, NJ was used for analyses. From this, the model may be calibrated, using historical utility bills, to predict the impact of theoretical energy savings measures.

Once annual energy savings from a particular measure have been predicted and the initial capital cost has been estimated, payback periods may be approximated. Equipment cost estimate calculations are provided in Appendix H.


Dual-fuel boilers, which burn both natural gas and light fuel oil, offer the Board of Education flexibility of choice. The cost and availability of each fuel may fluctuate. However, at this time the highest efficiency dual-fuel boilers, which are commercially available, are rated at about 86%. Smaller residential boilers are now able to operate on low-sulfur diesel fuel in the condensing temperature range, but they are not available in the larger capacities required for buildings such as schools. An impractical number of these smaller boilers would be required to adequately serve large buildings. Hence, CDM’s recommendation for condensing boilers is restricted to natural gas-fired units, which operate at a 91+% efficiency. Natural gas is also

significantly cheaper and easier to maintain than fuel oil, which makes it a more favorable option.

### 4.2.1 Benjamin Franklin Middle School

A model of Benjamin Franklin Middle School was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009 and oil bills from November 2007 to December 2009. Figure 4.2-1 below compares actual monthly electricity usage, with those predicted by the eQuest model.


Figure 4.2-1: Benjamin Franklin Middle School Electricity Usage



Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-2 below compares the school's actual monthly oil usage to model-predicted oil use. Actual oil usage accounts not only for the gallons of oil consumed per month, but also for the gallons of oil represented by the monthly natural gas consumption.

Figure 4.2-2: Benjamin Franklin Middle School Oil Usage




Currently, the heating system utilizes two (2) Smith Cast Iron Sectional boilers. Each boiler has a gross-output capacity of 4,517 MBH. CDM conservatively estimates these boilers to be 80% efficient.

CDM recommends replacing the aforementioned boilers with high-efficiency, natural gas-fired, condensing boilers. Based on the building model, and accounting for a 25% safety factor, CDM has calculated a peak heating load of 5,000 MBH. CDM anticipates that two (2) 3,000 MBH output, high-efficiency condensing boilers should adequately heat the school.

Figure 4.2-3 compares current gas usage with predicted gas usage resulting from a switch to high-efficiency, condensing boilers. Condensing boilers are modeled with a full-load efficiency of ~91.5% and return water temperature of 100°F.

**Figure 4.2-3: Benjamin Franklin Middle School – Boiler Upgrade - Oil Usage**



Fiscal savings from such an upgrade are then identified in Table 4.2-1 below. Lifetime savings calculations for all ECRM’s may be found in Appendix I. It’s important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

Due to the improved automation and control within modern condensing boilers, their operation and maintenance costs tend to be less than those of typical firetube boilers. CDM estimates a firetube boiler system will typically cost around \$3,500 per year for regular preventative maintenance, whereas a condensing boiler system would cost around \$2,000 per year. Therefore, replacing the existing boiler system with a condensing boiler system should result in an operation and maintenance cost savings of \$1,500 per year.

<b>Table 4.2-1: Benjamin Franklin Middle School Boiler Upgrade Payback</b>	
Current Annual Oil Cost for Existing Boilers	\$70,967
Predicted Annual Gas Cost for Condensing Boilers	\$38,830
Total Annual Savings	\$32,137
Initial Capital Cost of Upgrade	\$104,127
Incentives**	\$6,000
Cost of Upgrade	\$98,127
<b>Simple Payback</b>	<b>2.9</b>
Lifetime Energy Savings (24 years)*	\$1,142,363.47

<b>Table 4.2-1: Benjamin Franklin Middle School Boiler Upgrade Payback</b>	
Annual Maintenance Cost Savings (AMCS)	\$1,500
Annual Return on Investment (AROI)	30.11%
Internal Rate of Return (IRR)	37.12%
Net Present Value (NPV)	\$676,099.86

\*Assumes 3% yearly inflation on fuel costs

\*\*Incentives, per New Jersey Clean Energy Program, are \$1.00 per MBH

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM’s on site audit is listed in Table 4.2-2 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

Where equipment ages were not found on the equipment tags, they have been estimated based on the unit appearance or approximate renovation dates. In some cases, service locations may have been estimated based on unit proximity. Additionally, in cases where a unit’s manufacturer and/or model could not be determined due to an unreadable, faded, destroyed, or lost tag, manufacturer and model number information has been represented as “unknown”.

<b>Table 4.2-2 Benjamin Franklin Middle School HVAC Equipment Service Lives</b>							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Lobby/High Roof	Computer Lab	Friedrich	Model MR30C3F	SEER 18	~5	20
ACC	Gym/Cafeteria Roof	Server Classroom	Friedrich	Model MB30C3F	SEER 18	~5	20
ACC	Gym/Cafeteria Roof	Nurse’s Office	Friedrich	Same 2 ton unit as above	SEER 18	~5	20
ACC	Gym/Cafeteria Roof	Office/Admin area	Trane	Model 2TTR2024A10 00AA	Unknown	~5	20
ACC	Gym/Cafeteria Roof	Cafeteria	Trane	Model 2TTR2042B10 00AA	Unknown	~5	20



Section 4  
Energy Conservation and Retrofit Measures

ACC	Gym/Cafeteria Roof	Cafeteria	Trane	Model 2TTR2042B10 00AA	Unknown	~5	20
ACC	Gym/Cafeteria Roof	Media Center	Friedrich	Model MR30C3E	SEER 18	~5	20
ACC	Gym/Cafeteria Roof	Media Center	Friedrich	Model MR30C3E	SEER 18	~5	20
ACC	Gym/Cafeteria Roof	Media Center	Friedrich	Model MR30C3E	SEER 18	~5	20
ACC	Gym/Cafeteria Roof	Media Center	Friedrich	Model MR30C3E	SEER 18	~5	20
ACC	O&M Office	O&M Office	Carrier	Model 38CKC048300	Unknown	~5	20
ACC	Gym/Cafeteria Roof	Gym	Bohn	Model BST015H2C	Unknown	~5	20
ACC	Other	Tech 308	Friedrich	Model SL36L30A-C	SEER 18	~5	20
ACC	Other	Tech 307	Friedrich	Model SL36J30A-C	SEER 18	~5	20
ACC	Guidance Rooms	Guidance Rooms	Trane	Model 2TTR2024A10 00AA	Unknown	~5	20
ACC	Main Office/Windowless Classrooms	Main Office/windowless classrooms	Trane	Model 2TTR2048A10 00AA	Unknown	~5	20
ACC	Main Office/Windowless Classrooms	Main Office/windowless classrooms	Trane	Model 2TTR2042B10 00AA	Unknown	~5	20
ACC	Main Office/Windowless Classrooms	Main Office/windowless classrooms	Trane	Model 2TTR2024A10 00AA	Unknown	~5	20
AHU	Fan Room 1	Basement	Trane	Model MCCB008UA0 C0UA	~80%	~7	20
AHU	Fan Room 2	Basement	Trane	Model MCCB010UA0 C0UA	~80%	~7	20
AHU	O&M next to Conf Room	Basement	Trane	Model MCCB008UA0 C0UA	~80%	~7	20
AHU	O&M next to Conf Room	Basement	Trane	Model MCCB006UA0 C0UA	~80%	~7	20
AHU	Roof above Boiler Room	1st/2nd floor Toilets	Intellipak/ Trane	Model SLHFC40E44 G6C59D1D01 A0CE0G0KLO 0RT008600	~80%	~7	20
AHU	Gym/Cafeteria Roof	Gym/Cafeteria	unknown	Unknown	~80%	~7	20
AHU	Gym/Cafeteria Roof	Gym/Cafeteria	Trane	unknown	~80%	~7	20
AHU	Gym/Cafeteria Roof	Gym/Cafeteria	Trane	Model TSGA017U0B 000000A00A2 70	~80%	~7	20
AHU	Gym/Cafeteria Roof	Kitchen	Trane	Model TSCA006U0B 00...A00A117	~80%	7	20
AHU	Gym	Gym	Trane	Heating (large)	~80%	~7	20

Section 4  
Energy Conservation and Retrofit Measures

AHU	Gym	Gym	Trane	Heating (large)	~80%	~7	20
AHU	Girls/Boys Locker Rooms	Locker Rooms	Trane	Smaller	~80%	~7	20
AHU	Girls/Boys Locker Rooms	Locker Rooms	Trane	Smaller	~80%	~7	20
Boiler	boiler room	All rooms	Smith	28A Series	80%	>20	25
Boiler	boiler room	All rooms	Smith	28A Series	80%	>20	25
EF	Roof above Boiler Room	Auditorium	Loren Cook	Model 180C7B	Unknown	~5	20
EF	Roof above Boiler Room	2nd floor Toilets	Dayton	Model 4YY20	Unknown	~5	20
EF	Auditorium Roof	Auditorium	Loren Cook	Model 135C4B	Unknown	~5	20
EF	Auditorium Roof	Auditorium	Chelsea	Model R0K50	Unknown	~5	20
EF	Auditorium Roof	Auditorium	Chelsea	Model R6K30	Unknown	~5	20
EF	Lobby/High Roof	Auditorium	Loren Cook	Model 100C2B	Unknown	~5	20
EF	Lobby/High Roof	Toilet Rooms	Loren Cook	ACE Model 135C4B	Unknown	~5	20
EF	Lobby/High Roof	Classroom	Loren Cook	Model 100 C2B	Unknown	8	20
EF	Lobby/High Roof	Classroom	Loren Cook	Model 100C2B	Unknown	~5	20
EF	Lobby/High Roof	Classroom	Dayton	Model 4YY18	Unknown	~5	20
EF	Lobby/High Roof	Classroom	Loren Cook	Model 150C6B	Unknown	~5	20
EF	Music Room Roof	Classroom	Carnes	Model VEBK18P1A2 UA205PC1	Unknown	~5	20
EF	Music Room Roof	Classroom	Loren Cook	Model 100C2B	Unknown	~5	20
EF	General Hallway Roof	Classroom	Loren Cook	Model 135C5B	Unknown	~5	20
EF	Gym/Cafeteria Roof	Classroom	Loren Cook	Model 180C8B	Unknown	~5	20
EF	Gym/Cafeteria Roof	Classroom	Dayton	Model 3GY706	Unknown	~5	20
EF	Gym/Cafeteria Roof	Classroom	Loren Cook	Model 270C7B	Unknown	~5	20
EF	Gym/Cafeteria Roof	Classroom	Loren Cook	Model 270C7B	Unknown	~5	20
Pump	Boiler Room	Circulation	Baldor	M2531T	Unknown	~10	20
Pump	Boiler Room	Circulation	Baldor	M2531T	Unknown	~10	20
Pump	Boiler Room	Sump	Weil	H358	Unknown	~5	10
Pump	Boiler Room	Sump	AO Smith	H358	Unknown	~5	10
Pump	Boiler Room	Circulation	Robbins & Muers	Unknown	Unknown	~15	20
Pump	Boiler Room	Circulation	Unknown	P55CSS-1246	Unknown	~10	20

Pump	Boiler Room	Circulation	Unknown	P55CSS-1246	Unknown	~10	20
Pump	Boiler Room	Circulation	Grundfos	P/N 52722363	Unknown	~10	20
Wall ACU	Other	Classroom 304A	Unknown	Older 3 ton unit	Unknown	>15	10
Wall ACU	Other	Classroom 304	unknown	Older "real old" 2 ton unit	Unknown	>15	10
Wall ACU	Other	Mailroom	Air Temp	2 ton unit	Unknown	~10	10
Wall ACU	Other	Reading Room	Air Temp	2 ton unit	Unknown	~10	10
Wall ACU	Other	Teacher's Break Room near Cafeteria	Air Temp	3 ton unit	Unknown	~10	10

Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.


CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-3 below.

Table 4.2-3 Benjamin Franklin Middle School Domestic Water Heaters						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	AO Smith	Unknown	Unknown	Electric	Unknown	Poor

### 4.2.2 Bryant Elementary School


A model of the Bryant Elementary School was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009 and oil bills from November 2007 to December 2009. Figure 4.2-4 below compares actual monthly electricity usages, with those predicted by the eQuest model.

Figure 4.2-4: Bryant Elementary School Electricity Usage



Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-5 below compares the school's actual monthly oil usage to model-predicted oil use. Actual oil usage accounts not only for the gallons of oil consumed per month, but also for the gallons of oil represented by the monthly natural gas consumption.



Currently the HVAC systems at the Bryant Elementary School are controlled independently, by room thermostats. It is recommended that a direct digital control (DDC) building management system (BMS) be implemented. A system like this would monitor and control all HVAC equipment, allowing maintenance staff to operate systems and adjust climate control in real time to maximize comfort, while minimizing unnecessary heating and cooling.

Typically implementation of a BMS will save the owner 5-15% of the energy devoted to HVAC. As all systems are currently independently monitored and controlled, CDM conservatively estimates that implementing a DDC BMS will allow the school to save, on average, 10% of the energy being used for HVAC. Table 4.2-4 demonstrates the potential payback from such an implementation.

<b>Table 4.2-4: Bryant Elementary School DDC BMS Payback</b>	
Predicted Annual Savings (Gallons Oil)	3,322
Annual Savings (Oil)	\$7,708
Predicted Annual Savings (kWh)	21,038
Annual Savings (Electricity)	\$3,640
Total Annual Savings	\$11,347
Initial Capital Cost of Upgrade	\$40,915
Incentives**	\$0
Cost of Upgrade	\$40,915
Annual Maintenance Cost Savings (AMCS)	\$0
<b>Simple Payback</b>	<b>3.6</b>
Lifetime Energy Savings (15 years)*	\$211,044.62
Annual Return on Investment (AROI)	21.07%
Internal Rate of Return (IRR)	29.88%
Net Present Value (NPV)	\$124,334.44

\*Assumes 3% yearly inflation on oil and electricity costs


\*\*No Incentives found for this upgrade

Currently, the heating system utilizes two (2) Smith Cast Iron Sectional boilers. Each boiler has a gross-output capacity of 2903 MBH. CDM conservatively estimates these boilers to be 80% efficient.

CDM recommends replacing these boilers with high-efficiency, natural-gas fired, condensing boilers. Based on the building model, and accounting for a 25% safety factor, anticipates that two (2) 3,000 MBH output, high-efficiency condensing boilers should adequately heat the school. In this upgrade, the existing steam heating system would be retrofitted for hot water use. Steam traps would be replaced with hot water control valves, condensate piping would be scheduled for demolition, and new hot water return piping and insulation would be installed.

Figure 4.2-6 compares current gas usage with predicted gas usage resulting from a switch to high-efficiency, condensing boilers. Condensing boilers are modeled with a full-load efficiency of ~91.5% and return water temperature of 100°F.

**Figure 4.2-6: Bryant Elementary School – Boiler Upgrade - Oil Usage**



Fiscal savings from such an upgrade are then identified in Table 4.2-5 below. The aggregate cost of natural gas calculated from the utility data for this school is not representative of typical natural gas costs relative to other schools, because the school is still expensed for service and distribution charges despite using very little gas. As such, the cost of natural gas per therm used to calculate fiscal savings is the average of the aggregate costs for all eight buildings. Lifetime savings calculations for all ECRM’s may be found in Appendix I. It’s important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

Due to the improved automation and control within modern condensing boilers, their operation and maintenance costs tend to be less than those of typical firetube boilers. CDM estimates a firetube boiler system will typically cost around \$3,500 per year for regular preventative maintenance, whereas a condensing boiler system would cost around \$2,000 per year. Therefore, replacing the existing boiler system with a condensing boiler system should result in an operation and maintenance cost savings of \$1,500 per year.

<b>Table 4.2-5: Bryant Elementary School Boiler Upgrade Payback</b>	
Current Annual Oil Cost for Existing Boilers	\$77,076
Predicted Annual Gas Cost for Condensing Boilers	\$57,704

<b>Table 4.2-5: Bryant Elementary School Boiler Upgrade Payback</b>	
Total Annual Savings	\$19,371
Initial Capital Cost of Upgrade	\$181,165
Incentives**	\$6,000
Cost of Upgrade	\$175,165
<b>Simple Payback</b>	<b>8.4</b>
Lifetime Energy Savings (24 years)*	\$702,887.20
Annual Maintenance Cost Savings (AMCS)	\$1,500
Annual Return on Investment (AROI)	7.75%
Internal Rate of Return (IRR)	13.65%
Net Present Value (NPV)	\$301,609.52

\*Assumes 3% yearly inflation on fuel costs

\*\*Incentives, per New Jersey Clean Energy Program, are \$1.00 per MBH

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM’s on site audit is listed in Table 4.2-6 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

<b>Table 4.2-6 Bryant Elementary School HVAC Equipment Service Lives</b>							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Roof - Nurse's office	Nurse's Office	Trane	TTR018D100AO	Unknown	~7	20
ACC	Roof	Interior Classroom	Friedrich	MR24C3F	SEER 18	~5	20
ACC	Roof	Special Services	Friedrich	MR12C1F	SEER 18	~5	20
ACC	Roof	Special Services	Friedrich	MR12C1F	SEER 18	~5	20
ACC	Roof	Special Services	Friedrich	MR12C1F	SEER 18	~5	20

**Table 4.2-6 Bryant Elementary School HVAC Equipment Service Lives**

Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Roof - Server Room	Server Room	Dayton	outdoor: MAKA-024JAX; Indoor: MBHA-14J00NUAA	Unknown	~7	20
ACC	Roof	Speech Therapy	Friedrich	MR12Y1F	SEER 18	~5	20
ACC	Other	Principal's Office	Friedrich	outdoor: MR18Y3E; indoor: MW18Y3E	SEER 18	~5	20
ACC	Other	Main Office	Friedrich	outdoor: MR24C3E; indoor: MW24C3E	SEER 18	~5	20
AHU	Other	General Building	Trane	MCCA012MAG0A0A0DD0AA00...	~80%	13	20
Boiler	Boiler Room	Boiler Room	HB Smith	M45L Mills Boiler	~80%	>20	25
Boiler	Boiler Room	Boiler Room	HB Smith	M45L Mills Boiler	~80%	>20	25
EF	Roof	Unknown	PVC	DX 7B	Unknown	~7	20
EF	roof- lower, above classroom	Unknown	PVC	DX 9B	Unknown	~7	20
EF	Roof – Cafeteria	Cafeteria	PVC	DX16B	Unknown	~7	20
EF	Roof – Cafeteria	Cafeteria	PVC	DX9B	Unknown	~7	20
EF	Roof - Nurse's office	Nurse's Office	PVC	DX 7B	Unknown	~7	20
EF	Roof - Nurse's office	Nurse's Office	PVC	DX 7B	Unknown	~7	20
EF	Roof - Nurse's office	Nurse's Office	PVC	DX 7B	Unknown	~7	20
MAU	Roof – Cafeteria	Cafeteria	Trane	RAUCC20EBM13D	~75%	~7	20
Pump	Boiler Room	Circulation	Taco	P63CZC-3020	Unknown	~7	20
Pump	Boiler Room	Circulation	Taco	P63CZC-3020	Unknown	~7	20
Pump	Boiler Room	Sump	Unknown	unknown	Unknown	~5	10
Wall ACU	Other	Nurse's Office	Friedrich	KS15L10-A	Unknown	~5	10
Wall AC	Other	Room 15 - Child Therapy	Friedrich	MR24Y3F	Unknown	~5	10
Wall ACU	Other	Room 33	Whirlpool	ACQ082XA0	Unknown	~7	10
Wall ACU	Other	Room 33	Whirlpool	ACQ082XA0	Unknown	~7	10
Wall ACU	Other	Teacher's Lounge	GE	Unknown	Unknown	older	10



Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.


CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-7 below.

Table 4.2-7 Bryant Elementary School Domestic Water Heaters						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	Rheem	50	1PZ75	Electric	4500 W	Good
Roof Access - room adjacent to Cafeteria	Rudd Everclean	40	ELD40-B	Electric	6000 W	Good

### 4.2.3 Eugene Field Administration Building

A model of the Eugene Field Administration Building was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009 and oil bills from November 2007 to December 2009. Figure 4.2-7 below compares actual monthly electricity usages, with those predicted by the eQuest model.


**Figure 4.2-7: Eugene Field Administration Building Electricity Usage**



Local spikes in the summer could be attributed to summer session activities or increased occupancy due to administrative preparation for the next school year. Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-8 below compares the school's actual monthly oil usage to model-predicted oil use. Actual oil usage accounts not only for the gallons of oil consumed per month, but also for the gallons of oil represented by the monthly natural gas consumption.

**Figure 4.2-8: Eugene Field Administration Building Oil Usage**



Currently the HVAC systems at the Eugene Field Administration Building are controlled independently, by room thermostats. It is recommended that a direct digital control (DDC) building management system (BMS) be implemented. A system like this would monitor and control all HVAC equipment, allowing maintenance staff to operate systems and adjust climate control in real time to maximize comfort, while minimizing unnecessary heating and cooling.

Typically implementation of a BMS will save the owner 5-15% of the energy devoted to HVAC. As all systems are currently independently monitored and controlled, CDM conservatively estimates that implementing a DDC BMS will allow the building to save, on average, 10% of the energy being used for HVAC. Table 4.2-8 demonstrates the potential payback from such an implementation.

<b>Table 4.2-8: Eugene Field Administration Building DDC BMS Payback</b>	
Predicted Annual Savings (Gallons Oil)	911
Annual Savings (Oil)	\$2,095
Predicted Annual Savings (kWh)	10,212
Annual Savings (Electricity)	\$1,683
Total Annual Savings	\$3,777
Initial Capital Cost of Upgrade	\$21,456
Incentives**	\$0
Cost of Upgrade	\$21,456
Annual Maintenance Cost Savings (AMCS)	\$0
<b>Simple Payback</b>	<b>5.7</b>
Lifetime Energy Savings (15 years)*	\$70,256.14
Annual Return on Investment (AROI)	10.94%
Internal Rate of Return (IRR)	18.44%
Net Present Value (NPV)	\$33,554.74

\*Assumes 3% yearly inflation on oil and electricity costs


\*\*No Incentives found for this upgrade

Currently, the heating system utilizes two (2) Smith Cast Iron Sectional boilers. Each boiler has a gross-output capacity of 1827 MBH. CDM conservatively estimates these boilers to be 80% efficient.

CDM recommends replacing these boilers with high-efficiency, natural gas-fired, condensing boilers. Based on the building model, and accounting for a 25% safety factor, CDM anticipates that two (2) 3,000 MBH output, high-efficiency condensing boilers should adequately heat the school.

Figure 4.2-9 compares current gas usage with predicted gas usage resulting from a switch to high-efficiency, condensing boilers. Condensing boilers are modeled with a full-load efficiency of ~91.5% and return water temperature of 100°F.

**Figure 4.2-9: Eugene Field Administration Building – Boiler Upgrade – Oil Usage**



Fiscal savings from such an upgrade are then identified in Table 4.2-9 below. Lifetime savings calculations for all ECRM’s may be found in Appendix I. It’s important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

Due to the improved automation and control within modern condensing boilers, their operation and maintenance costs tend to be less than those of typical firetube boilers. CDM estimates a firetube boiler system will typically cost around \$3,500 per year for regular preventative maintenance, whereas a condensing boiler system would cost around \$2,000 per year. Therefore, replacing the existing boiler system with a condensing boiler system should result in an operation and maintenance cost savings of \$1,500 per year.

<b>Table 4.2-9: Eugene Field Administration Building Boiler Upgrade Payback</b>	
Current Annual Oil Cost for Existing Boilers	\$20,945
Predicted Annual Gas Cost for Condensing Boilers	\$15,428
Total Annual Savings	\$5,517
Initial Capital Cost of Upgrade	\$104,127
Incentives**	\$6,000
Cost of Upgrade	\$98,127
<b>Simple Payback</b>	<b>14.0</b>

<b>Table 4.2-9: Eugene Field Administration Building Boiler Upgrade Payback</b>	
Lifetime Energy Savings (24 years)*	\$225,935.69
Annual Maintenance Cost Savings (AMCS)	\$1,500
Annual Return on Investment (AROI)	2.98%
Internal Rate of Return (IRR)	7.18%
Net Present Value (NPV)	\$55,831.30

\*Assumes 3% yearly inflation on fuel costs

\*\*Incentives, per New Jersey Clean Energy Program, are \$1.00 per MBH

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM’s on site audit is listed in Table 4.2-10 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

<b>Table 4.2-10 Eugene Field Administration Building HVAC Equipment Service Lives</b>							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Meeting Room	Meeting Room	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Meeting room	Meeting room	York	CA91-25E	Unknown	~7	20
ACC	Secretary's Office	Secretary's Office	Friedrich	MW18C3E/M R18C3E	SEER 18	~5	20
ACC	Superintendent	Superintendent	Friedrich	MW30C3F/M R30C3F	SEER 18	~5	20
ACC	Assistant Superintendent	Assistant Superintendent	Friedrich	MW18C3E/M R18C3E	SEER 18	~5	20
ACC	David Bicofsky's Office	David Bicofsky's Office	Friedrich	MW24C3F/M R24C3F	SEER 18	~5	20
ACC	Admin Assistants	Admin Assistants	Friedrich	MW30C3F/M R30C3F	SEER 18	~5	20
ACC	Room 4A	Room 4A	Friedrich	MW18C3E/M R18C3E	SEER 18	~5	20
ACC	Room 4A	Room 4A	Friedrich	MW18C3E/M R18C3E	SEER 18	~5	20

**Table 4.2-10 Eugene Field Administration Building HVAC Equipment Service Lives**

Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Christine Flanagan's Office	Christine Flanagan's Office	Friedrich	MW12C1E/M R12C1E	SEER 18	~5	20
ACC	Christine Flanagan's Office	Christine Flanagan's Office	Friedrich	MW12C1E/M R12C1E	SEER 18	~5	20
ACC	Christine Flanagan's Office	Christine Flanagan's Office	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Deidre's Office	Deidre's Office	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Deidre's Office	Deidre's Office	Friedrich	MW12C1E/M R12C1E	SEER 18	~5	20
ACC	Deidre's Office	Deidre's Office	Friedrich	MW18C3E/M R18C3E	SEER 18	~5	20
ACC	Deidre's Office	Deidre's Office	Friedrich	MW24C3F/M R24C3F	SEER 18	~5	20
ACC	Room 5- Staff Development	Room 5- Staff Development	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 5- Staff Development	Room 5- Staff Development	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 7- Special Services	Room 7- Special Services	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 7- Special Services	Room 7- Special Services	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 7- Special Services	Room 7- Special Services	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 20 - Transportation	Room 20 - Transportation	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 20 - Transportation	Room 20 - Transportation	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 20 - Transportation	Room 20 - Transportation	Friedrich	MW24C3E/M R24C3E	SEER 18	~5	20
ACC	Room 20 - Transportation	Room 20 - Transportation	Friedrich	MW18Y3F/M R18Y3F	SEER 18	~5	20
ACC	Room off Office Spaces	Room off Office Spaces	Friedrich	MW18Y3F/M R18Y3F	SEER 18	~5	20
ACC	Roof	Unknown	Unitary Products Group	FTFP060H06 G		~7	20
ACC	Director of Students	Director of Students	Friedrich	MW12C1F/M R12C1F	SEER 18	~5	20
ACC	Director of Students	Director of Students	Friedrich	MW12C1F/M R12C1F	SEER 18	~5	20
ACC	Classroom 21	Classroom 21	Friedrich	MW24C3F/M R24C3F	SEER 18	~5	20
Boiler	Boiler Room	Bldg dist	HB Smith	28A-6	~80%	>20	25
Boiler	Boiler Room	Bldg dist	HB Smith	28A-6	~80%	>20	25
MAU	Gym	Gym	Carrier/Baldor	Unknown	~80%	~7	20

Table 4.2-10 Eugene Field Administration Building HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
MAU	Gym	Gym	Carrier/Baldor	Unknown	~80%	~7	20
Pump	Boiler Room	Circulation	Unknown	EVE145TTD R5352AB	Unknown	~10	20
Pump	Boiler Room	Circulation	Unknown	EVE145TTD R5352AB	Unknown	~10	20
Pump	Boiler Room	Circulation	Unknown	EVE145TTD R5352AB	Unknown	~10	20
Pump	Boiler Room	Fuel oil	Dayton	5K447C	Unknown	~10	20
Pump	Boiler Room	Fuel oil	Dayton	5K447C	Unknown	~10	20
Pump	Boiler Room	Circulation	Bell and Gossett	HV C10	Unknown	~10	20
Wall ACU	Faculty Room	Faculty Room	Unknown	Unknown	Unknown	~7	10
Wall ACU	Office (Gym)	Office (Gym)	GE	AMD10ABM1	Unknown	~7	10
Wall ACU	Secretary's Office	Secretary's Office	Trane	Unknown	Unknown	~7	10
Wall ACU	David Bicofsky's Office	David Bicofsky's Office	GE	Unknown	Unknown	~7	10
Wall ACU	Admin Assistants	Admin Assistants	GE	ABM22DAR	Unknown	~7	10
Wall ACU	Outer Large Admin	Outer Large Admin	EMI	Unknown	Unknown	~7	10
Wall ACU	Director's Office	Director's Office	GE	Unknown	Unknown	~7	10
Wall ACU	Server Room	Server Room	GE	Unknown	Unknown	~10	10
Wall ACU	Server Room	Server Room	GE	Unknown	Unknown	~10	10
Wall ACU	Classroom 25	Classroom 25	GE	Unknown	Unknown	~10	10
Wall ACU	Classroom 25	Classroom 25	Kenmore	Unknown	Unknown	~10	10
Wall ACU	Classroom 23	Classroom 23	Friedrich	Unknown	Unknown	~10	10
Wall ACU	Room 21 A & 21 B	Room 21 A & 21 B	Unknown	Unknown	Unknown	~10	10
Wall ACU	Room 21 A & 21 B	Room 21 A & 21 B	Unknown	Unknown	Unknown	~10	10

Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.


CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-11 below.

Table 4.2-11 Eugene Field Administration Building Domestic Water Heaters						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	Rheem	50	41V50	Gas fired	40 MBH	Good

### 4.2.4 Hawthorne Elementary School

A model of the Hawthorne Elementary School was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009. Figure 4.2-10 below compares actual monthly electricity usages, with those predicted by the eQuest model.

**Figure 4.2-10: Hawthorne Elementary School Electricity Usage**




Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-11 below compares the school’s actual monthly natural gas usage to model-predicted natural gas use.



**Figure 4.2-11: Hawthorne Elementary School Natural Gas Usage**



Currently the HVAC systems at the Hawthorne Elementary School are controlled independently, by room thermostats. It is recommended that a direct digital control (DDC) building management system (BMS) be implemented. A system like this would monitor and control all HVAC equipment, allowing maintenance staff to operate systems and adjust climate control in real time to maximize comfort, while minimizing unnecessary heating and cooling.

Typically implementation of a BMS will save the owner 5-15% of the energy devoted to HVAC. As all systems are currently independently monitored and controlled, CDM conservatively estimates that implementing a DDC BMS will allow the school to save, on average, 10% of the energy being used for HVAC. Table 4.2-12 demonstrates the potential payback from such an implementation.

<b>Table 4.2-12: Hawthorne Elementary School DDC BMS Payback</b>	
Predicted Annual Savings (Therms)	4,297
Annual Savings (Natural Gas)	\$5,371
Predicted Annual Savings (kWh)	13,276
Annual Savings (Electricity)	\$2,189
Total Annual Savings	\$7,560
Initial Capital Cost of Upgrade	\$42,584
Incentives**	\$0
Cost of Upgrade	\$42,584
Annual Maintenance Cost Savings (AMCS)	\$0
<b>Simple Payback</b>	<b>5.6</b>
Lifetime Energy Savings (15 years)*	\$140,607.09

Table 4.2-12: Hawthorne Elementary School DDC BMS Payback	
Annual Return on Investment (AROI)	11.09%
Internal Rate of Return (IRR)	18.62%
Net Present Value (NPV)	\$67,512.33


\*Assumes 3% yearly inflation on natural gas and electricity costs  
\*\*No Incentives found for this upgrade

Currently, the heating system utilizes two (2) Smith Cast Iron Sectional boilers. Each boiler has a gross-output capacity of 2289 MBH. CDM conservatively estimates these boilers to be 75% efficient.

CDM recommends replacing these boilers with high-efficiency, natural gas-fired, condensing boilers. Based on the building model, and accounting for a 25% safety factor, CDM has calculated a peak heating load of 2,400 MBH. CDM anticipates that two (2) 3,000 MBH output, high-efficiency condensing boilers should adequately heat the school. In this upgrade, the existing steam heating system would be retrofitted for hot water use. Steam traps would be replaced with hot water control valves, condensate piping would be scheduled for demolition, and new hot water return piping and insulation would be installed.

Figure 4.2-12 compares current gas usage with predicted gas usage resulting from a switch to high-efficiency, condensing boilers. Condensing boilers are modeled with a full-load efficiency of ~92% and return water temperature of 100°F.

Figure 4.2-12: Hawthorne Elementary School – Boiler Upgrade – Natural Gas Usage



Fiscal savings from such an upgrade are then identified in Table 4.2-13 below. Lifetime savings calculations for all ECRM’s may be found in Appendix I. It’s

important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

Due to the improved automation and control within modern condensing boilers, their operation and maintenance costs tend to be less than those of typical firetube boilers. CDM estimates a firetube boiler system will typically cost around \$3,500 per year for regular preventative maintenance, whereas a condensing boiler system would cost around \$2,000 per year. Therefore, replacing the existing boiler system with a condensing boiler system should result in an operation and maintenance cost savings of \$1,500 per year.

<b>Table 4.2-13: Hawthorne Elementary School Boiler Upgrade Payback</b>	
Predicted Annual Savings (Therms)	12,991
Total Annual Savings	\$16,239
Initial Capital Cost of Upgrade	\$181,165
Incentives**	\$6,000
Cost of Upgrade	\$175,165
<b>Simple Payback</b>	<b>9.9</b>
Lifetime Energy Savings (24 years)*	\$595,048.01
Annual Maintenance Cost Savings (AMCS)	\$1,500
Annual Return on Investment (AROI)	5.96%
Internal Rate of Return (IRR)	11.46%
Net Present Value (NPV)	\$228,620.39

\*Assumes 3% yearly inflation on natural gas costs

\*\*Incentives, per New Jersey Clean Energy Program, are \$1.00 per MBH

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM's on site audit is listed in Table 4.2-14 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

Table 4.2-14 Hawthorne Elementary School HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Roof	Principal's Office	Friedrich	MR24C3F	SEER 18	~5	20
ACC	Roof	Server Closet	Friedrich	MR24C3F	SEER 18	~5	20
ACC	Roof	Principal's Office	Friedrich	MR30C3F	SEER 18	~5	20
ACC	Left Roof	Interior	Trane	RAUC020EBM13D	Unknown	~7	20
AHU	Library Roof	Interior	Trane	SACA-501-A	Unknown	>20	20
AHU	Computer Lab Roof	Interior	Trane	SACA-501-A	Unknown	>20	20
AHU	Roof	Interior	Unknown	Unknown	Unknown	~15	20
AHU	Roof	Interior	Unknown	Unknown	Unknown	~15	20
Boiler	Boiler Room	Interior	HB Smith	Unknown	~75%	~25	25
Boiler	Boiler Room	Interior	HB Smith	Unknown	~75%	~25	25
EF	Roof	Interior	PVC	DX13B	Unknown	~7	20
EF	Roof	Interior	PVC	DX13B	Unknown	~7	20
EF	Roof	Interior	PVC	DX16B	Unknown	~7	20
EF	Roof	Interior	PVC	DX16B	Unknown	~7	20
EF	Roof	Interior	PVC	DX7B	Unknown	~7	20
EF	Roof	Interior	PVC	DX7B	Unknown	~7	20
EF	Classroom Roof	Interior	Unknown	Unknown	Unknown	~20	20
EF	Classroom Roof	Interior	Unknown	Unknown	Unknown	~20	20
EF	Roof	Restroom	PVC	DX13B	Unknown	~7	20
EF	Roof	Restroom	PVC	DX16B	Unknown	~7	20
EF	Roof	Restroom	PVC	DX7B	Unknown	~7	20
EF	Roof	Restroom	PVC	DX18B	Unknown	~7	20
EF	Roof	Cafeteria	PVC	DX16B	Unknown	~7	20
EF	Roof	Cafeteria	PVC	DX9B	Unknown	~7	20
EF	Roof	Cafeteria	PVC	DX7B	Unknown	~7	20
EF	Roof	Cafeteria	PVC	CM10	Unknown	~7	20

Table 4.2-14 Hawthorne Elementary School HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
EF	Roof	Cafeteria	Trane	MCCA012BBG0 A)DA0...	Unknown	14	20
Pump (P-1)	Boiler Room	Circulation	Emerson	P63CZB-3019	Unknown	~10	20
Pump (P-2)	Boiler Room	Circulation	Marathon	DQJ 56T17D5333B	Unknown	~10	20
Wall ACU	Teachers Lounge	Teachers Lounge	GE	AVM24DCR1	Unknown	~10	10
Wall ACU	Room 11 Child Study	Room 11 Child Study	GE	Unknown	Unknown	~10	10
Wall ACU	Nurse's Office	Nurse's Office	GE	Unknown	Unknown	~10	10
Wall ACU	Room 14	Room 14	GE	AVM18DAV1	Unknown	~10	10

Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.

It can be seen that several of the rooftop units have either exceeded or are close to exceeding their ASHRAE expected service lives. Consequently, it can be assumed that these units are not performing at their rated efficiencies. The two Trane units on the library and media center roof are 5 ton units that are in need of immediate replacement. Table 4.2-15 demonstrates the anticipated combined savings resulting from upgrading to similarly sized modern units, with higher cooling and heating efficiencies.

Table 4.2-15: Hawthorne Elementary School RTU Replacement Payback	
Predicted Annual Savings (therms)	268
Predicted Annual Savings (kwh)	2098
Total Annual Savings	\$681
Initial Capital Cost of Upgrade	\$17,753
Incentives**	\$790
Cost of Upgrade	\$16,963
<b>Simple Payback</b>	<b>24.9</b>
Lifetime Energy Savings (24 years)*	\$23,444.43
Annual Maintenance Cost Savings (AMCS)	\$0

Table 4.2-15: Hawthorne Elementary School RTU Replacement Payback	
Annual Return on Investment (ARO)	(-0.15%)
Internal Rate of Return (IRR)	(2.46%)
Net Present Value (NPV)	(\$1,095.17)

\*Assumes 3% yearly inflation on electricity costs

\*\*Incentives, per New Jersey Smart Start Program, \$79/Ton


CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-16 below.

Table 4.2-16 Hawthorne Elementary School Domestic Water Heaters						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	Rheem	80	81V80DA	Electric	4500 kW	Good

### 4.2.5 Lowell Elementary School

A model of the Lowell Elementary School was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009 and oil bills from November 2007 to December 2009. Figure 4.2-13 below compares actual monthly electricity usages, with those predicted by the eQuest model.


Figure 4.2-13: Lowell Elementary School Electricity Usage



Local spikes in the summer could be attributed to summer session activities or increased occupancy due to preparation for the next school year. Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-14 below compares the school’s actual monthly oil usage to model-predicted oil use. Actual oil usage accounts not only for the gallons of oil consumed per month, but also for the gallons of oil represented by the monthly natural gas consumption.

**Figure 4.2-14: Lowell Elementary School Oil Usage**



Currently the HVAC systems at the Lowell Elementary School are controlled independently, by room thermostats. It is recommended that a direct digital control (DDC) building management system (BMS) be implemented. A system like this would monitor and control all HVAC equipment, allowing maintenance staff to operate systems and adjust climate control in real time to maximize comfort, while minimizing unnecessary heating and cooling.

Typically implementation of a BMS will save the owner 5-15% of the energy devoted to HVAC. As all systems are currently independently monitored and controlled, CDM conservatively estimates that implementing a DDC BMS will allow the school to save, on average, 10% of the energy being used for HVAC. Table 4.2-17 demonstrates the potential payback from such an implementation.

<b>Table 4.2-17: Lowell Elementary School DDC BMS Payback</b>	
Predicted Annual Savings (Gallons Oil)	2,064
Annual Savings (Oil)	\$4,871
Predicted Annual Savings (kWh)	11,932
Annual Savings (Electricity)	\$2,238
Total Annual Savings	\$7,109
Initial Capital Cost of Upgrade	\$40,629
Incentives**	\$0
Cost of Upgrade	\$40,629
Annual Maintenance Cost Savings (AMCS)	\$0
<b>Simple Payback</b>	<b>5.7</b>
Lifetime Energy Savings (15 years)*	\$132,222.08
Annual Return on Investment (AROI)	10.83%
Internal Rate of Return (IRR)	18.31%
Net Present Value (NPV)	\$62,902.08

\*Assumes 3% yearly inflation on oil and electricity costs

\*\*No Incentives found for this upgrade


Currently, the heating system utilizes two (2) Smith Cast Iron Sectional boilers. Each boiler has a gross-output capacity of 2163 MBH. CDM conservatively estimates these boilers to be 80% efficient.

CDM recommends replacing these boilers with high-efficiency, natural gas-fired, condensing boilers. Based on the building model, and accounting for a 25% safety factor, CDM has calculated a peak heating load of 2,500 MBH. CDM anticipates that two (2) 3,000 MBH output, high-efficiency condensing boilers should adequately heat the school. In this upgrade, the existing steam heating system would be retrofitted for hot water use. Steam traps would be replaced with hot water control valves, condensate piping would be scheduled for demolition, and new hot water return piping and insulation would be installed.

Figure 4.2-15 compares current gas usage with predicted gas usage resulting from a switch to high-efficiency, condensing boilers. Condensing boilers are modeled with a full-load efficiency of ~92% and return water temperature of 100°F.



**Figure 4.2-15: Lowell Elementary School – Boiler Upgrade – Oil Usage**



Fiscal savings from such an upgrade are then identified in Table 4.2-18 below. Lifetime savings calculations for all ECRM’s may be found in Appendix I. It’s important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

Due to the improved automation and control within modern condensing boilers, their operation and maintenance costs tend to be less than those of typical firetube boilers. CDM estimates a firetube boiler system will typically cost around \$3,500 per year for regular preventative maintenance, whereas a condensing boiler system would cost around \$2,000 per year. Therefore, replacing the existing boiler system with a condensing boiler system should result in an operation and maintenance cost savings of \$1,500 per year.

<b>Table 4.2-18: Lowell Elementary School Boiler Upgrade Payback</b>	
Current Annual Oil Cost for Existing Boilers	\$48,707
Predicted Annual Gas Cost for Condensing Boilers	\$28,336
Total Annual Savings	\$20,371
Initial Capital Cost of Upgrade	\$222,990
Incentives**	\$6,000
Cost of Upgrade	\$216,990
<b>Simple Payback</b>	<b>9.9</b>
Lifetime Energy Savings (24 years)*	\$737,305.76
Annual Maintenance Cost Savings (AMCS)	\$1,500
Annual Return on Investment (ARO I)	5.91%

<b>Table 4.2-18: Lowell Elementary School Boiler Upgrade Payback</b>	
Internal Rate of Return (IRR)	11.44%
Net Present Value (NPV)	\$283,080.23

\*Assumes 3% yearly inflation on fuel costs

\*\*Incentives, per New Jersey Clean Energy Program, are \$1.00 per MBH

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM's on site audit is listed in Table 4.2-19 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

<b>Table 4.2-19 Lowell Elementary School HVAC Equipment Service Lives</b>							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Grade	Principal/Main Office	Friedrich	MR30C3E	SEER 18	~5	20
ACC	Grade	Principal/main office	Friedrich	MR30C3E	SEER 18	~5	20
ACC	Roof	Interior rooms (Special Ed)	International Comfort Products	ACS030A2C1 FBA030GC1	Unknown	~10	20
ACC	Roof	Library	Intercity Products Corps.	CA5548VHD2 CBA048HB2	Unknown	~10	20
ACC	Roof	Library	Intercity Products Corps.	CA5548VHD2 CBA048HB2	Unknown	~10	20
ACC	Roof	Server Closet	Friedrich	outdoor: MR12C1F indoor: MW12C1F	SEER 18	~5	20
ACC	Roof	Computer Room	Intercity Products Corps.	CA5536VHD2 CBA036HB2	Unknown	~10	20
ACC	Roof	Computer Room	Intercity Products Corps.	CA5536VHD2 CBA036HB2	Unknown	~10	20
ACC	Roof	Interior room	Friedrich	P-12	SEER 18	~5	20

**Table 4.2-19 Lowell Elementary School HVAC Equipment Service Lives**

Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
AHU	Roof	Cafeteria	McQuay	ALP019D	Unknown	~15	20
AHU	Room 228	Room 228	McQuay	BSCSISL114DH	Unknown	~15	20
Boiler	Boiler Room	Bldg Dist	HB Smith	28A-7	~80%	>20	25
Boiler	Boiler Room	Bldg Dist	HB Smith	28A-S/W-07	~80%	>20	25
EF	Roof	Restroom	Loren Cook	160PR 16PR	Unknown	~5	20
EF	Roof	Interior	Carnes	VTB18P1A1NA15SPCX	Unknown	~5	20
EF	Roof	Interior	Carnes	VTBK24S1C15SPCX	Unknown	~5	20
EF	Roof	Interior	Carnes	VTBK21R1C1NA15SPCX	Unknown	~5	20
EF	Roof	Interior	Carnes	VEBK10L1A1NA15APCX	Unknown	~5	20
EF	Roof	Restroom/Locker Room	Unknown	Unknown	Unknown	~20	20
EF	Roof	Restroom/Locker Room	Unknown	Unknown	Unknown	~20	20
EF	Roof	Restroom/Locker Room	Unknown	Unknown	Unknown	~20	20
EF	Roof	Restroom/Locker Room	Unknown	Unknown	Unknown	~20	20
EF	Roof	Restroom/Locker Room	Unknown	Unknown	Unknown	~20	20
EF	Roof	Restroom/Locker Room	Unknown	Unknown	Unknown	~20	20
EF	Roof	Kitchen	Carnes	VEBK08L1A1NA15APCX	Unknown	~7	20
EF	Low Roof	Interior	Carnes	Unknown	Unknown	~7	20
EF	Low Roof	Interior	Carnes	Unknown	Unknown	~7	20
EF	Low Roof	Interior	Carnes	Unknown	Unknown	~7	20
EF	Gym Roof	Gym	Loren Cook	80PR 8PR	Unknown	~7	20
EF	Gym Roof	Gym	Loren Cook	160PR 16PR	Unknown	~7	20
EF	Roof	Classroom	Carnes	VEBK08L1A1NA15APCX	Unknown	~7	20
EF	Roof	Cafeteria	Carnes	VWDK06F3A1NA15SPX	Unknown	~5	20
EF	Roof	Cafeteria	Carnes	VEBK301A1NA15SPCX	Unknown	~5	20
EF	Roof	Unknown	Carnes	V1BK15L1A1NL20...GX	Unknown	~5	20
EF	Roof	Unknown	Carnes	V1BK12K3A1NL20...GX	Unknown	~7	20

**Table 4.2-19 Lowell Elementary School HVAC Equipment Service Lives**

Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
Pump	Boiler Room	Circulation	Baldor	M3218T	Unknown	~10	20
Pump	Boiler Room	Circulation	Baldor	M3218T	Unknown	~10	20
Pump	Boiler Room	Feed Water	Baldor	Unknown	Unknown	~10	20
Pump	Boiler Room	Feed Water	Baldor	Unknown	Unknown	~10	20
Pump	Boiler Room	Circulation	Baldor	VM3158	Unknown	~10	20
Pump	Boiler Room	Sump	Unknown	8-135311-03	Unknown	~5	10
Pump	Boiler Room	Sump	Unknown	8-135311-03	Unknown	~5	10
wall ACU	Nurse's Office	Nurse's Office	Carrier	Unknown	Unknown	~7	10
wall ACU	Nurse's Office	Nurse's Office	Friedrich	Unknown	Unknown	~7	10
wall ACU	Room 120	Room 120	Hot Point	Unknown	Unknown	~10	10

Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.

It may be seen that some air handling units have likely exceeded their ASHRAE expected service lives. CDM recommends replacing these units as soon as financially feasible to ensure minimal downtime and mitigate increasing maintenance costs. However, CDM anticipates minimal energy savings from replacements as the units primarily utilize hot and chilled water coils and therefore do not have rated efficiencies that may be improved.


CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-20 below.

Table 4.2-20 Lowell Elementary School Domestic Water Heaters						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	AO Smith	40 gal	FSG 40 242	Gas-fired	32 MBH	Good

### 4.2.6 Teaneck High School

A model of the Teaneck High School was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009 and oil bills from January 2008 to December 2008. Figure 4.2-16 below compares actual monthly electricity usages, with those predicted by the eQuest model.


**Figure 4.2-16: Teaneck High School Electricity Usage**



Local spikes in the summer could be attributed to summer session activities or increased occupancy due to preparation for the next school year. Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-17 below compares actual oil usage to model-predicted oil use. Actual oil usage accounts not only for the gallons of oil consumed per month, but also for the gallons of oil represented by the monthly natural gas consumption. The boilers are dual-fuel and use either oil or natural gas depending on which fuel option is cheaper.

**Figure 4.2-17: Teaneck High School Oil Usage**



In the existing system, the single stage absorption chiller is energized by steam from the boilers, which requires the boilers to run all year long. This results in a spike in oil usage in the summer months. CDM recommends base loading the screw chillers in the summer months, so that the absorption chiller is only needed for peak conditions. The domestic hot water load on the existing boilers can be segregated to a new condensing domestic water heater to help accomplish this change. Table 4.2-21 provides anticipated savings associated with the implementation of a separate domestic hot water heater. No maintenance cost savings were considered for this measure.

<b>Table 4.2-21: Teaneck High School DHW Heater Payback</b>	
Current Annual Oil Cost for DHW load on existing boilers	\$15,702
Predicted Annual Gas Cost for separate DHW heater	\$5,725
Total Annual Savings	\$9,977
Initial Capital Cost of Upgrade	\$5,240
Incentives**	\$0
Cost of Upgrade	\$5,240
<b>Simple Payback</b>	<b>0.5</b>
Lifetime Energy Savings (24 years)*	\$343,471.86
Annual Maintenance Cost Savings (AMCS)	\$0
Annual Return on Investment (AROI)	186.24%

<b>Table 4.2-21: Teaneck High School DHW Heater Payback</b>	
Internal Rate of Return (IRR)	193.41%
Net Present Value (NPV)	\$227,233.40

\*Assumes 3% yearly inflation on fuel costs

\*\*No incentives were noted for domestic hot water heaters

Currently, the chilled water, hot water, and domestic hot water circulation pumps are set to provide a constant flow through their respective systems when in operation. The Board expressed interest in variable speed control for the hot water circulation pumps. Varying the flow in the water systems to match building requirements can provide significant electricity savings, as the pumps are no longer consistently running at full speed. However, the decreased electricity is compensated by an increase in the oil load. Since the oil usage is a function of boiler run time, the cast iron, firetube boilers run at full capacity whenever they are running. Therefore, a variable frequency drive (VFD) on the water circulation pumps causes the boiler to run longer and consume more fuel to meet the building's heating and cooling needs. Table 4.2-22 provides anticipated savings associated with the implementation of variable speed drives for all pumps. CDM anticipates no maintenance cost savings associated with variable speed drives.

<b>Table 4.2-22: Teaneck High School Variable Speed Hot Water Pump Payback</b>	
Predicted Annual Savings (kWh)	173,640
Electricity-related Savings	\$27,591
Predicted Annual Savings (Gal Oil)	-3,522
Oil-related Savings	-\$11,729
Total Annual Savings	\$15,863
Initial Capital Cost of Upgrade	\$76,123
Incentives**	\$0
Cost of Upgrade	\$76,123
<b>Simple Payback</b>	<b>4.8</b>
Lifetime Energy Savings (15 years)*	\$295,030.29
Annual Maintenance Cost Savings (AMCS)	\$0
Annual Return on Investment (AROI)	14.17%
Internal Rate of Return (IRR)	22.24%
Net Present Value (NPV)	\$154,888.40

\*Assumes 3% yearly inflation on oil and electricity costs

\*\*No incentives were noted for variable speed drives on hot water circulation pumps

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM's on site audit is listed in Table 4.3-23 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

Where equipment ages were not found on the equipment tags, they have been estimated based on the unit appearance or approximate renovation dates. In some cases, service locations may have been estimated based on unit proximity. Additionally, in cases where a unit's manufacturer and/or model could not be determined due to an unreadable, faded, destroyed, or lost tag, manufacturer and model number information has been represented as "unknown".

Table 4.2-23 Teaneck High School HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
Absorption Chiller	Boiler Room	Bldg. Dist.	Trane	ABSC046ALR01A AAHABBBBBAA0D 0 3011000011	Unknown	~5	23
ACC	Roof	Server Closet	Friedrich	MR09C1E	~SEER 18	~5	15
ACC	Roof	Server Closet	Friedrich	MR09C1E	~SEER 18	~5	15
ACC	Main Office	Main Office	Friedrich	NR30C3F; indoor evap: MW30Y3F	~SEER 18	~5	15
ACC	Principal Office	Principal Office	Friedrich	NR24C3F; indoor evap: MW24Y3F	~SEER 18	~5	15
ACC	Nurse's Office - 1st floor	Nurse's Office - 1st floor	Daikin	FXMQ36MVJU	Unknown	~5	15
ACC	Technician's Room	Technician's Room	Friedrich	outdoor: MR30C3F; indoor: MW30C3F	~SEER 18	~5	15
ACC	Technician's Room	Technician's Room	Friedrich	outdoor: MR30C3F; indoor: MW30C3F	~SEER 18	~5	15
ACU	Nurse's Office - 1st floor	Nurse's Office - 1st floor	Carrier	39EH08	Unknown	~5	15
AHU [RTU-5]	Roof	Auditorium	Tjernlund	Unknown	Unknown	>30	24



Table 4.2-23 Teaneck High School HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
AHU [RTU-4]	Roof	Media center	Tjernlund	Unknown	Unknown	>30	24
AHU [RTU-1]	Roof	Windowless classrooms	McQuay	RWS804BW	Unknown	~20	20
AHU [RTU-3]	Roof	Lecture Hall	unknown	unknown	Unknown	~20	20
AHU	Roof	Band Room	Trane	unknown	Unknown	~0	20
AHU [RTU-2]	Roof	guidance, media, exterior classrooms	McQuay	RWS804BW	Unknown	~20	20
AHU	Gym	Gym	Trane	B6C611A B/MA	Unknown	7	20
AHU	Gym	Gym	Trane	B6C611A B/MA	Unknown	7	20
AHU	Gym Locker Room	Gym Locker Room	Trane	MCCA010GAV0AAA000D0CCA00C0A0000AC000C000AA000	Unknown	~5	20
Boiler	Boiler Room	Bldg. Dist.	Cleaver Brooks	CB1-200-350-015	~85%	~10	25
Boiler	Boiler Room	Bldg. Dist.	Cleaver Brooks	CB1-200-350-015	~85%	~10	25
EF	Roof	Auditorium	Unknown	Unknown	Unknown	>20	20
EF	Roof	Auditorium	Unknown	Unknown	Unknown	>20	20
EF	Roof	Art Room 327	Greenheck	CUBE-131-4	Unknown	~5	20
EF	Roof	Art Room 325	Greenheck	GB-180-7	Unknown	~5	20
EF	Roof	Kitchen	PVC	FX36BFT	Unknown	~5	20
EF	Roof	Hallway	PVC	FX16BFT	Unknown	~5	20
EF	Roof	Hallway	PVC	DX7B	Unknown	~5	20
EF	Roof	Gym	Greenheck	GB-200-10	Unknown	~5	20
EF	Roof	Gym	Greenheck	GB-200-10	Unknown	~5	20
EF	Roof	Gym	Greenheck	GB-200-10	Unknown	~5	20
EF	Roof	Gym	Greenheck	GB-200-10	Unknown	~5	20
EF	Roof	3rd floor Hallway	PVC	AB35	Unknown	~5	20
EF	Roof	Boys toilet	PVC	DX10SR	Unknown	~5	20
EF	Roof	Girls Toilet	unknown	unknown	unknown	~15	20

Table 4.2-23 Teaneck High School HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
EF	Roof	Room adjacent to Girl's Toilet	PVC	DX10SR	Unknown	~15	20
EF	Roof	room 321	PVC	DX10SR	Unknown	~5	20
EF	Unknown	Unknown	Unknown	WXR82L	Unknown	~20	20
EF	Unknown	Unknown	Unknown	WXR82L	Unknown	~20	20
EF	Unknown	Unknown	Unknown	WXR82L	Unknown	~20	20
MAU	Art Rooms 327 & 325 (3rd fl)	Art Rooms 327 & 325 (3rd fl)	Trane	B6C611B B/MA	Unknown	8	20
MAU	Room 140 A	Gym	Trane	B6C611D B/MA	Unknown	8	20
MAU	Room 138 (Aux Gym)	Gym	Trane	B6C611C B/MA	Unknown	8	20
Pump	Boiler Room	Sump	Magnetek	8-186691-02	Unknown	~5	10
Pump	Boiler Room	Sump	Magnetek	8-186691-02	Unknown	~5	10
Pump	Boiler Room	Circulation	Universal Electric	SVE56T17D950A	Unknown	~10	20
Pump	Boiler Room	Circulation	Universal Electric	SVE56T17D950A	Unknown	~10	20
Pump	Boiler Room	Circulation	Bell and Gossett	100AB F49	Unknown	~10	20
Pump	Boiler Room	Circulation	Taco	007-BF5	Unknown	~10	20
Pump	Boiler Room	Circulation	Baldor	CJH3108	Unknown	~10	20
Pump	Boiler Room	Circulation	Baldor	CJH3108	Unknown	~10	20
Pump	Boiler Room	Condenser	Taco	FM5010	Unknown	~10	20
Pump	Boiler Room	Condenser	Taco	FM5010	Unknown	~10	20
Pump	Boiler Room	Circulation	Taco	92	Unknown	~10	20
Pump	Boiler Room	Circulation	Taco	92	Unknown	~10	20
Pump	Boiler Room	Circulation	Taco	FM4008	Unknown	~10	20
Pump	Boiler Room	Circulation	Taco	FM4008	Unknown	~10	20
Pump	Boiler Room	Circulation	US Electrical	B075	Unknown	~10	20
Pump	Boiler Room	Circulation	US Electrical	B075	Unknown	~10	20
Pump	Boiler Room	Circulation	Marathon	9VJ143TTDR5336A B	Unknown	~10	20
Pump	Boiler Room	Circulation	Marathon	9VJ143TTDR5336A B	Unknown	~10	20
Pump	Boiler Room	Fuel Oil	Marathon	91VN56T17324JP	Unknown	~10	20

Table 4.2-23 Teaneck High School HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
Pump	Boiler Room	Fuel Oil	Marathon	91VN56T17324JP	Unknown	~10	20
Pump (P-1)	Boiler Room	Circulation	BFS Industries	BFSB151-3/4	Unknown	~10	20
Pump (P-2)	Boiler Room	Circulation	BFS Industries	BFSB151-3/4	Unknown	~10	20
Pump (P-3)	Boiler Room	Circulation	BFS Industries	BFSB151-3/4	Unknown	~10	20
Pump	Boiler Room	Condenser	Baldor	37027X33	Unknown	~10	20
Pump	Boiler Room	Condenser	Baldor	37027X33	Unknown	~10	20
Pump	Boiler Room	Chiller	Unknown	Unknown	Unknown	~15	20
Pump	Boiler Room	Chiller	Unknown	Unknown	Unknown	~15	20
Screw Chiller	Boiler Office	Bldg Dist	Dunham	PCWX100	Unknown	~15	23
Screw Chiller	Boiler Office	Bldg Dist	Dunham	PCWX100	Unknown	~15	23
UH	Press Box	Press Box	QMark	MUH0381	Unknown	Unknown	13
Wall ACU	Room 303	Room 303	Frigidaire Electrolux	Unknown	Unknown	~10	10
Wall ACU	Technical Closet	Technical Closet	Unknown	Unknown	Unknown	~15	10
Wall ACU	Admin Office	Admin Office	Unknown	Unknown	Unknown	~15	10
Wall ACU	Science Lab	Science Lab	Unknown	Unknown	Unknown	~15	10

Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.

It can be seen that several of the rooftop units (RTU-1, 2, 3, 4, and 5) have either exceeded or are close to exceeding their ASHRAE expected service lives. Consequently, it can be assumed that these units are not performing at their rated efficiencies. Unfortunately, CDM was unable to determine the capacity of many of these units because model numbers were not available. For modeling and cost estimating purposes, the two large Tjernlund units have been assumed to each be 300 MBH models with a cooling capacity of 20 tons. Table 4.2-24 demonstrates the anticipated combined savings resulting from upgrading to similarly sized modern units, with a cooling seasonal energy efficiency ratio (SEER) of 14.7 (COP is approximately 3.76), and heating annual fuel utilization efficiency (AFUE) of 94.6%. Due to the increased efficiency and enhanced controls and capabilities of these units, they typically offer a 40% energy savings over their predecessors.

<b>Table 4.2-24: Teaneck High School RTU Replacements Payback</b>	
Predicted Annual Savings (therms)	1336
Predicted Annual Savings (kwh)	12696
Total Annual Savings	\$3,460
Initial Capital Cost of Upgrade	\$130,008
Incentives**	\$3,160
Cost of Upgrade	\$126,848
<b>Simple Payback</b>	<b>36.7</b>
Lifetime Energy Savings (24 years)*	\$119,115.59
Annual Maintenance Cost Savings (AMCS)	\$0
Annual Return on Investment (AROI)	(-1.44%)
Internal Rate of Return (IRR)	(-0.45%)
Net Present Value (NPV)	(\$46,226.14)

\*Assumes 3% yearly inflation on electricity costs

\*\*Incentives, per New Jersey Smart Start Program, \$79/Ton


CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-25 below.

<b>Table 4.2-25 Teaneck High School Domestic Water Heaters</b>						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	Bradford White	Unknown	40A-15-3-103-N-AA	Electric	Unknown	Not in Use

### 4.2.7 Thomas Jefferson Middle School

A model of Thomas Jefferson Middle School was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009 and oil bills from November 2007 to December 2009. Figure 4.2-18 below compares actual monthly electricity usages, with those predicted by the eQuest model.


**Figure 4.2-18: Thomas Jefferson Middle School Electricity Usage**



Local spikes in the summer could be attributed to summer session activities or increased occupancy due to preparation for the next school year. Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-19 below compares the school's actual monthly oil usage to model-predicted oil use. Actual oil usage accounts not only for the gallons of oil consumed per month, but also for the gallons of oil represented by the monthly natural gas consumption.

**Figure 4.2-19: Thomas Jefferson Middle School Oil Usage**




Currently, the heating system utilizes two (2) Smith Cast Iron Sectional boilers. Each boiler has a gross-output capacity of 5,618 MBH. CDM conservatively estimates these boilers to be 80% efficient.

CDM recommends replacing these boilers with high-efficiency, natural gas-fired, condensing boilers. Based on the building model, and accounting for a 25% safety factor, CDM has calculated a peak heating load of 6,700 MBH. CDM anticipates that three (3) 3,000 MBH output, high-efficiency condensing boilers should adequately heat the school.

Figure 4.2-20 compares current gas usage with predicted gas usage resulting from a switch to high-efficiency, condensing boilers. Condensing boilers are modeled with a full-load efficiency of ~91.5% and return water temperature of 100°F.

**Figure 4.2-20: Thomas Jefferson Middle School – Boiler Upgrade - Oil Usage**



Fiscal savings from such an upgrade are then identified in Table 4.2-26 below. Lifetime savings calculations for all ECRM's may be found in Appendix I. It's important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

Due to the improved automation and control within modern condensing boilers, their operation and maintenance costs tend to be less than those of typical firetube boilers. CDM estimates a firetube boiler system will typically cost around \$3,500 per year for regular preventative maintenance, whereas a condensing boiler system would cost around \$2,000 per year. Therefore, replacing the existing boiler system with a

condensing boiler system should result in an operation and maintenance cost savings of \$1,500 per year.

<b>Table 4.2-26: Thomas Jefferson Middle School Boiler Upgrade Payback</b>	
Current Annual Oil Cost for Existing Boilers	\$106,826
Predicted Annual Gas Cost for Condensing Boilers	\$59,658
Total Annual Savings	\$47,167
Initial Capital Cost of Upgrade	\$156,190
Incentives**	\$9,000
Cost of Upgrade	\$147,190
<b>Simple Payback</b>	<b>3.1</b>
Lifetime Energy Savings (24 years)*	\$1,659,804.34
Annual Maintenance Cost Savings (AMCS)	\$1,500
Annual Return on Investment (AROI)	28.90%
Internal Rate of Return (IRR)	35.94%
Net Present Value (NPV)	\$977,257.53

\*Assumes 3% yearly inflation on fuel costs

\*\*Incentives, per New Jersey Clean Energy Program, are \$1.00 per MBH

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM's on site audit is listed in Table 4.3-27 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

Where equipment ages were not found on the equipment tags, they have been estimated based on the unit appearance or approximate renovation dates. In some cases, service locations may have been estimated based on unit proximity. Additionally, in cases where a unit's manufacturer and/or model could not be determined due to an unreadable, faded, destroyed, or lost tag, manufacturer and model number information has been represented as "unknown".

**Table 4.2-27 Thomas Jefferson Middle School HVAC Equipment Service Lives**

Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Media Center/Classrooms Roof	Child Guidance	Trane XR12	Model 2TTR2036A00AA	Unknown	~5	20
ACC	Media Center/Classrooms Roof	Internal rooms	Carrier	Model 38CKC042.	Unknown	~5	20
ACC	Outer Wall	Server Closet	Friedrich	Model MB30C3F	SEER 18	~5	20
AHU	Media Center/Classrooms Roof	Auditorium	Trane/Intellepack	Model SLHFC40E46C5ND1D01A0CEL00RT00600	~80%	~7	20
AHU	Media Center/Classrooms Roof	Locker Rooms	Trane	Model TSCA006G0BA0EAD0CAAEDA	~80%	7	20
AHU	Main Office	Main Office	Trane	D5WB18042E0BABABA00A0	~80%	~7	20
AHU	Main Office	Main /Office	Trane	Model MCCB010U0C0UB	~80%	7	20
AHU	Chorus Room	Chorus Room	Trane	Model BCVC054E21D02E...BB...	~80%	7	20
AHU	Children Study	Children Study	Trane	Model 86G477AB	~80%	7	20
AHU	Basement serving Caf/Kitchen	Caf/Kitchen	Trane	Model MCCB017U0C0UB	~80%	7	20
AHU	Unknown	Unknown	Trane	Model BCH024E2A0A1C02 E00...BB...	~80%	7	20
AHU	Locker Room unit, under Gym	Gym	Trane	Model MCCB006U0C0UB	~80%	7	20
AHU	Locker Room unit, under Gym	Gym	Trane	Model MCCB014U0C0UA	~80%	7	20
AHU	Locker Room unit, under Gym	Gym	Trane	Model MCCB014U0C0UA	~80%	7	20
AHU	Grade	Main/Principal's Offices	Trane	Model TTA090A30	~80%	~7	20
AHU	Cafeteria	Cafeteria	Trane	Model MCCB021U0C0B	~80%	~7	20
Boiler	Boiler Room	All rooms	HB Smith	Series 450 Mills Bo	~80%	>20	25
Boiler	Boiler Room	All rooms	Trane	Series 450 Mills Bo	~80%	>20	25
EF	Media Center/Classrooms Roof	Unknown	Loren Cook	Model 135R4B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 70C15DH	Unknown	~5	20
EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 70C15DH	Unknown	~5	20
EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 120C4B	Unknown	~5	20



**Table 4.2-27 Thomas Jefferson Middle School HVAC Equipment Service Lives**

EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 90C15DH	Unknown	~5	20
EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 100C2B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Media Center	Loren Cook	Model 165C4B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Media Center	Loren Cook	Model 100R2B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Dance Room	Loren Cook	Model 180C6B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Kitchen	Unknown	Unknown	Unknown	~15	20
EF	Media Center/Classrooms Roof	Kitchen	unknown	unknown	Unknown	~15	20
EF	Media Center/Classrooms Roof	Gym	Loren Cook	Model 245C8B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Gym	Loren Cook	Model 245C8B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 100C10DH	Unknown	~5	20
EF	Media Center/Classrooms Roof	Restroom	Loren Cook	Model 90C10DH	Unknown	~5	20
EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 100C3B	Unknown	~5	20
EF	Media Center/Classrooms Roof	Restroom	Loren Cook	Model 70C15DH	Unknown	~5	20
EF	Media Center/Classrooms Roof	Locker Rooms	Loren Cook	Model 135C5B	Unknown	~5	20
EF	Kitchen	Kitchen	Loren Cook	Model 225TCNB	Unknown	~5	20
EF	Roof	Kitchen	Loren Cook	165 CPS	Unknown	~5	20
Pump	Boiler Room	Circulation	Bell and Gossett	M80121	Unknown	~10	20
Pump	Boiler Room	Circulation	Bell and Gossett	M80121	Unknown	~10	20
Pump	Boiler Room	Circulation	Baldor	M2531T	Unknown	~10	20
Pump	Boiler Room	Circulation	Baldor	M2531T	Unknown	~10	20
UH	Hallway near Boiler Room	Hallway near Boiler Room	Trane	Model UH8A080	Unknown	~7	13
UH	Kitchen Office	Kitchen Office	Gmark	Unknown	Unknown	~7	13

Table 4.2-27 Thomas Jefferson Middle School HVAC Equipment Service Lives							
Wall ACU	Nurse's Office	Nurse's Office	GE	Model ABM24PAR	Unknown	~10	10
Wall ACU	Teacher's Lounge	Teacher's Lounge	unknown	unknown	Unknown	~10	10
Wall ACU	G-6 Basement Comp Rm	G-6 Basement Comp Rm	GE	Model AM24DAR1	Unknown	~10	10
Wall ACU	G-6 Basement Comp Rm	G-6 Basement Comp Rm	GE	Model AM24DAR1	Unknown	~10	10
Wall ACU	G-6 Basement Comp Rm	G-6 Basement Comp Rm	GE	Model AM24DAR1	Unknown	~10	10
Wall ACU	Kitchen Office	Kitchen Office	Sharp	Unknown	Unknown	~10	10

Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.


CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-28 below.

Table 4.2-28 Thomas Jefferson Middle School Domestic Water Heaters						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	AO smith	Unknown	Model HW 200M 942	Electric	199 MBH	Fair

### 4.2.8 Whittier Elementary School

A model of the Whittier Elementary School was created in eQuest to predict heating and cooling loads for the building. To calibrate this model, CDM used electricity and natural gas bills from July, 2007 through December, 2009 and oil bills from November 2007 to December 2009. Figure 4.2-21 below compares actual monthly electricity usages, with those predicted by the eQuest model. Historical monthly usages were averaged for each month observed over multiple years.


Figure 4.2-21: Whittier Elementary School Electricity Usage



Local spikes in the summer could be attributed to summer session activities or increased occupancy due to preparation for the next school year. Increased electrical usage in the winter is indicative of the greater heat load during the peak heating season as well as the heavy occupancy during these months.

Figure 4.2-22 below compares the school's actual monthly oil usage to model-predicted oil use. Actual oil usage accounts not only for the gallons of oil consumed per month, but also for the gallons of oil represented by the monthly natural gas consumption.

Figure 4.2-22: Whittier Elementary School Oil Usage



Currently the HVAC systems at the Whittier Elementary School are controlled independently, by room thermostats. It is recommended that a direct digital control (DDC) building management system (BMS) be implemented. A system like this would monitor and control all HVAC equipment, allowing maintenance staff to operate systems and adjust climate control in real time to maximize comfort, while minimizing unnecessary heating and cooling.

Typically implementation of a BMS will save the owner 5-15% of the energy devoted to HVAC. As all systems are currently independently monitored and controlled, CDM conservatively estimates that implementing a DDC BMS will allow the school to save, on average, 10% of the energy being used for HVAC. Table 4.2-29 demonstrates the potential payback from such an implementation.

<b>Table 4.2-29: Whittier Elementary School DDC BMS Payback</b>	
Predicted Annual Savings (Gallons Oil)	3,122
Annual Savings (Oil)	\$7,400
Predicted Annual Savings (kWh)	20,053
Annual Savings (Electricity)	\$3,343
Total Annual Savings	\$10,742
Initial Capital Cost of Upgrade	\$47,539
Incentives**	\$0
Cost of Upgrade	\$47,539
Annual Maintenance Cost Savings (AMCS)	\$0
<b>Simple Payback</b>	<b>4.4</b>
Lifetime Energy Savings (15 years)*	\$199,797.00
Annual Return on Investment (AROI)	15.93%
Internal Rate of Return (IRR)	24.24%
Net Present Value (NPV)	\$108,903.46

\*Assumes 3% yearly inflation on oil and electricity costs


\*\*No Incentives found for this upgrade

Currently, the heating system utilizes two (2) Smith Cast Iron Sectional boilers. Each boiler has a gross-output capacity of 2,836 MBH. CDM conservatively estimates these boilers to be 80% efficient.

CDM recommends replacing these boilers with high-efficiency, natural gas-fired, condensing boilers. Based on the building model, and accounting for a 25% safety factor, CDM anticipates that two (2) 3,000 MBH output, high-efficiency condensing boilers should adequately heat the school. In this upgrade, the existing steam heating system would be retrofitted for hot water use. Steam traps would be replaced with hot water control valves, condensate piping would be scheduled for demolition, and new hot water return piping and insulation would be installed.

Figure 4.2-23 compares current gas usage with predicted gas usage resulting from a switch to high-efficiency, condensing boilers. Condensing boilers are modeled with a full-load efficiency of ~91.5% and return water temperature of 100°F.

**Figure 4.2-23: Whittier Elementary School – Boiler Upgrade - Oil Usage**



Fiscal savings from such an upgrade are then identified in Table 4.2-30 below. Lifetime savings calculations for all ECRM's may be found in Appendix I. It's important to note that these are estimates based on building models, and further investigation is warranted before pursuing boiler replacements.

Due to the improved automation and control within modern condensing boilers, their operation and maintenance costs tend to be less than those of typical firetube boilers. CDM estimates a firetube boiler system will typically cost around \$3,500 per year for regular preventative maintenance, whereas a condensing boiler system would cost around \$2,000 per year. Therefore, replacing the existing boiler system with a condensing boiler system should result in an operation and maintenance cost savings of \$1,500 per year.

<b>Table 4.2-30: Whittier Elementary School Boiler Upgrade Payback</b>	
Current Annual Oil Cost for Existing Boilers	\$73,996
Predicted Annual Gas Cost for Condensing Boilers	\$64,326
Total Annual Savings	\$9,670
Initial Capital Cost of Upgrade	\$222,990
Incentives**	\$6,000

<b>Table 4.2-30: Whittier Elementary School Boiler Upgrade Payback</b>	
Cost of Upgrade	\$216,990
<b>Simple Payback</b>	<b>19.4</b>
Lifetime Energy Savings (24 years)*	\$368,896.32
Annual Maintenance Cost Savings (AMCS)	\$1,500
Annual Return on Investment (AROI)	0.98%
Internal Rate of Return (IRR)	4.24%
Net Present Value (NPV)	\$33,728.57

\*Assumes 3% yearly inflation on fuel costs

\*\*Incentives, per New Jersey Clean Energy Program, are \$1.00 per MBH

Over several decades, ASHRAE has compiled data pertaining to service lives of most HVAC related equipment. From this, ASHRAE indicates a median service life (life until replacement) for HVAC related equipment that may be used as an estimate for the useful life of HVAC equipment currently in service. For example, ASHRAE indicates a make-up air unit has a median service life of 20 years. Therefore, if a make-up air unit has been in service for more than 20 years, the owner may want to consider replacement. Not only will a replacement ensure minimal downtime between units (the unit is replaced before it ceases to function), but it will also maintain rated system efficiency, as efficiency tends to decrease with age.

All major equipment noted during CDM's on site audit is listed in Table 4.2-31 below, along with estimated current ages and ASHRAE-expected service lives. It should be noted that only equipment that was observed at the time of the audit is included.

<b>Table 4.2-31 Whittier Elementary School HVAC Equipment Service Lives</b>							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
ACC	Roof	Elevator	Mitsubishi Mr. Slim	MU12NN; evap: MS12NN(leak)	SEER 18	~10	20
ACC	Roof	Classrooms	Trane	RAUCC40EPT030A0D000T00	Unknown	~7	20
ACC	Faculty Courtyard	Lunch Room in Basement	Friedrich	MR24C3E-A	SEER 18	~5	20
ACC	Front Entrance	Main Office	Friedrich	MR30C3F	SEER 18	~5	20
ACC	Principal's Office	Principal's Office	Friedrich	MR24C3F	SEER 18	~5	20
ACC	Other	Room 2 Computer Room	Friedrich	indoor: MW12C1F; outdoor: MR12C1F	SEER 18	~5	20
Boiler	Boiler Room	Bldg Dist	Smith	28A-13	~80%	>20	25
Boiler	Boiler Room	Bldg Dist	Smith	28A-S/W-09	~80%	>20	25
EF	Roof	Nurse's Office	Loren Cook	100C10DH	Unknown	~7	20

Table 4.2-31 Whittier Elementary School HVAC Equipment Service Lives							
Description [Tag ID]	Unit Location	Service Location	Manufacturer	Model	Estimated Efficiency	Estimated Age (Years)	ASHRAE Expected Life (Years)
EF	Roof	Nurse's office	Loren Cook	100C10DH	Unknown	~7	20
EF	Roof	Interior Rooms	Carnes	VEBK10K2A1NA20APCX	Unknown	~10	20
EF	Roof	Interior rooms	Carnes	VEBK12L1A1NA20APCX	Unknown	~10	20
EF	Roof	Interior rooms	Carnes	VEBK18M1A1NA20APCX	Unknown	~10	20
EF	Roof	Interior rooms	Carnes	VEBK24P1C1NA20APCX	Unknown	~10	20
EF	Roof	Interior rooms	Carnes	VEBK15L1A1NA20APCX	Unknown	~10	20
EF	Roof adjacent to Caf	Interior rooms	Unknown	Unknown	Unknown	~20	20
EF	Roof adjacent to Caf	Interior rooms	Unknown	Unknown	Unknown	~20	20
EF	Roof adjacent to Caf	Interior rooms	Unknown	Unknown	Unknown	~20	20
EF	Roof adjacent to Caf	Interior rooms	Unknown	Unknown	Unknown	~20	20
EF	Roof adjacent to Caf	Interior rooms	Unknown	Unknown	Unknown	~20	20
EF	Existing Roof area	Interior rooms	Unknown	Unknown	Unknown	~20	20
EF	Existing Roof area	Interior rooms	Unknown	Unknown	Unknown	~20	20
Pump	Boiler Room	Circulation	Emerson	P3FZY-4417	Unknown	~10	20
Pump	Boiler Room	Circulation	Emerson	P3FZY-4417	Unknown	~10	20
Pump	Boiler Room	Circulation	Marathon	5VJ213TTDV7049AA	Unknown	~10	20
Pump	Boiler Room	Circulation	Marathon	5VJ213TTDV7049AA	Unknown	~10	20
Pump	Boiler Room	Circulation	Leland-Faraday	M691A	Unknown	~10	20
Pump	Boiler Room	Circulation	Leland-Faraday	M691A	Unknown	~10	20
Wall ACU	Other	Child Study Team	RCA	Unknown	Unknown	~15	10

Many classrooms in the school utilize unit ventilators for heating. As facility personnel continue to service unit ventilators throughout the building, they should note the condition and approximate age of the units. Those that are older than 15 years should be considered for replacement, as they are likely operating significantly below the equipment-rated efficiency.

CDM also created an inventory of observed domestic water heaters. This will attempt to inform the BOE of any water heaters that are in need of replacement. Equipment observed to be in poor or aging condition would warrant replacement, as they are likely not operating at peak efficiency. This domestic water heater inventory may be seen as Table 4.2-32 below.

Table 4.2-32 Whittier Elementary School Domestic Water Heaters						
Location	Make	Storage Capacity (Gallons)	Model Number	Type	Heating Capacity	Observed Condition
Boiler Room	Rheem	50	41V50	Gas-Fired	40 MBH	Good
Basement Room	AO Smith	80	DVE80A917	Electric	15 kW	Good

## 4.3 Alternative Energy Sources

### 4.3.1 Photovoltaic Solar Energy System Overview

Photovoltaic (PV) cells convert energy in sunlight directly into electrical energy through the use of silicon semi conductors, diodes and collection grids. Several PV cells are then linked together in a single frame of module to become a solar panel. PV cells are able to convert the energy from the sun into electricity. The angle of inclination of the PV cells, the amount of sunlight available, the orientation of the panels, the amount of physical space available and the efficiency of the individual panels are all factors that affect the amount of electricity that is generated.

Based on the estimated cumulative total available roof area, calculations determine that the installation of eleven systems with a total rating of approximately 1395 kW (dc) will be appropriate for the eight School District buildings.

As part of this energy audit, a preliminary engineering feasibility study of the sites outlined above to support solar generation facilities was completed consisting of the following tasks:

- a. Site Visit by our engineers.
- b. Satellite Image Analysis and Conceptual design and layout of the photovoltaic system
- c. Design and construction cost estimates
- d. Determine a preliminary design for the size and energy production of the solar system.

The total unobstructed available area of each section of the roof with southern exposure was evaluated. It is important to note the following:



1. The structural integrity of the roofs was not confirmed during our site visit. The municipal buildings may require some degree of roofing work prior to the implementation of a solar system.
2. In the case of the flat areas, the PV system sizing and kWh production was calculated assuming the installation of a crystalline module facing south direction (220 Degree Azimuth) and tilted approximately 20 degrees to allow better rain water shedding and snow melting. Please note that the kWh production as well as system size may differ significantly based on final panel tilt selected during the RFP and design phase.
3. Blended electric rates were used based on actual utility bills and were applied for the facilities.

The following is a preliminary study on the feasibility of installing PV solar systems at the eight School District buildings to generate a portion of each facility's electricity requirements. Each system is designed to offset the electric purchased from the local utility and not as a backup or emergency source of power.



In order to determine the best location for the installation of the PV solar system, a satellite image analysis and site walkthrough of the facilities was performed on February 9-11<sup>th</sup>. As per the Scope of Work, only the facilities roofs were considered for PV installation.

Also, as part of our assessment we investigated possible locations for electrical equipment that need to be installed such as combiner boxes, disconnect switches and DC to AC inverters. Consideration was also given to locations of interconnection between the solar system and building's electrical grid.

#### **4.3.1.1 Benjamin Franklin Middle School**

The roof of the Benjamin Franklin Middle School is flat with very few obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 265.5 kW (dc).

## Electrical Service

The interconnection point for the PV system will require a modification or replacement of the existing 800A, 3 Phase, 208V service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

### 4.3.1.2 Bryant Elementary School

The roof of the Bryant Elementary School is flat with very few obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 49.8 kW (dc).

## Electrical Service

The interconnection point for the PV system will require a modification or replacement of the existing 800A, 3 Phase, 208V service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

### 4.3.1.3 Eugene Field Administration Building

The roof of the Eugene Field Administration Building is flat with very few obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 60.2 kW (dc).

## Electrical Service

The interconnection point for the PV system will require a modification or replacement of the existing 400A, 3 Phase, 208V service entrance equipment wherein

the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

#### **4.3.1.4 Hawthorne Elementary School**

The roof of the Hawthorne Elementary School is flat with very few obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 148.1 kW (dc).

#### **Electrical Service**

The interconnection point for the PV system will require a modification or replacement of the existing 800A, 3 Phase, 208V service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

#### **4.3.1.5 Lowell Elementary School**

The roof of the Lowell Elementary School is flat with very few obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 69.9 kW (dc).

#### **Electrical Service**

The interconnection point for the PV system will require a modification or replacement of the existing 800A, 3 Phase, 208V service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and

verification of existing electrical equipment would be required prior to implementation of a PV system.

#### **4.3.1.6 Teaneck High School**

The roof of the Teaneck High School is flat with numerous obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 277.8 kW (dc).

#### **Electrical Service**

The interconnection point for the PV system will require a modification or replacement of the existing 3000A, 3 Phase, 480V service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

#### **4.3.1.7 Thomas Jefferson Middle School**

The roof of the Thomas Jefferson Middle School is flat with very few obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 549.5 kW (dc).

#### **Electrical Service**

The interconnection point for the PV system will require a modification or replacement of the existing 800A, 3 Phase, 208V service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

#### 4.3.1.8 Whittier Elementary School

The roof of the Whittier Elementary School is flat with very few obstructions such as exhaust fans, rooftop HVAC units, and electrical and gas piping. There is a minimal amount of shading on the roof from adjacent foliage that would need to be addressed during the design phase of the project. The structural integrity of the roof was not confirmed although a visual inspection revealed no leaks or major defects. The structural integrity of the roof and the existence of a warranty shall be confirmed prior to the implementation of a PV system.

The Project Team conducted both a facility walkthrough and a satellite image analysis and based on the estimated total available area we calculated the installation of a solar system, rated at approximately 239.9 kW (dc).

#### Electrical Service

The interconnection point for the PV system will require a modification or replacement of the existing 800A, 3 Phase, 2080V service entrance equipment wherein the PV system feeder connections will have to be made after the main circuit breaker, and protective relaying will also have to be implemented. Any connection points would have to meet NEC and local utility requirements. Further investigation and verification of existing electrical equipment would be required prior to implementation of a PV system.

#### 4.3.1.9 Basis for Design and Calculations

The most common roof mounted system is referred to as a (“fixed tilt”) system typically mounted to a metal rack that can be fixed at a specific angle. There are also (“tracking systems”) or movable along one or two axes to follow the position of the sun during the day. For a roof-mounted PV system, tracking systems are very rarely installed and are usually used for ground-mounted systems only, as they require more complex racks and higher maintenance costs. For the “fixed” system, the tilt is determined based on the following factors: geographical location, total targeted kWh production, seasonal electricity requirements and weather conditions such as wind. Ideally, the module tilt for Northern New Jersey should be 25-35 degrees with an azimuth as close as possible to 180 (south); however, our experience has shown that PV systems are typically installed at a tilt of 20 degrees or lower in order to avoid any issues with wind and to maximize total system size

The type of PV panels and equipment used to mount the system shall be determined based on the wind conditions and structural integrity of the roof determined during the design phase of the project. In general, penetration/tie-down systems, non-penetrating ballasted type systems, or a combination of the two should be considered.

#### Calculation of PV System Yield

An industry accepted software package, PV Watts was used to calculate projected annual electrical production of the crystalline silicon PV system in its first year, as summarized in Table 4.3-1. The system was design to provide maximum kWh production based on available roof space.



**Table 4.3-1 Summary of Solar (PV) Systems**

Site	Est. Area (ft <sup>2</sup> )	kWh	Annual Energy Savings	Est. Annual SREC	Lifetime Energy Savings (25 Years)*	Annual Return On Investment (ARO I)	Net Present Value (NPV)	Internal Rate of Return (IRR)
<b>Benjamin Franklin Middle School</b>	26,548	325,372	\$50,107.3	\$205,127	\$1,856,213	4.20%	\$62,134	3.22%
<b>Bryant Elementary</b>	4,975.2	60,976	\$10,549	\$38,442	\$390,778	3.15%	-\$63,435	1.95%
<b>Eugene Field Administration Building</b>	6,025	73,837	\$12,183	\$46,550	\$451,320	3.32%	-\$63,957	2.09%
<b>Hawthorne Elementary School</b>	14,812	181,535	\$29,953	\$114,446	\$1,109,613	4.06%	\$25,081	3.16%
<b>Lowell Elementary School</b>	6,994	85,712	\$16,114	\$54,036	\$596,936	3.69%	-\$9,059	2.89%
<b>Teaneck High School</b>	27,776	340,420	\$54,127	\$214,613	\$2,005,114	4.27%	\$109,716	3.38%
<b>Thomas Jefferson Middle School</b>	54,953	673,498	\$119,883	\$424,598	\$4,441,022	4.63%	\$632,029	4.09%
<b>Whittier Elementary School</b>	23,987	293,984	\$49,095	\$185,338	\$1,818,724	4.30%	\$131,487	3.51%

\*3% yearly inflation on electricity costs

### Total Costs

It should be noted that construction costs are only estimates based on historic data compiled from similar installations, and engineering opinion. Additional engineering and analysis is required to confirm the condition of the roofs, structural integrity of the roofs, the system type, sizing, costs and savings. Budget costs assume existing roofs are structurally sound, do not need to be replaced, and can accommodate a solar system. For illustration purposes, a draft financial analysis pro forma is attached outlining all project costs and revenues.

**Table 4.3-2 Engineers Opinion of Probable Cost**

<b>Engineers Opinion of Probable Cost</b>	\$19,682,696
---	--------------

As stated above the estimated installation costs are based on significant experience+ with the pricing of solar installations in New Jersey, and are intended to provide the District with a realistic budget cost. A typical solar installation can vary in cost from \$7.00 - \$10.00 per watt depending on size, complexity of the system, labor rates, etc. Approximately 60-70% of that number is material costs while the balance is labor, engineering, etc. Like any installation, certain conditions can affect a price upward or downward. For purposes of this analysis the estimated installation cost does not include any roofing or structural work which may be required to maintain warranties

or for additional structural support. We have included a budget of \$9/watt for the solar system installation with an additional estimated budget of \$100,000 for potential electric service work.

Refer to Section 7 for discussion on Solar Renewable Energy Certificates and other financing options for solar projects. The financial model in Appendix E provides an annual forecast illustration of project revenues and costs for 25 years.

### 4.3.2 Wind Power Generation

On-site wind power generation typically utilizes a form of turbine, which is rotated with the flow of wind across it, this rotational force powers a generator, producing DC electricity. The DC electricity is then converted into AC electricity, which can be used for commercial power, or can be fed back into the power grid, reducing the overall electric demand. The size of the turbine is proportional to the amount of wind and concurrently the amount of energy it can produce.



CDM has determined that it is feasible for the Teaneck School District to install wind turbine energy systems at 8 of its sites. This is primarily due to 1.3 year payback for averaged wind speeds. There are many other incentives that could possibly provide additional funding which would reduce the payback period further, and possibly eliminate the cost of the turbine installation completely.

Because the School District does not have a large area for installation of a larger wind turbine at any of the 8 locations surveyed for the audit, a small 2.5kW wind turbine was chosen. A turbine of this size could be installed in most locations. Depending on area available, and funding, the School District may choose to install more than 1 wind turbine on the premises.

Utilizing the NASA Surface Meteorology wind mapping tool, it was determined that the local average wind speeds for Teaneck, NJ ranged from 9.01 mph to 13.02 mph, or 4.03 m/s to 4.5m/s at 20 meters above the ground. In general, around 7 mph of average wind speed, as determined over the course of a year, is necessary to “fuel” the turbine. These values fall within the range of feasibility for installation of a new wind turbine system.

For the purposes of this feasibility analysis, CDM chose a 2.5kW Wind Energy Solutions (WES) Tulipo wind turbine. This turbine size is used most often for small commercial applications. Power Curve data was determined through the use of the product specification sheets on vendor websites. Actual turbine size, height, location, and manufacturer should be determined upon design of a wind turbine system.

The estimated wind speed data, associated wind probability distribution function (weibull value), turbulence losses, and other relevant data were then incorporated into Wind Cad to estimate the annual output for the wind turbine. Refer to Appendix J for Wind Cad Modeling.

In order to determine simple payback analysis of the proposed wind turbine, CDM used the industry standard of \$3-\$8/W to compute total cost of the wind turbine. For this analysis, CDM used \$7/W. This figure includes Overhead & Profit values. By installing the proposed wind turbine, the BOE will offset between \$282.3 and \$736 per year in utility costs per facility based on the minimum and maximum average local wind speeds. In addition, Renewable Energy Credits (REC's) are obtainable for renewable power and incentives are available through the Renewable Energy Incentive Program (REIP); refer to Section 7 for a more in depth explanation.

This simple payback calculation takes into account the incentive provided for wind turbines through the REIP program. For the first 16,000 kWh of production, the incentive is \$3.20/kWh. For production between 16,000 kWh - 750,000 kWh the REIP program incentive is \$0.50/kWh. CDM used this incentive as an upfront deduction from the Engineer's Opinion of Probable Cost. In addition, in order to benefit from the REIP incentive, the BOE must purchase a wind turbine on the approved NJ Clean Energy list. CDM chose the WES Tulipo wind turbine for this analysis as it is approved by the NJ Clean Energy program and is the appropriate size for smaller commercial installations and the limited area available on the site. Refer to the NJ Clean Energy website for more information.

Table 4.3-3 includes a simple payback analysis for the installation of one wind turbine energy system. Refer to Appendix K for a more detailed wind turbine financing spreadsheet, including utility cost avoidance and REC's.

<b>Table 4.3-3: Simple Payback Analysis for Wind Turbine Energy System</b>			
<b>Parameter</b>	<b>Wind Turbine (Minimum Site Wind Speed – 9.01 mph)</b>	<b>Wind Turbine (Maximum Site Wind Speed – 13.02 mph)</b>	<b>Wind Turbine (Average Site Wind Speed – 11.2 mph)</b>
Engineer's Opinion of Probable Cost	\$21,895	\$21,895	\$21,895
Renewable Energy Incentive Program**	-\$12,214	-\$21,895	-\$20,304
Total Cost	\$9,681	\$0	\$1,591
1 <sup>st</sup> Year Production	3,817 kWh	8,316 kWh	6,345 kWh
Annual Estimated Electric Savings	\$643.2	\$1,401.2	\$1,069.1
Annual Estimated REC Revenue	\$95	\$208	\$159
<b>Project Simple Payback</b>	<b>13.1 Years</b>	<b>0 Years</b>	<b>1.3 Years</b>
Annual Return On Investment (ARO I)	3.65%	0	74.15%



<b>Table 4.3-3: Simple Payback Analysis for Wind Turbine Energy System</b>			
<b>Parameter</b>	<b>Wind Turbine (Minimum Site Wind Speed – 9.01 mph)</b>	<b>Wind Turbine (Maximum Site Wind Speed – 13.02 mph)</b>	<b>Wind Turbine (Average Site Wind Speed – 11.2 mph)</b>
Lifetime Energy Savings (15 years)**	\$23,827.2	\$51,907	\$39,604.6
Internal Rate of Return (IRR)	7.82%	0	80.26%
Net Present Value (NPV)	\$6,625.7	\$35,483.5	\$25,502.4

\*Refer to Appendix J for Wind Cad Modeling

\*\*REIP incentive is calculated for only the first year and is applied as a deduction.

Based on the simple payback model, summarized in Table 4.3-3, it would benefit the School District to further investigate the installation of a wind energy system for all 8 sites. This is primarily based on the initial upfront capital investment required for a wind turbine energy system installation and the 1.3 year average wind speed payback period.

It should be noted that CDM used only REC values, utility cost avoidance factors, and the REIP incentive in determining simple payback periods. As stated above, other incentives and financial programs such as Power Purchase Agreements are available to help finance this installation. For example, if a Power Purchase Agreement is completed, the private company financing the project would benefit from the 30% tax credit. Other incentives such as CREB's and first year usage incentives could be available to the School District in lowering the payback period. Refer to [www.dsireusa.org](http://www.dsireusa.org) for an extensive listing of possible incentives for the New Jersey area.

It should also be noted that the wind turbine represented above is for feasibility purposes only. If the BOE decides to install a wind turbine, different mounting heights, turbine sizes, and manufacturers should be considered. In addition, permits may be required for installation according to local zoning laws. The FAA must also be notified in order to give clearance for the tower, and for installation of aviation safety lights if necessary.

### 4.3.3 Ground Source Heat Pumps

Geothermal systems utilize the constant temperature of the earth throughout the year (at depths from 5 ft. to 1,000 ft. the earth temperature remains at 53 deg. F) as the primary source of energy for the heating/cooling and domestic hot water production. Additionally, since the earth is maintained at a constant temperature from heat absorbed from the sun this energy is considered a “renewable resource,” and therefore is not as reliant on existing supplies of fossil fuels

Even though this application requires significantly higher up-front costs, it has several advantages over conventional HVAC systems such as substantially lower operating and maintenance costs. The life span of the system is longer than conventional heating and cooling systems. Most loop fields are warranted for 25 to 50 years and are

expected to last at least 50 to 100 years. However it is important to note that geothermal systems are more difficult to install in existing facilities and require higher capital cost due to having to complete significant infrastructure changes. Therefore, installation of a geothermal system is not recommended at any of the Teaneck BOE facilities at this point.

## 4.4 Additional Measures

As discussed in Section 2, it may be possible to reduce the plug load of the buildings even further with the implementation of smart strips and energy star appliances. Smart Strips save energy by electronically unplugging all of the devices that are plugged into the “Automatically Switched outlets” when the device plugged into the control outlet is turned off. It is important to note that CDM is not suggesting that computers be plugged into the automatically switched off outlets, as there would be potential for the computers to be shut off mid-operation. There are a vast amount of computer peripherals that are typically left on after a computer is shut off, including monitors, scanners, printers and DSL/Cable modems. These peripherals can be plugged into the automatic outlets.

A standard Smart Strip has one ‘control’ outlet, six (6) outlets that are automatically switched off when the control device is and three (3) outlets that are always hot. An example of how the BOE can implement the use of Smart Strips within appropriate computer stations at the Teaneck High School Library is to plug a computer into the control outlet, five (5) monitors and a personal printer (8 W in standby mode) into the automatic outlets and three (3) computers into the always hot outlets. An LCD monitor can use up to 34W; in standby mode the monitor utilizes 1 – 2W. A CRT monitor typically utilizes around 75W. The following table 4.5-1 summarizes the payback of a Smart Strip, assuming 5 LCD monitors and 1 printer are automatically powered down that would otherwise been left on 8 hours/day and in standby mode 16 hours/day, 5 days/week for 9 months.

**Table 4.4-1: Simple Payback**

Smart Strip Classroom Application Example	
Predicted Annual Savings – 5 LCD monitors, 1 printer (kWh)	611
*Total Annual Savings	\$97
Initial Capital Cost	\$40
<b>Simple Payback (months)</b>	<b>5.0</b>
Lifetime Energy Savings (15 years)	\$1,804
Net Present Value (NPV)	\$1,452

\*Aggregate Cost of \$.1589/kWh taken from the Teaneck High School

The following Table 4.4-2 summarizes other applications for the Smart Strip that may be applicable throughout the buildings:

**Table 4.4-2 Applications for Smart Strips**

Control Outlet	Switched Outlets
Computer	Monitors, printers, scanners, lamps
TV	VCR, DVD player, cable box
Lamp	Stereo, space heater

The BOE should continue to implement Energy Star appliances. This is recommended on an 'as-needed' basis.

In addition to replacing old appliances with Energy Star appliances, the following two maintenance procedures can work to save the energy consumed by the refrigerators. One is cleaning dirty condenser coils, twice a year. A refrigerator's condenser coils and cooling fins are located either under the unit behind a grille in the front or on the back of the appliance. The coils can be cleaned with a brush or vacuum cleaner hose. The second source of wasted energy associated with a refrigerator is the door seal. Realignment of the door or replacing a no longer airtight door seal will work to improve energy efficiency.

It may also be considered that the 'Vending Misers' be purchased and utilized for vending machines throughout the schools. A 'Vending Miser' powers down a vending machine when the surrounding area is unoccupied and automatically repowers when the area is occupied, utilizing an infrared sensor. Similarly to occupancy sensors on lighting fixtures; however, the vending miser also monitors the ambient temperature while the vending machine is powered down and uses this as sort of an internal thermostat to power up the machine and ensure that the drinks remain cold. The implementation of a 'Vending Miser' also reduces maintenance costs and extends the life of the machine, by reducing the number of compressor cycles. A 'Vending Miser' is a \$180 investment, but has been found to reduce power consumption of a cold drink vending machine by an average of 46%.

# Section 5

## Evaluation of Energy Purchasing and Procurement Strategies

### 5.1 Energy Deregulation

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law and the deregulation of the market allowed all consumers to shop for their electric supplier. The intent was to create a competitive market for electrical energy supply. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party supplier. Energy deregulation in New Jersey increased the energy buyers' options by separating the function of electricity distribution from that of electricity supply.

To sell electric generation service in New Jersey, electric power suppliers must be licensed by the New Jersey Board of Public Utilities (NJ BPU). They must also be registered with the local public utility (PSE&G) to sell electric service in that utility's service areas. The following suppliers are licensed with the NJ BPU and are registered to sell electric service in the PSE&G service territory:

- Amerada Hess Corp
- BOC Energy Services
- Con Edison Solutions, Inc.
- Constellation New Energy, Inc.
- Direct Energy, LLC.
- First Energy Solutions Corp.
- Glacial Energy
- Integrys Energy Service
- Liberty Power
- Pepco Energy Services, Inc.
- PP&L Energy Plus, LLC.
- Reliant Energy Solutions East, LLC.
- Sempra Energy Solutions
- South Jersey Energy
- Strategic Energy LLC
- Suez Energy Resources NA, Inc
- UGI Energy Services

As noted in Section 3, the Board is currently benefiting from the deregulation of the market and is utilizing South Jersey Energy as their third party supplier. It could possibly benefit the Board to obtain price quotes from other third party suppliers.

## 5.2 Demand Response Program

A Demand Response Program is another opportunity for energy cost savings. Demand Response is a program through which a business can make money on reducing their electricity use when wholesale electricity prices are high or when heavy demand causes instability on the electric grid, which can result in voltage fluctuations or grid failure. Demand Response is an energy management program that compensates the participant for reducing their energy consumption at critical times. Demand Response is a highly efficient and cost efficient means of reducing the potential for electrical grid failure and price volatility and is one of the best solutions to the Mid-Atlantic region's current energy challenges.

The program provides at least two hours advance notice before curtailment is required. There is typically one event a year that lasts about three hours, and since this happens only in summer months, when demand for electricity is at its highest, it may better facilitate the District's involvement. This as a result of summer occupancy requirements, although, energy curtailment in discretionary.

Participation in Demand Response is generally done through companies known as Curtailment Service Providers, or CSPs, who are members of Pennsylvania New Jersey Maryland (PJM) Interconnection. There is no cost to enroll in the program and participation is voluntary, for instance, you can choose when you want to participate. In most cases, there is no penalty for declining to reduce your electricity use when you're asked to do so. The event is managed remotely by notifying your staff of the curtailment request and then enacting curtailment through your Building Management System.

CSPs will share in a percentage of your savings, which may differ among various CSPs, since there may be costs associated with the hardware and /or software required for participation, so it is recommended that a number of CSPs be contacted to review their offers.

# Section 6

## Ranking of Energy Conservation and Retrofit Measures (ECRM)

### 6.1 ECRMs

The main objective of this energy audit is to identify potential Energy Conservation and Retrofit Measures and to determine whether or not the identified ECRM's are economically feasible to warrant the cost for planning and implementation of each measure. Economic feasibility of each identified measure was evaluated through a simple payback analysis. The simple payback analysis consists of establishing the Engineer's Opinion of Probable Construction Cost estimates; O&M cost savings estimates, projected annual energy savings estimates and the potential value of New Jersey Clean Energy Rebates or Renewable Energy Credits, if applicable. The simple payback period is then determined as the amount of time (years) until the energy savings associated with each measure amounts to the capital investment cost.

As discussed in Section 3, aggregate unit costs for electrical energy delivery and usage, natural gas delivery and usage, and oil delivery and usage, which accounts for all demand and tariff charges at each complex, was determined and utilized in the simple payback analyses.

In general, ECRMs having a payback period of 20 years or less have been recommended and only those recommended ECRMs within Section 4 of the report have been ranked for possible implementation. The most attractive rankings are those with the lowest simple payback period.

Ranking of ECRMs has been broken down into the following categories:

- Lighting Systems
- HVAC Systems
- Solar
- Wind

#### 6.1.1 Lighting Systems

Table 6.1-1 includes the recommended ECRMs to provide energy savings for all building lighting systems, which include the installation of energy-efficient luminaires and occupancy sensors. A detailed discussion on building lighting systems is presented in Section 4.1.

<b>Table 6.1-1 Ranking of Energy Savings Measures Summary – Lighting System Retrofits</b>					
Location/Measure	Engineer's Opinion of Probable Cost	Incentives	Total Cost	Annual Fiscal Savings <sup>1</sup>	Simple Payback (Years)
<b>Teaneck High School - Press Box</b>	\$107.8	\$0	\$107.8	\$78.02	<b>1.4</b>
<b>Bryant Elementary School</b>	\$119,549	\$23,230	\$96,319	\$18,291.8	<b>5.3</b>
<b>Whittier Elementary School</b>	\$116,162.9	\$7,660	\$108,502.9	\$18,477.9	<b>5.9</b>
<b>Eugene Field Administration Building</b>	\$60,271.5	\$4,125	\$56,146.5	\$8,665.7	<b>6.5</b>
<b>Teaneck High School</b>	\$154,753.3	\$11,850	\$142,903.3	\$21,750.8	<b>6.6</b>
<b>Benjamin Franklin Middle School</b>	\$411,953.7	\$21,135	\$390,818.7	\$52,545.9	<b>7.4</b>
<b>Thomas Jefferson Middle School</b>	\$229,038.3	\$15,735	\$213,303.3	\$27,889.1	<b>7.6</b>
<b>Lowell Elementary School</b>	\$77,998.8	\$3,710	\$74,288.8	\$8,355	<b>8.9</b>
<b>Hawthorne Elementary School</b>	\$108,470.2	\$4,365	\$103,835.2	\$11,216	<b>9.3</b>

1. 'Total Cost' takes into account any applicable rebates.
2. 'Annual Fiscal Savings' takes into account maintenance costs savings.

### 6.1.2 HVAC Systems

Table 6.1-2 includes the recommended ECRM to provide energy savings for building HVAC systems, most of which provide a simple payback of less than 20 years. A detailed discussion on building HVAC systems is presented in Section 4.2.

<b>Table 6.1-2 Ranking of Energy Savings Measures Summary – HVAC System Upgrades</b>						
Building	Measure	Retrofit Cost	Incentives	Total Cost	Annual Fiscal Savings	Simple Payback (Years)
<b>Teaneck High School</b>	DW Heater	\$5,240	\$0	\$5,240	\$9,977	<b>0.5</b>
<b>Benjamin Franklin Middle School</b>	Boiler	\$104,127	\$6,000	\$98,127	\$33,637	<b>2.9</b>
<b>Thomas Jefferson Middle School</b>	Boiler	\$156,190	\$9,000	\$147,190	\$48,667	<b>3.1</b>
<b>Bryant Elementary School</b>	DDC BMS	\$40,915	\$0	\$40,915	\$11,347	<b>3.6</b>
<b>Whittier Elementary School</b>	DDC BMS	\$47,539	\$0	\$47,539	\$10,742	<b>4.4</b>
<b>Teaneck High School</b>	VFD	\$76,123	\$0	\$76,123	\$15,863	<b>4.8</b>
<b>Hawthorne Elementary School</b>	DDC BMS	\$42,584	\$0	\$42,584	\$7,560	<b>5.6</b>
<b>Eugene Field Administration Building</b>	DDC BMS	\$21,456	\$0	\$21,456	\$3,777	<b>5.7</b>
<b>Lowell Elementary School</b>	DDC BMS	\$40,629	\$0	\$40,629	\$7,109	<b>5.7</b>
<b>Bryant Elementary School</b>	Boiler	\$181,165	\$6,000	\$175,165	\$20,871	<b>8.4</b>



<b>Hawthorne Elementary School</b>	Boiler	\$181,165	\$6,000	\$175,165	\$17,739	<b>9.9</b>
<b>Lowell Elementary School</b>	Boiler	\$222,990	\$6,000	\$216,990	\$21,871	<b>9.9</b>
<b>Eugene Field Administration Building</b>	Boiler	\$104,127	\$6,000	\$98,127	\$7,017	<b>14.0</b>
<b>Whittier Elementary School</b>	Boiler	\$222,990	\$6,000	\$216,990	\$11,170	<b>19.4</b>
<b>Hawthorne Elementary School</b>	AHU	\$17,753	\$790	\$16,963	\$681	<b>24.9</b>
<b>Teaneck High School</b>	AHU	\$130,008	\$3,160	\$126,848	\$3,460	<b>36.7</b>

1. 'Total Cost' takes into account any applicable rebates.
2. 'Annual Fiscal Savings' takes into account maintenance costs savings.

### 6.1.3 Solar Energy

Implementation of new solar energy systems have been evaluated to determine the economic feasibility for furnishing and installing such systems for eight buildings for the Teaneck School District. Based on the simple payback modeling performed, it would benefit the Board to further investigate installing the solar energy systems. This is primarily based on the initial upfront capital investment required for a solar energy system installation and the average 12.7 year payback period.

Two major factors influencing the project financial evaluation is the variance of the prevailing energy market conditions and Solar Renewable Energy Credit (SREC) rates, with the largest impact to the payback model being the SREC credit pricing. For the payback model, conservative estimates of the SREC's market value over a 15 year period were assumed, as discussed in Section 4.3.

Table 6.1-3 includes a simple payback analysis for the installation of seven solar energy systems for the Teaneck School District. Refer to Appendix E for a more detailed solar financing spreadsheet.

<b>Table 6.1-3 Ranking of Energy Savings Measures Summary – Solar Energy Systems</b>				
<b>Building &amp; Measure</b>	<b>Retrofit Cost</b>	<b>Annual SREC Credit</b>	<b>Annual Fiscal Savings</b>	<b>Simple Payback (Years)</b>
<b>Thomas Jefferson Middle School - PV Solar System</b>	\$6,307,156	\$424,598	\$119,883	<b>11.6</b>
<b>Whittier Elementary School - PV Solar System</b>	\$2,823,532	\$185,338	\$49,095	<b>12.0</b>
<b>Teaneck High School - PV Solar System</b>	\$3,249,778	\$214,613	\$54,127	<b>12.1</b>
<b>Benjamin Franklin Middle School - PV Solar System</b>	\$3,111,650	\$205,127	\$50,107.3	<b>12.2</b>
<b>Hawthorne Elementary School - PV Solar System</b>	\$1,791,339	\$114,446	\$29,953	<b>12.4</b>
<b>Lowell Elementary School - PV Solar System</b>	\$911,769	\$54,036	\$16,114	<b>13.0</b>



<b>Eugene Field Administration Building - PV Solar System</b>	\$802,762	\$46,550	\$12,183	<b>13.7</b>
<b>Bryant Elementary - PV Solar System</b>	\$684,710	\$38,442	\$10,549	<b>14.0</b>

### 6.1.4 Wind Power Generation

Implementation of a new on-site wind energy system has been evaluated to determine the economic feasibility for furnishing and installing such systems for the Teaneck School District. Based on the simple payback modeling performed, it would benefit the Board to further investigate installing the on-site wind energy systems at the nine surveyed locations. This is primarily based on the initial upfront capital investment required for a wind energy system installation and an acceptable payback period.

Three major factors influencing the project financial evaluation is the variance of the prevailing energy market conditions, Renewable Energy Certificate (REC) rates and the Renewable Energy Incentive Program, with the largest impact to the simple payback model being the REIP incentive.

Table 6.1-4, includes a summary of the wind energy ECRM for the Teaneck School District.

<b>Table 6.1-4: Simple Payback Analysis for Wind Turbine Energy System</b>			
<b>Parameter</b>	<b>Wind Turbine (Minimum Site Wind Speed – 9.01 mph)</b>	<b>Wind Turbine (Maximum Site Wind Speed – 13.02 mph)</b>	<b>Wind Turbine (Average Site Wind Speed – 11.2 mph)</b>
Engineer’s Opinion of Probable Cost	\$21,895	\$21,895	\$21,895
Renewable Energy Incentive Program**	<b>-\$12,214</b>	<b>-\$21,895</b>	<b>-\$20,304</b>
Total Cost	\$9,681	\$0	\$1,591
1 <sup>st</sup> Year Production	3,817 kWh	8,316 kWh	6,345 kWh
Annual Estimated Electric Savings	\$643.2	\$1,401.2	\$1,069.1
Annual Estimated REC Revenue	\$95	\$208	\$159
<b>Project Simple Payback</b>	<b>13.1 Years</b>	<b>0 Years</b>	<b>1.3 Years</b>

## Section 7

# Available Grants, Incentives and Funding Sources

### 7.1 Renewable Energy

#### 7.1.1 Renewable Energy Certificates (NJ BPU)

As part of New Jersey's Renewable Portfolio Standards (RPS), electric suppliers are required to have an annually-increasing percentage of their retail sales generated by renewable energy. Electric suppliers fulfill this obligation by purchasing renewable energy certificates (RECs) from the owners of solar generating systems. One REC is created for every 1,000 kWh (1 MWh) of renewable electricity generated. Although solar systems generate electricity and SRECs in tandem, the two are independent commodities and sold separately. The RPS, and creation of RECs, is intended to provide additional revenue flow and financial support for renewable energy projects in New Jersey. Class I RECs, which include electricity generation from wind, wave, tidal, geothermal and sustainable biomass typically trade at around \$25/MWh. RECs generated from solar electricity, or SRECs, trade at \$550/MWh due to supplemental funding from NJ PBU. The supplemental funding will decrease over time to \$350/MWh.

#### 7.1.2 Clean Energy Solutions Capital Investment Loan/Grant (NJ EDA)

NJ EDA in cooperation with NJ DEP is offering interest-free loans and grants for energy efficiency, combined heat and power (CHP) and renewable energy projects with total project capital equipment costs of at least \$1 million. The interest-free loans are available for up to \$5 million, a portion of which may be issued as a grant. The most recent round was closed as of October 2009, but new CESCO program updates will be posted at [www.njeda.com](http://www.njeda.com). For additional information, contact [CESCO@njeda.com](mailto:CESCO@njeda.com) or call 866-534-7789.

#### 7.1.3 Renewable Energy Incentive Program (NJ BPU)

The Renewable Energy Incentive Program (REIP) provides rebates for installing solar, wind, and sustainable biomass systems in Smart Growth regions. Rebates of \$1.00 per watt are available for solar electricity projects up to 50 kW in capacity. Wind systems can receive rebates up to \$3.20 per expected kWh produced. Sustainable biomass rebates start at \$4.00 per watt installed with a maximum incentive amount of 30 percent of project costs. REIP will give out \$53.25 million in rebates from 2009 - 2012. Project owners must complete the Pay for Performance Program, Direct Install or Local Municipal audit, or the rebate will be reduced by \$0.10 per watt. For more information on REIP, please see [www.njcleanenergy.com](http://www.njcleanenergy.com).

#### 7.1.4 Grid Connected Renewables Program (NJ BPU)

The New Jersey Grid Connected Renewables Program offers competitive incentives for wind and sustainable biomass electricity generation projects larger than 1

Megawatt (MW). Applications for the most recent round of funding, which totaled \$6 million, were due January 8, 2010. Requests for Proposals (RFPs) for the next round will be posted at [www.njcleanenergy.com](http://www.njcleanenergy.com) and [www.state.nj.us/bpu](http://www.state.nj.us/bpu). A total of roughly \$16 million is available for incentives under this program during 2010. Most of the incentives offered under this program will take the form of a payment for energy production (\$/MWh) once the project is operating. Incentives range up to \$58.49/MWh for publicly-owned wastewater biogas projects. Up to 10% of the incentive may be requested in the form of a lump grant to cover up-front costs such as financing fees, interconnection fees, project design, permitting, and construction costs.

### **7.1.5 Utility Financing Programs**

All four Electric Distribution Companies (EDCs) in New Jersey have developed long term contracting or financing programs for the development of solar energy systems. In all of the programs, Solar Renewable Energy Credits (SRECs) generated by the solar energy systems will be sold at auction to energy suppliers who are required to purchase a certain quantity of SRECs to meet their Renewable Portfolio Standard requirements.

### **7.1.6 Renewable Energy Manufacturing Incentive (NJ BPU)**

New Jersey's Renewable Energy Manufacturing Incentive (REMI) program provides rebates to purchase and install solar panels, inverters, and racking systems manufactured in New Jersey. Rebates for panels start at \$0.25 per watt and rebates for racking systems and inverters start at \$0.15 per watt for solar projects up to 500 kW in capacity. To be eligible for REMI, applicants must apply to either the Renewable Energy Incentive Program (REIP) or the SREC Registration Program (SRP).

### **7.1.7 Clean Renewable Energy Bonds (IRS)**

CREBs are 0% interest bonds typically issued for up to approximately \$3.0 million administered by the Internal Revenue Service (IRS). Last year, \$2.2 billion in CREBs was allocated to municipal entities to fund 610 renewable energy projects, including anaerobic digestion. IRS has been allocating funding for CREBs annually since 2005. Last year, IRS solicited applications starting in April, which were due in August. The IRS is expected to receive additional funding for CREBs and release another round of solicitations in 2010.

### **7.1.8 Qualified Energy Conservation Bonds (IRS)**

These IRS 0% interest bonds are very similar to CREBs except they are allocated based on state and county population. New Jersey was allocated \$90 million as part of the ARRA stimulus fund. QECEBs are typically distributed through municipal bond banks or state economic development agencies.

### **7.1.9 Global Climate Change Mitigation Incentive Fund (US EDA)**

The Economic Development Agency (part of the U.S. Department of Commerce) administers the GCCMIF to public works projects that reduce greenhouse gas emissions and creates new jobs. In FY 2009, \$15 million was allocated to the fund, and additional funding is expected to be allocated in FY 2010. Applications are due on a rolling basis. The program does not have a maximum grant amount but does limit the grant to 50 percent of the project cost.

### **7.1.10 Private Tax-Exempt Financing**

Similar to traditional municipal bond financing, there are many private financial service companies that offer a myriad of options for tax-exempt financing of municipal projects. The providers of these services suggest that this capital can be offered at competitive rates in an expedited timeframe and with fewer complications when compared to traditional municipal financing methods. Though these factors would need to be compared on a case-by-case basis, the one distinct advantage to private financing on the current project would likely be the flexibility to structure payments to meet budget needs with consideration given to the terms and conditions of existing loan and/or bond agreements. It should also be noted that, in many cases, the construction and long term financing can be rolled into a single private financing agreement. Also, in some instances, equipment manufacturers have the ability to offer competitive financing terms (e.g. Siemens Financial Services Corporation), though financing from these sources is generally contingent upon a substantial portion of the project cost (~20% to 30%) being for their respective equipment.

### **7.1.11 Performance Based Contracts (ESCOs)**

A second financing alternative for a project of this nature would be to enter into a Performance Based Contract with an Energy Services Company (ESCO). The premise of this type of contract is that it requires no initial municipal capital contributions in order to implement the project - instead relying on future operations cost savings and/or energy production, to fund the annual payments. Prior to entering into an agreement for the funding of the project, an ESCO would perform an energy audit and/or conceptual studies to confirm future energy cost savings or energy production inherent with the projects implementation and operation. The contract would then be formulated based on some measurable parameter(s) (sludge reduction, energy production, etc.) which would be verified by measurement throughout the contract duration. The savings in energy costs or energy production would then be used to pay back the capital investment of the project over the contract time period (typically on the order of 10-years or less). The ESCO would guarantee the agreed upon energy savings or energy production. If the project does not meet energy savings or production commitments, the ESCO pays the owner the equivalent difference.

With this funding alternative, the ownership and operation of the facility would be maintained by the original owner. A performance contract may also include ESCO operation and maintenance of the energy-related facilities if that were deemed

appropriate. Significant ESCO's with experience in this area include Siemens Building Technologies, Chevron and Johnson Controls. CDM has functioned in several roles on performance based contracts including being the owner's representative and, on different contracts, providing design-build services (as a subcontractor to the ESCO). We can provide additional experience-based information upon request.

### **7.1.12 Power Purchase Agreements (SPCs)**

More commonly referred to as a Build-Own-Transfer (BOT) agreement in the Water/Wastewater industry, a Power Purchase Agreement (PPA) also delivers a project with no initial capital contribution by the original owner. In this model, a Special Purpose Company (SPC) created by a developer, would own the energy production facilities. Within the framework of a PPA, a SPC will typically lease property from the owners for construction and operation of the new facilities. The funding and construction of the new facilities would be performed by the SPC who would then own and operate the facilities for the duration of the contract (typically 20 to 30 years). Throughout that period of time, the original owner would purchase power from the SPC at a pre-negotiated rate which would take into account the initial capital cost, operation and maintenance of the constructed facility, ancillary benefits of the project and investor returns on investment. For renewable energy, financial incentives may enable this financing approach to compete favorably with utility power tariffs. Incentives include state and local tax credits, renewable energy credits, and Federal energy production tax credits or energy investment tax credits. It is expected that a number of experienced companies and developers may be interested in a PPA for New Jersey municipal renewable energy projects.

## **7.2 Energy Efficiency**

### **7.2.1 Introduction**

New Jersey's Clean Energy Program (NJ CEP) promotes increased energy efficiency and the use of clean, renewable sources of energy including solar, wind, geothermal, and sustainable biomass. The results for New Jersey are a stronger economy, less pollution, lower costs, and reduced demand for electricity. NJCEP offers financial incentives, programs, and services for residential, commercial, and municipal customers.

NJCEP reduces the need to generate electricity and burn natural gas which eliminates the pollution that would have been caused by such electric generation or natural gas usage. The benefits of these programs continue for the life of the measures installed, which on average is about 15 years. Thus, the public receives substantial environmental and public health benefits from programs that also lower energy bills and benefit the economy.

### **7.2.2 New Jersey Smart Start Buildings Program (NJ BPU)**

The New Jersey Smart Start Buildings Program offers rebate incentives for several qualifying equipment such as high efficient premium motors and lighting, and lighting controls.

Incentive information and incentive calculation worksheets are provided for the various new equipment installation identified in this report and are included in Appendix G.

### **7.2.3 Pay for Performance Program (NJ BPU)**

Another program offered through the New Jersey Smart Start Program, is the Pay for Performance Program. Commercial, industrial and institutional buildings with an average annual peak demand over 200 kW are eligible for participation. In addition, local government agencies, which do not meet the 200 kW demand requirement and are not receiving Energy Efficiency and Conservation Block Grants are eligible.

Incentives are available for buildings that are able to present an Energy Reduction Plans that reduce the building's current energy consumption by 15% or more, in addition to incentives for installing the recommended measures and incentives for presenting the energy savings in a post-construction benchmarking report. No more than 50% of the total energy savings may be derived from lighting retrofits. In addition, the total energy savings of 15% may not come from the implementation of one energy savings measure. The incentive structure is provided in Appendix G.

### **7.2.4 Clean Energy Solutions Capital Investment Loan/Grant (NJ EDA)**

NJ EDA in cooperation with NJ DEP is offering interest-free loans and grants for energy efficiency, combined heat and power (CHP) and renewable energy projects with total project capital equipment costs of at least \$1 million. The interest-free loans are available for up to \$5 million, a portion of which may be issued as a grant. The most recent round was closed as of October 2009, but new CESCO program updates will be posted at [www.njeda.com](http://www.njeda.com). For additional information, contact [CESCI@njeda.com](mailto:CESCI@njeda.com) or call 866-534-7789.

### **7.2.5 Private Tax-Exempt Financing**

Similar to traditional municipal bond financing, there are many private financial service companies that offer a myriad of options for tax-exempt financing of municipal projects. The providers of these services suggest that this capital can be offered at competitive rates in an expedited timeframe and with fewer complications when compared to traditional municipal financing methods. Though these factors would need to be compared on a case-by-case basis, the one distinct advantage to private financing on the current project would likely be the flexibility to structure payments to meet budget needs with consideration given to the terms and conditions of existing loan and/or bond agreements. It should also be noted that, in many cases, the construction and long term financing can be rolled into a single private financing agreement. Also, in some instances, equipment manufacturers have the ability to offer competitive financing terms (e.g. Siemens Financial Services Corporation), though financing from these sources is generally contingent upon a substantial portion of the project cost (~20% to 30%) being for their respective equipment.



### 7.2.6 Performance Based Contracts (ESCOs)

Another financing option would be to enter into a Performance Based Contract with an Energy Services Company (ESCO). The premise of this type of contract is that it requires no initial municipal capital contributions in order to implement the project - instead relying on future operations cost savings and/or energy production, to fund the annual payments. Prior to entering into an agreement for the funding of the project, an ESCO would perform an energy audit and/or conceptual studies to confirm future energy cost savings inherent with the projects implementation and operation. The contract would then be formulated based on some measurable parameter(s) (sludge reduction, energy production, etc) which would be verified by measurement throughout the contract duration. The savings in energy costs would then be used to pay back the capital investment of the project over the contract time period (typically on the order of 10-years or less). The ESCO would guarantee the agreed upon energy savings. If the project does not meet energy savings or production commitments, the ESCO pays the owner the equivalent difference.

With this funding alternative, the ownership and operation of the facility would be maintained by the original owner. A performance contract may also include ESCO operation and maintenance of the energy-related facilities if that were deemed appropriate. Significant ESCO's with experience in this area include Siemens Building Technologies, Chevron and Johnson Controls. CDM has functioned in several roles on performance based contracts including being the owner's representative and, on different contracts, providing design-build services (as a subcontractor to the ESCO). We can provide additional experience-based information upon request.

APPENDIX A


UTILITY BILL INFORMATION




Electric Bills - Teaneck Bryant							
			Account #				
			4136514905				
Service	Month	Year	PSE&G	Total KWH	Demand KW	Cost Per KWH	Cost Per Demand KW
			Electric Charges Meter #: 728001215				
Jun 14 - Jul 16	Jul	2007	\$4,429.27	21520.00	104.00	0.205821	42.58913
Jul 16 - Aug 14	Aug	2007	\$2,965.03	14480.00	47.20	0.204767	62.81843
Aug 14 - Sep 13	Sep	2007	\$3,598.19	14560.00	104.00	0.247128	34.59798
Sept 13 - Oct 12	Oct	2007	\$3,602.04	24480.00	108.00	0.147142	33.35222
Oct 12 - Nov 12	Nov	2007	\$3,087.09	23840.00	87.20	0.129492	35.40241
Nov 12 - Dec 13	Dec	2007	\$5,282.47	44000.00	95.20	0.120056	55.48813
Dec 13 - Jan 15	Jan	2008	\$6,374.14	48880.00	93.60	0.130404	68.09979
Jan 15 - Feb 14	Feb	2008	\$3,754.28	29440.00	88.00	0.127523	42.66227
Feb 14 - Mar 14	Mar	2008	\$2,615.85	18880.00	90.40	0.138551	28.93639
Mar 14 - Apr 16	Apr	2008	\$3,676.80	29040.00	93.60	0.126612	39.28205
Apr 16 - May 14	May	2008	\$6,161.83	47120.00	92.80	0.130769	66.39903
May 14 - Jun 13	Jun	2008	\$4,446.94	24000.00	100.80	0.185289	44.11647
Jun 13 - Jul 15	Jul	2008	\$4,678.91	21520.00	104.00	0.217421	44.98952
Jul 15 - Aug 13	Aug	2008	\$3,737.35	14480.00	104.00	0.258104	35.93606
Aug 13 - Sep 12	Sep	2008	\$4,315.38	18160.00	106.40	0.237631	40.55808
Sept 12 - Oct 13	Oct	2008	\$4,221.04	26160.00	108.00	0.161355	39.0837
Oct 13 - Nov 11	Nov	2008	\$6,912.90	43680.00	89.60	0.158262	77.1529
Nov 11 - Dec 12	Dec	2008	\$3,713.20	26080.00	86.40	0.142377	42.97685
Dec 12 - Jan 8	Jan	2009	\$3,147.88	20720.00	86.4	0.151925	36.4338
Jan 8 - Feb 6	Feb	2009	\$3,623.28	23840.00	88.8	0.151983	40.8027
Feb 6 - Mar 4	Mar	2009	\$2,910.72	16960.00	90.4	0.171623	32.19823
Mar 4 - Apr 7	Apr	2009	\$3,451.19	22160.00	90.4	0.15574	38.17688
Apr 7 - May 8	May	2009	\$4,574.80	31520.00	180.80	0.14514	25.3031
May 8 - Jun 10	Jun	2009	4726.13	25760.00	100	0.183468	47.2613
Jun 10 - Jul 13	Jul	2009	\$4,200.33	22000.00	100.0	0.190924	42.0033
Jul 13 - Aug 11	Aug	2009	\$3,220.69	14960.00	100.0	0.215287	32.2069
Aug 11 - Sep 11	Sep	2009	\$3,823.63	19200.00	100.0	0.199147	38.2363
Sept 11 - Oct 13	Oct	2009	\$3,538.70	23600.00	91.2	0.149945	38.80154
Oct 13 - Nov 10	Nov	2009	\$3,105.01	20400.00	91.2	0.152206	34.04616
Nov 10 - Dec 11	Dec	2009	\$3,914.26	26480.00	88.8	0.147819	44.0795

Month	Combined (KWH)	Demand (KW)
January	25080	87
February	21360	90
March	23000	92
April	34640	92
May	27760	141
June	23640	102
July	18240	102
August	16560	103
September	22680	104
October	33640	90
November	23240	89
December	23600	88
<b>Total</b>	<b>293440</b>	<b>1179</b>

Electrical Usage





Electrical Demand





Electric Bills - Teaneck Benjamin Franklin							
			Account #				
			4125119805				
			PSE&G Electric				
			Meter #:				
			778015617	Total KWH	Demand KW	Cost Per KWH	
Service	Month	Year				Cost Per Demand KW	
Jun 12 - Jul 12	Jul	2007	\$13,075.10	65880.00	288.00	0.198468427	45.39965278
Jul 12 - Aug 10	Aug	2007	\$13,075.10	65880.00	288.00	0.198468427	45.39965278
Aug 10 - Sep 11	Sep	2007	\$12,037.64	60960.00	244.80	0.197467848	49.17336601
Sept 11 - Oct 10	Oct	2007	\$11,141.34	73680.00	309.60	0.151212541	35.98624031
Oct 10 - Nov 8	Nov	2007	\$9,853.94	75600.00	256.80	0.130343122	38.3720405
Nov 8 - Dec 11	Dec	2007	\$10,585.98	82320.00	266.40	0.128595481	39.73716216
Dec 11 - Jan 11	Jan	2008	\$9,828.52	75120.00	264.00	0.130837593	37.22924242
Jan 11 - Feb 11	Feb	2008	\$10,978.33	84000.00	288.00	0.130694405	38.11920139
Feb 11 -Mar 12	Mar	2008	\$10,335.69	77280.00	283.20	0.133743401	36.49608051
Mar 12 - Apr 11	Apr	2008	\$10,498.71	80880.00	273.60	0.129806009	38.37247807
Apr 11 - May 12	May	2008	\$8,934.95	67680.00	264.00	0.132017583	33.84450758
May 12 - Jun 11	Jun	2008	\$12,864.08	71520.00	276.00	0.17986689	46.60898551
Jun 11 - Jul 11	Jul	2008	\$13,496.84	62400.00	276.00	0.216295513	48.9015942
Jul 11 - Aug 11	Aug	2008	\$12,203.32	58560.00	196.80	0.208390027	62.00873984
Aug 11 - Sep 10	Sep	2008	\$13,873.33	64560.00	280.80	0.214890489	49.40644587
Sept 10 - Oct 10	Oct	2008	\$14,174.78	82280.00	280.80	0.172274915	50.47998575
Oct 10 - Nov 7	Nov	2008	\$11,540.32	75840.00	271.20	0.152166667	42.55280236
Nov 7 - Dec 10	Dec	2008	\$10,732.95	71520.00	261.60	0.150069141	41.02807722
Dec 10 - Jan 6	Jan	2009	\$10,732.95	71520.00	261.60	0.150069141	41.02807722
Jan 6 - Feb 3	Feb	2009	\$11,508.90	75120.00	266.4	0.153206869	43.20157658
Feb 3 -Mar 3	Mar	2009	\$11,006.90	67680.00	268.8	0.162631501	40.94828869
Mar 4 - Apr 3	Apr	2009	\$12,201.91	80160.00	271.2	0.152219436	44.99229351
Apr 3 - Jun 8	May/Jun	2009	\$7,762.00	75000.00	180.6	0.103493267	42.97893134
Jun 8 - Jul 9	Jul	2009	\$7,762.00	75000.00	180.60	0.103493333	42.97895903
Jul 9 - Aug 7	Aug	2009	\$9,248.35	53280.00	184.8	0.173580143	50.04518398
Aug 7 - Sep 9	Sep	2009	\$10,376.88	55680.00	256.8	0.186366379	40.40841121
Sept 9 - Oct 8	Oct	2009	\$9,778.12	66240.00	264.0	0.147616546	37.03833333
Oct 8 - Nov 6	Nov	2009	\$12,153.43	83820.00	266.4	0.144994393	45.62098348
Nov 6 - Dec 9	Dec	2009	\$9,927.06	67440.00	256.8	0.147198399	38.6567757

Month	Combined (KWH)	Demand (KW)
January	73320	275
February	79560	275
March	72480	271
April	80520	268
May	71340	228
June	73260	228
July	57840	191
August	57120	269
September	65400	272
October	83050	269
November	71640	259
December	71520	262
<b>Total</b>	<b>857050</b>	<b>3067</b>





Electric Bills - Teaneck Eugene							
			Account #				
			4137010005				
Service	Month	Year	PSE&G Electric Charges Meter #: 678004548	Total KWH	Demand KW	Cost Per KWH	Cost Per Demand KW
Jun 14 - Jul 16	Jul	2007	\$3,588.25	18480.00	76.20	0.194169	47.0899
Jul 16 - Aug 14	Aug	2007	\$3,568.01	18510.00	69.90	0.192761	51.04449
Aug 14 - Sep 14	Sep	2007	\$3,471.01	18000.00	68.10	0.192834	50.96931
Sept 14 - Oct 12	Oct	2007	\$5,617.05	32220.00	66.60	0.174334	84.34009
Oct 12 - Nov 12	Nov	2007	\$1,877.21	14370.00	48.60	0.130634	38.62572
Nov 12 - Dec 13	Dec	2007	\$1,954.01	15180.00	44.10	0.128723	44.30862
Dec 13 - Jan 15	Jan	2008	\$1,941.92	15030.00	46.20	0.129203	42.0329
Jan 15 - Feb 13	Feb	2008	\$1,859.87	14250.00	41.10	0.130517	45.25231
Feb 13 - Mar 14	Mar	2008	\$1,890.70	14520.00	39.00	0.130213	48.47949
Mar 14 - Apr 15	Apr	2008	\$1,920.69	14880.00	45.90	0.129079	41.8451
Apr 15 - May 14	May	2008	\$1,635.81	12540.00	38.40	0.130447	42.59922
May 14 - Jun 13	Jun	2008	\$2,932.33	14820.00	75.30	0.197863	38.94197
Jun 13 - Jul 15	Jul	2008	\$3,643.84	18090.00	65.10	0.201428	55.97296
Jul 15 - Aug 13	Aug	2008	\$3,889.80	19080.00	67.50	0.203868	57.62667
Aug 13 - Sep 12	Sep	2008	\$3,779.64	18420.00	65.10	0.205192	58.05899
Sept 12 - Oct 13	Oct	2008	\$2,348.99	13980.00	55.80	0.168025	42.09659
Oct 13 - Nov 11	Nov	2008	\$2,059.24	13320.00	48.90	0.154598	42.11125
Nov 11 - Dec 12	Dec	2008	\$2,081.46	14130.00	39.60	0.147308	52.56212
Dec 12 - Jan 8	Jan	2009	\$1,791.56	11340.00	41.1	0.157986	43.59027
Jan 8 - Feb 5	Feb	2009	\$2,137.85	13860.00	42.3	0.154246	50.54019
Feb 5 - Mar 5	Mar	2009	\$2,106.77	13080.00	40.5	0.161068	52.01901
Mar 6 - Apr 7	Apr	2009	\$2,292.03	15120.00	40.2	0.151589	57.01567
Apr 7 - May 8	May	2009	\$2,200.59	14760.00	113.40	0.149091	19.40556
May 8 - Jun 10	Jun	2009	2532.68	14430.00	45.6	0.175515	55.54123
Jun 10 - Jul 13	Jul	2009	\$2,969.12	16350.00	60.6	0.181598	48.99538
Jul 13 - Aug 11	Aug	2009	\$3,044.94	16470.00	65.4	0.184878	46.55872
Aug 11 - Sep 11	Sep	2009	\$3,496.48	18840.00	75.3	0.185588	46.434
Sept 11 - Oct 12	Oct	2009	\$1,980.83	13110.00	54.0	0.151093	36.68204
Oct 12 - Nov 10	Nov	2009	\$1,958.58	13440.00	37.5	0.145728	52.2288
Nov 10 - Dec 11	Dec	2009	\$2,051.94	14130.00	37.5	0.145219	54.7184

Month	Combined (KWH)	Demand (KW)
January	13185	44
February	14055	42
March	13800	40
April	15000	43
May	13650	76
June	14625	60
July	17640	67
August	18020	68
September	18420	70
October	19770	59
November	13710	45
December	14480	40
<b>Total</b>	<b>186355</b>	<b>653</b>





Electric Bills - Teaneck Hawthorne							
			Account #				
			4134110505				
Service	Month	Year	PSE&G Electric Charges Meter #: 678004502	Total KWH	Demand KW	Cost Per KWH	Cost Per Demand KW
Jun 14 - Jul 16	Jul	2007	\$6,153.35	32220.00	127.20	0.190979	48.37539
Jul 16 - Aug 14	Aug	2007	\$4,783.47	23880.00	91.20	0.200313	52.45033
Aug 14 - Sep 13	Sep	2007	\$6,283.68	31440.00	142.20	0.199863	44.18903
Sept 13 - Oct 12	Oct	2007	\$4,696.80	32400.00	135.00	0.144963	34.79111
Oct 12 - Nov 12	Nov	2007	\$4,387.28	33660.00	140.40	0.130341	31.24843
Nov 12 - Dec 13	Dec	2007	\$4,846.73	38340.00	125.40	0.126414	38.65016
Dec 13 - Jan 15	Jan	2008	\$4,505.35	35040.00	127.20	0.128577	35.41942
Jan 15 - Feb 13	Feb	2008	\$4,661.49	36120.00	118.80	0.129056	39.23813
Feb 13 - Mar 14	Mar	2008	\$4,498.91	34200.00	125.40	0.131547	35.87648
Mar 14 - Apr 15	Apr	2008	\$4,600.79	36120.00	120.00	0.127375	38.33992
Apr 15 - May 14	May	2008	\$3,645.67	27480.00	115.80	0.132666	31.48247
May 14 - Jun 13	Jun	2008	\$5,819.44	32100.00	123.00	0.181291	47.31252
Jun 13 - Jul 15	Jul	2008	\$6,832.47	33660.00	127.20	0.202985	53.71439
Jul 15 - Aug 13	Aug	2008	\$5,835.50	27960.00	113.40	0.208709	51.45944
Aug 13 - Sep 12	Sep	2008	\$6,125.60	28020.00	123.60	0.218615	49.55987
Sept 12 - Oct 13	Oct	2008	\$4,989.20	30540.00	118.20	0.163366	42.20981
Oct 13 - Nov 11	Nov	2008	\$4,736.58	31740.00	123.60	0.149231	38.32184
Nov 11 - Dec 12	Dec	2008	\$5,221.86	36540.00	130.20	0.142908	40.10645
Dec 12 - Jan 8	Jan	2009	\$4,061.86	25920.00	128.4	0.156708	31.63442
Jan 8 - Feb 5	Feb	2009	\$4,741.09	31260.00	117	0.151666	40.52214
Feb 5 - Mar 4	Mar	2009	\$4,646.81	29100.00	118.2	0.159684	39.31311
Mar 4 - Apr 7	Apr	2009	\$5,413.21	36660.00	118.2	0.14766	45.79704
Apr 7 - May 8	May	2009	\$5,187.41	35340.00	232.80	0.146786	22.28269
May 8 - Jun 10	Jun	2009	6081.59	34140.00	116.4	0.178137	52.24734
Jun 10 - Jul 13	Jul	2009	\$6,541.38	37380.00	117.0	0.174997	55.90923
Jul 13 - Aug 11	Aug	2009	\$5,409.69	29220.00	117.0	0.185137	46.23667
Aug 11 - Sep 11	Sep	2009	\$5,338.53	28620.00	117.0	0.186531	45.62846
Sept 11 - Oct 12	Oct	2009	\$5,497.99	37140.00	126.0	0.148034	43.63484
Oct 12 - Nov 11	Nov	2009	\$4,613.08	30600.00	126.0	0.150754	36.61175
Nov 11 - Dec 11	Dec	2009	\$5,251.87	35340.00	126.0	0.14861	41.68151

Month	Combined (KWH)	Demand (KW)
January	30480	128
February	33690	118
March	31650	122
April	36390	119
May	31410	174
June	33120	120
July	34420	124
August	27020	107
September	29360	128
October	33360	126
November	32000	130
December	36740	127
<b>Total</b>	<b>389640</b>	<b>1523</b>





Electric Bills - Teaneck Lowell							
			Account #				
			4125048606				
Service	Month	Year	PSE&G	Total KWH	Demand KW	Cost Per KWH	Cost Per Demand KW
			Electric Charges Meter #: 728001842				
Jun 12 - Jul 12	Jul	2007	\$4,396.01	20960.00	105.60	0.209733	41.62888
Jul 12 - Aug 10	Aug	2007	\$8,212.38	43520.00	68.80	0.188704	119.366
Aug 10 - Sep 11	Sep	2007	\$4,340.34	20800.00	97.60	0.20867	44.4707
Sept 11 - Oct 10	Oct	2007	\$3,710.60	25280.00	97.60	0.14678	38.01844
Oct 10 - Nov 8	Nov	2007	\$3,424.36	26720.00	94.40	0.128157	36.275
Nov 8 - Dec 11	Dec	2007	\$3,812.61	30240.00	92.80	0.126078	41.08416
Dec 11 - Jan 11	Jan	2008	\$3,412.68	26560.00	92.80	0.128489	36.77457
Jan 11 - Feb 11	Feb	2008	\$3,643.02	28480.00	89.60	0.127915	40.65871
Feb 11 - Mar 12	Mar	2008	\$3,340.92	25440.00	89.60	0.131325	37.28705
Mar 12 - Apr 11	Apr	2008	\$3,400.86	26400.00	94.40	0.12882	36.02606
Apr 11 - May 12	May	2008	\$2,794.23	20960.00	92.80	0.133313	30.11024
May 12 - Jun 11	Jun	2008	\$5,082.86	28800.00	110.40	0.176488	46.0404
Jun 11 - Jul 11	Jul	2008	\$4,509.53	20320.00	105.60	0.221926	42.70388
Jul 11 - Aug 11	Aug	2008	\$5,152.09	23840.00	110.40	0.216111	46.66748
Aug 11 - Sep 10	Sep	2008	\$2,899.54	8160.00	112.00	0.355336	25.88875
Sept 10 - Oct 14	Oct	2008	3752.96	23600	89.60	0.159024	41.88571
Oct 14 - Nov 7	Nov	2008	3752.96	23600	107.20	0.159024	35.00896
Nov 7 - Dec 10	Dec	2008	\$3,883.27	27520.00	91.20	0.141107	42.57971
Dec 10 - Jan 6	Jan	2009	\$3,117.26	20320.00	94.4	0.153408	33.02182
Jan 6 - Feb 3	Feb	2009	\$3,819.08	25540.00	96	0.149533	39.78208
Feb 3 - Mar 3	Mar	2009	\$3,541.97	22080.00	91.2	0.160415	38.83739
Mar 4 - Apr 3	Apr	2009	\$4,238.06	28640.00	96	0.147977	44.14646
Apr 3 - May 6	May	2009	\$3,686.04	23520.00	139.20	0.156719	26.48017
May 6 - Jun 8	Jun	2009	4479.9	24960.00	88	0.179483	50.90795
Jun 8 - Jul 9	Jul	2009	\$3,898.17	20800.00	88.0	0.187412	44.29739
Jul 9 - Aug 7	Aug	2009	\$2,369.91	8960.00	99.2	0.264499	23.89022
Aug 7 - Sep 9	Sep	2009	\$2,419.78	9280.00	99.2	0.260752	24.39294
Sept 9 - Oct 8	Oct	2009	\$4,057.81	27360.00	94.4	0.148312	42.98528
Oct 8 - Nov 6	Nov	2009	\$3,748.87	24160.00	126.4	0.155168	29.65878
Nov 6 - Dec 9	Dec	2009	\$3,755.89	25280.00	89.6	0.148572	41.91842

Month	Combined (KWH)	Demand (KW)
January	23440	94
February	27010	93
March	23760	90
April	27520	95
May	22240	116
June	26880	99
July	20693	100
August	25440	93
September	12747	103
October	25413	94
November	24827	109
December	27680	91
<b>Total</b>	<b>287650</b>	<b>1177</b>



Electric Bills - Teaneck Thomas Jefferson								
				Account #				
				4134015308				
				PSE&G Electric				
				Meter #:	Total KWH	Demand KW	Cost Per KWH	Cost Per
				778015616				Demand KW
Comments	Service	Month	Year					
	Jun 14 - Jul 16	Jul	2007	\$11,051.13	57840.00	216.00	0.191063797	51.16263889
	Jul 16 - Aug 14	Aug	2007	\$9,367.53	48000.00	158.40	0.195156875	59.13844697
	Aug 14 - Sep 14	Sep	2007	\$9,798.42	54960.00	230.40	0.178282751	42.52786458
	Sept 13 - Oct 12	Oct	2007	\$9,798.42	54960.00	230.40	0.178282751	42.52786458
	Oct 12 - Nov 12	Nov	2007	\$6,490.55	68640.00	228.00	0.094559295	28.46732456
	Nov 12 - Dec 13	Dec	2007	\$10,104.44	78960.00	232.80	0.127969098	43.40395189
	Dec 13 - Jan 15	Jan	2008	\$9,838.42	77520.00	235.20	0.126914603	41.83001701
	Jan 15 - Feb 13	Feb	2008	\$10,239.26	78720.00	244.80	0.1300719	41.82704248
	Feb 13 - Mar 15	Mar	2008	\$10,653.28	82560.00	252.00	0.129036822	42.27492063
	Mar 15 - Apr 15	Apr	2008	\$10,434.61	82800.00	244.80	0.12602186	42.62504085
	Apr 15 - May 14	May	2008	\$8,034.55	60720.00	216.00	0.132321311	37.19699074
	May 14 - Jun 13	Jun	2008	\$11,847.96	66960.00	230.40	0.17694086	51.4234375
	Jun 13 - Jul 15	Jul	2008	\$10,498.64	47760.00	230.40	0.219820771	45.56701389
	Jul 15 - Aug 14	Aug	2008	\$7,776.60	39600.00	86.40	0.196378788	90.00694444
	Aug 14 - Sep 12	Sep	2008	\$10,649.32	48720.00	218.40	0.218582102	48.76062271
	Sept 12 - Oct 13	Oct	2008	\$10,107.91	61200.00	216.00	0.165161928	46.79587963
	Oct 13 - Nov 11	Nov	2008	\$9,981.88	67440.00	223.20	0.148011269	44.72168459
	Nov 11 - Dec 12	Dec	2008	\$11,233.60	78480.00	244.80	0.143139653	45.88888889
	Dec 12 - Jan 8	Jan	2009	\$8,607.52	55920.00	247.2	0.153925608	34.82006472
	Jan 8 - Feb 5	Feb	2009	\$10,931.98	73440.00	244.8	0.148855937	44.65678105
	Feb 5 - Mar 4	Mar	2009	\$9,736.95	61200.00	235.2	0.15910049	41.39859694
	Mar 4 - Apr 7	Apr	2009	\$12,758.30	88800.00	240	0.14367455	53.15958333
	Apr 7 - May 8	May	2009	\$2,503.78	59760.00	244.80	0.041897256	10.22785948
	May 8 - Jun 10	Jun	2009	\$18,209.21	68400.00	247.2	0.26621652	73.66185275
UNMETERED ALSO	Jun 10 - Jul 13	Jul	2009	\$9,735.50	51840.00	244.8	0.187798997	39.76919935
UNMETERED ALSO	Jul 13 - Aug 11	Aug	2009	\$5,296.46	31920.00	76.8	0.165929198	68.96432292
UNMETERED ALSO	Aug 11 - Sep 11	Sep	2009	\$8,716.82	46080.00	218.4	0.189167101	39.91217949
UNMETERED ALSO	Sept 11 - Oct 12	Oct	2009	\$8,778.19	59280.00	232.8	0.148080128	37.70700172
UNMETERED ALSO	Oct 12 - Nov 10	Nov	2009	\$9,952.49	68400.00	235.2	0.14550424	42.3150085
UNMETERED ALSO	Nov 10 - Dec 17	Dec	2009	\$12,889.29	89520.00	237.6	0.143982239	54.24785354

Month	Combined (KWH)	Demand (KW)
January	66720	241
February	76080	245
March	71880	244
April	85800	242
May	60240	230
June	67680	239
July	52480	230
August	39840	107
September	49920	222
October	58480	226
November	68160	229
December	82320	238
<b>Total</b>	<b>779600</b>	<b>2695</b>









Electric Bills - Teaneck High School																		
Account #																		
4133848918 Athletic Field Lighting																		
4133559908 Scoreboard																		
4133897017																		
Service	Month	Year	PSEG Electric Charges Meter #: 72801489			PSEG Electric Charges Meter #: 72600588			PSEG Electric Charges Meter #: 778014249			PSEG Electric Charges Meter #: 778014249						
			Total KWH	Demand KW	Cost Per KWH	Total KWH	Demand KW	Cost Per KWH	Total KWH	Demand KW	Cost Per KWH	Total KWH	Demand KW	Cost Per KWH				
Jan 14 - Jul 16	Jul	2007	\$2,327.34	400.00	142.40	5.81835	16,346.9798	\$352.69	1210.00	11.30	0.291479339	31,211.0442	26,775.56	146299	479.5	0.178918243	54,5892005	
Jul 16 - Aug 14	Aug	2007	\$694.35	0.00	0.00	#DIV/0!	#DIV/0!	\$361.91	1277.00	11.10	0.283404231	32,6045455	25079.49	148920	348.1	0.168412503	72,0482137	
Aug 14 - Sep 13	Sep	2007	\$2,386.09	1860.00	136.80	7.3547779	17,44217836	\$295.52	762.00	11.00	0.387921522	26,8654455	22482.15	194867	523.1	0.115717166	42,9786476	
Sep 13 - Oct 12	Oct	2007	\$1,148.04	880.00	139.20	1.3065909	8,247413793	\$196.40	858.00	11.00	0.228904249	17,8545455	22489.93	218879	640.4	0.102520778	35,04094032	
Oct 12 - Nov 12	Nov	2007	\$1,099.88	2860.00	139.20	0.3715811	7,801487612	\$121.20	384.00	14.10	0.352325281	8,995746811	23012.63	189054	527.7	0.121751688	43,60916451	
Nov 12 - Dec 13	Dec	2007	\$819.81	320.00	139.20	2.5619063	5,889439655	\$94.33	69.00	14.70	1.367101449	6,417008081	24422.65	201873	500.5	0.120880217	48,79605035	
Dec 13 - Jan 16	Jan	2008	\$809.06	0.00	0.00	#DIV/0!	#DIV/0!	\$11.01	20.00	0.20	1.5505	155.05	21806.15	177381	553.1	0.122933967	39,42532996	
Jan 16 - Feb 13	Feb	2008	\$170.34	0.00	0.00	#DIV/0!	#DIV/0!	\$28.69	15.00	0.20	1.932666667	145.45	22704.3	183037	508.4	0.124056899	44,63813980	
Feb 13 - Mar 15	Mar	2008	\$170.50	0.00	0.00	#DIV/0!	#DIV/0!	\$29.18	19.00	0.20	1.535789474	145.9	21064.95	168216	496	0.125225603	42,46965726	
Mar 15 - Apr 15	Apr	2008	\$173.62	0.00	0.80	#DIV/0!	#DIV/0!	\$39.89	72.00	1.50	0.554027778	26,59333333	22113.75	180763	506.8	0.1223356	43,63407056	
Apr 15 - May 14	May	2008	\$170.50	0.00	0.00	#DIV/0!	#DIV/0!	\$69.25	117.00	7.80	0.591802042	8,878265128	20508.7	163874	626	0.125042492	32,56919351	
May 14 - Jun 13	Jun	2008	\$258.31	0.00	0.00	#DIV/0!	#DIV/0!	\$28.71	550.00	10.60	0.415858384	21,57641509	30933.14	188561	630.8	0.164048451	49,03795181	
Jun 13 - Jul 15	Jul	2008	\$299.46	822.00	10.90	0.3649066	27,4733945	\$1,992.07	320.00	141.60	6.23521875	14,06829096	28592.02	153476	596.6	0.187518167	47,92494133	
Jul 15 - Aug 13	Aug	2008	\$501.06	825.00	10.70	0.3649212	28,1384886	\$373.83	0.00	0.00	#DIV/0!	#DIV/0!	2113.71	107702	379.6	0.157895211	36,14781349	
Aug 13 - Sep 12	Sep	2008	\$282.83	697.00	10.70	0.4057819	26,43271028	\$373.83	0.00	0.00	#DIV/0!	#DIV/0!	28661.2	14253	596.2	0.20112881	48,56184344	
Sep 12 - Oct 13	Oct	2008	\$162.65	463.00	10.80	0.3512959	15,96018519	\$1,211.86	2400.00	136.80	0.504941667	8,858625731	25012.54	163339	631	0.152945414	39,63952456	
Oct 13 - Nov 11	Nov	2008	\$127.23	137.00	12.80	0.9298861	9,89894375	\$1,238.84	2880.00	137.60	0.430152778	9,00397674	20809.49	150165	528.7	0.13916839	40,13729595	
Nov 11 - Dec 13	Dec	2008	\$97.83	30.00	8.40	3.261	11,64642807	\$1,238.56	2880.00	139.20	0.428916667	8,89487686	2282	171453	497.5	0.133039365	49,87336688	
Dec 13 - Jan 8	Jan	2009	\$63.87	11.00	0.2	5.8063636	319.35	\$361.61	0.00	0.00	#DIV/0!	#DIV/0!	17733.86	127374	494.5	0.139226687	35,86220425	
Jan 8 - Feb 5	Feb	2009	\$63.81	9.00	0.2	7.29	319.05	\$332.34	0.00	0.00	#DIV/0!	#DIV/0!	2147.98	154999	492.7	0.13920123	43,73448346	
Feb 5 - Mar 4	Mar	2009	\$64.09	11.00	0.2	5.8203636	320.45	\$334.46	0.00	0.80	#DIV/0!	#DIV/0!	2147.18	147617	507.1	0.145209843	42,29378821	
Mar 4 - Apr 7	Apr	2009	\$63.58	7.00	0.2	9.0828571	317.9	\$335.46	0.00	0.80	#DIV/0!	#DIV/0!	419.325	29301.93	20995	886.1	0.142273458	29,71496806
Apr 7 - May 8	May	2009	\$73.73	94.00	0.40	0.7843617	184.325	\$33.99	480.00	0.80	0.041645833	54.9075	24106.1	171,669	1265.2	0.140421948	19,05139137	
May 8 - Jun 10	Jun	2009	\$236.69	278.00	10.7	0.7902518	20,5313757	\$331.25	0.00	140.80	#DIV/0!	#DIV/0!	3962.24	203986	638.5	0.166653815	31,30606562	
Jun 10 - Jul 13	Jul	2009	\$3161.25	0.00	140.8	#DIV/0!	#DIV/0!	\$213.79	256.00	11.20	0.905429688	20,6953571	32360.46	173605	580.5	0.186402811	55,74583979	
Jul 13 - Aug 11	Aug	2009	\$4.27	0.00	0.0	#DIV/0!	#DIV/0!	\$70.08	2.00	0.00	35.04	#DIV/0!	30030.14	158334	514.1	0.189662344	58,41303249	
Aug 11 - Sep 10	Sep	2009	\$608.54	2400.00	137.6	0.2355583	4,42252907	\$93.00	29.00	1.60	1.172413793	57.5	34364.05	182746	631.7	0.1382378	54,27812845	
Sep 10 - Oct 12	Oct	2009	\$4.27	0.00	0.0	#DIV/0!	#DIV/0!	\$168.13	397.00	11.90	0.423501259	14,12857143	28356.31	187777	609.1	0.15101056	56,4444098	
Oct 12 - Nov 10	Nov	2009	\$609.17	2320.00	138.4	0.2625733	4,401517341	\$137.62	186.00	11.50	0.739892473	11,96695652	23957.53	166579	554.5	0.141659693	42,56411139	
Nov 10 - Dec 11	Dec	2009	\$644.50	3280.00	140.8	0.1964939	4,57745873	\$125.30	307.00	10.70	1.171028037	11,71028037	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	

Month	Combined (KWH)	Demand (KW)
January	52174	524
February	169008	501
March	157912	502
April	393569	746
May	82021	940
June	196249	635
July	377460	551
August	138139	414
September	173375	582
October	390815	627
November	468599	534
December	186663	499
Total	1966429	7061



Month	Combined (KWH)	Demand (KW)
January	6	0
February	5	0
March	6	0
April	4	1
May	47	0
June	139	5
July	407	88
August	275	4
September	1486	95
October	448	50
November	4906	97
December	1210	86
Total	5836	446

Month	Combined (KWH)	Demand (KW)
January	10	0
February	8	0
March	10	1
April	36	1
May	29	4
June	275	76
July	595	155
August	426	4
September	264	4
October	1218	53
November	1137	54
December	1619	55
Total	5296	307



Electric Bills - Teaneck Whittier							
			Account #				
			4132112918				
Service	Month	Year	PSE&G Electric Charges Meter #: 778003529; 728007765	Total KWH	Demand KW	Cost Per KWH	Cost Per Demand KW
Jun 13 - Jul 13	2007	Jul	\$6,263.00	32400.00	126.00	0.193302	49.70635
Jul 13 - Aug 13	2007	Aug	\$6,263.00	32400.00	126.00	0.193302	49.70635
Aug 13 - Sep 12	2007	Sep	\$11,941.77	59000.00	126.00	0.202403	94.77595
Sept 12 - Oct 11	2007	Oct	\$5,416.70	38000.00	132.00	0.142545	41.03561
Oct 11 - Nov 13	2007	Nov	\$4,663.64	36600.00	122.00	0.127422	38.22656
Nov 13 - Dec 12	2007	Dec	\$4,353.56	33800.00	114.00	0.128804	38.18912
Dec 12 - Jan 14	2008	Jan	\$4,254.54	33000.00	112.00	0.128925	37.98696
Jan 14 - Feb 12	2008	Feb	\$4,305.88	33000.00	112.00	0.130481	38.44536
Feb 12 -Mar 15	2008	Mar	\$4,279.27	32600.00	110.00	0.131266	38.90245
Mar 15 - Apr 14	2008	Apr	\$4,199.55	32600.00	110.00	0.128821	38.17773
Apr 14 - May 13	2008	May	\$3,579.14	27000.00	108.00	0.132561	33.14019
May 13 - Jun 12	2008	Jun	\$4,969.34	27000.00	106.00	0.18405	46.88057
Jun 12 - Jul 16	2008	Jul	\$7,321.60	30000.00	116.00	0.244053	63.11724
Jul 29 - Sep 12	2008	Aug	4707.455	21800	126.00	0.215938	37.36075
Jul 29 - Sep 12	2008	Sep	4707.455	21800	126.00	0.215938	37.36075
Sept 12 - Oct 10	2008	Oct	\$3,681.05	19600.00	128.00	0.187809	28.7582
Oct 10 - Nov 10	2008	Nov	\$4,800.17	32600.00	108.00	0.147244	44.44602
Nov 10 - Dec 11	2008	Dec	\$4,986.79	35000.00	108.00	0.14248	46.17398
Dec 11 - Jan 7	2009	Jan	\$4,021.49	26200.00	112	0.153492	35.90616
Jan 7 - Feb 5	2009	Feb	4357.16	30800	110	0.141466	39.61055
Feb 5 -Mar 4	2009	Mar	\$4,472.06	28600.00	110	0.156366	40.65509
Mar 5 - Apr 6	2009	Apr	\$5,222.62	36000.00	110	0.145073	47.47836
Apr 6 - May 7	2009	May	\$4,619.44	31400.00	212.00	0.147116	21.78981
May 7 - Jun 9	2009	Jun	4407.32	23000.00	106	0.191623	41.57849
Jun 9 - Jul 10	2009	Jul	\$4,407.32	23000.00	106.00	0.191623	41.57849
Jul 10 - Aug 10	2009	Aug	\$6,179.14	34000.00	126.00	0.181739	49.04079
Aug 10 - Sep 10	2009	Sep	\$6,735.87	38000.00	124.00	0.17726	54.32153
Sept 10 - Oct 9	2009	Oct	\$5,039.76	34200.00	110.00	0.147361	45.816
Oct 9 - Nov 9	2009	Nov	\$4,120.16	27400.00	110.00	0.150371	37.456
Nov 9 - Dec 10	2009	Dec	\$5,724.05	39200.00	114.00	0.146022	50.21096


Month	Combined (KWH)	Demand (KW)
January	29600	112
February	31900	111
March	30600	110
April	34300	110
May	29200	160
June	25000	106
July	28467	116
August	29400	126
September	39600	125
October	30600	123
November	32200	113
December	36000	112
<b>Total</b>	<b>376867</b>	<b>1425</b>






Natural Gas Bills							
Teaneck Gas Account #4125119805: Benjamin Franklin							
Date	Year	Month	Meter 2258618	Total Supply	Total Delivery	Total Charge	Cost/Therm
Jun 12 - Jul 12	2007	Jul	450.826	\$448.85	\$148.67	\$597.52	\$1.33
Jul 12 - Aug 10	2007	Aug	443.719	\$406.69	\$146.47	\$553.16	\$1.25
Aug 10 - Sep 11	2007	Sep	486.361	\$403.01	\$159.59	\$562.60	\$1.16
Sept 11 - Oct 10	2007	Oct	462.805	\$377.47	\$151.76	\$529.23	\$1.14
Oct 10 - Nov 8	2007	Nov	492.189	\$452.98	\$161.62	\$614.60	\$1.25
Nov 8 - Dec 11	2007	Dec	579.783	\$579.78	\$189.58	\$769.36	\$1.33
Dec 11 - Jan 11	2008	Jan	553.524	\$548.70	\$182.21	\$730.91	\$1.32
Jan 11 - Feb 11	2008	Feb	560.291	\$570.14	\$184.87	\$755.01	\$1.35
Feb 11 - Mar 12	2008	Mar	544.112	\$609.68	\$179.99	\$789.67	\$1.45
Mar 12 - Apr 11	2008	Apr	528.990	\$640.11	\$168.63	\$808.74	\$1.53
Apr 11 - May 12	2008	May	508.122	\$673.37	\$162.38	\$835.75	\$1.64
May 12 - Jun 11	2008	Jun	484.697	\$709.31	\$155.35	\$864.66	\$1.78
Jun 11 - Jul 11	2008	Jul	435.086	\$678.14	\$140.46	\$818.60	\$1.88
Jul 11 - Aug 11	2008	Aug	465.652	\$692.74	\$149.63	\$842.37	\$1.81
Aug 11 - Sep 10	2008	Sep	319.463	\$375.70	\$105.77	\$481.47	\$1.51
Sept 10 - Oct 10	2008	Oct	483.440	\$525.11	\$154.96	\$680.07	\$1.41
Oct 10 - Nov 7	2008	Nov	549.878	\$545.40	\$191.28	\$736.68	\$1.34
Nov 7 - Dec 10	2008	Dec	574.97	\$536.18	\$196.07	\$732.25	\$1.27
Dec 10 - Jan 6	2009	Jan	689.29	\$654.55	\$253.49	\$908.04	\$1.32
Jan 6 - Feb 3	2009	Feb	647.52	\$563.43	\$235.36	\$798.79	\$1.23
Feb 3 - Mar 3	2009	Mar	603.31	\$426.40	\$216.67	\$643.07	\$1.07
Mar 4 - Apr 4	2009	Apr	615.74	\$403.92	\$201.21	\$605.13	\$0.98
Apr 4 - Jun 8	2009	May/Jun	638.95	\$368.48	\$210.15	\$578.63	\$0.91
Apr 4 - Jun 8	2009	May/Jun	638.95	\$368.48	\$210.15	\$578.63	\$0.91
Jun 8 - Jul 9	2009	Jul	481.57	\$283.31	\$161.74	\$445.05	\$0.92
Jul 9 - Aug 7	2009	Aug	417.986	\$253.30	\$142.21	\$395.51	\$0.95
Aug 7 - Sep 9	2009	Sep	295.274	\$159.71	\$104.73	\$264.44	\$0.90
Sept 9 - Oct 8	2009	Oct	439.066	\$231.63	\$150.81	\$382.44	\$0.87
Oct 8 - Nov 6	2009	Nov	586.75	\$365.46	\$209.21	\$574.67	\$0.98
Nov 6 - Dec 9	2009	Dec	209.33	\$143.34	\$75.43	\$218.77	\$1.05

Month	Average Therm Usage
January	621
February	604
March	574
April	572
May	574
June	483
July	435
August	402
September	415
October	511
November	417
December	455




Natural Gas Bills							
Teaneck Gas Account #4136514905: Bryant							
Date	Year	Month	Meter 2809405	Total Supply	Total Delivery	Total Charge	Cost/Therm
Jun 14 - Jul 16	2007	Jul	1.049	\$1.04	\$10.39	\$11.43	\$10.90
Jul 16 - Aug 14	2007	Aug	1.051	\$0.95	\$10.39	\$11.34	\$10.79
Aug 14 - Sep 13	2007	Sep	0.000	\$0.00	\$10.07	\$10.07	#DIV/0!
Sept 13 - Oct 12	2007	Oct	0.000	\$0.00	\$10.07	\$10.07	#DIV/0!
Oct 12 - Nov 12	2007	Nov	3.148	\$2.94	\$11.24	\$14.18	\$4.50
Nov 12 - Dec 13	2007	Dec	1.047	\$1.05	\$10.26	\$11.31	\$10.80
Dec 13 - Jan 15	2008	Jan	45.953	\$45.50	\$28.04	\$73.54	\$1.60
Jan 15 - Feb 14	2008	Feb	15.651	\$16.09	\$16.06	\$32.15	\$2.05
Feb 14 -Mar 14	2008	Mar	35.440	\$40.02	\$23.89	\$63.91	\$1.80
Mar 14 - Apr 16	2008	Apr	25.041	\$30.51	\$17.44	\$47.95	\$1.91
Apr 16 - May 14	2008	May	9.390	\$11.99	\$22.68	\$34.67	\$3.69
May 14 - Jun 13	2008	Jun	1.042	\$1.53	\$10.24	\$11.77	\$11.30
Jun 13 - Jul 15	2008	Jul	1.043	\$1.64	\$10.24	\$11.88	\$11.39
Jul 15 - Aug 13	2008	Aug	1.046	\$1.51	\$10.24	\$11.75	\$11.23
Aug 13 - Sep 12	2008	Sep	0.000	\$0.00	\$9.93	\$9.93	#DIV/0!
Sept 12 - Oct 13	2008	Oct	0.000	\$0.00	\$9.93	\$9.93	#DIV/0!
Oct 13 - Nov 11	2008	Nov	5.227	\$5.12	\$11.95	\$17.07	\$3.27
Nov 11 - Dec 12	2008	Dec	25.09	\$23.50	\$19.92	\$43.42	\$1.73
Dec 12 - Jan 8	2009	Jan	9.40	\$8.87	\$13.69	\$22.56	\$2.40
Jan 8 - Feb 6	2009	Feb	55.41	\$47.23	\$32.38	\$79.61	\$1.44
Feb 6 -Mar 4	2009	Mar	27.23	\$19.19	\$20.94	\$40.13	\$1.47
Mar 4 - Apr 7	2009	Apr	8.36	\$5.42	\$12.52	\$17.94	\$2.15
Apr 7 - May 8	2009	May	2.09	\$1.20	\$10.63	\$11.83	\$5.67
May 8 - Jun 10	2009	Jun	0.00	\$0.00	\$10.12	\$10.12	#DIV/0!
Jun 10 - Jul 13	2009	Jul	1.042	\$0.65	\$10.45	\$11.10	\$10.65
Jul 13 - Aug 11	2009	Aug	1.042	\$0.58	\$10.46	\$11.04	\$10.60
Aug 11 - Sep 11	2009	Sep	1.043	\$0.52	\$10.46	\$10.98	\$10.53
Sept 11 - Oct 13	2009	Oct	0	\$0.00	\$10.12	\$10.12	#DIV/0!
Oct 13 - Nov 10	2009	Nov	5.202	\$3.31	\$12.17	\$15.48	\$2.98
Nov 10 - Dec 11	2009	Dec	6.218	\$4.29	\$12.58	\$16.87	\$2.71

Month	Average Therm Usage
January	28
February	36
March	31
April	17
May	6
June	1
July	1
August	1
September	0
October	0
November	5
December	11




Natural Gas Bills							
Teaneck Gas Account #4137010005: Eugene							
Date	Year	Month	Meter 2209899	Total Supply	Total Delivery	Total Charge	Cost/Therm
Jun 14 - Jul 16	2007	Jul	33.582	\$33.17	\$20.40	\$53.57	\$1.60
Jul 16 - Aug 14	2007	Aug	26.287	\$23.76	\$18.15	\$41.91	\$1.59
Aug 14 - Sep 14	2007	Sep	32.564	\$26.71	\$20.08	\$46.79	\$1.44
Sept 14 - Oct 12	2007	Oct	31.483	\$25.97	\$19.69	\$45.66	\$1.45
Oct 12 - Nov 12	2007	Nov	45.126	\$42.10	\$24.80	\$66.90	\$1.48
Nov 12 - Dec 13	2007	Dec	57.608	\$57.57	\$29.60	\$87.17	\$1.51
Dec 13 - Jan 15	2008	Jan	62.663	\$62.05	\$31.39	\$93.44	\$1.49
Jan 15 - Feb 13	2008	Feb	59.472	\$61.04	\$30.53	\$91.57	\$1.54
Feb 13 - Mar 14	2008	Mar	62.542	\$70.52	\$31.66	\$102.18	\$1.63
Mar 14 - Apr 15	2008	Apr	54.255	\$66.04	\$26.20	\$92.24	\$1.70
Apr 15 - May 14	2008	May	36.518	\$49.03	\$20.88	\$69.91	\$1.91
May 14 - Jun 13	2008	Jun	48.991	\$71.93	\$24.64	\$96.57	\$1.97
Jun 13 - Jul 15	2008	Jul	32.345	\$50.86	\$19.64	\$70.50	\$2.18
Jul 15 - Aug 13	2008	Aug	25.114	\$36.33	\$17.46	\$53.79	\$2.14
Aug 13 - Sep 12	2008	Sep	27.233	\$31.88	\$18.10	\$49.98	\$1.84
Sept 12 - Oct 13	2008	Oct	51.274	\$55.23	\$25.31	\$80.54	\$1.57
Oct 13 - Nov 11	2008	Nov	63.769	\$62.43	\$32.31	\$94.74	\$1.49
Nov 11 - Dec 12	2008	Dec	73.18	\$68.54	\$36.05	\$104.59	\$1.43
Dec 12 - Jan 8	2009	Jan	66.84	\$63.09	\$34.22	\$97.31	\$1.46
Jan 8 - Feb 5	2009	Feb	74.22	\$63.64	\$37.14	\$100.78	\$1.36
Feb 5 - Mar 5	2009	Mar	57.61	\$40.52	\$30.30	\$70.82	\$1.23
Mar 6 - Apr 7	2009	Apr	77.36	\$50.27	\$33.96	\$84.23	\$1.09
Apr 7 - May 8	2009	May	47.95	\$28.13	\$24.93	\$53.06	\$1.11
May 8 - Jun 10	2009	Jun	52.07	\$29.42	\$26.52	\$55.94	\$1.07
Jun 10 - Jul 13	2009	Jul	58.372	\$34.67	\$28.49	\$63.16	\$1.08
Jul 13 - Aug 11	2009	Aug	41.694	\$24.84	\$23.33	\$48.17	\$1.16
Aug 11 - Sep 11	2009	Sep	49.038	\$26.27	\$25.83	\$52.10	\$1.06
Sept 11 - Oct 12	2009	Oct	50.13	\$27.11	\$26.17	\$53.28	\$1.06
Oct 12 - Nov 10	2009	Nov	56.178	\$35.55	\$28.60	\$64.15	\$1.14
Nov 10 - Dec 11	2009	Dec	61.141	\$41.99	\$30.32	\$72.31	\$1.18

Month	Average Therm Usage
January	65
February	67
March	60
April	66
May	42
June	51
July	41
August	31
September	36
October	44
November	55
December	64




Natural Gas Bills							
Teaneck Gas Account #4134110505: Hawthorne							
Date	Year	Month	Meter 2415218	Total Supply	Total Delivery	Total Charge	Cost/Therm
Jun 14 - Jul 16	2007	Jul	0.000	\$0.00	\$92.03	\$92.03	#DIV/0!
Jul 16 - Aug 14	2007	Aug	0.000	\$0.00	\$92.03	\$92.03	#DIV/0!
Aug 14 - Sep 13	2007	Sep	2.101	\$1.73	\$92.26	\$93.99	\$44.74
Sept 13 - Oct 12	2007	Oct	0.000	\$0.00	\$92.03	\$92.03	#DIV/0!
Oct 12 - Nov 12	2007	Nov	2603.671	\$2,429.09	\$1,746.35	\$4,175.44	\$1.60
Nov 12 - Dec 13	2007	Dec	7304.707	\$7,300.07	\$2,584.33	\$9,884.40	\$1.35
Dec 13 - Jan 15	2008	Jan	8748.805	\$8,663.16	\$2,842.52	\$11,505.68	\$1.32
Jan 15 - Feb 13	2008	Feb	8607.819	\$8,834.46	\$2,695.14	\$11,529.60	\$1.34
Feb 13 - Mar 14	2008	Mar	8137.705	\$9,175.97	\$2,611.09	\$11,787.06	\$1.45
Mar 14 - Apr 15	2008	Apr	5144.867	\$6,262.65	\$540.83	\$6,803.48	\$1.32
Apr 15 - May 14	2008	May	691.756	\$928.78	\$164.97	\$1,093.75	\$1.58
May 14 - Jun 13	2008	Jun	170.947	\$250.99	\$109.95	\$360.94	\$2.11
Jun 13 - Jul 15	2008	Jul	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!
Jul 15 - Aug 13	2008	Aug	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!
Aug 13 - Sep 12	2008	Sep	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!
Sept 12 - Oct 13	2008	Oct	198.818	\$214.17	\$112.89	\$327.06	\$1.65
Oct 13 - Nov 11	2008	Nov	2329.142	\$2,280.34	\$1,576.42	\$3,856.76	\$1.66
Nov 11 - Dec 12	2008	Dec	7449.49	\$6,977.78	\$2,526.66	\$9,504.44	\$1.28
Dec 12 - Jan 8	2009	Jan	7750.37	\$7,315.11	\$2,618.57	\$9,933.68	\$1.28
Jan 8 - Feb 5	2009	Feb	8213.68	\$7,043.01	\$2,696.09	\$9,739.10	\$1.19
Feb 5 - Mar 4	2009	Mar	7300.52	\$5,145.62	\$2,523.25	\$7,668.87	\$1.05
Mar 4 - Apr 7	2009	Apr	6009.98	\$3,909.41	\$676.39	\$4,585.80	\$0.76
Apr 7 - May 8	2009	May	1861.66	\$1,092.60	\$289.35	\$1,381.95	\$0.74
May 8 - Jun 10	2009	Jun	173.91	\$98.25	\$114.03	\$212.28	\$1.22
Jun 10 - Jul 13	2009	Jul	0	\$0.00	\$93.72	\$93.72	#DIV/0!
Jul 13 - Aug 11	2009	Aug	0	\$0.00	\$93.72	\$93.72	#DIV/0!
Aug 11 - Sep 11	2009	Sep	0	\$0.00	\$93.72	\$93.72	#DIV/0!
Sept 11 - Oct 12	2009	Oct	237.075	\$128.03	\$122.66	\$250.69	\$1.06
Oct 12 - Nov 11	2009	Nov	4731.448	\$2,999.66	\$2,046.17	\$5,045.83	\$1.07
Nov 11 - Dec 11	2009	Dec	6310.994	\$4,335.17	\$2,341.04	\$6,676.21	\$1.06

Month	Average Therm Usage
January	8,250
February	8,411
March	7,719
April	5,577
May	1,277
June	172
July	0
August	0
September	1
October	145
November	3,221
December	7,022




Natural Gas Bills							
Teaneck Gas Account #4125048606: Lowell							
Date	Year	Month	Meter 2757568	Total Supply	Total Delivery	Total Charge	Cost/Therm
Jun 12 - Jul 12	2007	Jul	12.581	\$12.53	\$13.94	\$26.47	\$2.10
Jul 12 - Aug 10	2007	Aug	13.669	\$12.53	\$14.27	\$26.80	\$1.96
Aug 10 - Sep 11	2007	Sep	15.757	\$13.06	\$14.92	\$27.98	\$1.78
Sept 11 - Oct 10	2007	Oct	24.137	\$19.69	\$17.46	\$37.15	\$1.54
Oct 10 - Nov 8	2007	Nov	31.483	\$28.97	\$21.02	\$49.99	\$1.59
Nov 8 - Dec 11	2007	Dec	28.308	\$28.31	\$19.38	\$47.69	\$1.68
Dec 11 - Jan 11	2008	Jan	21.932	\$21.74	\$16.97	\$38.71	\$1.77
Jan 11 - Feb 11	2008	Feb	18.781	\$19.11	\$15.72	\$34.83	\$1.85
Feb 11 - Mar 12	2008	Mar	14.593	\$16.35	\$14.31	\$30.66	\$2.10
Mar 12 - Apr 11	2008	Apr	14.607	\$17.68	\$14.32	\$32.00	\$2.19
Apr 11 - May 12	2008	May	8.347	\$11.06	\$12.43	\$23.49	\$2.81
May 12 - Jun 11	2008	Jun	12.508	\$18.30	\$13.68	\$31.98	\$2.56
Jun 11 - Jul 11	2008	Jul	11.477	\$17.89	\$13.38	\$31.27	\$2.72
Jul 11 - Aug 11	2008	Aug	11.510	\$17.12	\$13.39	\$30.51	\$2.65
Aug 11 - Sep 10	2008	Sep	17.772	\$25.27	\$45.05	\$70.32	\$3.96
Sept 10 - Oct 14	2008	Oct	16.743	\$18.05	\$14.95	\$33.00	\$1.97
Oct 14 - Nov 7	2008	Nov	39.725	\$39.24	\$23.13	\$62.37	\$1.57
Nov 7 - Dec 10	2008	Dec	63.77	\$59.47	\$35.06	\$94.53	\$1.48
Dec 10 - Jan 6	2009	Jan	41.78	\$39.67	\$26.52	\$66.19	\$1.58
Jan 6 - Feb 3	2009	Feb	51.18	\$44.53	\$30.35	\$74.88	\$1.46
Feb 3 - Mar 3	2009	Mar	51.32	\$36.27	\$30.25	\$66.52	\$1.30
Mar 4 - Apr 3	2009	Apr	63.77	\$41.95	\$29.74	\$71.69	\$1.12
Apr 3 - May 6	2009	May	73.04	\$43.06	\$32.71	\$75.77	\$1.04
May 6 - Jun 8	2009	Jun	89.56	\$50.52	\$38.32	\$88.84	\$0.99
Jun 8 - Jul 9	2009	Jul	9.381	\$5.53	\$13.07	\$18.60	\$1.98
Jul 9 - Aug 7	2009	Aug	121.956	\$73.86	\$48.66	\$122.52	\$1.00
Aug 7 - Sep 9	2009	Sep	138.768	\$75.03	\$54.58	\$129.61	\$0.93
Sept 9 - Oct 8	2009	Oct	6.272	\$3.35	\$12.13	\$15.48	\$2.47
Oct 8 - Nov 6	2009	Nov	52.017	\$32.44	\$26.39	\$58.83	\$1.13
Nov 6 - Dec 9	2009	Dec	52.851	\$36.19	\$26.61	\$62.80	\$1.19

Month	Average Therm Usage
January	32
February	35
March	33
April	39
May	41
June	51
July	11
August	49
September	57
October	16
November	41
December	48




Natural Gas Bills																	
Teaneck Gas Account #4134127203: High School								Teaneck Gas Account #4133097017: High School									
Date	Year	Month	Meter 3128206	Total Supply	Total Delivery	Total Charge	Cost/Therm	Meter 3166301	Total Supply	Total Delivery	Total Charge	Cost/Therm	Overall Gas Use	Overall Total Charge	Overall Cost/Therm		
Jun 14 - Jul 16	2007	Jul	30735.675	\$30,360.09	\$2,888.32	\$33,248.41	\$1.08	14.692	\$14.51	\$14.58	\$29.09	\$1.98	30750.367	\$33,277.50	\$1.08		
Jul 16 - Aug 14	2007	Aug	28630.214	\$25,874.23	\$2,698.33	\$28,572.56	\$1.00	12.618	\$11.40	\$13.95	\$25.35	\$2.01	28642.832	\$28,597.91	\$1.00		
Aug 14 - Sep 13	2007	Sep	28980.000	\$23,809.29	\$2,729.90	\$26,539.19	\$0.92	33.615	\$27.62	\$20.41	\$48.03	\$1.43	29013.615	\$26,587.22	\$0.92		
Sept 13 - Oct 12	2007	Oct	17540.418	\$14,441.67	\$1,669.08	\$16,110.75	\$0.92	102.846	\$84.68	\$41.52	\$126.20	\$1.23	17643.264	\$16,236.95	\$0.92		
Oct 12 - Nov 12	2007	Nov	14322.012	\$13,361.69	\$4,628.96	\$17,990.65	\$1.26	114.389	\$106.72	\$51.68	\$158.40	\$1.38	14436.401	\$18,149.05	\$1.26		
Nov 12 - Dec 13	2007	Dec	19160.632	\$19,148.47	\$5,016.61	\$24,165.08	\$1.26	166.54	\$166.44	\$72.12	\$238.56	\$1.43	19327.172	\$24,403.64	\$1.26		
Dec 13 - Jan 16	2008	Jan	2943.854	\$2,927.62	\$7,102.99	\$10,030.61	\$3.41	199.47	\$197.49	\$84.78	\$282.27	\$1.42	3143.324	\$10,312.88	\$3.28		
Jan 16 - Feb 13	2008	Feb	32368.491	\$33,269.31	\$7,281.88	\$40,551.19	\$1.25	191.98	\$197.32	\$82.54	\$279.86	\$1.46	32560.471	\$40,831.05	\$1.25		
Feb 13 - Mar 15	2008	Mar	0.000	\$0.00	\$4,148.47	\$4,148.47	#DIV/0!	185.54	\$209.55	\$79.63	\$289.18	\$1.56	185.540	\$4,437.65	\$23.92		
Mar 15 - Apr 15	2008	Apr	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!	148.159	\$180.51	\$54.38	\$234.89	\$1.59	148.159	\$326.78	\$2.21		
Apr 15 - May 14	2008	May	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!	99.12	\$133.09	\$39.66	\$172.75	\$1.74	99.120	\$264.64	\$2.67		
May 14 - Jun 13	2008	Jun	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!	122.998	\$180.59	\$46.83	\$227.42	\$1.85	122.998	\$319.31	\$2.60		
Jun 13 - Jul 15	2008	Jul	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!	31.301	\$49.22	\$19.32	\$68.54	\$2.19	31.301	\$160.43	\$5.13		
Jul 15 - Aug 13	2008	Aug	0.000	\$0.00	\$91.89	\$91.89	#DIV/0!	6.278	\$9.08	\$11.81	\$20.89	\$3.33	6.278	\$112.78	\$17.96		
Aug 13 - Sep 12	2008	Sep	3904.250	\$4,570.09	\$438.07	\$5,008.16	\$1.28	41.897	\$49.05	\$22.49	\$71.54	\$1.71	3946.147	\$5,079.70	\$1.29		
Sept 12 - Oct 13	2008	Oct	73.928	\$79.64	\$99.70	\$179.34	\$2.43	83.713	\$90.18	\$35.04	\$125.22	\$1.50	157.641	\$304.56	\$1.93		
Oct 13 - Nov 11	2008	Nov	5.201	\$5.09	\$4,149.04	\$4,154.13	\$798.72	82.586	\$80.85	\$38.25	\$119.10	\$1.44	87.787	\$4,273.23	\$48.68		
Nov 11 - Dec 13	2008	Dec	1257.64	\$1,179.19	\$4,304.43	\$5,483.62	\$4.36	140.083	\$131.34	\$61.09	\$192.43	\$1.37	1397.722	\$5,676.05	\$4.06		
Dec 13 - Jan 8	2009	Jan	16894.67	\$15,930.90	\$7,286.43	\$23,217.33	\$1.37	106.527	\$100.45	\$49.05	\$149.50	\$1.40	17001.192	\$23,366.83	\$1.37		
Jan 8 - Feb 5	2009	Feb	22929.81	\$19,661.71	\$7,245.00	\$26,906.71	\$1.17	160.991	\$138.04	\$70.90	\$208.94	\$1.30	23090.803	\$27,115.65	\$1.17		
Feb 5 - Mar 4	2009	Mar	18345.60	\$12,930.51	\$6,379.76	\$19,310.27	\$1.05	113.121	\$79.73	\$51.59	\$131.32	\$1.16	18458.717	\$19,441.59	\$1.05		
Mar 4 - Apr 7	2009	Apr	17326.09	\$11,270.40	\$1,734.00	\$13,004.40	\$0.75	129.629	\$84.29	\$50.20	\$134.49	\$1.04	17455.717	\$13,138.89	\$0.75		
Apr 7 - May 8	2009	May	0.00	\$0.00	\$92.37	\$92.37	#DIV/0!	96.939	\$56.90	\$40.19	\$97.09	\$1.00	96.939	\$189.46	\$1.95		
May 8 - Jun 10	2009	Jun	17724.04	\$10,216.82	\$1,775.56	\$11,992.37	\$0.68	109.342	\$61.77	\$44.55	\$106.32	\$0.97	17833.383	\$12,098.69	\$0.68		
Jun 10 - Jul 13	2009	Jul	17724.04	\$10,216.82	\$1,775.56	\$11,992.37	\$0.68	41.694	\$24.74	\$23.25	\$47.99	\$1.15	17765.734	\$12,040.36	\$0.68		
Jul 13 - Aug 11	2009	Aug	5633.088	\$3,364.23	\$654.88	\$4,019.11	\$0.71	7.297	\$4.33	\$12.43	\$16.76	\$2.30	5640.385	\$4,035.87	\$0.72		
Aug 11 - Sep 10	2009	Sep	2870.67	\$1,542.59	\$401.68	\$1,944.27	\$0.68	27.128	\$14.55	\$18.81	\$33.36	\$1.23	2897.798	\$1,977.63	\$0.68		
Sept 10 - Oct 12	2009	Oct	11224.658	\$6,045.50	\$1,227.22	\$7,272.72	\$0.65	125.326	\$67.50	\$50.24	\$117.74	\$0.94	11349.984	\$7,390.46	\$0.65		
Oct 12 - Nov 10	2009	Nov	11890.261	\$7,520.05	\$4,289.20	\$11,809.25	\$0.99	134.203	\$84.92	\$60.74	\$145.66	\$1.09	12024.464	\$11,954.91	\$0.99		
Nov 10 - Dec 11	2009	Dec				\$0.00	#DIV/0!	138.863	\$95.36	\$62.35	\$157.71	\$1.14	138.863	\$157.71	\$1.14		

Month	Average Therm Usage
January	10,072
February	27,826
March	9,322
April	8,802
May	98
June	8,978
July	16,182
August	11,430
September	11,953
October	9,717
November	8,850
December	6,955




Natural Gas Bills							
Teaneck Gas Account #4134015308: Thomas Jefferson							
Date	Year	Month	Meter 3340982	Total Supply	Total Delivery	Total Charge	Cost/Therm
Jun 14 - Jul 16	2007	Jul	527.870	\$521.42	\$172.35	\$693.77	\$1.31
Jul 16 - Aug 14	2007	Aug	0.000	\$0.00	\$10.07	\$10.07	#DIV/0!
Aug 14 - Sep 14	2007	Sep	0.000	\$0.00	\$10.07	\$10.07	#DIV/0!
Sept 13 - Oct 12	2007	Oct	1551.078	\$1,277.06	\$484.39	\$1,761.45	\$1.14
Oct 12 - Nov 12	2007	Nov	504.783	\$470.94	\$180.10	\$651.04	\$1.29
Nov 12 - Dec 13	2007	Dec	739.479	\$739.01	\$272.45	\$1,011.46	\$1.37
Dec 13 - Jan 15	2008	Jan	763.445	\$755.97	\$279.98	\$1,035.95	\$1.36
Jan 15 - Feb 13	2008	Feb	641.674	\$658.57	\$235.68	\$894.25	\$1.39
Feb 13 - Mar 15	2008	Mar	632.713	\$714.60	\$229.19	\$943.79	\$1.49
Mar 15 - Apr 15	2008	Apr	797.136	\$971.17	\$249.09	\$1,220.26	\$1.53
Apr 15 - May 14	2008	May	739.751	\$993.22	\$231.87	\$1,225.09	\$1.66
May 14 - Jun 13	2008	Jun	776.558	\$1,140.17	\$242.91	\$1,383.08	\$1.78
Jun 13 - Jul 15	2008	Jul	498.732	\$784.20	\$159.55	\$943.75	\$1.89
Jul 15 - Aug 14	2008	Aug	138.126	\$198.69	\$51.37	\$250.06	\$1.81
Aug 14 - Sep 12	2008	Sep	348.791	\$407.88	\$114.57	\$522.45	\$1.50
Sept 12 - Oct 13	2008	Oct	491.812	\$529.79	\$157.48	\$687.27	\$1.40
Oct 13 - Nov 11	2008	Nov	496.563	\$486.16	\$167.67	\$653.83	\$1.32
Nov 11 - Dec 12	2008	Dec	825.86	\$773.57	\$298.37	\$1,071.94	\$1.30
Dec 12 - Jan 8	2009	Jan	697.65	\$658.47	\$255.68	\$914.15	\$1.31
Jan 8 - Feb 5	2009	Feb	761.05	\$652.58	\$280.25	\$932.83	\$1.23
Feb 5 - Mar 4	2009	Mar	658.83	\$464.36	\$240.08	\$704.44	\$1.07
Mar 4 - Apr 7	2009	Apr	896.95	\$583.43	\$288.57	\$872.00	\$0.97
Apr 7 - May 8	2009	May	747.37	\$438.59	\$242.96	\$681.55	\$0.91
May 8 - Jun 10	2009	Jun	791.42	\$447.09	\$259.29	\$706.38	\$0.89
Jun 10 - Jul 13	2009	Jul	683.788	\$405.56	\$225.41	\$630.97	\$0.92
Jul 13 - Aug 11	2009	Aug	511.799	\$305.62	\$172.24	\$477.86	\$0.93
Aug 11 - Sep 11	2009	Sep	466.387	\$249.99	\$159.57	\$409.56	\$0.88
Sept 11 - Oct 12	2009	Oct	507.571	\$274.16	\$172.62	\$446.78	\$0.88
Oct 12 - Nov 10	2009	Nov	401.57	\$254.04	\$135.40	\$389.44	\$0.97
Nov 10 - Dec 11	2009	Dec	825.922	\$567.11	\$289.12	\$856.23	\$1.04
Nov 10 - Dec 17	2009	Dec	636.078	\$438.37	\$210.59	\$648.96	\$1.02

Month	Average Therm Usage
January	731
February	701
March	646
April	847
May	744
June	784
July	570
August	217
September	272
October	850
November	468
December	797



Natural Gas Bills							
Teaneck Gas Account #4132120902: Whittier							
Date	Year	Month	Meter 3175230	Total Supply	Total Delivery	Total Charge	Cost/Therm
Jun 13 - Jul 13	2007	Jul	16.775	\$16.66	\$15.23	\$31.89	\$1.90
Jul 13 - Aug 13	2007	Aug	33.647	\$30.61	\$20.42	\$51.03	\$1.52
Aug 13 - Sep 12	2007	Sep	28.362	\$24.61	\$28.86	\$53.47	\$1.89
Sept 12 - Oct 11	2007	Oct	23.088	\$18.92	\$17.13	\$36.05	\$1.56
Oct 11 - Nov 13	2007	Nov	30.434	\$28.41	\$20.15	\$48.56	\$1.60
Nov 13 - Dec 12	2007	Dec	24.114	\$24.10	\$17.75	\$41.85	\$1.74
Dec 12 - Jan 14	2008	Jan	29.243	\$28.97	\$19.54	\$48.51	\$1.66
Jan 14 - Feb 12	2008	Feb	23.998	\$24.55	\$17.71	\$42.26	\$1.76
Feb 12 - Mar 15	2008	Mar	26.059	\$29.39	\$18.32	\$47.71	\$1.83
Mar 15 - Apr 14	2008	Apr	23.998	\$29.21	\$17.13	\$46.34	\$1.93
Apr 14 - May 13	2008	May	19.824	\$26.49	\$15.87	\$42.36	\$2.14
May 13 - Jun 12	2008	Jun	15.635	\$22.92	\$14.62	\$37.54	\$2.40
Jun 12 - Jul 16	2008	Jul	18.781	\$29.54	\$15.57	\$45.11	\$2.40
Jul 16 - Aug 14	2008	Aug	16.743	\$23.97	\$14.95	\$38.92	\$2.32
Aug 14 - Sep 12	2008	Sep	13.616	\$15.92	\$14.02	\$29.94	\$2.20
Sept 12 - Oct 10	2008	Oct	14.650	\$15.88	\$14.32	\$30.20	\$2.06
Oct 10 - Nov 10	2008	Nov	14.636	\$14.41	\$14.37	\$28.78	\$1.97
Nov 10 - Dec 11	2008	Dec	32.41	\$30.30	\$21.37	\$51.67	\$1.59
Dec 11 - Jan 7	2009	Jan	18.80	\$17.80	\$16.19	\$33.99	\$1.81
Jan 7 - Feb 5	2009	Feb	34.50	\$29.62	\$22.48	\$52.10	\$1.51
Feb 5 - Mar 4	2009	Mar	22.00	\$15.50	\$17.48	\$32.98	\$1.50
Mar 5 - Apr 6	2009	Apr	40.77	\$26.52	\$22.59	\$49.11	\$1.20
Apr 6 - May 7	2009	May	31.30	\$18.40	\$19.74	\$38.14	\$1.22
May 7 - Jun 9	2009	Jun	18.74	\$10.58	\$16.02	\$26.60	\$1.42
Jun 9 - Jul 10	2009	Jul	16.678	\$9.88	\$15.38	\$25.26	\$1.51
Jul 10 - Aug 10	2009	Aug	17.72	\$10.61	\$15.72	\$26.33	\$1.49
Aug 10 - Sep 10	2009	Sep	35.475	\$19.08	\$21.48	\$40.56	\$1.14
Sept 10 - Oct 9	2009	Oct	38.642	\$20.60	\$22.51	\$43.11	\$1.12
Oct 9 - Nov 9	2009	Nov	14.565	\$9.23	\$14.66	\$23.89	\$1.64
Nov 9 - Dec 10	2009	Dec	71.504	\$49.06	\$37.20	\$86.26	\$1.21


Month	Average Therm Usage
January	24
February	29
March	24
April	32
May	26
June	17
July	17
August	23
September	26
October	25
November	20
December	43






Oil Bills					
Teaneck Oil Account #128386: Benjamin Franklin					
Date	Year	Month	Cost/Gal	Gal	Total Cost
11/30/2007	2007	Nov	\$2.92	3001.5	\$8,762.58
12/3/2007	2007	Dec	\$2.87	2374.2	\$6,806.59
12/7/2007	2007	Dec	\$2.88	1500.2	\$4,315.18
12/17/2007	2007	Dec	\$2.95	1500.1	\$4,424.39
1/11/2008	2008	Jan	\$2.90	2003	\$5,800.49
1/15/2008	2008	Jan	\$2.93	1700	\$4,974.03
1/31/2008	2008	Jan	\$2.89	3672.5	\$10,609.49
2/8/2008	2008	Feb	\$2.79	1187.2	\$3,310.98
2/28/2008	2008	Feb	\$3.12	3800	\$11,848.02
3/7/2008	2008	Mar	\$3.36	1000	\$3,359.90
3/20/2008	2008	Mar	\$3.45	2000.1	\$6,895.14
10/30/2008	2008	Oct	\$2.32	3006	\$6,975.12
11/17/2008	2008	Nov	\$2.15	2036	\$4,383.30
12/1/2008	2008	Dec	\$2.08	1900	\$3,943.26
12/15/2008	2008	Dec	\$1.79	2400.1	\$4,291.14
12/22/2008	2008	Dec	\$1.69	1380	\$2,332.75
1/5/2009	2009	Jan	\$1.80	1000	\$1,800.40
1/14/2009	2009	Jan	\$1.89	2968.4	\$5,596.62
1/21/2009	2009	Jan	\$1.78	2785.7	\$4,952.70
1/27/2009	2009	Jan	\$1.80	1650	\$2,974.79
2/3/2009	2009	Feb	\$1.77	1700	\$3,001.18
2/11/2009	2009	Feb	\$1.65	1901.8	\$3,129.22
3/19/2009	2009	Mar	\$1.57	4936	\$7,734.22
4/17/2009	2009	Apr	\$1.72	2428.7	\$4,177.12
11/18/2009	2009	Nov	\$2.12	4568.3	\$9,679.31
11/18/2009	2009	Nov	\$2.12	437.7	\$927.40
12/17/2009	2009	Dec	\$2.03	3004.2	\$6,084.41

Month	Averaged
January	7889.8
February	4294.5
March	3968.05
April	2428.7
May	
June	
July	
August	
September	
October	3006
November	3347.833
December	4686.267




Oil Bills					
Teaneck Oil Account #128382: Bryant					
Date	Year	Month	Cost/Gal	Gal	Total Cost
11/1/2007	2007	Nov	\$2.83	809.2	\$2,287.53
11/30/2007	2007	Nov	\$2.92	2016.5	\$5,886.97
12/3/2007	2007	Dec	\$2.87	1069	\$3,064.72
12/7/2007	2007	Dec	\$2.88	2001.1	\$5,755.96
12/14/2007	2007	Dec	\$2.96	1896.6	\$5,607.11
1/2/2008	2008	Jan	\$2.99	1000	\$2,990.40
1/3/2008	2008	Jan	\$3.09	3708.1	\$11,450.24
1/10/2008	2008	Jan	\$2.95	1003.7	\$2,960.31
1/17/2008	2008	Jan	\$2.86	1500.1	\$4,290.14
1/24/2008	2008	Jan	\$2.77	1900.3	\$5,258.89
2/1/2008	2008	Feb	\$2.87	1434.2	\$4,121.75
2/8/2008	2008	Feb	\$2.79	1199.1	\$3,344.17
2/15/2008	2008	Feb	\$3.00	2501.9	\$7,515.46
2/25/2008	2008	Feb	\$3.10	1000	\$3,100.40
2/28/2008	2008	Feb	\$3.12	2151	\$6,706.60
3/7/2008	2008	Mar	\$3.36	1003.1	\$3,370.32
3/14/2008	2008	Mar	\$3.57	2410	\$8,603.46
3/20/2008	2008	Mar	3.45	900.2	\$3,103.35
10/30/2008	2008	Oct	\$2.32	3000	\$6,961.20
11/17/2008	2008	Nov	\$2.15	1800	\$3,875.22
12/1/2008	2008	Dec	\$2.08	2000	\$4,150.80
12/9/2008	2008	Dec	\$1.77	2785.4	\$4,931.27
12/15/2008	2008	Dec	\$1.79	2000	\$3,575.80
12/22/2008	2008	Dec	\$1.69	1500	\$2,535.60
1/5/2009	2009	Jan	\$1.80	2794.7	\$5,031.58
1/14/2009	2009	Jan	\$1.89	3102.5	\$5,849.45
1/20/2009	2009	Jan	\$1.87	2050.8	\$3,830.69
1/26/2009	2009	Jan	\$1.83	2350	\$4,295.57
2/4/2009	2009	Feb	\$1.71	1800	\$3,078.72
2/10/2009	2009	Feb	\$1.70	2297.2	\$3,894.67
2/18/2009	2009	Feb	\$1.53	1700	\$2,605.93
2/23/2009	2009	Feb	\$1.53	1000	\$1,530.40
3/19/2009	2009	Mar	\$1.57	3899.1	\$6,109.50
4/16/2009	2009	Apr	\$1.69	2390	\$4,044.84
11/19/2009	2009	Nov	\$2.11	2005.3	\$4,228.78
11/20/2009	2009	Nov	\$2.06	996.3	\$2,053.67
12/15/2009	2009	Dec	\$1.99	4007.5	\$7,956.09
12/29/2009	2009	Dec	\$2.20	3205.1	\$7,044.17

Month	Averaged
January	9705.1
February	7541.7
March	4106.2
April	2390
May	
June	
July	
August	
September	
October	3000
November	2542.433
December	6821.567




Oil Bills					
Teaneck Oil Account #128385: Eugene					
Date	Year	Month	Cost/Gal	Gal	Total Cost
11/30/2007	2007	Nov	\$2.92	804.5	\$2,348.66
12/21/2007	2007	Dec	\$2.93	1404.2	\$4,109.25
1/7/2008	2008	Jan	\$3.03	455.4	\$1,377.99
1/18/2008	2008	Jan	\$2.84	444.1	\$1,261.20
2/8/2008	2008	Feb	\$2.79	1004.8	\$2,802.29
2/28/2008	2008	Feb	\$3.12	1300	\$4,053.27
3/7/2008	2008	Mar	\$3.36	345.1	\$1,159.50
3/20/2008	2008	Mar	\$3.45	541	\$1,865.04
10/30/2008	2008	Oct	\$2.32	1362.3	\$3,161.08
11/17/2008	2008	Nov	\$2.15	500	\$1,076.45
12/9/2009	2008	Dec	\$1.77	1101.5	\$1,950.10
12/22/2008	2008	Dec	\$1.69	692	\$1,169.76
1/7/2009	2009	Jan	\$1.94	1000.1	\$1,935.59
1/20/2009	2009	Jan	\$1.87	752.1	\$1,404.85
1/27/2009	2009	Jan	\$1.80	401.5	\$723.86
2/9/2009	2009	Feb	\$1.72	675.9	\$1,162.82
2/17/2009	2009	Feb	\$1.65	400	\$659.16
3/19/2009	2009	Mar	\$1.57	1313.7	\$2,058.44
4/16/2009	2009	Apr	\$1.69	423.4	\$716.56
11/19/2009	2009	Nov	\$2.11	1700.1	\$3,585.17
12/17/2009	2009	Dec	\$2.03	1320.2	\$2,673.80

Month	Averaged
January	1526.6
February	1690.35
March	1099.9
April	423.4
May	
June	
July	
August	
September	
October	1362.3
November	1100.05
December	1556.85




Oil Bills					
Teaneck Oil Account #128383: Lowell					
Date	Year	Month	Cost/Gal	Gal	Total Cost
11/1/2007	2007	Nov	\$2.83	1000	\$2,826.90
11/30/2007	2007	Nov	\$2.92	2009.6	\$5,866.83
12/17/2007	2007	Dec	\$2.95	1500	\$4,424.10
12/21/2007	2007	Dec	\$2.93	1000.2	\$2,926.99
1/4/2008	2008	Jan	\$3.06	3929.1	\$12,036.40
1/11/2008	2008	Jan	\$2.90	1004.6	\$2,909.22
1/18/2008	2008	Jan	\$2.84	1500.7	\$4,261.84
1/31/2008	2008	Jan	\$2.89	2003	\$5,786.47
2/8/2008	2008	Feb	\$2.79	1000.2	\$2,789.46
2/28/2008	2008	Feb	\$3.12	3500	\$10,912.65
3/7/2008	2008	Mar	\$3.36	698.7	\$2,347.56
3/20/2008	2008	Mar	\$3.45	2000.1	\$6,895.14
10/31/2008	2008	Oct	\$2.32	4702	\$10,922.28
11/13/2008	2008	Nov	\$2.16	700.9	\$1,510.72
12/1/2008	2008	Dec	\$2.08	1868.2	\$3,877.26
12/15/2008	2008	Dec	\$1.79	2372.5	\$4,241.79
12/22/2008	2008	Dec	\$1.69	500	\$845.20
1/5/2009	2009	Jan	\$1.80	2000	\$3,600.80
1/14/2009	2009	Jan	\$1.89	1538.1	\$2,899.93
1/21/2009	2009	Jan	\$1.78	1500.2	\$2,667.21
1/27/2009	2009	Jan	\$1.80	997.1	\$1,797.67
2/4/2009	2009	Feb	\$1.71	1200	\$2,052.48
2/11/2009	2009	Feb	\$1.65	1000.1	\$1,645.56
3/19/2009	2009	Mar	\$1.57	4800.8	\$7,522.37
4/17/2009	2009	Apr	\$1.72	2501	\$4,301.47
11/19/2009	2009	Nov	\$2.11	3485.5	\$7,350.22
12/17/2009	2009	Dec	\$2.03	2000	\$4,050.60

Month	Averaged
January	7236.4
February	3350.15
March	3749.8
April	2501
May	
June	
July	
August	
September	
October	4702
November	2398.66667
December	3080.3




Oil Bills					
Teaneck Oil Account #128393: High School					
Date	Year	Month	Cost/Gal	Gal	Total Cost
1/29/2008	2008	Jan	\$2.87	4267.5	\$12,243.03
2/14/2008	2008	Feb	\$2.95	2800	\$8,263.92
2/15/2008	2008	Feb	\$3.00	5013	\$15,058.55
3/7/2008	2008	Mar	\$3.36	5016.2	\$16,853.93
3/24/2008	2008	Mar	\$3.42	6037.2	\$20,631.53
4/9/2008	2008	Apr	\$3.58	5957.9	\$21,313.79
5/5/2008	2008	May	\$3.55	6005	\$21,332.16
6/6/2008	2008	Jun	\$3.99	6023	\$24,040.20
7/2/2008	2008	Jul	\$4.22	5028	\$21,225.20
7/17/2008	2008	Jul	\$4.12	4525.6	\$18,663.12
8/1/2008	2008	Aug	\$3.77	2821.3	\$10,637.43
8/4/2008	2008	Aug	\$3.74	3200	\$11,969.28
8/26/2008	2008	Aug	\$3.46	6005.5	\$20,796.45
9/23/2008	2008	Sep	\$3.34	5991	\$20,027.31
9/23/2008	2008	Sep	\$3.34	5995.3	\$20,041.69
11/10/2008	2008	Nov	\$2.29	5989	\$13,702.23
11/28/2008	2008	Nov	\$2.04	6025	\$12,263.29

Month	Gal Usage 01/08 - 12/ 08
January	4,268
February	7,813
March	11,053
April	5,958
May	6,005
June	6,023
July	9,554
August	12,027
September	11,986
October	
November	12,014
December	




Oil Bills					
Teaneck Oil Account #128387: Thomas Jefferson					
Date	Year	Month	Cost/Gal	Gal	Total Cost
11/1/2007	2007	Nov	\$2.83	560.1	\$1,583.35
11/30/2007	2007	Nov	\$2.92	2202.7	\$6,430.56
12/3/2007	2007	Dec	\$2.87	1001.5	\$2,871.20
12/7/2007	2007	Dec	\$2.88	1511.3	\$4,347.10
12/17/2007	2007	Dec	\$2.95	3983.8	\$11,749.82
1/4/2008	2008	Jan	\$3.06	1278	\$3,915.03
1/7/2008	2008	Jan	\$3.03	5073.9	\$15,353.11
1/11/2008	2008	Jan	\$2.90	1400	\$4,054.26
1/18/2008	2008	Jan	\$2.84	2300.1	\$6,532.05
1/29/2008	2008	Jan	\$2.87	4453.7	\$12,777.22
2/14/2008	2008	Feb	\$2.95	4991.9	\$14,733.09
3/7/2008	2008	Mar	\$3.36	4001	\$13,442.96
3/27/2008	2008	Mar	\$3.50	4265	\$14,937.74
4/7/2008	2008	Apr	\$3.40	2499	\$8,502.60
10/30/2008	2008	Oct	\$2.32	3400	\$7,889.36
11/13/2008	2008	Nov	\$2.16	1700	\$3,664.18
12/1/2008	2008	Dec	\$2.08	2200	\$4,565.88
12/12/2008	2008	Dec	\$1.79	2795.8	\$5,012.59
12/22/2008	2008	Dec	\$1.69	1516	\$2,562.65
1/5/2009	2009	Jan	\$1.80	2265	\$4,077.91
1/14/2009	2009	Jan	\$1.89	2021.9	\$3,812.09
1/20/2009	2009	Jan	\$1.87	2889.1	\$5,396.55
1/27/2009	2009	Jan	\$1.80	2876.8	\$5,186.58
2/4/2009	2009	Feb	\$1.71	4410	\$7,542.86
2/11/2009	2009	Feb	\$1.65	2139.6	\$3,520.50
2/18/2009	2009	Feb	\$1.53	1350	\$2,069.42
3/19/2009	2009	Mar	\$1.57	2800	\$4,387.32
4/1/2009	2009	Apr	\$1.67	4414	\$7,375.35
4/17/2009	2009	Apr	\$1.72	2812.2	\$4,836.70
11/18/2009	2009	Nov	\$2.12	5004.5	\$10,603.53
11/19/2009	2009	Nov	\$2.11	1516.5	\$3,198.00
12/17/2009	2009	Dec	\$2.03	2995	\$6,065.77

Month	Averaged
January	12279.25
February	6445.75
March	5533
April	4862.6
May	
June	
July	
August	
September	
October	3400
November	3661.2667
December	5334.4667



Oil Bills					
Teaneck Oil Account #128381: Whittier					
Date	Year	Month	Cost/Gal	Gal	Total Cost
11/1/2007	2007	Nov	\$2.83	302.4	\$854.85
11/30/2007	2007	Nov	\$2.92	4010.6	\$11,708.55
12/12/2007	2007	Dec	\$2.86	2201.3	\$6,298.80
12/21/2007	2007	Dec	\$2.93	1001.8	\$2,931.67
1/4/2008	2008	Jan	\$3.06	3725.3	\$11,412.08
1/10/2008	2008	Jan	\$2.95	600.8	\$1,772.00
1/17/2008	2008	Jan	\$2.86	1255.2	\$3,589.75
1/24/2008	2008	Jan	\$2.77	1518	\$4,200.91
2/1/2008	2008	Feb	\$2.87	1501.2	\$4,314.30
2/8/2008	2008	Feb	\$2.79	1802.3	\$5,026.43
2/15/2008	2008	Feb	\$3.00	1502.1	\$4,512.16
2/25/2008	2008	Feb	\$3.10	450.4	\$1,396.42
2/28/2008	2008	Feb	\$3.12	2400.1	\$7,483.27
3/7/2008	2008	Mar	\$3.36	906.3	\$3,045.08
3/14/2008	2008	Mar	\$3.57	1301	\$4,644.44
3/20/2008	2008	Mar	\$3.45	900.4	\$3,104.04
3/27/2008	2008	Mar	\$3.50	1100	\$3,852.64
10/30/2008	2008	Oct	\$2.32	1317.7	\$3,057.59
11/17/2008	2008	Nov	\$2.15	1600	\$3,444.64
12/1/2008	2008	Dec	\$2.08	2700	\$5,603.58
12/15/2008	2008	Dec	\$1.79	2900	\$5,184.91
12/22/2008	2008	Dec	\$1.69	1360.1	\$2,299.11
1/5/2009	2009	Jan	\$1.80	2654.5	\$4,779.16
1/15/2009	2009	Jan	\$1.86	2792.6	\$5,206.52
1/20/2009	2009	Jan	\$1.87	1459.5	\$2,726.20
1/27/2009	2009	Jan	\$1.80	1652	\$2,978.39
2/2/2009	2009	Feb	\$1.86	1500	\$2,783.10
2/9/2009	2009	Feb	\$1.72	1400.3	\$2,409.08
2/23/2009	2009	Feb	\$1.53	1100	\$1,683.44
2/17/2009	2009	Feb	\$1.65	1311.5	\$2,161.22
3/19/2009	2009	Mar	\$1.57	2667.8	\$4,180.18
4/16/2009	2009	Apr	\$1.69	2264.7	\$3,832.78
11/19/2009	2009	Nov	\$2.11	2000.1	\$4,217.81
12/17/2009	2009	Dec	\$2.03	3008.6	\$6,093.32
12/29/2009	2009	Dec	\$2.20	1792.7	\$3,940.00

Month	Averaged
January	7828.95
February	6483.95
March	3437.75
April	2264.7
May	
June	
July	
August	
September	
October	1317.7
November	2637.7
December	4988.166667



APPENDIX B

STATEMENT OF ENERGY PERFORMANCE  
PORTFOLIO MANAGER REFERENCE SHEET





# STATEMENT OF ENERGY PERFORMANCE

## Benjamin Franklin Middle School

Building ID: 2244139

For 12-month Period Ending: November 30, 2009<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

**Facility**

Benjamin Franklin Middle School  
1315 Taft Road  
Teaneck, NJ 07666

**Facility Owner**

Teaneck Board of Education  
1 Merrison Street  
Teaneck, NJ 07666

**Primary Contact for this Facility**

Anthony D'Angelo  
1 Merrison Street  
Teaneck, NJ 07666

Year Built: 1957

Gross Floor Area (ft<sup>2</sup>): 100,202Energy Performance Rating<sup>2</sup> (1-100) 21**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase(kBtu)	2,861,098
Fuel Oil (No. 2) (kBtu)	4,168,579
Natural Gas (kBtu) <sup>4</sup>	638,089
Total Energy (kBtu)	7,667,766

**Energy Intensity<sup>5</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	77
Source (kBtu/ft <sup>2</sup> /yr)	144

**Emissions (based on site energy use)**

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	776
---	-----

**Electric Distribution Utility**

Public Service Elec &amp; Gas Co

**National Average Comparison**

National Average Site EUI	58
National Average Source EUI	109
% Difference from National Average Source EUI	32%
Building Type	K-12 School

**Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Certifying Professional**

Matthew Goss  
11 British American Boulevard  
Latham, NY 12110

## Notes:

- Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
- The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
- Values represent energy consumption, annualized to a 12-month period.
- Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
- Values represent energy intensity, annualized to a 12-month period.
- Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Benjamin Franklin Middle School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	1315 Taft Road, Teaneck, NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Middle School (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	100,202 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select "yes" for open weekends. The "yes" response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	93	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	2	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	40 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	12(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 778015617 (kWh (thousand Watt-hours))</b> <b>Space(s): Entire Facility</b> <b>Generation Method: Grid Purchase</b>		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
10/09/2009	11/06/2009	83,820.00
09/10/2009	10/08/2009	66,240.00
08/08/2009	09/09/2009	55,680.00
07/10/2009	08/07/2009	53,280.00
06/09/2009	07/09/2009	64,320.00
04/04/2009	06/08/2009	150,000.00
03/04/2009	04/03/2009	80,160.00
02/04/2009	03/03/2009	67,680.00
01/07/2009	02/03/2009	75,120.00
12/11/2008	01/06/2009	71,520.00
<b>778015617 Consumption (kWh (thousand Watt-hours))</b>		<b>767,820.00</b>
<b>778015617 Consumption (kBtu (thousand Btu))</b>		<b>2,619,801.84</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>2,619,801.84</b>
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 2258618 (therms)</b> <b>Space(s): Entire Facility</b>		
Start Date	End Date	Energy Use (therms)
10/09/2009	11/06/2009	586.75
09/10/2009	10/08/2009	439.07
08/08/2009	09/09/2009	295.27
07/10/2009	08/07/2009	417.99
06/09/2009	07/09/2009	481.57
04/04/2009	06/08/2009	1,277.91
03/04/2009	04/03/2009	615.74
02/04/2009	03/03/2009	603.31
01/07/2009	02/03/2009	647.52
12/11/2008	01/06/2009	689.29
<b>2258618 Consumption (therms)</b>		<b>6,054.42</b>
<b>2258618 Consumption (kBtu (thousand Btu))</b>		<b>605,442.00</b>

<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>	<b>605,442.00</b>	
<b>Is this the total Natural Gas consumption at this building including all Natural Gas meters?</b>	<input type="checkbox"/>	
<b>Fuel Type: Fuel Oil (No. 2)</b>		
<b>Meter: 128386 (Gallons)</b> <b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (Gallons)</b>
11/01/2009	11/30/2009	5,006.00
10/01/2009	10/31/2009	0.00
09/01/2009	09/30/2009	0.00
08/01/2009	08/31/2009	0.00
07/01/2009	07/31/2009	0.00
06/01/2009	06/30/2009	0.00
05/01/2009	05/31/2009	0.00
04/01/2009	04/30/2009	2,428.70
03/01/2009	03/31/2009	4,936.00
02/01/2009	02/28/2009	3,601.80
01/01/2009	01/31/2009	8,404.10
12/01/2008	12/31/2008	5,680.10
<b>128386 Consumption (Gallons)</b>		<b>30,056.70</b>
<b>128386 Consumption (kBtu (thousand Btu))</b>		<b>4,168,578.75</b>
<b>Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))</b>		<b>4,168,578.75</b>
<b>Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?</b>		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
Benjamin Franklin Middle School  
1315 Taft Road  
Teaneck, NJ 07666

**Facility Owner**  
Teaneck Board of Education  
1 Merrison Street  
Teaneck , NJ 07666

**Primary Contact for this Facility**  
Anthony D'Angelo  
1 Merrison Street  
Teaneck , NJ 07666

## General Information

Benjamin Franklin Middle School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	100,202
Year Built	1957
For 12-month Evaluation Period Ending Date:	November 30, 2009

## Facility Space Use Summary

Middle School	
Space Type	K-12 School
Gross Floor Area(ft <sup>2</sup> )	100,202
Open Weekends?	No
Number of PCs	93
Number of walk-in refrigeration/freezer units	2
Presence of cooking facilities	Yes
Percent Cooled	40
Percent Heated	90
Months <sup>o</sup>	12
High School?	No
School District <sup>o</sup>	Teaneck

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 11/30/2009)	Baseline (Ending Date 09/30/2008)	Rating of 75	Target	National Average
Energy Performance Rating	21	22	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	77	72	45	N/A	58
Source (kBtu/ft <sup>2</sup> )	144	142	86	N/A	109
Energy Cost					
\$/year	\$ 185,383.32	\$ 216,799.18	\$ 110,134.94	N/A	\$ 140,854.50
\$/ft <sup>2</sup> /year	\$ 1.85	\$ 2.16	\$ 1.10	N/A	\$ 1.41
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	776	753	461	N/A	590
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	8	8	5	N/A	6

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

- o - This attribute is optional.
- d - A default value has been supplied by Portfolio Manager.


# Statement of Energy Performance

## 2009

Benjamin Franklin Middle School  
1315 Taft Road  
Teaneck, NJ 07666

Portfolio Manager Building ID: 2244139

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).



This building uses 144 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending November 2009

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification





# STATEMENT OF ENERGY PERFORMANCE

## Bryant Elementary School

Building ID: 2244795  
 For 12-month Period Ending: October 31, 2009<sup>1</sup>  
 Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

**Facility**  
 Bryant Elementary School  
 1 Tyron Avenue  
 Teaneck, NJ 07666

**Facility Owner**  
 Teaneck Board of Education  
 1 Merrison Street  
 Teaneck, NJ 07666

**Primary Contact for this Facility**  
 Anthony D'Angelo  
 1 Merrison Street  
 Teaneck, NJ 07666

**Year Built:** 1926  
**Gross Floor Area (ft<sup>2</sup>):** 47,438

**Energy Performance Rating<sup>2</sup> (1-100)** 7

### Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu)	943,359
Fuel Oil (No. 2) (kBtu)	4,641,929
Natural Gas (kBtu) <sup>4</sup>	13,603
Total Energy (kBtu)	5,598,891

### Energy Intensity<sup>5</sup>

Site (kBtu/ft <sup>2</sup> /yr)	118
Source (kBtu/ft <sup>2</sup> /yr)	166

### Emissions (based on site energy use)

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	486
---	-----

### Electric Distribution Utility

Public Service Elec & Gas Co

### National Average Comparison

National Average Site EUI	72
National Average Source EUI	102
% Difference from National Average Source EUI	63%
Building Type	K-12 School

### Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

#### Notes:

- Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
- The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
- Values represent energy consumption, annualized to a 12-month period.
- Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
- Values represent energy intensity, annualized to a 12-month period.
- Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

### Certifying Professional

Matthew Goss  
 11 British American Boulevard  
 Latham, NY 12110



## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Bryant Elementary School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	1 Tyron Avenue, Teaneck, NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Bryant Elementary (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	47,438 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	10	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	0	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	30 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	12(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 728001215 (kWh (thousand Watt-hours))</b> <b>Space(s): Entire Facility</b> <b>Generation Method: Grid Purchase</b>		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
09/12/2009	10/13/2009	23,600.00
08/12/2009	09/11/2009	19,200.00
07/14/2009	08/11/2009	14,960.00
06/11/2009	07/13/2009	22,000.00
05/09/2009	06/10/2009	25,760.00
04/08/2009	05/08/2009	31,520.00
03/05/2009	04/07/2009	22,160.00
02/07/2009	03/04/2009	16,960.00
01/09/2009	02/06/2009	23,840.00
12/13/2008	01/08/2009	20,720.00
11/12/2008	12/12/2008	26,080.00
<b>728001215 Consumption (kWh (thousand Watt-hours))</b>		<b>246,800.00</b>
<b>728001215 Consumption (kBtu (thousand Btu))</b>		<b>842,081.60</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>842,081.60</b>
<b>Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?</b>		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 2809405 (therms)</b> <b>Space(s): Entire Facility</b>		
Start Date	End Date	Energy Use (therms)
09/12/2009	10/13/2009	0.00
08/12/2009	09/11/2009	1.04
07/14/2009	08/11/2009	1.04
06/11/2009	07/13/2009	1.04
05/09/2009	06/10/2009	0.00
04/08/2009	05/08/2009	2.09
03/05/2009	04/07/2009	8.36
02/07/2009	03/04/2009	27.23
01/09/2009	02/06/2009	55.41
12/13/2008	01/08/2009	9.40
11/12/2008	12/12/2008	25.09

<b>2809405 Consumption (therms)</b>	<b>130.70</b>
<b>2809405 Consumption (kBtu (thousand Btu))</b>	<b>13,070.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>	<b>13,070.00</b>
<b>Is this the total Natural Gas consumption at this building including all Natural Gas meters?</b>	<input type="checkbox"/>

**Fuel Type: Fuel Oil (No. 2)**

<b>Meter: 128382 (Gallons)</b>		
<b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (Gallons)</b>
10/01/2009	10/31/2009	0.00
09/01/2009	09/30/2009	0.00
08/01/2009	08/31/2009	0.00
07/01/2009	07/31/2009	0.00
06/01/2009	06/30/2009	0.00
05/01/2009	05/31/2009	0.00
04/01/2009	04/30/2009	2,390.00
03/01/2009	03/31/2009	3,899.10
02/01/2009	02/28/2009	6,797.20
01/01/2009	01/31/2009	10,298.00
12/01/2008	12/31/2008	8,285.40
11/01/2008	11/30/2008	1,800.00
<b>128382 Consumption (Gallons)</b>		<b>33,469.70</b>
<b>128382 Consumption (kBtu (thousand Btu))</b>		<b>4,641,929.43</b>
<b>Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))</b>		<b>4,641,929.43</b>
<b>Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?</b>		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

**Certifying Professional**

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
Bryant Elementary School  
1 Tyron Avenue  
Teaneck, NJ 07666

**Facility Owner**  
Teaneck Board of Education  
1 Merrison Street  
Teaneck , NJ 07666

**Primary Contact for this Facility**  
Anthony D'Angelo  
1 Merrison Street  
Teaneck , NJ 07666

## General Information

Bryant Elementary School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	47,438
Year Built	1926
For 12-month Evaluation Period Ending Date:	October 31, 2009

## Facility Space Use Summary

Bryant Elementary	
Space Type	K-12 School
Gross Floor Area(ft <sup>2</sup> )	47,438
Open Weekends?	No
Number of PCs	10
Number of walk-in refrigeration/freezer units	0
Presence of cooking facilities	Yes
Percent Cooled	30
Percent Heated	90
Months <sup>o</sup>	12
High School?	No
School District <sup>o</sup>	Teaneck

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 10/31/2009)	Baseline (Ending Date 09/30/2008)	Rating of 75	Target	National Average
Energy Performance Rating	7	4	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	118	119	57	N/A	72
Source (kBtu/ft <sup>2</sup> )	166	178	79	N/A	102
Energy Cost					
\$/year	\$ 105,297.69	\$ 141,823.21	\$ 50,547.89	N/A	\$ 64,643.49
\$/ft <sup>2</sup> /year	\$ 2.22	\$ 2.99	\$ 1.07	N/A	\$ 1.36
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	486	508	233	N/A	298
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	10	11	5	N/A	6

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

- o - This attribute is optional.
- d - A default value has been supplied by Portfolio Manager.

# Statement of Energy Performance

## 2009

Bryant Elementary School  
1 Tyron Avenue  
Teaneck, NJ 07666

Portfolio Manager Building ID: 2244795

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).

This building's score



1

50

100

Least Efficient

Average

Most Efficient

This building uses 166 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending October 2009

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification





# STATEMENT OF ENERGY PERFORMANCE

## Eugene Field Administration Building

Building ID: 2244835

For 12-month Period Ending: November 30, 2009<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

**Facility**

Eugene Field Administration Building  
1 Merrison Street  
Teaneck , NJ 07666

**Facility Owner**

Teaneck Board of Education  
1 Merrison Street  
Teaneck , NJ 07666

**Primary Contact for this Facility**

Anthony D'Angelo  
1 Merrison Street  
Teaneck , NJ 07666

Year Built: 1955

Gross Floor Area (ft<sup>2</sup>): 24,877Energy Performance Rating<sup>2</sup> (1-100) 82**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase(kBtu)	598,416
Fuel Oil (No. 2) (kBtu)	1,173,363
Natural Gas (kBtu) <sup>4</sup>	69,923
Total Energy (kBtu)	1,841,702

**Energy Intensity<sup>5</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	74
Source (kBtu/ft <sup>2</sup> /yr)	131

**Emissions (based on site energy use)**

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	181
---	-----

**Electric Distribution Utility**

Public Service Elec &amp; Gas Co

**National Average Comparison**

National Average Site EUI	112
National Average Source EUI	199
% Difference from National Average Source EUI	-34%
Building Type	Office

**Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Certifying Professional**

Matthew Goss  
11 British American Boulevard  
Latham, NY 12110

## Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Eugene Field Administration Building	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	Office	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	1 Merrison Street, Teaneck , NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Administration Building (Office)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	24,877 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Weekly operating hours</b>	85 Hours	Is this the total number of hours per week that the Office space is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support personnel. For facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed.		<input type="checkbox"/>
<b>Workers on Main Shift</b>	47	Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100. The normal worker density ranges between 0.3 and 10 workers per 1000 square feet (92.8 square meters)		<input type="checkbox"/>
<b>Number of PCs</b>	25	Is this the number of personal computers in the Office?		<input type="checkbox"/>
<b>Percent Cooled</b>	50% or more	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	50% or more	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>



## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 678004548 (kWh (thousand Watt-hours))</b> <b>Space(s):</b> Entire Facility <b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
10/13/2009	11/10/2009	13,440.00
09/12/2009	10/12/2009	13,110.00
08/12/2009	09/11/2009	18,840.00
07/14/2009	08/11/2009	16,470.00
06/11/2009	07/13/2009	16,350.00
05/09/2009	06/10/2009	14,430.00
04/08/2009	05/08/2009	14,760.00
03/06/2009	04/07/2009	15,120.00
02/06/2009	03/05/2009	13,080.00
01/09/2009	02/05/2009	13,860.00
12/13/2008	01/08/2009	11,340.00
<b>678004548 Consumption (kWh (thousand Watt-hours))</b>		<b>160,800.00</b>
<b>678004548 Consumption (kBtu (thousand Btu))</b>		<b>548,649.60</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>548,649.60</b>
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 2209899 (therms)</b> <b>Space(s):</b> Entire Facility		
Start Date	End Date	Energy Use (therms)
10/13/2009	11/10/2009	56.18
09/12/2009	10/12/2009	50.13
08/12/2009	09/11/2009	49.04
07/14/2009	08/11/2009	41.69
06/11/2009	07/13/2009	58.37
05/09/2009	06/10/2009	52.07
04/08/2009	05/08/2009	47.95
03/06/2009	04/07/2009	77.36
02/06/2009	03/05/2009	57.61
01/09/2009	02/05/2009	74.22
12/13/2008	01/08/2009	66.84

<b>2209899 Consumption (therms)</b>	<b>631.46</b>
<b>2209899 Consumption (kBtu (thousand Btu))</b>	<b>63,146.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>	<b>63,146.00</b>
<b>Is this the total Natural Gas consumption at this building including all Natural Gas meters?</b>	<input type="checkbox"/>

**Fuel Type: Fuel Oil (No. 2)**

<b>Meter: 128385 (Gallons)</b>		
<b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (Gallons)</b>
11/01/2009	11/30/2009	1,700.10
10/01/2009	10/31/2009	0.00
09/01/2009	09/30/2009	0.00
08/01/2009	08/31/2009	0.00
07/01/2009	07/31/2009	0.00
06/01/2009	06/30/2009	0.00
05/01/2009	05/31/2009	0.00
04/01/2009	04/30/2009	423.40
03/01/2009	03/31/2009	1,313.70
02/01/2009	02/28/2009	1,075.90
01/01/2009	01/31/2009	2,153.70
12/01/2008	12/31/2008	1,793.50
<b>128385 Consumption (Gallons)</b>		<b>8,460.30</b>
<b>128385 Consumption (kBtu (thousand Btu))</b>		<b>1,173,363.24</b>
<b>Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))</b>		<b>1,173,363.24</b>
<b>Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?</b>		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

## Facility

Eugene Field Administration Building  
1 Merrison Street  
Teaneck , NJ 07666

## Facility Owner

Teaneck Board of Education  
1 Merrison Street  
Teaneck , NJ 07666

## Primary Contact for this Facility

Anthony D'Angelo  
1 Merrison Street  
Teaneck , NJ 07666

## General Information

Eugene Field Administration Building	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	24,877
Year Built	1955
For 12-month Evaluation Period Ending Date:	November 30, 2009

## Facility Space Use Summary

Administration Building	
Space Type	Office
Gross Floor Area(ft <sup>2</sup> )	24,877
Weekly operating hours	85
Workers on Main Shift	47
Number of PCs	25
Percent Cooled	50% or more
Percent Heated	50% or more

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 11/30/2009)	Baseline (Ending Date 06/30/2009)	Rating of 75	Target	National Average
Energy Performance Rating	82	81	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	74	75	83	N/A	112
Source (kBtu/ft <sup>2</sup> )	131	134	147	N/A	199
Energy Cost					
\$/year	\$ 44,837.44	\$ 47,663.90	\$ 50,391.40	N/A	\$ 68,131.35
\$/ft <sup>2</sup> /year	\$ 1.80	\$ 1.92	\$ 2.02	N/A	\$ 2.74
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	181	185	203	N/A	275
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	7	7	8	N/A	11

More than 50% of your building is defined as Office. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

### Notes:

- o - This attribute is optional.
- d - A default value has been supplied by Portfolio Manager.


# Statement of Energy Performance

## 2009

Eugene Field Administration Building  
1 Merrison Street  
Teaneck , NJ 07666

Portfolio Manager Building ID: 2244835

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).



This building uses 131 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending November 2009

**Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.**

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification





# STATEMENT OF ENERGY PERFORMANCE

## Hawthorne Elementary School

Building ID: 2244841

For 12-month Period Ending: November 30, 2009<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

**Facility**

Hawthorne Elementary School  
201 Fycke Lane  
Teaneck, NJ 07666

**Facility Owner**

Teaneck Board of Education  
1 Merrison Street  
Teaneck, NJ 07666

**Primary Contact for this Facility**

Anthony D'Angelo  
1 Merrison Street  
Teaneck, NJ 07666

Year Built: 1925

Gross Floor Area (ft<sup>2</sup>): 49,373Energy Performance Rating<sup>2</sup> (1-100) 3**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase(kBtu)	1,337,185
Natural Gas (kBtu) <sup>4</sup>	4,315,928
Total Energy (kBtu)	5,653,113

**Energy Intensity<sup>5</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	115
Source (kBtu/ft <sup>2</sup> /yr)	182

**Emissions (based on site energy use)**

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	433
---	-----

**Electric Distribution Utility**

Public Service Elec &amp; Gas Co

**National Average Comparison**

National Average Site EUI	62
National Average Source EUI	98
% Difference from National Average Source EUI	86%
Building Type	K-12 School

**Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Certifying Professional**

Matthew Goss  
11 British American Boulevard  
Latham, NY 12110

## Notes:

- Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
- The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
- Values represent energy consumption, annualized to a 12-month period.
- Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
- Values represent energy intensity, annualized to a 12-month period.
- Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Hawthorne Elementary School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	201 Fycke Lane, Teaneck, NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Hawthorne Elementary (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	49,373 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	20	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	0	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	20 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	12(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 678004502 (kWh (thousand Watt-hours))</b> <b>Space(s): Entire Facility</b> <b>Generation Method: Grid Purchase</b>		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
10/13/2009	11/11/2009	30,600.00
09/12/2009	10/12/2009	37,140.00
08/12/2009	09/11/2009	28,620.00
07/14/2009	08/11/2009	29,220.00
06/11/2009	07/13/2009	37,380.00
05/09/2009	06/10/2009	34,140.00
04/08/2009	05/08/2009	35,340.00
03/05/2009	04/07/2009	36,660.00
02/06/2009	03/04/2009	29,100.00
01/09/2009	02/05/2009	31,260.00
12/13/2008	01/08/2009	25,920.00
<b>678004502 Consumption (kWh (thousand Watt-hours))</b>		<b>355,380.00</b>
<b>678004502 Consumption (kBtu (thousand Btu))</b>		<b>1,212,556.56</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>1,212,556.56</b>
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 2415218 (therms)</b> <b>Space(s): Entire Facility</b>		
Start Date	End Date	Energy Use (therms)
10/13/2009	11/11/2009	4,731.45
09/12/2009	10/12/2009	237.08
08/12/2009	09/11/2009	0.00
07/14/2009	08/11/2009	0.00
06/11/2009	07/13/2009	0.00
05/09/2009	06/10/2009	173.91
04/08/2009	05/08/2009	1,861.66
03/05/2009	04/07/2009	6,009.98
02/06/2009	03/04/2009	7,300.52
01/09/2009	02/05/2009	8,213.68
12/13/2008	01/08/2009	7,750.37



<b>2415218 Consumption (therms)</b>	<b>36,278.65</b>
<b>2415218 Consumption (kBtu (thousand Btu))</b>	<b>3,627,865.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>	<b>3,627,865.00</b>
<b>Is this the total Natural Gas consumption at this building including all Natural Gas meters?</b>	<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
Hawthorne Elementary School  
201 Fycke Lane  
Teaneck, NJ 07666

**Facility Owner**  
Teaneck Board of Education  
1 Merrison Street  
Teaneck, NJ 07666

**Primary Contact for this Facility**  
Anthony D'Angelo  
1 Merrison Street  
Teaneck, NJ 07666

## General Information

Hawthorne Elementary School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	49,373
Year Built	1925
For 12-month Evaluation Period Ending Date:	November 30, 2009

## Facility Space Use Summary

Hawthorne Elementary	
Space Type	K-12 School
Gross Floor Area(ft <sup>2</sup> )	49,373
Open Weekends?	No
Number of PCs	20
Number of walk-in refrigeration/freezer units	0
Presence of cooking facilities	Yes
Percent Cooled	20
Percent Heated	90
Months <sup>o</sup>	12
High School?	No
School District <sup>o</sup>	Teaneck

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 11/30/2009)	Baseline (Ending Date 07/31/2008)	Rating of 75	Target	National Average
Energy Performance Rating	3	3	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	115	111	48	N/A	62
Source (kBtu/ft <sup>2</sup> )	182	179	77	N/A	98
Energy Cost					
\$/year	\$ 109,886.96	\$ 117,571.86	\$ 46,344.47	N/A	\$ 59,262.18
\$/ft <sup>2</sup> /year	\$ 2.23	\$ 2.38	\$ 0.94	N/A	\$ 1.20
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	433	426	183	N/A	234
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	9	9	4	N/A	5

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.

# Statement of Energy Performance

## 2009

Hawthorne Elementary School  
201 Fycke Lane  
Teaneck, NJ 07666

Portfolio Manager Building ID: 2244841

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).

This building's score



1

50

100

Least Efficient

Average

Most Efficient

This building uses 182 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending November 2009

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification





# STATEMENT OF ENERGY PERFORMANCE

## Teaneck High School

Building ID: 2244849  
 For 12-month Period Ending: October 31, 2009<sup>1</sup>  
 Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

### Facility

Teaneck High School  
 100 Elizabeth Avenue  
 Teaneck, NJ 07666

### Facility Owner

Teaneck Board of Education  
 1 Merrison Street  
 Teaneck, NJ 07666

### Primary Contact for this Facility

Anthony D'Angelo  
 1 Merrison Street  
 Teaneck, NJ 07666

Year Built: 1934

Gross Floor Area (ft<sup>2</sup>): 215,808

Energy Performance Rating<sup>2</sup> (1-100) 25

### Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu)	6,414,883
Fuel Oil (No. 2) (kBtu)	1,666,228
Natural Gas (kBtu) <sup>4</sup>	14,089,978
Total Energy (kBtu)	22,171,089

### Energy Intensity<sup>5</sup>

Site (kBtu/ft <sup>2</sup> /yr)	
Source (kBtu/ft <sup>2</sup> /yr)	N/A

### Emissions (based on site energy use)

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	N/A
---	-----

### Electric Distribution Utility

Public Service Elec & Gas Co

### National Average Comparison

National Average Site EUI	82
National Average Source EUI	141
% Difference from National Average Source EUI	
Building Type	K-12 School

### Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

### Certifying Professional

Matthew Goss  
 11 British American Boulevard  
 Latham, NY 12110

#### Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Teaneck High School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	100 Elizabeth Avenue, Teaneck, NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Teaneck High School (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	215,808 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	Yes	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select "yes" for open weekends. The "yes" response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	209	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	2	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	12(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	Yes	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	-----	--	--	--------------------------

## ENERGY STAR<sup>®</sup> Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 778014249 (kWh (thousand Watt-hours))</b> <b>Space(s):</b> Entire Facility <b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
09/11/2009	10/12/2009	187,777.00
08/12/2009	09/10/2009	182,746.00
07/14/2009	08/11/2009	158,334.00
06/11/2009	07/13/2009	173,605.00
05/09/2009	06/10/2009	203,936.00
04/08/2009	05/08/2009	171.67
03/05/2009	04/07/2009	205,955.00
02/06/2009	03/04/2009	147,647.00
01/09/2009	02/05/2009	154,999.00
12/14/2008	01/08/2009	127,374.00
11/12/2008	12/13/2008	171,453.00
<b>778014249 Consumption (kWh (thousand Watt-hours))</b>		<b>1,713,997.67</b>
<b>778014249 Consumption (kBtu (thousand Btu))</b>		<b>5,848,160.05</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>5,848,160.05</b>
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 3128206 (therms)</b> <b>Space(s):</b> Entire Facility		
Start Date	End Date	Energy Use (therms)
09/11/2009	10/12/2009	11,224.66
08/12/2009	09/10/2009	2,870.67
07/14/2009	08/11/2009	5,633.09
06/11/2009	07/13/2009	17,724.04
05/08/2009	06/10/2009	17,724.04
04/08/2009	05/08/2009	0.00
03/05/2009	04/07/2009	17,326.09
02/06/2009	03/04/2009	18,345.60
01/09/2009	02/05/2009	22,929.81
12/14/2008	01/08/2009	16,894.67
11/12/2008	12/13/2008	1,257.64

<b>3128206 Consumption (therms)</b>		<b>131,930.31</b>
<b>3128206 Consumption (kBtu (thousand Btu))</b>		<b>13,193,031.00</b>
<b>Meter: 3166301 (therms)</b> <b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (therms)</b>
09/11/2009	10/12/2009	125.33
08/12/2009	09/10/2009	27.13
07/14/2009	08/11/2009	7.30
06/11/2009	07/13/2009	41.69
05/09/2009	06/10/2009	109.34
04/08/2009	05/08/2009	96.94
03/05/2009	04/07/2009	129.63
02/06/2009	03/04/2009	113.12
01/09/2009	02/05/2009	160.99
12/14/2008	01/08/2009	106.53
11/12/2008	12/13/2008	140.08
<b>3166301 Consumption (therms)</b>		<b>1,058.08</b>
<b>3166301 Consumption (kBtu (thousand Btu))</b>		<b>105,808.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>		<b>13,298,839.00</b>
<b>Is this the total Natural Gas consumption at this building including all Natural Gas meters?</b>		<input type="checkbox"/>

<b>Fuel Type: Fuel Oil (No. 2)</b>		
<b>Meter: 128393 (Gallons)</b> <b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (Gallons)</b>
11/01/2008	11/30/2008	12,014.00
<b>128393 Consumption (Gallons)</b>		<b>12,014.00</b>
<b>128393 Consumption (kBtu (thousand Btu))</b>		<b>1,666,227.67</b>
<b>Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))</b>		<b>1,666,227.67</b>
<b>Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?</b>		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.



# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
Teaneck High School  
100 Elizabeth Avenue  
Teaneck, NJ 07666

**Facility Owner**  
Teaneck Board of Education  
1 Merrison Street  
Teaneck , NJ 07666

**Primary Contact for this Facility**  
Anthony D'Angelo  
1 Merrison Street  
Teaneck , NJ 07666

## General Information

Teaneck High School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	215,808
Year Built	1934
For 12-month Evaluation Period Ending Date:	October 31, 2009

## Facility Space Use Summary

Teaneck High School	
Space Type	K-12 School
Gross Floor Area(ft <sup>2</sup> )	215,808
Open Weekends?	Yes
Number of PCs	209
Number of walk-in refrigeration/freezer units	2
Presence of cooking facilities	Yes
Percent Cooled	90
Percent Heated	90
Months <sup>o</sup>	12
High School?	Yes
School District <sup>o</sup>	Teaneck

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 10/31/2009)	Baseline (Ending Date 11/30/2008)	Rating of 75	Target	National Average
Energy Performance Rating	25	22	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	N/A	115	68	N/A	82
Source (kBtu/ft <sup>2</sup> )	N/A	189	N/A	N/A	141
Energy Cost					
\$/year	\$ 481,342.50	\$ 656,629.23	N/A	N/A	N/A
\$/ft <sup>2</sup> /year	\$ 2.23	\$ 3.04	N/A	N/A	N/A
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	N/A	2,248	N/A	N/A	N/A
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	N/A	10	N/A	N/A	N/A

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.





# STATEMENT OF ENERGY PERFORMANCE

## Lowell Elementary School

Building ID: 2244844

For 12-month Period Ending: November 30, 2009<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

**Facility**

Lowell Elementary School  
1025 Lincoln Place  
Teaneck, NJ 07666

**Facility Owner**

Teaneck Board of Education  
1 Merrison Street  
Teaneck, NJ 07666

**Primary Contact for this Facility**

Anthony D'Angelo  
1 Merrison Street  
Teaneck, NJ 07666

Year Built: 1934

Gross Floor Area (ft<sup>2</sup>): 47,106Energy Performance Rating<sup>2</sup> (1-100) 18**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase(kBtu)	897,168
Fuel Oil (No. 2) (kBtu)	3,295,772
Natural Gas (kBtu) <sup>4</sup>	75,681
Total Energy (kBtu)	4,268,621

**Energy Intensity<sup>5</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	91
Source (kBtu/ft <sup>2</sup> /yr)	136

**Emissions (based on site energy use)**

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	383
---	-----

**Electric Distribution Utility**

Public Service Elec &amp; Gas Co

**National Average Comparison**

National Average Site EUI	67
National Average Source EUI	100
% Difference from National Average Source EUI	36%
Building Type	K-12 School

**Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Certifying Professional**

Matthew Goss  
11 British American Boulevard  
Latham, NY 12110

## Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Lowell Elementary School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	1025 Lincoln Place, Teaneck, NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Lowell Elementary (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	47,106 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	23	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	0	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	20 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	12(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 728001842 (kWh (thousand Watt-hours))</b> <b>Space(s): Entire Facility</b> <b>Generation Method: Grid Purchase</b>		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
10/09/2009	11/06/2009	24,160.00
09/10/2009	10/08/2009	27,960.00
08/08/2009	09/09/2009	9,280.00
07/10/2009	08/07/2009	8,960.00
06/09/2009	07/09/2009	20,800.00
05/07/2009	06/08/2009	24,960.00
04/04/2009	05/06/2009	23,520.00
03/04/2009	04/03/2009	28,640.00
02/04/2009	03/03/2009	22,080.00
01/07/2009	02/03/2009	25,540.00
12/11/2008	01/06/2009	20,320.00
<b>728001842 Consumption (kWh (thousand Watt-hours))</b>		<b>236,220.00</b>
<b>728001842 Consumption (kBtu (thousand Btu))</b>		<b>805,982.64</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>805,982.64</b>
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 2415218 (therms)</b> <b>Space(s): Entire Facility</b>		
Start Date	End Date	Energy Use (therms)
10/09/2009	11/06/2009	52.02
09/10/2009	10/08/2009	6.27
08/08/2009	09/09/2009	138.77
07/10/2009	08/07/2009	121.96
06/09/2009	07/09/2009	9.38
05/07/2009	06/08/2009	89.56
04/04/2009	05/06/2009	73.04
03/04/2009	04/03/2009	63.77
02/04/2009	03/03/2009	51.32
01/07/2009	02/03/2009	51.18
12/11/2008	01/06/2009	41.78

2415218 Consumption (therms)	699.05
2415218 Consumption (kBtu (thousand Btu))	69,905.00
Total Natural Gas Consumption (kBtu (thousand Btu))	69,905.00
Is this the total Natural Gas consumption at this building including all Natural Gas meters?	<input type="checkbox"/>

**Fuel Type: Fuel Oil (No. 2)**

<b>Meter: 128383 (Gallons)</b>		
<b>Space(s): Entire Facility</b>		
Start Date	End Date	Energy Use (Gallons)
11/01/2009	11/30/2009	3,485.50
10/01/2009	10/31/2009	0.00
09/01/2009	09/30/2009	0.00
08/01/2009	08/31/2009	0.00
07/01/2009	07/31/2009	0.00
06/01/2009	06/30/2009	0.00
05/01/2009	05/31/2009	0.00
04/01/2009	04/30/2009	2,501.00
03/01/2009	03/31/2009	4,800.80
02/01/2009	02/28/2009	2,200.10
01/01/2009	01/31/2009	6,035.40
12/01/2008	12/31/2008	4,740.70
<b>128383 Consumption (Gallons)</b>		<b>23,763.50</b>
<b>128383 Consumption (kBtu (thousand Btu))</b>		<b>3,295,771.70</b>
<b>Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))</b>		<b>3,295,771.70</b>
Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
Lowell Elementary School  
1025 Lincoln Place  
Teaneck, NJ 07666

**Facility Owner**  
Teaneck Board of Education  
1 Merrison Street  
Teaneck , NJ 07666

**Primary Contact for this Facility**  
Anthony D'Angelo  
1 Merrison Street  
Teaneck , NJ 07666

## General Information

Lowell Elementary School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	47,106
Year Built	1934
For 12-month Evaluation Period Ending Date:	November 30, 2009

## Facility Space Use Summary

Lowell Elementary	
Space Type	K-12 School
Gross Floor Area(ft <sup>2</sup> )	47,106
Open Weekends?	No
Number of PCs	23
Number of walk-in refrigeration/freezer units	0
Presence of cooking facilities	Yes
Percent Cooled	20
Percent Heated	90
Months <sup>o</sup>	12
High School?	No
School District <sup>o</sup>	Teaneck

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 11/30/2009)	Baseline (Ending Date 09/30/2008)	Rating of 75	Target	National Average
Energy Performance Rating	18	16	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	91	89	52	N/A	67
Source (kBtu/ft <sup>2</sup> )	136	139	78	N/A	100
Energy Cost					
\$/year	\$ 86,950.37	\$ 109,397.08	\$ 49,913.47	N/A	\$ 63,826.29
\$/ft <sup>2</sup> /year	\$ 1.85	\$ 2.32	\$ 1.06	N/A	\$ 1.36
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	383	386	220	N/A	281
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	8	8	5	N/A	6

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.




# Statement of Energy Performance

## 2009

Lowell Elementary School  
1025 Lincoln Place  
Teaneck, NJ 07666

Portfolio Manager Building ID: 2244844

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).



This building uses 136 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending November 2009

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification





# STATEMENT OF ENERGY PERFORMANCE

## Thomas Jefferson Middle School

Building ID: 2244879

For 12-month Period Ending: November 30, 2009<sup>1</sup>

Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

**Facility**

Thomas Jefferson Middle School  
655 Teaneck Road  
Teaneck, NJ 07666

**Facility Owner**

Teaneck Board of Education  
1 Merrison Street  
Teaneck, NJ 07666

**Primary Contact for this Facility**

Anthony D'Angelo  
1 Merrison Street  
Teaneck, NJ 07666

Year Built: 1958

Gross Floor Area (ft<sup>2</sup>): 105,216Energy Performance Rating<sup>2</sup> (1-100) 30**Site Energy Use Summary<sup>3</sup>**

Electricity - Grid Purchase(kBtu)	2,537,875
Fuel Oil (No. 2) (kBtu)	5,687,892
Natural Gas (kBtu) <sup>4</sup>	797,693
Total Energy (kBtu)	9,023,460

**Energy Intensity<sup>5</sup>**

Site (kBtu/ft <sup>2</sup> /yr)	86
Source (kBtu/ft <sup>2</sup> /yr)	143

**Emissions (based on site energy use)**

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	847
---	-----

**Electric Distribution Utility**

Public Service Elec &amp; Gas Co

**National Average Comparison**

National Average Site EUI	72
National Average Source EUI	120
% Difference from National Average Source EUI	19%
Building Type	K-12 School

**Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:**

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional
Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.

**Certifying Professional**

Matthew Goss  
11 British American Boulevard  
Latham, NY 12110

## Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR<sup>®</sup> Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Thomas Jefferson Middle School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	655 Teaneck Road, Teaneck, NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Thomas Jefferson Middle School (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	105,216 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	127	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	3	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	50 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	12(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 778015616 (kWh (thousand Watt-hours))</b> <b>Space(s):</b> Entire Facility <b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
10/13/2009	11/10/2009	68,400.00
09/12/2009	10/12/2009	59,280.00
08/12/2009	09/11/2009	46,080.00
07/14/2009	08/11/2009	31,920.00
06/11/2009	07/13/2009	51,840.00
05/09/2009	06/10/2009	68,400.00
04/08/2009	05/08/2009	59,760.00
03/05/2009	04/07/2009	88,800.00
02/06/2009	03/04/2009	61,200.00
01/09/2009	02/05/2009	73,440.00
12/13/2008	01/08/2009	55,920.00
<b>778015616 Consumption (kWh (thousand Watt-hours))</b>		<b>665,040.00</b>
<b>778015616 Consumption (kBtu (thousand Btu))</b>		<b>2,269,116.48</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>2,269,116.48</b>
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 3340982 (therms)</b> <b>Space(s):</b> Entire Facility		
Start Date	End Date	Energy Use (therms)
10/13/2009	11/10/2009	401.57
09/12/2009	10/12/2009	507.57
08/12/2009	09/11/2009	466.39
07/14/2009	08/11/2009	511.80
06/11/2009	07/13/2009	683.79
05/09/2009	06/10/2009	791.42
04/08/2009	05/08/2009	747.37
03/05/2009	04/07/2009	896.95
02/06/2009	03/04/2009	658.83
01/09/2009	02/05/2009	761.05
12/13/2008	01/08/2009	697.65

<b>3340982 Consumption (therms)</b>	<b>7,124.39</b>
<b>3340982 Consumption (kBtu (thousand Btu))</b>	<b>712,439.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>	<b>712,439.00</b>
<b>Is this the total Natural Gas consumption at this building including all Natural Gas meters?</b>	<input type="checkbox"/>

**Fuel Type: Fuel Oil (No. 2)**

<b>Meter: 128387 (Gallons)</b>		
<b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (Gallons)</b>
11/01/2009	11/30/2009	6,521.00
10/01/2009	10/31/2009	0.00
09/01/2009	09/30/2009	0.00
08/01/2009	08/31/2009	0.00
07/01/2009	07/31/2009	0.00
06/01/2009	06/30/2009	0.00
05/01/2009	05/31/2009	0.00
04/01/2009	04/30/2009	7,226.20
03/01/2009	03/31/2009	2,800.00
02/01/2009	02/28/2009	7,899.60
01/01/2009	01/31/2009	10,052.80
12/01/2008	12/31/2008	6,511.80
<b>128387 Consumption (Gallons)</b>		<b>41,011.40</b>
<b>128387 Consumption (kBtu (thousand Btu))</b>		<b>5,687,891.57</b>
<b>Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))</b>		<b>5,687,891.57</b>
<b>Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?</b>		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

## Facility

Thomas Jefferson Middle School  
655 Teaneck Road  
Teaneck, NJ 07666

## Facility Owner

Teaneck Board of Education  
1 Merrison Street  
Teaneck, NJ 07666

## Primary Contact for this Facility

Anthony D'Angelo  
1 Merrison Street  
Teaneck, NJ 07666

## General Information

Thomas Jefferson Middle School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	105,216
Year Built	1958
For 12-month Evaluation Period Ending Date:	November 30, 2009

## Facility Space Use Summary

Thomas Jefferson Middle School	
Space Type	K-12 School
Gross Floor Area(ft <sup>2</sup> )	105,216
Open Weekends?	No
Number of PCs	127
Number of walk-in refrigeration/freezer units	3
Presence of cooking facilities	Yes
Percent Cooled	50
Percent Heated	90
Months <sup>o</sup>	12
High School?	No
School District <sup>o</sup>	Teaneck

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 11/30/2009)	Baseline (Ending Date 09/30/2008)	Rating of 75	Target	National Average
Energy Performance Rating	30	25	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	86	90	56	N/A	72
Source (kBtu/ft <sup>2</sup> )	143	151	94	N/A	120
Energy Cost					
\$/year	\$ 198,824.13	\$ 249,101.30	\$ 130,571.07	N/A	\$ 166,969.61
\$/ft <sup>2</sup> /year	\$ 1.89	\$ 2.37	\$ 1.24	N/A	\$ 1.59
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	847	891	556	N/A	711
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	8	8	5	N/A	7

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.







# STATEMENT OF ENERGY PERFORMANCE

## Whittier Elementary School

Building ID: 2244881  
 For 12-month Period Ending: November 30, 2009<sup>1</sup>  
 Date SEP becomes ineligible: N/A

Date SEP Generated: May 04, 2010

<b>Facility</b> Whittier Elementary School 491 West Englewood Avenue Teaneck, NJ 07666	<b>Facility Owner</b> Teaneck Board of Education 1 Merrison Street Teaneck , NJ 07666	<b>Primary Contact for this Facility</b> Anthony D'Angelo 1 Merrison Street Teaneck , NJ 07666
---	--	---

Year Built: 1921  
 Gross Floor Area (ft<sup>2</sup>): 55,118

Energy Performance Rating<sup>2</sup> (1-100) 15

### Site Energy Use Summary<sup>3</sup>

Electricity - Grid Purchase(kBtu)	1,267,811
Fuel Oil (No. 2) (kBtu)	3,850,478
Natural Gas (kBtu) <sup>4</sup>	34,633
Total Energy (kBtu)	5,152,922

### Energy Intensity<sup>5</sup>

Site (kBtu/ft <sup>2</sup> /yr)	93
Source (kBtu/ft <sup>2</sup> /yr)	148

### Emissions (based on site energy use)

Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	478
---	-----

### Electric Distribution Utility

Public Service Elec & Gas Co

### National Average Comparison

National Average Site EUI	66
National Average Source EUI	105
% Difference from National Average Source EUI	41%
Building Type	K-12 School

### Meets Industry Standards<sup>6</sup> for Indoor Environmental Conditions:

Ventilation for Acceptable Indoor Air Quality	N/A
Acceptable Thermal Environmental Conditions	N/A
Adequate Illumination	N/A

Stamp of Certifying Professional  Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate.
--

### Certifying Professional

Matthew Goss  
 11 British American Boulevard  
 Latham, NY 12110

#### Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

## ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

**Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.**

NOTE: You must check each box to indicate that each value is correct, OR include a note.

CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Building Name</b>	Whittier Elementary School	Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings?		<input type="checkbox"/>
<b>Type</b>	K-12 School	Is this an accurate description of the space in question?		<input type="checkbox"/>
<b>Location</b>	491 West Englewood Avenue, Teaneck, NJ 07666	Is this address accurate and complete? Correct weather normalization requires an accurate zip code.		<input type="checkbox"/>
<b>Single Structure</b>	Single Facility	Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building		<input type="checkbox"/>
Whittier Elementary (K-12 School)				
CRITERION	VALUE AS ENTERED IN PORTFOLIO MANAGER	VERIFICATION QUESTIONS	NOTES	<input checked="" type="checkbox"/>
<b>Gross Floor Area</b>	55,118 Sq. Ft.	Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area.		<input type="checkbox"/>
<b>Open Weekends?</b>	No	Is this building normally open at all on the weekends? This includes activities beyond the work conducted by maintenance, cleaning, and security personnel. Weekend activity could include any time when the space is used for classes, performances or other school or community activities. If the building is open on the weekend as part of the standard schedule during one or more seasons, the building should select ?yes? for open weekends. The ?yes? response should apply whether the building is open for one or both of the weekend days.		<input type="checkbox"/>
<b>Number of PCs</b>	26	Is this the number of personal computers in the K12 School?		<input type="checkbox"/>
<b>Number of walk-in refrigeration/freezer units</b>	0	Is this the total number of commercial walk-in type freezers and coolers? These units are typically found in storage and receiving areas.		<input type="checkbox"/>
<b>Presence of cooking facilities</b>	Yes	Does this school have a dedicated space in which food is prepared and served to students? If the school has space in which food for students is only kept warm and/or served to students, or has only a galley that is used by teachers and staff then the answer is "no".		<input type="checkbox"/>
<b>Percent Cooled</b>	40 %	Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment?		<input type="checkbox"/>
<b>Percent Heated</b>	90 %	Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment?		<input type="checkbox"/>
<b>Months</b>	12(Optional)	Is this school in operation for at least 8 months of the year?		<input type="checkbox"/>

<b>High School?</b>	No	Is this building a high school (teaching grades 10, 11, and/or 12)? If the building teaches to high school students at all, the user should check 'yes' to 'high school'. For example, if the school teaches to grades K-12 (elementary/middle and high school), the user should check 'yes' to 'high school'.		<input type="checkbox"/>
---------------------	----	--	--	--------------------------

## ENERGY STAR® Data Checklist for Commercial Buildings

### Energy Consumption

**Power Generation Plant or Distribution Utility:** Public Service Elec & Gas Co

Fuel Type: Electricity		
<b>Meter: 778003529 (kWh (thousand Watt-hours))</b> <b>Space(s):</b> Entire Facility <b>Generation Method:</b> Grid Purchase		
Start Date	End Date	Energy Use (kWh (thousand Watt-hours))
10/10/2009	11/09/2009	27,400.00
09/11/2009	10/09/2009	34,200.00
08/11/2009	09/10/2009	38,000.00
07/11/2009	08/10/2009	34,000.00
06/10/2009	07/10/2009	23,000.00
05/08/2009	06/09/2009	23,000.00
04/07/2009	05/07/2009	31,400.00
03/05/2009	04/06/2009	36,000.00
02/06/2009	03/04/2009	28,600.00
01/08/2009	02/05/2009	30,800.00
12/12/2008	01/07/2009	26,200.00
<b>778003529 Consumption (kWh (thousand Watt-hours))</b>		<b>332,600.00</b>
<b>778003529 Consumption (kBtu (thousand Btu))</b>		<b>1,134,831.20</b>
<b>Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu))</b>		<b>1,134,831.20</b>
Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters?		<input type="checkbox"/>
Fuel Type: Natural Gas		
<b>Meter: 3175230 (therms)</b> <b>Space(s):</b> Entire Facility		
Start Date	End Date	Energy Use (therms)
10/10/2009	11/09/2009	14.57
09/11/2009	10/09/2009	38.64
08/11/2009	09/10/2009	35.48
07/10/2009	08/10/2009	17.72
06/13/2009	07/09/2009	16.68
05/08/2009	06/12/2009	18.74
04/07/2009	05/07/2009	31.30
03/05/2009	04/06/2009	40.77
02/06/2009	03/04/2009	22.00
01/08/2009	02/05/2009	34.50
12/12/2008	01/07/2009	18.80

<b>3175230 Consumption (therms)</b>	<b>289.20</b>
<b>3175230 Consumption (kBtu (thousand Btu))</b>	<b>28,920.00</b>
<b>Total Natural Gas Consumption (kBtu (thousand Btu))</b>	<b>28,920.00</b>
<b>Is this the total Natural Gas consumption at this building including all Natural Gas meters?</b>	<input type="checkbox"/>

**Fuel Type: Fuel Oil (No. 2)**

<b>Meter: 128381 (Gallons)</b>		
<b>Space(s): Entire Facility</b>		
<b>Start Date</b>	<b>End Date</b>	<b>Energy Use (Gallons)</b>
11/01/2009	11/30/2009	2,000.10
10/01/2009	10/31/2009	0.00
09/01/2009	09/30/2009	0.00
08/01/2009	08/31/2009	0.00
07/01/2009	07/31/2009	0.00
06/01/2009	06/30/2009	0.00
05/01/2009	05/31/2009	0.00
04/01/2009	04/30/2009	2,264.70
03/01/2009	03/31/2009	2,667.80
02/01/2009	02/28/2009	5,311.80
01/01/2009	01/31/2009	8,558.60
12/01/2008	12/31/2008	6,960.10
<b>128381 Consumption (Gallons)</b>		<b>27,763.10</b>
<b>128381 Consumption (kBtu (thousand Btu))</b>		<b>3,850,478.22</b>
<b>Total Fuel Oil (No. 2) Consumption (kBtu (thousand Btu))</b>		<b>3,850,478.22</b>
<b>Is this the total Fuel Oil (No. 2) consumption at this building including all Fuel Oil (No. 2) meters?</b>		<input type="checkbox"/>

<b>Additional Fuels</b>	
Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility.	<input type="checkbox"/>

<b>On-Site Solar and Wind Energy</b>	
Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported.	<input type="checkbox"/>

## Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

Signature is required when applying for the ENERGY STAR.

# FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

**Facility**  
Whittier Elementary School  
491 West Englewood Avenue  
Teaneck, NJ 07666

**Facility Owner**  
Teaneck Board of Education  
1 Merrison Street  
Teaneck, NJ 07666

**Primary Contact for this Facility**  
Anthony D'Angelo  
1 Merrison Street  
Teaneck, NJ 07666

## General Information

Whittier Elementary School	
Gross Floor Area Excluding Parking: (ft <sup>2</sup> )	55,118
Year Built	1921
For 12-month Evaluation Period Ending Date:	November 30, 2009

## Facility Space Use Summary

Whittier Elementary	
Space Type	K-12 School
Gross Floor Area(ft <sup>2</sup> )	55,118
Open Weekends?	No
Number of PCs	26
Number of walk-in refrigeration/freezer units	0
Presence of cooking facilities	Yes
Percent Cooled	40
Percent Heated	90
Months <sup>o</sup>	12
High School?	No
School District <sup>o</sup>	Teaneck

## Energy Performance Comparison

Performance Metrics	Evaluation Periods		Comparisons		
	Current (Ending Date 11/30/2009)	Baseline (Ending Date 11/30/2009)	Rating of 75	Target	National Average
Energy Performance Rating	15	15	75	N/A	50
Energy Intensity					
Site (kBtu/ft <sup>2</sup> )	93	93	52	N/A	66
Source (kBtu/ft <sup>2</sup> )	148	148	82	N/A	105
Energy Cost					
\$/year	\$ 105,559.11	\$ 105,559.11	\$ 58,679.08	N/A	\$ 75,039.67
\$/ft <sup>2</sup> /year	\$ 1.92	\$ 1.92	\$ 1.07	N/A	\$ 1.36
Greenhouse Gas Emissions					
MtCO <sub>2</sub> e/year	478	478	266	N/A	340
kgCO <sub>2</sub> e/ft <sup>2</sup> /year	9	9	5	N/A	6

More than 50% of your building is defined as K-12 School. Please note that your rating accounts for all of the spaces listed. The National Average column presents energy performance data your building would have if your building had an average rating of 50.

Notes:

o - This attribute is optional.

d - A default value has been supplied by Portfolio Manager.


# Statement of Energy Performance

## 2009

Whittier Elementary School  
491 West Englewood Avenue  
Teaneck, NJ 07666

Portfolio Manager Building ID: 2244881

The energy use of this building has been measured and compared to other similar buildings using the Environmental Protection Agency's (EPA's) Energy Performance Scale of 1–100, with 1 being the least energy efficient and 100 the most energy efficient. For more information, visit [energystar.gov/benchmark](http://energystar.gov/benchmark).



This building uses 148 kBtu per square foot per year.\*

\*Based on source energy intensity for the 12 month period ending November 2009

Buildings with a score of 75 or higher may qualify for EPA's ENERGY STAR.

I certify that the information contained within this statement is accurate and in accordance with U.S. Environmental Protection Agency's measurement standards, found at [energystar.gov](http://energystar.gov)

Date of certification




APPENDIX C


EQUEST MODEL RUN SUMMARIES



**Electric Consumption (kWh)**



**Gas Consumption (Btu)**



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling


**Electric Consumption (kWh x000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	0.04	0.04	0.07	0.45	3.16	5.89	2.01	2.39	4.34	1.47	0.02	0.04	19.91
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	6.09	4.93	4.05	2.32	0.55	0.05	-	-	0.15	0.92	3.10	5.25	27.41
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	1.38	1.41	1.70	1.59	1.37	1.13	0.46	0.45	1.01	1.16	1.24	1.41	14.31
Vent. Fans	13.37	12.08	13.38	12.94	13.37	9.99	1.82	1.91	10.29	13.37	12.94	13.38	128.85
Pumps & Aux.	1.44	1.29	1.87	1.84	1.81	1.63	1.35	1.35	1.64	1.84	1.86	1.96	19.89
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	3.14	3.09	3.69	3.54	3.28	2.99	1.50	1.55	3.04	3.28	3.26	3.42	35.78
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	7.96	7.84	9.37	8.97	8.32	7.57	3.77	3.88	7.69	8.32	8.27	8.67	90.62
<b>Total</b>	<b>33.42</b>	<b>30.69</b>	<b>34.12</b>	<b>31.66</b>	<b>31.85</b>	<b>29.26</b>	<b>10.91</b>	<b>11.53</b>	<b>28.16</b>	<b>30.36</b>	<b>30.71</b>	<b>34.12</b>	<b>336.78</b>


**Gas Consumption (Btu x000,000,000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	1.09	0.87	0.68	0.37	0.08	0.01	-	-	0.02	0.15	0.49	0.89	4.66
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>1.09</b>	<b>0.87</b>	<b>0.68</b>	<b>0.37</b>	<b>0.08</b>	<b>0.01</b>	<b>-</b>	<b>-</b>	<b>0.02</b>	<b>0.15</b>	<b>0.49</b>	<b>0.89</b>	<b>4.66</b>

**Electric Consumption (kWh)**



**Gas Consumption (Btu)**



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling


**Electric Consumption (kWh x000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	0.02	0.05	0.18	0.48	0.85	0.92	1.00	0.78	0.46	0.16	0.03	4.94
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	0.02	0.01	0.00	-	-	-	-	-	-	-	-	0.00	0.04
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	18.14	17.00	15.59	15.32	16.65	15.15	12.91	13.27	16.03	16.65	17.16	16.29	190.16
Pumps & Aux.	11.83	10.61	11.38	8.77	2.23	0.24	0.02	0.00	0.61	3.99	8.95	11.03	69.65
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	22.48	21.31	20.84	21.00	23.02	19.48	16.15	16.34	21.41	23.02	22.63	20.84	248.53
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	36.08	35.53	31.28	32.70	37.68	27.58	16.32	16.83	33.63	37.68	37.49	31.28	374.07
<b>Total</b>	<b>88.55</b>	<b>84.47</b>	<b>79.14</b>	<b>77.96</b>	<b>80.07</b>	<b>63.31</b>	<b>46.32</b>	<b>47.45</b>	<b>72.46</b>	<b>81.80</b>	<b>86.40</b>	<b>79.46</b>	<b>887.39</b>


**Gas Consumption (Btu x000,000,000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	1.08	0.84	0.58	0.31	0.05	-	-	-	0.00	0.09	0.40	0.73	4.07
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.01	0.02	0.02	0.02	0.20
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>1.10</b>	<b>0.86</b>	<b>0.60</b>	<b>0.33</b>	<b>0.08</b>	<b>0.02</b>	<b>0.01</b>	<b>0.01</b>	<b>0.02</b>	<b>0.11</b>	<b>0.42</b>	<b>0.75</b>	<b>4.30</b>

**Electric Consumption (kWh)**



**Gas Consumption (Btu)**



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling


**Electric Consumption (kWh x000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	1.36	1.22	1.36	1.41	2.46	4.18	2.75	2.67	2.74	1.88	1.31	1.36	24.70
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	1.99	1.60	1.28	0.76	0.19	0.02	-	-	0.04	0.33	0.98	1.62	8.82
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	4.63	4.18	4.63	4.48	4.63	3.47	0.65	0.68	3.57	4.63	4.48	4.63	44.65
Pumps & Aux.	2.65	2.38	2.56	2.31	2.09	1.65	0.72	0.73	1.68	2.19	2.38	2.61	23.95
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	2.06	2.03	2.44	2.33	2.16	2.27	2.02	2.11	2.20	2.16	2.15	2.25	26.17
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	5.95	5.87	7.03	6.73	6.22	6.54	5.83	6.07	6.34	6.22	6.19	6.49	75.49
<b>Total</b>	<b>18.64</b>	<b>17.29</b>	<b>19.29</b>	<b>18.03</b>	<b>17.75</b>	<b>18.13</b>	<b>11.98</b>	<b>12.26</b>	<b>16.56</b>	<b>17.40</b>	<b>17.49</b>	<b>18.95</b>	<b>203.78</b>


**Gas Consumption (Btu x000,000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	282.3	226.1	180.0	106.7	27.0	2.5	-	-	5.9	46.8	137.8	227.9	1,243.0
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	3.1	3.1	3.8	3.5	3.0	2.9	2.4	2.4	2.5	2.6	2.8	3.1	35.2
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>285.4</b>	<b>229.2</b>	<b>183.8</b>	<b>110.2</b>	<b>30.0</b>	<b>5.4</b>	<b>2.4</b>	<b>2.4</b>	<b>8.4</b>	<b>49.4</b>	<b>140.6</b>	<b>231.0</b>	<b>1,278.2</b>

### Electric Consumption (kWh)



### Gas Consumption (Btu)



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling


#### Electric Consumption (kWh x000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	0.12	0.89	1.44	0.99	0.97	1.07	0.27	0.09	-	5.83
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	3.77	3.31	2.87	1.74	0.22	0.05	-	0.00	0.17	1.02	2.19	3.57	18.90
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	1.31	1.33	1.60	1.51	1.30	1.17	0.76	0.75	1.03	1.11	1.14	1.34	14.34
Vent. Fans	7.13	6.44	7.13	6.90	7.13	6.66	6.18	6.19	6.68	7.13	6.90	7.13	81.62
Pumps & Aux.	1.14	1.03	1.12	1.03	0.93	0.89	0.92	0.92	0.91	1.00	1.04	1.14	12.08
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	6.09	5.99	7.16	6.86	6.36	6.36	4.86	5.05	6.26	6.36	6.06	6.63	74.03
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	17.90	17.63	21.07	20.19	18.70	18.68	14.22	14.76	18.39	18.70	17.81	19.49	217.53
<b>Total</b>	<b>37.33</b>	<b>35.73</b>	<b>40.96</b>	<b>38.35</b>	<b>35.52</b>	<b>35.25</b>	<b>27.92</b>	<b>28.63</b>	<b>34.52</b>	<b>35.58</b>	<b>35.22</b>	<b>39.30</b>	<b>424.32</b>


#### Gas Consumption (Btu x000,000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	926.8	798.3	627.7	352.0	42.0	8.5	-	0.1	32.1	197.5	457.2	853.4	4,295.6
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>926.8</b>	<b>798.3</b>	<b>627.7</b>	<b>352.0</b>	<b>42.0</b>	<b>8.5</b>	<b>-</b>	<b>0.1</b>	<b>32.1</b>	<b>197.5</b>	<b>457.2</b>	<b>853.4</b>	<b>4,295.6</b>

**Electric Consumption (kWh)**



**Gas Consumption (Btu)**



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling

**Electric Consumption (kWh x000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	0.01	0.42	2.36	4.00	4.06	3.90	2.72	0.85	0.28	-	18.60
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	3.06	2.61	2.03	1.13	0.16	0.04	-	-	0.12	0.67	1.55	2.84	14.21
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	7.44	6.72	7.47	7.21	7.41	5.88	2.83	2.69	6.22	7.43	7.21	7.45	75.96
Pumps & Aux.	1.03	0.93	1.01	0.91	0.79	0.75	0.77	0.77	0.77	0.87	0.92	1.03	10.55
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	4.80	4.73	5.66	5.42	5.02	4.79	3.01	3.12	4.78	5.02	4.78	5.23	56.37
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	14.25	14.04	16.78	16.08	14.89	14.54	10.13	10.51	14.42	14.88	14.18	15.52	170.20
<b>Total</b>	<b>30.59</b>	<b>29.03</b>	<b>32.96</b>	<b>31.17</b>	<b>30.61</b>	<b>29.99</b>	<b>20.80</b>	<b>20.99</b>	<b>29.04</b>	<b>29.72</b>	<b>28.93</b>	<b>32.06</b>	<b>345.89</b>



**Gas Consumption (Btu x000,000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	633.1	537.9	390.9	211.4	28.6	6.8	-	-	21.7	123.1	291.0	580.8	2,825.3
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	5.8	5.9	7.1	6.7	5.8	5.2	3.2	3.2	4.6	4.9	5.0	5.9	63.4
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>638.9</b>	<b>543.9</b>	<b>398.0</b>	<b>218.2</b>	<b>34.3</b>	<b>12.0</b>	<b>3.2</b>	<b>3.2</b>	<b>26.2</b>	<b>128.0</b>	<b>296.1</b>	<b>586.8</b>	<b>2,888.7</b>



**Electric Consumption (kWh)**

**Gas Consumption (Btu)**



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling

**Electric Consumption (kWh x000)**


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	7.7	8.6	8.2	16.4	41.6	35.0	44.8	42.2	72.4	37.2	13.6	8.4	336.2
Heat Reject.	-	-	-	0.1	0.4	0.2	1.3	0.9	1.2	0.2	-	-	4.2
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	16.1	15.6	10.9	6.7	3.5	0.6	0.4	0.4	1.7	4.7	9.9	12.1	82.6
HP, Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	34.6	36.3	26.7	20.7	23.1	10.4	9.9	10.4	24.5	23.1	26.6	29.4	275.8
Pumps & Aux.	19.2	20.1	18.1	17.5	18.0	8.7	9.1	9.2	19.7	17.9	19.1	19.2	195.8
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	35.3	38.7	35.3	36.4	41.3	19.7	19.6	20.0	42.5	41.3	41.0	36.8	408.0
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	69.7	79.8	69.7	73.1	84.5	30.5	29.9	30.8	87.9	84.5	84.2	73.4	798.1
<b>Total</b>	<b>182.7</b>	<b>199.1</b>	<b>169.0</b>	<b>170.9</b>	<b>212.4</b>	<b>105.1</b>	<b>115.0</b>	<b>113.9</b>	<b>249.9</b>	<b>209.0</b>	<b>194.4</b>	<b>179.2</b>	<b>2,100.6</b>

**Gas Consumption (Btu x000,000,000)**


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	3.11	3.09	2.09	1.05	0.47	0.08	0.06	0.05	0.23	0.66	1.70	2.38	14.97
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.06	0.08	0.07	0.07	0.07	0.02	0.02	0.02	0.06	0.06	0.07	0.06	0.65
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>3.18</b>	<b>3.17</b>	<b>2.16</b>	<b>1.12</b>	<b>0.54</b>	<b>0.10</b>	<b>0.07</b>	<b>0.07</b>	<b>0.29</b>	<b>0.72</b>	<b>1.76</b>	<b>2.45</b>	<b>15.64</b>



**Electric Consumption (kWh)**



**Gas Consumption (Btu)**



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling


**Electric Consumption (kWh x000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	0.01	0.17	0.53	1.93	4.70	6.04	5.38	5.31	5.66	4.05	1.76	0.31	35.86
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	16.63	15.06	14.01	13.38	13.38	11.99	10.26	10.50	12.76	13.38	13.95	14.52	159.82
Pumps & Aux.	11.76	10.54	11.48	9.51	4.25	3.19	2.14	2.14	3.49	4.54	9.24	11.29	83.57
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	11.86	11.53	10.52	10.86	12.31	9.41	6.31	6.45	11.11	12.31	12.20	10.96	125.82
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	38.30	37.74	33.16	34.69	40.01	28.89	16.60	17.12	35.55	40.01	39.82	34.87	396.75
<b>Total</b>	<b>78.56</b>	<b>75.04</b>	<b>69.70</b>	<b>70.35</b>	<b>74.64</b>	<b>59.53</b>	<b>40.69</b>	<b>41.52</b>	<b>68.57</b>	<b>74.28</b>	<b>76.97</b>	<b>71.95</b>	<b>801.82</b>


**Gas Consumption (Btu x000,000,000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	1.41	1.13	0.83	0.48	0.14	0.07	0.05	0.05	0.07	0.18	0.57	0.98	5.95
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.03	0.03	0.02	0.02	0.03	0.02	0.01	0.01	0.02	0.02	0.02	0.02	0.25
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>1.44</b>	<b>1.16</b>	<b>0.86</b>	<b>0.51</b>	<b>0.17</b>	<b>0.09</b>	<b>0.05</b>	<b>0.06</b>	<b>0.09</b>	<b>0.21</b>	<b>0.59</b>	<b>1.00</b>	<b>6.23</b>

**Electric Consumption (kWh)**



**Gas Consumption (Btu)**



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling

**Electric Consumption (kWh x000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	3.41	3.07	3.48	4.33	11.60	18.93	6.34	5.97	11.70	7.01	3.30	3.40	82.55
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	5.63	4.57	3.68	2.04	0.44	0.04	-	-	0.16	0.84	2.84	4.92	25.15
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	4.56	4.21	4.79	4.64	4.67	3.54	0.57	0.56	3.68	4.67	4.40	4.67	44.97
Pumps & Aux.	4.58	4.13	4.55	4.35	4.38	3.74	2.48	2.48	3.81	4.42	4.37	4.57	47.85
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	6.32	5.96	6.86	6.83	6.32	5.66	2.57	2.49	5.78	6.59	6.02	6.86	68.26
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	13.99	13.20	15.20	15.14	13.99	12.52	5.60	5.43	12.79	14.60	13.33	15.20	150.97
<b>Total</b>	<b>38.49</b>	<b>35.15</b>	<b>38.56</b>	<b>37.32</b>	<b>41.41</b>	<b>44.43</b>	<b>17.55</b>	<b>16.93</b>	<b>37.92</b>	<b>38.12</b>	<b>34.25</b>	<b>39.63</b>	<b>419.76</b>

**Gas Consumption (Btu x000,000,000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	1.02	0.80	0.61	0.34	0.07	0.01	-	-	0.02	0.13	0.45	0.85	4.29
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.01	0.01	0.01	0.01	0.08
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
<b>Total</b>	<b>1.02</b>	<b>0.80</b>	<b>0.62</b>	<b>0.34</b>	<b>0.08</b>	<b>0.01</b>	<b>0.00</b>	<b>0.00</b>	<b>0.03</b>	<b>0.14</b>	<b>0.46</b>	<b>0.86</b>	<b>4.37</b>



APPENDIX D  
LIGHTING SPREADSHEETS

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Ball (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total		
Athletic Field Lights	000	Athletic Field Lights	(21) 1000W Metal Halide Fixture/Tower	4	90720	90.72	50	4536	\$4,848.5	None Proposed	4	90720	90.72	50	50	4536	4536	None Proposed	3	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Benjamin Franklin Middle School - Exterior	000	Exterior	13W CFL Fixture	5	65	0.065	5110	332.15	\$51.2	None Proposed	5	65	0.065	5110	5110	332.15	332.15	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Benjamin Franklin Middle School - Exterior	000	Exterior	Exterior Wall Packs (Assume 70w)	9	810	0.81	5110	4139.1	\$637.8	Replace 70W Wall Pack fixture with LED Area Light	9	495	0.495	5110	5110	2529.45	2529.45	None Proposed	0	0.315	1609.65	248.0	\$0.0	\$800.0	\$196.0	\$0.0	\$0.0	\$186.0	\$800.0	\$986.0	\$1,674.0	\$7,200.0	\$8,874.0		
Benjamin Franklin Middle School - Exterior	000	Exterior	Flood Lights (Assume 400W MH)	8	3684	3.684	5110	18723.04	\$2,865.2	Replace 400W MH fixture with LED Area Light	8	1856	1.856	5110	5110	9484.16	9484.16	None Proposed	0	1.808	9238.88	1,423.7	\$0.0	\$2,000.0	\$133.0	\$0.0	\$0.0	\$133.0	\$2,000.0	\$2,133.0	\$1,064.0	\$16,000.0	\$17,064.0		
Benjamin Franklin Middle School - Exterior	000	Exterior	Pole Mounted Luminaire - 1 Head (Assume 400W MH)	5	2290	2.29	5110	11701.9	\$1,803.3	Replace 400W MH fixture with LED Area Light	5	1160	1.16	5110	5110	5927.6	5927.6	None Proposed	0	1.13	5774.3	889.8	\$1,200.0	\$2,000.0	\$703.0	\$0.0	\$0.0	\$703.0	\$3,200.0	\$3,903.0	\$3,515.0	\$16,000.0	\$19,515.0		
Benjamin Franklin Middle School - Exterior	000	Exterior	Pole Mounted Luminaire - 2 Head (Assume 400W MH)	2	1832	1.832	5110	9361.52	\$1,442.6	Replace 400W MH fixture with LED Area Light	2	928	0.928	5110	5110	4742.08	4742.08	None Proposed	0	0.904	4619.44	711.9	\$1,200.0	\$4,000.0	\$836.0	\$0.0	\$0.0	\$836.0	\$5,200.0	\$6,036.0	\$1,672.0	\$10,400.0	\$12,072.0		
Benjamin Franklin Middle School - Interior	001	101	13W CFL Fixture	1	13	0.013	3285	42.705	\$6.6	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Benjamin Franklin Middle School - Interior	001	101	150W Incandescent Fixture	2	300	0.3	3285	985.5	\$151.9	Replace 150W Incandescent Fixture with 25W CFL	2	50	0.05	3285	3285	164.25	164.25	None Proposed	0	0.25	821.25	126.6	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$40.0	\$14.0	\$54.0		
Benjamin Franklin Middle School - Interior	001	101	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	2	85.6	0.0856	3285	281.196	\$43.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	48.64	0.04864	3285	3285	159.7824	159.7824	None Proposed	0	0.03696	121.4136	18.7	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$130.0	\$80.0	\$210.0		
Benjamin Franklin Middle School - Interior	001	101	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	27	2311.2	2.3112	3285	7592.292	\$1,170.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	27	1312.2	1.3122	3285	3285	4310.577	4310.577	None Proposed	0	0.999	3281.715	505.7	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$1,755.0	\$2,160.0	\$3,915.0		
Benjamin Franklin Middle School - Interior	001	102	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	10	1712	1.712	3285	5623.92	\$866.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	973	0.973	3285	3285	3196.305	3196.305	None Proposed	0	0.739	2427.615	374.1	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$650.0	\$1,250.0	\$1,900.0		
Benjamin Franklin Middle School - Interior	001	103	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	570	48792	48.792	3285	160281.72	\$24,699.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	570	27702	27.702	3285	3285	91001.07	91001.07	None Proposed	0	21.09	69280.65	10,676.1	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$37,050.0	\$45,600.0	\$82,650.0		
Benjamin Franklin Middle School - Interior	001	104	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	105	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	106	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	107	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	108	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	109	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	110	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	112	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	12	2054.4	2.0544	3285	6748.704	\$1,040.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	1167.6	1.1676	3285	3285	3835.566	3835.566	None Proposed	0	0.8868	2913.138	448.9	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$780.0	\$1,500.0	\$2,280.0		
Benjamin Franklin Middle School - Interior	001	113	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	12	2054.4	2.0544	3285	6748.704	\$1,040.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	1167.6	1.1676	3285	3285	3835.566	3835.566	None Proposed	0	0.8868	2913.138	448.9	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$780.0	\$1,500.0	\$2,280.0		
Benjamin Franklin Middle School - Interior	001	114	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	11	1883.2	1.8832	3285	6186.312	\$953.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	11	1070.3	1.0703	3285	3285	3515.9355	3515.9355	None Proposed	0	0.8129	2670.3765	411.5	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$715.0	\$1,375.0	\$2,090.0		
Benjamin Franklin Middle School - Interior	001	115	2x4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	6	672	0.672	3285	2207.52	\$340.2	None Proposed	6	672	0.672	3285	3285	2207.52	2207.52	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Benjamin Franklin Middle School - Interior	001	112A	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	224.5	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0		
Benjamin Franklin Middle School - Interior	001	Boiler Room	13W CFL Fixture	19	247	0.247	3285	811.395	\$125.0	None Proposed	19	247	0.247	3285	3285	811.395	811.395	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Benjamin Franklin Middle School - Interior	001	Boiler Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0		
Benjamin Franklin Middle School - Interior	001	Boiler Room	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$340.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	149.6	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$290.0	\$500.0	\$760.0		
Benjamin Franklin Middle School - Interior	001	Boy's Locker Room	13W CFL Fixture	1	13	0.013	3285	42.705	\$6.6	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Benjamin Franklin Middle School - Interior	001	Boy's Locker Room	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	21	1064.7	1.0647	3285	3497.5395	\$539.0	None Proposed	21	1064.7	1.0647	3285	3285	3497.5395	3497.5395	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	001	Boy's Locker Room	60W Incandescent Fixture	2	120	0.12	3285	394.2	\$60.7	Replace 60W Incandescent Fixture with 13W CFL	2	26	0.026	3285	3285	85.41	85.41	None Proposed	0	0.094	308.79	47.6	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$40.0	\$10.0	\$50.0		
Benjamin Franklin Middle School - Interior	001	Child Study	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$89.1	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$												

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total	
Benjamin Franklin Middle School - Interior	001	OM Office	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$267.3	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	001	Shop	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	25	2140	2.14	3285	7029.9	\$1,083.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	25	1215	1.215	3285	3285	3991.275	3991.275	None Proposed	0	0.925	3038.625	468.2	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$1,625.0	\$2,000.0	\$3,625.0	
Benjamin Franklin Middle School - Interior	001	Shop	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	24	4108.8	4.1088	3285	13497.408	\$2,079.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	24	2335.2	2.3352	3285	3285	7671.132	7671.132	None Proposed	0	1.7736	5826.276	897.8	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$1,560.0	\$3,000.0	\$4,560.0	
Benjamin Franklin Middle School - Interior	001	Shop	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	3285	735.84	\$113.4	None Proposed	2	224	0.224	3285	3285	735.84	735.84	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Benjamin Franklin Middle School - Interior	001	Stage Dressing Room	13W CFL Fixture	21	273	0.273	3285	896.805	\$138.2	None Proposed	21	273	0.273	3285	3285	896.805	896.805	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	001	Stairwell	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	1	42.8	0.0428	8760	374.928	\$57.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	24.32	0.02432	8760	8760	213.0432	213.0432	None Proposed	0	0.01848	161.8848	24.9	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$65.0	\$40.0	\$105.0	
Benjamin Franklin Middle School - Interior	001	Stairwell	70 Watt Metal Halide Fixture	1	95	0.095	8760	832.2	\$128.2	None Proposed	1	95	0.095	8760	8760	832.2	832.2	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	001	Storage	13W CFL Fixture	2	26	0.026	500	13	\$2.0	None Proposed	2	26	0.026	500	500	13	9.1	Ceiling Mounted Occupancy Sensor	1	0	3.9	0.6	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Benjamin Franklin Middle School - Interior	001	Storage	13W CFL Fixture	4	52	0.052	500	26	\$4.0	None Proposed	4	52	0.052	500	500	26	18.2	Ceiling Mounted Occupancy Sensor	1	0	7.8	1.2	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Benjamin Franklin Middle School - Interior	001	Storage	13W CFL Fixture	2	26	0.026	500	13	\$2.0	None Proposed	2	26	0.026	500	500	13	9.1	Ceiling Mounted Occupancy Sensor	1	0	3.9	0.6	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Benjamin Franklin Middle School - Interior	001	Storage	13W CFL Fixture	1	13	0.013	500	6.5	\$1.0	None Proposed	1	13	0.013	500	500	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Benjamin Franklin Middle School - Interior	001	Storage	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	5	253.5	0.2535	500	126.75	\$19.5	None Proposed	5	253.5	0.2535	500	500	126.75	88.725	Ceiling Mounted Occupancy Sensor	1	0	38.025	5.9	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Benjamin Franklin Middle School - Interior	001	Storage	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	500	171.2	\$26.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	500	500	97.2	68.04	Ceiling Mounted Occupancy Sensor	1	0.148	103.16	15.9	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$333.5	\$423.0	\$766.5	
Benjamin Franklin Middle School - Interior	001	Storage	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	500	513.6	\$78.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	500	500	291.9	204.33	Ceiling Mounted Occupancy Sensor	1	0.4434	309.27	47.7	\$105.0	\$20.0	\$65.0	\$103.0	\$73.5	\$65.0	\$125.0	\$190.0	\$483.5	\$853.0	\$1,316.5	
Benjamin Franklin Middle School - Interior	001	Women's Bathroom	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$3.9	None Proposed	1	50.7	0.0507	500	500	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.2	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Benjamin Franklin Middle School - Interior	001	Women's Bathroom	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	3	152.1	0.1521	500	76.05	\$11.7	None Proposed	3	152.1	0.1521	500	500	76.05	53.235	Ceiling Mounted Occupancy Sensor	1	0	22.815	3.5	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Benjamin Franklin Middle School - Interior	002	201	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Benjamin Franklin Middle School - Interior	002	202	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Benjamin Franklin Middle School - Interior	002	203	2x2 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	3	256.8	0.2568	3285	843.588	\$130.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	145.8	0.1458	3285	3285	478.953	478.953	None Proposed	0	0.111	364.635	56.2	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$195.0	\$240.0	\$435.0	
Benjamin Franklin Middle School - Interior	002	203	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	9	1540.8	1.5408	3285	5061.528	\$780.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	9	875.7	0.8757	3285	3285	2876.6745	2876.6745	None Proposed	0	0.6651	2184.8535	336.7	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$585.0	\$1,125.0	\$1,710.0	
Benjamin Franklin Middle School - Interior	002	205	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	8	405.6	0.4056	3285	1332.396	\$205.3	None Proposed	8	405.6	0.4056	3285	3285	1332.396	1332.396	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	002	206	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Benjamin Franklin Middle School - Interior	002	207	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	12	608.4	0.6084	3285	1998.594	\$308.0	None Proposed	12	608.4	0.6084	3285	3285	1998.594	1998.594	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	002	208	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$534.6	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	002	209	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Benjamin Franklin Middle School - Interior	002	210	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Benjamin Franklin Middle School - Interior	002	211	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Benjamin Franklin Middle School - Interior	002	270	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	6	513.6	0.5136	3285	1687.176	\$260.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	291.6	0.2916	3285	3285	957.906	957.906	None Proposed	0	0.222	729.27	112.4	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$390.0	\$480.0	\$870.0	
Benjamin Franklin Middle School - Interior	002	205A	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	224.5	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0	
Benjamin Franklin Middle School - Interior	002	205B	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	8	896	0.896	3285	2943.36	\$453.6	None Proposed	8	896	0.896	3285	3285	2943.36	2943.36	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	002	Auditorium	150W Incandescent Fixture	23	3450	3.45	3285	11333.25	\$1,746.4	Replace 150W Incandescent Fixture with 25W CFL	23	575	0.575	3285	3285	1888.875	1888.875	None Proposed	0	2.875	9444.375	1,455.4	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$460.0	\$161.0	\$621.0	
Benjamin Franklin Middle School - Interior	002	AV Storage	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$346.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	149.6												

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total
Benjamin Franklin Middle School - Interior	002	Music Room	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	3285	562.382	\$86.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	3285	3285	319.302	319.302	None Proposed	0	0.074	243.09	37.5	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$130.0	\$160.0	\$290.0
Benjamin Franklin Middle School - Interior	002	Principle's Office	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$346.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	149.6	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$260.0	\$500.0	\$760.0
Benjamin Franklin Middle School - Interior	002	Reading Room	13x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$25.7	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	002	Reading Room	23x4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	4	448	0.448	3285	1471.68	\$228.8	None Proposed	4	448	0.448	3285	3285	1471.68	1471.68	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	002	Stage	100W Incandescent Fixture	4	400	0.4	3285	1314	\$202.5	Replace 100W Incandescent Fixture with 25W CFL	4	100	0.1	3285	3285	328.5	328.5	None Proposed	0	0.3	985.5	151.9	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$80.0	\$28.0	\$108.0
Benjamin Franklin Middle School - Interior	002	Stage	13W CFL Fixture	5	65	0.065	3285	213.525	\$32.9	None Proposed	5	65	0.065	3285	3285	213.525	213.525	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	002	Stage	150W Incandescent Fixture	4	600	0.6	3285	1971	\$303.7	Replace 150W Incandescent Fixture with 25W CFL	4	100	0.1	3285	3285	328.5	328.5	None Proposed	0	0.5	1642.5	253.1	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$80.0	\$28.0	\$108.0
Benjamin Franklin Middle School - Interior	002	Stage	60W Incandescent Fixture	1	60	0.06	3285	197.1	\$30.4	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0.047	154.395	23.8	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0
Benjamin Franklin Middle School - Interior	002	Stage Lights	150W Incandescent Fixture	134	20100	20.1	3285	66028.5	\$10,174.9	Replace 150W Incandescent Fixture with 25W CFL	134	3350	3.35	3285	3285	11004.75	11004.75	None Proposed	0	16.75	55023.75	8,479.1	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$2,680.0	\$938.0	\$3,618.0
Benjamin Franklin Middle School - Interior	002	Teachers Lounge	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	10	856	0.856	3285	2811.96	\$433.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	486	0.486	3285	3285	1596.51	1596.51	None Proposed	0	0.37	1215.45	187.3	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$650.0	\$800.0	\$1,450.0
Benjamin Franklin Middle School - Interior	002	Teachers Lounge	60W Incandescent Fixture	1	60	0.06	3285	197.1	\$30.4	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0.047	154.395	23.8	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0
Benjamin Franklin Middle School - Interior	002	Women's Bathroom	13W CFL Fixture	1	13	0.013	500	6.5	\$1.0	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Benjamin Franklin Middle School - Interior	002	Women's Bathroom	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	500	85.6	\$13.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	500	350	48.6	34.02	Ceiling Mounted Occupancy Sensor	1	0.074	51.58	7.9	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$203.5	\$263.0	\$466.5
Benjamin Franklin Middle School - Interior	002	Women's Bathroom	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	1	85.6	0.0856	500	42.8	\$6.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	48.6	0.0486	500	350	24.3	17.01	Ceiling Mounted Occupancy Sensor	1	0.037	25.79	4.0	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$138.5	\$183.0	\$321.5
Benjamin Franklin Middle School - Interior	002	Women's Bathroom	13x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	3	152.1	0.1521	500	76.05	\$11.7	None Proposed	3	152.1	0.1521	500	350	76.05	53.235	Ceiling Mounted Occupancy Sensor	1	0	22.815	3.5	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Benjamin Franklin Middle School - Interior	002	Women's Bathroom	2' 17W Fluorescent Fixture	1	15	0.015	500	7.5	\$1.2	None Proposed	1	15	0.015	500	350	7.5	5.25	Ceiling Mounted Occupancy Sensor	1	0	2.25	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Benjamin Franklin Middle School - Interior	003	301	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$760.0	\$960.0	\$1,740.0
Benjamin Franklin Middle School - Interior	003	302	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$760.0	\$960.0	\$1,740.0
Benjamin Franklin Middle School - Interior	003	303	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$760.0	\$960.0	\$1,740.0
Benjamin Franklin Middle School - Interior	003	304	23x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	10	507	0.507	3285	1665.495	\$256.7	None Proposed	10	507	0.507	3285	3285	1665.495	1665.495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	003	305	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$760.0	\$960.0	\$1,740.0
Benjamin Franklin Middle School - Interior	003	306	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$760.0	\$960.0	\$1,740.0
Benjamin Franklin Middle School - Interior	003	307	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	16	1369.6	1.3696	3285	4499.136	\$693.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	16	777.6	0.7776	3285	3285	2554.416	2554.416	None Proposed	0	0.592	1944.72	299.7	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$1,040.0	\$1,280.0	\$2,320.0
Benjamin Franklin Middle School - Interior	003	308	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	18	1540.8	1.5408	3285	5061.528	\$760.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	18	874.8	0.8748	3285	3285	2873.718	2873.718	None Proposed	0	0.666	2187.81	337.1	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$1,170.0	\$1,440.0	\$2,610.0
Benjamin Franklin Middle School - Interior	003	309	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	9	770.4	0.7704	3285	2530.764	\$390.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	9	437.4	0.4374	3285	3285	1436.859	1436.859	None Proposed	0	0.333	1093.905	168.6	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$585.0	\$720.0	\$1,305.0
Benjamin Franklin Middle School - Interior	003	310	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	3	513.6	0.5136	3285	1687.176	\$260.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	291.9	0.2919	3285	3285	958.8915	958.8915	None Proposed	0	0.2217	728.2845	112.2	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$195.0	\$375.0	\$570.0
Benjamin Franklin Middle School - Interior	003	304A	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$520.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	224.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$760.0	\$960.0	\$1,740.0
Benjamin Franklin Middle School - Interior	003	Hallway	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	52	2225.6	2.2256	4015	8935.784	\$1,377.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	52	1264.64	1.26464	4015	4015	5077.5296	5077.5296	None Proposed	0	0.96096	3858.2544	594.6	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$3,380.0	\$2,080.0	\$5,460.0
Benjamin Franklin Middle School - Interior	003	Hallway	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	48	2054.4	2.0544	4015	8248.416	\$1,271.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	48	1167.36	1.16736	4015	4015	4686.9504	4686.9504	None Proposed	0	0.86704	3561.4656	548.8	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$3,120.0	\$1,920.0	\$5,040.0
Benjamin Franklin Middle School - Interior	003	Hallway	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	46	1968.8	1.9688	4015	7904.732	\$1,218.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	46	1118.72	1.11872	4015	4015	4491.6608	4491.6608	None Proposed	0	0.85008	3413.0712	526.0	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$2,960.0	\$1,840.0	\$4,800.0
Benjamin Franklin Middle School - Interior	003	Hallway	70 Watt Metal Halide Fixture	24	2280	2.28	4015	9154.2	\$1,410.7	None Proposed	24	2280	2.28	4015	4015	9154.2	9154.2	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Benjamin Franklin Middle School - Interior	003	Janitor's Closet	13W CFL Fixture	1	13																												

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total		
Bryant Elementary School - Interior	001	14	13W CFL Fixture	2	26	0.026	3285	85.41	\$14.8	None Proposed	2	26	0.026	3285	3285	85.41	85.41	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Bryant Elementary School - Interior	001	14	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4499.136	\$778.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	336.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0			
Bryant Elementary School - Interior	001	16	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	8	405.6	0.4056	3285	1332.396	\$230.5	None Proposed	8	405.6	0.4056	3285	3285	1332.396	1332.396	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Bryant Elementary School - Interior	001	16	60W Incandescent Fixture	1	60	0.06	3285	197.1	\$34.1	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0.047	154.395	26.7	\$0.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0			
Bryant Elementary School - Interior	001	17	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4499.136	\$778.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	336.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0			
Bryant Elementary School - Interior	001	18	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4499.136	\$778.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	336.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0			
Bryant Elementary School - Interior	001	19	13W CFL Fixture	1	13	0.013	3285	42.705	\$7.4	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Bryant Elementary School - Interior	001	19	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4499.136	\$778.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	336.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0			
Bryant Elementary School - Interior	001	19	60W Incandescent Fixture	1	60	0.06	3285	197.1	\$34.1	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0.047	154.395	26.7	\$0.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0			
Bryant Elementary School - Interior	001	21	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	11	968	0.968	3285	3179.88	\$550.1	None Proposed	11	968	0.968	3285	3285	3179.88	3179.88	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Bryant Elementary School - Interior	001	22	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	3	336	0.336	3285	1103.76	\$190.9	None Proposed	3	336	0.336	3285	3285	1103.76	1103.76	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Bryant Elementary School - Interior	001	23	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	6	672	0.672	3285	2207.52	\$381.9	None Proposed	6	672	0.672	3285	3285	2207.52	2207.52	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Bryant Elementary School - Interior	001	24	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	10	1120	1.12	3285	3679.2	\$636.5	None Proposed	10	1120	1.12	3285	3285	3679.2	3679.2	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Bryant Elementary School - Interior	001	25	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4499.136	\$778.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	336.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0			
Bryant Elementary School - Interior	001	26	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4499.136	\$778.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	336.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0			
Bryant Elementary School - Interior	001	27	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4499.136	\$778.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	336.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0			
Bryant Elementary School - Interior	001	28	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	9	1008	1.008	3285	3311.28	\$572.8	None Proposed	9	1008	1.008	3285	3285	3311.28	3311.28	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Bryant Elementary School - Interior	001	29	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	9	1008	1.008	3285	3311.28	\$572.8	None Proposed	9	1008	1.008	3285	3285	3311.28	3311.28	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Bryant Elementary School - Interior	001	30	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	12	608.4	0.6084	3285	1998.594	\$345.7	None Proposed	12	608.4	0.6084	3285	3285	1998.594	1998.594	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Bryant Elementary School - Interior	001	32	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$583.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	252.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0			
Bryant Elementary School - Interior	001	33	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	4	448	0.448	3285	1471.68	\$254.6	None Proposed	4	448	0.448	3285	3285	1471.68	1471.68	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Bryant Elementary School - Interior	001	Backstage Area	13W CFL Fixture	1	13	0.013	3285	42.705	\$7.4	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Bryant Elementary School - Interior	001	Backstage Area	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	3285	562.392	\$97.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	3285	3285	319.302	319.302	None Proposed	0	0.074	243.09	42.1	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$130.0	\$160.0	\$290.0			
Bryant Elementary School - Interior	001	Backstage Area	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$389.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	168.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$260.0	\$500.0	\$760.0			
Bryant Elementary School - Interior	001	Boiler Room	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	10	1120	1.12	3285	3679.2	\$636.5	None Proposed	10	1120	1.12	3285	3285	3679.2	3679.2	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Bryant Elementary School - Interior	001	Boiler Room	30W Incandescent Fixture	1	30	0.03	3285	98.55	\$17.0	Replace 30W Incandescent Fixture with 13W CFL	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0.017	55.845	9.7	\$0.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0			
Bryant Elementary School - Interior	001	Boy's Bathroom	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	1	112	0.112	500	56	\$9.7	None Proposed	1	112	0.112	500	350	56	39.2	Ceiling Mounted Occupancy Sensor	1	0	16.8	2.9	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Bryant Elementary School - Interior	001	Boy's Bathroom	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	500	112	\$19.4	None Proposed	2	224	0.224	500	350	112	78.4	Ceiling Mounted Occupancy Sensor	1	0	33.6	5.8	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Bryant Elementary School - Interior	001	Boy's Bathroom	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	500	112	\$19.4	None Proposed	2	224	0.224	500	350	112	78.4	Ceiling Mounted Occupancy Sensor	1	0	33.6	5.8	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Bryant Elementary School - Interior	001	Cafeteria	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	3285	333.099	\$57.6	None Proposed	2	101.4	0.1014	3285	3285	333.099	333.099	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Bryant Elementary School - Interior	001	Cafeteria	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	3	152.1	0.1521	3285	499.6485	\$86.4	None Proposed	3	152.1	0.1521	3285	3285	499.6485	499.6485	None Proposed	0	0	0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Bryant Elementary School - Interior	001	Cafeteria	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	28	4793.6	4.7936	3285	15746.976	\$2,724.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	28	2724.4	2.7244	3285	3285	8949.654	8949.654	None Proposed	0	2.0692	6797.322	1,175.9	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$1,820.0	\$3,500.0	\$5,320.0			
Bryant Elementary School - Interior	001	Copy Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	3285	562.392	\$97.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	3285	3285	319.302																			

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total
Eugene Field Administration Building - Interior	001	Boiler Room	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	5	856	0.856	3285	2811.96	\$463.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	5	486.5	0.4865	3285	3285	1598.125	1598.125	None Proposed	0	0.3695	1213.8075	200.1	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$325.0	\$625.0	\$950.0	
Eugene Field Administration Building - Interior	001	Break Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	3285	1124.784	\$185.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	3285	3285	638.604	638.604	None Proposed	0	0.148	486.18	80.1	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$260.0	\$320.0	\$580.0	
Eugene Field Administration Building - Interior	001	Conference Room	2x2 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	9	770.4	0.7704	3285	2530.764	\$417.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	9	437.4	0.4374	3285	3285	1436.859	1436.859	None Proposed	0	0.333	1093.905	180.3	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$585.0	\$720.0	\$1,305.0	
Eugene Field Administration Building - Interior	001	Gym	400W Metal Halide Fixtures	20	9160	9.16	3285	30090.6	\$4,960.1	Replace Metal Halide Fixtures with 6-Lamp Fluorescent Highbay Fixtures	20	4520	4.52	3285	3285	14848.2	14848.2	None Proposed	0	4.64	15242.4	2,512.5	\$168.0	\$105.0	\$100.0	\$0.0	\$100.0	\$273.0	\$373.0	\$2,000.0	\$5,460.0	\$7,460.0	
Eugene Field Administration Building - Interior	001	Hallway	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	30	1284	1.284	4015	5155.26	\$849.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	30	726.6	0.7296	4015	4015	2529.344	2529.344	None Proposed	0	0.5544	2225.916	366.9	\$35.0	\$5.0	\$65.0	\$0.0	\$65.0	\$40.0	\$105.0	\$1,950.0	\$1,200.0	\$3,150.0	
Eugene Field Administration Building - Interior	001	Janitors Closet	13W CFL Fixture	2	26	0.026	500	13	\$2.1	None Proposed	2	26	0.026	500	350	13	9.1	Ceiling Mounted Occupancy Sensor	1	0	3.9	0.6	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Eugene Field Administration Building - Interior	001	Mail Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	3285	562.392	\$92.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	3285	3285	319.302	319.302	None Proposed	0	0.074	243.09	40.1	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$130.0	\$160.0	\$290.0	
Eugene Field Administration Building - Interior	001	Main Office	2x2 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	15	1284	1.284	3285	4217.94	\$695.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	15	729	0.729	3285	3285	2394.765	2394.765	None Proposed	0	0.555	1823.175	300.5	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$975.0	\$1,200.0	\$2,175.0	
Eugene Field Administration Building - Interior	001	Main Office	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	7	354.9	0.3549	3285	1165.8465	\$192.2	None Proposed	7	354.9	0.3549	3285	3285	1165.8465	1165.8465	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	001	Main Office	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	14	2396.8	2.3968	3285	7873.488	\$1,297.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	14	1362.2	1.3622	3285	3285	4474.827	4474.827	None Proposed	0	1.0346	3398.661	560.2	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$910.0	\$1,750.0	\$2,660.0	
Eugene Field Administration Building - Interior	001	Men's Bathroom	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	500	85.6	\$14.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	500	350	48.6	34.02	Ceiling Mounted Occupancy Sensor	1	0.074	51.58	8.5	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$203.5	\$283.0	\$466.5
Eugene Field Administration Building - Interior	001	Men's Bathroom	60W Incandescent Fixture	1	60	0.06	500	30	\$4.9	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0.047	25.45	4.2	\$0.0	\$5.0	\$20.0	\$103.0	\$73.5	\$20.0	\$5.0	\$25.0	\$93.5	\$108.0	\$201.5
Eugene Field Administration Building - Interior	001	Office	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	3285	1124.784	\$185.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	3285	3285	638.604	638.604	None Proposed	0	0.148	486.18	80.1	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$260.0	\$320.0	\$580.0	
Eugene Field Administration Building - Interior	001	Office 2	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	14	1568	1.568	3285	5150.88	\$849.1	None Proposed	14	1568	1.568	3285	3285	5150.88	5150.88	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	001	Office Space	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	2	342.4	0.3424	3285	1124.784	\$185.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	194.6	0.1946	3285	3285	639.261	639.261	None Proposed	0	0.1478	485.523	80.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$130.0	\$250.0	\$380.0	
Eugene Field Administration Building - Interior	001	Room 4	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$27.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	001	Room 4	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	39	3432	3.432	3285	11274.12	\$1,858.4	None Proposed	39	3432	3.432	3285	3285	11274.12	11274.12	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	001	Room 4A	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	8	405.6	0.4056	3285	1332.396	\$219.6	None Proposed	8	405.6	0.4056	3285	3285	1332.396	1332.396	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	001	Special Services	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$95.3	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	001	Special Services	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$556.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	240.1	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0	
Eugene Field Administration Building - Interior	001	Special Services	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	18	2016	2.016	3285	6622.56	\$1,091.7	None Proposed	18	2016	2.016	3285	3285	6622.56	6622.56	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	001	Women's Bathroom	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.2	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Eugene Field Administration Building - Interior	001	Women's Bathroom	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	500	112	\$18.5	None Proposed	2	224	0.224	500	350	112	78.4	Ceiling Mounted Occupancy Sensor	1	0	33.8	5.5	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Eugene Field Administration Building - Interior	002	21	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$381.2	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	002	22	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$381.2	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	002	23	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$370.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	160.1	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$260.0	\$500.0	\$760.0	
Eugene Field Administration Building - Interior	002	25	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	7	1198.4	1.1984	3285	3936.744	\$649.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	7	681.1	0.6811	3285	3285	2237.4135	2237.4135	None Proposed	0	0.5173	1699.3305	280.1	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$455.0	\$875.0	\$1,330.0	
Eugene Field Administration Building - Interior	002	25	60W Incandescent Fixture	2	120	0.12	3285	394.2	\$65.0	Replace 60W Incandescent Fixture with 13W CFL	2	26	0.026	3285	3285	85.41	85.41	None Proposed	0	0.094	308.79	50.9	\$0.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$40.0	\$10.0	\$50.0	
Eugene Field Administration Building - Interior	002	Business Office	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	8	405.6	0.4056	3285	1332.396	\$219.6	None Proposed	8	405.6	0.4056	3285	3285	1332.396	1332.396	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	002	Business Office	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	24	4108.8	4.1088	3285	13497.408	\$2,224.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	24	2335.2	2.3352	3285	3285	7671.132	7671.132	None Proposed	0	1.7736	5826.276	960.4	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$1,560.0	\$3,000.0	\$4,560.0	
Eugene Field Administration Building - Interior	002	Hallway	13W CFL Fixture	18	234	0.234	4015	939.51	\$154.9	None Proposed	18	234	0.234	4015	4015	939.51	939.51	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Eugene Field Administration Building - Interior	002	Janitors Closet	13W CFL Fixture	1	13	0.013	500	6.5	\$1.1	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Eugene Field Administration Building - Interior	002	Men's Bathroom	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	500	50.7	\$8.4	None Proposed	2	101.4	0.1014	500	350	50.7	35.49	Ceiling Mounted Occupancy Sensor	1	0	15.21	2.5	\$0.0	\$0.0	\$0								

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total
Hawthorne Elementary School - Interior	001	20	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	15	1284	1.284	3285	4217.94	\$695.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	15	729	0.729	3285	3285	2394.765	2394.765	None Proposed	0	0.555	1823.175	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$975.0	\$1,200.0	\$2,175.0	
Hawthorne Elementary School - Interior	001	20	60W Incandescent Fixture	1	60	0.06	3285	197.1	\$32.5	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0.047	154.395	\$5.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0		
Hawthorne Elementary School - Interior	001	22	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	9	1540.8	1.5408	3285	5061.528	\$834.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	9	875.7	0.8757	3285	3285	2876.6745	2876.6745	None Proposed	0	0.6651	2184.8535	\$60.2	\$105.0	\$20.0	\$65.0	\$125.0	\$190.0	\$585.0	\$1,125.0	\$1,710.0			
Hawthorne Elementary School - Interior	001	23	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	11	1883.2	1.8832	3285	6186.312	\$1,020.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	11	1070.3	1.0703	3285	3285	3515.9355	3515.9355	None Proposed	0	0.8129	2670.3765	\$40.3	\$105.0	\$20.0	\$65.0	\$125.0	\$190.0	\$715.0	\$1,375.0	\$2,090.0			
Hawthorne Elementary School - Interior	001	24	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	10	1712	1.712	3285	5623.92	\$927.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	973	0.973	3285	3285	3196.305	3196.305	None Proposed	0	0.739	2427.615	\$40.2	\$105.0	\$20.0	\$65.0	\$125.0	\$190.0	\$650.0	\$1,250.0	\$1,900.0			
Hawthorne Elementary School - Interior	001	25	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	10	1712	1.712	3285	5623.92	\$927.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	973	0.973	3285	3285	3196.305	3196.305	None Proposed	0	0.739	2427.615	\$40.2	\$105.0	\$20.0	\$65.0	\$125.0	\$190.0	\$650.0	\$1,250.0	\$1,900.0			
Hawthorne Elementary School - Interior	001	26	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	9	1540.8	1.5408	3285	5061.528	\$834.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	9	875.7	0.8757	3285	3285	2876.6745	2876.6745	None Proposed	0	0.6651	2184.8535	\$60.2	\$105.0	\$20.0	\$65.0	\$125.0	\$190.0	\$585.0	\$1,125.0	\$1,710.0			
Hawthorne Elementary School - Interior	001	27	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$571.9	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Hawthorne Elementary School - Interior	001	28	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$571.9	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Hawthorne Elementary School - Interior	001	29	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$571.9	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Hawthorne Elementary School - Interior	001	30	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$571.9	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	32	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	9	1540.8	1.5408	3285	5061.528	\$834.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	9	875.7	0.8757	3285	3285	2876.6745	2876.6745	None Proposed	0	0.6651	2184.8535	\$60.2	\$105.0	\$20.0	\$65.0	\$125.0	\$190.0	\$585.0	\$1,125.0	\$1,710.0			
Hawthorne Elementary School - Interior	001	33	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$429.0	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	35	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	4	352	0.352	3285	1156.32	\$190.6	None Proposed	4	352	0.352	3285	3285	1156.32	1156.32	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	36	1x4 Fixtures w/ 3-T12 Lamp Fixture w/ Magnetic Ballast	1	128.4	0.1284	3285	421.794	\$69.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	73	0.073	3285	3285	239.805	239.805	None Proposed	0	0.0554	181.989	\$30.0	\$85.0	\$15.0	\$65.0	\$0.0	\$0.0	\$65.0	\$100.0	\$165.0	\$65.0	\$100.0	\$165.0
Hawthorne Elementary School - Interior	001	37	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$429.0	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	39	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$571.9	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	40	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$381.3	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	41	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$381.3	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	42	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$381.3	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	43	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$381.3	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	44	13W CFL Fixture	4	52	0.052	3285	170.82	\$28.2	None Proposed	4	52	0.052	3285	3285	170.82	170.82	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	44	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	1	42.8	0.0428	3285	140.596	\$23.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	24.32	0.02432	3285	3285	79.8912	79.8912	None Proposed	0	0.01648	60.7068	\$10.0	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$65.0	\$40.0	\$105.0
Hawthorne Elementary School - Interior	001	44	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	10	856	0.856	3285	2811.96	\$463.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	486	0.486	3285	3285	1596.51	1596.51	None Proposed	0	0.37	1215.45	\$200.4	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$650.0	\$800.0	\$1,450.0
Hawthorne Elementary School - Interior	001	Bathroom	13W CFL Fixture	1	13	0.013	500	6.5	\$1.1	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Hawthorne Elementary School - Interior	001	Bathroom	2x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	500	50.7	\$8.4	None Proposed	2	101.4	0.1014	500	350	50.7	35.49	Ceiling Mounted Occupancy Sensor	1	0	15.21	2.5	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Hawthorne Elementary School - Interior	001	Bathroom	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	500	88	\$14.5	None Proposed	2	176	0.176	500	350	88	61.6	Ceiling Mounted Occupancy Sensor	1	0	26.4	4.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Hawthorne Elementary School - Interior	001	Boiler Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	3285	562.392	\$92.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	3285	3285	319.302	319.302	None Proposed	0	0.074	243.09	\$40.1	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$130.0	\$160.0	\$290.0
Hawthorne Elementary School - Interior	001	Boiler Room	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	9	1540.8	1.5408	3285	5061.528	\$834.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	9	875.7	0.8757	3285	3285	2876.6745	2876.6745	None Proposed	0	0.6651	2184.8535	\$60.2	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$585.0	\$1,125.0	\$1,710.0
Hawthorne Elementary School - Interior	001	Cafeteria	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	4	202.8	0.2028	3285	666.198	\$109.8	None Proposed	4	202.8	0.2028	3285	3285	666.198	666.198	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	Cafeteria	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	36	3168	3.168	3285	10406.88	\$1,715.8	None Proposed	36	3168	3.168	3285	3285	10406.88	10406.88	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Hawthorne Elementary School - Interior	001	Closet	13W CFL Fixture	1	13	0.013	500	6.5	\$1.1	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5
Hawthorne Elementary School - Interior	001	Guidance	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	3	513.6	0.5136	3285	1687.176	\$278.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	291.9	0.2919	3285	3285	958.8915	958.8915	None Proposed	0	0.2217	728.2845	\$120.1	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$195.0	\$375.0	\$570.0
Hawthorne Elementary School - Interior	001	Gym	2x4 Fixtures w																														

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total			
Hawthorne Elementary School - Interior	001	Storage	13W CFL Fixture	1	13	0.013	500	6.5	\$1.1	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Storage	13W CFL Fixture	1	13	0.013	500	6.5	\$1.1	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Storage	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	1	85.6	0.0856	500	42.8	\$7.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	48.6	0.0486	500	350	24.3	17.01	Ceiling Mounted Occupancy Sensor	1	0.037	25.79	4.3	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$138.5	\$183.0	\$321.5			
Hawthorne Elementary School - Interior	001	Storage	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.2	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Storage	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	2	342.4	0.3424	500	171.2	\$28.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	194.6	0.1946	500	350	97.3	68.11	Ceiling Mounted Occupancy Sensor	1	0.1478	103.09	17.0	\$105.0	\$20.0	\$65.0	\$103.0	\$73.5	\$65.0	\$125.0	\$190.0	\$203.5	\$353.0	\$556.5			
Hawthorne Elementary School - Interior	001	Women's Bathroom	1X4 Fixtures w/ 1-T8 Lamps w/ Electronic Ballasts	1	25.4	0.0254	500	12.7	\$2.1	None Proposed	1	25.4	0.0254	500	350	12.7	8.89	Ceiling Mounted Occupancy Sensor	1	0	3.81	0.6	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Women's Bathroom	1X4 Fixtures w/ 1-T8 Lamps w/ Electronic Ballasts	4	101.6	0.1016	500	50.8	\$8.4	None Proposed	4	101.6	0.1016	500	350	50.8	35.56	Ceiling Mounted Occupancy Sensor	1	0	15.24	2.5	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Women's Bathroom	1X4 Fixtures w/ 1-T8 Lamps w/ Electronic Ballasts	4	101.6	0.1016	500	50.8	\$8.4	None Proposed	4	101.6	0.1016	500	350	50.8	35.56	Ceiling Mounted Occupancy Sensor	1	0	15.24	2.5	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Women's Bathroom	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	500	88	\$14.5	None Proposed	2	176	0.176	500	350	88	61.6	Ceiling Mounted Occupancy Sensor	1	0	26.4	4.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Women's Bathroom	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	500	88	\$14.5	None Proposed	2	176	0.176	500	350	88	61.6	Ceiling Mounted Occupancy Sensor	1	0	26.4	4.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Hawthorne Elementary School - Interior	001	Women's Bathroom	42W CFL Fixture	2	98	0.098	500	49	\$8.1	None Proposed	2	98	0.098	500	350	49	34.3	Ceiling Mounted Occupancy Sensor	1	0	14.7	2.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5			
Lowell Elementary School - Exterior	000	Exterior	Pole Mounted Luminaire - 1 Head (Assume 400W MH)	6	2748	2.748	5110	14042.28	\$2,634.5	Replace 400W MH fixture with LED Area Light	6	1392	1.392	5110	5110	7113.12	7113.12	None Proposed	0	1.356	6929.16	1,300.0	\$1,200.0	\$2,000.0	\$703.0	\$0.0	\$0.0	\$703.0	\$3,200.0	\$3,903.0	\$4,218.0	\$19,200.0	\$23,418.0			
Lowell Elementary School - Interior	001	101	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$633.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	273.3	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0			
Lowell Elementary School - Interior	001	102	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$633.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	273.3	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0			
Lowell Elementary School - Interior	001	103	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$633.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	273.3	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0			
Lowell Elementary School - Interior	001	104	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$633.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	273.3	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0			
Lowell Elementary School - Interior	001	105	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$633.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	273.3	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0			
Lowell Elementary School - Interior	001	106	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$633.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	273.3	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0			
Lowell Elementary School - Interior	001	109	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	12	1344	1.344	3285	4415.04	\$828.3	None Proposed	12	1344	1.344	3285	3285	4415.04	4415.04	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Lowell Elementary School - Interior	001	111	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	2	342.4	0.3424	3285	1124.784	\$211.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	194.6	0.1946	3285	3285	639.261	639.261	None Proposed	0	0.1478	485.523	91.1	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$130.0	\$250.0	\$380.0			
Lowell Elementary School - Interior	001	112	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	1	171.2	0.1712	3285	562.392	\$105.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	97.3	0.0973	3285	3285	319.6305	319.6305	None Proposed	0	0.0739	242.7615	45.5	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$65.0	\$125.0	\$190.0			
Lowell Elementary School - Interior	001	115	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	15	1320	1.32	3285	4336.2	\$813.5	None Proposed	15	1320	1.32	3285	3285	4336.2	4336.2	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Lowell Elementary School - Interior	001	116	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	11	968	0.968	3285	3179.88	\$596.6	None Proposed	11	968	0.968	3285	3285	3179.88	3179.88	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Lowell Elementary School - Interior	001	117	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	001	118	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	001	119	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	7	616	0.616	3285	2023.56	\$379.6	None Proposed	7	616	0.616	3285	3285	2023.56	2023.56	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	001	123	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$31.2	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	001	124	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$31.2	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	001	125	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$31.2	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Lowell Elementary School - Interior	001	128	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Lowell Elementary School - Interior	001	129	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Lowell Elementary School - Interior	001	130	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Lowell Elementary School - Interior	001	Cafeteria	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	35	3920	3.92																														



Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total					
Lowell Elementary School - Interior	002	210	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$325.4	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Lowell Elementary School - Interior	002	211	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	2	342.4	0.3424	3285	1124.784	\$211.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	194.6	0.1946	3285	3285	639.261	639.261	None Proposed	0	0.1478	485.523	91.1	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$130.0	\$250.0	\$380.0					
Lowell Elementary School - Interior	002	212	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$325.4	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0					
Lowell Elementary School - Interior	002	212	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	3285	735.84	\$138.1	None Proposed	2	224	0.224	3285	3285	735.84	735.84	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Lowell Elementary School - Interior	002	213	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	3	256.8	0.2568	3285	843.588	\$158.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	145.8	0.1458	3285	3285	476.953	476.953	None Proposed	0	0.111	364.635	68.4	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$195.0	\$240.0	\$435.0					
Lowell Elementary School - Interior	002	215	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$325.4	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Lowell Elementary School - Interior	002	216	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$325.4	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Lowell Elementary School - Interior	002	217	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	11	968	0.968	3285	3179.88	\$596.6	None Proposed	11	968	0.968	3285	3285	3179.88	3179.88	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Lowell Elementary School - Interior	002	219	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	20	1760	1.76	3285	5781.6	\$1,084.7	None Proposed	20	1760	1.76	3285	3285	5781.6	5781.6	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Lowell Elementary School - Interior	002	219	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	5	560	0.56	3285	1839.6	\$345.1	None Proposed	5	560	0.56	3285	3285	1839.6	1839.6	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Lowell Elementary School - Interior	002	219	42W CFL Fixture	19	931	0.931	3285	3058.335	\$573.8	None Proposed	19	931	0.931	3285	3285	3058.335	3058.335	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Lowell Elementary School - Interior	002	221	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$31.2	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Lowell Elementary School - Interior	002	222	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	11	557.7	0.5577	3285	1832.0445	\$343.7	None Proposed	11	557.7	0.5577	3285	3285	1832.0445	1832.0445	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	002	225	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Lowell Elementary School - Interior	002	226	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Lowell Elementary School - Interior	002	227	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$650.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Lowell Elementary School - Interior	002	Electrical Room	13W CFL Fixture	1	13	0.013	3285	42.705	\$8.0	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Lowell Elementary School - Interior	002	Halfway	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	46	1968.8	1.9688	4015	7904.732	\$1,483.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	46	1118.72	1.11872	4015	4015	4491.6608	4491.6608	None Proposed	0	0.85008	3413.0712	640.3	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$2,990.0	\$1,840.0	\$4,830.0					
Lowell Elementary School - Interior	002	Halfway	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	4015	4239.84	\$795.5	None Proposed	12	1056	1.056	4015	4015	4239.84	4239.84	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	002	Halfway	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	9	1008	1.008	4015	4047.12	\$759.3	None Proposed	9	1008	1.008	4015	4015	4047.12	4047.12	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Lowell Elementary School - Interior	002	Men's Bathroom	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	500	88	\$16.5	None Proposed	2	176	0.176	500	350	88	61.6	Ceiling Mounted Occupancy Sensor	1	0	26.4	5.0	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5					
Lowell Elementary School - Interior	002	Men's Bathroom	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	500	88	\$16.5	None Proposed	2	176	0.176	500	350	88	61.6	Ceiling Mounted Occupancy Sensor	1	0	26.4	5.0	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5					
Lowell Elementary School - Interior	002	Women's Bathroom	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.8	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5					
Lowell Elementary School - Interior	002	Women's Bathroom	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	500	88	\$16.5	None Proposed	2	176	0.176	500	350	88	61.6	Ceiling Mounted Occupancy Sensor	1	0	26.4	5.0	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5					
Lowell Elementary School - Interior	002	Women's Bathroom	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	500	88	\$16.5	None Proposed	2	176	0.176	500	350	88	61.6	Ceiling Mounted Occupancy Sensor	1	0	26.4	5.0	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5					
Press Box	000	Press Box	60W Incandescent Fixture	3	180	0.18	50	9	\$9.6	Replace 60W Incandescent Fixture with 13W CFL	3	39	0.039	50	50	1.95	1.95	None Proposed	1	0.141	7.05	7.5	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$60.0	\$15.0	\$75.0					
Press Box	000	Press Box	13W CFL Fixture	4	52	0.052	50	2.6	\$2.8	None Proposed	4	52	0.052	50	50	2.6	2.6	None Proposed	2	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Exterior	000	Exterior	Exterior Wall Packs (Assume 70w)	16	1440	1.44	5110	7358.4	\$1,169.4	Replace 70W Wall Pack fixture with LED Area Light	16	880	0.88	5110	5110	4496.8	4496.8	None Proposed	0	0.56	2861.6	454.8	\$0.0	\$800.0	\$186.0	\$0.0	\$0.0	\$186.0	\$800.0	\$986.0	\$2,976.0	\$12,800.0	\$15,776.0					
Teaneck High School - Exterior	000	Exterior	Flood Lights (Assume 400W MH)	3	1374	1.374	5110	7021.14	\$1,115.8	Replace 400W MH fixture with LED Area Light	3	696	0.696	5110	5110	3556.56	3556.56	None Proposed	0	0.678	3464.58	550.6	\$0.0	\$2,000.0	\$133.0	\$0.0	\$0.0	\$133.0	\$2,000.0	\$2,133.0	\$399.0	\$6,000.0	\$6,399.0					
Teaneck High School - Interior	000	Stairwell 1	1X4 Fixtures w/ 2-T8HO Lamps w/ Electronic Ballasts	5	648	0.648	8760	5676.48	\$902.1	None Proposed	5	648	0.648	8760	8760	5676.48	5676.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	000	Stairwell 2	1X4 Fixtures w/ 2-T8HO Lamps w/ Electronic Ballasts	5	648	0.648	8760	5676.48	\$902.1	None Proposed	5	648	0.648	8760	8760	5676.48	5676.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	000	Stairwell 3	1X4 Fixtures w/ 2-T8HO Lamps w/ Electronic Ballasts	5	648	0.648	8760	5676.48	\$902.1	None Proposed	5	648	0.648	8760	8760	5676.48	5676.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	000	Stairwell 4	1X4 Fixtures w/ 2-T8HO Lamps w/ Electronic Ballasts	5	648	0.648	8760	5676.48	\$902.1	None Proposed	5	648	0.648	8760	8760	5676.48	5676.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0														

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total						
Teaneck High School - Interior	001	121	2x2 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	6	513.6	0.5136	3285	1687.176	\$268.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	291.6	0.2916	3285	3285	957.906	957.906	None Proposed	0	0.222	729.27	115.9	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$390.0	\$480.0	\$870.0						
Teaneck High School - Interior	001	121	60W Incandescent Fixture	1	60	0.06	3285	197.1	\$31.3	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0.047	154.395	24.5	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0						
Teaneck High School - Interior	001	123	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	10	1712	1.712	3285	5623.92	\$893.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	973	0.973	3285	3285	3196.305	3196.305	None Proposed	0	0.739	2427.615	385.8	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$650.0	\$1,250.0	\$1,900.0						
Teaneck High School - Interior	001	125	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0					
Teaneck High School - Interior	001	126	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Teaneck High School - Interior	001	127	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Teaneck High School - Interior	001	127	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	14	1232	1.232	3285	4047.12	\$643.2	None Proposed	14	1232	1.232	3285	3285	4047.12	4047.12	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	128	2x4 Fixtures w/ 3-T12 Lamp Fixture w/ Magnetic Ballast	1	128.4	0.1284	3285	421.794	\$67.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	73	0.073	3285	3285	239.805	239.805	None Proposed	0	0.0554	181.989	28.9	\$85.0	\$15.0	\$65.0	\$0.0	\$0.0	\$65.0	\$100.0	\$165.0	\$65.0	\$100.0	\$165.0						
Teaneck High School - Interior	001	130	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Teaneck High School - Interior	001	132	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Teaneck High School - Interior	001	134	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	15	2568	2.568	3285	8435.88	\$1,340.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	15	1459.5	1.4595	3285	3285	4794.4575	4794.4575	None Proposed	0	1.1085	3641.4225	578.7	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$875.0	\$1,875.0	\$2,850.0						
Teaneck High School - Interior	001	138	2x2 Fixtures w/ 40W CFL Lamps	12	1920	1.92	3285	6307.2	\$1,002.4	Replace 40W CFL Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	608.4	0.6084	3285	3285	1998.594	1998.594	None Proposed	0	1.3116	4308.606	684.8	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	001	138	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	138	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	1	88	0.088	3285	289.08	\$45.9	None Proposed	1	88	0.088	3285	3285	289.08	289.08	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	140	2x2 Fixtures w/ 40W CFL Lamps	12	1920	1.92	3285	6307.2	\$1,002.4	Replace 40W CFL Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	608.4	0.6084	3285	3285	1998.594	1998.594	None Proposed	0	1.3116	4308.606	684.8	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	001	142	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	10	507	0.507	3285	1665.495	\$264.7	None Proposed	10	507	0.507	3285	3285	1665.495	1665.495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	142	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	4	202.8	0.2028	3285	666.198	\$105.9	None Proposed	4	202.8	0.2028	3285	3285	666.198	666.198	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	148	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	40	2028	2.028	3285	6661.98	\$1,058.8	None Proposed	40	2028	2.028	3285	3285	6661.98	6661.98	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	148	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	3285	333.099	\$52.9	None Proposed	2	101.4	0.1014	3285	3285	333.099	333.099	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	148	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	15	1320	1.32	3285	4336.2	\$689.1	None Proposed	15	1320	1.32	3285	3285	4336.2	4336.2	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	149	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	5	560	0.56	3285	1839.6	\$292.4	None Proposed	5	560	0.56	3285	3285	1839.6	1839.6	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	149	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	150	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3488.96	\$551.3	None Proposed	12	1056	1.056	3285	3285	3488.96	3488.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	001	150	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	28	4783.6	4.7836	3285	15746.976	\$2,502.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	28	2724.4	2.7244	3285	3285	8949.654	8949.654	None Proposed	0	2.0692	6797.322	1,080.3	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$1,800.0	\$3,500.0	\$5,320.0						
Teaneck High School - Interior	001	151	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	17	861.9	0.8619	3285	2831.3415	\$450.0	None Proposed	17	861.9	0.8619	3285	3285	2831.3415	2831.3415	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	001	151	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	001	153	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	14	709.8	0.7098	3285	2331.693	\$370.6	None Proposed	14	709.8	0.7098	3285	3285	2331.693	2331.693	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	001	153	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	155	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	3285	735.84	\$116.9	None Proposed	2	224	0.224	3285	3285	735.84	735.84	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	155	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	001	100A	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	6	304.2	0.3042	3285	999.297	\$158.8	None Proposed	6	304.2	0.3042	3285	3285	999.297	999.297	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	001	100A	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	5	856	0.856	3285	2811.																															

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total				
Teaneck High School - Interior	001	Storage	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	4	171.2	0.1712	500	85.6	\$13.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	97.28	0.09728	500	350	48.64	34.048	Ceiling Mounted Occupancy Sensor	1	0.07392	51.552	8.2	\$35.0	\$5.0	\$65.0	\$103.0	\$73.5	\$65.0	\$40.0	\$105.0	\$333.5	\$263.0	\$596.5				
Teaneck High School - Interior	001	Tank Room	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	2	342.4	0.3424	3285	1124.784	\$178.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	194.6	0.1946	3285	3285	639.261	639.261	None Proposed	0	0.1478	485.523	77.2	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$130.0	\$250.0	\$380.0				
Teaneck High School - Interior	001	Women's Bathroom	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	3	256.8	0.2568	500	128.4	\$20.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	145.8	0.1458	500	350	72.9	51.03	Ceiling Mounted Occupancy Sensor	1	0.111	77.37	12.3	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$268.5	\$343.0	\$611.5				
Teaneck High School - Interior	001	Women's Bathroom	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	3	256.8	0.2568	500	128.4	\$20.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	145.8	0.1458	500	350	72.9	51.03	Ceiling Mounted Occupancy Sensor	1	0.111	77.37	12.3	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$268.5	\$343.0	\$611.5				
Teaneck High School - Interior	001	Women's Bathroom	2x4 Fixtures w/ 3-T12 Lamp Fixture w/ Magnetic Ballast	1	128.4	0.1284	500	64.2	\$10.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	73	0.073	500	350	36.5	25.55	Ceiling Mounted Occupancy Sensor	1	0.0554	38.65	6.1	\$85.0	\$15.0	\$65.0	\$103.0	\$73.5	\$65.0	\$100.0	\$165.0	\$138.5	\$203.0	\$341.5				
Teaneck High School - Interior	001	Women's Bathroom	60W Incandescent Fixture	1	60	0.06	500	30	\$4.8	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0.047	25.45	4.0	\$0.0	\$5.0	\$20.0	\$103.0	\$73.5	\$20.0	\$5.0	\$25.0	\$93.5	\$106.0	\$201.5				
Teaneck High School - Interior	002	200	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	22	1115.4	1.1154	3285	3664.089	\$582.3	None Proposed	22	1115.4	1.1154	3285	3285	3664.089	3664.089	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Teaneck High School - Interior	002	200	2x2 Fixtures w/ 31W Ocron Lamp	17	527	0.527	3285	1731.195	\$275.1	None Proposed	17	527	0.527	3285	3285	1731.195	1731.195	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Teaneck High School - Interior	002	201	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	002	202	13W CFL Fixture	1	13	0.013	3285	42.705	\$6.8	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	002	203	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	205	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	206	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	207	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	208	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	209	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	211	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	212	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	213	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	214	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$367.5	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	215	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	216	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	217	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	218	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	218	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	17	861.9	0.8619	3285	2831.3415	\$450.0	None Proposed	17	861.9	0.8619	3285	3285	2831.3415	2831.3415	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	218	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	1	112	0.112	3285	367.92	\$58.5	None Proposed	1	112	0.112	3285	3285	367.92	367.92	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	219	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	220	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	222	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5495	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5495	166.5495	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	222	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	17	861.9	0.8619	3285	2831.3415	\$450.0	None Proposed	17	861.9	0.8619	3285	3285	2831.3415	2831.3415	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	002	222	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	1	112	0.112	3285	367.92	\$58.5	None Proposed	1	112	0.112	3285	3285	367.92	367.92	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	224	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	225	13W CFL Fixture	13	169	0.169	3285	555.165	\$88.2	None Proposed	13	169	0.169	3285	328																						

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total				
Teaneck High School - Interior	002	246	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	002	253	150W Incandescent Fixture	1	150	0.15	3285	492.75	\$78.3	Replace 150W Incandescent Fixture with 25W CFL	1	25	0.025	3285	3285	82.125	82.125	None Proposed	0	0.125	410.625	65.3	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$20.0	\$7.0	\$27.0				
Teaneck High School - Interior	002	200A	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0				
Teaneck High School - Interior	002	200B	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	002	200E	2x2 Fixtures w/ 31W Octron Lamp	4	124	0.124	3285	407.34	\$64.7	None Proposed	4	124	0.124	3285	3285	407.34	407.34	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0			
Teaneck High School - Interior	002	200G	2x2 Fixtures w/ 31W Octron Lamp	4	124	0.124	3285	407.34	\$64.7	None Proposed	4	124	0.124	3285	3285	407.34	407.34	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	200H	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	200J	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	200K	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	200L	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	200M	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	200N	2x2 Fixtures w/ 31W Octron Lamp	6	186	0.186	3285	611.01	\$97.1	None Proposed	6	186	0.186	3285	3285	611.01	611.01	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	200P	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	1	112	0.112	3285	367.92	\$58.5	None Proposed	1	112	0.112	3285	3285	367.92	367.92	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	209B	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	3285	166.5485	\$26.5	None Proposed	1	50.7	0.0507	3285	3285	166.5485	166.5485	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	002	209B	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	214B	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	225A	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	4	352	0.352	3285	1156.32	\$183.8	None Proposed	4	352	0.352	3285	3285	1156.32	1156.32	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	225A	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	8	896	0.896	3285	2943.36	\$467.8	None Proposed	8	896	0.896	3285	3285	2943.36	2943.36	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	225B	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	225B	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	002	225B	42W CFL Fixture	12	588	0.588	3285	1931.58	\$307.0	None Proposed	12	588	0.588	3285	3285	1931.58	1931.58	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	225D	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$91.9	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	225G	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$91.9	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	002	Auditorium	26W CFL Fixture	56	1456	1.456	3285	4782.96	\$760.1	None Proposed	56	1456	1.456	3285	3285	4782.96	4782.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	Auditorium	400W MH Fixture	21	9618	9.618	3285	31595.13	\$5,021.3	None Proposed	21	9618	9.618	3285	3285	31595.13	31595.13	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	Back Stage	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	21	1797.6	1.7976	3285	5895.116	\$938.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	21	1020.6	1.0206	3285	3285	3352.671	3352.671	None Proposed	0	0.777	2552.445	405.7	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$1,365.0	\$1,680.0	\$3,045.0	\$1,680.0	\$3,045.0		
Teaneck High School - Interior	002	Back Stage	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$536.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	231.5	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0	\$750.0	\$1,140.0		
Teaneck High School - Interior	002	Break Room	2x2 Fixtures w/ 31W Octron Lamp	2	62	0.062	3285	203.67	\$32.4	None Proposed	2	62	0.062	3285	3285	203.67	203.67	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	Faculty Bathroom	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.0	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.2	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	\$176.5	\$176.5		
Teaneck High School - Interior	002	Faculty Bathroom	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.0	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.2	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	\$176.5	\$176.5		
Teaneck High School - Interior	002	Hallway	150W Incandescent Fixture	1	150	0.15	4015	602.25	\$95.7	Replace 150W Incandescent Fixture with 25W CFL	1	25	0.025	4015	4015	100.375	100.375	None Proposed	0	0.125	501.875	79.8	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$20.0	\$7.0	\$27.0				
Teaneck High School - Interior	002	Hallway	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	107	5424.9	5.4249	4015	21780.9735	\$3,461.6	None Proposed	107	5424.9	5.4249	4015	4015	21780.9735	21780.9735	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	002	Men's Bathroom	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	3	256.8	0.2568	500	128.4	\$20.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	145.8	0.1458	500	350	72.9	51.03	Ceiling Mounted Occupancy Sensor	1	0.111	77.37																

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total		
Teaneck High School - Interior	003	318	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	18	1584	1.584	3285	5203.44	\$827.0	None Proposed	18	1584	1.584	3285	3285	5203.44	5203.44	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	319	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	321	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	19	1672	1.672	3285	5492.52	\$872.9	None Proposed	19	1672	1.672	3285	3285	5492.52	5492.52	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	322	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	325	400W Metal Halide Fixtures	6	2748	2.748	3285	9027.18	\$1,434.7	Replace Metal Halide Fixtures with 6-Lamp Fluorescent Highbay Fixtures	6	1356	1.356	3285	3285	4454.46	4454.46	None Proposed	0	1.392	4572.72	726.7	\$168.0	\$105.0	\$100.0	\$0.0	\$0.0	\$100.0	\$273.0	\$373.0	\$600.0	\$1,638.0	\$2,238.0		
Teaneck High School - Interior	003	326	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$413.5	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	327	400W Metal Halide Fixtures	6	2748	2.748	3285	9027.18	\$1,434.7	Replace Metal Halide Fixtures with 6-Lamp Fluorescent Highbay Fixtures	6	1356	1.356	3285	3285	4454.46	4454.46	None Proposed	0	1.392	4572.72	726.7	\$168.0	\$105.0	\$100.0	\$0.0	\$0.0	\$100.0	\$273.0	\$373.0	\$600.0	\$1,638.0	\$2,238.0		
Teaneck High School - Interior	003	330	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	1	85.6	0.0856	3285	281.196	\$44.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	48.6	0.0486	3285	3285	159.651	159.651	None Proposed	0	0.037	121.545	19.3	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$65.0	\$80.0	\$145.0		
Teaneck High School - Interior	003	330	2' 17W Fluorescent Fixture	2	30	0.03	3285	98.55	\$15.7	None Proposed	2	30	0.03	3285	3285	98.55	98.55	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Teaneck High School - Interior	003	332	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	15	1320	1.32	3285	4336.2	\$689.1	None Proposed	15	1320	1.32	3285	3285	4336.2	4336.2	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	334	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	44	1883.2	1.8832	3285	6186.312	\$983.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	44	1070.08	1.07008	3285	3285	3515.2128	3515.2128	None Proposed	0	0.81312	2671.0992	424.5	\$35.0	\$5.0	\$65.0	\$0.0	\$0.0	\$65.0	\$40.0	\$105.0	\$2,860.0	\$1,760.0	\$4,620.0		
Teaneck High School - Interior	003	334	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	66	5649.6	5.6496	3285	18558.936	\$2,949.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	66	3207.6	3.2076	3285	3285	10536.966	10536.966	None Proposed	0	2.442	8021.97	1,274.9	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$4,290.0	\$5,280.0	\$9,570.0		
Teaneck High School - Interior	003	334	2x2 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	10	856	0.856	3285	2811.96	\$446.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	486	0.486	3285	3285	1596.51	1596.51	None Proposed	0	0.37	1215.45	193.2	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$650.0	\$800.0	\$1,450.0		
Teaneck High School - Interior	003	344	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	45	5040	5.04	3285	16556.4	\$2,631.3	None Proposed	45	5040	5.04	3285	3285	16556.4	16556.4	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	300A	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	300A	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$367.5	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	300B	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$275.7	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	300C	2x2 Fixtures w/ 31W Octron Lamp	6	186	0.186	3285	611.01	\$97.1	None Proposed	6	186	0.186	3285	3285	611.01	611.01	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	300N	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$91.9	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	300T	2x2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	3285	333.099	\$52.9	None Proposed	2	101.4	0.1014	3285	3285	333.099	333.099	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	325A	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	3	264	0.264	3285	867.24	\$137.8	None Proposed	3	264	0.264	3285	3285	867.24	867.24	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	326A	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$91.9	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	327A	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$91.9	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	Cafeteria B	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	46	5152	5.152	3285	16924.32	\$2,689.7	None Proposed	46	5152	5.152	3285	3285	16924.32	16924.32	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	Closet	13W CFL Fixture	1	13	0.013	500	6.5	\$1.0	None Proposed	1	13	0.013	500	500	6.5	6.5	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Teaneck High School - Interior	003	Hallway	100W Incandescent Fixture	3	300	0.3	4015	1204.5	\$191.4	Replace 100W Incandescent Fixture with 25W CFL	3	75	0.075	4015	4015	301.125	301.125	None Proposed	0	0.225	903.375	143.6	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$27.0	\$60.0	\$21.0	\$81.0		
Teaneck High School - Interior	003	Hallway	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	94	4765.8	4.7658	4015	19134.687	\$3,041.0	None Proposed	94	4765.8	4.7658	4015	4015	19134.687	19134.687	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	Kitchen	150W Incandescent Fixture	15	2250	2.25	3285	7391.25	\$1,174.7	Replace 150W Incandescent Fixture with 25W CFL	15	375	0.375	3285	3285	1231.875	1231.875	None Proposed	0	1.875	6159.375	978.9	\$0.0	\$7.0	\$20.0	\$0.0	\$0.0	\$20.0	\$7.0	\$300.0	\$105.0	\$405.0			
Teaneck High School - Interior	003	Kitchen	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	5	253.5	0.2535	3285	832.7475	\$132.3	None Proposed	5	253.5	0.2535	3285	3285	832.7475	832.7475	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	Kitchen	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	20	1760	1.76	3285	5781.6	\$918.9	None Proposed	20	1760	1.76	3285	3285	5781.6	5781.6	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Teaneck High School - Interior	003	Men's Bathroom	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	500	171.2	\$27.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	500	350	97.2	68.04	Ceiling Mounted Occupancy Sensor	1	0.148	103.16	16.4	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$333.5	\$423.0	\$756.5		
Teaneck High School - Interior	003	Women's Bathroom	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	500	171.2	\$27.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	500	350	97.2	68.04	Ceiling Mounted Occupancy Sensor	1	0.148	103.16	16.4	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$333.5	\$423.0	\$756.5		
Teaneck High School - Interior	003	Women's Bathroom	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	500	171.2	\$27.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	500	350	97.2</																			

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bus (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total
Thomas Jefferson Middle School - Interior	001	106	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Thomas Jefferson Middle School - Interior	001	107	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Thomas Jefferson Middle School - Interior	001	108	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Thomas Jefferson Middle School - Interior	001	109	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Thomas Jefferson Middle School - Interior	001	110	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Thomas Jefferson Middle School - Interior	001	111	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	12	1056	1.056	3285	3468.96	\$617.8	None Proposed	12	1056	1.056	3285	3285	3468.96	3468.96	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	001	113	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	24	2054.4	2.0544	3285	6748.704	\$1,201.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	24	1166.4	1.1664	3285	3285	3831.624	3831.624	None Proposed	0	0.888	2917.08	519.5	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$1,560.0	\$1,920.0	\$3,480.0	
Thomas Jefferson Middle School - Interior	001	115	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	32	2739.2	2.7392	3285	8998.272	\$1,602.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	32	1555.2	1.5552	3285	3285	5108.832	5108.832	None Proposed	0	1.184	3889.44	692.7	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$2,080.0	\$2,560.0	\$4,640.0	
Thomas Jefferson Middle School - Interior	001	129	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$483.4	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	001	108A	2x4 Fixtures w/ 3-T12 Lamp Fixture w/ Magnetic Ballast	10	1284	1.284	3285	4217.94	\$751.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	730	0.73	3285	3285	2398.05	2398.05	None Proposed	0	0.554	1819.89	324.1	\$85.0	\$15.0	\$65.0	\$0.0	\$65.0	\$100.0	\$165.0	\$650.0	\$1,000.0	\$1,650.0	
Thomas Jefferson Middle School - Interior	001	114A	2x4 Fixtures w/ 3-T12 Lamp Fixture w/ Magnetic Ballast	6	770.4	0.7704	3285	2530.764	\$450.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	438	0.438	3285	3285	1438.83	1438.83	None Proposed	0	0.324	1091.934	194.5	\$85.0	\$15.0	\$65.0	\$0.0	\$65.0	\$100.0	\$165.0	\$390.0	\$600.0	\$990.0	
Thomas Jefferson Middle School - Interior	001	114B	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$308.9	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	001	114C	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$308.9	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	114D	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$411.9	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	116A	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0	
Thomas Jefferson Middle School - Interior	001	116A	2x4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	3	336	0.336	3285	1103.76	\$198.6	None Proposed	3	336	0.336	3285	3285	1103.76	1103.76	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	117A	13W CFL Fixture	1	13	0.013	3285	42.705	\$7.6	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	117A	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	8	704	0.704	3285	2312.64	\$411.9	None Proposed	8	704	0.704	3285	3285	2312.64	2312.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	117B	2x4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	6	528	0.528	3285	1734.48	\$308.9	None Proposed	6	528	0.528	3285	3285	1734.48	1734.48	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	120A	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.969	259.4	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0	
Thomas Jefferson Middle School - Interior	001	120B	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	3285	1124.784	\$200.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	3285	3285	638.604	638.604	None Proposed	0	0.148	486.18	86.6	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$260.0	\$320.0	\$580.0	
Thomas Jefferson Middle School - Interior	001	Auditorium	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	30	1284	1.284	3285	4217.94	\$751.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	30	729.6	0.7296	3285	3285	2396.736	2396.736	None Proposed	0	0.5544	1821.204	324.4	\$35.0	\$5.0	\$65.0	\$0.0	\$65.0	\$40.0	\$105.0	\$1,850.0	\$1,200.0	\$3,150.0	
Thomas Jefferson Middle School - Interior	001	Auditorium	42W CFL Fixture	6	294	0.294	3285	965.79	\$172.0	None Proposed	6	294	0.294	3285	3285	965.79	965.79	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Band	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	4	342.4	0.3424	3285	1124.784	\$200.3	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	194.4	0.1944	3285	3285	638.604	638.604	None Proposed	0	0.148	486.18	86.6	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$260.0	\$320.0	\$580.0	
Thomas Jefferson Middle School - Interior	001	Band	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	34	5620.8	5.6208	3285	19121.328	\$3,405.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	34	3308.2	3.3082	3285	3285	10867.437	10867.437	None Proposed	0	2.5126	8253.891	1,470.0	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$2,210.0	\$4,250.0	\$6,460.0	
Thomas Jefferson Middle School - Interior	001	Cafeteria	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	64	5478.4	5.4784	3285	17996.544	\$3,205.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	64	3110.4	3.1104	3285	3285	10217.664	10217.664	None Proposed	0	2.368	7778.88	1,385.4	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$4,160.0	\$5,120.0	\$9,280.0	
Thomas Jefferson Middle School - Interior	001	Child Study	2x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	5	428	0.428	3285	1405.98	\$250.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	5	243	0.243	3285	3285	798.255	798.255	None Proposed	0	0.185	607.725	108.2	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$325.0	\$400.0	\$725.0	
Thomas Jefferson Middle School - Interior	001	Custodians	13W CFL Fixture	3	39	0.039	500	19.5	\$3.5	None Proposed	3	39	0.039	500	500	19.5	19.5	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	001	Custodians	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	500	85.6	\$15.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	500	500	48.6	48.6	None Proposed	0	0.074	37	6.6	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$130.0	\$160.0	\$290.0	
Thomas Jefferson Middle School - Interior	001	Custodians	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	10	1712	1.712	500	856	\$152.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	973	0.973	500	500	486.5	486.5	None Proposed	0	0.739	369.5	65.8	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$650.0	\$1,250.0	\$1,900.0	
Thomas Jefferson Middle School - Interior	001	Dance Room	13W CFL Fixture	7	91	0.091	3285	298.935	\$53.2	None Proposed	7	91	0.091	3285	3285	298.935	298.935	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	001	Dance Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	10	856	0.856	3285	2811.96	\$500.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	486	0.486	3285	3285	1596.51	1596.51	None Proposed	0	0.37	1215.45	216.5	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$650.0	\$800.0	\$1,450.0	

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total
Thomas Jefferson Middle School - Interior	001	Men's Bathroom	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	500	85.6	\$15.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	500	350	48.6	34.02	Ceiling Mounted Occupancy Sensor	1	0.074	\$15.8	9.2	\$70.0	\$10.0	\$65.0	\$103.0	\$73.5	\$65.0	\$80.0	\$145.0	\$303.5	\$263.0	\$466.5
Thomas Jefferson Middle School - Interior	001	Men's Bathroom	2X2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.5	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Men's Bathroom	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	500	112	\$19.9	None Proposed	2	224	0.224	500	350	112	78.4	Ceiling Mounted Occupancy Sensor	1	0	33.6	6.0	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Men's Locker Room	13W CFL Fixture	6	78	0.078	3285	256.23	\$45.6	None Proposed	6	78	0.078	3285	3285	256.23	256.23	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Men's Locker Room	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$400.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	172.9	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$260.0	\$500.0	\$760.0
Thomas Jefferson Middle School - Interior	001	Men's Room	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.5	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Men's Room	60W Incandescent Fixture	1	60	0.06	500	30	\$5.3	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0.047	25.45	4.5	\$0.0	\$5.0	\$20.0	\$103.0	\$73.5	\$20.0	\$5.0	\$25.0	\$93.5	\$108.0	\$201.5
Thomas Jefferson Middle School - Interior	001	Nurse	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	9	792	0.792	3285	2601.72	\$463.4	None Proposed	9	792	0.792	3285	3285	2601.72	2601.72	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Practice Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	5	428	0.428	3285	1405.98	\$250.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	5	243	0.243	3285	3285	798.255	798.255	None Proposed	0	0.185	607.725	108.2	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$325.0	\$400.0	\$725.0
Thomas Jefferson Middle School - Interior	001	Stairwell	13W CFL Fixture	1	13	0.013	8760	113.88	\$20.3	None Proposed	1	13	0.013	8760	8760	113.88	113.88	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Stairwell	13W CFL Fixture	1	13	0.013	8760	113.88	\$20.3	None Proposed	1	13	0.013	8760	8760	113.88	113.88	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Stairwell	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	1	85.6	0.0856	8760	749.856	\$133.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	48.6	0.0486	8760	8760	425.736	425.736	None Proposed	0	0.037	324.12	57.7	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$65.0	\$80.0	\$145.0
Thomas Jefferson Middle School - Interior	001	Stairwell	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	3	256.8	0.2568	8760	2249.568	\$400.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	145.8	0.1458	8760	8760	1277.208	1277.208	None Proposed	0	0.111	972.36	173.2	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$195.0	\$240.0	\$435.0
Thomas Jefferson Middle School - Interior	001	Stairwell 1	13W CFL Fixture	2	26	0.026	8760	227.76	\$40.6	None Proposed	2	26	0.026	8760	8760	227.76	227.76	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Stairwell 1	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	2	171.2	0.1712	8760	1499.712	\$267.1	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	97.2	0.0972	8760	8760	851.472	851.472	None Proposed	0	0.074	648.24	115.4	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$130.0	\$160.0	\$290.0
Thomas Jefferson Middle School - Interior	001	Stairwell 2	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	1	85.6	0.0856	8760	749.856	\$133.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	48.6	0.0486	8760	8760	425.736	425.736	None Proposed	0	0.037	324.12	57.7	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$65.0	\$80.0	\$145.0
Thomas Jefferson Middle School - Interior	001	Stairwell 5	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	3	256.8	0.2568	8760	2249.568	\$400.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	3	145.8	0.1458	8760	8760	1277.208	1277.208	None Proposed	0	0.111	972.36	173.2	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$195.0	\$240.0	\$435.0
Thomas Jefferson Middle School - Interior	001	Stairwell 5	60W Incandescent Fixture	1	60	0.06	8760	525.6	\$93.6	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	8760	8760	113.88	113.88	None Proposed	0	0.047	411.72	73.3	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0
Thomas Jefferson Middle School - Interior	001	Storage	13W CFL Fixture	1	13	0.013	500	6.5	\$1.2	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Storage	13W CFL Fixture	1	13	0.013	500	6.5	\$1.2	None Proposed	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0	1.95	0.3	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Storage	13W CFL Fixture	4	52	0.052	500	26	\$4.6	None Proposed	4	52	0.052	500	350	26	18.2	Ceiling Mounted Occupancy Sensor	1	0	7.8	1.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Storage	60W Incandescent Fixture	4	240	0.24	500	120	\$21.4	Replace 60W Incandescent Fixture with 13W CFL	4	52	0.052	500	350	26	18.2	Ceiling Mounted Occupancy Sensor	1	0.188	101.8	18.1	\$0.0	\$5.0	\$20.0	\$103.0	\$73.5	\$20.0	\$5.0	\$25.0	\$153.5	\$123.0	\$276.5
Thomas Jefferson Middle School - Interior	001	Storage	60W Incandescent Fixture	3	180	0.18	500	90	\$16.0	Replace 60W Incandescent Fixture with 13W CFL	3	39	0.039	500	350	19.5	13.65	Ceiling Mounted Occupancy Sensor	1	0.141	76.35	13.6	\$0.0	\$5.0	\$20.0	\$103.0	\$73.5	\$20.0	\$5.0	\$25.0	\$133.5	\$118.0	\$251.5
Thomas Jefferson Middle School - Interior	001	Supply	13W CFL Fixture	2	26	0.026	3285	85.41	\$15.2	None Proposed	2	26	0.026	3285	3285	85.41	85.41	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	001	Women's Bathroom	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	500	50.7	\$9.0	None Proposed	2	101.4	0.1014	500	350	50.7	35.49	Ceiling Mounted Occupancy Sensor	1	0	15.21	2.7	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Women's Bathroom	2X4 Fixtures w/ 4-T8 Lamps w/ Electronic Ballasts	2	224	0.224	500	112	\$19.9	None Proposed	2	224	0.224	500	350	112	78.4	Ceiling Mounted Occupancy Sensor	1	0	33.6	6.0	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Women's Locker Room	13W CFL Fixture	13	169	0.169	3285	555.165	\$98.9	None Proposed	13	169	0.169	3285	3285	555.165	555.165	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	001	Women's Locker Room	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	28	1419.6	1.4196	3285	4663.386	\$830.5	None Proposed	28	1419.6	1.4196	3285	3285	4663.386	4663.386	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Women's Locker Room	2X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	3285	333.099	\$59.3	None Proposed	2	101.4	0.1014	3285	3285	333.099	333.099	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	001	Women's Room	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.5	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.4	\$0.0	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5	
Thomas Jefferson Middle School - Interior	001	Women's Room	60W Incandescent Fixture	1	60	0.06	500	30	\$5.3	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	500	350	6.5	4.55	Ceiling Mounted Occupancy Sensor	1	0.047	25.45	4.5	\$0.0	\$5.0	\$20.0	\$103.0	\$73.5	\$20.0	\$5.0	\$25.0	\$93.5	\$108.0	\$201.5
Thomas Jefferson Middle School - Interior	002	201	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0
Thomas Jefferson Middle School - Interior	002	202	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed	0	0.444	1458.54	259.8	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$780.0	\$960.0	\$1,740.0
Thomas Jefferson Middle School - Interior	002	203	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	12	1027.2	1.0272	3285	3374.352	\$601.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	12	583.2	0.5832	3285	3285	1915.812	1915.812	None Proposed															

Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bulb (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total	
Thomas Jefferson Middle School - Interior	002	Elevator	1x4 Fixtures w/ 1-T12 Lamp Fixture w/ Magnetic Ballast	1	42.8	0.0428	8760	374.928	\$66.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	24.32	0.02432	8760	8760	213.0432	213.0432	None Proposed	0	0.01848	161.8848	28.8	\$35.0	\$5.0	\$65.0	\$0.0	\$65.0	\$40.0	\$105.0	\$65.0	\$40.0	\$105.0		
Thomas Jefferson Middle School - Interior	002	Hallway	13W CFL Fixture	1	13	0.013	4015	52.195	\$9.3	None Proposed	1	13	0.013	4015	4015	52.195	52.195	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Thomas Jefferson Middle School - Interior	002	Hallway	150W Incandescent Fixture	1	150	0.15	4015	602.25	\$107.3	Replace 150W Incandescent Fixture with 25W CFL	1	25	0.025	4015	4015	100.375	100.375	None Proposed	0	0.125	501.875	89.4	\$0.0	\$7.0	\$20.0	\$0.0	\$20.0	\$7.0	\$27.0	\$20.0	\$7.0	\$27.0		
Thomas Jefferson Middle School - Interior	002	Hallway	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	18	3081.6	3.0816	4015	12372.624	\$2,203.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	18	1751.4	1.7514	4015	4015	7031.871	7031.871	None Proposed	0	1.3302	5340.753	951.2	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$1,170.0	\$2,250.0	\$3,420.0		
Thomas Jefferson Middle School - Interior	002	Hallway	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	11	1883.2	1.8832	4015	7561.048	\$1,346.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	11	1070.3	1.0703	4015	4015	4297.2545	4297.2545	None Proposed	0	0.8129	3263.7935	581.3	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$715.0	\$1,375.0	\$2,090.0		
Thomas Jefferson Middle School - Interior	002	Maintenance	42W CFL Fixture	1	49	0.049	3285	160.965	\$28.7	None Proposed	1	49	0.049	3285	3285	160.965	160.965	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0		
Thomas Jefferson Middle School - Interior	002	Maintenance	42W CFL Fixture	1	49	0.049	3285	160.965	\$28.7	None Proposed	1	49	0.049	3285	3285	160.965	160.965	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	002	Maintenance	42W CFL Fixture	1	49	0.049	3285	160.965	\$28.7	None Proposed	1	49	0.049	3285	3285	160.965	160.965	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	002	Media Center	13W CFL Fixture	1	13	0.013	3285	42.705	\$7.6	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	002	Media Center	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	49	4194.4	4.1944	3285	13778.604	\$2,453.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	49	2381.4	2.3814	3285	3285	7822.899	7822.899	None Proposed	0	1.813	5955.705	1,060.7	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$3,185.0	\$3,920.0	\$7,105.0		
Thomas Jefferson Middle School - Interior	002	Media Center	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$400.6	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	172.9	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$260.0	\$500.0	\$760.0		
Thomas Jefferson Middle School - Interior	002	Men's Bathroom	1x4 Fixtures w/ 1-T8 Lamps w/ Electronic Ballasts	2	50.8	0.0508	500	25.4	\$4.5	None Proposed	2	50.8	0.0508	500	350	25.4	17.78	Ceiling Mounted Occupancy Sensor	1	0	7.62	1.4	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Thomas Jefferson Middle School - Interior	002	Men's Bathroom	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	1	50.7	0.0507	500	25.35	\$4.5	None Proposed	1	50.7	0.0507	500	350	25.35	17.745	Ceiling Mounted Occupancy Sensor	1	0	7.605	1.4	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Thomas Jefferson Middle School - Interior	002	Men's Bathroom	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	3	152.1	0.1521	500	76.05	\$13.5	None Proposed	3	152.1	0.1521	500	350	76.05	53.235	Ceiling Mounted Occupancy Sensor	1	0	22.815	4.1	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Thomas Jefferson Middle School - Interior	002	Roof Access	13W CFL Fixture	8	104	0.104	3285	341.64	\$60.8	None Proposed	8	104	0.104	3285	3285	341.64	341.64	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	002	Science Work Room	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	6	513.6	0.5136	3285	1687.176	\$300.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	6	291.6	0.2916	3285	3285	957.906	957.906	None Proposed	0	0.222	729.27	129.9	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$390.0	\$480.0	\$870.0		
Thomas Jefferson Middle School - Interior	002	Stairwell	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	6	304.2	0.3042	8760	2664.792	\$474.6	None Proposed	6	304.2	0.3042	8760	8760	2664.792	2664.792	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	
Thomas Jefferson Middle School - Interior	002	Stairwell	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	4	202.8	0.2028	8760	1776.528	\$316.4	None Proposed	4	202.8	0.2028	8760	8760	1776.528	1776.528	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	002	Stairwell	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	6	304.2	0.3042	8760	2664.792	\$474.6	None Proposed	6	304.2	0.3042	8760	8760	2664.792	2664.792	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Thomas Jefferson Middle School - Interior	002	Stairwell	60W Incandescent Fixture	1	60	0.06	8760	525.6	\$93.6	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	8760	8760	113.88	113.88	None Proposed	0	0.047	411.72	73.3	\$0.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0		
Thomas Jefferson Middle School - Interior	002	Stairwell	60W Incandescent Fixture	1	60	0.06	8760	525.6	\$93.6	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	8760	8760	113.88	113.88	None Proposed	0	0.047	411.72	73.3	\$0.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0		
Thomas Jefferson Middle School - Interior	002	Stairwell	60W Incandescent Fixture	1	60	0.06	8760	525.6	\$93.6	Replace 60W Incandescent Fixture with 13W CFL	1	13	0.013	8760	8760	113.88	113.88	None Proposed	0	0.047	411.72	73.3	\$0.0	\$5.0	\$20.0	\$0.0	\$20.0	\$5.0	\$25.0	\$20.0	\$5.0	\$25.0		
Thomas Jefferson Middle School - Interior	002	Women's Bathroom	1x4 Fixtures w/ 1-T8 Lamps w/ Electronic Ballasts	2	50.8	0.0508	500	25.4	\$4.5	None Proposed	2	50.8	0.0508	500	350	25.4	17.78	Ceiling Mounted Occupancy Sensor	1	0	7.62	1.4	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Thomas Jefferson Middle School - Interior	002	Women's Bathroom	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	3	152.1	0.1521	500	76.05	\$13.5	None Proposed	3	152.1	0.1521	500	350	76.05	53.235	Ceiling Mounted Occupancy Sensor	1	0	22.815	4.1	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Thomas Jefferson Middle School - Interior	002	Women's Bathroom	1x4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	500	50.7	\$9.0	None Proposed	2	101.4	0.1014	500	350	50.7	35.49	Ceiling Mounted Occupancy Sensor	1	0	15.21	2.7	\$0.0	\$0.0	\$103.0	\$73.5	\$0.0	\$0.0	\$0.0	\$73.5	\$103.0	\$176.5		
Whittier Elementary School - Exterior	000	Exterior	Exterior Wall Packs (Assume 70w)	8	720	0.72	5110	3679.2	\$613.2	Replace 70W Wall Pack Fixture with LED Area Light	8	440	0.44	5110	5110	2248.4	2248.4	None Proposed	0	0.28	1430.8	238.5	\$0.0	\$800.0	\$186.0	\$0.0	\$186.0	\$800.0	\$986.0	\$1,488.0	\$6,400.0	\$7,888.0		
Whittier Elementary School - Interior	000	Basement	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	28	2396.8	2.3968	3285	7873.488	\$1,312.2	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	28	1360.8	1.3608	3285	3285	4470.228	4470.228	None Proposed	0	1.036	3403.26	567.2	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$1,820.0	\$2,240.0	\$4,060.0		
Whittier Elementary School - Interior	001	1	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	2	342.4	0.3424	3285	1124.784	\$187.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	2	194.6	0.1946	3285	3285	639.261	639.261	None Proposed	0	0.1478	485.523	80.9	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$130.0	\$250.0	\$380.0		
Whittier Elementary School - Interior	001	2	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	1	85.6	0.0856	3285	281.196	\$46.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	48.6	0.0486	3285	3285	159.651	159.651	None Proposed	0	0.037	121.545	20.3	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$65.0	\$80.0	\$145.0		
Whittier Elementary School - Interior	001	2	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	4	684.8	0.6848	3285	2249.568	\$374.9	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	4	389.2	0.3892	3285	3285	1278.522	1278.522	None Proposed	0	0.2956	971.046	161.8	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$260.0	\$500.0	\$760.0		
Whittier Elementary School - Interior	001	3	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	1	171.2	0.1712	3285	562.392	\$93.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	1	97.3	0.0973	3285	3285	319.6305	319.6305	None Proposed	0	0.0739	242.7615	40.5	\$105.0	\$20.0	\$65.0	\$0.0	\$65.0	\$125.0	\$190.0	\$65.0	\$125.0	\$190.0		
Whittier Elementary School - Interior	001	4	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	10	856	0.856	3285	2811.96	\$468.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf. 0.78 Ballast Factor Ballast	10	486	0.486	3285	3285	1596.51	1596.51	None Proposed	0	0.37	1215.45	202.6	\$70.0	\$10.0	\$65.0	\$0.0	\$65.0	\$80.0	\$145.0	\$650.0	\$800.0	\$1,450.0		
Whittier Elementary School - Interior	001	4	2x2 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	3	152.1	0.1521	3285	499.6485	\$83.3	None Proposed	3	152.1	0.1521	3285	3285	499.6485	499.6485	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Whittier Elementary School - Interior	001																																	





Appendix D - Lighting Upgrades

Building	Floor	Location/Room #	Existing Fixture/Lamp & Ballast Description	Qty of Existing Fixtures	Existing Fixture Watts	Existing kW	Operating Hours	Existing kWh	Existing Annual Energy Cost	Proposed Replacement Solution	Qty of Existing Fixtures	Proposed Fixture Watts	Proposed kW Base	Proposed Operational Hours Without Sensors	Proposed Operational Hours With Sensors	Proposed kWh Without Sensors	Proposed kWh With Sensors	Proposed Occupancy Sensor Type	Occupancy Sensor Quantity	Total kW Saved	Total kWh Saved	Energy Cost Savings	Ballast/Fixture/Reflector Per Unit Price	Bub (Per Unit Price)	Labor (Per Unit Price)	Occupancy Sensor (Per Unit Price)	Occupancy Sensor (Per Unit Labor Price)	Labor Subtotal	Materials Subtotal	Labor & Materials Subtotal	Labor Total	Materials Total	Labor & Materials Total	
Whittier Elementary School - Interior	002	221	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	8	1369.6	1.3696	3285	4495.136	\$749.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	8	778.4	0.7784	3285	3285	2557.044	2557.044	None Proposed	0	0.5912	1942.092	323.7	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$520.0	\$1,000.0	\$1,520.0	
Whittier Elementary School - Interior	002	222	13W CFL Fixture	1	13	0.013	3285	42.705	\$7.1	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Whittier Elementary School - Interior	002	223	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	2	176	0.176	3285	578.16	\$96.4	None Proposed	2	176	0.176	3285	3285	578.16	578.16	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Whittier Elementary School - Interior	002	223	60W Incandescent Fixture	2	120	0.12	3285	394.2	\$65.7	Replace 60W Incandescent Fixture with 13W CFL	2	26	0.026	3285	3285	85.41	85.41	None Proposed	0	0.094	308.79	51.5	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$40.0	\$10.0	\$50.0	
Whittier Elementary School - Interior	002	224	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$562.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	242.8	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0	
Whittier Elementary School - Interior	002	225	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$562.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	242.8	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0	
Whittier Elementary School - Interior	002	226	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	1	171.2	0.1712	3285	562.392	\$93.7	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	1	97.3	0.0973	3285	3285	319.6305	319.6305	None Proposed	0	0.0739	242.7615	40.5	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$65.0	\$125.0	\$190.0	
Whittier Elementary School - Interior	002	227	1X4 Fixtures w/ 2-T8 Lamps w/ Electronic Ballasts	2	101.4	0.1014	3285	333.099	\$55.5	None Proposed	2	101.4	0.1014	3285	3285	333.099	333.099	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Whittier Elementary School - Interior	002	228	2x4 Fixtures w/ 4-T12 Lamp Fixture w/ Magnetic Ballast	6	1027.2	1.0272	3285	3374.352	\$562.4	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	6	583.8	0.5838	3285	3285	1917.783	1917.783	None Proposed	0	0.4434	1456.569	242.8	\$105.0	\$20.0	\$65.0	\$0.0	\$0.0	\$65.0	\$125.0	\$190.0	\$390.0	\$750.0	\$1,140.0	
Whittier Elementary School - Interior	002	229	13W CFL Fixture	1	13	0.013	3285	42.705	\$7.1	None Proposed	1	13	0.013	3285	3285	42.705	42.705	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Whittier Elementary School - Interior	002	Electrical Room	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	396	34848	34.848	3285	114475.68	\$19,079.0	None Proposed	396	34848	34.848	3285	3285	114475.68	114475.68	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Whittier Elementary School - Interior	002	Elevator	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	1	85.6	0.0856	8760	749.856	\$125.0	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	1	48.6	0.0486	8760	8760	425.736	425.736	None Proposed	0	0.037	324.12	54.0	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$65.0	\$80.0	\$145.0	
Whittier Elementary School - Interior	002	Hallway	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	66	5649.6	5.6496	4015	22683.144	\$3,780.5	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	66	3207.6	3.2076	4015	4015	12878.514	12878.514	None Proposed	0	2.442	9804.63	1,634.1	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$4,290.0	\$5,280.0	\$9,570.0	
Whittier Elementary School - Interior	002	Hallway	2X4 Fixtures w/ 3-T8 Lamps w/ Electronic Ballasts	11	968	0.968	4015	3886.52	\$647.7	None Proposed	11	968	0.968	4015	4015	3886.52	3886.52	None Proposed	0	0	0	0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
Whittier Elementary School - Interior	002	Stairwell	1x4 Fixtures w/ 2-T12 Lamp Fixture w/ Magnetic Ballast	7	599.2	0.5992	8760	5248.992	\$874.8	Replace T12 Bulbs With High Perf. T8 Bulbs, Replace Ballast w/ High Perf., 0.78 Ballast Factor Ballast	7	340.2	0.3402	8760	8760	2980.152	2980.152	None Proposed	0	0.259	2268.84	378.1	\$70.0	\$10.0	\$65.0	\$0.0	\$0.0	\$65.0	\$80.0	\$145.0	\$455.0	\$560.0	\$1,015.0	
Whittier Elementary School - Interior	002	Stairwell	60W Incandescent Fixture	2	120	0.12	8760	1051.2	\$175.2	Replace 60W Incandescent Fixture with 13W CFL	2	26	0.026	8760	8760	227.76	227.76	None Proposed	0	0.094	823.44	137.2	\$0.0	\$5.0	\$20.0	\$0.0	\$0.0	\$20.0	\$5.0	\$25.0	\$40.0	\$10.0	\$50.0	

APPENDIX E

SOLAR ENERGY FINANCING WORKSHEET

**Benjamin Franklin Middle School**

Design Goal: Provide  
17% of average annual electricity

**Existing Conditons**

Average Annual Electrical Usage (kWh) 1,899,653  
Current Utility Price (\$/kWh) 0.154

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day  
Solar Capacity Required (kW) 265.48  
Roof Space Needed (sq-ft) 26,548.00  
Annual Solar kWh (PV Watts) 325,372  
Net System installation Cost (\$9/kWh) \$2,389,320  
Electrical Service Modification Cost \$100,000  
Total System Installation Cost **\$2,489,320**  
Materials \$1,742,524  
Labor \$746,796  
Engineers Opinion of Probable Cost \$3,111,650

**Assumptions**

Annual System Degredation 0.50%  
Annual Utility Inflation 3.00%  
Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cummulative Cash Flow
Install							
1	0.1540	325,372.0	\$50,107.3	\$205,127	(\$6,507)	\$248,726.4	\$248,726.4
2	0.1586	323,745.1	\$51,352.5	\$198,998	(\$6,475)	\$243,875.9	\$492,602.3
3	0.1634	322,126.4	\$52,628.6	\$192,994	(\$6,443)	\$239,179.9	\$731,782.3
4	0.1683	320,515.8	\$53,936.4	\$186,268	(\$6,410)	\$233,794.1	\$965,576.4
5	0.1733	318,913.2	\$55,276.7	\$179,777	(\$6,378)	\$228,675.1	\$1,194,251.5
6	0.1785	317,318.6	\$56,650.3	\$173,511	(\$6,346)	\$223,815.4	\$1,418,066.9
7	0.1839	315,732.0	\$58,058.1	\$167,465	(\$6,315)	\$219,208.0	\$1,637,274.9
8	0.1894	314,153.4	\$59,500.8	\$161,628	(\$6,283)	\$214,846.2	\$1,852,121.0
9	0.1951	312,582.6	\$60,979.4	\$155,996	(\$6,252)	\$210,723.4	\$2,062,844.5
10	0.2009	311,019.7	\$62,494.8	\$150,559	(\$6,220)	\$206,833.6	\$2,269,678.0
11	0.2070	309,464.6	\$64,047.8	\$145,312	(\$6,189)	\$203,170.7	\$2,472,848.7
12	0.2132	307,917.3	\$65,639.3	\$140,248	(\$6,158)	\$199,729.1	\$2,672,577.8
13	0.2196	306,377.7	\$67,270.5	\$135,360	(\$6,128)	\$196,503.4	\$2,869,081.2
14	0.2262	304,845.8	\$68,942.2	\$130,643	(\$6,097)	\$193,488.4	\$3,062,569.6
15	0.2329	303,321.6	\$70,655.4	\$126,090	(\$6,066)	\$190,679.2	\$3,253,248.7
16	0.2399	301,805.0	\$72,411.2	\$7,545	(\$6,036)	\$73,920.2	\$3,327,168.9
17	0.2471	300,295.9	\$74,210.6	\$7,507	(\$6,006)	\$75,712.1	\$3,402,880.9
18	0.2545	298,794.5	\$76,054.7	\$7,470	(\$5,976)	\$77,548.7	\$3,480,429.6
19	0.2622	297,300.5	\$77,944.7	\$7,433	(\$5,946)	\$79,431.2	\$3,559,860.8
20	0.2700	295,814.0	\$79,881.6	\$7,395	(\$5,916)	\$81,360.7	\$3,641,221.5
21	0.2781	294,334.9	\$81,866.6	\$7,358	(\$5,887)	\$83,338.3	\$3,724,559.8
22	0.2865	292,863.2	\$83,901.0	\$7,322	(\$5,857)	\$85,365.4	\$3,809,925.1
23	0.2951	291,398.9	\$85,986.0	\$7,285	(\$5,828)	\$87,443.0	\$3,897,368.1
24	0.3039	289,941.9	\$88,122.7	\$7,249	(\$5,799)	\$89,572.4	\$3,986,940.5
25	0.3131	288,492.2	\$90,312.6	\$7,212	(\$5,770)	\$91,755.0	\$4,078,695.6

**Bryant Elementary School**

Design Goal: Provide

25% of average annual electricity

**Existing Conditons**

Average Annual Electrical Usage (kWh) 246,880

Current Utility Price (\$/kWh) \$0.1730

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day

Solar Capacity Required (kW) 49.752

Roof Space Needed (sq-ft) 4975.2

Annual Solar kWh (PV Watts) 60,976

Net System installation Cost (\$9/kWh) \$447,768

Electrical Service Modification Cost \$100,000

Total System Installation Cost **\$547,768**

Materials \$383,438

Labor \$164,330

Engineers Opinion of Probable Cost \$684,710

**Assumptions**

Annual System Degredation 0.50%

Annual Utility Inflation 3.00%

Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cummulative Cash Flow
Install							
1	0.1730	60,976.0	\$10,548.8	\$38,442	(\$1,220)	\$47,770.9	\$47,770.9
2	0.1782	60,671.1	\$10,811.0	\$37,293	(\$1,213)	\$46,890.7	\$94,661.5
3	0.1835	60,367.8	\$11,079.6	\$36,168	(\$1,207)	\$46,040.1	\$140,701.6
4	0.1890	60,065.9	\$11,355.0	\$34,907	(\$1,201)	\$45,061.0	\$185,762.6
5	0.1947	59,765.6	\$11,637.1	\$33,691	(\$1,195)	\$44,132.7	\$229,895.3
6	0.2006	59,466.8	\$11,926.3	\$32,517	(\$1,189)	\$43,253.7	\$273,149.0
7	0.2066	59,169.4	\$12,222.7	\$31,384	(\$1,183)	\$42,422.8	\$315,571.9
8	0.2128	58,873.6	\$12,526.4	\$30,290	(\$1,177)	\$41,638.8	\$357,210.6
9	0.2192	58,579.2	\$12,837.7	\$29,234	(\$1,172)	\$40,900.3	\$398,110.9
10	0.2257	58,286.3	\$13,156.7	\$28,215	(\$1,166)	\$40,206.4	\$438,317.3
11	0.2325	57,994.9	\$13,483.7	\$27,232	(\$1,160)	\$39,555.9	\$477,873.2
12	0.2395	57,704.9	\$13,818.7	\$26,283	(\$1,154)	\$38,947.7	\$516,820.9
13	0.2467	57,416.4	\$14,162.1	\$25,367	(\$1,148)	\$38,380.9	\$555,201.8
14	0.2541	57,129.3	\$14,514.1	\$24,483	(\$1,143)	\$37,854.5	\$593,056.3
15	0.2617	56,843.7	\$14,874.7	\$23,630	(\$1,137)	\$37,367.7	\$630,423.9
16	0.2695	56,559.4	\$15,244.4	1,414	(\$1,131)	\$15,527.2	\$645,951.1
17	0.2776	56,276.6	\$15,623.2	1,407	(\$1,126)	\$15,904.6	\$661,855.7
18	0.2859	55,995.3	\$16,011.4	1,400	(\$1,120)	\$16,291.4	\$678,147.1
19	0.2945	55,715.3	\$16,409.3	1,393	(\$1,114)	\$16,687.9	\$694,835.0
20	0.3034	55,436.7	\$16,817.1	1,386	(\$1,109)	\$17,094.3	\$711,929.3
21	0.3125	55,159.5	\$17,235.0	1,379	(\$1,103)	\$17,510.8	\$729,440.1
22	0.3218	54,883.7	\$17,663.3	1,372	(\$1,098)	\$17,937.7	\$747,377.8
23	0.3315	54,609.3	\$18,102.2	1,365	(\$1,092)	\$18,375.3	\$765,753.0
24	0.3414	54,336.3	\$18,552.1	1,358	(\$1,087)	\$18,823.7	\$784,576.8
25	0.3517	54,064.6	\$19,013.1	1,352	(\$1,081)	\$19,283.4	\$803,860.2

**Eugene Fields Administration Building**

Design Goal: Provide  
45% of average annual electricity

**Existing Conditons**

Average Annual Electrical Usage (kWh) 163,590  
Current Utility Price (\$/kWh) \$0.1650

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day  
Solar Capacity Required (kW) 60.2455  
Roof Space Needed (sq-ft) 6024.55  
Annual Solar kWh (PV Watts) 73,837  
Net System installation Cost (\$9/kWh) \$542,210  
Electrical Service Modification Cost \$100,000  
Total System Installation Cost **\$642,210**  
Materials \$449,547  
Labor \$192,663  
Engineers Opinion of Probable Cost \$802,762

**Assumptions**

Annual System Degredation 0.50%  
Annual Utility Inflation 3.00%  
Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cummulative Cash Flow
Install							
1	0.1650	73,837.0	\$12,183.1	\$46,550	(\$1,477)	\$57,255.9	\$57,255.9
2	0.1700	73,467.8	\$12,485.9	\$45,159	(\$1,469)	\$56,175.4	\$113,431.3
3	0.1750	73,100.5	\$12,796.1	\$43,796	(\$1,462)	\$55,130.4	\$168,561.8
4	0.1803	72,735.0	\$13,114.1	\$42,270	(\$1,455)	\$53,929.4	\$222,491.2
5	0.1857	72,371.3	\$13,440.0	\$40,797	(\$1,447)	\$52,789.5	\$275,280.7
6	0.1913	72,009.4	\$13,774.0	\$39,375	(\$1,440)	\$51,708.9	\$326,989.6
7	0.1970	71,649.4	\$14,116.3	\$38,003	(\$1,433)	\$50,686.2	\$377,675.8
8	0.2029	71,291.1	\$14,467.1	\$36,678	(\$1,426)	\$49,719.7	\$427,395.5
9	0.2090	70,934.7	\$14,826.6	\$35,400	(\$1,419)	\$48,808.1	\$476,203.6
10	0.2153	70,580.0	\$15,195.0	\$34,167	(\$1,412)	\$47,950.0	\$524,153.6
11	0.2217	70,227.1	\$15,572.6	\$32,976	(\$1,405)	\$47,143.9	\$571,297.5
12	0.2284	69,876.0	\$15,959.6	\$31,827	(\$1,398)	\$46,388.7	\$617,686.2
13	0.2353	69,526.6	\$16,356.2	\$30,717	(\$1,391)	\$45,683.1	\$663,369.3
14	0.2423	69,179.0	\$16,762.6	\$29,647	(\$1,384)	\$45,026.0	\$708,395.3
15	0.2496	68,833.1	\$17,179.2	\$28,614	(\$1,377)	\$44,416.3	\$752,811.6
16	0.2571	68,488.9	\$17,606.1	\$1,712	(\$1,370)	\$17,948.5	\$770,760.1
17	0.2648	68,146.5	\$18,043.6	\$1,704	(\$1,363)	\$18,384.3	\$789,144.4
18	0.2727	67,805.7	\$18,492.0	\$1,695	(\$1,356)	\$18,831.0	\$807,975.4
19	0.2809	67,466.7	\$18,951.5	\$1,687	(\$1,349)	\$19,288.8	\$827,264.3
20	0.2893	67,129.4	\$19,422.4	\$1,678	(\$1,343)	\$19,758.1	\$847,022.4
21	0.2980	66,793.7	\$19,905.1	\$1,670	(\$1,336)	\$20,239.1	\$867,261.4
22	0.3069	66,459.8	\$20,399.7	\$1,661	(\$1,329)	\$20,732.0	\$887,993.4
23	0.3162	66,127.5	\$20,906.7	\$1,653	(\$1,323)	\$21,237.3	\$909,230.7
24	0.3256	65,796.8	\$21,426.2	\$1,645	(\$1,316)	\$21,755.2	\$930,985.9
25	0.3354	65,467.8	\$21,958.6	\$1,637	(\$1,309)	\$22,286.0	\$953,271.9

**Hawthorne Elementary School**

Design Goal: Provide

50% of average annual electricity

**Existing Conditons**

Current Average Annual Electrical Usage (kW) 364,800

Current Utility Price (\$/kWh) \$0.1650

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day

Solar Capacity Required (kW) 148.119

Roof Space Needed (sq-ft) 14811.9

Annual Solar kWh (PV Watts) 181,535

Net System installation Cost (\$9/kWh) \$1,333,071

Electrical Service Modification Cost \$100,000

Total System Installation Cost **\$1,433,071**

Materials \$1,003,150

Labor \$429,921

Engineers Opinion of Probable Cost \$1,791,339

**Assumptions**

Annual System Degredation 0.50%

Annual Utility Inflation 3.00%

Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cummulative Cash Flow
Install							
1	0.1650	181,535.0	\$29,953.3	\$114,446	(\$3,631)	\$140,769.0	\$140,769.0
2	0.1700	180,627.3	\$30,697.6	\$111,027	(\$3,613)	\$138,112.4	\$278,881.3
3	0.1750	179,724.2	\$31,460.4	\$107,677	(\$3,594)	\$135,543.2	\$414,424.5
4	0.1803	178,825.6	\$32,242.2	\$103,925	(\$3,577)	\$132,590.4	\$547,014.9
5	0.1857	177,931.4	\$33,043.5	\$100,303	(\$3,559)	\$129,787.7	\$676,802.6
6	0.1913	177,041.8	\$33,864.6	\$96,807	(\$3,541)	\$127,131.1	\$803,933.7
7	0.1970	176,156.6	\$34,706.1	\$93,434	(\$3,523)	\$124,616.6	\$928,550.3
8	0.2029	175,275.8	\$35,568.6	\$90,177	(\$3,506)	\$122,240.5	\$1,050,790.8
9	0.2090	174,399.4	\$36,452.5	\$87,035	(\$3,488)	\$119,999.2	\$1,170,790.0
10	0.2153	173,527.4	\$37,358.3	\$84,002	(\$3,471)	\$117,889.3	\$1,288,679.3
11	0.2217	172,659.8	\$38,286.7	\$81,074	(\$3,453)	\$115,907.6	\$1,404,586.9
12	0.2284	171,796.5	\$39,238.1	\$78,249	(\$3,436)	\$114,050.8	\$1,518,637.8
13	0.2353	170,937.5	\$40,213.1	\$75,522	(\$3,419)	\$112,316.1	\$1,630,953.9
14	0.2423	170,082.8	\$41,212.4	\$72,890	(\$3,402)	\$110,700.6	\$1,741,654.5
15	0.2496	169,232.4	\$42,236.6	\$70,350	(\$3,385)	\$109,201.5	\$1,850,856.0
16	0.2571	168,386.2	\$43,286.1	\$4,210	(\$3,368)	\$44,128.1	\$1,894,984.1
17	0.2648	167,544.3	\$44,361.8	\$4,189	(\$3,351)	\$45,199.5	\$1,940,183.6
18	0.2727	166,706.6	\$45,464.2	\$4,168	(\$3,334)	\$46,297.7	\$1,986,481.3
19	0.2809	165,873.0	\$46,594.0	\$4,147	(\$3,317)	\$47,423.3	\$2,033,904.7
20	0.2893	165,043.7	\$47,751.8	\$4,126	(\$3,301)	\$48,577.1	\$2,082,481.7
21	0.2980	164,218.5	\$48,938.5	\$4,105	(\$3,284)	\$49,759.6	\$2,132,241.3
22	0.3069	163,397.4	\$50,154.6	\$4,085	(\$3,268)	\$50,971.6	\$2,183,212.9
23	0.3162	162,580.4	\$51,400.9	\$4,065	(\$3,252)	\$52,213.8	\$2,235,426.7
24	0.3256	161,767.5	\$52,678.3	\$4,044	(\$3,235)	\$53,487.1	\$2,288,913.8
25	0.3354	160,958.6	\$53,987.3	\$4,024	(\$3,219)	\$54,792.1	\$2,343,705.9

**Lowell Elementary School**

Design Goal: Provide

36% of average annual electricity

**Existing Conditons**

Current Average Annual Electrical Usage (kW) 240,580

Current Utility Price (\$/kWh) \$0.1880

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day

Solar Capacity Required (kW) 69.935

Roof Space Needed (sq-ft) 6993.5

Annual Solar kWh (PV Watts) 85,712

Net System installation Cost (\$9/kWh) \$629,415

Electrical Service Modification Cost \$100,000

**Total System Installation Cost \$729,415**

Materials \$510,591

Labor \$218,825

Engineers Opinion of Probable Cost \$911,769

**Assumptions**

Annual System Degredation 0.50%

Annual Utility Inflation 3.00%

Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cummulative Cash Flow
Install							
1	0.1880	85,712.0	\$16,113.9	\$54,036	(\$1,714)	\$68,435.6	\$68,435.6
2	0.1936	85,283.4	\$16,514.3	\$52,422	(\$1,706)	\$67,230.3	\$135,665.9
3	0.1994	84,857.0	\$16,924.7	\$50,840	(\$1,697)	\$66,067.5	\$201,733.4
4	0.2054	84,432.7	\$17,345.2	\$49,068	(\$1,689)	\$64,724.8	\$266,458.2
5	0.2116	84,010.6	\$17,776.3	\$47,358	(\$1,680)	\$63,454.2	\$329,912.4
6	0.2179	83,590.5	\$18,218.0	\$45,708	(\$1,672)	\$62,253.9	\$392,166.3
7	0.2245	83,172.6	\$18,670.7	\$44,115	(\$1,663)	\$61,122.1	\$453,288.4
8	0.2312	82,756.7	\$19,134.7	\$42,577	(\$1,655)	\$60,057.0	\$513,345.3
9	0.2382	82,342.9	\$19,610.2	\$41,094	(\$1,647)	\$59,056.9	\$572,402.3
10	0.2453	81,931.2	\$20,097.5	\$39,661	(\$1,639)	\$58,120.4	\$630,522.6
11	0.2527	81,521.6	\$20,596.9	\$38,279	(\$1,630)	\$57,245.8	\$687,768.4
12	0.2602	81,113.9	\$21,108.8	\$36,945	(\$1,622)	\$56,431.7	\$744,200.1
13	0.2680	80,708.4	\$21,633.3	\$35,658	(\$1,614)	\$55,676.8	\$799,876.9
14	0.2761	80,304.8	\$22,170.9	\$34,415	(\$1,606)	\$54,979.8	\$854,856.8
15	0.2844	79,903.3	\$22,721.9	\$33,216	(\$1,598)	\$54,339.4	\$909,196.2
16	0.2929	79,503.8	\$23,286.5	\$1,988	(\$1,590)	\$23,684.0	\$932,880.2
17	0.3017	79,106.3	\$23,865.2	\$1,978	(\$1,582)	\$24,260.7	\$957,140.9
18	0.3107	78,710.7	\$24,458.2	\$1,968	(\$1,574)	\$24,851.8	\$981,992.7
19	0.3201	78,317.2	\$25,066.0	\$1,958	(\$1,566)	\$25,457.6	\$1,007,450.3
20	0.3297	77,925.6	\$25,688.9	\$1,948	(\$1,559)	\$26,078.5	\$1,033,528.8
21	0.3395	77,536.0	\$26,327.3	\$1,938	(\$1,551)	\$26,714.9	\$1,060,243.7
22	0.3497	77,148.3	\$26,981.5	\$1,929	(\$1,543)	\$27,367.2	\$1,087,610.9
23	0.3602	76,762.6	\$27,652.0	\$1,919	(\$1,535)	\$28,035.8	\$1,115,646.7
24	0.3710	76,378.7	\$28,339.1	\$1,909	(\$1,528)	\$28,721.0	\$1,144,367.7
25	0.3822	75,996.8	\$29,043.4	\$1,900	(\$1,520)	\$29,423.3	\$1,173,791.1



**Teaneck High School**

Design Goal: Provide

57% of average annual electricity

**Existing Conditions**

Current Average Annual Electrical Usage (kWh) 600,000

Current Utility Price (\$/kWh) \$0.1590

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day

Solar Capacity Required (kW) 277.758

Roof Space Needed (sq-ft) 27775.8

Annual Solar kWh (PV Watts) 340,420

Net System installation Cost (\$/kWh) \$2,499,822

Electrical Service Modification Cost \$100,000

Total System Installation Cost **\$2,599,822**

Materials \$1,819,875

Labor \$779,947

Engineers Opinion of Probable Cost \$3,249,778

**Assumptions**

Annual System Degredation 0.50%

Annual Utility Inflation 3.00%

Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cumulative Cash Flow
Install							
1	0.1590	340,420.0	\$54,126.8	\$214,613	(\$6,808)	\$261,931.7	\$261,931.7
2	0.1638	338,717.9	\$55,471.8	\$208,202	(\$6,774)	\$256,899.3	\$518,831.0
3	0.1687	337,024.3	\$56,850.3	\$201,920	(\$6,740)	\$252,029.4	\$770,860.4
4	0.1737	335,339.2	\$58,263.0	\$194,883	(\$6,707)	\$246,439.0	\$1,017,299.4
5	0.1790	333,662.5	\$59,710.9	\$188,091	(\$6,673)	\$241,128.7	\$1,258,428.1
6	0.1843	331,994.2	\$61,194.7	\$181,536	(\$6,640)	\$236,090.9	\$1,494,519.0
7	0.1899	330,334.2	\$62,715.4	\$175,210	(\$6,607)	\$231,318.2	\$1,725,837.2
8	0.1955	328,682.5	\$64,273.9	\$169,103	(\$6,574)	\$226,803.7	\$1,952,640.9
9	0.2014	327,039.1	\$65,871.1	\$163,210	(\$6,541)	\$222,540.5	\$2,175,181.4
10	0.2075	325,403.9	\$67,508.0	\$157,522	(\$6,508)	\$218,522.2	\$2,393,703.6
11	0.2137	323,776.9	\$69,185.5	\$152,033	(\$6,476)	\$214,742.7	\$2,608,446.3
12	0.2201	322,158.0	\$70,904.8	\$146,734	(\$6,443)	\$211,196.0	\$2,819,642.3
13	0.2267	320,547.2	\$72,666.8	\$141,621	(\$6,411)	\$207,876.5	\$3,027,518.8
14	0.2335	318,944.5	\$74,472.5	\$136,685	(\$6,379)	\$204,778.8	\$3,232,297.7
15	0.2405	317,349.8	\$76,323.2	\$131,922	(\$6,347)	\$201,897.9	\$3,434,195.6
16	0.2477	315,763.0	\$78,219.8	\$7,894	(\$6,315)	\$79,798.6	\$3,513,994.2
17	0.2551	314,184.2	\$80,163.6	\$7,855	(\$6,284)	\$81,734.5	\$3,595,728.7
18	0.2628	312,613.3	\$82,155.6	\$7,815	(\$6,252)	\$83,718.7	\$3,679,447.4
19	0.2707	311,050.2	\$84,197.2	\$7,776	(\$6,221)	\$85,752.5	\$3,765,199.8
20	0.2788	309,495.0	\$86,289.5	\$7,737	(\$6,190)	\$87,837.0	\$3,853,036.8
21	0.2872	307,947.5	\$88,433.8	\$7,699	(\$6,159)	\$89,973.5	\$3,943,010.4
22	0.2958	306,407.8	\$90,631.4	\$7,660	(\$6,128)	\$92,163.4	\$4,035,173.8
23	0.3047	304,875.7	\$92,883.6	\$7,622	(\$6,098)	\$94,408.0	\$4,129,581.7
24	0.3138	303,351.3	\$95,191.7	\$7,584	(\$6,067)	\$96,708.5	\$4,226,290.2
25	0.3232	301,834.6	\$97,557.2	\$7,546	(\$6,037)	\$99,066.4	\$4,325,356.6

**Thomas Jefferson Middle School**

Design Goal: Provide

96% of average annual electricity

**Existing Conditons**

Current Average Annual Electrical Usage (kW) 698,640

Current Utility Price (\$/kWh) \$0.1780

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day

Solar Capacity Required (kW) 549.525

Roof Space Needed (sq-ft) 54952.5

Annual Solar kWh (PV Watts) 673,498

Net System installation Cost (\$/kWh) \$4,945,725

Electrical Service Modification Cost \$100,000

**Total System Installation Cost \$5,045,725**

Materials \$3,532,008

Labor \$1,513,718

Engineers Opinion of Probable Cost \$6,307,156

**Assumptions**

Annual System Degredation 0.50%

Annual Utility Inflation 3.00%

Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cummulative Cash Flow
Install							
1	0.1780	673,498.0	\$119,882.6	\$424,598	(\$13,470)	\$531,010.7	\$531,010.7
2	0.1833	670,130.5	\$122,861.7	\$411,913	(\$13,403)	\$521,372.3	\$1,052,383.0
3	0.1888	666,779.9	\$125,914.8	\$399,484	(\$13,336)	\$512,063.6	\$1,564,446.6
4	0.1945	663,446.0	\$129,043.8	\$385,562	(\$13,269)	\$501,337.2	\$2,065,783.8
5	0.2003	660,128.7	\$132,250.6	\$372,125	(\$13,203)	\$491,173.4	\$2,556,957.3
6	0.2064	656,828.1	\$135,537.0	\$359,157	(\$13,137)	\$481,557.3	\$3,038,514.6
7	0.2125	653,543.9	\$138,905.1	\$346,640	(\$13,071)	\$472,474.5	\$3,510,989.0
8	0.2189	650,276.2	\$142,356.9	\$334,560	(\$13,006)	\$463,911.2	\$3,974,900.3
9	0.2255	647,024.8	\$145,894.4	\$322,900	(\$12,940)	\$455,854.4	\$4,430,754.6
10	0.2322	643,789.7	\$149,519.9	\$311,647	(\$12,876)	\$448,291.5	\$4,879,046.1
11	0.2392	640,570.8	\$153,235.5	\$300,786	(\$12,811)	\$441,210.5	\$5,320,256.7
12	0.2464	637,367.9	\$157,043.4	\$290,304	(\$12,747)	\$434,600.1	\$5,754,856.7
13	0.2538	634,181.1	\$160,945.9	\$280,187	(\$12,684)	\$428,449.2	\$6,183,306.0
14	0.2614	631,010.2	\$164,945.4	\$270,422	(\$12,620)	\$422,747.7	\$6,606,053.6
15	0.2692	627,855.1	\$169,044.3	\$260,998	(\$12,557)	\$417,485.4	\$7,023,539.1
16	0.2773	624,715.8	\$173,245.1	\$15,618	(\$12,494)	\$176,368.7	\$7,199,907.7
17	0.2856	621,592.3	\$177,550.2	\$15,540	(\$12,432)	\$180,658.2	\$7,380,565.9
18	0.2942	618,484.3	\$181,962.3	\$15,462	(\$12,370)	\$185,054.8	\$7,565,620.6
19	0.3030	615,391.9	\$186,484.1	\$15,385	(\$12,308)	\$189,561.1	\$7,755,181.7
20	0.3121	612,314.9	\$191,118.2	\$15,308	(\$12,246)	\$194,179.8	\$7,949,361.5
21	0.3215	609,253.3	\$195,867.5	\$15,231	(\$12,185)	\$198,913.8	\$8,148,275.3
22	0.3311	606,207.1	\$200,734.8	\$15,155	(\$12,124)	\$203,765.9	\$8,352,041.2
23	0.3411	603,176.0	\$205,723.1	\$15,079	(\$12,064)	\$208,739.0	\$8,560,780.1
24	0.3513	600,160.2	\$210,835.3	\$15,004	(\$12,003)	\$213,836.1	\$8,774,616.2
25	0.3618	597,159.4	\$216,074.6	\$14,929	(\$11,943)	\$219,060.4	\$8,993,676.6

**Whittier Elementary School**

Design Goal: Provide  
79% of average annual electricity

**Existing Conditions**

Current Average Annual Electrical Usage (kWh) 371,800  
Current Utility Price (\$/kWh) \$0.1670

**Calculations**

Solar Rating (Zip Code: 07666) 4.60 kWh/sq-m/day  
Solar Capacity Required (kW) 239.8695  
Roof Space Needed (sq-ft) 23986.95  
Annual Solar kWh (PV Watts) 293,984  
Net System installation Cost (\$9/kWh) \$2,158,826  
Electrical Service Modification Cost \$100,000  
Total System Installation Cost **\$2,258,826**  
Materials \$1,581,178  
Labor \$677,648  
Engineers Opinion of Probable Cost \$2,823,532

**Assumptions**

Annual System Degredation 0.50%  
Annual Utility Inflation 3.00%  
Annual Maintenance Costs 2%

Year	Utility Price	Solar kWh	Utility Savings	SRECS	Maintenance Costs	Annual Cash Flow	Cumulative Cash Flow
Install							
1	0.1670	293,984.0	\$49,095.3	\$185,338	(\$5,880)	\$228,554.0	\$228,554.0
2	0.1720	292,514.1	\$50,315.3	\$179,801	(\$5,850)	\$224,266.5	\$452,820.5
3	0.1772	291,051.5	\$51,565.7	\$174,376	(\$5,821)	\$220,120.8	\$672,941.3
4	0.1825	289,596.3	\$52,847.1	\$168,299	(\$5,792)	\$215,354.3	\$888,295.7
5	0.1880	288,148.3	\$54,160.3	\$162,434	(\$5,763)	\$210,831.3	\$1,099,127.0
6	0.1936	286,707.5	\$55,506.2	\$156,773	(\$5,734)	\$206,545.2	\$1,305,672.1
7	0.1994	285,274.0	\$56,885.6	\$151,310	(\$5,705)	\$202,489.6	\$1,508,161.8
8	0.2054	283,847.6	\$58,299.2	\$146,036	(\$5,677)	\$198,658.6	\$1,706,820.4
9	0.2116	282,428.4	\$59,747.9	\$140,947	(\$5,649)	\$195,046.4	\$1,901,866.8
10	0.2179	281,016.2	\$61,232.6	\$136,035	(\$5,620)	\$191,647.4	\$2,093,514.2
11	0.2244	279,611.2	\$62,754.3	\$131,294	(\$5,592)	\$188,456.3	\$2,281,970.4
12	0.2312	278,213.1	\$64,313.7	\$126,719	(\$5,564)	\$185,468.1	\$2,467,438.5
13	0.2381	276,822.0	\$65,911.9	\$122,302	(\$5,536)	\$182,677.9	\$2,650,116.5
14	0.2452	275,437.9	\$67,549.8	\$118,040	(\$5,509)	\$180,081.3	\$2,830,197.8
15	0.2526	274,060.7	\$69,228.4	\$113,927	(\$5,481)	\$177,673.7	\$3,007,871.5
16	0.2602	272,690.4	\$70,948.7	\$6,817	(\$5,454)	\$72,312.2	\$3,080,183.7
17	0.2680	271,327.0	\$72,711.8	\$6,783	(\$5,427)	\$74,068.5	\$3,154,252.2
18	0.2760	269,970.3	\$74,518.7	\$6,749	(\$5,399)	\$75,868.6	\$3,230,120.7
19	0.2843	268,620.5	\$76,370.5	\$6,716	(\$5,372)	\$77,713.6	\$3,307,834.3
20	0.2928	267,277.4	\$78,268.3	\$6,682	(\$5,346)	\$79,604.7	\$3,387,439.0
21	0.3016	265,941.0	\$80,213.3	\$6,649	(\$5,319)	\$81,543.0	\$3,468,982.0
22	0.3107	264,611.3	\$82,206.6	\$6,615	(\$5,292)	\$83,529.6	\$3,552,511.7
23	0.3200	263,288.2	\$84,249.4	\$6,582	(\$5,266)	\$85,565.9	\$3,638,077.5
24	0.3296	261,971.8	\$86,343.0	\$6,549	(\$5,239)	\$87,652.9	\$3,725,730.4
25	0.3395	260,661.9	\$88,488.6	\$6,517	(\$5,213)	\$89,791.9	\$3,815,522.3

APPENDIX F

FACILITY DATA FORMS



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Benjamin Franklin Middle School			
<b>Street Address</b> 1315 Taft Road		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> 3 Story Structure Grades 5 - 8			
<b>Total Sq Ft</b> 100,202	<b>Year Built</b> 1957	<b>Hours/Week Occupied</b> 90	<b>Number of Employees</b> 105 emp. / 575 students
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/> Emergency Services	<input type="checkbox"/> Garage		
<input type="checkbox"/> Center/Meeting Hall/Library	<input type="checkbox"/> Offices		
<input type="checkbox"/> Recreation/Entertainment/Parks	<input type="checkbox"/> Religious		
<input checked="" type="checkbox"/> School	<input type="checkbox"/> School: College		
<input type="checkbox"/> Water Treatment/Pumping	<input type="checkbox"/> Other: _____		

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

<b>The Data Below is for the 12 Month Period:</b> <u>7</u> / <u>1</u> / <u>08</u> to <u>6</u> <u>3</u> <u>0</u> <u>0</u> <u>9</u>
---



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #42 008 678 18	
<b>Annual kWh Use</b> 862,080	<b>Annual Electricity Cost</b> \$136,841.27
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #42 008 678 18	
<b>Annual Use in Therms</b> 6,662.257	<b>Annual Natural Gas Cost</b> \$8,403.43

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Allied #128386	
<b>Annual Use in Gallons</b> 30,092.70	<b>Annual Fuel Oil Cost</b> \$55,321.93

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

<b>Date Received:</b> _____	<b>Project No.:</b> _____
-----------------------------	---------------------------



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Bryant Elementary School			
<b>Street Address</b> 1 Tryon Avenue		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> 1 Story Structure Grades Pre-K & K			
<b>Total Sq Ft</b> 47,438	<b>Year Built</b> 1926 (1948,1952,1997)	<b>Hours/Week Occupied</b> 90	<b>Number of Employees</b> 76 emp. / 385 students
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/>	<b>Emergency Services</b>	<input type="checkbox"/>	<b>Garage</b>
<input type="checkbox"/>	<b>Center/Meeting Hall/Library</b>	<input type="checkbox"/>	<b>Offices</b>
<input type="checkbox"/>	<b>Recreation/Entertainment/Parks</b>	<input type="checkbox"/>	<b>Religious</b>
<input checked="" type="checkbox"/>	<b>School</b>	<input type="checkbox"/>	<b>School: College</b>
<input type="checkbox"/>	<b>Water Treatment/Pumping</b>	<input type="checkbox"/>	<b>Other:</b> _____

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

<b>The Data Below is for the 12 Month Period:</b> <u>7</u> / <u>1</u> / <u>08</u> to <u>6</u> / <u>30</u> / <u>09</u>
---



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #65 828 671 05	
<b>Annual kWh Use</b> 291,040	<b>Annual Electricity Cost</b> \$45,770.43
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #65 828 671 05	
<b>Annual Use in Therms</b> 134.892	<b>Annual Natural Gas Cost</b> \$286.17

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Allied #128382	
<b>Annual Use in Gallons</b> 36469.70	<b>Annual Fuel Oil Cost</b> \$66,337.71

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

<b>Date Received:</b> _____	<b>Project No.:</b> _____
-----------------------------	---------------------------





# APPENDIX C - FACILITY DATA FORM

Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.

## FACILITY INFORMATION

Please complete the information below for this specific facility that is seeking enrollment in the Program.

<b>Facility Name</b> Eugene Field Administration Building			
<b>Street Address</b> 1 Merrison Street		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> 2 Story Structure Central Administration Offices			
<b>Total Sq Ft</b> 24,877	<b>Year Built</b> 1955	<b>Hours/Week Occupied</b> 85	<b>Number of Employees</b> 47 employees
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/> Emergency Services	<input type="checkbox"/> Garage		
<input type="checkbox"/> Center/Meeting Hall/Library	<input checked="" type="checkbox"/> Offices		
<input type="checkbox"/> Recreation/Entertainment/Parks	<input type="checkbox"/> Religious		
<input type="checkbox"/> School	<input type="checkbox"/> School: College		
<input type="checkbox"/> Water Treatment/Pumping	<input type="checkbox"/> Other: _____		

## ENERGY DATA

Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.

<b>The Data Below is for the 12 Month Period:</b> 7 / 1 / 0 8 to 6 / 3 0 0 9
--



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #65 900 523 01	
<b>Annual kWh Use</b> 179,610	<b>Annual Electricity Cost</b> \$30,848.01
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #65 900 523 01	
<b>Annual Use in Therms</b> 648.96	<b>Annual Natural Gas Cost</b> \$916.28

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Allied #128385	
<b>Annual Use in Gallons</b> 9,297.5	<b>Annual Fuel Oil Cost</b> \$17,170.33

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

Date Received: _____	Project No.: _____
----------------------	--------------------



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Hawthorne Elementary School			
<b>Street Address</b> 201 Fycke Lane		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> 1 Story Structure Grades 1 - 4			
<b>Total Sq Ft</b> 49,373	<b>Year Built</b> 1925 (1950,1997)	<b>Hours/Week Occupied</b> 90	<b>Number of Employees</b> 60 emp. / 342 students
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/>	<b>Emergency Services</b>	<input type="checkbox"/>	<b>Garage</b>
<input type="checkbox"/>	<b>Center/Meeting Hall/Library</b>	<input type="checkbox"/>	<b>Offices</b>
<input type="checkbox"/>	<b>Recreation/Entertainment/Parks</b>	<input type="checkbox"/>	<b>Religious</b>
<input checked="" type="checkbox"/>	<b>School</b>	<input type="checkbox"/>	<b>School: College</b>
<input type="checkbox"/>	<b>Water Treatment/Pumping</b>	<input type="checkbox"/>	<b>Other:</b> _____

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

**The Data Below is for the 12 Month Period:** 7 / 1 / 08 to 6 / 30 / 09



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #67 562 643 03	
<b>Annual kWh Use</b> 414,450	<b>Annual Electricity Cost</b> \$63,843.93
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #67 562 643 03	
<b>Annual Use in Therms</b> 41,287.56	<b>Annual Natural Gas Cost</b> \$47,485.61

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Fuel Oil Cost</b>

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

Date Received: _____	Project No.: _____
----------------------	--------------------



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Lowell Elementary School			
<b>Street Address</b> 1025 Lincoln Place		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> 2 Story Structure Grades 1 - 4			
<b>Total Sq Ft</b> 47,106	<b>Year Built</b> 1934 (1998)	<b>Hours/Week Occupied</b> 90	<b>Number of Employees</b> 61 emp. / 305 students
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/> Emergency Services	<input type="checkbox"/> Garage		
<input type="checkbox"/> Center/Meeting Hall/Library	<input type="checkbox"/> Offices		
<input type="checkbox"/> Recreation/Entertainment/Parks	<input type="checkbox"/> Religious		
<input checked="" type="checkbox"/> School	<input type="checkbox"/> School: College		
<input type="checkbox"/> Water Treatment/Pumping	<input type="checkbox"/> Other: _____		

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

The Data Below is for the 12 Month Period: 7 / 1 / 08 to 6 / 30 / 09



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #65 900 523 01	
<b>Annual kWh Use</b> 322,400	<b>Annual Electricity Cost</b> \$46,721.38
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #65 900 523 01	
<b>Annual Use in Therms</b> 17,257.89	<b>Annual Natural Gas Cost</b> \$765.89

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Allied #128383	
<b>Annual Use in Gallons</b> 25,680.90	<b>Annual Fuel Oil Cost</b> \$47,910.42

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

Date Received: _____	Project No.: _____
----------------------	--------------------



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Teaneck High School			
<b>Street Address</b> 100 Elizabeth Avenue		<b>County</b> Bergen	
<b>City</b> Teaneck	<b>State</b> New Jersey	<b>Zip</b> 07666	
<b>Facility's Description</b> 3 Story Structure Grades 9 - 12			
<b>Total Sq Ft</b> 215,808	<b>Year Built</b> 1927-34 (1956,1978)	<b>Hours/Week Occupied</b> 110	<b>Number of Employees</b> 187 emp. / 1,410 students
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/>	Emergency Services	<input type="checkbox"/>	Garage
<input type="checkbox"/>	Center/Meeting Hall/Library	<input type="checkbox"/>	Offices
<input type="checkbox"/>	Recreation/Entertainment/Parks	<input type="checkbox"/>	Religious
<input checked="" type="checkbox"/>	School	<input type="checkbox"/>	School: College
<input type="checkbox"/>	Water Treatment/Pumping	<input type="checkbox"/>	Other: _____

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

<b>The Data Below is for the 12 Month Period:</b> <u>7</u> / <u>1</u> / <u>08</u> to <u>6</u> <u>3</u> <u>0</u> <u>0</u> <u>9</u>
---



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #42 003 120 18	
<b>Annual kWh Use</b> 1,695,696	<b>Annual Electricity Cost</b> \$295,315.62
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #42 003 120 18 (Meter 1) PSE&G #66 793 594 06 (Meter 2)	
<b>Annual Use in Therms</b> 1,102.407 (Meter 1) 116,185.3 (Meter 2- 9/08-7/09)	<b>Annual Natural Gas Cost</b> \$1,425.38 (Meter1) \$121,524.85 (Meter2 9/08-7/09)

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Allied #128393	
<b>Annual Use in Gallons</b> * 45,580.7 (7/1/08-12/1/09) switched to gas	<b>Annual Fuel Oil Cost</b> * \$149,446.88 (7/1/08-12/1/09) switched to gas

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

Date Received: _____	Project No.: _____
----------------------	--------------------





## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Teaneck High School - Athletic Field - Lights			
<b>Street Address</b> 100 Elizabeth Avenue		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> Lighting for Athletic Field / Stadium - 4 light poles - Used Mainly for Varsity, Junior Varsity, Freshman, & Recreational Football Games and Marching Band & Cheerleader Practice for the Months of September - November.			
<b>Total Sq Ft</b> N/A	<b>Year Built</b> 1996	<b>Hours/Week Occupied</b> Sept = 9, Oct-Nov = 25	<b>Number of Employees</b> N/A
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/> Emergency Services	<input type="checkbox"/> Garage		
<input type="checkbox"/> Center/Meeting Hall/Library	<input type="checkbox"/> Offices		
<input type="checkbox"/> Recreation/Entertainment/Parks	<input type="checkbox"/> Religious		
<input checked="" type="checkbox"/> School	<input type="checkbox"/> School: College		
<input type="checkbox"/> Water Treatment/Pumping	<input type="checkbox"/> Other: _____		

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

<b>The Data Below is for the 12 Month Period:</b> 7 / 1 / 0 8    to    6 3 0 0 9
--



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #65 806 170 04	
<b>Annual kWh Use</b> 9,100.80	<b>Annual Electricity Cost</b> \$7,848.28
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Therms</b>	<b>Annual Natural Gas Cost</b>

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Fuel Oil Cost</b>

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

<b>Date Received:</b> _____	<b>Project No.:</b> _____
-----------------------------	---------------------------



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Teaneck High School - Athletic Field - Scoreboard			
<b>Street Address</b> 100 Elizabeth Avenue		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> Scoreboard for Athletic Field / Stadium used for Varsity, Junior Varsity, Freshman, & Recreational Football Games for the Months of September - November. Also power & lighting for Press Box and Field House, which is used for Storage.			
<b>Total Sq Ft</b> N/A	<b>Year Built</b> 1989	<b>Hours/Week Occupied</b> Sept -Nov = 9	<b>Number of Employees</b> N/A
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/> Emergency Services	<input type="checkbox"/> Garage		
<input type="checkbox"/> Center/Meeting Hall/Library	<input type="checkbox"/> Offices		
<input type="checkbox"/> Recreation/Entertainment/Parks	<input type="checkbox"/> Religious		
<input checked="" type="checkbox"/> School	<input type="checkbox"/> School: College		
<input type="checkbox"/> Water Treatment/Pumping	<input type="checkbox"/> Other: _____		

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

<b>The Data Below is for the 12 Month Period:</b> <u>7</u> / <u>1</u> / <u>08</u> to <u>6</u> <u>3</u> <u>0</u> <u>0</u> <u>9</u>
---



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #67 473 393 04	
<b>Annual kWh Use</b> 3,384	<b>Annual Electricity Cost</b> \$1,816.79
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Therms</b>	<b>Annual Natural Gas Cost</b>

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Fuel Oil Cost</b>

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

<b>Date Received:</b> _____	<b>Project No.:</b> _____
-----------------------------	---------------------------



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Thomas Jefferson Middle School			
<b>Street Address</b> 655 Teaneck Road		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> 3 Story Structure Grades 5 - 8			
<b>Total Sq Ft</b> 105,216	<b>Year Built</b> 1958	<b>Hours/Week Occupied</b> 90	<b>Number of Employees</b> 55 emp. / 627 students
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/>	<b>Emergency Services</b>	<input type="checkbox"/>	<b>Garage</b>
<input type="checkbox"/>	<b>Center/Meeting Hall/Library</b>	<input type="checkbox"/>	<b>Offices</b>
<input type="checkbox"/>	<b>Recreation/Entertainment/Parks</b>	<input type="checkbox"/>	<b>Religious</b>
<input checked="" type="checkbox"/>	<b>School</b>	<input type="checkbox"/>	<b>School: College</b>
<input type="checkbox"/>	<b>Water Treatment/Pumping</b>	<input type="checkbox"/>	<b>Other:</b> _____

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

<b>The Data Below is for the 12 Month Period:</b> 7 / 1 / 0 8 to 6 / 3 0 0 9
--



### ELECTRICITY

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #42 003 988 18	
<b>Annual kWh Use</b> 750,720	<b>Annual Electricity Cost</b> \$122,936.61
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

### NATURAL GAS

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #42 003 988 18	
<b>Annual Use in Therms</b> 7,353.257	<b>Annual Natural Gas Cost</b> \$8,940.65

### FUEL OIL

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Allied #128387	
<b>Annual Use in Gallons</b> 41,903.40	<b>Annual Fuel Oil Cost</b> \$75,955.27

### PROPANE

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

### OTHER

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

### STAFF USE ONLY

Date Received: _____	Project No.: _____
----------------------	--------------------



## APPENDIX C - FACILITY DATA FORM

*Complete one Facility Data Form for **each** building. If you are seeking to energy audit multiple buildings, complete one Facility Data Form for each.*

### FACILITY INFORMATION

*Please complete the information below for this specific facility that is seeking enrollment in the Program.*

<b>Facility Name</b> Whittier Elementary School			
<b>Street Address</b> 491 West Englewood Avenue		<b>County</b> Bergen	
<b>City</b> Teaneck		<b>State</b> New Jersey	<b>Zip</b> 07666
<b>Facility's Description</b> 2 Story Structure Grades 1 - 4			
<b>Total Sq Ft</b> 55,118	<b>Year Built</b> 1921 (1948,1952,1997)	<b>Hours/Week Occupied</b> 90	<b>Number of Employees</b> 55 emp. / 402 students
<b>Building Type (Check only one of the following):</b>			
<input type="checkbox"/> Emergency Services	<input type="checkbox"/> Garage		
<input type="checkbox"/> Center/Meeting Hall/Library	<input type="checkbox"/> Offices		
<input type="checkbox"/> Recreation/Entertainment/Parks	<input type="checkbox"/> Religious		
<input checked="" type="checkbox"/> School	<input type="checkbox"/> School: College		
<input type="checkbox"/> Water Treatment/Pumping	<input type="checkbox"/> Other: _____		

### ENERGY DATA

*Please complete the energy information below for the most recent 12 month period available. In order to gain a complete picture of the facility's energy use, be sure to include all types of energy used by the facility. Do not include vehicle fuel.*

<b>The Data Below is for the 12 Month Period:</b> 7 / 1 / 0 8    to    6 / 3 0 0 9
--



**ELECTRICITY**

<b>Electric Utility Name &amp; Account Number(s)</b> PSE&G #65 182 085 03	
<b>Annual kWh Use</b> 363,000	<b>Annual Electricity Cost</b> \$57,304.61
<b>Max Summer kW</b> See attached document	<b>Max Winter kW</b> See attached document

**NATURAL GAS**

<b>Natural Gas Utility Name &amp; Account Number(s)</b> PSE&G #66 128 016 03	
<b>Annual Use in Therms</b> 276.941	<b>Annual Natural Gas Cost</b> \$457.54

**FUEL OIL**

<b>Fuel Oil Utility Name &amp; Account Number(s)</b> Allied #128381	
<b>Annual Use in Gallons</b> 28,680.70	<b>Annual Fuel Oil Cost</b> \$52,358.57

**PROPANE**

<b>Propane Utility Name &amp; Account Number(s)</b> Not Applicable	
<b>Annual Use in Gallons</b>	<b>Annual Propane Cost</b>

**OTHER**

*In this section please indicate any other fuel type that the facility uses, such as: solar energy, wind energy, bio-fuel, cogeneration, fuel cells.*

<b>Other Fuel Type:</b> Not Applicable	
<b>Annual Energy Use (indicate units)</b>	<b>Annual Energy Cost</b>

**STAFF USE ONLY**

Date Received: _____	Project No.: _____
----------------------	--------------------



**TEANECK BOARD OF EDUCATION  
PSEG ANNUAL DEMAND KW from July 2008 to June 2009**

<u>MONTH</u>	<u>B.F.M.S.</u>	<u>BRYANT</u>	<u>EUGENE FIELD</u>	<u>HAWTHORNE</u>	<u>LOWELL</u>	<u>TEANECK H.S.</u>	<u>TEANECK H.S. FIELD - LIGHTS</u>	<u>TEANECK H.S. SCOREBOARD</u>	<u>T.J.M.S.</u>	<u>WHITTIER</u>
Jul-08	276.00	104.00	65.10	127.20	105.60	596.60	141.60	10.90	230.40	no bill
Aug-08	196.80	104.00	67.50	113.40	110.40	379.60	0.00	10.70	86.40	116.00
Sep-08	280.80	106.40	65.10	123.60	112.00	590.20	0.00	10.70	218.40	126.00
Oct-08	280.80	108.00	55.80	118.20	89.60	631.00	136.80	10.80	216.00	128.00
Nov-08	271.20	89.60	48.90	123.60	107.20	520.70	137.60	12.80	223.20	108.00
Dec-08	no bill	86.40	39.60	130.20	91.20	497.50	139.20	8.40	224.80	108.00
Jan-09	261.60	86.40	41.10	128.40	94.40	494.50	0.00	0.20	247.20	112.00
Feb-09	266.40	88.80	42.30	117.00	96.00	492.70	0.00	0.20	244.80	110.00
Mar-09	268.80	90.40	40.50	118.20	91.20	507.10	0.80	0.20	235.20	110.00
Apr-09	271.20	90.40	40.20	118.20	96.00	986.10	0.80	0.20	240.00	110.00
May-09	no bill	180.80	113.40	232.80	92.80	1265.20	0.80	0.40	244.80	212.00
Jun-09	240.00	100.00	45.60	116.40	88.00	638.50	0.00	10.70	247.20	106.00

APPENDIX G

NJ SMARTSTART INCENTIVES INFORMATION AND WORKSHEETS



# 2010 Prescriptive Lighting Application

## Customer Information

Company		Electric Utility Serving Applicant		Electric Account No.		Installation Date	
Facility Address				City		State	Zip
Type of Project <input type="checkbox"/> New Construction <input type="checkbox"/> Renovation <input type="checkbox"/> Equipment Replacement						Size of Building	
Company Mailing Address				City		State	Zip
Contact Person (Name/Title)				Telephone No. (   )		Fax No. (   )	
Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Exempt				Federal Tax ID# or SSN		Email Address	
Incentive Payment to <input type="checkbox"/> Customer <input type="checkbox"/> Contractor <input type="checkbox"/> Other				Please assign payment to contractor/vendor/other indicated below Customer Signature			

## Payee Information (must submit W-9 form with application)

Company						Contact Name		Incorporated? Yes   No		Email Address	
Street Address				City		State	Zip	Telephone No. (   )		Fax No. (   )	

## Contractor/Vendor Information (if different from Payee)

Company						Contact Name		Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No		Email Address	
Street Address				City		State	Zip	Telephone No. (   )		Fax No. (   )	

## Building Type (circle one)

Education-Primary School; Education-Community College; Education-University; Grocery; Medical-Hospital; Medical-Clinic; Lodging Hotel(Guest Rooms); Lodging Motel; Manufacturing-Light Industrial; Office-Large; Office-Small; Restaurant-Sit Down; Restaurant-Fast Food; Retail-3 Story Large; Retail- Single Story Large; Retail-Small; Storage Conditioned; Storage Unconditioned; Warehouse; Other

## Prescriptive Lighting Incentive

**\$ \_\_\_\_\_ Total Incentive (per attached worksheet calculations)**

**Note: Prescriptive Lighting Worksheet must accompany this application.**

## Specific Program Requirements\* (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. Incentives for T-5 and T-8 lamps with electronic ballasts are available only for fixtures with a Total Harmonic Distortion of  $\leq 20\%$ .
4. All eligible lighting devices must be UL listed.
5. Requirements for CFL fixtures (must meet all requirements):
  - Fixtures must be new and ENERGY STAR qualified
  - Fixtures must have replaceable electronic ballasts
  - Total Harmonic Distortion (THD) must not exceed 33%
  - Power factor of the ballast must be no less than 90%
  - The manufacturer must warrant all fixtures for a minimum of 3 years. Warranty does not pertain to lamps or photocells not physically part of the fixture.
  - The installer must warrant fixture installation – minimum of 1 yr.
- 5.1 Screw-in PAR 38 or 30 Compact Fluorescent Lamps (CFL) with Aluminum Reflectors replacing existing incandescent fixtures.
  - The lamp must be warranted by the manufacturer for 8,000 hours
  - Total Harmonic Distortion must not exceed 33%
  - Power factor of the ballast must be  $\geq 90\%$
6. Pulse Start Metal Halide (including pole-mounted parking lot lighting) must have a 12% minimum wattage reduction.
7. T-5 or T-8 Fixtures replacing incandescent or T-12 fluorescent fixtures greater than 250 watt or High Intensity Discharge shall comply as follows:
  - 7.1 T-5 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.0; have reflectivity greater than or equal to 91%; have a minimum 2 lamps; and be designated as F54T5 HO.
  - 7.2 T-8 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.14; have reflectivity greater than or equal to 91%; have a minimum of 4 lamps; and be designated as F32T8, minimum 32 watts.
  - 7.3 Incentives for delamp T-8 lamps with new reflectors are available only for fixtures with a Total Harmonic Distortion of  $\leq 20\%$ . Electronic ballast replacement required for all eligible delamp fixtures. Eligible delamping can include reduction in linear lamp feet from existing conditions. For example, 1-8' linear fluorescent lamp can be considered as 2-4' linear lamps. U-bend lamps 4' in total length can be considered as 2-F17/T8 lamps.
  - 7.4 Electronic ballast replacement is necessary for all eligible delamp fixtures.
  - 7.5 Reduced wattage T8 (28W/25W 4') (1-4 lamps) retrofit requires lamp and ballast replacement.
8. LED Refrigerated/Freezer Case Lighting must meet NEEP Design Lights Consortium Standards or be on an ENERGY STAR or a SSL Qualified Product list. For new door installations on existing open cases, indicate the number of LED fixtures to be installed. Also indicate "New Door" in the Fixture Type column on the Prescriptive Lighting Worksheet (ie. New Door 5' LED).

### Application Checklist (Before submitting your application, please make sure you have signed in the space below and completed the following items.)

- Payee Information is filled out and a W-9 form of the payee is included
- Manufacturer's specification sheets for proposed technology are included
- A copy (all pages) of a recent month's utility bill is included

### ACKNOWLEDGEMENT

_____ <b>CUSTOMER'S SIGNATURE</b>	By signing, I certify that I have read, understand and agree to the Specific Program Requirements/Terms and Conditions listed on this application form. I will also submit for approval a properly completed application package, which includes this signed application, worksheet (if applicable), manufacturer's specification sheets and complete utility bill (name and address on utility bill must match name and address on application).
--------------------------------------	---

### Prescriptive Lighting Measures and Incentives\*

Type of Fixture	Incentive																																				
<b>Recessed and Surface-Mounted Compact Fluorescents</b> (New Fixtures Replacing Incandescent Fixtures Only): <small>Only available for hard-wired, electronically ballasted new fixtures with rare earth phosphor lamps and 4-pin based tubes (including: twin tube, quad tube, triple tube, 2D or circline lamps), THD<math>\leq 33\%</math> and BF<math>&gt; 0.9</math></small>	\$25 per 1-lamp fixture \$30 per 2-lamp or more fixture																																				
<b>Screw-in PAR 38 or PAR 30 (CFL) as per 5.1 above</b>	\$7 per lamp replaced																																				
<b>High-Efficiency Fluorescent Fixtures:</b> For retrofit of T-12 fixtures to T-5 or T-8 with electronic ballasts	\$15 per fixture (1-4 lamps retrofits)																																				
<b>For replacement of fixtures with new T-5 or T-8 fixtures</b>																																					
<table border="1" style="width: 100%; border-collapse: collapse; font-size: x-small;"> <thead> <tr> <th>Type of Old Fixture</th> <th>Wattage of Old Fixture</th> <th>Type of New Fixture</th> <th>Incentive Per Fixture Removed</th> </tr> </thead> <tbody> <tr> <td>HID, T-12, Incandescent</td> <td><math>\geq 1000</math> Watts</td> <td>T-5, T-8</td> <td>\$284</td> </tr> <tr> <td>HID, T-12, Incandescent</td> <td>400-999 Watt</td> <td>T-5, T-8</td> <td>\$100</td> </tr> <tr> <td>HID, T-12, Incandescent</td> <td>250-399 Watt</td> <td>T-5, T-8</td> <td>\$50</td> </tr> <tr> <td>HID only</td> <td>175-249 Watt</td> <td>T-5, T-8</td> <td>\$45</td> </tr> <tr> <td>HID only</td> <td>100-174 Watt</td> <td>T-5, T-8</td> <td>\$30</td> </tr> <tr> <td>HID only</td> <td>75-99 Watt</td> <td>T-5, T-8</td> <td>\$16</td> </tr> <tr> <td>T-12 only</td> <td><math>&lt; 250</math> Watt</td> <td>T-5, T-8 (1 &amp; 2 lamp)</td> <td>\$25</td> </tr> <tr> <td>T-12 only</td> <td><math>&lt; 250</math> Watt</td> <td>T-5, T-8 (3 &amp; 4 lamp)</td> <td>\$30</td> </tr> </tbody> </table>	Type of Old Fixture	Wattage of Old Fixture	Type of New Fixture	Incentive Per Fixture Removed	HID, T-12, Incandescent	$\geq 1000$ Watts	T-5, T-8	\$284	HID, T-12, Incandescent	400-999 Watt	T-5, T-8	\$100	HID, T-12, Incandescent	250-399 Watt	T-5, T-8	\$50	HID only	175-249 Watt	T-5, T-8	\$45	HID only	100-174 Watt	T-5, T-8	\$30	HID only	75-99 Watt	T-5, T-8	\$16	T-12 only	$< 250$ Watt	T-5, T-8 (1 & 2 lamp)	\$25	T-12 only	$< 250$ Watt	T-5, T-8 (3 & 4 lamp)	\$30	
Type of Old Fixture	Wattage of Old Fixture	Type of New Fixture	Incentive Per Fixture Removed																																		
HID, T-12, Incandescent	$\geq 1000$ Watts	T-5, T-8	\$284																																		
HID, T-12, Incandescent	400-999 Watt	T-5, T-8	\$100																																		
HID, T-12, Incandescent	250-399 Watt	T-5, T-8	\$50																																		
HID only	175-249 Watt	T-5, T-8	\$45																																		
HID only	100-174 Watt	T-5, T-8	\$30																																		
HID only	75-99 Watt	T-5, T-8	\$16																																		
T-12 only	$< 250$ Watt	T-5, T-8 (1 & 2 lamp)	\$25																																		
T-12 only	$< 250$ Watt	T-5, T-8 (3 & 4 lamp)	\$30																																		
For retrofit of T-8 fixtures by permanent delamping & new reflectors are available only for fixtures with a total Harmonic Distortion of $\leq 20\%$ . Electronic ballast replacement required for all eligible delamp fixtures.	\$20 per fixture																																				
<b>New Construction &amp; Complete Renovation</b>	Performance based only																																				
LED Exit Signs (new fixtures only):																																					
For existing facilities with connected load $< 75$ kW	\$20 per fixture																																				
For existing facilities with connected load $\geq 75$ kW	\$10 per fixture																																				
Pulse Start Metal Halide (for fixtures $\geq 150$ watts)	\$25 per fixture (includes parking lot lighting)																																				
Parking lot low bay - LED	\$45 per fixture																																				
T-12 to T-8 fixtures by permanent delamping & new reflectors. Electronic ballast replacement is necessary for all eligible delamp fixtures.	\$30 per fixture																																				
Retrofit of existing 32 watt T-8 system to Reduced Wattage (28W/25W 4')	\$10 per fixture (1-4 lamps)																																				
LED Refrigerated/Freezer Case Lighting: Incentive for replacement of fluorescent lighting systems in medium or low temperature display cases	\$42 per 5' LED fixture \$65 per 6' LED fixture																																				
Induction Lighting Fixtures																																					
Retrofit of HID	\$50 per HID ( $\geq 100$ W) fixture retrofitted with induction lamp, power coupler and generator. Replacement unit must use 30% less wattage per fixture than existing HID system																																				
Replacement of HID	\$70 per HID ( $\geq 100$ W) fixture with a new induction fixture																																				

**Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.**

New Jersey's Clean Energy Program  
 c/o TRC Energy Services  
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095  
 Phone: 866-657-6278 • Fax: 732-855-0422

**Visit our web site: [NJCleanEnergy.com/ssb](http://NJCleanEnergy.com/ssb)**



## Program Terms and Conditions

### Definitions:

**Design Incentives** – Incentives that may be offered to design professionals by the Program.

**Design Services** – Services that may be offered to design professionals under the Program.

**Energy-Efficient Measures** – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

**New Jersey Utilities** – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

**Administrator** – New Jersey Board of Public Utilities, Office of Clean Energy

**Participating Customers** – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

**Product Installation or Equipment Installation** – Installation of the Energy-Efficient Measures.

**Market Manager** – TRC Energy Services.

**Program** – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

**Program Incentives** – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

**Program Offer** – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

**Application and Eligibility Process** – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

**Exceptions for Approval** – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

**Post Installation Approval** – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.

Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

*Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not eligible for incentives offered through this program.*

**Incentive Amount** – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

**Tax Liability** – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

**Endorsement** – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

**Warranties** – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

**Limitation of Liability** – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

**Assignment** – The Participating Customer may assign Program Incentive payments to a specified vendor.

**Participating Customer's Certification** – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

**Termination** – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

**Acknowledgement** – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.



## Specific Program Requirements\* (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. Incentives for T-5 and T-8 lamps with electronic ballasts are available only for fixtures with a Total Harmonic Distortion of  $\leq 20\%$ .
4. All eligible lighting devices must be UL listed.
5. Requirements for CFL fixtures (must meet all requirements):
  - Fixtures must be new and Energy Star qualified
  - Fixtures must have replaceable electronic ballasts
  - Total Harmonic Distortion (THD) must not exceed 33%
  - Power factor of the ballast must be no less than 90%
  - The manufacturer must warrant all fixtures for a minimum of 3 years. Warranty does not pertain to lamps or photocells not physically part of the fixture.
  - The installer must warrant fixture installation – minimum of 1 yr.
- 5.1 Screw-in PAR 38 or 30 Compact Fluorescent Lamps (CFL) with Aluminum Reflectors replacing existing incandescent fixtures.
  - The lamp must be warranted by the manufacturer for 8,000 hours
  - Total Harmonic Distortion must not exceed 33%
  - Power factor of the ballast must be  $\geq 90\%$
6. Pulse Start Metal Halide (including pole-mounted parking lot lighting) must have a 12% minimum wattage reduction.
7. T-5 or T-8 Fixtures replacing incandescent or T-12 fluorescent fixtures greater than 250 watt or High Intensity Discharge shall comply as follows:
  - 7.1 T-5 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.0; have reflectivity greater than or equal to 91%; have a minimum 2 lamps; and be designated as F54T5 HO.
  - 7.2 T-8 fixtures replacing T-12 fluorescent or incandescent fixtures 250 watts or greater, or HID fixtures shall have a ballast factor greater than or equal to 1.14; have reflectivity greater than or equal to 91%; have a minimum of 4 lamps; and be designated as F32T8, minimum 32 watts.
  - 7.3 Incentives for delamped T-8 lamps with new reflectors are available only for fixtures with a total Harmonic Distortion of  $\leq 20\%$ . Electronic ballast replacement required for all eligible delamped fixtures. Eligible delamping can include reduction in linear lamp feet from existing conditions. For example, 1-8' linear fluorescent lamp can be considered as 2-4' linear lamps. U-bend lamps 4' in total length can be considered as 2-F17/T8 lamps.
  - 7.4 Electronic ballast replacement is necessary for all eligible delamped fixtures.
  - 7.5 Reduced wattage T8 (28W/25W 4') (1-4 lamps) retrofit requires lamp and ballast replacement.
8. LED Refrigerated/Freezer Case Lighting must meet NEEP Design Lights Consortium Standards or be on an ENERGY STAR or a SSL Qualified Product list. For new door installations on existing open cases, indicate the number of LED fixtures to be installed. Also indicate "New Door" in the Fixture Type column on the Prescriptive Lighting Worksheet (ie. New Door 5' LED).

### ACKNOWLEDGEMENT

_____ <b>CUSTOMER'S SIGNATURE</b>	By signing, I certify that I have read, understand and agree to the Specific Program Requirements/Terms and Conditions listed on this application form, I will also submit for approval a properly completed application package, which includes this signed application, worksheet (if applicable), manufacturer's specification sheets and complete utility bill (name and address on utility bill must match name and address on application).
--------------------------------------	---

### Prescriptive Lighting Measures and Incentives\*

Type of Fixture		Incentive	
<b>Recessed and Surface-Mounted Compact Fluorescents</b> (New Fixtures Replacing Incandescent Fixtures Only): <small>Only available for hard-wired, electronically ballasted new fixtures with rare earth phosphor lamps and 4-pin based tubes (including: twin tube, quad tube, triple tube, 2D or circline lamps), THD<math>\leq 33\%</math> and BF<math>&gt; 0.9</math></small>		\$25 per 1-lamp fixture \$30 per 2-lamp or more fixture	
<b>Screw-in PAR 38 or PAR 30 (CFL) as per 5.1 above</b>		\$7 per lamp replaced	
<b>High-Efficiency Fluorescent Fixtures:</b> For retrofit of T-12 fixtures to T-5 or T-8 with electronic ballasts		\$15 per fixture (1-4 lamps retrofits)	
<b>For replacement of fixtures with new T-5 or T-8 fixtures</b>			
Type of Old Fixture	Wattage of Old Fixture	Type of New Fixture	Incentive Per Fixture Removed
HID, T-12, Incandescent	$\geq 1000$ Watts	T-5, T-8	\$284
HID, T-12, Incandescent	400-999 Watt	T-5, T-8	\$100
HID, T-12, Incandescent	250-399 Watt	T-5, T-8	\$50
HID only	175-249 Watt	T-5, T-8	\$43
HID only	100-174 Watt	T-5, T-8	\$30
HID only	75-99 Watt	T-5, T-8	\$16
T-12 only	$\leq 250$ Watt	T-5, T-8 (1 & 2 lamp)	\$25
T-12 only	$\leq 250$ Watt	T-5, T-8 (3 & 4 lamp)	\$30
For retrofit of T-8 fixtures by permanent delamping & new reflectors are available only for fixtures with a total Harmonic Distortion of $\leq 20\%$ . Electronic ballast replacement required for all eligible delamped fixtures.		\$20 per fixture	
<b>New Construction &amp; Complete Renovation</b>		Performance based only	
LED Exit Signs (new fixtures only): For existing facilities with connected load $< 75$ kW		\$20 per fixture	
For existing facilities with connected load $\geq 75$ kW		\$10 per fixture	
Pulse Start Metal Halide (for fixtures $\geq 150$ watts)		\$25 per fixture (includes parking lot lighting)	
Parking lot low bay - LED		\$43 per fixture	
T-12 to T-8 fixtures by permanent delamping & new reflectors. Electronic ballast replacement is necessary for all eligible delamped fixtures.		\$30 per fixture	
Retrofit of existing 32 watt T-8 system to Reduced Wattage (28W/25W 4')		\$10 per fixture (1-4 lamps)	
LED Refrigerated/Freezer Case Lighting: Incentive for replacement of fluorescent lighting systems in medium or low temperature display cases		\$42 per 5' LED Fixture \$65 per 6' LED Fixture	
Induction Lighting Fixtures Retrofit of HID		\$50 per HID ( $\geq 100W$ ) fixture retrofitted with induction lamp, power coupler and generator. Replacement unit must use 50% less wattage per fixture than existing HID system	
Replacement of HID		\$70 per HID ( $\geq 100W$ ) fixture with a new induction fixture	

**Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.**

New Jersey's Clean Energy Program  
 c/o TRC Energy Services  
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095  
 Phone: 866-657-6278 • Fax: 732-855-0422

**Visit our web site: [NJCleanEnergy.com/ssb](http://NJCleanEnergy.com/ssb)**





## Program Terms and Conditions

### Definitions:

**Design Incentives** – Incentives that may be offered to design professionals by the Program.

**Design Services** – Services that may be offered to design professionals under the Program.

**Energy-Efficient Measures** – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

**New Jersey Utilities** – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

**Administrator** – New Jersey Board of Public Utilities, Office of Clean Energy

**Participating Customers** – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

**Product Installation or Equipment Installation** – Installation of the Energy-Efficient Measures.

**Market Manager** – TRC Energy Services.

**Program** – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

**Program Incentives** – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

**Program Offer** – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

**Application and Eligibility Process** – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

**Exceptions for Approval** – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

**Post Installation Approval** – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.

Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

*Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not eligible for incentives offered through this program.*

**Incentive Amount** – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

**Tax Liability** – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

**Endorsement** – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

**Warranties** – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

**Limitation of Liability** – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

**Assignment** – The Participating Customer may assign Program Incentive payments to a specified vendor.

**Participating Customer's Certification** – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

**Termination** – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

**Acknowledgement** – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.



## 2010 Lighting Controls Application

### Customer Information

Company	Electric Utility Serving Applicant	Electric Account No.	Installation Date
Facility Address	City	State	Zip
Type of Project <input type="checkbox"/> New Construction <input type="checkbox"/> Renovation <input type="checkbox"/> Equipment Replacement	Size of Building		
Company Mailing Address	City	State	Zip
Contact Person (Name/Title)	Telephone No. (   )	Fax No. (   )	
Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Exempt	Federal Tax ID# or SSN	Email Address	
Incentive Payment to <input type="checkbox"/> Customer <input type="checkbox"/> Contractor <input type="checkbox"/> Other	Please assign payment to contractor/vendor/other indicated below Customer Signature		

### Payee Information (must submit W-9 form with application)

Company						Contact Name	Incorporated? Yes   No	Email Address
Street Address		City	State	Zip	Telephone No. (   )	Fax No. (   )	Federal Tax ID#	

### Contractor/Vendor Information (if different from Payee)

Company						Contact Name	Incorporated? <input type="checkbox"/> Yes <input type="checkbox"/> No	Email Address
Street Address		City	State	Zip	Telephone No. (   )	Fax No. (   )	Federal Tax ID#	

### Building Type (circle one)

Education-Primary School; Education-Community College; Education-University; Grocery; Medical-Hospital; Medical-Clinic; Lodging Hotel(Guest Rooms); Lodging Motel; Manufacturing-Light Industrial; Office-Large; Office-Small; Restaurant-Sit Down; Restaurant-Fast Food; Retail-3 Story Large; Retail- Single Story Large; Retail-Small; Storage Conditioned; Storage Unconditioned; Warehouse; Other

### Lighting Control Incentive

**\$ \_\_\_\_\_ Total Incentive (per attached worksheet calculations)**

**Note: Lighting Controls Incentive Worksheet must accompany this application.**

**Specific Program Requirements\*** (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements, including special requirements for lighting controls.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. All lighting controls eligible for incentives must be UL listed.
4. Lighting control incentives are only available for control of eligible energy efficient lighting fixtures.
5. If more than one eligible lighting control device is associated with the same eligible fixture, the incentive paid will be for the lighting control device that yields the largest incentive only.
6. Occupancy Sensor Controls (existing facilities only):
  - There is no incentive available for occupancy sensors installed in a space where they are prohibited by state or local building or safety code. Additionally, no incentive is eligible for occupancy sensors in the following specific spaces in all cases: stairways, restrooms (remote mounted only allowed), elevators, corridors/hallways, lobbies, and closets/storage areas.
  - Incentives will only be paid for eligible occupancy sensors (OSW & OSR) controlling at least 2 eligible lighting fixtures and, for OSR installations, a minimum total connected load of 180 watts.
  - Incentives will only be paid for eligible OSRH occupancy sensors controlling eligible fixtures when the controlled wattage is greater than 180 watts.
  - Occupancy sensors with manual override to the "ON" position are ineligible for incentive.
7. High-Low Controls (OHLF and OHLH):
  - Incentives will not be paid for high-low controls on eligible fluorescent fixtures where daylight dimming controls can be effectively employed.
  - Incentives will not be paid for spaces smaller than 250 square feet.
  - Incentives available only when "low level" is no more than 60% of "high level."
  - Incentives are not available for the following spaces: stairways, elevators, corridors/hallways, or lobbies.
  - OHLF will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
  - OHLH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.
8. Daylight Dimming Controls for eligible fixtures:
  - Incentives will only be paid for eligible daylight dimming controls operating at least 4 eligible ballasts with a minimum total connected load of 240 watts.
  - Dimming shall be continuous or stepped at 4 or more levels.
  - Incentives will be paid only for eligible daylight dimming control systems designed in accordance with IESNA practice as delineated in "RP-5-99, IESNA Recommended Practice of Daylighting."
  - DLD will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
  - DDH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.

**Application Checklist** (Before submitting your application, please make sure you have signed in the space below and completed the following items.)

- Payee Information is filled out and a W-9 form of the payee is included
- Manufacturer's specification sheets for proposed technology are included
- A copy (all pages) of a recent month's utility bill is included

**ACKNOWLEDGEMENT**

\_\_\_\_\_  
CUSTOMER'S SIGNATURE

By signing, I certify that I have read, understand and agree to the Specific Program Requirements/Terms and Conditions listed on this application form, I will also submit for approval a properly completed application package, which includes this signed application, worksheet (if applicable), manufacturer's specification sheets and complete utility bill (name and address on utility bill must match name and address on application).

**Lighting Control Prescriptive Incentives\***

Control Device Type	Incentive per Unit
OSW – Occupancy Sensor Wall Mounted (Existing facilities only)	\$20 per control
OSR – Occupancy Sensor Remote Mounted (Existing facilities only)	\$35 per control
DLD – Fluorescent Daylight Dimming	\$25 per fixture controlled
DLD – Fluorescent Daylight Dimming (Office Applications)	\$50 per fixture controlled
OHLF – Occupancy Controlled High-Low with Step Ballast	\$25 per fixture controlled
OSRH – Occupancy Sensor Remote Mounted	\$35 per control
OHLH – Occupancy Controlled High-Low with Step Ballast	\$75 per fixture controlled
DDH – Daylight Dimming	\$75 per fixture controlled

**Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.**

New Jersey's Clean Energy Program  
 c/o TRC Energy Services  
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095  
 Phone: 866-657-6278 • Fax: 732-855-0422

**Visit our web site: [www.NJCleanEnergy.com](http://www.NJCleanEnergy.com)**



## Program Terms and Conditions

### Definitions:

**Design Incentives** – Incentives that may be offered to design professionals by the Program.

**Design Services** – Services that may be offered to design professionals under the Program.

**Energy-Efficient Measures** – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

**New Jersey Utilities** – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

**Administrator** – New Jersey Board of Public Utilities, Office of Clean Energy

**Participating Customers** – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

**Product Installation or Equipment Installation** – Installation of the Energy-Efficient Measures.

**Market Manager** – TRC Energy Services.

**Program** – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

**Program Incentives** – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

**Program Offer** – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

**Application and Eligibility Process** – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

**Exceptions for Approval** – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

**Post Installation Approval** – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.



Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

*Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not be eligible for incentives offered through this program.*

**Incentive Amount** – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

**Tax Liability** – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

**Endorsement** – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

**Warranties** – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

**Limitation of Liability** – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

**Assignment** – The Participating Customer may assign Program Incentive payments to a specified vendor.

**Participating Customer's Certification** – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

**Termination** – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

**Acknowledgement** – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.



**Specific Program Requirements\*** (These requirements are in addition to the Program Terms and Conditions.)

1. Please refer to the Program Guide for additional applicable technical requirements, including special requirements for lighting controls.
2. Include the manufacturer's specification sheet with the application package and mail or fax directly to the Commercial/Industrial Market Manager.
3. All lighting controls eligible for incentives must be UL listed.
4. Lighting control incentives are only available for control of eligible energy efficient lighting fixtures.
5. If more than one eligible lighting control device is associated with the same eligible fixture, the incentive paid will be for the lighting control device that yields the largest incentive only.
6. Occupancy Sensor Controls (existing facilities only):
  - There is no incentive available for occupancy sensors installed in a space where they are prohibited by state or local building or safety code. Additionally, no incentive is eligible for occupancy sensors in the following specific spaces in all cases: stairways, restrooms (remote mounted only allowed), elevators, corridors/hallways, lobbies, and closets/storage areas.
  - Incentives will only be paid for eligible occupancy sensors (OSW & OSR) controlling at least 2 eligible lighting fixtures and, for OSR installations, a minimum total connected load of 180 watts.
  - Incentives will only be paid for eligible OSRH occupancy sensors controlling eligible fixtures when the controlled wattage is greater than 180 watts.
  - Occupancy sensors with manual override to the "ON" position are ineligible for incentive.
7. High-Low Controls (OHLF and OHLH):
  - Incentives will not be paid for high-low controls on eligible fluorescent fixtures where daylight dimming controls can be effectively employed.
  - Incentives will not be paid for spaces smaller than 250 square feet.
  - Incentives available only when "low level" is no more than 60% of "high level."
  - Incentives are not available for the following spaces: stairways, elevators, corridors/hallways, or lobbies.
  - OHLF will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
  - OHLH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.
8. Daylight Dimming Controls for Eligible Fixtures:
  - Incentives will only be paid for eligible daylight dimming controls operating at least 4 eligible ballasts with a minimum total connected load of 240 watts.
  - Dimming shall be continuous or stepped at 4 or more levels.
  - Incentives will be paid only for eligible daylight dimming control systems designed in accordance with IESNA practice as delineated in "RP-5-99, IESNA Recommended Practice of Daylighting."
  - DLD will control fixtures that have a ballast factor less than 1.0 for T-5s and 1.14 for T-8s.
  - DDH will control fixtures that have a ballast factor greater than or equal to 1.0 for T-5s and 1.14 for T-8s.

**Lighting Control Prescriptive Incentives\***

<b>Control Device Type</b>	<b>Incentive per Unit</b>
OSW – Occupancy Sensor Wall Mounted (Existing facilities only)	\$20 per control
OSR – Occupancy Sensor Remote Mounted (Existing facilities only)	\$35 per control
DLD – Fluorescent Daylight Dimming	\$25 per fixture controlled
DLD – Fluorescent Daylight Dimming (Office Applications)	\$50 per fixture controlled
OHLF – Occupancy Controlled High-Low with Step Ballast	\$25 per fixture controlled
OSRH – Occupancy Sensor Remote Mounted	\$35 per control
OHLH – Occupancy Controlled High-Low with Step Ballast	\$75 per fixture controlled
DDH – Daylight Dimming	\$75 per fixture controlled

**Mail or fax your application package DIRECTLY to the Commercial/Industrial Market Manager.**

New Jersey's Clean Energy Program  
 c/o TRC Energy Services  
 900 Route 9 North, Suite 104 • Woodbridge, NJ 07095  
 Phone: 866-657-6278 • Fax: 732-855-0422

**Visit our web site: [www.NJCleanEnergy.com](http://www.NJCleanEnergy.com)**





## Program Terms and Conditions

### Definitions:

**Design Incentives** – Incentives that may be offered to design professionals by the Program.

**Design Services** – Services that may be offered to design professionals under the Program.

**Energy-Efficient Measures** – Any device eligible to receive a Program Incentive payment through the NJ Clean Energy Commercial and Industrial Program (New Jersey SmartStart Buildings).

**New Jersey Utilities** – The regulated electric and/or gas utilities in the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

**Administrator** – New Jersey Board of Public Utilities, Office of Clean Energy

**Participating Customers** – Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

**Product Installation or Equipment Installation** – Installation of the Energy-Efficient Measures.

**Market Manager** – TRC Energy Services.

**Program** – The Commercial and Industrial Energy-Efficient Construction Program (New Jersey SmartStart Buildings) offered herein by the New Jersey Board of Public Utilities, Office of Clean Energy pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

**Program Incentives** – Refers to the amount or level of incentive that the Program provides to Participating Customers pursuant to the Program offered herein (see description under “Incentive Amount” heading).

**Program Offer** – Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities identified above. Program Incentives for new construction are available only for projects in areas designated for growth in the State Plan. Public school (K-12) new construction projects are exempted from this restriction and are eligible for new Program incentives throughout the State. Customers, or their trade allies, can determine if a location is in a designated growth area by referring to the Smart Growth Locator available from the HMFA website or contact the Market Manager if you are uncertain about project eligibility.

**Application and Eligibility Process** – The Program pays incentives after the installation of qualified energy efficient measures that were pre-approved (for exceptions to this condition, please refer to “Exceptions for Approval”). In order to be eligible for Program Incentives, a Customer, or an agent (contractor/vendor) authorized by a Customer, must submit a properly completed application package. The package must include an application signed by the customer; a complete (current) utility bill; and technology worksheet and manufacturer’s cut sheets (where appropriate). This information must be submitted to the Market Manager before equipment is installed. Applications for measures that are self installed by customers must be submitted by the customer and not the sales vendor of the measure, however, the customer may elect to assign payment of the incentive to the sales vendor. This application package must be received by the Market Manager on or before December 31, 2010 in order to be eligible for 2010 incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. If eligible, the Customer will receive an approval letter with the estimated authorized incentive amount and the date by which the equipment must be installed in order for the approval to remain in effect. Upon receipt of an approval letter, the Customer may then proceed to install the equipment listed on the approved application. Equipment installed prior to the date of the Market Manager’s approval letter is not eligible for an incentive. The Market Manager reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the approval letter. All equipment must be purchased within 12 months of date of application. **Any Customer and/or agent who purchases equipment prior to the receipt of an incentive approval letter does so at his/her own risk.**

**Exceptions for Approval** – The Application and Eligibility Process pertains to all projects except for those involving either Unitary HVAC or Motors having an incentive amount less than \$5,000. These measures, at this incentive level, may be installed without prior approval. In addition, but at the sole discretion of the Market Manager, emergency replacement of equipment may not require a prior approval determination and letter. **In such cases, please notify the Market Manager of such emergencies as early as possible, that an application will soon be sent in that was not pre-approved.**

**Post Installation Approval** – After installation is completed, the Customer, or an agent authorized by the Customer, must finalize and submit an invoice for the purchase of the equipment (material cost must be broken out from labor costs), and any other required documentation as specified on the equipment application or in the Market Manager’s initial approval letter.

Please refer to the Program Guide on the NJCleanEnergy.com/ssb website for the complete Application and Eligibility Process.

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing product or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time.

Energy-Efficient Measures must be installed in buildings located within a New Jersey Utilities' service territory and designated on the Participating Customer's incentive application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program materials and incentive applications. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease. Design Incentives are available to design professionals as described in the Program materials and applications. A different and separate agreement must be executed by participating design professionals to be eligible for this type of incentive. The design professional does not need to be based in New Jersey.

*Equipment procured by Participating Customers through another program offered by New Jersey's Clean Energy Program or the New Jersey Utilities, as applicable, is not eligible for incentives through this program. Customers who have not contributed to the Societal Benefits Charge of the applicable New Jersey Utility are not be eligible for incentives offered through this program.*

**Incentive Amount** – Program Incentives will equal either: a) the approved Program Incentive amount, or b) the actual equipment cost of the Energy-Efficient Measure, whichever is less, as determined by the Market Manager. Products offered at no direct cost to the customer are ineligible. Incomplete application submissions, applications requiring inspections and unanticipated high volume of activities may cause processing delays. Program Incentives are limited to \$500,000 per utility account in a calendar year. Contact the Market Manager regarding any questions.

**Tax Liability** – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their Federal Tax Identification number or social security number to the Market Manager on the application form in order to receive a Program Incentive. In addition, Participating Customers must also provide a Tax Clearance Form (Business Assistance or Incentive Clearance Certificate) that is dated within 90 days of equipment installation.

**Endorsement** – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

**Warranties** – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITLY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

**Limitation of Liability** – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against the Market Manager or the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator, be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

**Assignment** – The Participating Customer may assign Program Incentive payments to a specified vendor.

**Participating Customer's Certification** – Participating Customer certifies that he/she purchased and installed the equipment listed in their application at their defined New Jersey location. Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements listed in the application.

**Termination** – The New Jersey Board of Public Utilities reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

**Acknowledgement** – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the NJ SmartStart Buildings Program. Additionally, I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program.

# New Jersey Clean Energy Program

## Technical Worksheet – Solar Electric Equipment Information

**Please carefully read all of the following information. With the help of your Installation Contractor, fully complete Sections A through D, as applicable, of the attached Technical Worksheet for Solar Electric Equipment, as well as the New Jersey Clean Energy Program Rebate Application Form.**

### GENERAL TERMS AND CONDITIONS

Rebates will be processed based on the date the New Jersey Clean Energy Program (NJCEP) approves the Final Application Form, not on the purchase date of the equipment. Program procedures and rebates are subject to change or cancellation without notice.

To qualify for a rebate, Applicant must comply with all Program Eligibility Requirements, Terms and Conditions, and Installation Requirements, and submit a completed Pre-Installation Application Form. For more information about the New Jersey Clean Energy Program, or for assistance in completing applications or forms, please see [www.njcleanenergy.com](http://www.njcleanenergy.com) or call 866-NJSMART

### INSTALLATION REQUIREMENTS

Equipment installation must meet the following minimum requirements in order to qualify for payment under the provisions of the New Jersey Clean Energy Program; proposed changes to the requirements will be considered, but they must be documented by the Applicant or Installation Contractor and approved by the NJCEP. These requirements are not all-encompassing and are intended only to address certain minimum safety and efficiency standards.

#### A: Code Requirements

1. The installation must comply with the provisions of the National Electrical Code and all other applicable local, state and federal codes or practices.
2. All required permits must be properly obtained and posted.
3. The NJCEP Inspection must be performed before the local Building Code Enforcement Office. If not, this may delay the processing of the rebate
4. All required inspections must be performed (i.e., Electrical/NEC, Local Building Codes Enforcement Office, etc.). Note: In order to ensure compliance with provisions of the NEC, an inspection by a state-licensed electrical inspector is mandatory.

#### B: Solar Electric Module Array

1. Modules must be UL Listed and must be properly installed according to manufacturer's instructions.
2. The maximum amount of sunlight available year-round on a daily basis should not be obstructed. All applications must include documentation of the impact from any obstruction on the annual performance of the solar electric array. This analysis can be performed by using the New Jersey Clean Power Estimator on the program website [www.njcep.com](http://www.njcep.com).
3. In order to qualify for program incentives, the solar electric system must adhere to a minimum design threshold, relative to the estimated system production using PVWATTS:
  - Solar electric array orientations require that the calculated system output must be at least 80% of the default output calculated by PVWatts. Additionally, all individual series strings of modules output must be at least 70% of the default output calculated by PVWatts.
  - For building integrated solar electric systems (i.e., part of the building envelope materials are comprised of solar electric components), the estimated system output must be 40% of the default output estimated by PVWATTS.
4. System wiring must be installed in accordance with the provisions of the NEC.
5. All modules installed in a series string must be installed in the same plane.

#### C: Inverter and Controls

1. The inverter and controls must be properly installed according to manufacturer's instructions.
2. The inverter must be certified as compliant with the requirements of IEEE 929 for small photovoltaic systems and with UL 1741.
3. The system should be equipped with the following visual indicators and/or controls:
  - On/off switch • Operating mode setting indicator • AC/DC over current protection • Operating status indicator
4. Warning labels must be posted on the control panels and junction boxes indicating that the circuits are energized by an alternate power source independent of utility-provided power.
5. Operating instructions must be posted on or near the system, or on file with facilities operation and maintenance documents.
6. Systems must have monitoring capability that is readily accessible to the owner. This monitor (meter or display) must at minimum display instantaneous and cumulative production. All projects greater than 10kW must have an output meter that meets ANSI C.12 standards

#### D: Control Panel to Solar Electric Array Wire Runs

1. Areas where wiring passes through ceilings, walls or other areas of the building must be properly restored, booted and sealed.
2. All interconnecting wires must be copper. (Some provisions may be made for aluminum wiring; approval must be received from utility engineering departments prior to acceptance.)
3. Thermal insulation in areas where wiring is installed must be replaced to "as found or better condition." Access doors to these areas must be properly sealed and gasketed.
4. Wiring connections must be properly made, insulated and weather-protected.
5. All wiring must be attached to the system components by the use of strain relief's or cable clamps, unless enclosed in conduit.
6. All outside wiring must be rated for wet conditions and/or encased in liquid-tight conduit.
7. Insulation on any wiring located in areas with potential high ambient temperature must be rated at 90° C or higher.
8. All wiring splices must be contained in UL-approved workboxes.

#### E: Batteries (If Applicable)

1. The batteries must be installed according to the manufacturer's instructions.
2. Battery terminals must be adequately protected from accidental contact.
3. DC-rated over current protection must be provided in accordance with the provisions of the NEC.

# New Jersey Clean Energy Program

## Technical Worksheet – Solar Electric Equipment Information

Original Application Date: _____	Revised Application Date: _____
Customer Name: _____ (Corresponding to Rebate Application Form)	Application Number: _____ (Assigned by the NJBPU)

### A: EQUIPMENT INFORMATION

1. Solar Electric Module Manufacturer: \_\_\_\_\_ Module Model Number: \_\_\_\_\_

2. Power Rating per Module: \_\_\_\_\_ DC Watts (Refer to STC conditions) Number of Modules: \_\_\_\_\_

3. Total Array Output: \_\_\_\_\_ DC Watts (No. of Modules x Power Rating)

4. Inverter Manufacturer: \_\_\_\_\_ Inverter Model Number: \_\_\_\_\_

5. Inverter's Continuous AC Rating: \_\_\_\_\_ AC Watts Number of Inverters: \_\_\_\_\_

6. Total Inverter Output: \_\_\_\_\_ AC Watts (Inverter Continuous AC Rating x Number of Inverters)

7. Inverter's Peak Efficiency: \_\_\_\_\_ (Refer to manufacturer's peak efficiency rating)

### B: PROPOSED INSTALLATION/INTERCONNECTION INFORMATION

1. Solar Electric Array Location:  Rooftop  Pole Mount or Ground Mount Location: \_\_\_\_\_

2. Solar Electric Module Orientation: \_\_\_\_\_ degrees (e.g., 180 degrees magnetic south)  
**Note: in Central New Jersey, magnetic south compass reading is 10 degrees east of true south.**

3. Solar Electric Module Tilt: \_\_\_\_\_ degrees (e.g., flat mount = 0 degrees; vertical mount = 90 degrees)

4. Solar Electric Module Tracking:  Fixed  Single-axis  Double-axis

5. Inverter Location:  Indoor  Outdoor Location: \_\_\_\_\_

6. Utility-Accessible AC Disconnect Switch Location: \_\_\_\_\_

7. System Type and Mode of Operation:  
 Utility interactive (parallel/capable of back feeding the meter) ( with battery backup)  
 Dedicated circuit, utility power as backup (transfer switch) ( with battery charging)  
 Stand-alone (system confined to an independent circuit, no utility backup) ( with battery charging)

### C: INCENTIVE REQUEST CALCULATION

1. System rated output (Section A, line 3 above): \_\_\_\_\_ DC Watts

2. Incentive Calculation (Calculate appropriate incentive based on System Rated Output):

<b>Residential Applicants that perform Energy Efficiency Audit</b>	<b>Commercial, Farm, Public and Non-Profit</b>
a. 0 to 10,000 Watts x \$1.75/Watt = \$ _____ +	0 to 50,000 Watts x \$1.00/Watt = \$ _____ +
<b>Residential Applicants that <u>do not</u> perform Energy Efficiency Audit</b>	
b. 0 to 10,000 Watts x \$1.55/Watt = \$ _____ +	
<b>Large PV Project Applications</b>	
> 50,000 Watts = \$ _____ Not eligible for rebates _____	
d. Total Rebate Calculation: \$ _____	Total Rebate Calculation: \$ _____

3. School Applicants: Maximum Annual School Rebate: \$ \_\_\_\_\_  
(For Public School applicants, enter the lesser value from no. 6 on the School Application form or \$50,000)

4. Total Installed System Cost: \$ \_\_\_\_\_  
(Eligible installed system cost includes all equipment, installation, and applicable interconnection costs before the New Jersey Clean Energy Program incentive.)

5. Requested Incentive (Enter the appropriate value from C2. b or c): \$ \_\_\_\_\_

### D: WARRANTY INFORMATION

1. Module: \_\_\_\_\_ Years at \_\_\_\_\_ Percent of Rated Power Output    2. Inverter: \_\_\_\_\_ Years    3. Installation: \_\_\_\_\_ Years

*Revised January 2009*

## APPENDIX H

### ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COSTS

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Benjamin Franklin Middle School</b> Lighting Upgrades	1	ls.		\$ 175,011.00	1	ls.	\$ 111,565.50	\$ 111,565.50	\$ 286,576.50
	Subtotal				175,011.00				111,565.50	

SUBTOTAL = \$ 286,576.50  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 42,986.48  
 SUB-TOTAL w/ OH & P = \$ 329,562.98  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 82,390.74  
 BUDGET COST ESTIMATE = \$ 411,953.72

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Bryant Middle School</b> Lighting Upgrades	1	ls.		\$ 50,831.00	1	ls.	\$ 32,333.50	\$ 32,333.50	\$ 83,164.50
	Subtotal				50,831.00				32,333.50	

SUBTOTAL = \$ 83,164.50  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 12,474.68  
 SUB-TOTAL w/ OH & P = \$ 95,639.18  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 23,909.79  
 BUDGET COST ESTIMATE = \$ 119,548.97

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Eugene Field Administration Building</b> Lighting Upgrades	1	ls.		\$ 27,385.00	1	ls.	\$ 14,543.00	\$ 14,543.00	\$ 41,928.00
	Subtotal				27,385.00				14,543.00	

SUBTOTAL = \$ 41,928.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 6,289.20  
 SUB-TOTAL w/ OH & P = \$ 48,217.20  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 12,054.30  
 BUDGET COST ESTIMATE = \$ 60,271.50

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Hawthorne Elementary School</b> Lighting Upgrades	1	ls.		\$ 52,078.00	1	ls.	\$ 23,379.50	\$ 23,379.50	\$ 75,457.50
	Subtotal				52,078.00				23,379.50	

SUBTOTAL = \$ 75,457.50  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 11,318.63  
 SUB-TOTAL w/ OH & P = \$ 86,776.13  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 21,694.03  
 BUDGET COST ESTIMATE = \$ 108,470.16

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Lowell Elementary School</b> Lighting Upgrades	1	ls.		\$ 37,570.00	1	ls.	\$ 16,690.00	\$ 16,690.00	\$ 54,260.00
	Subtotal				37,570.00				16,690.00	

SUBTOTAL = \$ 54,260.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 8,139.00  
 SUB-TOTAL w/ OH & P = \$ 62,399.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 15,599.75  
 BUDGET COST ESTIMATE = \$ 77,998.75

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Teaneck High School</b> Lighting Upgrades	1	ls.		\$ 72,128.00	1	ls.	\$ 35,526.50	\$ 35,526.50	\$ 107,654.50
	Subtotal				72,128.00				35,526.50	

SUBTOTAL = \$ 107,654.50  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 16,148.18  
 SUB-TOTAL w/ OH & P = \$ 123,802.68  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 30,950.67  
 BUDGET COST ESTIMATE = \$ 154,753.34



# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Thomas Jefferson Middle School</b> Lighting Upgrades	1	ls.		\$ 95,989.00	1	ls.	\$ 63,342.00	\$ 63,342.00	\$ 159,331.00
	Subtotal				95,989.00				63,342.00	

SUBTOTAL = \$ 159,331.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 23,899.65  
 SUB-TOTAL w/ OH & P = \$ 183,230.65  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 45,807.66  
 BUDGET COST ESTIMATE = \$ 229,038.31

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Whittier Elementary School</b> Lighting Upgrades	1	ls.		\$ 51,721.00	1	ls.	\$ 29,088.00	\$ 29,088.00	\$ 80,809.00
	Subtotal				51,721.00				29,088.00	

SUBTOTAL = \$ 80,809.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 12,121.35  
 SUB-TOTAL w/ OH & P = \$ 92,930.35  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 23,232.59  
 BUDGET COST ESTIMATE = \$ 116,162.94

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	Teaneck High School - Press Box Lighting Upgrades	1	ls.		\$ 15.00	1	ls.	\$ 60.00	\$ 60.00	\$ 75.00
	Subtotal				15.00				60.00	

SUBTOTAL = \$ 75.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 11.25  
 SUB-TOTAL w/ OH & P = \$ 86.25  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 21.56  
 BUDGET COST ESTIMATE = \$ 107.81

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Benjamin Franklin Middle School</b>									
	Solar	1	ls.		\$ 1,742,524.00	1	ls.	\$ 746,796.00	\$ 746,796.00	\$ 2,489,320.00
	Subtotal				1,742,524.00				746,796.00	
SUBTOTAL = \$										2,489,320.00
CONTINGENCY % =										0.25
CONTINGENCY = \$										622,330.00
BUDGET COST ESTIMATE = \$										<u>3,111,650.00</u>

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Bryant Middle School</b>									
	Solar	1	ls.		\$ 383,438.00	1.00	ls.	\$ 164,330.00	\$ 164,330.00	\$ 547,768.00
	Subtotal				383,438.00				164,330.00	
SUBTOTAL = \$										547,768.00
CONTINGENCY % =										0.25
CONTINGENCY = \$										136,942.00
BUDGET COST ESTIMATE = \$										<u>684,710.00</u>

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Eugene Field Administration Building</b>									
	Solar	1	ls.		\$ 449,547.00	1	ls.	\$ 192,663.00	\$ 192,663.00	\$ 642,210.00
	Subtotal				449,547.00				192,663.00	

SUBTOTAL = \$ 642,210.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 160,552.50  
 BUDGET COST ESTIMATE = \$ 802,762.50

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Hawthorne Elementary School</b>									
	Solar	1	ls.		\$ 1,003,150.00	1	ls.	\$ 429,921.00	\$ 429,921.00	\$ 1,433,071.00
	Subtotal				1,003,150.00				429,921.00	

SUBTOTAL = \$ 1,433,071.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 358,267.75  
 BUDGET COST ESTIMATE = \$ 1,791,338.75

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Lowell Elementary School</b>									
	Solar	1	ls.		\$ 510,591.00	1	ls.	\$ 218,825.00	\$ 218,825.00	\$ 729,416.00
	Subtotal				510,591.00				218,825.00	

SUBTOTAL = \$ 729,416.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 182,354.00  
 BUDGET COST ESTIMATE = \$ 911,770.00

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Teaneck High School</b>									
	Solar	1	ls.		\$ 1,819,875.00	1	ls.	\$ 779,947.00	\$ 779,947.00	\$ 2,599,822.00
	Subtotal				1,819,875.00				779,947.00	

SUBTOTAL = \$ 2,599,822.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 649,955.50  
 BUDGET COST ESTIMATE = \$ 3,249,777.50

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF CONSTRUCTION COST ESTIMATE

Location: Teaneck BOE  
 Estimate by: RNG  
 Checked by: JM

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Thomas Jefferson Middle School</b>									
	Solar	1	ls.		\$ 3,532,008.00	1	ls.	\$ 1,513,718.00	\$ 1,513,718.00	\$ 5,045,726.00
	Subtotal				3,532,008.00				1,513,718.00	

SUBTOTAL = \$ 5,045,726.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 1,261,431.50  
 BUDGET COST ESTIMATE = \$ 6,307,157.50

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Whittier Elementary School</b>									
	Solar	1	ls.		\$ 1,581,178.00	1	ls.	\$ 677,648.00	\$ 677,648.00	\$ 2,258,826.00
	Subtotal				1,581,178.00				677,648.00	

SUBTOTAL = \$ 2,258,826.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 564,706.50  
 BUDGET COST ESTIMATE = \$ 2,823,532.50

CDM  
 15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

**ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST**

Location: Teaneck - Board of Education  
 Estimate by: AN  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
1	<b>Benjamin Franklin Middle School</b>									
	Boiler, Gas-Fired, Condensing High Efficiency 3,000 MBH	2	ea.	\$ 25,218.00	\$ 50,436.00	2	ea.	\$ 11,000.00	\$ 22,000.00	\$ 72,436.00
	Subtotal				50,436.00				22,000.00	

SUBTOTAL = \$ 72,436.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 10,865.40  
 SUB-TOTAL w/ OH & P = \$ 83,301.40  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 20,825.35  
 BUDGET COST ESTIMATE = \$ 104,126.75

Note:  
 Labor pricing is per RS Means 2010.  
 Boiler pricing is per manufacturer quote dated 2/26/2010 (includes cost of existing system demolition).

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
2	<b>Bryant Elementary School</b>									
	Boiler, Gas-Fired, Condensing High Efficiency 3,000 MBH	2	ea.	\$ 25,218.00	\$ 50,436.00	2	ea.	\$ 11,000.00	\$ 22,000.00	\$ 72,436.00
	Demolition of Heat Exchanger, Shell and Tube	1	ea.	\$ -	\$ -	1	ea.	\$ 605.00	\$ 605.00	\$ 605.00
	Demolition of Condensate Receiver	1	ea.	\$ -	\$ -	1	ea.	\$ 543.70	\$ 543.70	\$ 543.70
	Demolition of Condensate Return Piping	1,110	L.F.	\$ -	\$ -	1,110	L.F.	\$ 5,209.25	\$ 5,209.25	\$ 5,209.25
	HW Return Piping (steel, black, threaded, 2.5")	70	L.F.	\$ 19.35	\$ 1,354.50	70	L.F.	\$ 19.50	\$ 1,365.00	\$ 2,719.50
	HW Return Piping (steel, black, threaded, 2")	80	L.F.	\$ 12.55	\$ 1,004.00	80	L.F.	\$ 15.20	\$ 1,216.00	\$ 2,220.00
	HW Return Piping (steel, black, threaded, 1.5")	80	L.F.	\$ 9.40	\$ 752.00	80	L.F.	\$ 12.15	\$ 972.00	\$ 1,724.00
	HW Return Piping (steel, black, threaded, 1")	80	L.F.	\$ 6.20	\$ 496.00	80	L.F.	\$ 10.20	\$ 816.00	\$ 1,312.00
	HW Return Piping (steel, black, threaded, 0.75")	800	L.F.	\$ 4.26	\$ 3,408.00	800	L.F.	\$ 8.90	\$ 7,120.00	\$ 10,528.00
	Hydronic HW Control Valve, 0.75"	40	ea.	\$ 56.50	\$ 2,260.00	40	ea.	\$ 27.50	\$ 1,100.00	\$ 3,360.00
	Controls Upgrades	1	ea.	\$ -	\$ -	1	ea.	\$ -	\$ -	\$ 16,438.42
	Air Control, Air Separator, 2.5"	1	ea.	\$ 940.00	\$ 940.00	1	ea.	\$ 194.00	\$ 194.00	\$ 1,134.00
	Circulation Pump, Cast Iron, 3 HP	2	ea.	\$ 2,400.00	\$ 4,800.00	2	ea.	\$ 490.00	\$ 980.00	\$ 5,780.00
Expansion Tank, Steel, 80 gal	2	ea.	\$ 870.00	\$ 1,740.00	2	ea.	\$ 139.00	\$ 278.00	\$ 2,018.00	
Subtotal				50,436.00				22,000.00		

SUBTOTAL = \$ 126,027.87  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 18,904.18  
 SUB-TOTAL w/ OH & P = \$ 144,932.05  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 36,233.01  
 BUDGET COST ESTIMATE = \$ 181,165.06

Note:  
 All pricing is per RS Means 2010, with exception of boiler and controls upgrade.  
 Boiler pricing is per manufacturer quote dated 2/26/2010 (includes cost of existing system demolition).  
 Controls upgrade pricing is estimated as 15% of total mechanical system cost.

CDM  
 15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

**ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST**

Location: Teaneck - Board of Education  
 Estimate by: AN  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
3	<b>Eugene Field Administration Building</b>									
	Boiler, Gas-Fired, Condensing High Efficiency 3,000 MBH	2	ea.	\$ 25,218.00	\$ 50,436.00	2	ea.	\$ 11,000.00	\$ 22,000.00	\$ 72,436.00
	Subtotal				50,436.00				22,000.00	

SUBTOTAL = \$ 72,436.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 10,865.40  
 SUB-TOTAL w/ OH & P = \$ 83,301.40  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 20,825.35  
 BUDGET COST ESTIMATE = \$ 104,126.75

Note:  
 Labor pricing is per RS Means 2010.  
 Boiler pricing is per manufacturer quote dated 2/26/2010 (includes cost of existing system demolition).

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
4	<b>Hawthorne Elementary School</b>									
	Boiler, Gas-Fired, Condensing High Efficiency 3,000 MBH	2	ea.	\$ 25,218.00	\$ 50,436.00	2	ea.	\$ 11,000.00	\$ 22,000.00	\$ 72,436.00
	Demolition of Heat Exchanger, Shell and Tube	1	ea.	\$ -	\$ -	1	ea.	\$ 605.00	\$ 605.00	\$ 605.00
	Demolition of Condensate Receiver	1	ea.	\$ -	\$ -	1	ea.	\$ 543.70	\$ 543.70	\$ 543.70
	Demolition of Condensate Return Piping	1,110	L.F.	\$ -	\$ -	1,110	L.F.	\$ 5,209.25	\$ 5,209.25	\$ 5,209.25
	HW Return Piping (steel, black, threaded, 2.5")	70	L.F.	\$ 19.35	\$ 1,354.50	70	L.F.	\$ 19.50	\$ 1,365.00	\$ 2,719.50
	HW Return Piping (steel, black, threaded, 2")	80	L.F.	\$ 12.55	\$ 1,004.00	80	L.F.	\$ 15.20	\$ 1,216.00	\$ 2,220.00
	HW Return Piping (steel, black, threaded, 1.5")	80	L.F.	\$ 9.40	\$ 752.00	80	L.F.	\$ 12.15	\$ 972.00	\$ 1,724.00
	HW Return Piping (steel, black, threaded, 1")	80	L.F.	\$ 6.20	\$ 496.00	80	L.F.	\$ 10.20	\$ 816.00	\$ 1,312.00
	HW Return Piping (steel, black, threaded, 0.75")	800	L.F.	\$ 4.26	\$ 3,408.00	800	L.F.	\$ 8.90	\$ 7,120.00	\$ 10,528.00
	Hydronic HW Control Valve, 0.75"	40	ea.	\$ 56.50	\$ 2,260.00	40	ea.	\$ 27.50	\$ 1,100.00	\$ 3,360.00
	Controls Upgrades	1	ea.	\$ -	\$ -	1	ea.	\$ -	\$ -	\$ 16,438.42
	Air Control, Air Separator, 2.5"	1	ea.	\$ 940.00	\$ 940.00	1	ea.	\$ 194.00	\$ 194.00	\$ 1,134.00
	Circulation Pump, Cast Iron, 3 HP	2	ea.	\$ 2,400.00	\$ 4,800.00	2	ea.	\$ 490.00	\$ 980.00	\$ 5,780.00
	Expansion Tank, Steel, 80 gal	2	ea.	\$ 870.00	\$ 1,740.00	2	ea.	\$ 139.00	\$ 278.00	\$ 2,018.00
Subtotal				50,436.00				22,000.00		

SUBTOTAL = \$ 126,027.87  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 18,904.18  
 SUB-TOTAL w/ OH & P = \$ 144,932.05  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 36,233.01  
 BUDGET COST ESTIMATE = \$ 181,165.06

Note:  
 All pricing is per RS Means 2010, with exception of boiler and controls upgrade.  
 Boiler pricing is per manufacturer quote dated 2/26/2010 (includes cost of existing system demolition).  
 Controls upgrade pricing is estimated as 15% of total mechanical system cost.



CDM  
 15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

**ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST**

Location: Teaneck - Board of Education  
 Estimate by: AN  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
<b>Lowell Elementary School</b>										
5	Boiler, Gas-Fired, Condensing High Efficiency 3,000 MBH	2	ea.	\$ 25,218.00	\$ 50,436.00	2	ea.	\$ 11,000.00	\$ 22,000.00	\$ 72,436.00
	Demolition of Heat Exchanger, Shell and Tube	1	ea.	\$ -	\$ -	1	ea.	\$ 605.00	\$ 605.00	\$ 605.00
	Demolition of Condensate Receiver	1	ea.	\$ -	\$ -	1	ea.	\$ 543.70	\$ 543.70	\$ 543.70
	Demolition of Condensate Return Piping	2,030	L.F.	\$ -	\$ -	2,030	L.F.	\$ 9,381.25	\$ 9,381.25	\$ 9,381.25
	HW Return Piping (steel, black, threaded, 3")	70	L.F.	\$ 25.00	\$ 1,750.00	70	L.F.	\$ 22.50	\$ 1,575.00	\$ 3,325.00
	HW Return Piping (steel, black, threaded, 2")	120	L.F.	\$ 12.55	\$ 1,506.00	120	L.F.	\$ 15.20	\$ 1,824.00	\$ 3,330.00
	HW Return Piping (steel, black, threaded, 1.5")	120	L.F.	\$ 9.40	\$ 1,128.00	120	L.F.	\$ 12.15	\$ 1,458.00	\$ 2,586.00
	HW Return Piping (steel, black, threaded, 1")	120	L.F.	\$ 6.20	\$ 744.00	120	L.F.	\$ 10.20	\$ 1,224.00	\$ 1,968.00
	HW Return Piping (steel, black, threaded, 0.75")	1,600	L.F.	\$ 4.26	\$ 6,816.00	1,600	L.F.	\$ 8.90	\$ 14,240.00	\$ 21,056.00
	Hydronic HW Control Valve, 0.75"	80	ea.	\$ 56.50	\$ 4,520.00	80	ea.	\$ 27.50	\$ 2,200.00	\$ 6,720.00
	Controls Upgrades	1	ea.	\$ -	\$ -	1	ea.	\$ -	\$ -	\$ 20,233.50
	Air Control, Air Separator, 3"	1	ea.	\$ 1,450.00	\$ 1,450.00	1	ea.	\$ 243.00	\$ 243.00	\$ 1,693.00
	Circulation Pump, Cast Iron, 10 HP	2	ea.	\$ 3,675.00	\$ 7,350.00	2	ea.	\$ 610.00	\$ 1,220.00	\$ 8,570.00
	Expansion Tank, Steel, 100 gal	2	ea.	\$ 1,175.00	\$ 2,350.00	2	ea.	\$ 163.00	\$ 326.00	\$ 2,676.00
	Subtotal				50,436.00				22,000.00	

SUBTOTAL = \$ 155,123.45

MARKUP % = \$ 0.15

MARKUP = \$ 23,268.52

SUB-TOTAL w/ OH & P = \$ 178,391.97

CONTINGENCY % = 0.25

CONTINGENCY = \$ 44,597.99

BUDGET COST ESTIMATE = \$ 222,989.96

Note:

All pricing is per RS Means 2010, with exception of boiler and controls upgrade.

Boiler pricing is per manufacturer quote dated 2/26/2010 (includes cost of existing system demolition).

Controls upgrade pricing is estimated as 15% of total mechanical system cost.

ITEM	DESCRIPTION	QTY	UNIT	*MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	**LABOR COST	LABOR SUBTOTAL	TOTAL
<b>Thomas Jefferson Middle School</b>										
6	Boiler, Gas-Fired, Condensing High Efficiency 3,000 MBH	3	ea.	\$ 25,218.00	\$ 75,654.00	3	ea.	\$ 11,000.00	\$ 33,000.00	\$ 108,654.00
	Subtotal				75,654.00				33,000.00	

SUBTOTAL = \$ 108,654.00

MARKUP % = \$ 0.15

MARKUP = \$ 16,298.10

SUB-TOTAL w/ OH & P = \$ 124,952.10

CONTINGENCY % = 0.25

CONTINGENCY = \$ 31,238.03

BUDGET COST ESTIMATE = \$ 156,190.13

Note:

Labor pricing is per RS Means 2010.

Boiler pricing is per manufacturer quote dated 2/26/2010 (includes cost of existing system demolition).

CDM  
 15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

**ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST**

Location: Teaneck - Board of Education  
 Estimate by: AN  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
	<b>Whittier Elementary School</b>									
7	Boiler, Gas-Fired, Condensing High Efficiency 3,000 MBH	2	ea.	\$ 25,218.00	\$ 50,436.00	2	ea.	\$ 11,000.00	\$ 22,000.00	\$ 72,436.00
	Demolition of Heat Exchanger, Shell and Tube	1	ea.	\$ -	\$ -	1	ea.	\$ 605.00	\$ 605.00	\$ 605.00
	Demolition of Condensate Receiver	1	ea.	\$ -	\$ -	1	ea.	\$ 543.70	\$ 543.70	\$ 543.70
	Demolition of Condensate Return Piping	2,030	L.F.	\$ -	\$ -	2,030	L.F.	\$ 9,381.25	\$ 9,381.25	\$ 9,381.25
	HW Return Piping (steel, black, threaded, 3")	70	L.F.	\$ 25.00	\$ 1,750.00	70	L.F.	\$ 22.50	\$ 1,575.00	\$ 3,325.00
	HW Return Piping (steel, black, threaded, 2")	120	L.F.	\$ 12.55	\$ 1,506.00	120	L.F.	\$ 15.20	\$ 1,824.00	\$ 3,330.00
	HW Return Piping (steel, black, threaded, 1.5")	120	L.F.	\$ 9.40	\$ 1,128.00	120	L.F.	\$ 12.15	\$ 1,458.00	\$ 2,586.00
	HW Return Piping (steel, black, threaded, 1")	120	L.F.	\$ 6.20	\$ 744.00	120	L.F.	\$ 10.20	\$ 1,224.00	\$ 1,968.00
	HW Return Piping (steel, black, threaded, 0.75")	1,600	L.F.	\$ 4.26	\$ 6,816.00	1,600	L.F.	\$ 8.90	\$ 14,240.00	\$ 21,056.00
	Hydronic HW Control Valve, 0.75"	80	ea.	\$ 56.50	\$ 4,520.00	80	ea.	\$ 27.50	\$ 2,200.00	\$ 6,720.00
	Controls Upgrades	1	ea.	\$ -	\$ -	1	ea.	\$ -	\$ -	\$ 20,233.50
	Air Control, Air Separator, 3"	1	ea.	\$ 1,450.00	\$ 1,450.00	1	ea.	\$ 243.00	\$ 243.00	\$ 1,693.00
	Circulation Pump, Cast Iron, 10 HP	2	ea.	\$ 3,675.00	\$ 7,350.00	2	ea.	\$ 610.00	\$ 1,220.00	\$ 8,570.00
	Expansion Tank, Steel, 100 gal	2	ea.	\$ 1,175.00	\$ 2,350.00	2	ea.	\$ 163.00	\$ 326.00	\$ 2,676.00
	Subtotal				50,436.00				22,000.00	

SUBTOTAL =	\$	155,123.45
MARKUP % =	\$	0.15
MARKUP =	\$	23,268.52
SUB-TOTAL w/ OH & P =	\$	178,391.97
CONTINGENCY % =		0.25
CONTINGENCY =	\$	44,597.99
BUDGET COST ESTIMATE =	\$	222,989.96

Note:

All pricing is per RS Means 2010, with exception of boiler and controls upgrade.  
 Boiler pricing is per manufacturer quote dated 2/26/2010 (includes cost of existing system demolition).  
 Controls upgrade pricing is estimated as 15% of total mechanical system cost.

CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

**ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST**

Location: Teaneck - Board of Education  
 Estimate by: AN  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	*MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	**LABOR COST	LABOR SUBTOTAL	TOTAL
8	<b>Hawthorne Elementary School</b> Air-Handler, High Efficiency 60 MBH heating, 5 tons cooling	2	ea.	\$ 4,850.00	\$ 9,700.00	2	ea.	\$ 1,325.00	\$ 2,650.00	\$ 12,350.00
	Subtotal				9,700.00				2,650.00	

SUBTOTAL = \$ 12,350.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 1,852.50  
 SUB-TOTAL w/ OH & P = \$ 14,202.50  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 3,550.63  
 BUDGET COST ESTIMATE = \$ 17,753.13

\*Pricing per RS Means 2010  
 \*\*Pricing per RS Means 2010

ITEM	DESCRIPTION	QTY	UNIT	*MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	**LABOR COST	LABOR SUBTOTAL	TOTAL
9	<b>Teaneck High School</b> Air-Handler, High Efficiency 300 MBH heating, 20 tons cooling	2	ea.	\$ 42,845.00	\$ 85,690.00	2	ea.	\$ 2,375.00	\$ 4,750.00	\$ 90,440.00
	Subtotal				85,690.00				4,750.00	

SUBTOTAL = \$ 90,440.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 13,566.00  
 SUB-TOTAL w/ OH & P = \$ 104,006.00  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 26,001.50  
 BUDGET COST ESTIMATE = \$ 130,007.50

\*Pricing per manufacturer quote 2/1/10  
 \*\*Pricing per RS Means 2010

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Estimate by: **EMB**  
 Checked by: **MG**

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL & LABOR UNIT COST	MATERIAL & LABOR SUBTOTAL	TOTAL
10	<b>Bryant Elementary School</b> DDC Control System	47,438	SF	\$ 0.60	\$ 28,462.80	\$ 28,462.80
	Subtotal				28,462.80	

Notes:

- DDC Control System Pricing is estimated at \$0.60 per square foot
- At an assumed \$400 per control point, this will allow for 102 points

SUBTOTAL =	\$	28,462.80
MARKUP % =	\$	0.15
MARKUP =	\$	4,269.42
<b>SUB-TOTAL w/ OH &amp; P =</b>	<b>\$</b>	<b>32,732.22</b>
CONTINGENCY % =		0.25
CONTINGENCY =	\$	8,183.06
<b>BUDGET COST ESTIMATE =</b>	<b>\$</b>	<b>40,915.28</b>

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL & LABOR UNIT COST	MATERIAL & LABOR SUBTOTAL	TOTAL
11	<b>Eugene Field Administration Building</b> DDC Control System	24,877	SF	\$ 0.60	\$ 14,926.20	\$ 14,926.20
	Subtotal				14,926.20	

Notes:

- DDC Control System Pricing is estimated at \$0.60 per square foot
- At an assumed \$400 per control point, this will allow for 54 points

SUBTOTAL =	\$	14,926.20
MARKUP % =	\$	0.15
MARKUP =	\$	2,238.93
<b>SUB-TOTAL w/ OH &amp; P =</b>	<b>\$</b>	<b>17,165.13</b>
CONTINGENCY % =		0.25
CONTINGENCY =	\$	4,291.28
<b>BUDGET COST ESTIMATE =</b>	<b>\$</b>	<b>21,456.41</b>

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Estimate by: EMB  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL & LABOR UNIT COST	MATERIAL & LABOR SUBTOTAL	TOTAL
12	<b>Hawthorne Elementary School</b> DDC Control System	49,373	SF	\$ 0.60	\$ 29,623.80	\$ 29,623.80
	Subtotal				29,623.80	

Notes:

- DDC Control System Pricing is estimated at \$0.60 per square foot
- At an assumed \$400 per control point, this will allow for 106 points

SUBTOTAL =	\$	29,623.80
MARKUP % =	\$	0.15
MARKUP =	\$	4,443.57
<b>SUB-TOTAL w/ OH &amp; P =</b>	<b>\$</b>	<b>34,067.37</b>
CONTINGENCY % =		0.25
CONTINGENCY =	\$	8,516.84
<b>BUDGET COST ESTIMATE =</b>	<b>\$</b>	<b>42,584.21</b>

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL & LABOR UNIT COST	MATERIAL & LABOR SUBTOTAL	TOTAL
13	<b>Lowell Elementary School</b> DDC Control System	47,106	SF	\$ 0.60	\$ 28,263.60	\$ 28,263.60
	Subtotal				28,263.60	

Notes:

- DDC Control System Pricing is estimated at \$0.60 per square foot
- At an assumed \$400 per control point, this will allow for 102 points

SUBTOTAL =	\$	28,263.60
MARKUP % =	\$	0.15
MARKUP =	\$	4,239.54
<b>SUB-TOTAL w/ OH &amp; P =</b>	<b>\$</b>	<b>32,503.14</b>
CONTINGENCY % =		0.25
CONTINGENCY =	\$	8,125.79
<b>BUDGET COST ESTIMATE =</b>	<b>\$</b>	<b>40,628.93</b>

# CDM

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

## ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

Estimate by: EMB  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL & LABOR UNIT COST	MATERIAL & LABOR SUBTOTAL	TOTAL
14	<b>Whittier Elementary School</b> DDC Control System	55,118	SF	\$ 0.60	\$ 33,070.80	\$ 33,070.80
	Subtotal				33,070.80	

Notes:

- DDC Control System Pricing is estimated at \$0.60 per square foot
- At an assumed \$400 per control point, this will allow for 119 points

SUBTOTAL =	\$	33,070.80
MARKUP % =	\$	0.15
MARKUP =	\$	4,960.62
<u>SUB-TOTAL w/ OH &amp; P =</u>		<u>\$ 38,031.42</u>
CONTINGENCY % =		0.25
CONTINGENCY =	\$	9,507.86
BUDGET COST ESTIMATE =	\$	<u>47,539.28</u>

# CDM

## ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

Estimate by: ASN  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
15	<b>Teaneck High School</b> Variable Frequency Drive, Enclosed (NEMA 1), 460 Volt, 10 HP motor	7	ea.	\$ 1,550.00	\$ 10,850.00	7	ea.	\$ 795.00	\$ 5,565.00	\$ 16,415.00
	2 Way Zone Valve, Bronze Body, High Head, 125' Pump Head, 1/2" Soldered**	210	ea.	\$ 152.00	\$ 31,920.00	210	ea.	\$ 22.00	\$ 4,620.00	\$ 36,540.00
	Subtotal				42,770.00				10,185.00	

Pricing per RS Means Costworks 2010

\*\*Assumes 1 valve per unit ventilator, 30 unit ventilators per pump, with 25% contingency

SUBTOTAL =	\$	52,955.00
MARKUP % =	\$	0.15
MARKUP =	\$	7,943.25
SUB-TOTAL w/ OH & P =	\$	60,898.25
CONTINGENCY % =		0.25
CONTINGENCY =	\$	15,224.56
BUDGET COST ESTIMATE =	\$	76,122.81

# CDM

## ENGINEER'S OPINION OF PROBABLE CONSTRUCTION COST

15 British American Blvd  
 Latham, NY 12110  
 Phone (518) 782-4500  
 Fax (518) 786-3810

Estimate by: ASN  
 Checked by: MG

ITEM	DESCRIPTION	QTY	UNIT	MATERIAL UNIT COST	MATERIAL SUBTOTAL	QTY	UNIT	LABOR COST	LABOR SUBTOTAL	TOTAL
16	<b>Teaneck High School</b> Water Heater, Gas-Fired, High Efficiency 194 MBH	1	ea.	\$ 2,675.00	\$ 2,675.00	1	ea.	\$ 970.00	\$ 970.00	\$ 3,645.00

Pricing per RS Means Costworks 2010

SUBTOTAL = \$ 3,645.00  
 MARKUP % = \$ 0.15  
 MARKUP = \$ 546.75  
 SUB-TOTAL w/ OH & P = \$ 4,191.75  
 CONTINGENCY % = 0.25  
 CONTINGENCY = \$ 1,047.94  
 BUDGET COST ESTIMATE = \$ 5,239.69



APPENDIX I

ECRM FINANCIAL ANALYSES

ECM	Benjamin Franklin Middle School - Interior & Exterior Lighting	Bryant Elementary School Interior & Exterior Lighting	Eugene Fields Administration Building- Interior & Exterior Lighting	Hawthorne Elementary School - Interior & Exterior Lighting	Lowell Elementary School - Interior & Exterior Lighting	Teaneck High School - Interior & Exterior Lighting	Teaneck High School - Press Box- Interior Lighting	Thomas Jefferson Middle School - Interior & Exterior Lighting	Whittier Elementary School - Interior & Exterior Lighting
Assumed Inflation (Gas)									
Initial Yearly Savings (Gas)									
Assumed Inflation (Electricity)	3%	3%	3%	3%	3%	3%	3%	3%	3%
Initial Yearly Savings (Electricity)	\$45,923.70	\$15,536.60	\$7,891.90	\$10,015.50	\$7,834.30	\$20,173.50	\$7.50	\$25,679.30	\$16,811.00
Assumed Average Useful Life (Years)	15	15	15	15	15	15	15	15	15
<b>Lifetime Savings</b>	<b>\$854,130.94</b>	<b>\$288,963.89</b>	<b>\$146,780.77</b>	<b>\$186,277.42</b>	<b>\$145,709.47</b>	<b>\$375,205.19</b>	<b>\$139.49</b>	<b>\$477,607.09</b>	<b>\$312,666.34</b>
<b>Year</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>
1	\$45,923.70	\$15,536.60	\$7,891.90	\$10,015.50	\$7,834.30	\$20,173.50	\$7.50	\$25,679.30	\$16,811.00
2	\$47,301.41	\$16,002.70	\$8,128.66	\$10,315.97	\$8,069.33	\$20,778.71	\$7.73	\$26,449.68	\$17,315.33
3	\$48,720.45	\$16,482.78	\$8,372.52	\$10,625.44	\$8,311.41	\$21,402.07	\$7.96	\$27,243.17	\$17,834.79
4	\$50,182.07	\$16,977.26	\$8,623.69	\$10,944.21	\$8,560.75	\$22,044.13	\$8.20	\$28,060.46	\$18,369.83
5	\$51,687.53	\$17,486.58	\$8,882.40	\$11,272.53	\$8,817.57	\$22,705.45	\$8.44	\$28,902.28	\$18,920.93
6	\$53,238.15	\$18,011.18	\$9,148.88	\$11,610.71	\$9,082.10	\$23,386.62	\$8.69	\$29,769.35	\$19,488.56
7	\$54,835.30	\$18,551.51	\$9,423.34	\$11,959.03	\$9,354.66	\$24,088.21	\$8.96	\$30,662.43	\$20,073.21
8	\$56,480.36	\$19,108.06	\$9,706.04	\$12,317.80	\$9,635.20	\$24,810.86	\$9.22	\$31,582.30	\$20,675.41
9	\$58,174.77	\$19,681.30	\$9,997.22	\$12,687.34	\$9,924.26	\$25,555.19	\$9.50	\$32,529.77	\$21,295.67
10	\$59,920.01	\$20,271.74	\$10,297.14	\$13,067.96	\$10,221.98	\$26,321.84	\$9.79	\$33,505.66	\$21,934.54
11	\$61,717.61	\$20,879.89	\$10,606.05	\$13,459.99	\$10,528.64	\$27,111.50	\$10.08	\$34,510.83	\$22,592.58
12	\$63,569.14	\$21,506.29	\$10,924.24	\$13,863.79	\$10,844.50	\$27,924.84	\$10.38	\$35,546.16	\$23,270.36
13	\$65,476.22	\$22,151.48	\$11,251.96	\$14,279.71	\$11,169.94	\$28,762.59	\$10.69	\$36,612.54	\$23,968.47
14	\$67,440.50	\$22,816.02	\$11,589.52	\$14,708.10	\$11,504.93	\$29,625.46	\$11.01	\$37,710.92	\$24,687.52
15	\$69,463.72	\$23,500.50	\$11,937.21	\$15,149.34	\$11,850.08	\$30,514.23	\$11.34	\$38,842.25	\$25,428.15

ECM	Benjamin Franklin Middle School - Interior Lighting	Bryant Elementary School Interior Lighting	Eugene Fields Administration Building- Interior Lighting	Hawthorne Elementary School - Interior Lighting	Lowell Elementary School - Interior Lighting	Teaneck High School - Interior Lighting	Thomas Jefferson Middle School - Interior Lighting	Whittier Elementary School - Interior Lighting
Assumed Inflation (Gas)								
Initial Yearly Savings (Gas)								
Assumed Inflation (Electricity)	3%	3%	3%	3%	3%	3%	3%	3%
Initial Yearly Savings (Electricity)	\$42,650.30	\$15,103.50	\$6,586.30	\$9,248.80	\$6,534.30	\$19,168.10	\$24,587.20	\$16,572.50
Assumed Average Useful Life (Years)	15	15	15	15	15	15	15	15
<b>Lifetime Savings</b>	<b>\$793,249.26</b>	<b>\$280,908.70</b>	<b>\$122,498.03</b>	<b>\$172,017.63</b>	<b>\$121,530.88</b>	<b>\$356,505.84</b>	<b>\$457,295.22</b>	<b>\$308,230.50</b>
<b>Year</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>
1	\$42,650.30	\$15,103.50	\$6,586.30	\$9,248.80	\$6,534.30	\$19,168.10	\$24,587.20	\$16,572.50
2	\$43,929.81	\$15,556.61	\$6,783.89	\$9,526.26	\$6,730.33	\$19,743.14	\$25,324.82	\$17,069.68
3	\$45,247.70	\$16,023.30	\$6,987.41	\$9,812.05	\$6,932.24	\$20,335.44	\$26,084.56	\$17,581.77
4	\$46,605.13	\$16,504.00	\$7,197.03	\$10,106.41	\$7,140.21	\$20,945.50	\$26,867.10	\$18,109.22
5	\$48,003.29	\$16,999.12	\$7,412.94	\$10,409.61	\$7,354.41	\$21,573.87	\$27,673.11	\$18,652.49
6	\$49,443.39	\$17,509.10	\$7,635.33	\$10,721.89	\$7,575.04	\$22,221.08	\$28,503.30	\$19,212.07
7	\$50,926.69	\$18,034.37	\$7,864.39	\$11,043.55	\$7,802.30	\$22,887.71	\$29,358.40	\$19,788.43
8	\$52,454.49	\$18,575.40	\$8,100.32	\$11,374.86	\$8,036.36	\$23,574.35	\$30,239.15	\$20,382.08
9	\$54,028.12	\$19,132.66	\$8,343.33	\$11,716.10	\$8,277.46	\$24,281.58	\$31,146.33	\$20,993.55
10	\$55,648.97	\$19,706.64	\$8,593.63	\$12,067.59	\$8,525.78	\$25,010.02	\$32,080.72	\$21,623.35
11	\$57,318.44	\$20,297.84	\$8,851.44	\$12,429.61	\$8,781.55	\$25,760.32	\$33,043.14	\$22,272.05
12	\$59,037.99	\$20,906.78	\$9,116.98	\$12,802.50	\$9,045.00	\$26,533.13	\$34,034.44	\$22,940.22
13	\$60,809.13	\$21,533.98	\$9,390.49	\$13,186.58	\$9,318.35	\$27,329.13	\$35,055.47	\$23,628.42
14	\$62,633.40	\$22,180.00	\$9,672.20	\$13,582.17	\$9,595.84	\$28,149.00	\$36,107.13	\$24,337.27
15	\$64,512.41	\$22,845.40	\$9,962.37	\$13,989.64	\$9,883.72	\$28,993.47	\$37,190.35	\$25,067.39

ECM	Benjamin Franklin Middle School - Exterior Lighting	Bryant Elementary School Exterior Lighting	Eugene Fields Administration Building - Exterior Lighting	Hawthorne Elementary School - Exterior Lighting	Lowell Elementary School - Exterior Lighting	Teaneck High School - Exterior Lighting	Thomas Jefferson Middle School - Exterior Lighting	Whittier Elementary School - Exterior Lighting
Assumed Inflation (Gas)								
Initial Yearly Savings (Gas)								
Assumed Inflation (Electricity)	3%	3%	3%	3%	3%	3%	3%	3%
Initial Yearly Savings (Electricity)	\$3,273.40	\$433.20	\$1,305.60	\$766.70	\$1,300.00	\$1,005.40	\$1,092.10	\$238.50
Assumed Average Useful Life (Years)	15	15	15	15	15	15	15	15
<b>Lifetime Savings</b>	<b>\$60,881.68</b>	<b>\$8,057.05</b>	<b>\$24,282.74</b>	<b>\$14,259.79</b>	<b>\$24,178.59</b>	<b>\$18,699.35</b>	<b>\$20,311.87</b>	<b>\$4,435.84</b>
<b>Year</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>	<b>Annual Savings</b>
1	\$3,273.40	\$433.20	\$1,305.60	\$766.70	\$1,300.00	\$1,005.40	\$1,092.10	\$238.50
2	\$3,371.60	\$446.20	\$1,344.77	\$789.70	\$1,339.00	\$1,035.56	\$1,124.86	\$245.66
3	\$3,472.75	\$459.58	\$1,385.11	\$813.39	\$1,379.17	\$1,066.63	\$1,158.61	\$253.02
4	\$3,576.93	\$473.37	\$1,426.66	\$837.79	\$1,420.55	\$1,098.63	\$1,193.37	\$260.62
5	\$3,684.24	\$487.57	\$1,469.46	\$862.93	\$1,463.16	\$1,131.59	\$1,229.17	\$268.43
6	\$3,794.77	\$502.20	\$1,513.55	\$888.82	\$1,507.06	\$1,165.53	\$1,266.04	\$276.49
7	\$3,908.61	\$517.26	\$1,558.95	\$915.48	\$1,552.27	\$1,200.50	\$1,304.02	\$284.78
8	\$4,025.87	\$532.78	\$1,605.72	\$942.94	\$1,598.84	\$1,236.52	\$1,343.15	\$293.32
9	\$4,146.65	\$548.76	\$1,653.90	\$971.23	\$1,646.80	\$1,273.61	\$1,383.44	\$302.12
10	\$4,271.04	\$565.23	\$1,703.51	\$1,000.37	\$1,696.21	\$1,311.82	\$1,424.94	\$311.19
11	\$4,399.18	\$582.18	\$1,754.62	\$1,030.38	\$1,747.09	\$1,351.17	\$1,467.69	\$320.52
12	\$4,531.15	\$599.65	\$1,807.26	\$1,061.29	\$1,799.50	\$1,391.71	\$1,511.72	\$330.14
13	\$4,667.09	\$617.64	\$1,861.47	\$1,093.13	\$1,853.49	\$1,433.46	\$1,557.07	\$340.04
14	\$4,807.10	\$636.17	\$1,917.32	\$1,125.92	\$1,909.09	\$1,476.46	\$1,603.79	\$350.25
15	\$4,951.31	\$655.25	\$1,974.84	\$1,159.70	\$1,966.37	\$1,520.76	\$1,651.90	\$360.75

IRR, NPV, AROI

Inflation Rate: 3%

Lighting Upgrades - Interior & Exterior Benjamin Franklin Middle School		Lighting Upgrades - Interior & Exterior Bryant Elementary School		Lighting Upgrades - Interior & Exterior Eugene Fields Administration Building		Lighting Upgrades - Interior & Exterior Hawthorne Elementary School		Lighting Upgrades - Interior & Exterior Lowell Elementary School		Lighting Upgrades - Interior & Exterior Teaneck High School		Lighting Upgrades - Interior & Exterior Thomas Jefferson Middle School		Lighting Upgrades - Interior & Exterior Whittier Elementary School		Lighting Upgrades - Interior Teaneck High School - Press Box	
Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15	
Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow
0	(\$390,818.70)	0	(\$96,319.00)	0	(\$56,146.50)	0	(\$103,835.20)	0	(\$74,288.80)	0	(\$142,903.30)	0	(\$213,303.30)	0	(\$108,502.90)	0	(\$107.80)
1	\$52,545.83	1	\$18,291.79	1	\$8,665.70	1	\$11,215.99	1	\$8,354.98	1	\$21,750.83	1	\$27,889.09	1	\$18,477.92	1	\$78.02
2	\$54,122.20	2	\$18,840.54	2	\$8,925.67	2	\$11,552.47	2	\$8,605.63	2	\$22,403.35	2	\$28,725.76	2	\$19,032.26	2	\$80.36
3	\$55,745.87	3	\$19,405.76	3	\$9,193.44	3	\$11,899.04	3	\$8,863.80	3	\$23,075.46	3	\$29,587.54	3	\$19,603.23	3	\$82.77
4	\$57,418.25	4	\$19,987.93	4	\$9,469.24	4	\$12,256.02	4	\$9,129.71	4	\$23,767.72	4	\$30,475.16	4	\$20,191.32	4	\$85.25
5	\$59,140.79	5	\$20,587.57	5	\$9,753.32	5	\$12,623.70	5	\$9,403.60	5	\$24,480.75	5	\$31,389.42	5	\$20,797.06	5	\$87.81
6	\$60,915.02	6	\$21,205.20	6	\$10,045.92	6	\$13,002.41	6	\$9,685.71	6	\$25,215.17	6	\$32,331.10	6	\$21,420.97	6	\$90.45
7	\$62,742.47	7	\$21,841.35	7	\$10,347.30	7	\$13,392.48	7	\$9,976.28	7	\$25,971.63	7	\$33,301.03	7	\$22,063.60	7	\$93.16
8	\$64,624.74	8	\$22,496.59	8	\$10,657.72	8	\$13,794.25	8	\$10,275.57	8	\$26,750.78	8	\$34,300.06	8	\$22,725.51	8	\$95.95
9	\$66,563.49	9	\$23,171.49	9	\$10,977.45	9	\$14,208.08	9	\$10,583.84	9	\$27,553.30	9	\$35,329.06	9	\$23,407.28	9	\$98.83
10	\$68,560.39	10	\$23,866.64	10	\$11,306.77	10	\$14,634.32	10	\$10,901.35	10	\$28,379.90	10	\$36,388.94	10	\$24,109.49	10	\$101.80
11	\$70,617.20	11	\$24,582.64	11	\$11,645.98	11	\$15,073.35	11	\$11,228.39	11	\$29,231.30	11	\$37,480.60	11	\$24,832.78	11	\$104.85
12	\$72,735.72	12	\$25,320.12	12	\$11,995.36	12	\$15,525.55	12	\$11,565.25	12	\$30,108.24	12	\$38,605.02	12	\$25,577.76	12	\$108.00
13	\$74,917.79	13	\$26,079.72	13	\$12,355.22	13	\$15,991.32	13	\$11,912.20	13	\$31,011.48	13	\$39,763.17	13	\$26,345.10	13	\$111.24
14	\$77,165.32	14	\$26,862.11	14	\$12,725.87	14	\$16,471.06	14	\$12,269.57	14	\$31,941.83	14	\$40,956.07	14	\$27,135.45	14	\$114.58
15	\$79,480.28	15	\$27,667.97	15	\$13,107.65	15	\$16,965.19	15	\$12,637.66	15	\$32,900.08	15	\$42,184.75	15	\$27,949.51	15	\$118.01
IRR	13.17%	IRR	20.09%	IRR	15.76%	IRR	9.47%	IRR	10.12%	IRR	15.48%	IRR	12.67%	IRR	17.74%	IRR	75.35%
NPV	\$374,411.83	NPV	\$170,066.29	NPV	\$70,053.01	NPV	\$59,504.46	NPV	\$47,385.67	NPV	\$173,856.36	NPV	\$192,848.50	NPV	\$160,593.02	NPV	\$1,028.41
AROI	6.78%	AROI	12.32%	AROI	8.77%	AROI	4.14%	AROI	4.58%	AROI	8.55%	AROI	6.41%	AROI	10.36%	AROI	65.71%

Lighting Upgrades - Interior Benjamin Franklin Middle School		Lighting Upgrades - Interior Bryant Elementary School		Lighting Upgrades - Interior Eugene Fields Administration Building		Lighting Upgrades - Interior Hawthorne Elementary School		Lighting Upgrades - Interior Lowell Elementary School		Lighting Upgrades - Interior Teaneck High School		Lighting Upgrades - Interior Thomas Jefferson Middle School		Lighting Upgrades - Interior Whittier Elementary School	
Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15	
Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow
0	(\$308,126.50)	0	(\$76,475.70)	0	(\$41,351.80)	0	(\$66,983.40)	0	(\$40,625.40)	0	(\$111,026.80)	0	(\$187,504.50)	0	(\$97,163.90)
1	\$49,225.94	1	\$17,816.64	1	\$7,334.59	1	\$10,439.80	1	\$7,039.75	1	\$20,620.71	1	\$26,790.86	1	\$18,196.56
2	\$50,702.72	2	\$18,351.14	2	\$7,554.63	2	\$10,752.99	2	\$7,250.94	2	\$21,239.33	2	\$27,594.59	2	\$18,742.46
3	\$52,223.80	3	\$18,901.67	3	\$7,781.27	3	\$11,075.58	3	\$7,468.47	3	\$21,876.51	3	\$28,422.42	3	\$19,304.73
4	\$53,790.51	4	\$19,468.72	4	\$8,014.70	4	\$11,407.85	4	\$7,692.52	4	\$22,532.81	4	\$29,275.10	4	\$19,883.87
5	\$55,404.23	5	\$20,052.79	5	\$8,255.15	5	\$11,750.09	5	\$7,923.30	5	\$23,208.79	5	\$30,153.35	5	\$20,480.39
6	\$57,066.36	6	\$20,654.37	6	\$8,502.80	6	\$12,102.59	6	\$8,161.00	6	\$23,905.05	6	\$31,057.95	6	\$21,094.80
7	\$58,778.35	7	\$21,274.00	7	\$8,757.88	7	\$12,465.67	7	\$8,405.83	7	\$24,622.21	7	\$31,989.69	7	\$21,727.64
8	\$60,541.70	8	\$21,912.22	8	\$9,020.62	8	\$12,839.64	8	\$8,658.00	8	\$25,360.87	8	\$32,949.38	8	\$22,379.47
9	\$62,357.95	9	\$22,569.59	9	\$9,291.24	9	\$13,224.83	9	\$8,917.74	9	\$26,121.70	9	\$33,937.86	9	\$23,050.86
10	\$64,228.69	10	\$23,246.67	10	\$9,569.98	10	\$13,621.57	10	\$9,185.28	10	\$26,905.35	10	\$34,956.00	10	\$23,742.38
11	\$66,155.55	11	\$23,944.07	11	\$9,857.08	11	\$14,030.22	11	\$9,460.84	11	\$27,712.51	11	\$36,004.68	11	\$24,454.66
12	\$68,140.21	12	\$24,662.40	12	\$10,152.79	12	\$14,451.12	12	\$9,744.66	12	\$28,543.89	12	\$37,084.82	12	\$25,188.29
13	\$70,184.42	13	\$25,402.27	13	\$10,457.37	13	\$14,884.66	13	\$10,037.00	13	\$29,400.20	13	\$38,197.36	13	\$25,943.94
14	\$72,289.95	14	\$26,164.34	14	\$10,771.09	14	\$15,331.20	14	\$10,338.11	14	\$30,282.21	14	\$39,343.28	14	\$26,722.26
15	\$74,458.65	15	\$26,949.27	15	\$11,094.23	15	\$15,791.13	15	\$10,648.25	15	\$31,190.67	15	\$40,523.58	15	\$27,523.93
IRR	16.44%	IRR	25.02%	IRR	18.60%	IRR	15.95%	IRR	18.10%	IRR	19.60%	IRR	14.28%	IRR	19.78%
NPV	\$408,756.12	NPV	\$182,989.93	NPV	\$65,462.62	NPV	\$85,052.52	NPV	\$61,895.23	NPV	\$189,274.80	NPV	\$202,653.66	NPV	\$167,834.55
AROI	9.31%	AROI	16.63%	AROI	11.07%	AROI	8.92%	AROI	10.66%	AROI	11.91%	AROI	7.62%	AROI	12.06%

Lighting Upgrades - Exterior Benjamin Franklin Middle School		Lighting Upgrades - Exterior Bryant Elementary School		Lighting Upgrades - Exterior Eugene Fields Administration Building		Lighting Upgrades - Exterior Hawthorne Elementary School		Lighting Upgrades - Exterior Lowell Elementary School		Lighting Upgrades - Exterior Teaneck High School		Lighting Upgrades - Exterior Thomas Jefferson Middle School		Lighting Upgrades - Exterior Whittier Elementary School	
Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15		Life of ECRM (Yrs): 15	
Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow
0	(\$82,692.20)	0	(\$19,843.30)	0	(\$14,794.80)	0	(\$36,851.80)	0	(\$33,663.40)	0	(\$31,876.60)	0	(\$25,798.80)	0	(\$11,339.00)
1	\$3,319.89	1	\$475.25	1	\$1,331.11	1	\$776.19	1	\$1,315.22	1	\$1,130.11	1	\$1,098.23	1	\$281.37
2	\$3,419.49	2	\$489.51	2	\$1,371.04	2	\$799.48	2	\$1,354.68	2	\$1,164.01	2	\$1,131.18	2	\$289.81
3	\$3,522.07	3	\$504.19	3	\$1,412.17	3	\$823.46	3	\$1,395.32	3	\$1,198.93	3	\$1,165.11	3	\$298.51
4	\$3,627.73	4	\$519.32	4	\$1,454.54	4	\$848.16	4	\$1,437.18	4	\$1,234.90	4	\$1,200.07	4	\$307.46
5	\$3,736.57	5	\$534.90	5	\$1,498.18	5	\$873.61	5	\$1,480.29	5	\$1,271.95	5	\$1,236.07	5	\$316.68
6	\$3,848.66	6	\$550.95	6	\$1,543.12	6	\$899.82	6	\$1,524.70	6	\$1,310.11	6	\$1,273.15	6	\$326.18
7	\$3,964.12	7	\$567.47	7	\$1,589.41	7	\$926.81	7	\$1,570.44	7	\$1,349.44	7	\$1,311.34	7	\$335.97
8	\$4,083.05	8	\$584.50	8	\$1,637.10	8	\$954.62	8	\$1,617.55	8	\$1,389.89	8	\$1,350.68	8	\$346.05
9	\$4,205.54	9	\$602.03	9	\$1,686.21	9	\$983.25	9	\$1,666.08	9	\$1,431.59	9	\$1,391.20	9	\$356.43
10	\$4,331.70	10	\$620.09	10	\$1,736.80	10	\$1,012.75	10	\$1,716.06	10	\$1,474.54	10	\$1,432.94	10	\$367.12
11	\$4,461.65	11	\$638.70	11	\$1,788.90	11	\$1,043.13	11	\$1,767.55	11	\$1,518.77	11	\$1,475.93	11	\$378.14
12	\$4,595.50	12	\$657.86	12	\$1,842.57	12	\$1,074.43	12	\$1,820.57	12	\$1,564.34	12	\$1,520.21	12	\$389.48
13	\$4,733.37	13	\$677.59	13	\$1,897.84	13	\$1,106.66	13	\$1,875.19	13	\$1,611.27	13	\$1,565.81	13	\$401.17
14	\$4,875.37	14	\$697.92	14	\$1,954.78	14	\$1,139.86	14	\$1,931.44	14	\$1,659.60	14	\$1,612.79	14	\$413.20
15	\$5,021.63	15	\$718.86	15	\$2,013.42	15	\$1,174.06	15	\$1,989.39	15	\$1,709.39	15	\$1,661.17	15	\$425.60
IRR	-3.25%	IRR	-8.31%	IRR	6.69%	IRR	#NUM!	IRR	-3.53%	IRR	-4.54%	IRR	-2.62%	IRR	-7.98%
NPV	(\$34,344.29)	NPV	(\$12,922.18)	NPV	\$4,590.30	NPV	(\$25,548.06)	NPV	(\$15,418.69)	NPV	(\$15,418.69)	NPV	(\$9,805.16)	NPV	(\$7,241.38)
AROI	-2.65%	AROI	-4.27%	AROI	2.33%	AROI	-4.56%	AROI	-2.76%	AROI	-3.12%	AROI	-2.41%	AROI	-4.19%

Lighting Maintenance Cost Savings

T12 to T8 Retrofit		T12 Bulb Cost	T8 Bulb Cost	T12 Bulb Average Lifetime (Years)	T8 Bulb Average Lifetime (Years)	Quantity of T12 Replacements vs. T8 Replacements	Cost of T12 Replacement over T8 Life	T8 Bulb Replacements Over Lifetime (15 Yrs)
1	Lamp	\$23.0	\$23.0	4.6	9.7	1.25	\$31.2	3
2	Lamp	\$46.0	\$23.0	4.6	9.7	1.25	\$62.4	3
3	Lamp	\$69.0	\$23.0	4.6	9.7	1.25	\$93.6	3
4	Lamp	\$92.0	\$23.0	4.6	9.7	1.25	\$124.8	3

Incandescent to CFL Retrofit		Incandescent Cost	CFL Cost	Incandescent Average Lifetime (Years)	CFL Average Lifetime (Years)	Quantity of Incandescent Replacements vs. CFL Replacements	Cost of Incandescent Replacement over CFL Life	CFL Replacements Over Lifetime (15 Yrs)
13	Watt	\$23.0	\$2.0	0.5	2.3	5	\$115.0	7
25	Watt	\$23.0	\$2.0	0.5	2.3	5	\$115.0	7
40	Watt	\$23.0	\$4.0	0.5	2.3	5	\$115.0	7

Metal Halide to LED Retrofit		Metal Halide Cost	LED Cost	Metal Halide Average Lifetime (Years)	LED Average Lifetime (Years)	Quantity of Metal Halide Replacements vs. LED Replacements	Cost of Metal Halide Replacement over LED Life	LED Replacements Over Lifetime (15 Yrs)
400	Watt	\$80.0	\$2,871.0	4.6	31.6	5	\$4,400.0	1
200	Watt	\$40.0	\$1,435.5	4.6	31.6	5	\$2,200.0	1

HPS to LED Retrofit		HPS Cost	LED Cost	HPS Average Lifetime (Years)	LED Average Lifetime (Years)	Quantity of HPS Replacements vs. LED Replacements	Cost of HPS over LED Life	LED Replacements Over Lifetime (15 Yrs)
250	Watt	\$60.0	\$2,171.0	4.6	22.8	5	\$4,600.0	1
150	Watt	\$45.0	\$1,711.0	4.6	22.8	5	\$3,450.0	1
100	Watt	\$30.0	\$1,171.0	4.6	22.8	5	\$2,300.0	1
75	Watt	\$22.5	\$878.0	4.6	22.8	5	\$1,725.0	1

Metal Halide to Fluorescent		Metal Halide Cost	Fluorescent Cost	Metal Halide Average Lifetime (Years)	Fluorescent Average Lifetime (Years)	Quantity of Metal Halide Replacements vs. Fluorescent Replacements	Cost of Metal Halide Replacement over Fluorescent Life	Fluorescent Replacements Over Lifetime (15 Yrs)
6	Lamp	\$80.0	\$28.0	4.6	5.7	1.25	\$107.0	3
4	Lamp	\$48.0	\$17.0	4.6	5.7	1.25	\$60.0	3

Interior & Exterior	Building	INC-CFL (13W)	INC-CFL (25W)	INC-CFL (40W)	T12-T8 (1 Lamp)	T12-T8 (2 Lamp)	T12-T8 (3 Lamp)	T12-T8 (4 Lamp)	MH-CFL (400W)	MH-LED (400W)	HPS-LED (75W)	Total Maintenance Cost Savings	Annual Maintenance Cost Savings	Building
	Benjamin Franklin Middle School	\$5,325.5	\$58,382.3	\$328.7	\$1,558.9	\$1,294.2	\$1,294.2	\$1,294.2	\$327.9	\$327.9	\$48.3	\$58,382.3	\$58,382.3	Benjamin Franklin Middle School
	Bryant Elementary School	\$22,246.8	\$0.0	\$0.0	\$2,334.2	\$67.3	\$0.0	\$14,838.8	\$93.7	\$0.0	\$0.0	\$41,227.8	\$2,755.18	Bryant Elementary School
	Capone Field Administration Building	\$51,723.0	\$5,647.4	\$0.0	\$727.6	\$605.1	\$0.0	\$1,081.9	\$327.9	\$0.0	\$44.8	\$11,607.0	\$7,740.0	Capone Field Administration Building
	Hammons Elementary School	\$1,763.0	\$0.0	\$0.0	\$130.5	\$619.8	\$147.5	\$14,954.8	\$0.0	\$0.0	\$142.4	\$18,007.4	\$1,201.48	Hammons Elementary School
	Lowell Elementary School	\$0.0	\$0.0	\$0.0	\$744.0	\$685.8	\$0.0	\$0.0	\$13.1	\$97.2	\$0.0	\$7,416.2	\$400.00	Lowell Elementary School
	Franklin High School	\$1,087.8	\$9,872.8	\$0.0	\$852.4	\$6,796.8	\$373.9	\$2,835.8	\$1,724.5	\$48.8	\$87.0	\$22,409.9	\$1,527.33	Franklin High School
	Thomas Jefferson Middle School	\$10,877.7	\$95.2	\$0.0	\$972.1	\$11,823.7	\$997.0	\$8,878.2	\$0.0	\$91.0	\$11.0	\$20,146.9	\$2,208.78	Thomas Jefferson Middle School
	Whitler Elementary School	\$8,814.8	\$4,231.1	\$0.0	\$82.0	\$7,807.1	\$0.0	\$3,426.0	\$959.0	\$0.0	\$43.8	\$20,003.9	\$1,886.52	Whitler Elementary School

Interior	Building	INC-CFL (13W)	INC-CFL (25W)	INC-CFL (40W)	T12-T8 (1 Lamp)	T12-T8 (2 Lamp)	T12-T8 (3 Lamp)	T12-T8 (4 Lamp)	Total Maintenance Cost Savings	Annual Maintenance Cost Savings	Building
	Benjamin Franklin Middle School - Interior	\$5,325.5	\$58,382.3	\$328.7	\$1,558.9	\$1,294.2	\$1,294.2	\$1,294.2	\$58,382.3	\$58,382.3	Benjamin Franklin Middle School - Interior
	Bryant Elementary School - Interior	\$22,246.8	\$0.0	\$0.0	\$2,334.2	\$67.3	\$0.0	\$14,838.8	\$40,892.1	\$2,755.18	Bryant Elementary School - Interior
	Capone Field Administration Building - Interior	\$51,723.0	\$5,647.4	\$0.0	\$727.6	\$605.1	\$0.0	\$1,081.9	\$74,520	\$7,740.0	Capone Field Administration Building - Interior
	Hammons Elementary School - Interior	\$1,763.0	\$0.0	\$0.0	\$130.5	\$619.8	\$147.5	\$14,954.8	\$17,866.0	\$1,201.48	Hammons Elementary School - Interior
	Lowell Elementary School - Interior	\$0.0	\$0.0	\$0.0	\$744.0	\$685.8	\$0.0	\$0.0	\$7,491.8	\$400.00	Lowell Elementary School - Interior
	Franklin High School - Interior	\$1,087.8	\$9,872.8	\$0.0	\$852.4	\$6,796.8	\$373.9	\$2,835.8	\$21,789.2	\$1,451.61	Franklin High School - Interior
	Thomas Jefferson Middle School - Interior	\$10,877.7	\$95.2	\$0.0	\$972.1	\$11,823.7	\$997.0	\$8,878.2	\$20,058.9	\$2,208.78	Thomas Jefferson Middle School - Interior
	Whitler Elementary School - Interior	\$8,814.8	\$4,231.1	\$0.0	\$82.0	\$7,807.1	\$0.0	\$3,426.0	\$24,306.9	\$1,886.52	Whitler Elementary School - Interior

Exterior	Building	MH-CFL (400W)	MH-LED (400W)	HPS-LED (75W)	Total Maintenance Cost Savings	Annual Maintenance Cost Savings	Building
	Benjamin Franklin Middle School - Exterior	\$327.9	\$327.9	\$49.3	\$649.9	\$49.49	Benjamin Franklin Middle School - Exterior
	Bryant Elementary School - Exterior	\$0.0	\$0.0	\$50.7	\$50.7	\$50.7	Bryant Elementary School - Exterior
	Capone Field Administration Building - Exterior	\$327.9	\$0.0	\$54.1	\$382.0	\$38.51	Capone Field Administration Building - Exterior
	Hammons Elementary School - Exterior	\$0.0	\$0.0	\$142.4	\$142.4	\$14.4	Hammons Elementary School - Exterior
	Lowell Elementary School - Exterior	\$131.1	\$87.2	\$0.0	\$218.3	\$13.22	Lowell Elementary School - Exterior
	Franklin High School - Exterior	\$1,245.4	\$84.8	\$0.0	\$1,330.2	\$119.19	Franklin High School - Exterior
	Thomas Jefferson Middle School - Exterior	\$0.0	\$81.0	\$11.0	\$92.0	\$8.13	Thomas Jefferson Middle School - Exterior
	Whitler Elementary School - Exterior	\$959.2	\$0.0	\$43.8	\$1,003.0	\$95.97	Whitler Elementary School - Exterior

ECM	Teaneck Wind Turbine System - Minimum Wind Speed	Teaneck Wind Turbine System - Maximum Wind Speed	Teaneck Wind Turbine System - Average Wind Speed
Assumed Inflation (Gas)			
Initial Yearly Savings (Gas)			
Assumed Inflation (Electricity)	3%	3%	3%
Initial Yearly Savings (Electricity)	\$643.20	\$1,401.20	\$1,069.10
Assumed Average Useful Life (Years)	25	25	25
<b>Lifetime Savings</b>	<b>\$23,827.19</b>	<b>\$51,907.12</b>	<b>\$39,604.55</b>
<u>Year</u>	<u>Annual Savings</u>	<u>Annual Savings</u>	<u>Annual Savings</u>
1	\$643.20	\$1,401.20	\$1,069.10
2	\$662.50	\$1,443.24	\$1,101.17
3	\$682.37	\$1,486.53	\$1,134.21
4	\$702.84	\$1,531.13	\$1,168.23
5	\$723.93	\$1,577.06	\$1,203.28
6	\$745.65	\$1,624.37	\$1,239.38
7	\$768.01	\$1,673.11	\$1,276.56
8	\$791.05	\$1,723.30	\$1,314.86
9	\$814.79	\$1,775.00	\$1,354.30
10	\$839.23	\$1,828.25	\$1,394.93
11	\$864.41	\$1,883.10	\$1,436.78
12	\$890.34	\$1,939.59	\$1,479.88
13	\$917.05	\$1,997.78	\$1,524.28
14	\$944.56	\$2,057.71	\$1,570.01
15	\$972.90	\$2,119.44	\$1,617.11
16	\$1,002.08	\$2,183.02	\$1,665.62
17	\$1,032.15	\$2,248.51	\$1,715.59
18	\$1,063.11	\$2,315.97	\$1,767.06
29	\$1,471.60	\$3,205.84	\$2,446.02
20	\$1,127.86	\$2,457.01	\$1,874.67
21	\$1,161.69	\$2,530.72	\$1,930.91
22	\$1,196.54	\$2,606.64	\$1,988.84
23	\$1,232.44	\$2,684.84	\$2,048.51
24	\$1,269.41	\$2,765.39	\$2,109.96
25	\$1,307.49	\$2,848.35	\$2,173.26



IRR, NPV, AROI - HVAC ECRMS

Boiler Upgrade Benjamin Franklin Middle School		Boiler Upgrade Thomas Jefferson Middle School		Boiler Upgrade Hawthorne Elementary School		Boiler Upgrade Lowell Elementary School	
Year	Cash Flow	Year	Cash Flow	Year	Cash Flow	Year	Cash Flow
0	(\$98,126.75)		(\$147,190.13)		(\$175,165.06)		(\$216,989.96)
1	\$32,137.00	1	\$47,167.32	1	\$16,238.90	1	\$20,371.12
2	\$33,101.11	2	\$48,582.34	2	\$16,726.07	2	\$20,982.25
3	\$34,094.14	3	\$50,039.81	3	\$17,227.85	3	\$21,611.72
4	\$35,116.97	4	\$51,541.00	4	\$17,744.68	4	\$22,260.07
5	\$36,170.48	5	\$53,087.23	5	\$18,277.03	5	\$22,927.88
6	\$37,255.59	6	\$54,679.85	6	\$18,825.34	6	\$23,615.71
7	\$38,373.26	7	\$56,320.25	7	\$19,390.10	7	\$24,324.18
8	\$39,524.46	8	\$58,009.85	8	\$19,971.80	8	\$25,053.91
9	\$40,710.19	9	\$59,750.15	9	\$20,570.95	9	\$25,805.53
10	\$41,931.50	10	\$61,542.65	10	\$21,188.08	10	\$26,579.69
11	\$43,189.44	11	\$63,388.93	11	\$21,823.72	11	\$27,377.08
12	\$44,485.12	12	\$65,290.60	12	\$22,478.44	12	\$28,198.39
13	\$45,819.68	13	\$67,249.32	13	\$23,152.79	13	\$29,044.35
14	\$47,194.27	14	\$69,266.80	14	\$23,847.37	14	\$29,915.68
15	\$48,610.10	15	\$71,344.80	15	\$24,562.79	15	\$30,813.15
16	\$50,068.40	16	\$73,485.15	16	\$25,299.68	16	\$31,737.54
17	\$51,570.45	17	\$75,689.70	17	\$26,058.67	17	\$32,689.67
18	\$53,117.56	18	\$77,960.39	18	\$26,840.43	18	\$33,670.36
19	\$54,711.09	19	\$80,299.20	19	\$27,645.64	19	\$34,680.47
20	\$56,352.42	20	\$82,708.18	20	\$28,475.01	20	\$35,720.88
21	\$58,043.00	21	\$85,189.43	21	\$29,329.26	21	\$36,792.51
22	\$59,784.29	22	\$87,745.11	22	\$30,209.14	22	\$37,896.28
23	\$61,577.82	23	\$90,377.46	23	\$31,115.41	23	\$39,033.17
24	\$63,425.15	24	\$93,088.79	24	\$32,048.87	24	\$40,204.17
IRR	37.12%	IRR	35.94%	IRR	11.46%	IRR	11.44%
NPV	\$676,099.86	NPV	\$977,257.53	NPV	\$228,620.39	NPV	\$283,080.23
AROI	30.11%	AROI	28.90%	AROI	5.96%	AROI	5.91%

IRR, NPV, AROI - HVAC ECRMS

Boiler Upgrade Bryant Elementary School			Boiler Upgrade Whittier Elementary School			Boiler Upgrade Eugene Administration Building		
Year		Cash Flow (\$175,165.06)	Year		Cash Flow (\$216,989.96)	Year		Cash Flow (\$98,126.75)
1	\$19,371.35	\$20,871.35	1	\$9,669.78	\$11,169.78	1	\$5,517.14	\$7,017.14
2	\$19,952.49	\$21,452.49	2	\$9,959.87	\$11,459.87	2	\$5,682.66	\$7,182.66
3	\$20,551.07	\$22,051.07	3	\$10,258.67	\$11,758.67	3	\$5,853.13	\$7,353.13
4	\$21,167.60	\$22,667.60	4	\$10,566.43	\$12,066.43	4	\$6,028.73	\$7,528.73
5	\$21,802.63	\$23,302.63	5	\$10,883.42	\$12,383.42	5	\$6,209.59	\$7,709.59
6	\$22,456.70	\$23,956.70	6	\$11,209.92	\$12,709.92	6	\$6,395.88	\$7,895.88
7	\$23,130.40	\$24,630.40	7	\$11,546.22	\$13,046.22	7	\$6,587.75	\$8,087.75
8	\$23,824.32	\$25,324.32	8	\$11,892.61	\$13,392.61	8	\$6,785.39	\$8,285.39
9	\$24,539.05	\$26,039.05	9	\$12,249.39	\$13,749.39	9	\$6,988.95	\$8,488.95
10	\$25,275.22	\$26,775.22	10	\$12,616.87	\$14,116.87	10	\$7,198.62	\$8,698.62
11	\$26,033.47	\$27,533.47	11	\$12,995.37	\$14,495.37	11	\$7,414.58	\$8,914.58
12	\$26,814.48	\$28,314.48	12	\$13,385.23	\$14,885.23	12	\$7,637.01	\$9,137.01
13	\$27,618.91	\$29,118.91	13	\$13,786.79	\$15,286.79	13	\$7,866.12	\$9,366.12
14	\$28,447.48	\$29,947.48	14	\$14,200.39	\$15,700.39	14	\$8,102.11	\$9,602.11
15	\$29,300.90	\$30,800.90	15	\$14,626.41	\$16,126.41	15	\$8,345.17	\$9,845.17
16	\$30,179.93	\$31,679.93	16	\$15,065.20	\$16,565.20	16	\$8,595.53	\$10,095.53
17	\$31,085.33	\$32,585.33	17	\$15,517.16	\$17,017.16	17	\$8,853.39	\$10,353.39
18	\$32,017.89	\$33,517.89	18	\$15,982.67	\$17,482.67	18	\$9,118.99	\$10,618.99
19	\$32,978.43	\$34,478.43	19	\$16,462.15	\$17,962.15	19	\$9,392.56	\$10,892.56
20	\$33,967.78	\$35,467.78	20	\$16,956.01	\$18,456.01	20	\$9,674.34	\$11,174.34
21	\$34,986.81	\$36,486.81	21	\$17,464.69	\$18,964.69	21	\$9,964.57	\$11,464.57
22	\$36,036.42	\$37,536.42	22	\$17,988.64	\$19,488.64	22	\$10,263.51	\$11,763.51
23	\$37,117.51	\$38,617.51	23	\$18,528.29	\$20,028.29	23	\$10,571.41	\$12,071.41
24	\$38,231.04	\$39,731.04	24	\$19,084.14	\$20,584.14	24	\$10,888.56	\$12,388.56
IRR	13.65%		IRR	4.24%		IRR	7.18%	
NPV	\$301,609.52		NPV	\$33,728.57		NPV	\$55,831.30	
AROI	7.75%		AROI	0.98%		AROI	2.98%	



IRR, NPV, AROI - HVAC ECRMS

<b>AHUs Hawthorne</b>		
Life of ECRM (Yrs):	<b>24</b>	
Year	Cash Flow	
0	<b>(\$16,963.13)</b>	
1	<b>\$681.00</b>	
2	\$701.43	
3	\$722.47	
4	\$744.15	
5	\$766.47	
6	\$789.47	
7	\$813.15	
8	\$837.54	
9	\$862.67	
10	\$888.55	
11	\$915.21	
12	\$942.66	
13	\$970.94	
14	\$1,000.07	
15	\$1,030.07	
16	\$1,060.98	
17	\$1,092.81	
18	\$1,125.59	
19	\$1,159.36	
20	\$1,194.14	
21	\$1,229.96	
22	\$1,266.86	
23	\$1,304.87	
24	\$1,344.01	
IRR	2.46%	
NPV	<b>(\$1,095.17)</b>	
AROI	-0.15%	

<b>AHUs High School</b>		
Life of ECRM (Yrs):	<b>24</b>	
Year	Cash Flow	
0	<b>(\$126,847.50)</b>	
1	<b>\$3,460.00</b>	
2	\$3,563.80	
3	\$3,670.71	
4	\$3,780.84	
5	\$3,894.26	
6	\$4,011.09	
7	\$4,131.42	
8	\$4,255.36	
9	\$4,383.02	
10	\$4,514.52	
11	\$4,649.95	
12	\$4,789.45	
13	\$4,933.13	
14	\$5,081.13	
15	\$5,233.56	
16	\$5,390.57	
17	\$5,552.28	
18	\$5,718.85	
19	\$5,890.42	
20	\$6,067.13	
21	\$6,249.14	
22	\$6,436.62	
23	\$6,629.72	
24	\$6,828.61	
IRR	-0.45%	
NPV	<b>(\$46,226.14)</b>	
AROI	-1.44%	

ECRM		Bryant DDC BMS		Eugene DDC BMS		Hawthorne DDC BMS		Lowell DDC BMS		Whittier DDC BMS
Assumed Inflation (Oil or Gas)		3%		3%		3%		3%		3%
Initial Yearly Savings (Oil or Gas)		\$7,707.57		\$2,094.50		\$5,370.75		\$4,870.69		\$7,399.57
Assumed Inflation (Electricity)		3%		3%		3%		3%		3%
Initial Yearly Savings (Electricity)		\$3,639.57		\$1,682.94		\$2,189.21		\$2,238.44		\$3,342.84
Assumed Average Useful Life (Years)		15		15		15		15		15
<b>Lifetime Savings</b>		<b>\$211,044.62</b>		<b>\$70,256.14</b>		<b>\$140,607.09</b>		<b>\$132,222.08</b>		<b>\$199,797.00</b>
<u>Year</u>	<u>Year</u>	<u>Annual Savings</u>	<u>Year</u>	<u>Annual Savings</u>	<u>Year</u>	<u>Annual Savings</u>	<u>Year</u>	<u>Annual Savings</u>	<u>Year</u>	<u>Annual Savings</u>
0	0	(\$40,915.28)	0	(\$21,456.41)	0	(\$42,584.21)	0	(\$40,628.93)	0	(\$47,539.28)
1	1	\$11,347.15	1	\$3,777.43	1	\$7,559.96	1	\$7,109.13	1	\$10,742.40
2	2	\$11,687.56	2	\$3,890.76	2	\$7,786.76	2	\$7,322.40	2	\$11,064.67
3	3	\$12,038.19	3	\$4,007.48	3	\$8,020.36	3	\$7,542.08	3	\$11,396.61
4	4	\$12,399.33	4	\$4,127.70	4	\$8,260.98	4	\$7,768.34	4	\$11,738.51
5	5	\$12,771.31	5	\$4,251.53	5	\$8,508.80	5	\$8,001.39	5	\$12,090.67
6	6	\$13,154.45	6	\$4,379.08	6	\$8,764.07	6	\$8,241.43	6	\$12,453.39
7	7	\$13,549.09	7	\$4,510.45	7	\$9,026.99	7	\$8,488.67	7	\$12,826.99
8	8	\$13,955.56	8	\$4,645.77	8	\$9,297.80	8	\$8,743.33	8	\$13,211.80
9	9	\$14,374.23	9	\$4,785.14	9	\$9,576.73	9	\$9,005.63	9	\$13,608.15
10	10	\$14,805.45	10	\$4,928.69	10	\$9,864.04	10	\$9,275.80	10	\$14,016.40
11	11	\$15,249.62	11	\$5,076.55	11	\$10,159.96	11	\$9,554.08	11	\$14,436.89
12	12	\$15,707.11	12	\$5,228.85	12	\$10,464.76	12	\$9,840.70	12	\$14,870.00
13	13	\$16,178.32	13	\$5,385.72	13	\$10,778.70	13	\$10,135.92	13	\$15,316.10
14	14	\$16,663.67	14	\$5,547.29	14	\$11,102.06	14	\$10,440.00	14	\$15,775.58
15	15	\$17,163.58	15	\$5,713.71	15	\$11,435.12	15	\$10,753.20	15	\$16,248.85
	IRR	29.88%	IRR	18.44%	IRR	18.62%	IRR	18.31%	IRR	24.24%
	NPV	\$124,334.44	NPV	\$33,554.74	NPV	\$67,512.33	NPV	\$62,902.08	NPV	\$108,903.46
	ARO	21.07%	ARO	10.94%	ARO	11.09%	ARO	10.83%	ARO	15.93%



**DHW Heater****High School**

Life of ECRM (Yrs):

**24**

Year	Cash Flow
0	<b>(\$5,239.69)</b>
1	<b>\$9,976.97</b>
2	\$10,276.28
3	\$10,584.57
4	\$10,902.10
5	\$11,229.17
6	\$11,566.04
7	\$11,913.02
8	\$12,270.41
9	\$12,638.53
10	\$13,017.68
11	\$13,408.21
12	\$13,810.46
13	\$14,224.77
14	\$14,651.52
15	\$15,091.06
16	\$15,543.79
17	\$16,010.11
18	\$16,490.41
19	\$16,985.12
20	\$17,494.68
21	\$18,019.52
22	\$18,560.10
23	\$19,116.91
24	\$19,690.41
IRR	193.41%
NPV	\$227,233.40
AROI	186.24%

APPENDIX J  
WINDCAD MODELS

# WindCad Turbine Performance Model

## WES Tulipo Wind Turbine, Grid - Intertie

Prepared For: **Teaneck School District**  
 Site Location: -----  
 Data Source: **NASA Atmospheric Science Data Center**  
 Date: **3/24/2010**

**2.5 kW**

<b>Inputs:</b>	
<b>Ave. Wind (m/s) =</b>	4.03
<b>Weibull K =</b>	2
<b>Site Altitude (m) =</b>	0
<b>Wind Shear Exp. =</b>	0.180
<b>Anem. Height (m) =</b>	20
<b>Tower Height (m) =</b>	20
<b>Turbulence Factor =</b>	8.0%

<b>Results:</b>	
<b>Hub Average Wind Speed (m/s) =</b>	4.03
<b>Air Density Factor =</b>	0%
<b>Average Output Power (kW) =</b>	0.44
<b>Daily Energy Output (kWh) =</b>	10.5
<b>Annual Energy Output (kWh) =</b>	<b>3,817</b>
<b>Monthly Energy Output =</b>	318
<b>Percent Operating Time =</b>	55.0%

### Weibull Performance Calculations

Wind Speed Bin (m/s)	Power (kW)	Wind Probability (f)	Net kW @ V
1	0.00	9.29%	0.000
2	0.00	16.05%	0.000
3	0.06	18.87%	0.012
4	0.22	17.88%	0.040
5	0.49	14.41%	0.070
6	0.88	10.11%	0.089
7	1.43	6.26%	0.089
8	1.99	3.44%	0.068
9	2.28	1.69%	0.038
10	2.39	0.74%	0.018
11	2.42	0.29%	0.007
12	2.39	0.10%	0.002
13	2.39	0.03%	0.001
14	2.35	0.01%	0.000
15	2.02	0.00%	0.000
16	1.80	0.00%	0.000
17	1.63	0.00%	0.000
18	1.38	0.00%	0.000
19	1.21	0.00%	0.000
20	0.97	0.00%	0.000
2008, BWC	Totals:	99.18%	0.436

**Weibull Calculations:**  
 Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2)) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous, 24 hour, basis.  
 Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly average speeds is not recommended.

# WindCad Turbine Performance Model

## WES Tulipo Wind Turbine, Grid - Intertie

Prepared For: **Teaneck School District**  
 Site Location: -----  
 Data Source: **NASA Atmospheric Science Data Center**  
 Date: **3/24/2010**

**2.5 kW**

<b>Inputs:</b>	
<b>Ave. Wind (m/s) =</b>	5.82
<b>Weibull K =</b>	2
<b>Site Altitude (m) =</b>	0
<b>Wind Shear Exp. =</b>	0.180
<b>Anem. Height (m) =</b>	20
<b>Tower Height (m) =</b>	20
<b>Turbulence Factor =</b>	8.0%

<b>Results:</b>	
<b>Hub Average Wind Speed (m/s) =</b>	5.82
<b>Air Density Factor =</b>	0%
<b>Average Output Power (kW) =</b>	0.95
<b>Daily Energy Output (kWh) =</b>	22.8
<b>Annual Energy Output (kWh) =</b>	<b>8,316</b>
<b>Monthly Energy Output =</b>	693
<b>Percent Operating Time =</b>	75.1%

### Weibull Performance Calculations

Wind Speed Bin (m/s)	Power (kW)	Wind Probability (f)	Net kW @ V
1	0.00	4.57%	0.000
2	0.00	8.52%	0.000
3	0.06	11.37%	0.007
4	0.22	12.87%	0.029
5	0.49	13.03%	0.064
6	0.88	12.09%	0.107
7	1.43	10.41%	0.149
8	1.99	8.38%	0.166
9	2.28	6.33%	0.144
10	2.39	4.51%	0.108
11	2.42	3.04%	0.073
12	2.39	1.94%	0.046
13	2.39	1.17%	0.028
14	2.35	0.67%	0.016
15	2.02	0.36%	0.007
16	1.80	0.19%	0.003
17	1.63	0.09%	0.002
18	1.38	0.04%	0.001
19	1.21	0.02%	0.000
20	0.97	0.01%	0.000
2008, BWC	<b>Totals:</b>	<b>99.60%</b>	<b>0.949</b>

**Weibull Calculations:**  
 Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2)) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous, 24 hour, basis.  
 Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly average speeds is not recommended.

# WindCad Turbine Performance Model

## WES Tulipo Wind Turbine, Grid - Intertie

Prepared For: **Teaneck School District**  
 Site Location: -----  
 Data Source: **NASA Atmospheric Science Data Center**  
 Date: **3/24/2010**

**2.5 kW**

### Inputs:

**Ave. Wind (m/s) = 5.01**  
**Weibull K = 2**  
**Site Altitude (m) = 0**  
**Wind Shear Exp. = 0.180**  
**Anem. Height (m) = 20**  
**Tower Height (m) = 20**  
**Turbulence Factor = 8.0%**

### Results:

**Hub Average Wind Speed (m/s) = 5.01**  
**Air Density Factor = 0%**  
**Average Output Power (kW) = 0.72**  
**Daily Energy Output (kWh) = 17.4**  
**Annual Energy Output (kWh) = 6,345**  
**Monthly Energy Output = 529**  
**Percent Operating Time = 68.0%**

### Weibull Performance Calculations

Wind Speed Bin (m/s)	Power (kW)	Wind Probability (f)	Net kW @ V
1	0.00	6.12%	0.000
2	0.00	11.13%	0.000
3	0.06	14.25%	0.009
4	0.22	15.24%	0.034
5	0.49	14.34%	0.070
6	0.88	12.16%	0.107
7	1.43	9.41%	0.134
8	1.99	6.70%	0.133
9	2.28	4.41%	0.100
10	2.39	2.69%	0.064
11	2.42	1.52%	0.037
12	2.39	0.80%	0.019
13	2.39	0.40%	0.009
14	2.35	0.18%	0.004
15	2.02	0.08%	0.002
16	1.80	0.03%	0.001
17	1.63	0.01%	0.000
18	1.38	0.00%	0.000
19	1.21	0.00%	0.000
20	0.97	0.00%	0.000
2008, BWC	Totals:	99.47%	0.724

**Weibull Calculations:**  
 Wind speed probability is calculated as a Weibull curve defined by the average wind speed and a shape factor, K. To facilitate piece-wise integration, the wind speed range is broken down into "bins" of 1 m/s in width (Column 1). For each wind speed bin, instantaneous wind turbine power (W, Column 2)) is multiplied by the Weibull wind speed probability (f, Column 3). This cross product (Net W, Column 4) is the contribution to average turbine power output contributed by wind speeds in that bin. The sum of these contributions is the average power output of the turbine on a continuous, 24 hour, basis.  
 Best results are achieved using annual or monthly average wind speeds. Use of daily or hourly average speeds is not recommended.



APPENDIX K

WIND FINANCIAL WORKSHEETS

**Teaneck Board of Education**  
**(Minimum Average Site Wind Speed @20m – 9.01 mph)**

Annual kWh 3,817  
 Engineer's Opinion of Probable Cost \$21,875.00

**Assumptions**

Annual System Degredation 0.50%  
 Annual Utility Inflation 3.00%  
 Annual Maintenance Costs \$0.02/kWh Production  
 REC Factor \$25/MWh Production  
 REIP Incentive \$3.20/kWh First 16,000 kWh  
 \$0.50/kWh 16,000 kWh - 750,000 kWh

Year	Utility Price	Annual Wind kWh Production	Utility Savings	Renewable Energy Credits (RECs)	Renewable Energy Incentive Program (REIP)	Maintenance Costs	Annual Cash Flow	Cumulative Cash Flow
1	0.1685	3,817.0	\$643.2	\$95	\$12,214	(\$76)	\$662.2	\$662.2
2	0.1736	3,797.9	\$659.1	\$95	\$0	(\$76)	\$678.1	\$1,340.4
3	0.1788	3,778.9	\$675.5	\$94	\$0	(\$76)	\$694.4	\$2,034.8
4	0.1841	3,760.0	\$692.3	\$94	\$0	(\$75)	\$711.1	\$2,745.9
5	0.1896	3,741.2	\$709.5	\$94	\$0	(\$75)	\$728.2	\$3,474.1
6	0.1953	3,722.5	\$727.1	\$93	\$0	(\$74)	\$745.8	\$4,219.9
7	0.2012	3,703.9	\$745.2	\$93	\$0	(\$74)	\$763.7	\$4,983.6
8	0.2072	3,685.4	\$763.7	\$92	\$0	(\$74)	\$782.2	\$5,765.8
9	0.2135	3,667.0	\$782.7	\$92	\$0	(\$73)	\$801.1	\$6,566.9
10	0.2199	3,648.6	\$802.2	\$91	\$0	(\$73)	\$820.4	\$7,387.3
11	0.2264	3,630.4	\$822.1	\$91	\$0	(\$73)	\$840.3	\$8,227.5
12	0.2332	3,612.2	\$842.5	\$90	\$0	(\$72)	\$860.6	\$9,088.1
13	0.2402	3,594.2	\$863.5	\$90	\$0	(\$72)	\$881.4	\$9,969.6
14	0.2474	3,576.2	\$884.9	\$89	\$0	(\$72)	\$902.8	\$10,872.4
15	0.2549	3,558.3	\$906.9	\$89	\$0	(\$71)	\$924.7	\$11,797.1
16	0.2625	3,540.5	\$929.5	\$89	\$0	(\$71)	\$947.2	\$12,744.2
17	0.2704	3,522.8	\$952.5	\$88	\$0	(\$70)	\$970.2	\$13,714.4
18	0.2785	3,505.2	\$976.2	\$88	\$0	(\$70)	\$993.7	\$14,708.1
19	0.2869	3,487.7	\$1,000.5	\$87	\$0	(\$70)	\$1,017.9	\$15,726.0
20	0.2955	3,470.2	\$1,025.3	\$87	\$0	(\$69)	\$1,042.7	\$16,768.7
21	0.3043	3,452.9	\$1,050.8	\$86	\$0	(\$69)	\$1,068.1	\$17,836.8
22	0.3135	3,435.6	\$1,076.9	\$86	\$0	(\$69)	\$1,094.1	\$18,930.9
23	0.3229	3,418.5	\$1,103.7	\$85	\$0	(\$68)	\$1,120.8	\$20,051.7
24	0.3325	3,401.4	\$1,131.1	\$85	\$0	(\$68)	\$1,148.1	\$21,199.8
25	0.3425	3,384.4	\$1,159.2	\$85	\$0	(\$68)	\$1,176.2	\$22,376.0

**Teaneck Board of Education**

**(Maximum Average Site Wind Speed @20m - 13.02 mph)**

Annual kWh 8,316  
 Engineer's Opinion of Probable Cost \$21,875.00

**Assumptions**

Annual System Degredation 0.50%  
 Annual Utility Inflation 3.00%  
 Annual Maintenance Costs \$0.02/kWh Production  
 REC Factor \$25/MWh Production  
 REIP Incentive \$3.20/kWh First 16,000 kWh  
 \$0.50/kWh 16,000 kWh - 750,000 kWh

Year	Utility Price	Annual Wind kWh Production	Utility Savings	Renewable Energy Credits (RECs)	Renewable Energy Incentive Program (REIP)	Maintenance Costs	Annual Cash Flow	Cumulative Cash Flow
1	0.1685	8,316.0	\$1,401.2	\$208	\$26,611	(\$166)	\$1,442.8	\$1,442.8
2	0.1736	8,274.4	\$1,436.1	\$207	\$0	(\$165)	\$1,477.4	\$2,920.3
3	0.1788	8,233.0	\$1,471.8	\$206	\$0	(\$165)	\$1,512.9	\$4,433.2
4	0.1841	8,191.9	\$1,508.3	\$205	\$0	(\$164)	\$1,549.3	\$5,982.5
5	0.1896	8,150.9	\$1,545.8	\$204	\$0	(\$163)	\$1,586.6	\$7,569.0
6	0.1953	8,110.2	\$1,584.2	\$203	\$0	(\$162)	\$1,624.8	\$9,193.8
7	0.2012	8,069.6	\$1,623.6	\$202	\$0	(\$161)	\$1,663.9	\$10,857.7
8	0.2072	8,029.3	\$1,663.9	\$201	\$0	(\$161)	\$1,704.1	\$12,561.8
9	0.2135	7,989.1	\$1,705.3	\$200	\$0	(\$160)	\$1,745.2	\$14,307.1
10	0.2199	7,949.2	\$1,747.7	\$199	\$0	(\$159)	\$1,787.4	\$16,094.5
11	0.2264	7,909.4	\$1,791.1	\$198	\$0	(\$158)	\$1,830.6	\$17,925.1
12	0.2332	7,869.9	\$1,835.6	\$197	\$0	(\$157)	\$1,874.9	\$19,800.0
13	0.2402	7,830.5	\$1,881.2	\$196	\$0	(\$157)	\$1,920.4	\$21,720.4
14	0.2474	7,791.4	\$1,928.0	\$195	\$0	(\$156)	\$1,966.9	\$23,687.3
15	0.2549	7,752.4	\$1,975.9	\$194	\$0	(\$155)	\$2,014.6	\$25,702.0
16	0.2625	7,713.7	\$2,025.0	\$193	\$0	(\$154)	\$2,063.5	\$27,765.5
17	0.2704	7,675.1	\$2,075.3	\$192	\$0	(\$154)	\$2,113.7	\$29,879.2
18	0.2785	7,636.7	\$2,126.9	\$191	\$0	(\$153)	\$2,165.0	\$32,044.2
19	0.2869	7,598.5	\$2,179.7	\$190	\$0	(\$152)	\$2,217.7	\$34,261.9
20	0.2955	7,560.5	\$2,233.9	\$189	\$0	(\$151)	\$2,271.7	\$36,533.6
21	0.3043	7,522.7	\$2,289.4	\$188	\$0	(\$150)	\$2,327.0	\$38,860.6
22	0.3135	7,485.1	\$2,346.3	\$187	\$0	(\$150)	\$2,383.7	\$41,244.3
23	0.3229	7,447.7	\$2,404.6	\$186	\$0	(\$149)	\$2,441.8	\$43,686.2
24	0.3325	7,410.5	\$2,464.3	\$185	\$0	(\$148)	\$2,501.4	\$46,187.6
25	0.3425	7,373.4	\$2,525.6	\$184	\$0	(\$147)	\$2,562.5	\$48,750.0

**Teaneck Board of Education**  
**(Average Site Wind Speed @20m - 11.21 mph)**

Annual kWh 6,345  
 Engineer's Opinion of Probable Cost \$21,875.00

**Assumptions**

Annual System Degredation 0.50%  
 Annual Utility Inflation 3.00%  
 Annual Maintenance Costs \$0.02/kWh Production  
 REC Factor \$25/MWh Production  
 REIP Incentive \$3.20/kWh First 16,000 kWh  
 \$0.50/kWh 16,000 kWh - 750,000 kWh

Year	Utility Price	Annual Wind kWh Production	Utility Savings	Renewable Energy Credits (RECs)	Renewable Energy Incentive Program (REIP)	Maintenance Costs	Annual Cash Flow	Cumulative Cash Flow
1	0.1685	6,345.0	\$1,069.1	\$159	\$20,304	(\$127)	\$1,100.9	\$1,100.9
2	0.1736	6,313.3	\$1,095.7	\$158	\$0	(\$126)	\$1,127.3	\$2,228.1
3	0.1788	6,281.7	\$1,122.9	\$157	\$0	(\$126)	\$1,154.3	\$3,382.5
4	0.1841	6,250.3	\$1,150.8	\$156	\$0	(\$125)	\$1,182.1	\$4,564.5
5	0.1896	6,219.0	\$1,179.4	\$155	\$0	(\$124)	\$1,210.5	\$5,775.1
6	0.1953	6,188.0	\$1,208.7	\$155	\$0	(\$124)	\$1,239.7	\$7,014.8
7	0.2012	6,157.0	\$1,238.8	\$154	\$0	(\$123)	\$1,269.6	\$8,284.3
8	0.2072	6,126.2	\$1,269.6	\$153	\$0	(\$123)	\$1,300.2	\$9,584.5
9	0.2135	6,095.6	\$1,301.1	\$152	\$0	(\$122)	\$1,331.6	\$10,916.1
10	0.2199	6,065.1	\$1,333.4	\$152	\$0	(\$121)	\$1,363.8	\$12,279.9
11	0.2264	6,034.8	\$1,366.6	\$151	\$0	(\$121)	\$1,396.8	\$13,676.6
12	0.2332	6,004.6	\$1,400.5	\$150	\$0	(\$120)	\$1,430.6	\$15,107.2
13	0.2402	5,974.6	\$1,435.3	\$149	\$0	(\$119)	\$1,465.2	\$16,572.4
14	0.2474	5,944.7	\$1,471.0	\$149	\$0	(\$119)	\$1,500.7	\$18,073.1
15	0.2549	5,915.0	\$1,507.6	\$148	\$0	(\$118)	\$1,537.1	\$19,610.3
16	0.2625	5,885.4	\$1,545.0	\$147	\$0	(\$118)	\$1,574.5	\$21,184.7
17	0.2704	5,856.0	\$1,583.4	\$146	\$0	(\$117)	\$1,612.7	\$22,797.4
18	0.2785	5,826.7	\$1,622.8	\$146	\$0	(\$117)	\$1,651.9	\$24,449.3
19	0.2869	5,797.6	\$1,663.1	\$145	\$0	(\$116)	\$1,692.1	\$26,141.4
20	0.2955	5,768.6	\$1,704.4	\$144	\$0	(\$115)	\$1,733.3	\$27,874.7
21	0.3043	5,739.8	\$1,746.8	\$143	\$0	(\$115)	\$1,775.5	\$29,650.1
22	0.3135	5,711.1	\$1,790.2	\$143	\$0	(\$114)	\$1,818.7	\$31,468.9
23	0.3229	5,682.5	\$1,834.7	\$142	\$0	(\$114)	\$1,863.1	\$33,332.0
24	0.3325	5,654.1	\$1,880.3	\$141	\$0	(\$113)	\$1,908.5	\$35,240.5
25	0.3425	5,625.8	\$1,927.0	\$141	\$0	(\$113)	\$1,955.1	\$37,195.6