



# Local Government Energy Audit: Energy Audit Report



## Jewish Community Center of S, H & W Counties, Inc. Main Building

775 Talamini Road  
Bridgewater, NJ 08807

09/05/2017

Report by:

**TRC Energy Services**



Copyright ©2016 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

## Disclaimer

---

The intent of this energy analysis report is to identify energy savings opportunities associated with recommended upgrades to the facility's systems at this site. Approximate savings are included in this report to make decisions about reducing energy use at the facility. This report is not intended to serve as a detailed engineering design document. Detailed design efforts are required in order to implement several of the improvements evaluated as part of this energy analysis.

The energy conservation measures and estimates of energy consumption contained in this report have been reviewed for technical accuracy. However, all estimates contained herein of energy consumption at the site are not guaranteed, because energy consumption ultimately depends on behavioral factors, the weather, and many other uncontrollable variables. The energy assessor and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy consumption vary from the estimated consumption shown herein.

Estimated installation costs are based on a variety of sources, including our own experience at similar facilities, our own pricing research using local contractors and vendors, and cost estimating handbooks such as those provided by RS Means. The cost estimates represent our best judgment for the proposed action. The Owner is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for a particular installation, and for conditions which cannot be known prior to in-depth investigation and design, the energy assessor does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates and are based on program information available at the time this report is written. The NJBPU reserves the right to extend, modify, or terminate programs without prior or further notice, including incentive levels and eligibility requirements. The Owner should review available program incentives and requirements prior to selecting and/or installing any recommended measures.

# Table of Contents

---

<b>1</b>	<b>Executive Summary .....</b>	<b>6</b>
1.1	Facility Summary .....	6
1.2	Your Cost Reduction Opportunities.....	6
	Energy Conservation Measures.....	6
	Energy Efficient Practices .....	8
	Self-Generation Measures .....	9
1.3	Implementation Planning.....	9
<b>2</b>	<b>Facility Information and Existing Conditions .....</b>	<b>11</b>
2.1	Project Contacts .....	11
2.2	General Site Information.....	11
2.3	Building Occupancy .....	11
2.4	Building Envelope .....	12
2.5	On-site Generation.....	12
2.6	Energy-Using Systems .....	12
	Lighting .....	12
	Air Conditioning (DX).....	13
	Building Energy Management System .....	13
	Domestic Hot Water.....	13
	Food Service & Laundry Equipment.....	13
	Refrigeration .....	13
	Plug Load & Vending Machines.....	13
2.7	Water-Using Systems .....	14
<b>3</b>	<b>Site Energy Use and Costs .....</b>	<b>15</b>
3.1	Total Cost of Energy .....	15
3.2	Electricity Usage .....	16
3.3	Natural Gas Usage .....	17
3.4	Benchmarking.....	18
3.5	Energy End-Use Breakdown .....	19
<b>4</b>	<b>Energy Conservation Measure .....</b>	<b>20</b>
4.1	Recommended ECMs .....	20
4.1.1	Lighting Upgrades.....	21
	ECM 1: Install LED Fixtures.....	21
	ECM 2: Retrofit Fixtures with LED Lamps.....	22
	ECM 3: Install LED Exit Signs.....	22
4.1.2	Lighting Control Measures .....	23
	ECM 4: Install Occupancy Sensor Lighting Controls .....	23
4.1.3	Electric Unitary HVAC Measures .....	24
	ECM 5: Install High Efficiency Electric AC.....	24
4.1.4	HVAC System Improvements .....	24

ECM 6: Install Dual Enthalpy outside Economizer Control.....	25
4.1.5 Domestic Water Heating Upgrade .....	25
ECM 7: Install Low-Flow DHW Devices.....	25
4.1.6 Food Service Equipment & Refrigeration Measures. ....	26
ECM 8: Dishwasher Replacement .....	26
ECM 9: Replace Refrigeration Equipment.....	26
4.1.7 Plug Load Equipment Control - Vending Machine .....	27
ECM 10: Vending Machine Control .....	27
<b>5 Energy Efficient Practices .....</b>	<b>28</b>
Reduce Air Leakage .....	28
Close Doors and Windows .....	28
Perform Proper Lighting Maintenance.....	28
Develop a Lighting Maintenance Schedule .....	28
Ensure Lighting Controls Are Operating Properly .....	28
Perform Routine Motor Maintenance .....	29
Use Fans to Reduce Cooling Load .....	29
Practice Proper Use of Thermostat Schedules and Temperature Resets .....	29
Clean Evaporator/Condenser Coils on AC Systems .....	29
Clean and/or Replace HVAC Filters .....	29
Check for and Seal Duct Leakage .....	29
Perform Proper Boiler Maintenance.....	29
Perform Proper Furnace Maintenance .....	30
Perform Proper Water Heater Maintenance .....	30
Plug Load Controls.....	30
Water Conservation .....	30
<b>6 Self-Generation Measures .....</b>	<b>31</b>
6.1 Photovoltaic.....	31
6.2 Combined Heat and Power .....	32
<b>7 Project Funding / Incentives .....</b>	<b>34</b>
7.1 SmartStart .....	35
7.2 Direct Install .....	36
<b>8 Energy Purchasing and Procurement Strategies .....</b>	<b>37</b>
8.1 Retail Electric Supply Options.....	37
8.2 Retail Natural Gas Supply Options .....	37
Appendix A: Equipment Inventory & Recommendations	
Appendix B: ENERGY STAR Statement of Energy Performance	
Appendix C: Photo Gallery	

# Table of Figures

---

Figure 1 – Previous 12 Month Utility Costs..... 7

Figure 2 – Potential Post-Implementation Costs ..... 7

Figure 3 – Summary of Energy Reduction Opportunities ..... 7

Figure 4 – Photovoltaic Potential..... 9

Figure 5 – Project Contacts ..... 11

Figure 6 - Building Schedule..... 11

Figure 7 - Utility Summary ..... 15

Figure 8 - Energy Cost Breakdown ..... 15

Figure 9 - Electric Usage & Demand..... 16

Figure 10 - Electric Usage & Demand..... 16

Figure 11 - Natural Gas Usage..... 17

Figure 12 - Natural Gas Usage..... 17

Figure 13 - Energy Use Intensity Comparison – Existing Conditions..... 18

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures ..... 18

Figure 15 - Energy Balance (% and kBtu/SF) ..... 19

Figure 16 – Summary of Recommended ECMs..... 20

Figure 17 – Summary of Lighting Upgrade ECMs..... 21

Figure 18 – Summary of Lighting Control ECMs ..... 23

Figure 19 - Summary of Unitary HVAC ECMs..... 24

Figure 20 - Summary of HVAC System Improvement ECMs ..... 24

Figure 21 - Summary of Domestic Water Heating ECMs ..... 25

Figure 22 - Photovoltaic Screening ..... 31

Figure 23 - Combined Heat and Power Screening ..... 32

Figure 24 - ECM Incentive Program Eligibility..... 34

# I EXECUTIVE SUMMARY

---

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for Abundant Life Original Glorious Church.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

TRC Energy Services (TRC) conducted this study as part of a comprehensive effort to assist New Jersey nonprofits in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

## I.1 Facility Summary

The Jewish Community Center is an agency of the Jewish Federation of Somerset, Hunterdon and Warren Counties, serving their residents with fitness, recreation, social, cultural and educational programming for the entire community. The Main Building is a single story, 36,000 square foot facility built in 1999. There are two buildings on the site. Spaces include the main office, community multipurpose rooms, gymnasium, fitness room, non-commercial kitchen and an aquatic center (pool). The building is constructed of brick over structural steel, with accents of vinyl siding. There are two types of roofing: a flat roof with white membrane in good condition and saddle roofs covered in asphalt shingles. Windows are single pane cut-up in good condition, with no observable infiltration. Exterior doors are constructed of aluminum and are in good condition. Lighting is primarily four-foot fluorescent T8 fixtures. HVAC equipment includes two (2) window air conditioners and eight (8) package cooling with gas heat roof top unit ranging in size from 12.5 to 15 tons. Cooling and heating are controlled by 5 zones thermostat. The bathrooms and kitchen are ventilated via mechanical exhaust fans located on the roof.

A thorough description of the facility and our observations are located in Section 2.

## I.2 Your Cost Reduction Opportunities

### Energy Conservation Measures

TRC evaluated ten Energy Conservation Measures (ECM) with potential to reduce annual energy costs by roughly \$18,698 and annual greenhouse gas emissions by 192,314 lbs CO<sub>2</sub>e. The measures would pay for themselves in roughly 3.1 years. The breakdown of existing and potential utility costs is illustrated in Figure 1 and Figure 2. These projects represent an opportunity to reduce the building's annual energy use by 20%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of existing energy use is located in Section 3 “Site Energy Use and Costs”.

The evaluated measures have been listed and grouped into major categories as shown in Figure 3. Brief descriptions of the categories are below with descriptions of the individual opportunities located in Section 4, “Energy Conservation Measur.”

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Reduction (lbs)
<b>Lighting Upgrades</b>		104,493	14.3	0.0	0.0	0.0	0.0	\$13,736.93	\$44,936.93	\$6,210.00	\$38,726.93	2.82	105,224
ECM 1   Install LED Fixtures	Yes	45,768	7.0	0.0	0.0	0.0	0.0	\$6,016.83	\$26,747.78	\$3,945.00	\$22,802.78	3.79	46,088
ECM 2   Retrofit Fixtures with LED Lamps	Yes	56,692	7.2	0.0	0.0	0.0	0.0	\$7,452.92	\$15,070.06	\$2,265.00	\$12,805.06	1.72	57,089
ECM 3   Install LED Exit Signs	Yes	2,032	0.2	0.0	0.0	0.0	0.0	\$267.17	\$3,119.10	\$0.00	\$3,119.10	11.67	2,047
<b>Lighting Control Measures</b>		7,434	0.9	0.0	0.0	0.0	0.0	\$977.30	\$2,088.00	\$360.00	\$1,728.00	1.77	7,486
ECM 4   Install Occupancy Sensor Lighting Controls	Yes	7,434	0.9	0.0	0.0	0.0	0.0	\$977.30	\$2,088.00	\$360.00	\$1,728.00	1.77	7,486
<b>Electric Unitary HVAC Measures</b>		452	0.3	0.0	0.0	0.0	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456
ECM 5   Install High Efficiency Electric AC	Yes	452	0.3	0.0	0.0	0.0	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456
<b>Electric Chiller Replacement</b>		0	0.0	0.0	0.0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0
ECM 6   Install Dual Enthalpy Outside Economizer Control	Yes	763	0.2	0.0	0.0	0.0	0.0	\$100.26	\$1,000.00	\$500.00	\$500.00	4.99	768
ECM 7   Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	627.2	0.0	0.0	627.2	\$3,178.16	\$1,052.16	\$0.00	\$1,052.16	0.33	73,436
<b>Food Service Equipment &amp; Refrigeration Measures</b>		3,701	0.4	0.0	0.0	0.0	0.0	\$486.60	\$12,853.88	\$925.00	\$11,928.88	24.51	3,727
ECM 8   Dishwasher Replacement	Yes	1,213	0.1	0.0	0.0	0.0	0.0	\$159.44	\$4,341.88	\$400.00	\$3,941.88	24.72	1,221
ECM 9   Replace Refrigeration Equipment	Yes	2,489	0.3	0.0	0.0	0.0	0.0	\$327.15	\$8,512.00	\$525.00	\$7,987.00	24.41	2,506
<b>Plug Load Equipment Control - Vending Machine</b>		1,209	0.0	0.0	0.0	0.0	0.0	\$158.92	\$2,156.40	\$0.00	\$2,156.40	13.57	1,217
ECM 10   Vending Machine Control	Yes	1,209	0.0	0.0	0.0	0.0	0.0	\$158.92	\$2,156.40	\$0.00	\$2,156.40	13.57	1,217
<b>Custom Measures</b>		0	0.0	0.0	0.0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0
<b>TOTALS</b>		<b>118,052</b>	<b>16.1</b>	<b>627.2</b>	<b>0.0</b>	<b>0.0</b>	<b>627.2</b>	<b>\$18,697.65</b>	<b>\$66,264.89</b>	<b>\$7,995.00</b>	<b>\$58,269.89</b>	<b>3.12</b>	<b>192,314</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

**Lighting Upgrades** generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measure save energy by reducing the power used by the lighting components due to improved electrical efficiency.

**Lighting Controls** measures generally involve the installation of automated controls to turn off lights or reduce light output when conditions allow. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

**Electric Unitary HVAC** measures generally involve replacing old inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide cooling equivalent to older

air condition systems, but use less energy. These measures save energy by reducing the power used by the air condition system due to improved electrical efficiency.

**HVAC System Improvements** generally involve the installation of automated controls to reduce heating and cooling demand when conditions allow. These measures could encompass changing temperature set points, using outside air for free cooling, or limiting excessive outside air during extreme outdoor air temperatures. These measures save energy by reducing the demand on the systems and the amount of time systems operate.

**Domestic Water Heating** upgrade measures generally involve replacing old inefficient domestic water heating systems with modern energy efficient systems. New domestic water heating systems can provide equivalent or greater capacity as older systems, but use less energy. These measures save energy by reducing the fuel used by the domestic water heating systems due to improved efficiency or the removal of standby losses.

**Plug Load Equipment** control measures generally involve installing automation that limits the power use or operation of equipment plugged into an electrical receptacle based on occupancy.

### **Energy Efficient Practices**

Energy performance can also be improved by employing certain behavioral and operational adjustments as well as performing routine maintenance on building systems. Through these practices equipment lifetime can be extended; occupant comfort, health and safety can be improved; and annual energy, operation, and maintenance costs can be reduced. TRC identified 16 opportunities including:

- Reduce Air Leakage
- Close Doors and Windows
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Perform Routine Motor Maintenance
- Use Fans to Reduce Cooling Load
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Check for and Seal Duct Leakage
- Perform Proper Boiler Maintenance
- Perform Proper Furnace Maintenance
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these Energy Efficient Practices, please refer to Section 5.



## Self-Generation Measures

TRC evaluated the potential for installing self-generation sources for the Main Building. Based on the configuration of the site and its loads there is a high potential for installing a photovoltaic (PV) array.

*Figure 4 – Photovoltaic Potential*

Potential	High	
System Potential	107	kW DC STC
Electric Generation	127,477	kWh/yr
Displaced Cost	\$11,090	/yr
Installed Cost	\$278,200	

For details on our evaluation and the self-generation potential, please refer to Section 6.

### 1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, the equipment changes outlined for each ECM need to be selected and installed through project implementation. One of the first considerations is if there is capital available for project implementation. Another consideration is whether to pursue individual ECMs, a group of ECMs, or a comprehensive approach wherein all ECMs are pursued, potentially in conjunction with other facility projects or improvements.

Rebates, incentives, and financing are available from the NJBPU, NJCEP, as well as some of the state's investor-owned utilities, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any project, please review the appropriate incentive program guidelines before proceeding. This is important because in most cases you will need to submit an application for the incentives before purchasing materials and beginning installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install (DI)

For facilities with capital available for implementation of selected individual measures or phasing implementation of selected measures over multiple years, incentives are available through the SmartStart program. To participate in this program you may use internal resources, or an outside firm or contractor, to design the ECM(s), select the equipment and apply for the incentive(s). Program pre-approval is required for some SmartStart incentives, so only after receiving approval may the ECM(s) be installed. The incentive values listed above in Figure 3 represent the SmartStart program and are explained further in Section 7, as well as the other programs as mentioned below.

This facility also qualifies for the Direct Install program which, through an authorized network of participating contractors, can assist with the implementation of a group of measures versus installing individual measures or phasing implementation. This turnkey program provides incentives up to 70% of the cost of the project identified by the designated contractor.

For facilities without capital available to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with external project development, design, and implementation services as well as financing for implementing ECMs. This LGEA report is the first step for participating in ESIP and should help you determine next steps. Refer to Section **Error! Reference source not found.** for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a program (non-NJCEP) designed to reduce consumer electric load when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability locally. By enabling grid operators to call upon Curtailment Service Providers and energy consumers to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants will receive payments whether or not their facility is called upon to curtail their load. Refer to Section **Error! Reference source not found.** for additional information on this program.

Additional descriptions of all relevant incentive programs are located in Section 7. You may also check the following website for further information on available rebates and incentives: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

To ensure projects are implemented such that maximum savings and incentives are achieved, bids and specifications should be reviewed by your procurement personnel and/or consultant(s) to ensure that selected equipment coincides with LGEA recommendations, as well as applicable incentive program guidelines and requirements.

## 2 FACILITY INFORMATION AND EXISTING CONDITIONS

### 2.1 Project Contacts

*Figure 5 – Project Contacts*

Name	Role	E-Mail	Phone #
Customer			
Laura Friedman	Executive Director	<a href="mailto:lfriedman@ssbjcc.org">lfriedman@ssbjcc.org</a>	908-725-6994
Designated Representative			
Laura Friedman	Executive Director	<a href="mailto:lfriedman@ssbjcc.org">lfriedman@ssbjcc.org</a>	908-725-6994
TRC Energy Services			
Moussa Traore	Auditor	<a href="mailto:mtraore@trcsolutions.com">mtraore@trcsolutions.com</a>	732855-2879

### 2.2 General Site Information

TRC performed an energy audit at the Main Building on August 25, 2016. The TRC auditor met with Laurie Friedman to review the facility operations and focus the investigation on specific energy-using systems.

The Jewish Community Center is an agency of the Jewish Federation of Somerset, Hunterdon and Warren Counties, serving their residents with fitness, recreation, social, cultural and educational programming for the entire community. The Main Building is a single story, 36,000 square foot facility built in 1999. There are two buildings on the site. Spaces include the main office, community multipurpose rooms, gymnasium, fitness room, non-commercial kitchen and an aquatic center (pool). The building is constructed of brick over structural steel, with accents of vinyl siding. There are two types of roofing: a flat roof with white membrane in good condition and saddle roofs covered in asphalt shingles. Windows are single pane cut-up in good condition, with no observable infiltration. Exterior doors are constructed of aluminum and are in good condition. Lighting is primarily four-foot fluorescent T8 fixtures. HVAC equipment includes two (2) window air conditioners and eight (8) package cooling with gas heat roof top unit ranging in size from 12.5 to 15 tons. Cooling and heating are controlled by 5 zones thermostat. The bathrooms and kitchen are ventilated via mechanical exhaust fans located on the roof.

### 2.3 Building Occupancy

The Main Building is open to the community every day and used year round. The typical schedule is presented in the table below.

*Figure 6 - Building Schedule*

Building Occupancy Schedule		
Building Name	Weekday/Weekend	Operating Schedule
Main Building	Weekday	7:30 AM - 11:30 PM
Main Building	Weekend	7:30 AM - 11:30 PM

## 2.4 Building Envelope

The base of the building consists of poured concrete foundation supported on continuous footings. The building is constructed of brick wall and structural steel. The exterior facades are accented with vinyl siding.

There is a center flat roof covered with a white membrane in good condition surrounded by saddle roofs with asphalt shingles.

Overall we found the building to be reasonably air-tight. Exterior doors are constructed of aluminum and are in good condition. Weather stripping was observed around the door openings. Exterior doors, thresholds, related flashing, caulking and weather-stripping were inspected for signs of moisture, air-leakage and other energy-compromising issues. Overall, the doors were found to be in good condition with only a few signs of uncontrolled moisture, air-leakage and/or other energy-compromising issues

The building has single pane cut-up windows. Windows, shading devices, sills, related flashing and caulking were inspected as far as accessibility allowed for signs of moisture, air-leakage and other energy compromising issues. Overall, the windows were found to be in good condition with no signs of uncontrolled moisture, air-leakage and/or other energy-compromising issues. A



## 2.5 On-site Generation

There is no on-site electric generation capacity.

## 2.6 Energy-Using Systems

Please refer to Appendix A: Equipment Inventory & Recommendations for an inventory of your equipment.

### Lighting

Interior lighting is provided by the following types of equipment:

- linear fluorescent fixtures using 32 watt T8 lamps with electronic and magnetic ballasts
- compact fluorescent lamps (CFL)
- LED fixtures (main office and hallway).



Most spaces use 2-lamp or 3-lamp, 2 x 4 foot recessed troffers with diffusers.

Lighting control in most spaces is provided by manual light switch. Lobbies and main lobby do not contain any occupancy sensors and are on 24 hours per day throughout the year.

Exterior lighting consists of 150-watt, wall mounted metal halide fixtures, 100-watt recessed metal halide fixtures and more recently, 40-watt wall-mounted LED fixture. Parking lot pole lighting contains 400-watt metal halide and LED fixtures. Exterior lighting is controlled by photocells.

## **Air Conditioning (DX)**

Two 15-ton and six 12.5-tons Lennox package cooling with gas heat are used to condition the building. All the units are located on the center flat roof of the building. The units are constant air volume with four (4) 1/12 hp supply fan and no return fan. The units use a scroll compressor and a direct-expansion (DX) coil. The units are controlled by individual Honeywell thermostats located in each of the five zones. Thermostats are generally set to 72°F but adjustable by tenants. The units operate between 7:30 AM and 11:30 PM Monday through Sunday.



## **Building Energy Management System**

There is no building energy management system.

## **Domestic Hot Water**

The domestic hot water system consists of one Bradford White gas fired, non-condensing hot water heater with an input rating of 199 KBtu/hr and a nominal efficiency of 89%. The water heater has 80-gallon storage tank and is in good working condition. Hot water in the facility is used in the restrooms and for shower in the locker rooms. The facility also has a 1,222.5 kBtu/hr commercial indoor pool heater located in the pump room.



## **Food Service & Laundry Equipment**



The non-commercial kitchen is occasionally used to prepare and store food. The kitchen is also used to prepare hot snacks for some events each year. Most cooking is done using the two convection ovens and the single large griddle.

The small snack bar located near the gymnasium and contains commercial refrigerators storing beverages and snacks.

## **Refrigeration**

A low profile, air defrost Heatcraft walk-in refrigerator located at the rear indoor pool that is used to store food and beverage. The refrigerator has a single 0.54 ton air cooled scroll compressor. The walk-in space temperature is maintained at 34°F. The kitchen also has a free standing commercial size freezer.

## **Plug Load & Vending Machines**

There are approximately 32 computer work stations throughout the facility, roughly 99% of which are desktop units with LCD monitors. There is no centralized PC power management software installed. Two server closets use cooling provided by a package roof top unit.

There are three (3) glass fronted refrigerated beverage vending machines and one non-refrigerated snack vending machines.

## 2.7 Water-Using Systems

There are four restrooms and two locker rooms. Two restrooms with showers serve the outdoor pool and the two locker rooms serve the indoor pool, fitness center and gymnasium. A sampling of restrooms found that faucets are rated for 3.5 gpm, toilets are rated at 2.5 gallons per flush and urinals are rated at 2 gallons per flush. Showerheads are rated at 2.5 gpm.



### 3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings and determine the annual energy performance metrics for the building in energy cost/ft<sup>2</sup> and energy use/ft<sup>2</sup>. These energy use indices are indicative of the relative energy effectiveness of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy use for similar facilities such as local climate conditions, daily occupancy hours of the facility, seasonal fluctuations in occupancy, daily operating hours of energy use systems, and occupant behavior. Refer to Section 3.4 for additional information.

#### 3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12 month period of utility usage data that was provided for each utility. The annual consumption and cost were developed from this information.

*Figure 7 - Utility Summary*

Utility Summary for Main Building		
Fuel	Usage	Cost
Electricity	586,954 kWh	\$82,049
Natural Gas	60,539 Therms	\$30,677
Total		\$112,726

The current utility cost for this site is \$112,726 as shown in the chart below.

*Figure 8 - Energy Cost Breakdown*



### 3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost (combined for commodity, transmission and distribution) for the past 12 months is \$0.131/kWh, which is the blended rate used throughout the analyses in this report. Summer consumption rises due to use of cooling units. Base electrical load for the building consists primarily of lighting, refrigeration, pool water pump motors and related equipment, domestic water heating and electronics accounting for the remainder.

Figure 9 - Electric Usage & Demand




Figure 10 - Electric Usage & Demand

Electric Billing Data for Main Building						
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost	TRC Estimated Usage?
4/17/15	30	42,480	97	\$348	\$6,098	Yes
5/18/15	31	44,897	105	\$378	\$6,286	Yes
6/17/15	30	46,646	121	\$437	\$7,679	Yes
7/17/15	30	49,577	120	\$432	\$8,081	Yes
8/17/15	31	54,874	126	\$454	\$8,505	Yes
9/16/15	30	50,811	128	\$463	\$7,870	Yes
10/15/15	29	44,023	110	\$399	\$5,847	Yes
11/13/15	29	45,154	109	\$393	\$5,936	Yes
12/16/15	33	51,994	104	\$377	\$6,397	Yes
1/19/16	34	56,314	113	\$410	\$6,779	Yes
2/17/16	29	52,097	114	\$412	\$6,424	Yes
3/17/16	29	48,086	105	\$383	\$6,147	Yes
Totals	365	586,954	128.0571314	\$4,887	\$82,049	Yes
Annual	365	586,954	128.0571314	\$4,887	\$82,049	Yes



### 3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.507/therm, which is the blended rate used throughout the analyses in this report.

Figure 11 - Natural Gas Usage




Figure 12 - Natural Gas Usage

Gas Billing Data for Main Building				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
4/17/15	30	5,850	\$3,415	Yes
5/18/15	31	3,024	\$1,731	Yes
6/17/15	30	1,540	\$931	Yes
7/17/15	30	535	\$373	Yes
8/17/15	31	399	\$297	Yes
9/16/15	30	217	\$191	Yes
10/15/15	29	2,699	\$1,516	Yes
11/13/15	29	4,156	\$3,725	Yes
12/16/15	33	6,233	\$5,002	Yes
1/19/16	34	7,632	\$5,963	Yes
2/17/16	29	8,151	\$6,022	Yes
3/17/16	29	5,696	\$4,321	Yes
Apr-16	32	5,308	\$2,689	12
Annual	365	60,539	\$30,677	

### 3.4 Benchmarking

This facility was benchmarked using *Portfolio Manager*, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® Score for select building types.

The EUI measures a building’s energy consumption per square foot, and it is the standard metric for comparing building energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy”. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

**Figure 13 - Energy Use Intensity Comparison – Existing Conditions**

Energy Use Intensity Comparison - Existing Conditions		
	Jewish Community Center Of Somerset	National Median Building Type: Other - General
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	351.3	123.1
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	223.8	78.8

By implementing all recommended measures covered in this reporting, the Project’s estimated post-implementation EUI improves as shown in the table below:

**Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures**

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Main Buildibg	National Median Building Type: Other - General
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	297.8	123.1
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	195.2	78.8

Many types of commercial buildings are eligible to receive ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification.


A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.

For more information on Energy Star certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

### 3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance uses standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building and determine their proportional contribution to overall building energy usage. This visual representation of energy end uses highlights systems that may benefit most from energy efficiency projects.

Figure 15 - Energy Balance (% and kBtu/SF)



## 4 ENERGY CONSERVATION MEASURE

### Level of Analysis

The goal of this audit report is to identify potential energy projects, help prioritize specific measures for implementation, and set the Jewish Community Center on a path to receive financial incentives. For this audit report, most measures have received a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is considered sufficient to make “Go/No-Go” decisions and to prioritize energy projects. Savings are based on the New Jersey Board of Public Utilities New Jersey Clean Energy Program Protocols to Measure Resource Savings dated March 17, 2014. Further analysis or investigation may be required to calculate more accurate savings to support any custom SmartStart, Pay for Performance, or Large Energy Users incentive applications. Financial incentives for the ECMs identified in this report were calculated based the NJ prescriptive SmartStart program. Depending on your implementation strategy, the project may be eligible for more lucrative incentives through other programs as identified in Section 7.

The following sections describe the evaluated measures.

### 4.1 Recommended ECMs

The measures were evaluated by the auditor and are recommended for implementation at the facility.

**Figure 16 – Summary of Recommended ECMs**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		104,493	14.3	0.0	0.0	0.0	0.0	\$13,736.93	\$44,936.93	\$6,210.00	\$38,726.93	2.82	105,224
ECM 1 Install LED Fixtures	Yes	45,768	7.0	0.0	0.0	0.0	0.0	\$6,016.83	\$26,747.78	\$3,945.00	\$22,802.78	3.79	46,088
ECM 2 Retrofit Fixtures with LED Lamps	Yes	56,692	7.2	0.0	0.0	0.0	0.0	\$7,452.92	\$15,070.06	\$2,265.00	\$12,805.06	1.72	57,089
ECM 3 Install LED Exit Signs	Yes	2,032	0.2	0.0	0.0	0.0	0.0	\$267.17	\$3,119.10	\$0.00	\$3,119.10	11.67	2,047
<b>Lighting Control Measures</b>		7,434	0.9	0.0	0.0	0.0	0.0	\$977.30	\$2,088.00	\$360.00	\$1,728.00	1.77	7,486
ECM 4 Install Occupancy Sensor Lighting Controls	Yes	7,434	0.9	0.0	0.0	0.0	0.0	\$977.30	\$2,088.00	\$360.00	\$1,728.00	1.77	7,486
<b>Electric Unitary HVAC Measures</b>		452	0.3	0.0	0.0	0.0	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456
ECM 5 Install High Efficiency Electric AC	Yes	452	0.3	0.0	0.0	0.0	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456
<b>Electric Chiller Replacement</b>		0	0.0	0.0	0.0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0
ECM 6 Install Dual Enthalpy Outside Economizer Control	Yes	763	0.2	0.0	0.0	0.0	0.0	\$100.26	\$1,000.00	\$500.00	\$500.00	4.99	768
ECM 7 Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	627.2	0.0	0.0	627.2	\$3,178.16	\$1,052.16	\$0.00	\$1,052.16	0.33	73,436
<b>Food Service Equipment &amp; Refrigeration Measures</b>		3,701	0.4	0.0	0.0	0.0	0.0	\$486.60	\$12,853.88	\$925.00	\$11,928.88	24.51	3,727
ECM 8 Dishwasher Replacement	Yes	1,213	0.1	0.0	0.0	0.0	0.0	\$159.44	\$4,341.88	\$400.00	\$3,941.88	24.72	1,221
ECM 9 Replace Refrigeration Equipment	Yes	2,489	0.3	0.0	0.0	0.0	0.0	\$327.15	\$8,512.00	\$525.00	\$7,987.00	24.41	2,506
<b>Plug Load Equipment Control - Vending Machine</b>		1,209	0.0	0.0	0.0	0.0	0.0	\$158.92	\$2,156.40	\$0.00	\$2,156.40	13.57	1,217
ECM 10 Vending Machine Control	Yes	1,209	0.0	0.0	0.0	0.0	0.0	\$158.92	\$2,156.40	\$0.00	\$2,156.40	13.57	1,217
<b>Custom Measures</b>		0	0.0	0.0	0.0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0
<b>TOTALS</b>		118,052	16.1	627.2	0.0	0.0	627.2	\$18,697.65	\$66,264.89	\$7,995.00	\$58,269.89	3.12	192,314

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Please refer to Appendix A: Equipment Inventory & Recommendations for a detailed list of the locations and equipment affected by the recommended ECMs.

## 4.1.1 Lighting Upgrades

Lighting Upgrades include several “submeasures” as outlined in Figure 17 below.

**Figure 17 – Summary of Lighting Upgrade ECMs**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>104,493</b>	<b>14.3</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>\$13,736.93</b>	<b>\$44,936.93</b>	<b>\$6,210.00</b>	<b>\$38,726.93</b>	<b>2.82</b>	<b>105,224</b>
ECM 1 Install LED Fixtures	Yes	45,768	7.0	0.0	0.0	0.0	0.0	\$6,016.83	\$26,747.78	\$3,945.00	\$22,802.78	3.79	46,088
ECM 2 Retrofit Fixtures with LED Lamps	Yes	56,692	7.2	0.0	0.0	0.0	0.0	\$7,452.92	\$15,070.06	\$2,265.00	\$12,805.06	1.72	57,089
ECM 3 Install LED Exit Signs	Yes	2,032	0.2	0.0	0.0	0.0	0.0	\$267.17	\$3,119.10	\$0.00	\$3,119.10	11.67	2,047

### ECM 1: Install LED Fixtures

#### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	37,105	4.8	0.0	\$4,877.92	\$16,726.25	\$1,425.00	\$15,301.25	3.14	37,364
Exterior	8,663	2.2	0.0	\$1,138.92	\$10,021.53	\$2,520.00	\$7,501.53	6.59	8,724

#### *Measure Description*

This measure evaluates replacing existing fluorescent fixtures with new high performance LED light fixtures. This measure saves energy by installing LED sources which use less power than other technologies with a comparable light output.

Maintenance savings are anticipated since LED sources have burn hours which are generally more than twice that of a fluorescent source and more than 10 times incandescent sources. Maintenance savings may be partially offset by the higher material costs associated with LED sources.

During planning and design for the installation of new fixtures, we recommend a holistic approach that considers both the technology of the lighting sources and how they are controlled.

## ECM 2: Retrofit Fixtures with LED Lamps

### Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	56,692	7.2	0.0	\$7,452.92	\$15,070.06	\$2,265.00	\$12,805.06	1.72	57,089
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0

### Measure Description

This measure evaluates replacing linear fluorescent lamps with LED tube lamps and replacing HID, incandescent and halogen screw-in/plug-in based lamps with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed although there is a fluorescent fixture ballast in place. Other tube lamps require that fluorescent fixture ballasts be removed or replaced with LED drivers. Screw-in/plug-in LED lamps can be used as a direct replacement for most other screw-in/plug-in lamps. This measure saves energy by installing LED sources which use less power than other technologies with a comparable light output.

Maintenance savings are anticipated since LED sources have burn hours which are more than twice that of a fluorescent source and more than 10 times incandescent sources. LED lamps that use the existing fluorescent fixture ballast will be constrained by the remaining hours of the ballast. Maintenance savings may be partially offset by the higher material costs associated with LED sources.

During retrofit planning and design, we recommend a holistic approach that considers both the technology of the lighting sources and how they are controlled.

## ECM 3: Install LED Exit Signs

### Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	2,032	0.2	0.0	\$267.17	\$3,119.10	\$0.00	\$3,119.10	11.67	2,047
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0

### Measure Description

This measure evaluates replacing incandescent and compact fluorescent lighting in exit signs with LEDs. LED sources require virtually no maintenance and LED exit signs have a life expectancy of at least 20 years. Many manufacturers can provide retrofit kits that meet fire and safety code requirements. Retrofit kits are less expensive and simpler to install than replacement signs, however, new fixtures would have a longer useful life and are therefore recommended.

A reduction in maintenance costs will be realized with the proposed retrofit because lamps will not have to be replaced as frequently.

### 4.1.2 Lighting Control Measures

Lighting control measures include several “submeasures” as outlined in Figure 18 below.

**Figure 18 – Summary of Lighting Control ECMs**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>		7,434	0.9	0.0	0.0	0.0	0.0	\$977.30	\$2,088.00	\$360.00	\$1,728.00	1.77	7,486
ECM 4   Install Occupancy Sensor Lighting Controls	Yes	7,434	0.9	0.0	0.0	0.0	0.0	\$977.30	\$2,088.00	\$360.00	\$1,728.00	1.77	7,486
<b>TOTALS</b>		118,052	16.1	627.2	0.0	0.0	627.2	\$18,697.65	\$66,264.89	\$7,995.00	\$58,269.89	3.12	192,314

### ECM 4: Install Occupancy Sensor Lighting Controls

#### Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
7,434	0.9	0.0	\$977.30	\$2,088.00	\$360.00	\$1,728.00	1.77	7,486

#### Measure Description

This measure evaluates installing occupancy sensors to control light fixtures that are currently manually controlled in restrooms, storage rooms, multipurpose rooms and private offices. Sensors detect occupancy using ultrasonic and/or infrared wave technologies. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Occupants will also be able to manually turn off fixtures. Energy savings result from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. Ceiling-mounted or remote-mounted sensors require the use of low voltage switching relays or a wireless signal to the switch. In general, use wall switch replacement sensors for single occupant offices and other small rooms. Install ceiling-mounted or remote mounted sensors in locations without local switching, in situations where the existing wall switches are not in the line-of-sight of the main work area, and in large spaces. We recommend a holistic design approach that considers both the technology of the lighting sources and how they are controlled.

Maintenance savings are anticipated due to reduced lamp operation, however, additional maintenance costs may be incurred because the occupancy sensors may require periodic adjustment; it is anticipated that the net effect on maintenance costs will be negligible.

### 4.1.3 Electric Unitary HVAC Measures

Unitary HVAC measures include several “submeasures” as outlined in Figure 19 below.

**Figure 19 - Summary of Unitary HVAC ECMs**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Electric Unitary HVAC Measures</b>		452	0.3	0.0	0.0	0.0	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456
ECM 5   Install High Efficiency Electric AC	Yes	452	0.3	0.0	0.0	0.0	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456
<b>TOTALS</b>		118,052	16.1	627.2	0.0	0.0	627.2	\$18,697.65	\$66,264.89	\$7,995.00	\$58,269.89	3.12	192,314

### ECM 5: Install High Efficiency Electric AC

*Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
452	0.3	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456

*Measure Description*

This measure evaluates replacing package air conditioners with high efficiency package air conditioners. There have been significant improvements in both compressor and fan motor efficiencies in the past several years. Therefore, electricity savings can be achieved by replacing old units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the old and new unit, the cooling load, and the annual operating hours.

Please refer to Appendix A: Equipment Inventory & Recommendations for more information about the equipment affected by this measure.

### 4.1.4 HVAC System Improvements

HVAC system improvement measures include several “submeasures” as outlined in Figure 20 below.

**Figure 20 - Summary of HVAC System Improvement ECMs**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Electric Unitary HVAC Measures</b>		452	0.3	0.0	0.0	0.0	0.0	\$59.47	\$2,177.52	\$0.00	\$2,177.52	36.61	456
ECM 6   Install Dual Enthalpy Outside Economizer Control	Yes	763	0.2	0.0	0.0	0.0	0.0	\$100.26	\$1,000.00	\$500.00	\$500.00	4.99	768



## ECM 6: Install Dual Enthalpy outside Economizer Control

### Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
763	0.2	0.0	\$100.26	\$1,000.00	\$500.00	\$500.00	4.99	768

### Measure Description

Dual enthalpy economizers are used to control a ventilation system’s outside air intake in order to reduce total cooling load. A dual enthalpy economizer monitors the air temperature and humidity of both the outside and return air. The control supplies the lowest energy (temperature and humidity) air to the air handling system. When outside air conditions allow, outside air can be used for cooling in place of the air handling system’s compressor. This reduces the demand on the cooling system, lowering its usage hours, saving energy. Savings result from using outside air instead of mechanical cooling whenever possible.

## 4.1.5 Domestic Water Heating Upgrade

Domestic water heating measures include several “submeasures” as outlined in Figure 21 below.

Figure 21 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
ECM 7   Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	627.2	0.0	0.0	627.2	\$3,178.16	\$1,052.16	\$0.00	\$1,052.16	0.33	73,436

## ECM 7: Install Low-Flow DHW Devices

### Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
0	0.0	627.2	\$3,178.16	\$1,052.16	\$0.00	\$1,052.16	0.33	73,436

### Measure Description

This measure evaluates the savings from installing low flow domestic water devices to reduce overall water flow in general and hot water flow in particular. Low flow showerheads and faucet aerators reduce the water flow, relative to standard showerheads and aerators, from the fixture. All of the low flow devices reduce the overall water flow from the fixture which generally reduces the amount of hot water used resulting in energy and water savings.

## 4.1.6 Food Service Equipment & Refrigeration Measures.

Food Service Equipment measures include several “submeasures” as outlined in Figure 22 below

**Figure 22 – Food Service Equipment & Refrigeration ECMs**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Natural Gas Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual N/A Savings (MMBtu)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Food Service Equipment &amp; Refrigeration Measures</b>		<b>3,701</b>	<b>0.4</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>\$486.60</b>	<b>\$12,853.88</b>	<b>\$925.00</b>	<b>\$11,928.88</b>	<b>24.51</b>	<b>3,727</b>
ECM 8 Dishwasher Replacement	Yes	1,213	0.1	0.0	0.0	0.0	0.0	\$159.44	\$4,341.88	\$400.00	\$3,941.88	24.72	1,221
ECM 9 Replace Refrigeration Equipment	Yes	2,489	0.3	0.0	0.0	0.0	0.0	\$327.15	\$8,512.00	\$525.00	\$7,987.00	24.41	2,506

### **ECM 8: Dishwasher Replacement**

#### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
1,213	0.1	0.0	\$159.44	\$4,341.88	\$400.00	\$3,941.88	24.72	1,221

#### *Measure Description*

We recommend the replacement of existing dishwasher with new energy efficient under-counter dishwasher. New high efficiency models often use an average of 40% less energy and water, compared to current standard efficiency equipment.

### **ECM 9: Replace Refrigeration Equipment**

#### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
2,489	0.3	0.0	\$327.15	\$8,512.00	\$525.00	\$7,987.00	24.41	2,506

#### *Measure Description*

We recommend replacing existing commercial refrigerator, freezers, with new Energy Star™ high efficiency equipment. There have been many improvements in refrigeration system equipment, operation, and insulation. The energy savings associated with this measure come from reduced energy usage, due to more efficient technology, and reduced run times.

## 4.1.7 Plug Load Equipment Control - Vending Machine

### **ECM 10: Vending Machine Control**

#### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
1,209	0.0	0.0	\$158.92	\$2,156.40	\$0.00	\$2,156.40	13.57	1,217

#### *Measure Description*

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor based controls to reduce the energy use. These controls power down the machine when the surrounding area is vacant, then monitor the surrounding temperature and power up the cooling system at regular intervals to keep the product cool. Savings are a function of the activity level around the vending machine.

## 5 ENERGY EFFICIENT PRACTICES

---

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of low or no-cost efficiency strategies. By employing certain behavioral and operational adjustments as well as performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and annual energy, operation, and maintenance costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

### Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

### Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

### Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

### Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

### Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

## **Perform Routine Motor Maintenance**

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

## **Use Fans to Reduce Cooling Load**

Utilizing ceiling fans to supplement cooling is a low cost strategy to reduce cooling load considerably. Thermostat settings can be increased by 4°F with no change in overall occupant comfort when the wind chill effect of moving air is employed for cooling.

## **Practice Proper Use of Thermostat Schedules and Temperature Resets**

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10 °F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

## **Clean Evaporator/Condenser Coils on AC Systems**

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

## **Clean and/or Replace HVAC Filters**

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

## **Check for and Seal Duct Leakage**

Duct leakage in commercial buildings typically accounts for 5 to 25 percent of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building, significantly increasing cooling and heating costs. By sealing sources of leakage, cooling, heating, and ventilation energy use can be reduced significantly, depending on the severity of air leakage.

## **Perform Proper Boiler Maintenance**

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side

of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up in order to sustain efficiency and equipment life.

### **Perform Proper Furnace Maintenance**

Preventative furnace maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should include tasks such as checking for gas / carbon monoxide leaks; changing the air and fuel filters; checking components for cracks, corrosion, dirt, or debris build-up; ensuring the ignition system is working properly; testing and adjusting operation and safety controls; inspecting the electrical connections; and ensuring proper lubrication for motors and bearings.

### **Perform Proper Water Heater Maintenance**

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

### **Plug Load Controls**

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to "Assessing and Reducing Plug and Process Loads in Office Buildings" <http://www.nrel.gov/docs/fy13osti/54175.pdf>, or "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>

### **Water Conservation**

Installing low flow faucets or faucet aerators, low flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low flow toilets and low flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.5 for any low-flow ECM recommendations.

## 6 SELF-GENERATION MEASURES

Self-generation measures include both renewable (e.g., solar, wind) and non-renewable (e.g., microturbines) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


### 6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a High potential for installing a PV array.

The amount of free area, ease of installation (roof top), and the lack of shading elements contribute to the high potential for PV at the site. A PV array located on the roof of the main building may be feasible. If Jewish Community Center of Somerset is interested in pursuing the installation of PV, we recommended a full feasibility study be conducted.

**Figure 22 - Photovoltaic Screening**



Potential	High	
System Potential	107	kW DC STC
Electric Generation	127,477	kWh/yr
Displaced Cost	\$11,090	/yr
Installed Cost	\$278,200	

Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SREC Registration Program prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey’s solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing. Refer to Section 8.6 for additional information.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1)

## 6.2 Combined Heat and Power

In non-industrial settings, combined heat and power (CHP) is the on-site generation of electricity and recovery of heat which is put to beneficial use. Common prime movers in CHP applications include reciprocating engines, microturbines, fuel cells, and (at large facilities) gas turbines. Electricity is typically interconnected to the sites local distribution system. Heat is recovered from the exhaust stream and the ancillary cooling system and interconnected to the existing hot water (or steam) distribution system.

CHP systems are typically used to produce a portion of the electricity needed by a facility, with the balance of electric needs satisfied by purchase from the grid. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility’s ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a Low potential for installing a cost-effective CHP system.


Low or infrequent thermal load, and lack of space near the existing thermal generation are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in NJ specializing in commercial CHP cost assessment and installation, go to:

[http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/)

**Figure 23 - Combined Heat and Power Screening**





Refer to Section **Error! Reference source not found.** for additional information in the Combined Heat & Power and Fuel Cell Program.

## 7 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and others, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s 1999 Electricity Restructuring Law which requires all customers of investor-owned electric and gas utilities to pay this charge on their monthly energy bills. As a contributor to the fund you were able to participate in the LGEA program and are also eligible to utilize the equipment incentive programs. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 24 for a list of the eligible programs identified for each recommended ECM.

**Figure 24 - ECM Incentive Program Eligibility**

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install
ECM 1	Install LED Fixtures	X		x
ECM 2	Retrofit Fixtures with LED Lamps	X		x
ECM 3	Install LED Exit Signs			X
ECM 4	Install Occupancy Sensor Lighting Controls	x		X
ECM 5	Install High Efficiency Electric AC	X		X
ECM 6	Install Dual Enthalpy Outside Economizer Control	x		X
ECM 7	Install Low-Flow Domestic Hot Water Devices			X
ECM 8	Dishwasher Replacement	x		X
ECM 9	Replace Refrigeration Equipment	x		X
ECM 10	Vending Machine Control			x

SmartStart is generally well suited for implementation of individual or small sets of measures, with the flexibility to install projects at your own pace using in-house staff or a preferred contractor. Direct Install (DI) caters to small to mid-size facilities to bundle measures and simplify participation, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities and requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption; applicants can use in-house staff or preferred contractor.

*Generally, the incentive values provided throughout the report assume the SS program is utilized because it provides a consistent comparison of available incentives.*

Brief descriptions of all relevant alternative financing and incentive programs are located in the sections below. You may also check the following website for further information, including most current program availability, requirements, and incentive levels: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 7.1 SmartStart

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. SmartStart offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

### **Equipment with Prescriptive Incentives Currently Available:**

*Electric Chillers*  
*Electric Unitary HVAC*  
*Gas Cooling*  
*Gas Heating*  
*Gas Water Heating*  
*Ground Source Heat Pumps*  
*Lighting*

*Lighting Controls*  
*Refrigeration Doors*  
*Refrigeration Controls*  
*Refrigerator/Freezer Motors*  
*Food Service Equipment*  
*Variable Frequency Drives*

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

### **Incentives**

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less. Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

### **How to Participate**

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB).

## 7.2 Direct Install

Direct Install (DI) is a turnkey program available to existing small to mid-sized facilities with a peak electric demand that did not exceed 200 kW in any of the preceding 12 months. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and install those measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

### **Incentives**

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

### **How to Participate**

To participate in the DI program you will need to contact the participating contractor assigned to the county where your facility is located; a complete list is provided on the DI website identified below. The contractor will be paid the program incentive directly which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps mentioned above, and the remaining 30% of the cost is your responsibility to the contractor.

Since DI offers a free assessment, LGEA applicants that do not meet the audit program eligibility requirements, but do meet the DI requirements, may be moved directly into this program.

Detailed program descriptions and applications can be found at: [www.njcleanenergy.com/DI](http://www.njcleanenergy.com/DI)

## 8 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 8.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

### 8.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service to customers who choose not to buy from a Third Party Supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

# Appendix A: Equipment Inventory & Recommendations

## Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Laura Office	2	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	None	No	2	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Office	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	4	LED - Linear Tubes: (2) U-Lamp	Wall Switch	40	5,694	0.07	566	0.0	\$74.44	\$252.80	\$0.00	3.40
Main Office	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.61	4,830	0.0	\$634.90	\$1,134.40	\$220.00	1.44
Data Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	5,694	0.08	637	0.0	\$83.74	\$150.40	\$30.00	1.44
Camp Office	2	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	None	No	2	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Reception Area	10	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	None	No	10	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Reception Area	1	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	79	0.0	\$10.41	\$107.56	\$0.00	10.33
Reception Area	5	Halogen Incandescent: PAR30 60W	Wall Switch	60	5,694	Fixture Replacement	No	5	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.20	1,576	0.0	\$207.24	\$318.26	\$25.00	1.42
Front Entrance	2	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	None	No	2	LED - Fixtures: Downlight Surface Mount	Occupancy Sensor	22	3,986	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Front Entrance	1	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	79	0.0	\$10.41	\$107.56	\$0.00	10.33
Library	1	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	79	0.0	\$10.41	\$107.56	\$0.00	10.33
Library	7	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	7	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.36	2,817	0.0	\$370.36	\$642.40	\$125.00	1.40
Hallway	32	LED - Fixtures: Downlight Surface Mount	Wall Switch	22	5,694	None	No	32	LED - Fixtures: Downlight Surface Mount	Wall Switch	22	5,694	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Hallway	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	5	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.13	1,062	0.0	\$139.57	\$292.50	\$50.00	1.74
Hallway	3	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.02	238	0.0	\$31.23	\$322.67	\$0.00	10.33
Multipurpose Room1	10	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	10	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.51	4,025	0.0	\$529.09	\$984.00	\$190.00	1.50
Multipurpose Room1	8	Incandescent: 4x60W Lamp/Fixture- Hanging Pendant	Wall Switch	60	5,694	Fixture Replacement	No	2	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.37	2,947	0.0	\$387.40	\$127.30	\$10.00	0.30
Multipurpose Room1	4	Incandescent: 60W Wall Sconce	Wall Switch	60	5,694	Fixture Replacement	No	4	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.16	1,261	0.0	\$165.79	\$254.60	\$20.00	1.42
Multipurpose Room1	16	Halogen Incandescent: Recessed PAR30 60W	Wall Switch	60	5,694	Fixture Replacement	No	16	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.64	5,044	0.0	\$663.15	\$1,018.42	\$80.00	1.42
Multipurpose Room1	1	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	79	0.0	\$10.41	\$107.56	\$0.00	10.33
Multipurpose Room2	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	8	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.41	3,220	0.0	\$423.27	\$833.60	\$160.00	1.59
Multipurpose Room2	1	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	79	0.0	\$10.41	\$107.56	\$0.00	10.33
Multipurpose Room2	3	Incandescent: 60W Wall Sconce	Wall Switch	60	5,694	Fixture Replacement	No	3	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.12	946	0.0	\$124.34	\$190.95	\$15.00	1.42
Multipurpose Room2	8	Incandescent: 4x60W Lamp/Fixture- Hanging Pendant	Wall Switch	60	5,694	Fixture Replacement	No	2	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.37	2,947	0.0	\$387.40	\$127.30	\$80.00	0.12
Multipurpose Room2	16	Incandescent: Recessed PAR30 60W	Wall Switch	60	5,694	Fixture Replacement	No	16	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.64	5,044	0.0	\$663.15	\$1,018.42	\$0.00	1.54

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Multipurpose Room3	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	No	12	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	5,694	0.48	3,822	0.0	\$502.44	\$902.40	\$180.00	1.44
Multipurpose Room3	2	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	158	0.0	\$20.82	\$215.11	\$0.00	10.33
Multipurpose Room3	2	Incandescent: 4x60W Lamp/Fixture- Hanging Pendant	Wall Switch	240	5,694	Fixture Replacement	No	2	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	11	5,694	0.37	2,947	0.0	\$387.40	\$127.30	\$10.00	0.30
Multipurpose Room3	16	Incandescent: Recessed PAR30 60W	Wall Switch	60	5,694	Fixture Replacement	Yes	16	LED - Fixtures: Downlight Solid State Retrofit	Occupancy Sensor	11	3,986	0.68	5,384	0.0	\$707.82	\$1,250.42	\$120.00	1.60
Kitchen	4	LED - Fixtures: Downlight Surface Mount	Wall Switch	40	5,694	None	No	4	LED - Fixtures: Downlight Surface Mount	Wall Switch	40	5,694	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Kitchen	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.25	2,012	0.0	\$264.54	\$492.00	\$95.00	1.50
Women's Bathroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.15	1,207	0.0	\$158.73	\$341.60	\$65.00	1.74
Mens Bathroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.15	1,207	0.0	\$158.73	\$341.60	\$65.00	1.74
Mens Bathroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.05	425	0.0	\$55.83	\$117.00	\$20.00	1.74
Gym Stage	1	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	5,694	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.10	830	0.0	\$109.12	\$58.50	\$10.00	0.44
Hallway Betw 2 Bldg	3	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.02	238	0.0	\$31.23	\$322.67	\$0.00	10.33
Hallway Betw 2 Bldg	1	LED - Fixtures: Downlight Surface Mount	Wall Switch	22	5,694	None	No	1	LED - Fixtures: Downlight Surface Mount	Wall Switch	22	5,694	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Hallway Betw 2 Bldg	2	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	5,694	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.21	1,660	0.0	\$218.23	\$117.00	\$20.00	0.44
Exterior Perimeter Light	17	Metal Halide: (1) 100W Lamp	Daylight Dimming	128	2,847	Fixture Replacement	No	17	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	45	2,847	1.15	4,539	0.0	\$596.75	\$6,641.51	\$1,700.00	8.28
Exterior Perimeter Light	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	40	2,847	None	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	40	2,847	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Exterior Perimeter Light	4	Metal Halide: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	150	2,847	Fixture Replacement	No	4	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	45	2,847	0.34	1,351	0.0	\$177.63	\$1,562.71	\$400.00	6.55
Exterior Perimeter Light	4	Metal Halide: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	400	2,847	Fixture Replacement	No	4	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	146	2,847	0.83	3,269	0.0	\$429.70	\$1,562.71	\$400.00	2.71
Exterior Perimeter Bath-Womens	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.31	2,415	0.0	\$317.45	\$567.20	\$110.00	1.44
Exterior Perimeter Bath-Womens	1	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	79	0.0	\$10.41	\$107.56	\$0.00	10.33
Exterior Perimeter Mens-Womens	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.31	2,415	0.0	\$317.45	\$567.20	\$110.00	1.44
Exterior Perimeter Mens-Womens	1	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	79	0.0	\$10.41	\$107.56	\$0.00	10.33
Hallway To Indoor Pool	2	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	158	0.0	\$20.82	\$215.11	\$0.00	10.33
Telecom Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.03	212	0.0	\$27.91	\$58.50	\$10.00	1.74
Men's Locker Room	10	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	10	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.51	4,025	0.0	\$529.09	\$868.00	\$170.00	1.32
Men's Locker Room	2	Exit Signs: Incandescent	Wall Switch	14	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	Wall Switch	6	8,760	0.01	158	0.0	\$20.82	\$215.11	\$0.00	10.33

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Men's Locker Room	1	Linear Fluorescent - T5: 2 T5 (14W) - 2L	Wall Switch	20	5,694	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	5,694	0.00	19	0.0	\$2.54	\$48.20	\$10.00	15.05
Men's Locker Room	1	Halogen Incandescent: Ceiling Mounted CFL 26W	Wall Switch	26	5,694	Fixture Replacement	No	1	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	13	5,694	0.01	84	0.0	\$11.00	\$63.65	\$5.00	5.33
Director Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.10	805	0.0	\$105.82	\$266.40	\$50.00	2.05
Fitness Room	18	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	No	18	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	5,694	0.72	5,733	0.0	\$753.66	\$1,353.60	\$270.00	1.44
Fitness Room	2	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	158	0.0	\$20.82	\$215.11	\$0.00	10.33
Mechanical Room	11	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	11	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.30	2,336	0.0	\$307.05	\$643.50	\$110.00	1.74
Spin Studio	20	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	20	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	1.02	8,049	0.0	\$1,058.17	\$1,620.00	\$320.00	1.23
Spin Studio	2	Exit Signs: Incandescent	Wall Switch	14	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	Wall Switch	6	8,760	0.01	158	0.0	\$20.82	\$215.11	\$0.00	10.33
Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	5,694	0.04	318	0.0	\$41.87	\$75.20	\$15.00	1.44
Gymnasium	24	Linear Fluorescent - T8: 4' T8 (32W) - 6L	Wall Switch	176	5,694	Relamp	No	24	LED - Linear Tubes: (6) 4' Lamps	Wall Switch	87	5,694	1.74	13,743	0.0	\$1,806.76	\$3,221.36	\$0.00	1.78
Gymnasium	3	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.02	238	0.0	\$31.23	\$322.67	\$0.00	10.33
Gym Spin Studio	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	5,694	0.04	318	0.0	\$41.87	\$75.20	\$15.00	1.44
Snack Bar	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,986	0.20	1,610	0.0	\$211.63	\$416.80	\$80.00	1.59
Snack Bar	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.03	212	0.0	\$27.91	\$58.50	\$10.00	1.74
Storage Room2	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.05	425	0.0	\$55.83	\$117.00	\$20.00	1.74
Storage Room1	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.05	425	0.0	\$55.83	\$117.00	\$20.00	1.74
Indoor Pool	8	Metal Halide: (1) 400W Lamp Hanging Pendant	Wall Switch	400	5,694	Fixture Replacement	No	8	LED - Fixtures: Parking Garage Fixture	Wall Switch	146	5,694	1.65	13,074	0.0	\$1,718.79	\$11,289.60	\$800.00	6.10
Indoor Pool	3	Exit Signs: Incandescent	None	14	8,760	Fixture Replacement	No	3	LED Exit Signs: 2 W Lamp	None	6	8,760	0.02	238	0.0	\$31.23	\$322.67	\$0.00	10.33
Staff Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,694	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	5,694	0.04	318	0.0	\$41.87	\$75.20	\$15.00	1.44
Indoor Pool Ext. Light	3	Metal Halide: (1) 150W Lamp Wall Pack	Daylight Dimming	150	2,847	Fixture Replacement	No	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	45	2,847	0.26	1,013	0.0	\$133.22	\$1,172.03	\$300.00	6.55
Pump Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,694	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,694	0.05	425	0.0	\$55.83	\$117.00	\$20.00	1.74
Roof Top Light	4	Incandescent: Pole Lighting 60W	Daylight Dimming	60	2,847	Fixture Replacement	No	4	LED - Fixtures: Downlight Solid State Retrofit	Daylight Dimming	11	2,847	0.16	631	0.0	\$82.89	\$254.60	\$20.00	2.83



### Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Pump Room	Pump Room	2	Other	2.0	64.0%	No	2,745	No	64.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Pump Room	Pump Room	1	Other	1.0	64.0%	No	2,745	No	64.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Pump Room	Pump Room	1	Water Supply Pump	15.0	89.0%	No	3,391	No	89.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Gym Spin Studio	Gym Spin Studio	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		Yes	0.22	608	0.0	\$79.87	\$1,588.76	\$250.00	16.76
Indoor Pool Staff Room	Indoor Pool Staff Room	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		Yes	0.22	608	0.0	\$79.87	\$1,588.76	\$250.00	16.76
Roof Top	Main Building	2	Packaged Terminal AC	15.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof Top	Main Building	6	Packaged Terminal AC	12.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis							
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Pump Room	Indoor Pool	1	Condensing Hot Water Boiler	143.00	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### DHW Inventory & Recommendations

		Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Storage Room 1	Early Childhood Building	1	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Pump Room	Indoor Pool	1	Tankless Water Heater	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Low-Flow Device Recommendations

		Recommendation Inputs			Energy Impact & Financial Analysis							
Location	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Kitchen	1	Faucet Aerator (Kitchen)	5.50	2.20	0.00	0	18.8	\$95.07	\$7.17	\$0.00	0.08	
Womens Bathroom	3	Faucet Aerator (Lavatory)	3.50	1.00	0.00	0	42.6	\$216.06	\$21.51	\$0.00	0.10	
Womens Bathroom	5	Pre-Rinse Spray Valve	2.50	1.15	0.00	0	322.4	\$1,633.44	\$621.75	\$0.00	0.38	
Mens Bathroom	3	Faucet Aerator (Lavatory)	3.50	1.00	0.00	0	42.6	\$216.06	\$21.51	\$0.00	0.10	
Mens Bathroom	3	Pre-Rinse Spray Valve	2.50	1.15	0.00	0	193.4	\$980.07	\$373.05	\$0.00	0.38	
Snack Bar	1	Faucet Aerator (Kitchen)	3.50	2.20	0.00	0	7.4	\$37.45	\$7.17	\$0.00	0.19	

### Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Refrigerator/Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Outside Pump Room	1	Stand-Up Freezer, Solid Door (31 - 50 cu. ft.)	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Novelty Cooler Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis							
	Quantity	Cooler Description	Install Automatic Shutoff Control?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Kitchen	1	Freezer	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	
Kitchen	1	Freezer	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	
Kitchen	1	Freezer	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	

### Cooking Equipment Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Equipment Type	High Efficiency Equipment?	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Electric Combination Oven/Steam Cooker (<15 Pans)	Yes	No	0.00	0	0.0	\$0.00	\$15,789.30	\$1,000.00	0.00
Kitchen	1	Electric Combination Oven/Steam Cooker (<15 Pans)	Yes	No	0.00	0	0.0	\$0.00	\$15,789.30	\$1,000.00	0.00

### Dishwasher Inventory & Recommendations

Existing Conditions						Proposed Conditions	Energy Impact & Financial Analysis						
Location	Quantity	Dishwasher Type	Water Heater Fuel Type	Booster Heater Fuel Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Payback w/ Incentives in Years
Kitchen	1	Under Counter (Low Temp)	Electric	N/A	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Plug Load Inventor

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Main Building	37	Desktop Computer	110.0	Yes
Main Office	1	Printer	46.0	Yes
Main Office	1	Water Foutain	35.0	Yes
Main Office	1	Printer	46.0	Yes
Main Office	1	Printer	16.0	Yes
Main Office	1	Printer Multifunction	760.0	Yes
Kitchen	1	Microwave	1,000.0	No
Kitchen	1	Coffee Machine	700.0	No
Kitchen	1	Microwave	1,000.0	No
Kitchen	1	Toaster	800.0	No
Fitness Room	4	Ceiling Fan	35.0	No
Fitness Room	3	TV ( hanging)	128.0	Yes
Fitness Room	2	Small Wall Fan	10.0	Yes
Spin Studio	6	Ceiling Fan	35.0	No
Gym Spin Studio	4	Small Wall Fan	10.0	Yes
Snack Bar	1	Chest Freezer	250.0	No
Snack Bar	1	Microwave	1,000.0	No
Indoor Pool	2	Big Floor Fan	250.0	No

### Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Hallway	1	Glass Fronted Refrigerated	No	0.00	0	0.0	\$0.00	\$718.80	\$0.00	0.00
Hallway	1	Non-Refrigerated	No	0.00	0	0.0	\$0.00	\$718.80	\$0.00	0.00
Snack Bar	1	Glass Fronted Refrigerated	Yes	0.00	1,209	0.0	\$158.92	\$718.80	\$0.00	4.52

# Appendix B: ENERGY STAR® Statement of Energy Performance

## ENERGY STAR® Statement of Energy Performance

LEARN MORE AT [energystar.gov](http://energystar.gov)

# N/A

ENERGY STAR® Score<sup>1</sup>

**Jewish Community Center - S, H & W Counties, Inc**

**Primary Property Type:** Mixed Use Property  
**Gross Floor Area (ft²):** 36,000  
**Built:** 1999

**For Year Ending:** February 29, 2016  
**Date Generated:** September 30, 2016

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address	Property Owner	Primary Contact
Jewish Community Center - S, H & W Counties, Inc 775 Talamini Rd Bridgewater, New Jersey 08807 Property ID: 5086064	_____ ( ) - _____	_____ ( ) - _____

Energy Consumption and Energy Use Intensity (EUI)				
<b>Site EUI</b>	<b>Annual Energy by Fuel</b>		<b>National Median Comparison</b>	
183.8 kBtu/ft²	Natural Gas (kBtu) 4,613,213 (70%)	Electric - Grid (kBtu) 2,002,688 (30%)	National Median Site EUI (kBtu/ft²)	73.2
			National Median Source EUI (kBtu/ft²)	123.1
			% Diff from National Median Source EUI	151%
<b>Source EUI</b>			<b>Annual Emissions</b>	
309.2 kBtu/ft²			Greenhouse Gas Emissions (Metric Tons CO2e/year)	513

**Signature & Stamp of Verifying Professional**

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**Licensed Professional**

\_\_\_\_\_  
( ) - \_\_\_\_\_  
\_\_\_\_\_



Professional Engineer Stamp (if applicable)

## Appendix C: Photo Gallery



Main Hallway




Indoor Pool Utica Cast iron Boiler



Indoor Pool




Indoor Pool Exterior View



Outdoor pools



Gymnasium



Fitness Room



Roofs



Parking Lot View from the Roof Top