



Local Government Energy Audit: Energy Audit Report



Copyright ©2016 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Administration Building

Union County Vocational-Technical
Schools

1776 Raritan Road

Scotch Plains, NJ 07076

January 23, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary	6
1.1	Facility Summary	6
1.2	Your Cost Reduction Opportunities.....	6
	Energy Conservation Measures.....	6
	Energy Efficient Practices	7
	On-Site Generation Measures.....	8
	Implementation Planning.....	8
2	Facility Information and Existing Conditions	10
2.1	Project Contacts	10
2.2	General Site Information.....	10
2.3	Building Occupancy	10
2.4	Building Envelope	10
2.5	Energy-Using Systems	11
	Lighting System	11
	Direct Expansion Air Conditioning System (DX)	11
	Domestic Hot Water Heating System.....	11
	Building Plug Load	12
2.6	Water-Using Systems	12
3	Site Energy Use and Costs	13
3.1	Total Cost of Energy	13
3.2	Electricity Usage	14
3.3	Natural Gas Usage	15
3.4	Benchmarking.....	16
3.5	Energy End-Use Breakdown	18
4	Energy Conservation Measures	19
4.1	Recommended ECMs	19
4.1.1	Lighting Upgrades.....	20
	ECM 1: Install LED Fixtures.....	20
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	21
	ECM 3: Retrofit Fixtures with LED Lamps.....	21
4.1.2	Lighting Control Measures	22
	ECM 4: Install Occupancy Sensor Lighting Controls	22
5	Energy Efficient Practices	23
	Reduce Air Leakage	23
	Close Doors and Windows	23
	Use Window Treatments/Coverings	23
	Perform Proper Lighting Maintenance.....	23
	Develop a Lighting Maintenance Schedule	23
	Ensure Lighting Controls Are Operating Properly	24
	Turn Off Unneeded Motors.....	24
	Perform Routine Motor Maintenance	24

Use Fans to Reduce Cooling Load	24
Practice Proper Use of Thermostat Schedules and Temperature Resets	24
Ensure Economizers are Functioning Properly.....	24
Clean Evaporator/Condenser Coils on AC Systems.....	25
Clean and/or Replace HVAC Filters	25
Check for and Seal Duct Leakage	25
Perform Proper Furnace Maintenance	25
Perform Proper Water Heater Maintenance	25
Plug Load Controls.....	25
Replace Computer Monitors	26
Water Conservation	26
6 On-Site Generation Measures	27
6.1 Photovoltaic.....	27
7 Demand Response	29
8 Project Funding / Incentives	30
8.1 SmartStart	31
8.2 Direct Install	32
8.3 Energy Savings Improvement Program	32
9 Energy Purchasing and Procurement Strategies	34
9.1 Retail Electric Supply Options.....	34
9.2 Retail Natural Gas Supply Options	34

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs.....	7
Figure 2 – Potential Post-Implementation Costs	7
Figure 3 – Summary of Energy Reduction Opportunities	7
Figure 4 – Project Contacts	10
Figure 5 - Building Schedule.....	10
Figure 6 - Utility Summary	13
Figure 7 - Energy Cost Breakdown	13
Figure 8 - Electric Usage & Demand.....	14
Figure 9 - Electric Usage & Demand.....	14
Figure 10 - Natural Gas Usage.....	15
Figure 11 - Natural Gas Usage.....	15
Figure 12 - Energy Use Intensity Comparison – Existing Conditions.....	16
Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures	16
Figure 14 - Energy Balance (% and kBtu/SF)	18
Figure 15 – Summary of Recommended ECMs.....	19
Figure 16 – Summary of Lighting Upgrade ECMs.....	20
Figure 17 – Summary of Lighting Control ECMs	22
Figure 18 - Photovoltaic Screening	27
Figure 19 - ECM Incentive Program Eligibility	30

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Union County Vocational- Technical Schools (UCVTS) Administration Building. The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments and schools in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

UCVTS - Administration Building is a one-story, 6,824 square foot facility comprised of general office space with a small kitchen. The Administration Building acts as the central offices for the Union County Vocational- Technical Schools (UCTVS). The facility was built in 2007 and is in good condition.

The lighting system consists of standard wattage T8 lamps with a combination of pendant mount, lay in fixtures, indirect fixtures, and wall scones. The heating ventilation and cooling (HVAC) system consists of one Trane packaged unit that feeds variable air volume boxes in the space. The facility has a Trane DDC control system that appeared to be operating effectively during the site visit.

A more thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated four (4) measures which together represent an opportunity for UCVTS - Administration Building to reduce annual energy costs by roughly \$2,080 and annual greenhouse gas emissions by 16,771 lbs CO₂e. We estimate that if all measures were implemented as recommended, the project would pay for itself in 11.3 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce UCVTS - Administration Building's annual energy use by 5%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of UCVTS - Administration Building's existing energy use can be found in Section 3. Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			13,104	2.2	0.0	\$1,636.56	\$21,436.00	\$810.00	\$20,626.00	12.6	13,196
ECM 1	Install LED Fixtures	Yes	3,075	0.5	0.0	\$384.01	\$4,500.00	\$0.00	\$4,500.00	11.7	3,096
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	8,415	1.4	0.0	\$1,050.91	\$10,440.00	\$810.00	\$9,630.00	9.2	8,473
ECM 3	Retrofit Fixtures with LED Lamps	Yes	1,615	0.3	0.0	\$201.65	\$6,496.00	\$0.00	\$6,496.00	32.2	1,626
Lighting Control Measures			3,551	0.6	0.0	\$443.45	\$3,364.00	\$580.00	\$2,784.00	6.3	3,576
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	3,551	0.6	0.0	\$443.45	\$3,364.00	\$580.00	\$2,784.00	6.3	3,576
TOTALS			16,655	2.8	0.0	\$2,080.01	\$24,800.00	\$1,390.00	\$23,410.00	11.3	16,771

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measure save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Energy Efficient Practices

TRC also identified 19 low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at UCVTS - Administration Building include:

- Reduce Air Leakage
- Close Doors and Windows
- Use Window Treatments/Coverings
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Turn Off Unneeded Motors
- Perform Routine Motor Maintenance
- Use Fans to Reduce Cooling Load
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Ensure Economizers are Functioning Properly
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Check for and Seal Duct Leakage
- Perform Proper Furnace Maintenance
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Replace Computer Monitors
- Water Conservation

For details on these Energy Efficient Practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-Site generation for UCVTS - Administration Building. Based on the configuration of the site and its loads there is a low potential for installing solar photovoltaic (PV) and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements. Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the

final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated DI contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8 or www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Jim Ferris	Consultant	jferris@jfpconsulting.net	(908) 347-3784
Mark Leary	Facilities Director	mleary@ucvts.org	
TRC Energy Services			
Brian Dattellas	Auditor	bdattellas@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On January 1, 2017, TRC performed an energy audit at UCVTS - Administration Building located in Scotch Plains, New Jersey. TRCs' team met with Mark Leary, Facilities Director to review the facility operations and help focus our investigation on specific energy-using systems.

UCVTS - Administration Building is a 6,824 square foot facility comprised of office space and is used as the central administrative facility for Union County Vocational-Technical Schools.

2.3 Building Occupancy

The Administration Building operates on weekdays from 7 am to 7 pm. The building is occupied by approximately 10 Union County Vocational-Technical Schools staff members.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Administration Building	Weekday	7:00am - 7:00pm
Administration Building	Weekend	none

2.4 Building Envelope

The building appears constructed from concrete block, and structural steel with a stone facade. The building has pitched roofs covered with black membrane and steel planks. The roof is in good condition. The buildings have double pane windows which are also in good condition and show little sign of excessive infiltration. The exterior doors are constructed of aluminum and in good condition. The facility sits on a concrete slab.

2.5 Energy-Using Systems

Lighting System

The lighting system consists of standard wattage T8 lamps with a combination of pendant mount, lay in fixtures, indirect fixtures and, wall scones. All can and recessed fixtures were found to be outfitted with compact fluorescent lamps. This system was found to be in good condition. The current system is a good candidate for an LED retrofit/re-lamp which would lead to maximum energy savings with minimal investment.

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's lighting equipment.



Figure 1 Front Entrance with Typical CFL Lighting

Direct Expansion Air Conditioning System (DX)

A 30-ton Carrier direct-expansion (DX) package unit with a gas-fired furnace and outside air economizer conditions the building. The unit is located on the ground of the south half of the building. It provides constant air volume with a single 10 hp supply fan and a 2 hp return fan. The terminal units in the space are variable air volume boxes. The unit uses a scroll compressor and a DX coil. An outside air economizer to uses free cooling when the outside air temperature is lower than the return air temperature. The gas-fired furnace provides heating as needed.

Domestic Hot Water Heating System

The domestic hot water heating system consists of one (1) RUUD gas-fired hot water heater with an input rating of 1,000 kBtu/hr each and a nominal efficiency of 88%. The water heater has a 50-gallon storage tank.




Figure 2 Trane Control System

Building Plug Load

There are roughly 27 computer work stations throughout the facility. There are three (3) small printers and one (1) large printer operating in the facility.

The kitchen/staff room has some basic cooking equipment and a refrigerator. The facility has one (1) refrigerated beverage vending machine.

2.6 Water-Using Systems

There are 4 (four) restrooms. Faucets are rated for 1.5 gallons per minute (gpm), the toilets are rated at 2.5 gallons per flush (gpf) and the urinals are rated at 2 gpf.




Figure 3 Facility Drawing

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for UCVTS - Administration Building		
Fuel	Usage	Cost
Electricity	197,680 kWh	\$24,688
Natural Gas	3,951 Therms	\$3,710
Total		\$28,398

The current annual energy cost for this facility is \$28,398 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.125/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for UCVTS - Administration Building					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
5/20/15	29	15,120	49	\$216	\$1,847
6/19/15	30	9,040	46	\$579	\$1,159
7/21/15	32	23,040	56	\$698	\$3,029
8/19/15	29	14,960	55	\$689	\$2,146
9/18/15	30	15,040	40	\$502	\$2,041
10/19/15	31	13,920	50	\$221	\$1,770
11/19/15	31	18,000	52	\$231	\$2,128
12/18/15	29	23,280	50	\$234	\$2,590
1/21/16	34	24,480	52	\$254	\$2,736
2/19/16	29	15,520	54	\$242	\$1,888
3/21/16	31	12,960	45	\$201	\$1,698
4/20/16	30	12,320	43	\$195	\$1,654
Totals	365	197,680	56	\$4,261	\$24,688
Annual	365	197,680	56	\$4,261	\$24,688

3.3 Natural Gas Usage

Natural gas is provided by Elizabethtown Gas. The average gas cost for the past 12 months is \$0.939/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for UCVTS - Administration Building			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
5/20/15	29	212	\$232
6/19/15	30	28	\$70
7/21/15	32	0	\$5
8/19/15	29	0	\$72
9/18/15	30	0	\$144
10/19/15	31	0	\$5
11/19/15	31	2	\$70
12/18/15	29	84	\$128
1/21/16	34	213	\$218
2/19/16	29	1,231	\$1,097
3/21/16	31	1,712	\$1,147
4/20/16	30	470	\$522
Totals	365	3,951	\$3,710
Annual	365	3,951	\$3,710

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building's consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility's energy consumption per square foot, and it is the standard metric for comparing buildings' energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of "site energy" and "source energy." Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	UCVTS - Administration Building	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	371.1	148.1
Site Energy Use Intensity (kBtu/ft ²)	156.7	67.3

Implementation of all recommended measures in this report would improve the building's estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	UCVTS - Administration Building	National Median Building Type: Office
Source Energy Use Intensity (kBtu/ft ²)	345.0	148.1
Site Energy Use Intensity (kBtu/ft ²)	148.4	67.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building's energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification.

A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the UCVTS - Administration Building regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom Smart Start or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive Smart Start program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,104	2.2	0.0	\$1,636.56	\$21,436.00	\$810.00	\$20,626.00	12.6	13,196
ECM 1	Install LED Fixtures	3,075	0.5	0.0	\$384.01	\$4,500.00	\$0.00	\$4,500.00	11.7	3,096
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	8,415	1.4	0.0	\$1,050.91	\$10,440.00	\$810.00	\$9,630.00	9.2	8,473
ECM 3	Retrofit Fixtures with LED Lamps	1,615	0.3	0.0	\$201.65	\$6,496.00	\$0.00	\$6,496.00	32.2	1,626
Lighting Control Measures		3,551	0.6	0.0	\$443.45	\$3,364.00	\$580.00	\$2,784.00	6.3	3,576
ECM 4	Install Occupancy Sensor Lighting Controls	3,551	0.6	0.0	\$443.45	\$3,364.00	\$580.00	\$2,784.00	6.3	3,576
TOTALS		16,655	2.8	0.0	\$2,080.01	\$24,800.00	\$1,390.00	\$23,410.00	11.3	16,771

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Recommended upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,104	2.2	0.0	\$1,636.56	\$21,436.00	\$810.00	\$20,626.00	12.6	13,196
ECM 1	Install LED Fixtures	3,075	0.5	0.0	\$384.01	\$4,500.00	\$0.00	\$4,500.00	11.7	3,096
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	8,415	1.4	0.0	\$1,050.91	\$10,440.00	\$810.00	\$9,630.00	9.2	8,473
ECM 3	Retrofit Fixtures with LED Lamps	1,615	0.3	0.0	\$201.65	\$6,496.00	\$0.00	\$6,496.00	32.2	1,626

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	3,075	0.5	0.0	\$384.01	\$4,500.00	\$0.00	\$4,500.00	11.7	3,096

Measure Description

We recommend replacing existing fixtures containing fluorescent lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten (10) times longer than many incandescent lamps.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	8,415	1.4	0.0	\$1,050.91	\$10,440.00	\$810.00	\$9,630.00	9.2	8,473
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten (10) times longer than many incandescent lamps.

ECM 3: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	1,615	0.3	0.0	\$201.65	\$6,496.00	\$0.00	\$6,496.00	32.2	1,626
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing T8 and compact fluorescent system with an LED system. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes.

4.1.2 Lighting Control Measures

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		3,551	0.6	0.0	\$443.45	\$3,364.00	\$580.00	\$2,784.00	6.3	3,576
ECM 4	Install Occupancy Sensor Lighting Controls	3,551	0.6	0.0	\$443.45	\$3,364.00	\$580.00	\$2,784.00	6.3	3,576

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 4: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,551	0.6	0.0	\$443.45	\$3,364.00	\$580.00	\$2,784.00	6.3	3,576

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in all restrooms, storage rooms, classrooms, offices areas, etc. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Use Window Treatments/Coverings

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming set points and sensitivity are appropriately configured.

Turn Off Unneeded Motors

Electric motors often run unnecessarily, and this is an overlooked opportunity to save energy. These motors should be identified and turned off when appropriate. For example, exhaust fans often run unnecessarily when ventilation requirements are already met. Reducing run hours for these motors can result in significant energy savings. Whenever possible, use automatic devices such as twist timers or occupancy sensors to ensure that motors are turned off when not needed.

Perform Routine Motor Maintenance

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Use Fans to Reduce Cooling Load

Utilizing ceiling fans to supplement cooling is a low cost strategy to reduce cooling load considerably. Thermostat settings can be increased by 4°F with no change in overall occupant comfort when the wind chill effect of moving air is employed for cooling.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating set points and increase cooling set points). Cooling load can be reduced further by increasing the facility's occupied set point temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Ensure Economizers are Functioning Properly

Economizers, when properly configured, can be used to significantly reduce mechanical cooling. However, if the outdoor thermostat or enthalpy control is malfunctioning or the damper is stuck or improperly adjusted, benefits from the economizer may not be fully realized. As such, periodic inspection and maintenance is required to ensure proper operation. This maintenance should be scheduled with maintenance of the facility's air conditioning system and should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position. A malfunctioning economizer can significantly increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Check for and Seal Duct Leakage

Duct leakage in commercial buildings typically accounts for 5% to 25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building, significantly increasing cooling and heating costs. By sealing sources of leakage, cooling, heating, and ventilation energy use can be reduced significantly, depending on the severity of air leakage.

Perform Proper Furnace Maintenance

Preventative furnace maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should include tasks such as checking for gas / carbon monoxide leaks; changing the air and fuel filters; checking components for cracks, corrosion, dirt, or debris build-up; ensuring the ignition system is working properly; testing and adjusting operation and safety controls; inspecting the electrical connections; and ensuring proper lubrication for motors and bearings.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

Replace Computer Monitors

Replacing old computer monitors or displays with efficient monitors will reduce energy use. ENERGY STAR® rated monitors have specific requirements for on mode power consumption as well as idle and sleep mode power. According to the ENERGY STAR® website monitors that have earned the ENERGY STAR® label are 25% more efficient than standard monitors.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-Site Generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility's electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has a low potential for installing a PV array. The pitched roofing structure would make it more difficult to mount a solar array. This is the main reason why the system potential is low.

If UCVTS - Administration Building is interested in pursuing the installation of PV, we recommended a more detailed study specific to solar feasibility at the site be conducted.

Figure 18 - Photovoltaic Screening



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey's Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 19 for a list of the eligible programs identified for each recommended ECM.

Figure 19 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	x		x			
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	x		x			
ECM 3	Retrofit Fixtures with LED Lamps	x		x			
ECM 4	Install Occupancy Sensor Lighting Controls	x		x			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey's largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity's annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for a recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

How to Participate

To participate in the Direct Install program you will need to contact the participating contractor who the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since Direct Install offers a free assessment of eligible measures, Direct Install is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by

the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Parking Lot	9	Halogen Incandescent: Pole Mount	None	100	4,000	LED Retrofit	No	9	LED - Fixtures: Architectural Flood/Spot Luminaire	None	27	4,000	0.52	3,075	0.0	\$384.01	\$4,500.00	\$0.00	11.72
Exit Signs	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Common Area	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.02	99	0.0	\$12.33	\$232.00	\$30.00	16.38
Boiler Room	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,000	LED Retrofit	Yes	3	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,800	0.12	728	0.0	\$90.92	\$464.00	\$35.00	4.72
Boiler Room	5	Compact Fluorescent: Wall Scones	Wall Switch	17	4,000	LED Retrofit	Yes	5	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.02	119	0.0	\$14.90	\$696.00	\$20.00	45.36
Office 1	9	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	9	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.15	889	0.0	\$110.99	\$1,160.00	\$110.00	9.46
Office 1 Bath	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Occupancy Sensor	33	4,000	LED Retrofit	No	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	4,000	0.03	150	0.0	\$18.70	\$232.00	\$20.00	11.33
Office 1 Side	4	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.07	395	0.0	\$49.33	\$580.00	\$60.00	10.54
Womans Bath Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,000	LED Retrofit	Yes	2	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,800	0.03	205	0.0	\$25.54	\$348.00	\$30.00	12.45
Womans Bath Room	4	Compact Fluorescent: 3 - Pin CFL	Wall Switch	32	4,000	LED Retrofit	Yes	4	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.06	376	0.0	\$46.99	\$580.00	\$20.00	11.92
Mens Bath	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,000	LED Retrofit	Yes	2	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,800	0.03	205	0.0	\$25.54	\$348.00	\$30.00	12.45
Mens Bath	4	Compact Fluorescent: 4 - Pin CFL	Wall Switch	32	4,000	LED Retrofit	Yes	4	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.06	376	0.0	\$46.99	\$580.00	\$20.00	11.92
Board Room	21	Halogen Incandescent: MR- 16	Wall Switch	16	4,000	LED Retrofit	Yes	21	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.07	403	0.0	\$50.32	\$2,552.00	\$20.00	50.31
Board Room	6	Halogen Incandescent: Par- 30	Wall Switch	30	4,000	LED Retrofit	Yes	6	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.09	508	0.0	\$63.48	\$812.00	\$20.00	12.48
Board Room	2	Compact Fluorescent: Circular Fixture	Wall Switch	56	4,000	LED Retrofit	Yes	2	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.07	413	0.0	\$51.55	\$348.00	\$20.00	6.36
Board Room	10	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,000	LED Retrofit	Yes	10	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,800	0.17	1,023	0.0	\$127.71	\$1,276.00	\$70.00	9.44
Kitchen	8	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	8	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.13	790	0.0	\$98.66	\$1,044.00	\$100.00	9.57
Office 2	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,000	LED Retrofit	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,800	0.07	390	0.0	\$48.75	\$348.00	\$40.00	6.32
Office 2	6	Compact Fluorescent: 3 - Pin CFL	Wall Switch	32	4,000	LED Retrofit	Yes	6	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.10	564	0.0	\$70.49	\$812.00	\$20.00	11.24
Office 3	3	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	3	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.05	296	0.0	\$37.00	\$464.00	\$50.00	11.19
Office 4	3	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	3	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.05	296	0.0	\$37.00	\$464.00	\$50.00	11.19
Office 5	6	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	6	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.10	592	0.0	\$74.00	\$812.00	\$80.00	9.89
Back Office	8	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	8	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.13	790	0.0	\$98.66	\$1,044.00	\$100.00	9.57
Side Office Area	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,000	LED Retrofit	Yes	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.08	469	0.0	\$58.57	\$348.00	\$40.00	5.26
Superintendents Office	4	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.07	395	0.0	\$49.33	\$580.00	\$60.00	10.54

Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Superintendents Office	10	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	10	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.17	987	0.0	\$123.33	\$1,276.00	\$120.00	9.37
Bathroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	4,000	LED Retrofit	Yes	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	2,800	0.02	99	0.0	\$12.33	\$232.00	\$30.00	16.38
Bathroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	22	4,000	LED Retrofit	Yes	1	LED - Linear Tubes: (1) 2' Lamp	Occupancy Sensor	9	2,800	0.01	75	0.0	\$9.38	\$232.00	\$25.00	22.07
Side Vestibul	8	Halogen Incandescent: Side Mount	Wall Switch	17	4,000	LED Retrofit	Yes	8	LED Screw-In Lamps: LED Lamp	Occupancy Sensor	17	2,800	0.03	191	0.0	\$23.85	\$1,044.00	\$20.00	42.94
Storage 1	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,000	LED Retrofit	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,800	0.10	585	0.0	\$73.12	\$464.00	\$50.00	5.66
Storage 2	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,000	LED Retrofit	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,800	0.13	781	0.0	\$97.49	\$580.00	\$60.00	5.33
Mechanical Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,000	LED Retrofit	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,800	0.07	390	0.0	\$48.75	\$348.00	\$40.00	6.32

Motor Inventory & Recommendations

		Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Administration Building	Administration Building	1	Supply Fan	15.0	89.0%	Yes	4,000	No	89.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Administration Building	Administration Building	1	Return Fan	2.5	85.0%	No	4,000	No	85.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

		Existing Conditions				Proposed Conditions								Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Administration Building	Administration Building	1	Packaged AC	40.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

		Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Administration Building	Administration Building	1	Furnace	250.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00


DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical Room	Administration Building	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
PC	12	Personal Computer	1,000.0	No

Appendix B: ENERGY STAR® Statement of Energy Performance




ENERGY STAR® Statement of Energy Performance

1

Administration Building

Primary Property Type: Office
Gross Floor Area (ft²): 6,824
Built: 2007

For Year Ending: April 30, 2016
Date Generated: June 05, 2017



ENERGY STAR®
Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information				
Property Address Administration Building 1776 Raritan Road Scotch Plains, New York 07076		Property Owner Union County Schools 1776 Raritan Road Scotch Plains, NJ 07076 () -	Primary Contact Mark Leary 1776 Raritan Road Scotch Plains, NJ 07076 (908) 654-9860 mleary@ucvts.org	
Property ID: 5910604				
Energy Consumption and Energy Use Intensity (EUI)				
Site EUI	Annual Energy by Fuel		National Median Comparison	
162.2 kBtu/ft ²	Electric - Grid (kBtu)	674,009 (61%)	National Median Site EUI (kBtu/ft ²)	60.6
	Natural Gas (kBtu)	432,573 (39%)	National Median Source EUI (kBtu/ft ²)	140.8
			% Diff from National Median Source EUI	167%
Source EUI	Annual Emissions		Annual Emissions	
376.7 kBtu/ft ²			Greenhouse Gas Emissions (Metric Tons CO2e/year)	100

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

Brian Dattellas
1430 Broadway
10th Floor
New York, NY 10018
5166339063
BDattellas@trcsolutions.com



Professional Engineer Stamp
(if applicable)