



# Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

## **Police Crime Scene Unit**

59 South Olden Avenue  
Trenton, New Jersey 08609  
City of Trenton  
December 31, 2018

Final Report by:

**TRC Energy Services**

## **Disclaimer**

---

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

# Table of Contents

---

<b>1 Executive Summary .....</b>	<b>1</b>
1.1 Facility Summary .....	1
1.2 Your Cost Reduction Opportunities.....	1
Energy Conservation Measures.....	1
Energy Efficient Practices .....	2
On-Site Generation Measures.....	3
1.3 Implementation Planning .....	3
<b>2 Facility Information and Existing Conditions .....</b>	<b>5</b>
2.1 Project Contacts .....	5
2.2 General Site Information .....	5
2.3 Building Occupancy .....	5
2.4 Building Envelope .....	6
2.5 On-Site Generation.....	6
2.6 Energy-Using Systems .....	7
Lighting System .....	7
Direct Expansion Air Conditioning System (DX) .....	8
Domestic Hot Water Heating System.....	8
Building Plug Load .....	8
2.7 Water-Using Systems .....	8
<b>3 Site Energy Use and Costs .....</b>	<b>9</b>
3.1 Total Cost of Energy .....	9
3.2 Electricity Usage .....	10
3.3 Natural Gas Usage .....	11
3.4 Benchmarking.....	12
3.5 Energy End-Use Breakdown .....	13
<b>4 Energy Conservation Measures.....</b>	<b>14</b>
4.1 Recommended ECMs .....	14
4.1.1 Lighting Upgrades.....	15
ECM 1: Install LED Fixtures.....	15
ECM 2: Retrofit Fixtures with LED Lamps.....	16
4.1.2 Lighting Control Measures .....	17
ECM 3: Install Occupancy Sensor Lighting Controls .....	17
ECM 4: Install High/Low Lighting Controls .....	18
<b>5 Energy Efficient Practices .....</b>	<b>19</b>
Close Doors and Windows .....	19
Use Window Treatments/Coverings .....	19
Perform Proper Lighting Maintenance.....	19
Develop a Lighting Maintenance Schedule .....	19
Ensure Lighting Controls Are Operating Properly .....	19
Practice Proper Use of Thermostat Schedules and Temperature Resets .....	20

---

Clean Evaporator/Condenser Coils on AC Systems .....	20
Perform Proper Water Heater Maintenance .....	20
Water Conservation .....	20
<b>6 On-Site Generation Measures .....</b>	<b>21</b>
6.1    Photovoltaic.....	22
6.2    Combined Heat and Power .....	23
<b>7 Demand Response .....</b>	<b>24</b>
<b>8 Project Funding / Incentives .....</b>	<b>25</b>
8.1    SmartStart .....	26
8.2    Direct Install .....	27
8.3    Energy Savings Improvement Program .....	28
<b>9 Energy Purchasing and Procurement Strategies .....</b>	<b>29</b>
9.1    Retail Electric Supply Options.....	29
9.2    Retail Natural Gas Supply Options .....	29

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

## Table of Figures

---

Figure 1 – Previous 12 Month Utility Costs.....	1
Figure 2 – Potential Post-Implementation Costs .....	1
Figure 3 – Summary of Energy Reduction Opportunities .....	2
Figure 4 – Project Contacts .....	5
Figure 5 - Building Schedule.....	5
Figure 6 - Utility Summary .....	9
Figure 7 - Energy Cost Breakdown .....	9
Figure 8 - Electric Usage & Demand.....	10
Figure 9 - Electric Usage & Demand.....	10
Figure 10 - Natural Gas Usage.....	11
Figure 11 - Natural Gas Usage.....	11
Figure 12 - Energy Use Intensity Comparison – Existing Conditions.....	12
Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures .....	12
Figure 14 - Energy Balance (% and kBtu/SF) .....	13
Figure 15 – Summary of Recommended ECMs.....	14
Figure 16 – Summary of Lighting Upgrade ECMs.....	15
Figure 17 – Summary of Lighting Control ECMs .....	17
Figure 18 - Photovoltaic Screening .....	22
Figure 19 - Combined Heat and Power Screening .....	23
Figure 20 - ECM Incentive Program Eligibility.....	25

## I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for the Police Crime Scene Unit.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

### I.1 Facility Summary

The Police Crime Scene Unit is a two-story 4,508 square foot facility comprised of various space types such as offices, an exam room, lab, vehicle bay, a basement, and restrooms.


Lighting at Police Crime Scene Unit primarily consists of 4' linear fluorescent T8 fixtures. The building is conditioned by eleven split-system air-source heat pumps that appear to be in good operating condition. A thorough description of the facility and our observations are located in Section 2.

### I.2 Your Cost Reduction Opportunities


#### Energy Conservation Measures

TRC evaluated four measures which together represent an opportunity for Police Crime Scene Unit to reduce annual energy costs by roughly \$3,511 and annual greenhouse gas emissions by 22,807 lbs CO<sub>2</sub>e. We estimate that if all measures were implemented as recommended, the project would pay for itself in roughly 2.0 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Police Crime Scene Unit's annual energy use by 35%.

**Figure 1 – Previous 12 Month Utility Costs**



**Figure 2 – Potential Post-Implementation Costs**



A detailed description of the Police Crime Scene Unit's existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

**Figure 3 – Summary of Energy Reduction Opportunities**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)	
<b>Lighting Upgrades</b>											
ECM 1   Install LED Fixtures	Yes	3,534	0.6	0.0	\$547.80	\$2,897.90	\$300.00	\$2,597.90	4.7	3,559	
ECM 2   Retrofit Fixtures with LED Lamps	Yes	15,764	2.5	0.0	\$2,443.62	\$3,879.43	\$1,060.00	\$2,819.43	1.2	15,874	
<b>Lighting Control Measures</b>											
ECM 3   Install Occupancy Sensor Lighting Controls	Yes	3,158	0.5	0.0	\$489.49	\$1,890.00	\$245.00	\$1,645.00	3.4	3,180	
ECM 4   Install High/Low Lighting Controls	Yes	193	0.0	0.0	\$29.87	\$200.00	\$140.00	\$60.00	2.0	194	
<b>TOTALS FOR HIGH PRIORITY MEASURES</b>			<b>22,648</b>	<b>3.6</b>	<b>0.0</b>	<b>\$3,510.78</b>	<b>\$8,867.33</b>	<b>\$1,745.00</b>	<b>\$7,122.33</b>	<b>2.0</b>	<b>22,807</b>
<b>TOTALS FOR ALL EVALUATED MEASURES</b>			<b>22,648</b>	<b>3.6</b>	<b>0.0</b>	<b>\$3,510.78</b>	<b>\$8,867.33</b>	<b>\$1,745.00</b>	<b>\$7,122.33</b>	<b>2.0</b>	<b>22,807</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

**Lighting Upgrades** generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

**Lighting Controls** measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

## **Energy Efficient Practices**

TRC also identified nine low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at the Police Crime Scene Unit include:

- Close Doors and Windows
- Use Window Treatments/Coverings
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean Evaporator/Condenser Coils on AC Systems
- Perform Proper Water Heater Maintenance
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

## On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for the Police Crime Scene Unit. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

## I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 2 FACILITY INFORMATION AND EXISTING CONDITIONS

### 2.1 Project Contacts

*Figure 4 – Project Contacts*

Name	Role	E-Mail	Phone #
<b>Customer</b>			
Hoggarth Stephen	Principal Engineer	hstephen@trentonnj.org	(609) 989-3615
<b>TRC Energy Services</b>			
Vish Nimbalkar	Auditor	VNaikNimbalkar@trcsolutions.com	(732) 855-0033

### 2.2 General Site Information

On April 27, 2018, TRC performed an energy audit at the Police Crime Scene Unit located in Trenton, New Jersey. TRC's team met with Hoggarth Stephen to review the facility operations and help focus our investigation on specific energy-using systems.

The Police Crime Scene Unit is a two-story 4,508 square foot facility comprised of various space types such as offices, an exam room, lab, vehicle bay, a basement, and restrooms.

Lighting at Police Crime Scene Unit primarily consists of 4' linear fluorescent T8 fixtures. The building is conditioned by five split-system air-source heat pumps (eleven indoor units and five outdoor units) that appear to be in good operating condition.

The building was constructed in 1913. Over the last eight years the facility has replaced all of its existing T12 fluorescent fixtures with T8 fluorescent fixtures as well as upgrading their compact fluorescent exit signs with LED exit signs.

### 2.3 Building Occupancy

The building is open as needed, seven days a week. The typical schedule is presented in the table below.

*Figure 5 - Building Schedule*

Building Name	Weekday/Weekend	Operating Schedule
Police Crime Scene Unit	Weekday	5AM - 9PM
Police Crime Scene Unit	Weekend	9AM - 5PM

## 2.4 Building Envelope

The building has a masonry bearing wall structure with brick exterior walls and plaster on the interior. The windows are single pane wooden framed, with the majority of them having exterior storm windows. The exterior doors are either wooden or steel with the garage doors being wooden and the entry doors being either wooden or steel. The roof is a sloped asphalt shingle over plywood on wooden rafters.



Image 1 – Building Envelope

## 2.5 On-Site Generation

Police Crime Scene Unit does not have any on-site electric generation capacity.

## 2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

### Lighting System

Lighting at the facility is provided mostly by 32-Watt linear fluorescent T8 lamps with electronic ballasts as well as some compact fluorescent lamps (CFL) and a few LED screw-in lamps. Most of the fixtures are 2-lamp, 3-lamp, or 4-lamp, 4-foot long troffers with diffusers.

A small area of the basement is lit with 60-Watt screw-in incandescent lamps.

Lighting control in most spaces is provided by manually operated wall switches.

The building's exterior lighting is minimal and consists of high pressure sodium (HPS) fixtures that are controlled by photocells.



Image 2 – Typical linear fluorescent fixtures



Image 3 – Exterior fixture

### **Direct Expansion Air Conditioning System (DX)**

There are five outdoor air-source heat pump condensers serving 11 indoor fan coil units that supply heating and cooling to the building. The outdoor units are located on the roof of the building and the indoor units are located in the various interior spaces.



Image 4 – Indoor unit (ductless heat pump fan coil)



Image 5 – Outdoor units (condensers)

### **Domestic Hot Water Heating System**

The domestic hot water heating system for the facility consists of a single 25-gallon Rheem gas fired water heater with an input rating of 70 MBH and a nominal efficiency of 80%.

### **Building Plug Load**

There are eight computer work stations at this facility. The remaining plug loads are made up of typical office and break room equipment and include the following:

- Small Xerox copier
- Large copier
- Toaster oven
- Microwave
- Refrigerator
- Server rack

## **2.7 Water-Using Systems**

There is a single restroom at this facility with a shower, sink and toilet, all of which are low flow.

## 3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

### 3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

*Figure 6 - Utility Summary*

Utility Summary for Police Crime Scene Unit		
Fuel	Usage	Cost
Electricity	51,880 kWh	\$8,042
Natural Gas	444 Therms	\$444
Total		\$8,486

The current annual energy cost for this facility is \$8,486 as shown in the chart below.


*Figure 7 - Energy Cost Breakdown*



### 3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.155/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. Higher electrical demand during the peak cooling and heating periods is typical for a building heated and cooled with electric air-source heat pumps. The monthly electricity consumption and peak demand are shown in the chart below.

*Figure 8 - Electric Usage & Demand*




*Figure 9 - Electric Usage & Demand*

Electric Billing Data for Police Crime Scene Unit					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
2/5/16	29	5,360	13		\$655
3/8/16	32	5,860	13		\$710
4/7/16	30	3,900	10		\$748
5/6/16	29	3,260	12		\$796
6/7/16	32	3,140	12		\$523
7/7/16	30	3,360	12		\$550
8/5/16	29	5,120	17		\$815
9/6/16	32	5,340	17		\$847
10/5/16	29	3,220	15		\$562
11/3/16	29	2,460	10		\$314
12/6/16	33	3,980	11		\$486
1/6/17	31	6,880	15		\$1,035
<b>Totals</b>	<b>365</b>	<b>51,880</b>	<b>17</b>	<b>\$0</b>	<b>\$8,042</b>
<b>Annual</b>	<b>365</b>	<b>51,880</b>	<b>17</b>	<b>\$0</b>	<b>\$8,042</b>

### 3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.999/therm, which is the estimated blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

*Figure 10 - Natural Gas Usage*



*Figure 11 - Natural Gas Usage*

Gas Billing Data for Police Crime Scene Unit			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
2/5/15	29	138	\$109
3/8/15	32	77	\$65
4/7/15	30	25	\$28
5/6/15	29	24	\$27
6/7/15	32	24	\$27
7/7/15	30	21	\$25
8/5/15	29	20	\$25
9/6/16	32	22	\$26
10/5/16	29	20	\$25
11/3/16	29	21	\$26
12/6/16	33	26	\$30
1/6/17	31	26	\$30
<b>Totals</b>	<b>365</b>	<b>444</b>	<b>\$444</b>
<b>Annual</b>	<b>365</b>	<b>444</b>	<b>\$444</b>

### 3.4 Benchmarking

This facility was benchmarked using Portfolio Manager®, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager® analyzes your building's consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility's energy consumption per square foot, and it is the standard metric for comparing buildings' energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of "site energy" and "source energy." Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

**Figure 12 - Energy Use Intensity Comparison – Existing Conditions**

Energy Use Intensity Comparison - Existing Conditions		
	Police Crime Scene Unit	National Median Building Type: Fire/Police Station
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	133.6	154.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	49.1	88.3

Implementation of all recommended measures in this report would improve the building's estimated EUI significantly, as shown in the table below:

**Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures**


Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Police Crime Scene Unit	National Median Building Type: Fire/Police Station
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	79.8	154.4
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	32.0	88.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building's energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. This facility does not currently qualify for an ENERGY STAR® score.

### 3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



## 4 ENERGY CONSERVATION MEASURES

### *Level of Analysis*

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Police Crime Scene Unit regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMS identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

### 4.1 Recommended ECMS

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

*Figure 15 – Summary of Recommended ECMS*

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>									
ECM 1   Install LED Fixtures	3,534	0.6	0.0	\$547.80	\$2,897.90	\$300.00	\$2,597.90	4.7	3,559
ECM 2   Retrofit Fixtures with LED Lamps	15,764	2.5	0.0	\$2,443.62	\$3,879.43	\$1,060.00	\$2,819.43	1.2	15,874
<b>Lighting Control Measures</b>									
ECM 3   Install Occupancy Sensor Lighting Controls	3,158	0.5	0.0	\$489.49	\$1,890.00	\$245.00	\$1,645.00	3.4	3,180
ECM 4   Install High/Low Lighting Controls	193	0.0	0.0	\$29.87	\$200.00	\$140.00	\$60.00	2.0	194
<b>TOTALS</b>	<b>22,648</b>	<b>3.6</b>	<b>0.0</b>	<b>\$3,510.78</b>	<b>\$8,867.33</b>	<b>\$1,745.00</b>	<b>\$7,122.33</b>	<b>2.0</b>	<b>22,807</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

#### 4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 16 below.

**Figure 16 – Summary of Lighting Upgrade ECMs**

Energy Conservation Measure				Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>				19,298	3.1	0.0	\$2,991.42	\$6,777.33	\$1,360.00	\$5,417.33	1.8	19,433
ECM 1	Install LED Fixtures			3,534	0.6	0.0	\$547.80	\$2,897.90	\$300.00	\$2,597.90	4.7	3,559
ECM 2	Retrofit Fixtures with LED Lamps			15,764	2.5	0.0	\$2,443.62	\$3,879.43	\$1,060.00	\$2,819.43	1.2	15,874

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

#### ECM 1: Install LED Fixtures

##### *Summary of Measure Economics*

Interior/Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	3,534	0.6	0.0	\$547.80	\$2,897.90	\$300.00	\$2,597.90	4.7	3,559

##### *Measure Description*

We recommend replacing existing exterior fixtures containing HID lamps with new high-performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes greater than HID sources.

## **ECM 2: Retrofit Fixtures with LED Lamps**

### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	15,764	2.5	0.0	\$2,443.62	\$3,879.43	\$1,060.00	\$2,819.43	1.2	15,874
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

### *Measure Description*

We recommend retrofitting the existing incandescent, CFL, and fluorescent fixtures with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies, including compact fluorescent. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tube.

#### 4.1.2 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 17 below.

**Figure 17 – Summary of Lighting Control ECMs**

Energy Conservation Measure			Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>			3,350	0.5	0.0	\$519.36	\$2,090.00	\$385.00	\$1,705.00	3.3	3,374
ECM 3	Install Occupancy Sensor Lighting Controls		3,158	0.5	0.0	\$489.49	\$1,890.00	\$245.00	\$1,645.00	3.4	3,180
ECM 4	Install High/Low Lighting Controls		193	0.0	0.0	\$29.87	\$200.00	\$140.00	\$60.00	2.0	194

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

#### ECM 3: Install Occupancy Sensor Lighting Controls

##### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
3,158	0.5	0.0	\$489.49	\$1,890.00	\$245.00	\$1,645.00	3.4	3,180

##### *Measure Description*

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

## **ECM 4: Install High/Low Lighting Controls**

### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
193	0.0	0.0	\$29.87	\$200.00	\$140.00	\$60.00	2.0	194

### *Measure Description*

We recommend installing occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons. Typical areas for such lighting control are stairwells, interior corridors, parking lots, and parking garages.

Lighting fixtures with these controls operate at default low levels when the area is not occupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. The lighting systems are switched to full lighting levels whenever an occupant is detected. Fixtures are automatically switched back to low level after an area has been vacant for a preset period of time. Energy savings results from only providing full lighting levels when it is required.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage needs to be provided to ensure that lights turn on in each area as an occupant approaches.

Additional savings from reduced lighting maintenance may also result from this measure, due to reduced lamp operation.

## 5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

### **Close Doors and Windows**

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

### **Use Window Treatments/Coverings**

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

### **Perform Proper Lighting Maintenance**

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

### **Develop a Lighting Maintenance Schedule**

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

### **Ensure Lighting Controls Are Operating Properly**

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

## **Practice Proper Use of Thermostat Schedules and Temperature Resets**

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

## **Clean Evaporator/Condenser Coils on AC Systems**

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

## **Perform Proper Water Heater Maintenance**

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

## **Water Conservation**

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gallons per minute (gpm) for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

## 6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


## 6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility's electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has a **low** potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

**Figure 18 - Photovoltaic Screening**



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1)

## 6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility's ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a **low** potential for installing a cost-effective CHP system.

Low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: [http://www.nicleanenergy.com/commercial-industrial/programs/ni-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/](http://www.nicleanenergy.com/commercial-industrial/programs/ni-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/).

**Figure 19 - Combined Heat and Power Screening**



## 7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csp.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

**In our opinion, the facility is not a good candidate for DR.**

## 8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey's Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 20 for a list of the eligible programs identified for each recommended ECM.

*Figure 20 - ECM Incentive Program Eligibility*

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	X		X			
ECM 2	Retrofit Fixtures with LED Lamps	X		X			
ECM 3	Install Occupancy Sensor Lighting Controls	X		X			
ECM 4	Install High/Low Lighting Controls	X		X			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 8.1 SmartStart

### Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

#### **Equipment with Prescriptive Incentives Currently Available:**

*Electric Chillers*

*Electric Unitary HVAC*

*Gas Cooling*

*Gas Heating*

*Gas Water Heating*

*Ground Source Heat Pumps*

*Lighting*

*Lighting Controls*

*Refrigeration Doors*

*Refrigeration Controls*

*Refrigerator/Freezer Motors*

*Food Service Equipment*

*Variable Frequency Drives*

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

### Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

### How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB).

## 8.2 Direct Install

### Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for a recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

### Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

### How to Participate

To participate in the Direct Install program you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since Direct Install offers a free assessment of eligible measures, Direct Install is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: [www.njcleanenergy.com/DI](http://www.njcleanenergy.com/DI).

### 8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter into contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: [www.njcleanenergy.com/ESIP](http://www.njcleanenergy.com/ESIP).

*Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.*

## 9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

### 9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third-party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility is purchasing electricity from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

### 9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility is purchasing natural gas from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

## Appendix A: Equipment Inventory & Recommendations

### Lighting Inventory & Recommendations

Location	Fixture Quantity	Existing Conditions			Proposed Conditions					Energy Impact & Financial Analysis									
		Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Vehicle Bay	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,912	Relamp	No	8	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,912	0.36	1,474	0.0	\$228.52	\$584.24	\$160.00	1.86
Restroom	2	Compact Fluorescent 1 - 13W CFL	Wall Switch	13	728	Relamp	No	2	LED Screw-In Lamps: (1) 6W LED screw-in	Wall Switch	6	728	0.01	12	0.0	\$1.79	\$48.42	\$0.00	27.12
Exam Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,184	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,184	0.03	81	0.0	\$12.62	\$36.52	\$10.00	2.10
Lab	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	4,900	Relamp	Yes	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,430	0.48	3,251	0.0	\$504.00	\$854.24	\$195.00	1.31
Lab	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,900	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,900	0.05	365	0.0	\$56.65	\$73.03	\$20.00	0.94
Stairwell	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,900	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,900	0.05	365	0.0	\$56.65	\$73.03	\$20.00	0.94
2nd Floor Top of Stairs	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,900	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	3,430	0.14	924	0.0	\$143.17	\$346.06	\$180.00	1.16
2nd Floor Main Room	14	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	4,900	Relamp	Yes	14	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,430	0.71	4,849	0.0	\$751.62	\$1,036.82	\$245.00	1.05
2nd Floor Main Room	5	Linear Fluorescent - T8: 2' T8 (17W) - 4L	Wall Switch	63	4,900	Relamp	Yes	5	LED - Linear Tubes: (4) 2' Lamps	Occupancy Sensor	34	3,430	0.16	1,085	0.0	\$168.23	\$595.15	\$135.00	2.74
2nd Floor Front Office	4	Linear Fluorescent - T8: 2' T8 (17W) - 4L	Wall Switch	63	4,900	Relamp	Yes	4	LED - Linear Tubes: (4) 2' Lamps	Occupancy Sensor	34	3,430	0.13	868	0.0	\$134.58	\$530.12	\$115.00	3.08
2nd Floor Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,900	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,900	0.05	365	0.0	\$56.65	\$73.03	\$20.00	0.94
Basement	3	LED Screw-In Lamps: 1 - 6W Screw-in LED	Wall Switch	6	4,900	None	No	3	LED Screw-In Lamps: 1 - 6W Screw-in LED	Wall Switch	6	4,900	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Basement	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,900	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,900	0.05	365	0.0	\$56.65	\$73.03	\$20.00	0.94
Basement	2	Incandescent: 1 - 60W Screw-in Incandescent	Wall Switch	60	4,900	Relamp	No	2	LED Screw-In Lamps: (1) 6W LED screw-in	Wall Switch	6	4,900	0.09	598	0.0	\$92.70	\$48.42	\$0.00	0.52
Break Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	4,900	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,430	0.20	1,385	0.0	\$214.75	\$489.09	\$95.00	1.84
Main Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	4,900	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,430	0.31	2,078	0.0	\$322.12	\$598.64	\$125.00	1.47
Main Office	2	Linear Fluorescent - T8: 2' T8 (17W) - 4L	Wall Switch	63	4,900	Relamp	No	2	LED - Linear Tubes: (4) 2' Lamps	Wall Switch	34	4,900	0.05	321	0.0	\$49.78	\$130.06	\$40.00	1.81
Main Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,900	Relamp	Yes	6	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	3,430	0.11	726	0.0	\$112.52	\$379.55	\$65.00	2.80
Whole Building	7	Exit signs: LED - 2 W Lamp	None	6	8,760	None	No	7	Exit signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Exterior	3	High-Pressure Sodium: (1) 250W Lamp	Daylight Dimming	295	4,380	Fixture Replacement	No	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	57	4,380	0.58	3,534	0.0	\$547.80	\$2,897.90	\$300.00	4.74

## Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kWh Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Vehicle Bay	Vehicle Bay	1	Exhaust Fan	0.3	68.5%	No	320	No	68.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Lab	Fume hood	1	Exhaust Fan	0.3	68.5%	No	2,745	No	68.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

## Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis								
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Vehicle Bay	Vehicle Bay	2	Split-System Air-Source HP	2.00	24.00	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2nd Flr	stairwell/hallway	1	Split-System Air-Source HP	1.00	13.60	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Lab	Lab	1	Split-System Air-Source HP	2.00	24.00	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Rm	Main Rm	2	Split-System Air-Source HP	1.00	13.60	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom	Restroom	1	Split-System Air-Source HP	1.00	13.60	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Break Room	Break Room	1	Split-System Air-Source HP	1.00	13.60	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Office	Main Office	2	Split-System Air-Source HP	1.00	13.60	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Office	Main Office	1	Split-System Air-Source HP	1.00	13.60	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

## DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis					
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak KW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mech Rm	Break room/Restrooms/Lab	1	Storage Tank Water Heater (<= 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

## Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Office	1	Small Xerox Printer	350.0	Yes
Office	1	Large Copier	1,400.0	Yes
Breakroom	1	Large Toaster Oven	1,000.0	No
Breakroom	1	Microwave	1,000.0	
Breakroom	1	Refigerator/Freezer	600.0	
Office	8	Computer Work Stations	110.0	

## Appendix B: ENERGY STAR® Statement of Energy Performance



# N/A

### Police Crime Scene Unit

Primary Property Type: Police Station  
 Gross Floor Area (ft<sup>2</sup>): 4,508  
 Built: 1976

ENERGY STAR®  
 Score<sup>1</sup>

For Year Ending: January 31, 2017  
 Date Generated: October 09, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

#### Property & Contact Information

Property Address	Property Owner	Primary Contact
Police Crime Scene Unit 59 South Olden Avenue Trenton, New Jersey 08609	City of Trenton 319 East State Street Trenton, NJ 08618 (____) ____ - _____	Hoggarth Stephen 319 East State Street Trenton, NJ 08618 6099993615 hstephen@trentonnj.org

Property ID: 5992167

#### Energy Consumption and Energy Use Intensity (EUI)

Site EUI 48.1 kBtu/ft <sup>2</sup>	Annual Energy by Fuel	National Median Comparison	
		National Median Site EUI (kBtu/ft <sup>2</sup> )	49.6
	Electric - Grid (kBtu) 181,738 (84%)	National Median Source EUI (kBtu/ft <sup>2</sup> )	124.9
	Natural Gas (kBtu) 35,279 (16%)	% Diff from National Median Source EUI	-3%
<b>Source EUI</b> 121.1 kBtu/ft <sup>2</sup>		<b>Annual Emissions</b> Greenhouse Gas Emissions (Metric Tons CO2e/year)	

#### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Licensed Professional

\_\_\_\_\_  
(\_\_\_\_) \_\_\_\_ - \_\_\_\_\_  
\_\_\_\_\_



Professional Engineer Stamp  
(if applicable)