



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Municipal Building

Township of Waterford

2131 Auburn Avenue
Atco, NJ 08004

10/15/2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	6
1.1	Facility Summary	6
1.2	Your Cost Reduction Opportunities.....	6
	Energy Conservation Measures.....	6
	Energy Efficient Practices	8
	On-Site Generation Measures.....	8
1.3	Implementation Planning.....	8
2	Facility Information and Existing Conditions	10
2.1	Project Contacts	10
2.2	General Site Information.....	10
2.3	Building Occupancy	10
2.4	Building Envelope	10
2.5	On-Site Generation.....	11
2.6	Energy-Using Systems	11
	Lighting System	11
	Hot Water Heating System.....	12
	Direct Expansion Air Conditioning System (DX)	12
	Domestic Hot Water Heating System.....	13
	Building Plug Load	13
2.7	Water-Using Systems	14
3	Site Energy Use and Costs.....	15
3.1	Total Cost of Energy	15
3.2	Electricity Usage	16
3.3	Natural Gas Usage	17
3.4	Benchmarking.....	18
3.5	Energy End-Use Breakdown	19
4	Energy Conservation Measures	20
4.1	Recommended ECMs	20
4.1.1	Lighting Upgrades.....	21
	ECM 1: Install LED Fixtures	21
	ECM 2: Retrofit Fixtures with LED Lamps.....	21
4.1.2	Lighting Control Measures	22
	ECM 3: Install Occupancy Sensor Lighting Controls	22
	ECM 4: Install High/Low Lighting Controls	23
4.1.3	Motor Upgrades	24
	ECM 5: Premium Efficiency Motors.....	24
4.1.4	Variable Frequency Drive Measures	25
	ECM 6: Install VFDs on Hot Water Pumps.....	25

ECM 7: Install VFDs on Cooling Tower Fans	25
5 Energy Efficient Practices	27
Reduce Air Leakage	27
Use Window Treatments/Coverings	27
Perform Regular Lighting Maintenance	27
Develop a Lighting Maintenance Schedule	27
Ensure Lighting Controls Are Operating Properly	27
Clean Evaporator/Condenser Coils on AC Systems	28
Clean and/or Replace HVAC Filters	28
Perform Regular Boiler Maintenance.....	28
Perform Regular Water Heater Maintenance	28
Plug Load Controls.....	28
Water Conservation	28
6 On-Site Generation Measures	30
6.1 Photovoltaic.....	30
6.2 Combined Heat and Power	31
7 Demand Response	32
8 Project Funding / Incentives	33
8.1 SmartStart	34
8.2 Direct Install	35
8.3 Energy Savings Improvement Program	35
9 Energy Purchasing and Procurement Strategies	37
9.1 Retail Electric Supply Options.....	37
9.2 Retail Natural Gas Supply Options	37

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 7

Figure 2 – Potential Post-Implementation Costs 7

Figure 3 – Summary of Energy Reduction Opportunities 7

Figure 4 – Project Contacts 10

Figure 5 - Building Schedule..... 10

Figure 6 - Utility Summary 15

Figure 7 - Energy Cost Breakdown 15

Figure 8 - Graph of Electric Usage & Demand 16

Figure 9 - Table of Electric Usage & Demand..... 16

Figure 10 - Graph of Natural Gas Usage 17

Figure 11 - Table of Natural Gas Usage..... 17

Figure 12 - Energy Use Intensity Comparison – Existing Conditions..... 18

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 18

Figure 14 - Energy Balance (% and kBtu/SF) 19

Figure 15 – Summary of Recommended ECMs..... 20

Figure 16 – Summary of Lighting Upgrade ECMs..... 21

Figure 17 – Summary of Lighting Control ECMs 22

Figure 18 – Summary of Variable Frequency Drive ECMs 25

Figure 19 - Photovoltaic Screening 30

Figure 20 - Combined Heat and Power Screening 31

Figure 21 - ECM Incentive Program Eligibility..... 33

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for Municipal Building.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

The Municipal Building is a 11,750 square-foot, single story building comprised of municipal offices, police station with a holding cell, and court room. The building is occupied year-round.

The roofing systems consists of a center flat roof surrounded by pitched roof with standing metal seam covering. The exterior walls are finished with brick veneer and concrete block. The windows throughout the facility are a combination of single and double paned with metal frames.

Lighting consists primarily of aging linear fluorescent fixtures. Most of the heating and cooling is provided by multiple water source heat pumps which are served by a closed loop cooling tower and a condensing boiler. Additionally, there are two air-source heat pumps that provide heating and cooling to some of the offices. Restrooms are heated with electric resistance heat baseboards. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated seven measures which together represent an opportunity to reduce annual energy costs by \$8,186 and annual greenhouse gas emissions by 49,207 lbs. CO₂e. We estimate that if all measures were implemented as recommended, the project would pay for itself in roughly 4.6 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce the Municipal Building's annual energy use by 20%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Municipal Building’s existing energy use can be found in Section 3 “Site Energy Use and Costs.”

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4, “Energy Conservation Measures.”

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Dem and Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		29,533	6.7	0.0	\$4,947.48	\$22,665.86	\$3,050.00	\$19,615.86	4.0	29,740
ECM 1 Install LED Fixtures	Yes	9,572	1.5	0.0	\$1,603.54	\$10,156.03	\$1,000.00	\$9,156.03	5.7	9,639
ECM 2 Retrofit Fixtures with LED Lamps	Yes	19,961	5.2	0.0	\$3,343.93	\$12,509.82	\$2,050.00	\$10,459.82	3.1	20,101
Lighting Control Measures		4,044	1.0	0.0	\$677.48	\$8,076.00	\$945.00	\$7,131.00	10.5	4,072
ECM 3 Install Occupancy Sensor Lighting Controls	Yes	3,603	0.9	0.0	\$603.59	\$7,676.00	\$945.00	\$6,731.00	11.2	3,628
ECM 4 Install High/Low Lighting Controls	Yes	441	0.1	0.0	\$73.89	\$400.00	\$0.00	\$400.00	5.4	444
Motor Upgrades		132	0.0	0.0	\$22.05	\$1,229.49	\$0.00	\$1,229.49	55.8	133
ECM 5 Premium Efficiency Motors	Yes	132	0.0	0.0	\$22.05	\$1,229.49	\$0.00	\$1,229.49	55.8	133
Variable Frequency Drive (VFD) Measures		15,157	1.3	0.0	\$2,539.11	\$9,827.55	\$0.00	\$9,827.55	3.9	15,263
ECM 6 Install VFDs on Hot Water Pumps	Yes	10,180	1.3	0.0	\$1,705.45	\$6,551.70	\$0.00	\$6,551.70	3.8	10,252
ECM 7 Install VFDs on Cooling Tower Fans	Yes	4,976	0.0	0.0	\$833.67	\$3,275.85	\$0.00	\$3,275.85	3.9	5,011
TOTALS		48,866	9.0	0.0	\$8,186.12	\$41,798.90	\$3,995.00	\$37,803.90	4.6	49,207

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Motor Upgrades generally involve replacing older standard efficiency motors with high efficiency standard (IHP 2014). Motors replacements generally assume the same size motors, just higher efficiency. Although occasionally additional savings can be achieved by downsizing motors to better meet current

load requirements. This measure saves energy by reducing the power used by the motors, due to improved electrical efficiency.

Variable Frequency Drives (VFDs) are motor control devices. These measures control the speed of a motor so that the motor spins at peak efficiency during partial load conditions. Sensors adapt the speed to flow, temperature, or pressure settings which is much more efficient than using a valve or damper to control flow rates, or running the motor at full speed when only partial power is needed. These measures save energy by controlling motor usage more efficiently.

Energy Efficient Practices

TRC Energy Services also identified 11 low cost or no cost energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Municipal Building include:

- Reduce Air Leakage
- Use Window Treatments/Coverings
- Perform Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Perform Boiler Maintenance
- Perform Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these Energy Efficient Practices, please refer to Section 5.

On-Site Generation Measures

TRC Energy Services evaluated the potential for installing on-site generation for Municipal Building. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program, you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SS incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SS program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated DI contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: www.njcleanenergy.com/ci

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Susan Danson	Township Administrator	susan.danson@waterfordtp.com	(856) 768-2300
Designated Representative			
Christopher D. Briglia	Municipal Engineer	cbrig@arh-us.com	(609) 561-0482 ext. 3119
TRC Energy Services			
Moussa Traore	Auditor	MTraore@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On April 17, 2018, TRC performed an energy audit at Municipal Building located in Atco, NJ. TRC’s team met with Joe Maltese to review the facility operations and help focus our investigation on specific energy-using systems.

Municipal Building is a 11,750 square-foot facility comprised municipal offices, police station with a holding cell, and court room in a single-story building. The building was constructed in 1977.

2.3 Building Occupancy

The building is open Monday through Friday. The typical schedule is presented in the table below. During a typical day, the facility is occupied by approximately 25 staff.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Municipal Building	Weekday	8:30 AM - 4:30 PM
Municipal Building	Weekend	Closed

2.4 Building Envelope

The building is constructed of concrete block, and structural steel with the northern portion of the building having a stucco façade and the southern portion having a brick façade. The building has a pitched standing seam metal roof with one flat section covered with a light-colored membrane. The building has framed windows and doors which appear to be in good condition.



Image 1: Building Envelope

2.5 On-Site Generation

The Municipal Building does not have any on-site electric generation capacity.

2.6 Energy-Using Systems

Please see **Appendix A: Equipment Inventory & Recommendations** for an inventory of the facility's equipment.

Lighting System

Lighting is provided mostly by linear 32-Watt fluorescent T8 lamps with electronic ballasts as well as some compact fluorescent lamps (CFL). Most of the fixtures are 2-lamp, 4-foot long recessed fixtures with prismatic lenses. A portion of the courtroom is lit with 60-watt incandescent lamps. Lighting is manually controlled with a wall switch in most spaces, except for two restrooms which have occupancy sensors. The building's exterior lighting is minimal and consists of metal halide (MH) fixtures controlled by photocells.



Image 2: Recessed Can Fixture



Image 3: Typical Linear Fluorescent

Hot Water Heating System



Image 4: Condensing Boiler

The heating hot water system consists of a single Weil-McLain 216 kBtu/hr output condensing boiler. The boiler has a nominal combustion efficiency of 94%. Hot water is provided to the water source heat pump in the mechanical room and the 19 water source heat pumps located throughout the facility via a 5 HP constant speed pump. The boiler appeared to be in good condition and well maintained.

Direct Expansion Air Conditioning System (DX)

There are nineteen 1-ton console (in-room) water-source heat pump units (WSHPs) and one 2.5-ton WSHP supplying heating and cooling to the building. Nineteen of the units are located throughout the building workspaces and the 2.5-ton unit is in the mechanical room. As needed, heat is added to the water loop by the boiler or removed with the cooling tower. All the WSHPs use direct-expansion (DX) coils.

The WSHPs utilize either scroll or rotary compressors depending on the model and size of the unit. Heating in the restrooms is provided by electric resistance baseboard heaters. The units are controlled by individual thermostats located in zones.



Image 5: 2.5-ton WSHP



Image 6: In-Room 1-ton WSHP

Domestic Hot Water Heating System

The domestic hot water heating system consists of a single A.O. Smith gas fired hot water heater with an input rating of 40 kBtu/hr. and a nominal efficiency of 80%. The water heater has a 40-gallon storage tank.



Image 7: Domestic Water Heater

Building Plug Load

There are roughly 32 computer work stations throughout the facility. There is no centralized PC power management software installed. Additional plug load is made up of typical office support equipment and break room appliances.

2.7 Water-Using Systems

There are 4 restrooms at this facility and a break room with faucets rated as low-flow.

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are several factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section in Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Municipal Building		
Fuel	Usage	Cost
Electricity	174,480 kWh	\$29,229
Natural Gas	2,210 Therms	\$2,501
Total		\$31,731

The current annual energy cost for this facility is \$32,811 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by Atlantic City Electric. The average electric cost over the past 12 months was \$0.168/kWh, which is the blended rate that includes energy supply, distribution, and other charges, including demand. This rate is used throughout the analyses in this report to assess energy costs and savings. Relatively constant electrical demand year-round, as seen across all months except December, is typical for WSHP systems. It is unclear what caused the electrical demand to drop by 30 kW in December. Additional investigation would be required to determine the cause of this anomaly. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Graph of Electric Usage & Demand




Figure 9 - Table of Electric Usage & Demand

Electric Billing Data for Municipal Building						
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost	TRC Estimated Usage?
7/18/16	33	20,880	72		\$2,483	No
8/15/16	28	21,680	73		\$3,736	No
9/16/16	32	22,240	70		\$3,999	No
10/18/16	32	12,720	73		\$2,233	No
11/14/16	27	10,320	73		\$1,797	No
12/15/16	31	11,600	40		\$2,007	No
1/17/17	33	15,440	73		\$2,665	No
2/14/17	28	12,560	69		\$2,168	Yes
3/15/17	29	11,760	73		\$2,039	No
4/18/17	34	13,200	73		\$2,293	No
5/16/17	28	9,920	73		\$1,730	No
6/15/17	30	12,160	73		\$2,081	No
Totals	365	174,480	72.8	\$0	\$29,229	
Annual	365	174,480	72.8	\$0	\$29,229	

3.3 Natural Gas Usage

Natural gas is provided by South Jersey Gas. The average gas cost for the past 12 months is \$1.132/therm, which is the blended rate used throughout the analyses in this report. The gas use profile is consistent with sites served by WSHP systems that utilize gas fired hot water boilers to add heat to the water during colder weather. The monthly gas consumption is shown in the chart below.

Figure 10 - Graph of Natural Gas Usage




Figure 11 - Table of Natural Gas Usage

Gas Billing Data for Municipal Building				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
7/18/16	34	15	\$47	No
8/14/16	27	12	\$40	Yes
9/16/16	33	9	\$41	No
10/18/16	32	13	\$56	Yes
11/14/16	27	111	\$132	No
12/15/16	31	372	\$386	No
1/17/17	33	596	\$609	No
2/14/17	28	442	\$455	No
3/15/17	29	345	\$362	No
4/18/17	34	256	\$281	No
5/16/17	28	39	\$65	No
6/15/17	30	6	\$35	No
Totals	366	2,216	\$2,508	2
Annual	365	2,210	\$2,501	

3.4 Benchmarking

This facility was benchmarked using *Portfolio Manager*, an online tool created and managed by the U.S. Environmental Protection Agency (EPA) through the ENERGY STAR™ program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR Score for select building types.

Energy Use Intensity is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy”. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Municipal Building	National Median Building Type: Municipal
Source Energy Use Intensity (kBtu/ft ²)	178.8	148.1
Site Energy Use Intensity (kBtu/ft ²)	69.5	67.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the Table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Municipal Building	National Median Building Type: Municipal
Source Energy Use Intensity (kBtu/ft ²)	134.3	148.1
Site Energy Use Intensity (kBtu/ft ²)	55.3	67.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR™ score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. Your building is one of the building categories that are eligible to receive a score. This facility has a current score of 32.

A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see

Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on Energy Star certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use Energy Star Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

To provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Municipal Building regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		29,533	6.7	0.0	\$4,947.48	\$22,665.86	\$3,050.00	\$19,615.86	4.0	29,740
ECM 1	Install LED Fixtures	9,572	1.5	0.0	\$1,603.54	\$10,156.03	\$1,000.00	\$9,156.03	5.7	9,639
ECM 2	Retrofit Fixtures with LED Lamps	19,961	5.2	0.0	\$3,343.93	\$12,509.82	\$2,050.00	\$10,459.82	3.1	20,101
Lighting Control Measures		4,044	1.0	0.0	\$677.48	\$8,076.00	\$945.00	\$7,131.00	10.5	4,072
ECM 3	Install Occupancy Sensor Lighting Controls	3,603	0.9	0.0	\$603.59	\$7,676.00	\$945.00	\$6,731.00	11.2	3,628
ECM 4	Install High/Low Lighting Controls	441	0.1	0.0	\$73.89	\$400.00	\$0.00	\$400.00	5.4	444
Motor Upgrades		132	0.0	0.0	\$22.05	\$1,229.49	\$0.00	\$1,229.49	55.8	133
ECM 5	Premium Efficiency Motors	132	0.0	0.0	\$22.05	\$1,229.49	\$0.00	\$1,229.49	55.8	133
Variable Frequency Drive (VFD) Measures		15,157	1.3	0.0	\$2,539.11	\$9,827.55	\$0.00	\$9,827.55	3.9	15,263
ECM 6	Install VFDs on Hot Water Pumps	10,180	1.3	0.0	\$1,705.45	\$6,551.70	\$0.00	\$6,551.70	3.8	10,252
ECM 7	Install VFDs on Cooling Tower Fans	4,976	0.0	0.0	\$833.67	\$3,275.85	\$0.00	\$3,275.85	3.9	5,011
TOTALS		48,866	9.0	0.0	\$8,186.12	\$41,798.90	\$3,995.00	\$37,803.90	4.6	49,207

* - All incentives presented in this table are based on N.J. Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Please see **Appendix A: Equipment Inventory & Recommendations** for a detailed list of the locations and recommended upgrades for each measure.

4.1.1 Lighting Upgrades

Recommended upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		29,533	6.7	0.0	\$4,947.48	\$22,665.86	\$3,050.00	\$19,615.86	4.0	29,740
ECM 1	Install LED Fixtures	9,572	1.5	0.0	\$1,603.54	\$10,156.03	\$1,000.00	\$9,156.03	5.7	9,639
ECM 2	Retrofit Fixtures with LED Lamps	19,961	5.2	0.0	\$3,343.93	\$12,509.82	\$2,050.00	\$10,459.82	3.1	20,101

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	9,572	1.5	0.0	\$1,603.54	\$10,156.03	\$1,000.00	\$9,156.03	5.7	9,639

Measure Description

We recommend replacing existing fixtures containing metal halide (MH) lamps with new high-performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which significantly more than that of MH lamps.

ECM 2: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	19,961	5.2	0.0	\$3,343.93	\$12,509.82	\$2,050.00	\$10,459.82	3.1	20,101
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing incandescent and linear fluorescent T8 lamps with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent.

4.1.2 Lighting Control Measures

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures	4,044	1.0	0.0	\$677.48	\$8,076.00	\$945.00	\$7,131.00	10.5	4,072
ECM 3 Install Occupancy Sensor Lighting Controls	3,603	0.9	0.0	\$603.59	\$7,676.00	\$945.00	\$6,731.00	11.2	3,628
ECM 4 Install High/Low Lighting Controls	441	0.1	0.0	\$73.89	\$400.00	\$0.00	\$400.00	5.4	444

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled. Please see **Appendix A: Equipment Inventory & Recommendations** for a detailed list of the locations and recommended lighting controls upgrades for each lighting measure.

ECM 3: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,603	0.9	0.0	\$603.59	\$7,676.00	\$945.00	\$6,731.00	11.2	3,628

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in restrooms, storage rooms, offices, court room, evidence room, corridors, and office areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 4: Install High/Low Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
441	0.1	0.0	\$73.89	\$400.00	\$0.00	\$400.00	5.4	444

Measure Description

We recommend installing occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons. Typical areas for such lighting control are stairwells, interior corridors, parking lots, and parking garages.

Lighting fixtures with these controls operate at default low levels when the area is not occupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. The lighting systems are switched to full lighting levels whenever an occupant is detected. Fixtures are automatically switched back to low level after an area has been vacant for a preset period. Energy savings results from only providing full lighting levels when it is required.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage needs to be provided to ensure that lights turn on in each area as an occupant approaches.

Additional savings from reduced lighting maintenance may also result from this measure, due to reduced lamp operation.

4.1.3 Motor Upgrades

ECM 5: Premium Efficiency Motors

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
132	0.0	0.0	\$22.05	\$1,229.49	\$0.00	\$1,229.49	55.8	133

Measure Description

We recommend replacing the standard efficiency motor running the cooling tower fan with IHP 2014 efficiency motors. Our evaluation assumes that the existing motor will be replaced with a motor of equivalent size and type. Although occasionally additional savings can be achieved by downsizing motors to better meet the motor’s current load requirements. The base case motor efficiency was estimated from nameplate information and our best estimates of motor run hours. Efficiencies of the proposed motor upgrade was obtained from the *New Jersey’s Clean Energy Program Protocols to Measure Resource Savings*. Savings are based on the difference between baseline and proposed efficiencies and the assumed annual operating hours.

4.1.4 Variable Frequency Drive Measures

Our recommendations for variable frequency drive (VFD) measures are summarized in Figure 18 below.

Figure 18 – Summary of Variable Frequency Drive ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		15,157	1.3	0.0	\$2,539.11	\$9,827.55	\$0.00	\$9,827.55	3.9	15,263
ECM 6	Install VFDs on Hot Water Pumps	10,180	1.3	0.0	\$1,705.45	\$6,551.70	\$0.00	\$6,551.70	3.8	10,252
ECM 7	Install VFDs on Cooling Tower Fans	4,976	0.0	0.0	\$833.67	\$3,275.85	\$0.00	\$3,275.85	3.9	5,011

ECM 6: Install VFDs on Hot Water Pumps

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
10,180	1.3	0.0	\$1,705.45	\$6,551.70	\$0.00	\$6,551.70	3.8	10,252

Measure Description

We recommend installing variable frequency drives (VFD) to control the hot water pumps. This measure requires that most of the WSHPs be served by 2-way valves and that a differential pressure sensor is installed in the hot water loop. As the hot water valves close, the differential pressure increases. The VFD modulates pump speed to maintain a differential pressure setpoint. Energy savings results from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

ECM 7: Install VFDs on Cooling Tower Fans

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
4,976	0.0	0.0	\$833.67	\$3,275.85	\$0.00	\$3,275.85	3.9	5,011

Measure Description

We recommend installing a variable frequency drives (VFD) to control the cooling tower fan motor. The VFD will allow the cooling tower fan to operate at the minimum speed necessary to maintain the temperature of the condenser water returning to the WSHPs. Energy savings results from reducing fan

speed (and power). The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Use Window Treatments/Coverings

A substantial amount of heat gain can occur through uncovered or untreated windows, especially older single pane windows and east or west-facing windows. Treatments such as high-reflectivity films or covering windows with shades or shutters can reduce solar heat gain and, consequently, cooling load and can reduce internal heat loss and the associated heating load.

Perform Regular Lighting Maintenance

To sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost-effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Perform Regular Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to retain proper functionality and efficiency of the heating system. Fuel burning equipment should undergo yearly tune-ups to ensure they are operating as safely and efficiently as possible from a combustion standpoint. A tune-up should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Buildup of dirt, dust, or deposits on the internal surfaces of a boiler can greatly affect its heat transfer efficiency. These deposits can accumulate on the water side or fire side of the boiler. Boilers should be cleaned regularly according to the manufacturer's instructions to remove this build up to sustain efficiency and equipment life.

Perform Regular Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to "Assessing and Reducing Plug and Process Loads in Office Buildings" <http://www.nrel.gov/docs/fy13osti/54175.pdf>, or "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot

water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before deciding to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a **Low** potential for installing a PV array.

To be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

Figure 19 - Photovoltaic Screening



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-fags>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility’s ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a **Low** potential for installing a cost-effective CHP system.

Lack of gas service, low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

Figure 20 - Combined Heat and Power Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically, an electric customer needs to can reduce their electric demand, within minutes, by at least 100 kW or more to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (www.pjm.com/markets-and-operations/demand-response/csps.aspx). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (www.pjm.com/training/trainingmaterial.aspx), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion, the facility is not a good candidate for DR curtailment.

8 PROJECT FUNDING / INCENTIVES

The NJCEP can provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 21 for a list of the eligible programs identified for each recommended ECM.

Figure 21 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	x		x			
ECM 2	Retrofit Fixtures with LED Lamps	x		x			
ECM 3	Install Occupancy Sensor Lighting Controls	x		x			
ECM 4	Install High/Low Lighting Controls			x			
ECM 5	Premium Efficiency Motors			x			
ECM 6	Install VFDs on Hot Water Pumps			x			
ECM 7	Install VFDs on Cooling Tower Fans			x			

SmartStart (SS) is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install (DI) caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SS program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the Retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one-year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to apply for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB

8.2 Direct Install

Overview

Direct Install (DI) is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for any recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to **70%** of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

How to Participate

To participate in the DI program, you will need to contact the participating contractor who the region of the state where your facility is located. A complete list of DI program partners is provided on the DI website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since DI offers a free assessment of eligible measures, DI is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract", whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO";
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations;
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by

the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third-party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility is purchasing electricity from a third-party supplier, review and compare prices at the end of the current contract or every couple of years.

A list of third-party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility is purchasing natural gas from a third-party supplier, review and compare prices at the end of the current contract or every couple of years.

A list of third-party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Elect Rm	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.04	172	0.0	\$28.75	\$117.00	\$20.00	3.37
Meeting Rm	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.03	100	0.0	\$16.82	\$58.50	\$10.00	2.88
Mech Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.11	402	0.0	\$67.27	\$234.00	\$40.00	2.88
PD Corridor	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	1,820	0.20	761	0.0	\$127.50	\$551.00	\$60.00	3.85
Various	9	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	9	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Lunch Rm	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.20	761	0.0	\$127.50	\$621.00	\$95.00	4.13
Locker Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.05	201	0.0	\$33.63	\$117.00	\$20.00	2.88
Restroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	None	33	8,760	Relamp	Yes	1	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,820	0.02	302	0.0	\$50.60	\$318.20	\$45.00	5.40
Holding Cell	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$75.00	5.05
PD Main Office	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.30	1,142	0.0	\$191.26	\$796.50	\$125.00	3.51
Storage	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$40.00	5.46
File Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.10	381	0.0	\$63.75	\$445.50	\$65.00	5.97
Office	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.27	1,015	0.0	\$170.00	\$738.00	\$115.00	3.66
Evidence Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$75.00	5.05
Common Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$75.00	5.05
Storage Rm	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.03	100	0.0	\$16.82	\$58.50	\$10.00	2.88
Chief Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,600	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	0.23	893	0.0	\$149.62	\$650.53	\$115.00	3.58
Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$75.00	5.05
Chief Office	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Town Hall Corridor	9	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	9	LED - Linear Tubes: (3) 4' Lamps	High/Low Control	44	1,820	0.45	1,712	0.0	\$286.88	\$876.80	\$135.00	2.59
Town Hall Corridor	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	2,600	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	2,600	0.01	53	0.0	\$8.92	\$35.90	\$5.00	3.46
Mens Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,600	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,600	0.08	301	0.0	\$50.45	\$175.50	\$30.00	2.88
Womens Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	2,600	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,600	0.08	301	0.0	\$50.45	\$175.50	\$30.00	2.88
Closet	1	Compact Fluorescent: Screw-in (14W) - 1L	Wall Switch	14	2,600	Relamp	No	1	LED Screw-In Lamps: (10W) - 1L	Wall Switch	10	2,600	0.00	13	0.0	\$2.14	\$53.75	\$0.00	25.11
Township Admin Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.20	761	0.0	\$127.50	\$570.80	\$95.00	3.73

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Meeting Rm	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.27	1,015	0.0	\$170.00	\$738.00	\$115.00	3.66
Meeting Rm	6	Incandescent- Screw-in (60W) - 1L	Wall Switch	60	2,600	Relamp	Yes	6	LED Screw-In Lamps: (9W) - 1L	Occupancy Sensor	9	1,820	0.26	980	0.0	\$164.20	\$592.52	\$65.00	3.21
Desk	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	49	0.0	\$8.15	\$48.20	\$10.00	4.68
Closet	1	Compact Fluorescent- Screw-in (14W) - 1L	Wall Switch	14	2,600	Relamp	No	1	LED Screw-In Lamps: (10W) - 1L	Wall Switch	10	2,600	0.00	13	0.0	\$2.14	\$53.75	\$0.00	25.11
Lunch Rm	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.05	201	0.0	\$33.63	\$117.00	\$20.00	2.88
File Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$75.00	5.05
Office	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.17	634	0.0	\$106.25	\$562.50	\$85.00	4.49
Clerks Office	15	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.50	1,903	0.0	\$318.76	\$1,147.50	\$185.00	3.02
Office	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.27	1,015	0.0	\$170.00	\$738.00	\$115.00	3.66
Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.20	761	0.0	\$127.50	\$621.00	\$95.00	4.13
Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$75.00	5.05
Taxation Office	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.30	1,142	0.0	\$191.26	\$796.50	\$125.00	3.51
Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.20	761	0.0	\$127.50	\$621.00	\$95.00	4.13
Office	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	2,600	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	2,600	0.01	53	0.0	\$8.92	\$35.90	\$5.00	3.46
Front Entrance	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.10	381	0.0	\$63.75	\$420.40	\$65.00	5.57
Front Entrance	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Parking lot	4	Metal Halide: (1) 400W Lamp	Daylight Dimming	458	4,380	Fixture Replacement	No	4	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Daylight Dimming	137	4,380	1.02	6,572	0.0	\$1,100.93	\$7,811.97	\$400.00	6.73
Wall Packs	6	Metal Halide: (1) 175W Lamp	Daylight Dimming	215	4,380	Fixture Replacement	No	6	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	65	4,380	0.72	4,628	0.0	\$775.22	\$2,344.06	\$600.00	2.25
Court Room	6	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	2,600	Relamp	Yes	6	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	1,820	0.10	399	0.0	\$66.81	\$485.40	\$65.00	6.29
Court Room	20	Incandescent- Screw-in (60W) - 1L	Wall Switch	60	2,600	Relamp	Yes	20	LED Screw-In Lamps: (9W) - 1L	Occupancy Sensor	9	1,820	0.85	3,267	0.0	\$547.32	\$1,615.06	\$170.00	2.64
Court Room	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Court Clerk Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.20	761	0.0	\$127.50	\$621.00	\$95.00	4.13
Court Clerk Office	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,600	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,600	0.04	151	0.0	\$25.23	\$75.20	\$15.00	2.39
Court Clerk Office	2	Incandescent- Screw-in (60W) - 1L	Wall Switch	60	2,600	Relamp	No	2	LED Screw-In Lamps: (9W) - 1L	Wall Switch	9	2,600	0.08	310	0.0	\$51.98	\$107.51	\$10.00	1.88
Court Clerk Office	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	49	0.0	\$8.15	\$48.20	\$10.00	4.68

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Back Entrance	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,600	0.03	100	0.0	\$16.82	\$58.50	\$10.00	2.88
Town Administration	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.17	634	0.0	\$106.25	\$562.50	\$85.00	4.49
Town Administration	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,600	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	507	0.0	\$85.00	\$504.00	\$75.00	5.05
Womens Restroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	33	2,600	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	2,600	0.01	49	0.0	\$8.15	\$48.20	\$10.00	4.68

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
exterior	Cooling Tower	1	Cooling Tower Fan	5.0	88.0%	No	2,745	Yes	89.5%	Yes	1	0.04	5,108	0.0	\$855.72	\$4,505.34	\$0.00	5.26
exterior	Cooling Tower	1	Other	0.5	70.0%	No	2,745	No	70.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rm	Condenser Water Pump 1	1	Condenser Water Pump	5.0	87.5%	No	2,745	No	87.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rm	Condenser Water Pump 2	1	Condenser Water Pump	5.0	87.5%	No	2,745	No	87.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rm	Heating Water	1	Heating Hot Water Pump	5.0	87.5%	No	2,745	No	87.5%	Yes	1	0.64	5,090	0.0	\$852.72	\$3,275.85	\$0.00	3.84
Mech Rm	Heating Water	1	Heating Hot Water Pump	5.0	87.5%	No	2,745	No	87.5%	Yes	1	0.64	5,090	0.0	\$852.72	\$3,275.85	\$0.00	3.84
Mech Rm	WSHP	1	Supply Fan	0.3	70.0%	No	2,745	No	70.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Various	Console WSHP	19	Supply Fan	0.0	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions									Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mech Rm	Building	1	Water Source HP	2.50	36.20	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Office	1	Split-System Air-Source HP	1.00	10.90	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Roof	Office	1	Split-System Air-Source HP	1.92	25.00	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom	Restrooms	4	Electric Resistance Heat		6.82	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Various	Offices, Open area, Copy room	19	Water Source HP	1.00	13.90	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions							Energy Impact & Financial Analysis								
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years		
Mech Rm	building	1	Condensing Hot Water Boiler	216.43	No								0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis									
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years			
Mech Rm	Building	1	Storage Tank Water Heater (≤ 50 Gal)	No									0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Offices	32	Desktop computer	270.0	
Break room	5	Refrigerator	600.0	
Various	6	TV	250.0	
Break room	3	Microwave	1,500.0	
Break room	2	Water Cooler	83.0	
Various	16	Printer	50.0	
Various	4	Copy Machine	1,500.0	
Break room	1	Coffee Machine	1,000.0	

Appendix B: ENERGY STAR® Statement of Energy Performance



ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

32

ENERGY STAR® Score¹

Waterford Township Municipal Building

Primary Property Type: Office
Gross Floor Area (ft²): 11,750
Built: 1977

For Year Ending: June 30, 2017
Date Generated: May 02, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address	Property Owner	Primary Contact
Waterford Township Municipal Building 2131 Auburn Avenue Atco, New Jersey 08004	Township of Waterford 2131 Auburn Avenue Atco, NJ 08004 856-768-2300	Susan Danson 2131 Auburn Avenue Atco, NJ 08004 856-768-2300 susan.danson@waterfordtwp.com

Property ID: 6320712

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
69.5 kBtu/ft²	Electric - Grid (kBtu) 595,326 (73%) Natural Gas (kBtu) 221,129 (27%)	National Median Site EUI (kBtu/ft²) 58 National Median Source EUI (kBtu/ft²) 149.4 % Diff from National Median Source EUI 20%
Source EUI	178.9 kBtu/ft²	Annual Emissions
		Greenhouse Gas Emissions (Metric Tons CO2e/year) 78

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional



Professional Engineer Stamp (if applicable)